



Wheelabrator North Broward, Inc.
2600 NW 48th Street
Pompano Beach, FL 33073

RECEIVED

APR 27 2010

**BUREAU OF
AIR REGULATION**

REPORT ON COMPLIANCE TESTING

Performed for:
**WHEELABRATOR NORTH BROWARD, INC.
ASH HANDLING SYSTEM, LIME SILO VENTS,
UNITS 1, 2 AND 3 SDA INLETS, FF OUTLETS AND STACKS
POMPANO BEACH, FL
VOLUME II OF II**

CleanAir Project No: 10955-2
Revision 0: April 23, 2010



Wheelabrator North Broward Inc.

A Waste Management Company

2600 Wiles Road
Pompano Beach, FL 33073
(954) 971-8701 Tel
(954) 971-8703 Fax

April 27, 2010

UPS# 1Z26X1500394865542

RECEIVED

APR 27 2010

**BUREAU OF
AIR REGULATION**

Mr. Lennon Anderson
Air Program Administrator
Florida Department of Environmental Protection
Southeast District
400 North Congress Ave., Suite 200
West Palm Beach, FL 33401

Re: Wheelabrator North Broward
2010 Annual Compliance Stack Test and RATA Reports

Dear Mr. Anderson:

Please find enclosed a copy of the final compliance stack test report and the continuous emissions monitoring system certification RATA report for testing conducted on March 16-18 of this year by Clean Air Engineering, Inc.

I, the undersigned, am a responsible official, as defined in Rule 62-210.200, F.A.C., of the Title V source addressed in this submittal. I hereby certify, based on information and belief formed after reasonable inquiry, that the statements and information in this document are true, accurate and complete.

If there are any questions, please contact this office at (954) 971-8701.

Sincerely,

Scott McIlvaine
Plant Manager

- cc: USEPA, Region IV, Pesticides and Toxics Management Division, Air & EPCRA Enforcement Branch, Air Enforcement Section (with) UPS# 1Z26X1500390744304
- FDEP, Tallahassee, Bureau of Air Regulation, New Source Review Section, (with) UPS# 1Z26X1500394730124
- Broward County Department of Planning and Environmental Protection, Air Quality Division (with) UPS# 1Z26X1500393811511

- Chuck Faller (with)
- Ram Tewari – BCWRS (without)
- Tim Porter (without)
- Rob French – MPI (with) UPS# 1Z26X1500392976131



WHEELABRATOR NORTH BROWARD, INC.
POMPANO BEACH, FL

CleanAir Project No: 10955-2

FIELD DATA

G

This Page Intentionally Left Blank

TEST LOCATION:

FF-Outlet

Particulate / Metals TESTING

METHOD:

5/29

PAGE

1

OF

2

UNIT:

1

RUN:

1

FIELD DATA SHEET

Cross-Section of Test Location



Duct Dimensions (in.) 96x96

Static Pres (in. H₂O) -10.0
Port Len. (in.) 10.0
Gas Flow (In) Out of page (In) Out all the way

Client	Wheeler	Project No.	10911
Plant	N. Broward	Date	3/16/10
Meter Operator	P. Bihun		
Probe Operator	P. Bihun		

Meter Box	661-66	Sample Box No.	M11
Meter Y _d	0.9900	Meter ΔH	1.6820
K Factor	233 2.20 m	Pitot C _p	0.805
Leak Rate Before	0.002 (cfm)	[Lpm]	@ 15 (in. Hg)
Leak Rate After	0.002 (cfm)	[Lpm]	@ 8 (in. Hg)
Pitot Leak Check Before:	<input checked="" type="checkbox"/>	After:	Good <input checked="" type="checkbox"/> Bad <input type="checkbox"/>

Amb. Temp. (°F)	60	Bar. Press.	30.09 (in. Hg) [mbar]
Probe I.D. No.	67-4-4		
Liner Material	Glass		

Filter No.	F-15-35		
Thimble No.	1014		
Nozzle Diameter	0.270	Nozzle I.D.	2704

Start Time: 7:21 Stop Time: 9:32

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. (ft ³) [L]	Stack Temp. T _s (°F)	Probe T _p (°F)	Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{min} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T _{trap} (°F)	Notes
						Set Points							
1-1	5	0.43	0.90	76.485	292	245	252	49	59	57	2.5	0.25	9.8
2	10	0.51	1.1	82.20	293	249	251	46	61	57	2.5	0.25	9.3
3	15	0.57	1.3	85.41	293	255	250	46	64	58	3.0	0.25	10.4
4	20	0.64	1.4	88.79	294	252	252	47	65	58	3.0	0.25	10.3
5	25	0.64	1.4	92.180	294	250	250	48	66	58	3.0	0.25	10.4
27	30	0.57	1.3	95.51	293	245	250	49	66	59	3.0	0.25	10.0
2	35	0.52	1.2	98.59	294	246	249	48	67	60	3.0	0.25	10.0
3	40	0.52	1.2	101.69	294	254	250	48	68	60	3.0	0.25	9.7
4	45	0.68	1.5	105.20	294	253	252	48	69	61	3.5	0.25	10.3
5	50	0.60	1.3	108.455	294	250	250	49	70	61	3.0	0.25	10.0
37	55	0.63	1.4	111.87	294	246	251	50	68	61	3.0	0.25	9.5
0	60	0.53	1.2	115.04	293	246	250	51	69	61	3.0	0.25	10.8
Total	*			80.240									
Average		0.7507	1.2680		293.280				64.3800				

Sum of square roots

Circle correct bracketed units on data sheet.

1503

G-3

TEST LOCATION: FF Outlet

UNIT: 1

RUN: 1

Particulate Matter TESTING FIELD DATA SHEET

METHOD: 5129 PAGE 2 OF 2

Client <u>Wheelabrator</u>	Project No. <u>10955</u>
Plant <u>N. Broward</u>	Date <u>3/16/10</u>
Meter Operator <u>P. Bikua</u>	
Probe Operator <u>P. Bikua</u>	

Meter Box	Sample Box No.
Meter Y _d	Meter ΔH _@
K Factor	Pitot C _p

Leak Rate Before	[cfm] [Lpm]	@	(in. Hg)
Leak Rate After	[cfm] [Lpm]	@	(in. Hg)
Pitot Leak Check Before:	<input type="checkbox"/> After: Good	<input type="checkbox"/> Bad	<input type="checkbox"/>

Cross-Section of Test Location

↑
[N] [UP]

Duct Dimensions (in.)

Static Pres (in. H ₂ O)	Port Len. (in.)	Gas Flow [In] [Out] of page	First point all the way [In] [Out]
------------------------------------	-----------------	-----------------------------	------------------------------------

Amb. Temp. (°F)	Bar. Press. [in. Hg] [mbar]
Probe I.D. No.	
Liner Material	

Filter No.	
Thimble No.	
Nozzle Diameter	Nozzle I.D.

Start Time:	Stop Time:
-------------	------------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. (ft ³) [L]	Stack Temp. T _s (°F)	Probe T _p (°F)	Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{m in} (°F)	DGM Outlet T _{m out} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T _t (°F)	Notes
						Set Points							
						<u>210</u>	<u>20</u>						
7	65	0.55	1.3	115.30	294	254	249	52	68	61	3.0	0.25	10.3
7	70	0.62	1.5	121.80	294	252	257	52	69	61	3.5	0.25	10.2
7	75	0.68	1.5	125.290	293	200	257	54	69	62	3.5	0.25	10.5 (24370)
4-1	80	0.61	1.4	128.67	294	248	250	55	69	62	3.5	0.25	10.5 (2006)
2	85	0.46	1.0	131.71	294	245	257	55	70	62	3.0	0.25	10.4
3	90	0.42	0.94	134.51	293	254	250	55	70	62	3.0	0.25	10.5
4	95	0.61	1.4	137.89	295	257	250	50	69	62	3.5	0.25	10.4 (141.45)
5	100	0.68	1.5	141.415	294	250	249	57	70	63	3.5	0.25	10.7 (2004)
5-1	105	0.45	1.0	144.35	291	248	250	48	69	63	3.0	0.25	10.4
2	110	0.45	1.0	147.23	292	250	251	60	70	63	3.0	0.25	10.6
3	115	0.47	1.1	150.20	290	250	249	59	71	63	3.0	0.25	10.6
4	120	0.58	1.3	153.50	292	251	252	60	71	63	3.5	0.25	10.1
5	125	0.69	1.5	156.945	294	250	251	61	71	63	3.5	0.25	10.7
	Total												
	Average												

Sum of square roots. 14.49

Circle correct bracketed units on data sheet.

1710

QA/QC AB
Date 3/16/10

TEST LOCATION: FF outlet

UNIT: 1

RUN: 2

Particulate/Metals TESTING FIELD DATA SHEET

METHOD: 5/29 PAGE 1 OF 2

Client <u>Wheelabrator</u>	Project No. <u>1095E</u>
Plant <u>N. Broward</u>	Date <u>3/16/10</u>
Meter Operator <u>P. Bihun</u>	
Probe Operator <u>P. Bihun</u>	

Meter Box <u>6el-6</u>	Sample Box No. <u>M10</u>
Meter Yd <u>12.900</u>	Meter ΔH@ <u>1.4820</u>
K Factor <u>2.23</u>	Pitot Cp <u>0.808</u>
Leak Rate Before <u>0.003 (in)</u> [Lpm] @ <u>15</u> (in. Hg)	
Leak Rate After <u>0.002 (in)</u> [Lpm] @ <u>8</u> (in. Hg)	
Pitot Leak Check Before: <input checked="" type="checkbox"/> After: Good <input checked="" type="checkbox"/> Bad <input type="checkbox"/>	

Cross-Section of Test Location

Duct Dimensions (in.) 96x96

Static Pres (in. H ₂ O) <u>10.0</u>	Port Len. (in.) <u>10.0</u>	Gas Flow (in) [Out] of page <u>(in) [Out]</u>	First point all the way <u>(in) [Out]</u>
--	-----------------------------	---	---

Amb. Temp. (°F)	Bar. Press. <u>30.01</u> (in. Hg) [mbar]
Probe I.D. No. <u>62-F-4</u>	
Liner Material <u>Glass</u>	

Filter No. <u>E-115-36</u>	
Thimble No. <u>N 10A</u>	
Nozzle Diameter <u>0.270</u>	Nozzle I.D. <u>2704</u>

Start Time: <u>10:00</u>	Stop Time: <u>12:14</u>
--------------------------	-------------------------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m (in) ³ [L]	Stack Temp. Ts (°F)	Probe T _p (°F)		Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{out} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T ₁ (°F)	Notes
						Set Points	Set Points						
1-1	5	0.58	1.3	157.285	293	247	250	57	63	62	4.0	0.20	10.7
2	10	0.57	1.4	163.96	295	254	252	54	65	62	3.5	0.20	10.5 K=2.36
3	15	0.61	1.4	147.33	295	252	255	52	68	63	4.0	0.20	10.6
4	20	0.72	1.7	171.06	295	253	251	51	68	62	4.5	0.20	10.6
5	25	0.68	1.6	174.690	295	250	250	53	70	63	4.0	0.20	10.3 174.742
2-1	30	0.49	1.1	177.66	292	247	250	56	70	64	3.0	0.20	10.7 (-0.9)
2	35	0.54	1.2	180.80	293	247	250	57	72	64	3.5	0.20	10.9
3	40	0.61	1.4	184.17	294	253	246	56	72	65	3.5	0.20	9.8
4	45	0.67	1.5	187.68	295	252	250	56	74	65	4.0	0.20	10.7
5	50	0.65	1.5	191.210	294	250	249	57	74	66	4.0	0.20	11.0 191.265
3-1	55	0.56	1.3	194.50	293	246	250	57	73	66	3.5	0.20	10.8 (-0.95)
2	60	0.45	1.0	197.39	295	250	251	58	74	66	3.0	0.20	9.1
Total	*			81.500									
Average		0.749	1.3032	16.4	295.0400				68.7000	66.4			

Sum of square roots

Circle correct bracketed units on data sheet.

QA/QC PB
Date 3/16/10



G-5

TEST LOCATION: PF outlet

UNIT: 1

RUN: 2

Particulate / Metals TESTING
FIELD DATA SHEET

METHOD: 5729 PAGE 2 OF 2

Client <u>W. K. Lebra</u>	Project No. <u>10291T</u>
Plant <u>N. Broward</u>	Date <u>3/16/10</u>
Meter Operator <u>P. Bihun</u>	
Probe Operator <u>P. Bihun</u>	

Meter Box	Sample Box No.
Meter Y _d	Meter ΔH _@
K Factor	Pitot C _p
Leak Rate Before [cfm] [Lpm] @ (in. Hg)	
Leak Rate After [cfm] [Lpm] @ (in. Hg)	
Pitot Leak Check Before: <input type="checkbox"/> After: Good <input type="checkbox"/> Bad <input type="checkbox"/>	

Cross-Section of Test Location

↑
[N] [UP]

Duct Dimensions (in.)

Static Pres (in. H ₂ O)	Port Len. (in.)	Gas Flow [In] [Out] of page	First point all the way [In] [Out]
------------------------------------	-----------------	-----------------------------	------------------------------------

Amb. Temp. (°F)	Bar. Press. [in. Hg] [mbar]
Probe I.D. No.	
Liner Material	

Filter No.	
Thimble No.	
Nozzle Diameter	Nozzle I.D.

Start Time:	Stop Time:
-------------	------------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. (ft ³) [L]	Stack Temp. T _s (°F)	Probe T _p (°F)	Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{min} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T _t (°F)	Notes
						Set Points							
						280	250						O ₂
7	65	0.50	1.3	200.64	295	254	250	60	74	66	3.5	0.20	19.0
4	70	0.60	1.4	203.29	295	251	250	58	74	66	4.0	0.20	10.3
5	75	0.63	1.5	207.535	294	251	248	59	75	67	4.0	0.20	10.6
4-1	80	0.53	1.2	210.74	292	248	251	59	73	66	3.5	0.20	11.1 (2.045)
2	85	0.50	1.2	213.87	295	247	250	60	73	66	3.5	0.20	10.5
3	90	0.55	1.3	217.16	296	254	249	61	73	66	4.0	0.20	10.5
4	95	0.57	1.3	220.43	296	253	250	61	74	66	4.0	0.20	10.5
5	100	0.62	1.4	223.870	297	250	250	62	75	67	4.0	0.20	10.6 223.915
5-1	105	0.45	1.0	226.76	297	250	249	63	73	67	3.5	0.20	10.7 (2.045)
2	110	0.43	0.99	229.64	297	245	250	64	73	67	3.5	0.20	9.9
3	115	0.40	0.92	232.41	296	250	250	64	74	67	3.5	0.20	10.8
4	120	0.42	0.97	235.26	297	251	249	63	74	67	3.5	0.20	10.9
5	125	0.72	1.7	238.980	300	251	250	63	74	67	4.5	0.20	10.6
	Total												
	Average												

* Sum of square roots.

Circle correct bracketed units on data sheet.

QA/QC 113
Date 3/16/10

1024

TEST LOCATION: FF Outlet

UNIT: 1

RUN: 3

TESTING FIELD DATA SHEET

METHOD: 5129 PAGE 1 OF 2

Client <u>Wheelabrator</u>	Project No. <u>10955</u>
Plant <u>N. Broward</u>	Date <u>3/16/10</u>
Meter Operator <u>P. Bihun</u>	
Probe Operator <u>P. Bihun</u>	

Meter Box <u>64-6</u>	Sample Box No. <u>1115</u>
Meter Yd <u>09900</u>	Meter ΔH@ <u>1.6520</u>
K Factor <u>2.30</u>	Pitot Cp <u>0.805</u>
Leak Rate Before <u>0.004</u> [Lpm] @ <u>15</u> (in. Hg)	
Leak Rate After <u>0.003</u> [Lpm] @ <u>8</u> (in. Hg)	
Pitot Leak Check Before: <input checked="" type="checkbox"/> A After: Good <input checked="" type="checkbox"/> Bad <input type="checkbox"/>	

Cross-Section of Test Location

Duct Dimensions (in.) 9x9

Static Pres (in. H ₂ O) <u>-10.1</u>	Port Len. (in.) <u>10.0</u>	Gas Flow (in) [Out] of page <u>9x9</u>	First point all the way (in) [Out] <u>9x9</u>
---	-----------------------------	--	---

Amb. Temp. (°F) <u>68</u>	Bar. Press. <u>30.01</u> (in. Hg) (mbar)
Probe I.D. No. <u>67-8-4</u>	
Liner Material <u>Galss</u>	

Filter No. <u>E-115-77</u>	
Thimble No. <u>N/A</u>	
Nozzle Diameter <u>0.270</u>	Nozzle I.D. <u>270-1</u>

Start Time: 12:36 Stop Time: 14:47

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. (ft ³) [L]	Stack Temp. T _s (°F)	Probe T _p (°F)	Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{max} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T _t (°F)	Notes	
						Set Points								
1-1	5	0.45	1.0	239.315	300	247	250	54	70	68	2.5	0.20	10.5	
2	10	0.54	1.2	245.42	301	251	253	48	71	68	3.0	0.20	10.7	
3	15	0.57	1.3	245.75	302	257	252	45	73	68	3.0	0.20	10.5	
4	20	0.63	1.5	242.34	302	257	249	45	75	69	3.5	0.20	10.5	
5	25	0.60	1.4	251.770	301	249	249	46	77	69	3.5	0.20	11.0	
2-1	30	0.54	1.2	258.58	299	248	250	48	76	69	3.0	0.20	10.8 (-0.04)	
2	35	0.47	1.1	261.95	301	248	251	48	77	70	3.0	0.20	10.8	
3	40	0.60	1.4	265.37	302	254	250	49	78	70	3.0	0.20	11.1	
4	45	0.80	1.8	264.23	303	251	250	49	79	71	3.5	0.20	11.2	
5	50	0.65	1.5	272.785	302	249	249	49	80	71	3.5	0.20	10.7	
3-1	55	0.66	1.5	276.37	299	247	249	51	78	71	3.5	0.20	10.6 (-0.04)	
2	60	0.56	1.3	279.67	301	245	251	52	79	71	3.5	0.20	11.0	
Total														
Average														

Sum of square roots.

Circle correct bracketed units on data sheet.

G-7



TEST LOCATION: rr outlet

UNIT: 1

RUN: 3

Particulate/Metals TESTING
FIELD DATA SHEET


METHOD: 5129 PAGE 2 OF 2

Client <u>Whitaker</u>	Project No. <u>10951</u>
Plant <u>N. Blvd</u>	Date <u>3/16/10</u>
Meter Operator <u>P. Bihun</u>	
Probe Operator <u>P. Bihun</u>	

Meter Box	Sample Box No.
Meter Y _d	Meter ΔH _@
K Factor	Pitot C _p

Leak Rate Before	[cfm] [Lpm]	@	(in. Hg)
Leak Rate After	[cfm] [Lpm]	@	(in. Hg)

Pitot Leak Check Before: After: Good Bad



Amb. Temp. (°F)	Bar. Press. [in. Hg] [mbar]
Probe I.D. No.	
Liner Material	

Filter No.	
Thimble No.	
Nozzle Diameter	Nozzle I.D.

Start Time: _____ Stop Time: _____

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. (ft ³)	Stack Temp. T _s (°F)	Probe T _p (°F)		Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{max} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T ₁ (°F)	Notes
						200	250							
3	65	0.65	1.6	253.29	302	250	253	53	79	71	3.5	0.20	10.8	
4	70	0.66	1.5	286.80	303	254	250	53	80	72	3.5	0.20	9.8	
5	75	0.70	1.6	290.430	302	249	249	55	80	72	3.5	0.20	10.6	
4-1	80	0.60	1.4	293.85	300	247	247	57	80	73	3.5	0.20	11.1	
2	85	0.47	1.1	296.82	300	244	252	57	81	73	3.0	0.20	10.9	
3	90	0.50	1.2	300.04	302	255	250	57	81	73	3.0	0.20	11.1	
4	95	0.67	1.5	303.58	302	254	250	57	82	73	3.5	0.20	11.3	
5	100	0.69	1.6	307.280	301	250	249	58	83	74	4.0	0.20	11.0	
5-1	105	0.41	1.0	310.26	301	250	247	60	82	74	3.0	0.20	9.8	
2	110	0.42	0.97	313.09	299	249	251	61	82	75	3.0	0.20	11.0	
3	115	0.35	0.81	315.69	297	251	251	62	82	75	3.0	0.20	10.5	
4	120	0.43	0.99	318.58	299	252	249	63	82	75	3.0	0.20	11.3	
5	125	0.75	1.7	322.380	299	251	250	64	82	75	4.0	0.20	11.0	
Total														
Average														

Sum of square roots. 14.97

Circle correct bracketed units on data sheet.

QA/QC PR
Date 3/16/10



Impinger Weight Sheet

Client Wheelabrator		Unit Name/Location Unit 1 FF Outlet	
Plant North Broward	Job No. 10955	Method	5/29

Run No. 1	Filter Type Quartz	Sample Box No. M15
Date 3/16/10	Lot No. 56079	pH
Analyst B. Wilke	Filter No. E115-35	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty	734.9	459.3	275.6	
Impinger 2	100 ml 5%HNO3/10%H2O2	655.2	544.3	110.9	QA/QC <i>BW</i> Date 3/16
Impinger 3	100 ml 5%HNO3/10%H2O2	569.3	547.7	21.6	
Impinger 4	Empty	442.7	437.8	4.9	
Impinger 5	100 ml 4%KMnO4/10%H2SO4	543.8	542.6	1.2	Total Weight (gm)
Impinger 6	100 ml 4%KMnO4/10%H2SO4	559.3	560.2	-0.9	413.3
Impinger 7	Silica Gel	725.3	707.1	18.2	431.5

Run No. 2	Filter Type Quartz	Sample Box No. M10
Date 3/16/10	Lot No. 56079	pH
Analyst B. Wilke	Filter No. E115-36	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty	687.1	437.6	249.5	
Impinger 2	100 ml 5%HNO3/10%H2O2	673.8	555.1	118.7	QA/QC <i>BW</i> Date 3/16
Impinger 3	100 ml 5%HNO3/10%H2O2	571.0	534.3	36.7	
Impinger 4	Empty	451.7	445.5	6.2	
Impinger 5	100 ml 4%KMnO4/10%H2SO4	545.3	543.2	2.1	Total Weight (gm)
Impinger 6	100 ml 4%KMnO4/10%H2SO4	538.7	538.6	0.1	413.3
Impinger 7	Silica Gel	739.3	720.4	18.9	432.2

Run No. 3	Filter Type Quartz	Sample Box No. M15
Date 3/16/10	Lot No. 56079	pH
Analyst B. Wilke	Filter No. E-115-37	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty	746.2	461.6	284.6	
Impinger 2	100 ml 5%HNO3/10%H2O2	645.1	541.8	103.3	QA/QC <i>BW</i> Date 3/16
Impinger 3	100 ml 5%HNO3/10%H2O2	569.4	550.8	18.6	
Impinger 4	Empty	442.4	439.5	2.9	
Impinger 5	100 ml 4%KMnO4/10%H2SO4	542.9	541.5	1.4	Total Weight (gm)
Impinger 6	100 ml 4%KMnO4/10%H2SO4	559.9	559.9	0.0	53 411.3 410.8
Impinger 7	Silica Gel	735.7	721.5	14.2	52 425.5 425.0



TEST LOCATION: FF outlet
 UNIT: 1 RUN: 1

Fluoride TESTING
FIELD DATA SHEET

METHOD: 13B PAGE 1 OF 2

Client <u>wheelabrator</u>	Project No. <u>10955</u>
Plant <u>N. Broward</u>	Date <u>3-17-10</u>
Meter Operator <u>A. Obuchowski</u>	
Probe Operator <u>B. ARNOLD</u>	

Meter Box <u>61-6</u>	Sample Box No.
Meter Y _d <u>0.9900</u>	Meter ΔH _@ <u>1.6E20</u>
K Factor <u>2.3</u>	Pitot C _p <u>0.812</u>
Leak Rate Before <u>0.002</u> [cfm] [Lpm] @ <u>15</u> (in. Hg)	
Leak Rate After <u>0.001</u> [cfm] [Lpm] @ <u>22</u> (in. Hg)	
Pitot Leak Check Before: <input checked="" type="checkbox"/> After: Good <input checked="" type="checkbox"/> Bad <input type="checkbox"/>	

Cross-Section of Test Location

↑
 [UP]
 5

Duct Dimensions (in.) 96 x 96

Static Pres (in. H ₂ O) <u>-10.3</u>	Port Len. (in.) <u>10</u>	Gas Flow <u>[UP]</u> [Out] of page	First point all the way <u>[UP]</u> [Out]
---	---------------------------	------------------------------------	---

Amb. Temp. (°F) <u>70</u>	Bar. Press. <u>30.0</u> [in. Hg] [mbar]
Probe I.D. No. <u>67-E-14</u>	
Liner Material <u>glass</u>	

Filter No. <u>-</u>		
Thimble No. <u>-</u>		
Nozzle Diameter <u>0.6E</u>	Nozzle I.D. <u>26E-1</u>	

Start Time: <u>11:46</u>	Stop Time: <u>12:56</u>
--------------------------	-------------------------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. [L]	Stack Temp. T _s (°F)	Probe T _p (°F)		Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{out} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. O ₂ T ₁ % (°F)	Notes
						Set Points	Set Points							
	<u>2.5</u>			<u>323.725</u>		<u>250</u>	<u>250</u>							<u>02</u>
<u>5-1</u>	<u>2.5</u>	<u>0.54</u>	<u>1.2</u>	<u>325.33</u>	<u>304</u>	<u>250</u>	<u>249</u>	<u>62</u>	<u>62</u>	<u>61</u>	<u>2</u>	<u>0.30</u>	<u>11.0</u>	
<u>-2</u>	<u>5</u>	<u>0.56</u>	<u>1.3</u>	<u>326.99</u>	<u>301</u>	<u>255</u>	<u>251</u>	<u>58</u>	<u>63</u>	<u>61</u>	<u>3</u>	<u>0.30</u>	<u>10.9</u>	
<u>-7</u>	<u>7.5</u>	<u>0.63</u>	<u>1.4</u>	<u>328.64</u>	<u>302</u>	<u>255</u>	<u>252</u>	<u>56</u>	<u>65</u>	<u>62</u>	<u>3</u>	<u>0.30</u>	<u>10.9</u>	
<u>-4</u>	<u>10</u>	<u>0.75</u>	<u>1.7</u>	<u>330.51</u>	<u>304</u>	<u>256</u>	<u>250</u>	<u>54</u>	<u>66</u>	<u>61</u>	<u>3</u>	<u>0.30</u>	<u>10.4</u>	
<u>-5</u>	<u>12.5</u>	<u>0.79</u>	<u>1.8</u>	<u>332.41</u>	<u>304</u>	<u>255</u>	<u>253</u>	<u>54</u>	<u>68</u>	<u>62</u>	<u>3</u>	<u>0.30</u>	<u>10.2</u>	<u>332.41</u>
<u>4-1</u>	<u>15</u>	<u>0.69</u>	<u>1.6</u>	<u>334.28</u>	<u>301</u>	<u>250</u>	<u>256</u>	<u>56</u>	<u>68</u>	<u>62</u>	<u>3</u>	<u>0.30</u>	<u>10.9</u>	<u>-0.7</u>
<u>-2</u>	<u>17.5</u>	<u>0.56</u>	<u>1.3</u>	<u>335.96</u>	<u>304</u>	<u>248</u>	<u>250</u>	<u>57</u>	<u>70</u>	<u>63</u>	<u>3</u>	<u>0.30</u>	<u>8.9</u>	
<u>-3</u>	<u>20</u>	<u>0.66</u>	<u>1.5</u>	<u>337.64</u>	<u>303</u>	<u>249</u>	<u>248</u>	<u>59</u>	<u>71</u>	<u>63</u>	<u>3</u>	<u>0.30</u>	<u>10.6</u>	
<u>-4</u>	<u>22.5</u>	<u>0.78</u>	<u>1.8</u>	<u>339.55</u>	<u>303</u>	<u>250</u>	<u>248</u>	<u>60</u>	<u>73</u>	<u>64</u>	<u>3</u>	<u>0.30</u>	<u>10.3</u>	<u>341.51</u>
<u>-5</u>	<u>25</u>	<u>0.76</u>	<u>1.7</u>	<u>341.45</u>	<u>304</u>	<u>250</u>	<u>249</u>	<u>61</u>	<u>74</u>	<u>64</u>	<u>3</u>	<u>0.30</u>	<u>10.4</u>	
<u>3-1</u>	<u>27.5</u>	<u>0.59</u>	<u>1.4</u>	<u>343.18</u>	<u>300</u>	<u>250</u>	<u>253</u>	<u>62</u>	<u>74</u>	<u>64</u>	<u>3</u>	<u>0.30</u>	<u>10.8</u>	<u>-0.05</u>
<u>-2</u>	<u>30</u>	<u>0.57</u>	<u>1.3</u>	<u>344.82</u>	<u>304</u>	<u>249</u>	<u>249</u>	<u>62</u>	<u>76</u>	<u>65</u>	<u>3</u>	<u>0.30</u>	<u>10.0</u>	
<u>-3</u>	<u>32.5</u>	<u>0.65</u>	<u>1.5</u>	<u>346.46</u>	<u>304</u>	<u>250</u>	<u>248</u>	<u>63</u>	<u>76</u>	<u>65</u>	<u>3</u>	<u>0.30</u>	<u>10.1</u>	
	Total	<u>19.8383</u>	<u>36.40</u>	<u>12.9350</u>	<u>7565</u>				<u>1601</u>	<u>1546</u>				
	Average	<u>0.7935</u>	<u>1.4560</u>		<u>302.60</u>				<u>66.490</u>	<u>68.28</u>				

Sum of square roots.

Circle correct bracketed units on data sheet.

QA/QC 0
 Date 3-17-10


G-10

TEST LOCATION: FF outlet
 UNIT: 1 RUN: 1

Fluoride TESTING
FIELD DATA SHEET

METHOD: 13B PAGE 2 OF 2

Client <u>Wheelabrator</u>	Project No. <u>10455</u>
Plant <u>N. Broward</u>	Date <u>3-17-10</u>
Meter Operator <u>A. Obuchowski</u>	
Probe Operator <u>B. Arnold</u>	



Amb. Temp. (°F)	Bar. Press. [in. Hg] [mbar]
Probe I.D. No.	
Liner Material	

Meter Box	Sample Box No.
Meter Y _d	Meter ΔH _@
K Factor	Pitot C _p
Leak Rate Before [cfm] [Lpm] @ (in. Hg)	
Leak Rate After [cfm] [Lpm] @ (in. Hg)	
Pitot Leak Check Before: <input type="checkbox"/>	After: Good <input type="checkbox"/> Bad <input type="checkbox"/>

Filter No.	
Thimble No.	
Nozzle Diameter	Nozzle I.D.

Start Time:	Stop Time:
-------------	------------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. [ft ³] [L]	Stack Temp. T _s (°F)	Probe T _p (°F)	Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{m in} (°F)	DGM Outlet T _{m out} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T _t (°F)	Notes
						Set Points							
-4	35	0.72	1.7	348.31	303	251	250	62	76	65	3	0.30	10.3
-5	37.5	0.69	1.6	350.15	303	250	250	61	76	66	3	0.30	9.9
2-1	40	0.64	1.5	351.99	303	248	249	57	73	66	3	0.30	10.5
-2	42.5	0.50	1.2	353.57	302	248	250	54	74	66	3	0.30	10.0
-3	45	0.46	1.1	355.07	301	250	249	53	74	66	3	0.30	10.6
-4	47.5	0.60	1.4	356.80	302	250	252	52	74	66	3	0.30	10.2
-5	50	0.70	1.6	358.55	303	250	250	52	75	66	3	0.30	10.7
1-1	52.5	0.51	1.2	360.19	300	247	249	51	73	67	3	0.30	10.7
-2	55	0.54	1.2	361.77	303	250	252	49	74	67	3	0.30	10.9
-3	57.5	0.54	1.2	363.37	302	252	251	48	75	67	3	0.30	10.2
-4	60	0.63	1.4	365.04	302	251	250	48	75	67	3	0.30	10.9
-5	62.5	0.77	1.8	366.97	303	251	251	48	76	67	3	0.30	10.5
	Total	*											
	Average												

350.26
0.11
358.63
10.8

* Sum of square roots. Circle correct bracketed units on data sheet.



QA/QC SB
 Date 3/17

G-11

TEST LOCATION: FF outlet
 UNIT: 21 RUN: 2


Fluoride TESTING
 FIELD DATA SHEET

METHOD: 13B PAGE 1 OF 2

Client <u>wheelabrator</u>	Project No. <u>6055</u>
Plant <u>N. Broward</u>	Date <u>3-17-10</u>
Meter Operator <u>A. Obuchowski</u>	
Probe Operator <u>B. ARNOLD</u>	

Meter Box <u>61-6</u>	Sample Box No. <u>B7</u>
Meter Y _d <u>0.9900</u>	Meter ΔH _@ <u>1.6E20</u>
K Factor <u>2.7</u>	Pitot C _p <u>0.ER</u>

Leak Rate Before <u>0.002</u> [cfm] [Lpm] @ <u>15</u> (in. Hg)
Leak Rate After <u>0.002</u> [cfm] [Lpm] @ <u>15</u> (in. Hg)
Pitot Leak Check Before: <input type="checkbox"/> After: Good <input checked="" type="checkbox"/> Bad <input type="checkbox"/>



Duct Dimensions (in.) <u>96x96</u>			
Static Pres (in. H ₂ O) <u>-10.4</u>	Port Len. (in.) <u>10</u>	Gas Flow (in) [Out] of page <u>4</u>	First point all the way [6] [Out]

Amb. Temp. (°F) <u>70</u>	Bar. Press. <u>30.0</u> [in. Hg] [mbar]
Probe I.D. No. <u>67-E-14</u>	
Liner Material <u>316S</u>	

Filter No. <u>-</u>		
Thimble No. <u>-</u>		
Nozzle Diameter <u>0.28E</u>	Nozzle I.D. <u>26E-1</u>	

Start Time: <u>13:15</u>	Stop Time: <u>14:27</u>
--------------------------	-------------------------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. [ft ³] [L]	Stack Temp. T _s (°F)	Probe T _p (°F)		Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{out} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T ₁ (°F)	Notes
						250	256							
1-1	2.5	0.54	1.24	<u>367.345</u>	299	261	249	54	68	66	3.0	0.3	11.3	
2	5	0.53	1.2	<u>370.49</u>	300	259	251	53	70	66	2.5		11.4	
3	7.5	0.51	1.2	<u>372.04</u>	300	256	251	51	71	66	3.0		12.4	
4	10	0.58	1.3	<u>373.36</u>	301	253	252	51	73	66	3.0		10.8	
5	12.5	0.76	1.7	<u>375.53</u>	301	252	251	51	74	66	3.0		10.1	
2-1	15	0.67	1.5	<u>377.41</u>	302	247	249	52	74	67	3.5		11.3	
2	17.5	0.58	1.3	<u>379.05</u>	304	248	250	52	74	67	3.5		9.3	
3	20	0.65	1.5	<u>380.77</u>	301	250	251	54	76	67	3.5		10.8	
4	22.5	0.74	1.7	<u>382.61</u>	303	251	250	57	77	68	4.0		10.4	
5	25	0.74	1.7	<u>384.47</u>	302	251	251	60	78	68	4.0		10.9	
3-1	27.5	0.65	1.5	<u>386.32</u>	301	250	250	64	76	68	3.5		11.1	
2	30	0.53	1.2	<u>387.92</u>	303	249	249	64	77	68	3.5		9.6	
3	32.5	0.57	1.3	<u>389.55</u>	302	250	251	64	78	68	3.0		11.4	
Total		<u>19.9818</u>	32.0000	<u>42.9200</u>	7551				1864	1694				
Average		<u>0.7993</u>	<u>1.5200</u>		<u>362.0100</u>									

Sum of square roots.

Circle correct bracketed units on data sheet.

QA/QC BA
 Date 3-17-10

71.600

1.4736

G-12


TEST LOCATION: FF outlet Fluoride TESTING METHOD: 13B PAGE 1 OF 2

UNIT: 1 RUN: 3

FIELD DATA SHEET

Client <u>wheelcenter</u>	Project No. <u>10055</u>
Plant <u>N. Broward</u>	Date <u>3-17-10</u>
Meter Operator <u>A. Chuchowski</u>	
Probe Operator <u>B. Arnold</u>	

Meter Box <u>61-6</u>	Sample Box No.
Meter Y _d <u>0.9900</u>	Meter ΔH @ <u>1.6820</u>
K Factor <u>2.7</u>	Pitot C _p <u>0.812</u>
Leak Rate Before <u>0.002</u> [cfm] [Lpm] @ <u>15</u> (in. Hg)	
Leak Rate After <u>0.002</u> [cfm] [Lpm] @ <u>15</u> (in. Hg)	
Pitot Leak Check Before: <input type="checkbox"/>	After: Good <input checked="" type="checkbox"/> Bad <input type="checkbox"/>



Amb. Temp. (°F) <u>70</u>	Bar. Press. <u>30.0</u> [in. Hg] [mbar]
Probe I.D. No. <u>67-E-14</u>	
Liner Material <u>g/SS</u>	

Filter No. <u>-</u>		
Thimble No. <u>-</u>		
Nozzle Diameter <u>0.26E</u>	Nozzle I.D. <u>26E-1</u>	

Start Time: 14:45 Stop Time: 15:53

Traverse Point Number	Min/pt 2.5 Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. <u>11.1</u> [L]	Stack Temp. T _s (°F)	Probe T _p (°F)	Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{out} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. O ₂ T _i 1/2 (°F)	Notes
						250	250						
5-1	2.5	0.51	1.2	412.95	302	259	244	60	66	66	2.68	0.30	11.2
-2	5	0.52	1.2	414.54	301	255	250	57	69	66	2		10.4
-3	7.5	0.55	1.3	416.14	303	258	251	56	70	66	2		11.8
-4	10	0.63	1.4	417.82	302	256	251	55	71	66	2		9.0
-5	12.5	0.58	1.3	419.46	302	253	250	55	72	66	2		10.8
4-1	15	0.58	1.3	421.15	302	250	252	57	71	66	2		10.9
-2	17.5	0.54	1.2	422.70	303	249	249	58	72	66	2		10.8
-3	20	0.65	1.5	424.39	303	250	249	59	72	66	2		11.1
-4	22.5	0.69	1.6	426.06	304	251	251	60	73	66	2		10.5
-5	25	0.77	1.2	427.95	302	250	252	61	74	66	2		10.9
3-1	28.7	0.71	1.6	429.81	302	250	250	62	73	66	3		10.3
-2	30	0.54	1.2	431.40	304	248	252	62	73	66	3		11.0
-3	32.5	0.64	1.5	433.18	303	250	249	63	73	66	3		10.5
	Total	*19.1426	33.820	411.470	75.65				1822	1662			
	Average	0.7657	1.3528		302.60				69.680	69.700			

Sum of square roots.

Circle correct bracketed units on data sheet.

QA/QC 2
Date 7/17




TEST LOCATION: FF outlet
 UNIT: 1 RUN: 3

fluoride TESTING
FIELD DATA SHEET

METHOD: 13 D PAGE 2 OF 2

Client <u>Wheelabrator</u>	Project No. <u>10455</u>
Plant <u>N. Broward</u>	Date <u>3-17-10</u>
Meter Operator <u>A. Bucher SEI</u>	
Probe Operator <u>BARNOLD</u>	



Amb. Temp. (°F)	Bar. Press.	[in. Hg] [mbar]
Probe I.D. No.		
Liner Material		

Meter Box	Sample Box No.
Meter Y _d	Meter ΔH _@
K Factor	Pitot C _p

Filter No.		
Thimble No.		
Nozzle Diameter	Nozzle I.D.	

Leak Rate Before	[cfm] [Lpm]	@	(in. Hg)
Leak Rate After	[cfm] [Lpm]	@	(in. Hg)
Pitot Leak Check Before:	<input type="checkbox"/>	After: Good	<input type="checkbox"/> Bad <input type="checkbox"/>

Duct Dimensions (in.)			
Static Pres (in. H ₂ O)	Port Len. (in.)	Gas Flow [In] [Out] of page	First point all the way [In] [Out]

Start Time:	Stop Time:
-------------	------------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. [ft ³] [L]	Stack Temp. T _s (°F)	Probe T _p (°F)	Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{max} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T _t (°F)	Notes
						Set Points							
-4	35	0.65	2.5	434.95	304	250	250	62	74	67	3	0.30	9.7
-5	37.5	0.66	1.5	436.74	303	251	249	60	75	67	3		10.0
2-1	40	0.66	1.5	438.55	302	249	249	60	73	67	3		10.9
-2	42.5	0.53	1.2	440.14	304	248	252	61	74	67	3		10.5
-7	45	0.53	1.2	441.69	304	250	250	61	74	67	3		11.3
-4	47.5	0.60	1.4	443.11	305	251	249	62	75	67	3		8.4
-5	50	0.69	1.6	445.21	303	251	250	60	75	67	3		11.3
1-1	52.5	0.49	1.1	446.79	302	250	249	56	75	67	3		10.9
-2	55	0.50	1.2	448.35	302	249	249	56	74	68	3		10.9
-7	57.5	0.40	0.92	449.77	301	250	250	55	74	67	3		9.0
-4	60	0.56	1.2	451.33	300	250	250	55	74	67	3		11.5
-5	62.5	0.65	1.5	453.11	302	250	251	56	74	67	3		9.1
	Total	*											
	Average												

* Sum of square roots.

Circle correct bracketed units on data sheet.



G-15

79
436.89
0.05
445.32
0.09

Impinger Weight Sheet

Client: Wheelabrator		Unit Name/Location: Unit 1 FF Outlet	
Plant: North Broward	Job No.: 10955	Method: 13B	

Run No.: 1	Filter Type: Teflon glass mat	Sample Box No.: B6
Date: 3/17/10	Lot No.:	pH:
Analyst: B. Wilke	Filter No.: NA	Rinse:

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	100 mL DI H2O	665.4	546.3	119.1	QA/QC: BW Date: 3/17
Impinger 2	100 mL DI H2O	620.2	562.5	67.7	
Impinger 3	Empty	480.7	459.0	21.7	
Impinger 4	Silica Gel	826.4	721.6 809.4	17.0	
				Total Weight (gm)	208.5
					225.5

Run No.: 2	Filter Type: Teflon glass mat	Sample Box No.: B7
Date: 3/17/10	Lot No.:	pH:
Analyst: R. Vicere	Filter No.: NA	Rinse:

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	100 mL DI H2O	658.1	542.1	116.0	QA/QC: JB Date: 3/17
Impinger 2	100 mL DI H2O	621.1	544.3	76.8	
Impinger 3	Empty	458.4	437.7	20.7	
Impinger 4	Silica Gel	799.4	780.6	18.8	
				Total Weight (gm)	213.5
					232.3

Run No.: 3	Filter Type: Teflon glass mat	Sample Box No.: B5
Date: 3/17/10	Lot No.:	pH:
Analyst: B. Wilke	Filter No.: NA	Rinse:

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	100 mL DI H2O	661.5	540.4	121.1	QA/QC: BW Date: 3/17
Impinger 2	100 mL DI H2O	619.3	550.6	68.7	
Impinger 3	Empty	469.1	450.5	18.6	
Impinger 4	Silica Gel	765.0	653.0 741.1	23.9	
				Total Weight (gm)	208.4
					232.3



TEST LOCATION: FF outlet
 UNIT: 1 RUN: 1

HCL TESTING
FIELD DATA SHEET

METHOD: 26A PAGE 1 OF 1

Client <u>Wheelabrator</u>	Project No. <u>10955</u>
Plant <u>N. Brewer</u>	Date <u>3-18-10</u>
Meter Operator <u>A. Obuchowski</u>	
Probe Operator	

Meter Box <u>E5-2</u>	Sample Box No. <u>B21</u>
Meter Y _d <u>1.0066</u>	Meter ΔH _@ <u>1.7759</u>
K Factor <u>-</u>	Pitot C _p

Leak Rate Before <u>0.003</u> [cfm] [Lpm] @ <u>15</u> (in. Hg)
Leak Rate After [cfm] [Lpm] @ (in. Hg)
Pitot Leak Check Before: <input checked="" type="checkbox"/> After: Good <input checked="" type="checkbox"/> Bad <input type="checkbox"/>

Cross-Section of Test Location

Duct Dimensions (in.) 96x96

Static Pres (in. H ₂ O) <u>-11.1</u>	Port Len. (in.) <u>16</u>	Gas Flow <u>UP</u> [Out] of page	First point all the way <u>UP</u> [Out]
---	---------------------------	----------------------------------	---

Amb. Temp. (°F) <u>65</u>	Bar. Press. <u>30.05</u> [in. Hg] [mbar]
Probe I.D. No. <u>67-4-3</u>	
Liner Material <u>9/455</u>	

Filter No. <u>-</u>	
Thimble No. <u>-</u>	
Nozzle Diameter <u>-</u>	Nozzle I.D. <u>-</u>

Start Time: <u>7:02</u>	Stop Time: <u>8:02</u>
-------------------------	------------------------

G-17

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. [L]	Stack Temp. T _s (°F)	Probe T _p (°F)	Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{m in} (°F)	DGM Outlet T _{m out} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T _t (°F)	Notes
						Set Points							
				<u>269.160</u>		<u>300</u>	<u>300</u>						<u>02</u>
<u>3-1</u>	<u>5</u>	<u>N/A</u>	<u>1.5</u>	<u>272.58</u>	<u>308</u>	<u>296</u>	<u>299</u>	<u>47</u>	<u>59</u>	<u>57</u>	<u>5</u>	<u>N/A</u>	<u>10.2</u>
	<u>10</u>		<u>1.5</u>	<u>275.83</u>	<u>309</u>	<u>297</u>	<u>300</u>	<u>43</u>	<u>59</u>	<u>57</u>	<u>5</u>		<u>9.9</u>
	<u>15</u>		<u>1.5</u>	<u>279.19</u>	<u>310</u>	<u>297</u>	<u>300</u>	<u>43</u>	<u>63</u>	<u>57</u>	<u>5</u>		<u>11.1</u>
	<u>20</u>		<u>1.5</u>	<u>282.44</u>	<u>309</u>	<u>299</u>	<u>300</u>	<u>44</u>	<u>65</u>	<u>57</u>	<u>5</u>		<u>10.9</u>
	<u>25</u>		<u>1.5</u>	<u>285.87</u>	<u>307</u>	<u>300</u>	<u>300</u>	<u>46</u>	<u>68</u>	<u>58</u>	<u>5</u>		<u>9.9</u>
	<u>30</u>		<u>1.5</u>	<u>289.17</u>	<u>307</u>	<u>300</u>	<u>300</u>	<u>49</u>	<u>69</u>	<u>58</u>	<u>5</u>		<u>10.2</u>
	<u>35</u>		<u>1.5</u>	<u>292.53</u>	<u>307</u>	<u>299</u>	<u>300</u>	<u>53</u>	<u>70</u>	<u>58</u>	<u>5</u>		<u>9.4</u>
	<u>40</u>		<u>1.5</u>	<u>295.89</u>	<u>307</u>	<u>300</u>	<u>299</u>	<u>56</u>	<u>70</u>	<u>59</u>	<u>5</u>		<u>9.5</u>
	<u>45</u>		<u>1.5</u>	<u>299.18</u>	<u>307</u>	<u>299</u>	<u>300</u>	<u>60</u>	<u>70</u>	<u>59</u>	<u>5</u>		<u>9.8</u>
	<u>50</u>		<u>1.5</u>	<u>302.64</u>	<u>307</u>	<u>299</u>	<u>300</u>	<u>61</u>	<u>70</u>	<u>60</u>	<u>5</u>		<u>9.5</u>
	<u>55</u>		<u>1.5</u>	<u>305.92</u>	<u>307</u>	<u>298</u>	<u>300</u>	<u>61</u>	<u>70</u>	<u>60</u>	<u>5</u>		<u>9.3</u>
	<u>60</u>		<u>1.5</u>	<u>309.265</u>	<u>307</u>	<u>298</u>	<u>299</u>	<u>62</u>	<u>70</u>	<u>60</u>	<u>5</u>		<u>9.9</u>
	Total		<u>1.8</u>	<u>40.1650</u>	<u>3692</u>				<u>607</u>	<u>700</u>			
	Average		<u>1.50</u>	<u>40.1650</u>	<u>3692</u>				<u>62.6250</u>				

* Sum of square roots.

Circle correct bracketed units on data sheet.



TEST LOCATION: FF outlet
 UNIT: 1 RUN: 2


HCL TESTING
FIELD DATA SHEET

METHOD: 26A PAGE 1 OF 1

Client <u>wheelabrator</u>	Project No. <u>10955</u>
Plant <u>N. Broward</u>	Date <u>3-16-10</u>
Meter Operator <u>A. Obuchovskii</u>	
Probe Operator	

Meter Box <u>05-2</u>	Sample Box No.
Meter Y _d <u>1.0066</u>	Meter ΔH ₀ <u>1.3759</u>
K Factor	Pitot C _p

Leak Rate Before <u>0.002</u> [cfm] [Lpm] @ <u>15</u> (in. Hg)
Leak Rate After <u>0.001</u> [cfm] [Lpm] @ <u>15</u> (in. Hg)
Pitot Leak Check Before: <input type="checkbox"/> After: Good <input checked="" type="checkbox"/> Bad <input type="checkbox"/>



Duct Dimensions (in.) <u>46x96</u>			
Static Pres (in. H ₂ O) <u>10.9</u> <u>20.50</u>	Port Len. (in.) <u>10</u>	Gas Flow <u>60</u> [Out] of page	First point all the way <u>60</u> [Out]

Amb. Temp. (°F) <u>65</u>	Bar. Press. <u>30.05</u> [in. Hg] [mbar]
Probe I.D. No. <u>67-4-3</u>	
Liner Material <u>glass</u>	

Filter No.		
Thimble No.		
Nozzle Diameter	Nozzle I.D.	

Start Time: <u>9:26</u>	Stop Time: <u>10:37</u>
-------------------------	-------------------------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Onifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. (L)	Stack Temp. T _s (°F)	Probe T _p (°F)		Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{max} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T _t (°F)	Notes
						Set Points	Filter T _f (°F)						
	<u>5</u>	<u>N/A</u>	<u>1.5</u>	<u>309.830</u>		<u>300</u>	<u>300</u>						
<u>3.1</u>	<u>5</u>	<u>N/A</u>	<u>1.5</u>	<u>313.18</u>	<u>309</u>	<u>300</u>	<u>300</u>	<u>50</u>	<u>61</u>	<u>60</u>	<u>5</u>	<u>N/A</u>	<u>9.4</u>
	<u>10</u>		<u>1.5</u>	<u>316.51</u>	<u>310</u>	<u>300</u>	<u>300</u>	<u>49</u>	<u>61</u>	<u>60</u>	<u>5</u>		<u>9.1</u>
	<u>15</u>		<u>1.5</u>	<u>319.79</u>	<u>309</u>	<u>296</u>	<u>301</u>	<u>49</u>	<u>64</u>	<u>60</u>	<u>5</u>		<u>10.1</u>
	<u>20</u>		<u>1.5</u>	<u>323.05</u>	<u>309</u>	<u>298</u>	<u>300</u>	<u>51</u>	<u>65</u>	<u>61</u>	<u>5</u>		<u>9.9</u>
	<u>26</u>		<u>1.5</u>	<u>326.39</u>	<u>310</u>	<u>299</u>	<u>301</u>	<u>53</u>	<u>67</u>	<u>61</u>	<u>5</u>		<u>10.0</u>
	<u>30</u>		<u>1.5</u>	<u>329.72</u>	<u>308</u>	<u>299</u>	<u>299</u>	<u>55</u>	<u>66</u>	<u>62</u>	<u>5</u>		<u>10.0</u>
	<u>35</u>		<u>1.5</u>	<u>333.10</u>	<u>305</u>	<u>297</u>	<u>301</u>	<u>58</u>	<u>66</u>	<u>62</u>	<u>5</u>		<u>9.2</u>
	<u>40</u>		<u>1.5</u>	<u>336.41</u>	<u>310</u>	<u>297</u>	<u>301</u>	<u>59</u>	<u>68</u>	<u>63</u>	<u>5</u>		<u>10.3</u>
	<u>45</u>		<u>1.5</u>	<u>339.24</u>	<u>310</u>	<u>298</u>	<u>301</u>	<u>60</u>	<u>69</u>	<u>63</u>	<u>5</u>		<u>10.1</u>
	<u>50</u>		<u>1.5</u>	<u>343.77</u>	<u>310</u>	<u>297</u>	<u>299</u>	<u>61</u>	<u>68</u>	<u>63</u>	<u>5</u>		<u>10.1</u>
	<u>55</u>		<u>1.5</u>	<u>346.40</u>	<u>309</u>	<u>299</u>	<u>299</u>	<u>62</u>	<u>68</u>	<u>63</u>	<u>5</u>		<u>9.6</u>
	<u>60</u>		<u>1.5</u>	<u>349.730</u>	<u>310</u>	<u>299</u>	<u>300</u>	<u>63</u>	<u>67</u>	<u>63</u>	<u>5</u>		<u>9.2</u>
	Total *		<u>1.8</u>	<u>349.90</u>	<u>309</u>				<u>790</u>	<u>741</u>			
	Average		<u>1.50</u>	<u>349.0833</u>					<u>63.7917</u>				

* Sum of square roots.

Circle correct bracketed units on data sheet.

QA/QC 0
 Date 3-16



G-18

TEST LOCATION: FF outlet

HCL


TESTING

METHOD: 26A PAGE 1 OF 1

UNIT: 1

RUN: 3

FIELD DATA SHEET



Client <u>Wheelabrator</u>	Project No. <u>10955</u>
Plant <u>N. Broward</u>	Date <u>3-18-10</u>
Meter Operator <u>A. Obuchowski</u>	
Probe Operator <u>-</u>	

Meter Box <u>85-2</u>	Sample Box No.
Meter Y _d <u>1.0066</u>	Meter ΔH _@ <u>1.9759</u>
K Factor <u>-</u>	Pitot C _p

Leak Rate Before <u>0.006</u> [Lpm] @ <u>15</u> (in. Hg)
Leak Rate After <u>0.002</u> [Lpm] @ <u>15</u> (in. Hg)
Pitot Leak Check Before: <input checked="" type="checkbox"/> After: Good <input checked="" type="checkbox"/> Bad <input type="checkbox"/>

Amb. Temp. (°F) <u>65</u>	Bar. Press. <u>30.05</u> [in. Hg] [mbar]
Probe I.D. No. <u>67-4-3</u>	
Liner Material <u>91455</u>	

Filter No. <u>-</u>		
Thimble No. <u>-</u>		
Nozzle Diameter <u>-</u>	Nozzle I.D. <u>-</u>	

Start Time: <u>11:49</u>	Stop Time: <u>12:49</u>
--------------------------	-------------------------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. (L)	Stack Temp. T _s (°F)	Probe T _p (°F)	Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{max} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T _t (°F)	Notes
						Set Points							
3-1	5	N/A	1.5	351.710	310	300	300	54	67	65	5	N/A	10.4
	10		1.5	358.45	310	299	300	52	67	65	5		10.5
	15		1.5	361.79	308	296	302	53	69	65	5		10.9
	20		1.5	365.12	307	299	300	56	72	66	5		11.0
	25		1.5	368.05	309	297	299	59	71	66	5		10.8
	30		1.5	371.80	311	298	298	61	72	67	5		10.8
	35		1.5	375.17	311	297	300	61	72	67	5		10.6
	40		1.5	378.59	311	300	300	62	74	68	5		10.0
	45		1.5	381.87	312	299	301	61	74	68	5		9.4
	50		1.5	385.21	310	297	300	60	73	68	5		10.4
	55		1.5	388.55	310	297	300	60	72	68	5		10.2
	60		1.5	391.845	310	296	301	62	73	69	5		9.5
	Total	*	1.5	40.1550	319				856	802			
	Average		1.50		309.9167				69.0833				

* Sum of square roots.

Circle correct bracketed units on data sheet.

QA/QC OK
Date 3-18



Impinger Weight Sheet

Client Wheelabrator		Unit Name/Location Unit 1 FF Outlet	
Plant North Broward	Job No. 10955	Method	Mod. 26A

Run No. 1	Filter Type Quartz	Sample Box No. B21
Date 3/18/10	Lot No.	pH
Analyst B. Wilke	Filter No. NA	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	50 mL 0.1N H2SO4	501.4	472.8	28.6	
Impinger 2	100 mL 0.1N H2SO4	741.6	642.1	99.5	
Impinger 3	100 mL 0.1N H2SO4	582.6	535.0	47.6	
Impinger 4	Empty	472.6	448.5	24.1	
Impinger 5	Silica Gel	735.2	717.6	17.6	Total Weight (gm)
					199.8
					217.4

QA/QC *SW*
 Date 3/18

Run No. 2	Filter Type Quartz	Sample Box No. B11
Date 3/18/10	Lot No.	pH
Analyst B. Wilke	Filter No. NA	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	50 mL 0.1N H2SO4	524.0 504.6	469.1 460.1	63.9	
Impinger 2	100 mL 0.1N H2SO4	680.6 629.1	561.4	119.2	
Impinger 3	100 mL 0.1N H2SO4	589.0 582.0	555.6	33.4	
Impinger 4	Empty	465.1 439.9	456.4	8.7	
Impinger 5	Silica Gel	791.5	780.5	11.0	Total Weight (gm)
					225.2
					236.2

QA/QC *SB*
 Date 3/18

Run No. 3	Filter Type Quartz	Sample Box No. B21 B21
Date 3/18/10	Lot No.	pH
Analyst R. Vique	Filter No. NA	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	50 mL 0.1N H2SO4	503.1	472.6	30.5	
Impinger 2	100 mL 0.1N H2SO4	571.2	642.0	115.7	
Impinger 3	100 mL 0.1N H2SO4	757.7	535.8	35.4	
Impinger 4	Empty	458.9	448.6	10.3	
Impinger 5	Silica Gel	735.2	716.0	19.2	Total Weight (gm)
					191.9
					211.1

QA/QC *SB*
 Date 3/18



TEST LOCATION: SDA INLET

HCL


TESTING

METHOD: ZGA PAGE 1 OF 1

UNIT: 1 RUN: 1

FIELD DATA SHEET

Cross-Section of Test Location



Client <u>Wheeler</u>	Project No. <u>10955</u>
Plant <u>N. Broward</u>	Date <u>3-19-10</u>
Meter Operator <u>B. Arnold</u>	
Probe Operator <u>B. Arnold</u>	

Amb. Temp. (°F) <u>58</u>	Bar. Press. <u>30.05</u> [in. Hg] [mbar]
Probe I.D. No. <u>67-4-4</u>	
Liner Material <u>GLASS</u>	

Meter Box <u>85-4</u>	Sample Box No. <u>822</u>
Meter Y _d <u>1.0085</u>	Meter ΔH ₀ <u>1.7723</u>
K Factor <u>N/A</u>	Pitot C _p

Filter No. <u>N/A</u>	
Thimble No. <u>N/A</u>	
Nozzle Diameter <u>N/A</u>	Nozzle I.D. <u>N/A</u>

Leak Rate Before <u>0.002</u> [cfm] [Lpm] @ <u>15</u> (in. Hg)
Leak Rate After <u>0.003</u> [cfm] [Lpm] @ <u>22</u> (in. Hg)
Pitot Leak Check Before: <input checked="" type="checkbox"/> After: Good <input checked="" type="checkbox"/> Bad <input type="checkbox"/>

Duct Dimensions (in.) <u>105</u>			
Static Pres (in. H ₂ O) <u>-1.9</u>	Port Len. (in.) <u>14</u>	Gas Flow (in) [Out] of page <u>(n)</u>	First point all the way (n) [Out]

Start Time: <u>7:02</u>	Stop Time: <u>8:02</u>
-------------------------	------------------------

Traverse Point Number	Min/pt 5 Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. [ft ³] [L]	Stack Temp. T _s (°F)	Probe T _p Filter T _f (°F)		Cond. Temp. T _c (°F)	DGM Inlet T _{m in} (°F)	DGM Outlet T _{m out} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T _t (°F)	Notes
						355	355						
1-1	5		1.2	614.080	486	355	356	60	58	56	3.0	9.7	
	10			620.24	487	356	356	58	59	56	3.5	9.6	
	15			623.31	493	352	356	61	64	57	5.5	10.6	
	20			626.40	493	350	354	65	63	58	7.0	10.1	
	25			629.49	488	355	353	60	63	58	9.0	9.8	
	30			632.57	488	357	354	60	63	58	9.8	9.6	
	35			635.64	492	358	355	59	63	58	12.0	8.8	
	40			638.74	490	355	355	59	63	58	14.0	8.8	
	45			641.87	489	354	354	62	63	58	16.5	8.6	
	50			644.98	486	353	355	62	63	60	17.5	9.4	
	55			648.09	486	356	354	61	63	59	19.5	9.5	
	60		1.1	651.130	488	352	353	62	63	57	22.0	9.7	
Total			14.300	37.0500	5864				748	690			
Average			1.1917	37.0500	486.822				60.1250				

Sum of square roots.

Circle correct bracketed units on data sheet.

QA/QC BA
Date 3-19-10


G-21

TEST LOCATION: SDA INLET
 UNIT: 1 RUN: 2

HCL TESTING
FIELD DATA SHEET

METHOD: Z6A PAGE 1 OF 1

Client Wheabrator Project No. 10955
 Plant N. Broward Date 3-19-10
 Meter Operator B. ARNOLD
 Probe Operator B. ARNOLD



Amb. Temp. (°F) 62 Bar. Press. 30.05 [in. Hg] [mbar]
 Probe I.D. No. 67-4-4
 Liner Material GLASS

Meter Box 85-4 Sample Box No. B16
 Meter Y_d 1.0085 Meter ΔH_@ 1.7727
 K Factor N/A Pitot C_p
 Leak Rate Before 0.004 [Lpm] @ 15 (in. Hg)
 Leak Rate After 0.003 [Lpm] @ 22 (in. Hg)
 Pitot Leak Check Before: After: Good Bad

Duct Dimensions (in.) 105
 Static Pres (in. H₂O) -1.7 Port Len. (in.) 14 Gas Flow (In) [Out] First point all the way (In) [Out]
 of page

Filter No. N/A
 Thimble No. N/A
 Nozzle Diameter N/A Nozzle I.D. N/A

Start Time: 9:26 Stop Time: 10:37

G-22

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. (ft ³) [L]	Stack Temp. T _s (°F)	Probe T _p (°F)		Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{out} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. (°F)	Notes
						Set Points	Filter T _f (°F)						
	<u>5</u>			<u>655.840</u>		<u>355</u>	<u>355</u>					<u>02</u>	
<u>1-1</u>	<u>5</u>		<u>1.2</u>	<u>658.81</u>	<u>485</u>	<u>351</u>	<u>365</u>	<u>66</u>	<u>62</u>	<u>61</u>	<u>3.0</u>	<u>9.4</u>	<u>-1100 Feb</u>
	<u>10</u>			<u>661.92</u>	<u>485</u>	<u>355</u>	<u>360</u>	<u>64</u>	<u>66</u>	<u>63</u>	<u>6.5</u>	<u>9.5</u>	<u>STOP + Leak ✓</u>
	<u>15</u>			<u>664.82</u>	<u>489</u>	<u>357</u>	<u>357</u>	<u>61</u>	<u>66</u>	<u>63</u>	<u>10.0</u>	<u>8.5</u>	<u>Change filter</u>
	<u>20</u>			<u>667.79</u>	<u>489</u>	<u>356</u>	<u>356</u>	<u>60</u>	<u>69</u>	<u>63</u>	<u>13.0</u>	<u>9.2</u>	
	<u>25</u>			<u>670.71</u>	<u>494</u>	<u>360</u>	<u>358</u>	<u>58</u>	<u>70</u>	<u>64</u>	<u>16.5220</u>	<u>9.9</u>	<u>670.820 HCL</u>
	<u>30</u>			<u>673.91</u>	<u>489</u>	<u>344</u>	<u>348</u>	<u>57</u>	<u>65</u>	<u>64</u>	<u>3.0</u>	<u>9.6</u>	
	<u>35</u>			<u>676.82</u>	<u>485</u>	<u>361</u>	<u>350</u>	<u>58</u>	<u>67</u>	<u>65</u>	<u>3.0</u>	<u>9.4</u>	
	<u>40</u>			<u>679.75</u>	<u>487</u>	<u>349</u>	<u>357</u>	<u>59</u>	<u>67</u>	<u>65</u>	<u>4.5</u>	<u>10.1</u>	
	<u>45</u>			<u>682.69</u>	<u>491</u>	<u>347</u>	<u>346</u>	<u>59</u>	<u>71</u>	<u>65</u>	<u>5.5</u>	<u>10.1</u>	
	<u>50</u>			<u>685.78</u>	<u>494</u>	<u>350</u>	<u>349</u>	<u>60</u>	<u>72</u>	<u>66</u>	<u>7.0</u>	<u>9.3</u>	
	<u>55</u>			<u>688.68</u>	<u>490</u>	<u>351</u>	<u>350</u>	<u>60</u>	<u>69</u>	<u>66</u>	<u>9.0</u>	<u>8.6</u>	
	<u>60</u>			<u>691.690</u>	<u>491</u>	<u>352</u>	<u>353</u>	<u>60</u>	<u>69</u>	<u>66</u>	<u>10.5</u>	<u>8.2</u>	
	Total *			<u>35.7400</u>					<u>815</u>	<u>771</u>			
	Average				<u>489.6533</u>				<u>66.0837</u>				

*Sum of square roots.

Circle correct bracketed units on data sheet.

QA/QC BA
 Date 3-19-10



TEST LOCATION: SDA INLET

HeL

TESTING

METHOD: ZGA PAGE 1 OF 1


UNIT: 1

RUN: 3

FIELD DATA SHEET

Cross-Section of Test Location

(N) (UP)



Duct Dimensions (in.) 105

Static Pres (in. H ₂ O)	Port Len. (in.)	Gas Flow (in. H ₂ O) [Out]	First point all the way (in.) [Out]
<u>-1.7</u>	<u>14</u>	<u>10</u> of page	<u>1</u>

Amb. Temp. (°F) <u>70</u>	Bar. Press. <u>30.05</u> [(in. Hg) (mbar)]
Probe I.D. No. <u>67-4-4</u>	
Liner Material <u>GLASS</u>	

Filter No. <u>N/A</u>		
Thimble No. <u>N/A</u>		
Nozzle Diameter <u>N/A</u>	Nozzle I.D.	<u>N/A</u>

Start Time: <u>11:49</u>	Stop Time: <u>12:49</u>
--------------------------	-------------------------

Client <u>WheLabrator</u>	Project No. <u>10955</u>
Plant <u>N. Broward</u>	Date <u>3-11-10</u>
Meter Operator <u>B. Arnold</u>	
Probe Operator <u>B. Arnold</u>	

Meter Box <u>85-4</u>	Sample Box No. <u>22</u>
Meter Y _d <u>1.0085</u>	Meter ΔH _@ <u>1.7223</u>
K Factor <u>N/A</u>	Pitot C _p

Leak Rate Before <u>0.003</u> [cfm] [Lpm] @ <u>15</u> (in. Hg)
Leak Rate After <u>0.003</u> [cfm] [Lpm] @ <u>18</u> (in. Hg)
Pitot Leak Check Before: <input checked="" type="checkbox"/> After: Good <input checked="" type="checkbox"/> Bad <input type="checkbox"/>

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. (ft ³) [L]	Stack Temp. T _s (°F)	Probe T _p (°F)	Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{min} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T ₁ (°F)	Notes
						Set Points						BA T ₁ (°F)	
				<u>691.850</u>		<u>355</u>	<u>355</u>					<u>62</u>	
<u>1-1</u>	<u>5</u>		<u>1.2</u>	<u>694.83</u>	<u>494</u>	<u>351</u>	<u>355</u>	<u>65</u>	<u>72</u>	<u>72</u>	<u>2.5</u>	<u>9.7</u>	
	<u>10</u>			<u>697.73</u>	<u>496</u>	<u>355</u>	<u>354</u>	<u>61</u>	<u>74</u>	<u>72</u>	<u>3.0</u>	<u>16.1</u>	
	<u>15</u>			<u>700.68</u>	<u>491</u>	<u>353</u>	<u>354</u>	<u>58</u>	<u>78</u>	<u>73</u>	<u>4.0</u>	<u>10.7</u>	
	<u>20</u>			<u>703.65</u>	<u>494</u>	<u>358</u>	<u>359</u>	<u>58</u>	<u>78</u>	<u>74</u>	<u>5.5</u>	<u>11.0</u>	
	<u>25</u>			<u>706.63</u>	<u>501</u>	<u>357</u>	<u>355</u>	<u>59</u>	<u>78</u>	<u>74</u>	<u>7.5</u>	<u>10.7</u>	
	<u>30</u>			<u>709.63</u>	<u>500</u>	<u>357</u>	<u>354</u>	<u>57</u>	<u>78</u>	<u>75</u>	<u>8.5</u>	<u>10.6</u>	
	<u>35</u>			<u>712.61</u>	<u>502</u>	<u>359</u>	<u>357</u>	<u>56</u>	<u>77</u>	<u>75</u>	<u>10.0</u>	<u>10.4</u>	
	<u>40</u>			<u>715.60</u>	<u>501</u>	<u>350</u>	<u>355</u>	<u>58</u>	<u>78</u>	<u>75</u>	<u>11.5</u>	<u>10.6</u>	
	<u>45</u>			<u>718.58</u>	<u>497</u>	<u>357</u>	<u>353</u>	<u>60</u>	<u>79</u>	<u>76</u>	<u>13.5</u>	<u>10.3</u>	
	<u>50</u>			<u>721.53</u>	<u>497</u>	<u>355</u>	<u>355</u>	<u>61</u>	<u>76</u>	<u>75</u>	<u>15.0</u>	<u>9.7</u>	
	<u>55</u>			<u>724.50</u>	<u>494</u>	<u>352</u>	<u>355</u>	<u>63</u>	<u>75</u>	<u>75</u>	<u>16.0</u>	<u>9.5</u>	
	<u>60</u>			<u>727.450</u>	<u>496</u>	<u>355</u>	<u>355</u>	<u>64</u>	<u>76</u>	<u>74</u>	<u>18.0</u>	<u>9.0</u>	
	Total			<u>35.6000</u>	<u>5693</u>				<u>919</u>	<u>870</u>			
	Average				<u>496.9167</u>				<u>75.3750</u>				

* Sum of square roots.

Circle correct bracketed units on data sheet.

G-23

Impinger Weight Sheet

Client: Wheelabrator		Unit Name/Location: Unit 1, SDA Inlet	
Plant: North Broward	Job No.: 10955	Method:	Mod. 26A

Run No. 1	Filter Type: Quartz	Sample Box No. B22
Date: 3/18/10	Lot No.	pH
Analyst: B. Wilcox	Filter No. NA	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	50 mL 0.1N H2SO4	504.6	479.6		
Impinger 2	100 mL 0.1N H2SO4	629.1	537.6		
Impinger 3	100 mL 0.1N H2SO4	582.0	557.1		
Impinger 4	Empty	439.9	430.7		
Impinger 5	Silica Gel	775.4	753.7		
					Total Weight (gm)

QA/QC SB
 Date 3/18

Run No. 2	Filter Type: Quartz	Sample Box No. B16
Date: 3/18/10	Lot No.	pH
Analyst: E. Vicore / B. Wilcox	Filter No. NA	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	50 mL 0.1N H2SO4	523.3	454.7	68.6	
Impinger 2	100 mL 0.1N H2SO4	606.5	542.4 557.7BW	64.1	
Impinger 3	100 mL 0.1N H2SO4	550.5	540.8	9.7	
Impinger 4	Empty	466.8	463.4	3.4	
Impinger 5	Silica Gel	764.5	753.2	11.3	
					Total Weight (gm)
					145.8
					157.1

QA/QC SB
 Date 3/18

Run No. 3	Filter Type: Quartz	Sample Box No.
Date: 3/18/10	Lot No.	pH
Analyst: E. Vicore	Filter No. NA	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	50 mL 0.1N H2SO4	538.6	469.9	68.7	
Impinger 2	100 mL 0.1N H2SO4	597.4	537.1	60.3	
Impinger 3	100 mL 0.1N H2SO4	561.1	553.2	7.9	
Impinger 4	Empty	432.6	430.6	2.0	
Impinger 5	Silica Gel	722.8	711.4	11.4	
					Total Weight (gm)
					138.9
					150.3

QA/QC SB
 Date 3/18

TEST LOCATION: FF outlet
 UNIT: 2 RUN: 1

Particulate / Metals TESTING
 FIELD DATA SHEET

METHOD: 5129 PAGE 1 OF 2

Client <u>Whelanator</u>	Project No. <u>10755</u>
Plant <u>N. Broward</u>	Date <u>3/18/10</u>
Meter Operator	
Probe Operator	

Meter Box <u>166-24</u>	Sample Box No. <u>M15</u>
Meter Y _d <u>0.9904</u>	Meter ΔH _@ <u>1.7576</u>
K Factor <u>2.35</u>	Pitot C _p <u>0.807</u>
Leak Rate Before <u>0.004</u> [cfm] [Lpm]	@ <u>15</u> (in. Hg)
Leak Rate After <u>0.004</u> [cfm] [Lpm]	@ <u>5</u> (in. Hg)
Pitot Leak Check Before: <input checked="" type="checkbox"/> After: Good <input checked="" type="checkbox"/> Bad <input type="checkbox"/>	

Cross-Section of Test Location

Duct Dimensions (in.) 9x96

Static Pres (in. H ₂ O)	Port Len. (in.)	Gas Flow (In) (Out)	First point (In) (Out)
<u>-10.6</u>	<u>10.0</u>		

Amb. Temp. (°F) <u>60</u>	Bar. Press <u>30.05</u> (in. Hg) [mbar]
Probe I.D. No. <u>67-4-4</u>	
Liner Material <u>Glass</u>	

Filter No. <u>E-115-30</u>	
Thimble No. <u>N/A</u>	
Nozzle Diameter <u>0.270</u>	Nozzle I.D. <u>2707</u>

Start Time: <u>7:09</u>	Stop Time: <u>9:22</u>
-------------------------	------------------------

G-25

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. (ft ³)	Stack Temp. T _s (°F)	Probe T _p (°F)	Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{m in} (°F)	DGM Outlet T _{m out} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T _t (°F)	Notes
						Set Points							
5-1	5	0.59	1.4	446.115	308	210	250	54	59	57	4.5	0.20	9.9
2	10	0.48	1.1	452.36	307	283	260	47	61	58	3.5	0.20	9.7
3	15	0.46	1.1	451.23	308	257	253	44	63	58	3.5	0.20	9.9
4	20	0.50	1.2	458.32	308	252	248	44	66	58	4.0	0.20	10.0
5	25	0.42	0.99	461.025	308	249	250	44	68	59	3.5	0.20	8.8
4-1	30	0.55	1.3	464.29	307	246	247	45	68	60	4.0	0.20	10.3
2	35	0.54	1.3	467.47	309	243	254	44	71	61	4.0	0.20	10.2
3	40	0.67	1.6	471.05	309	257	252	44	72	61	4.5	0.20	9.5
4	45	0.70	1.7	474.72	309	254	249	44	74	62	5.0	0.20	10.4
5	50	0.68	1.6	478.275	309	250	250	45	76	63	4.5	0.20	10.0
3-1	55	0.59	1.4	481.61	308	246	248	46	74	64	4.5	0.20	10.4
2	60	0.53	1.3	484.86	309	243	254	46	76	65	4.0	0.20	10.3
Total													
Average		0.7819	1.4596	84.670	307.480				69.9	64			

* Sum of square roots

Circle correct bracketed units on data sheet.

TEST LOCATION: FF Outlet

UNIT: 2 RUN: 1


Particulate Matter TESTING
FIELD DATA SHEET

METHOD: 5129 PAGE 2 OF 2

Client <u>Wheelabrator</u>	Project No. <u>1051T</u>
Plant <u>N. Broward</u>	Date <u>3/11/10</u>
Meter Operator <u>P. Bihun</u>	
Probe Operator <u>P. Bihun</u>	

Meter Box	Sample Box No.
Meter Y _d	Meter ΔH _@
K Factor	Pitot C _p

Leak Rate Before	[cfm] [Lpm]	@	(in. Hg)
Leak Rate After	[cfm] [Lpm]	@	(in. Hg)
Pitot Leak Check Before:	<input type="checkbox"/>	After: Good	<input type="checkbox"/> Bad <input type="checkbox"/>



Duct Dimensions (in.)			
Static Pres (in. H ₂ O)	Port Len. (in.)	Gas Flow [In] [Out]	First point all the way of page [In] [Out]

Amb. Temp. (°F)	Bar. Press. [in. Hg] [mbar]
Probe I.D. No.	
Liner Material	

Filter No.	
Thimble No.	
Nozzle Diameter	Nozzle I.D.

Start Time:	Stop Time:
-------------	------------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. (L)	Stack Temp. T _s (°F)	Probe T _p (°F)		Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{out} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T _i (°F)	Notes
						210	210						
3	65	0.58	1.4	488.21	309	257	207	47	77	66	4.5	0.20	10.8
4	70	0.66	1.6	491.81	310	253	249	47	78	67	4.5	0.20	9.9
5	75	0.72	1.7	495.505	309	250	249	47	79	67	5.0	0.20	10.4
2	80	0.61	1.4	498.87	308	245	249	49	77	68	4.5	0.20	10.7
2	85	0.87	2.0	502.81	309	249	285	50	79	68	5.5	0.20	10.6
3	90	0.72	1.7	506.51	309	286	249	49	80	69	5.0	0.20	9.6
4	95	0.82	1.9	510.39	305	252	247	50	81	70	5.5	0.20	10.0
5	100	0.75	1.8	514.18	307	210	250	51	82	70	5.0	0.20	10.3
1	105	0.55	1.3	517.50	305	248	246	53	78	71	4.5	0.20	10.3
2	110	0.60	1.4	520.86	303	210	252	53	81	71	4.5	0.20	8.8
3	115	0.55	1.3	524.05	303	280	280	53	82	72	4.5	0.20	9.3
4	120	0.58	1.4	527.40	305	252	280	55	82	72	4.5	0.20	9.3
5	125	0.68	1.6	531.025	306	251	280	55	82	72	5.0	0.20	9.4
	Total												
	Average												

Sum of square roots.

Circle correct bracketed units on data sheet.

QA/QC PB
Date 3/11/10



G-26

TEST LOCATION:

FF Outlet

TESTING FIELD DATA SHEET

METHOD: 5129 PAGE 1 OF 2

UNIT: 2

RUN: 2

Cross-Section of Test Location



Duct Dimensions (in.) 96x96

Static Pres (in. H ₂ O)	Port Len. (in.)	Gas Flow (m) [Out] of page	First point all the way (In) [Out]
-10.6	10.0		

Amb. Temp. (°F)	65	Bar. Press.	30.1 (in. Hg) (mbar)
Probe I.D. No.	67-5-4		
Liner Material	Glas		

Filter No.	E-115-31		
Thimble No.	N/A		
Nozzle Diameter	0.270	Nozzle I.D.	0.270

Start Time:	9:49	Stop Time:	12:02
-------------	------	------------	-------

Client	Wheelabrator	Project No.	10955
Plant	N. Brown	Date	3/18/10
Meter Operator	P. Bishop		
Probe Operator	L. Bishop		

Meter Box	116-24	Sample Box No.	M10
Meter Y _d	0.9904	Meter ΔH ₀	1.716
K Factor	2.3	Pitot C _p	0.805

Leak Rate Before	0.003 (m) [Lpm]	@	15 (in. Hg)
Leak Rate After	0.002 (m) [Lpm]	@	9 (in. Hg)
Pitot Leak Check Before:	<input checked="" type="checkbox"/>	After:	Good <input checked="" type="checkbox"/> Bad <input type="checkbox"/>

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. (ft ³)	Stack Temp. T _s (°F)	Probe T _p Filter T _r (°F)		Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{min} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T _t (°F)	Notes
						Set Points							
5-1	5	0.58	1.4	531.310	307	246	250	59	73	72	4.5	0.25	10.0
2	10	0.59	1.4	537.96	307	253	251	50	75	72	4.5	0.21	9.5
3	15	0.60	1.4	541.26	308	258	257	47	78	72	4.5	0.25	10.5
4	20	0.67	1.6	544.83	310	252	250	47	80	73	5.0	0.25	9.4
5	25	0.66	1.6	548.900	310	250	250	48	82	74	5.0	0.25	9.3
4-1	30	0.53	1.3	551.68	308	246	249	51	81	74	4.5	0.25	9.6
2	35	0.57	1.2	554.82	308	248	250	50	83	74	4.5	0.25	9.8
3	40	0.58	1.4	558.18	308	254	250	49	84	75	5.0	0.25	9.9
4	45	0.62	1.5	561.66	308	257	249	49	85	76	5.0	0.25	10.2
5	50	0.62	1.5	565.150	308	257	250	50	86	76	5.0	0.25	10.3
3-1	55	0.57	1.3	568.41	308	247	250	53	84	77	4.5	0.25	9.9
2	60	0.50	1.2	571.54	308	245	251	53	86	77	4.5	0.25	8.9
Total													
Average		0.7481	1.3930	516.30	307.1000				81.9000				

*Sum of square roots.

Circle correct bracketed units on data sheet.

3028 QA/QC Date 3/18/10

1169



TEST LOCATION:

RF outlet


Particulate/Metals TESTING FIELD DATA SHEET

METHOD: 5729 PAGE 2 OF 2

UNIT: 2

RUN: 2

Client <u>Wheeler</u>	Project No. <u>1095T</u>
Plant <u>N. Brown</u>	Date <u>3/18/10</u>
Meter Operator <u>P. Bihun</u>	
Probe Operator <u>P. Bihun</u>	



Amb. Temp. (°F)	Bar. Press.	[in. Hg] [mbar]
Probe I.D. No.		
Liner Material		

Meter Box	Sample Box No.
Meter Y _d	Meter ΔH _@
K Factor	Pitot C _p

Filter No.		
Thimble No.		
Nozzle Diameter	Nozzle I.D.	

Leak Rate Before	[cfm] [Lpm]	@	(in. Hg)
Leak Rate After	[cfm] [Lpm]	@	(in. Hg)
Pitot Leak Check Before:	<input type="checkbox"/>	After: Good	<input type="checkbox"/> Bad <input type="checkbox"/>

Duct Dimensions (in.)			
Static Pres (in. H ₂ O)	Port Len. (in.)	Gas Flow [In] [Out]	First point all the way of page [In] [Out]

Start Time:	Stop Time:
-------------	------------

G-28

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. [L]	Stack Temp. T _s (°F)	Probe T _p (°F)	Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{m in} (°F)	DGM Outlet T _{m out} (°F)	Pump Vacuum (in.Hg)	XAD Trap Temp. T _t (°F)	Notes
						Set Points							
						<u>200</u>	<u>250</u>					<u>Reg. Plan</u>	<u>O₂</u>
<u>3</u>	<u>65</u>	<u>0.53</u>	<u>1.3</u>	<u>574.77</u>	<u>307</u>	<u>251</u>	<u>250</u>	<u>52</u>	<u>87</u>	<u>78</u>	<u>5.0</u>	<u>0.25</u>	<u>10.1</u>
<u>4</u>	<u>70</u>	<u>0.56</u>	<u>1.3</u>	<u>578.00</u>	<u>307</u>	<u>253</u>	<u>250</u>	<u>52</u>	<u>88</u>	<u>79</u>	<u>5.0</u>	<u>0.25</u>	<u>9.7</u>
<u>5</u>	<u>75</u>	<u>0.56</u>	<u>1.3</u>	<u>581.215</u>	<u>307</u>	<u>250</u>	<u>250</u>	<u>53</u>	<u>89</u>	<u>79</u>	<u>5.0</u>	<u>0.25</u>	<u>9.6</u>
<u>2-1</u>	<u>80</u>	<u>0.53</u>	<u>1.3</u>	<u>574.50</u>	<u>306</u>	<u>248</u>	<u>250</u>	<u>56</u>	<u>88</u>	<u>80</u>	<u>5.0</u>	<u>0.25</u>	<u>10.4</u>
<u>2</u>	<u>85</u>	<u>0.47</u>	<u>1.1</u>	<u>571.56</u>	<u>306</u>	<u>246</u>	<u>250</u>	<u>58</u>	<u>89</u>	<u>81</u>	<u>4.5</u>	<u>0.25</u>	<u>9.8</u>
<u>3</u>	<u>90</u>	<u>0.56</u>	<u>1.3</u>	<u>590.65</u>	<u>308</u>	<u>253</u>	<u>250</u>	<u>57</u>	<u>90</u>	<u>82</u>	<u>5.0</u>	<u>0.25</u>	<u>10.0</u>
<u>4</u>	<u>95</u>	<u>0.64</u>	<u>1.5</u>	<u>594.07</u>	<u>307</u>	<u>251</u>	<u>250</u>	<u>56</u>	<u>90</u>	<u>82</u>	<u>5.5</u>	<u>0.25</u>	<u>10.5</u>
<u>5</u>	<u>100</u>	<u>0.74</u>	<u>1.7</u>	<u>597.715</u>	<u>308</u>	<u>250</u>	<u>250</u>	<u>56</u>	<u>91</u>	<u>82</u>	<u>5.5</u>	<u>0.25</u>	<u>10.3</u>
<u>1-1</u>	<u>105</u>	<u>0.55</u>	<u>1.3</u>	<u>601.09</u>	<u>306</u>	<u>250</u>	<u>250</u>	<u>59</u>	<u>89</u>	<u>83</u>	<u>5.0</u>	<u>0.25</u>	<u>10.0</u>
<u>2</u>	<u>110</u>	<u>0.54</u>	<u>1.3</u>	<u>604.32</u>	<u>308</u>	<u>249</u>	<u>250</u>	<u>59</u>	<u>90</u>	<u>83</u>	<u>5.0</u>	<u>0.25</u>	<u>10.0</u>
<u>3</u>	<u>115</u>	<u>0.43</u>	<u>1.0</u>	<u>607.20</u>	<u>308</u>	<u>250</u>	<u>251</u>	<u>59</u>	<u>92</u>	<u>84</u>	<u>4.5</u>	<u>0.25</u>	<u>10.3</u>
<u>4</u>	<u>120</u>	<u>0.40</u>	<u>0.94</u>	<u>609.97</u>	<u>307</u>	<u>251</u>	<u>250</u>	<u>60</u>	<u>91</u>	<u>84</u>	<u>4.5</u>	<u>0.25</u>	<u>10.1</u>
<u>5</u>	<u>125</u>	<u>0.51</u>	<u>1.2</u>	<u>613.125</u>	<u>307</u>	<u>251</u>	<u>250</u>	<u>61</u>	<u>91</u>	<u>84</u>	<u>5.0</u>	<u>0.25</u>	<u>10.3</u>
	Total												
	Average												

Sum of square roots.

Circle correct bracketed units on data sheet.

QA/QC FB
Date 3/18/10




TEST LOCATION: FF Outlet
 UNIT: 2 RUN: 3

Purified/Model's TESTING
 FIELD DATA SHEET

METHOD: 5/29 PAGE 1 OF 2

Client Wpurbator Project No. 10955
 Plant N. Brown Date 3/18/10
 Meter Operator P. Bihun
 Probe Operator P. Bihun

Meter Box 66-24 Sample Box No. M15
 Meter Y_d 0.9904 Meter ΔH₀ 1.716
 K Factor 2.35 Pitot C_p 0.805
 Leak Rate Before 0.0038 [Lpm] @ 15 (in. Hg)
 Leak Rate After 0.0036 [Lpm] @ 9 (in. Hg)
 Pitot Leak Check Before: After: Good Bad



Amb. Temp. (°F) 70 Bar. Press. 30.07 (in. Hg) [mbar]
 Probe I.D. No. 678-4
 Liner Material Glass

Filter No. B-115-32
 Thimble No. N/A
 Nozzle Diameter 0.270 Nozzle I.D. 270-1

Start Time: 12:27 Stop Time: 14:39

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. [L]	Stack Temp. T _s (°F)	Probe T _p (°F)	Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{max} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T _t (°F)	Notes
						Set Points							
				<u>6134.55</u>		<u>200</u>	<u>250</u>					<u>0.25</u>	<u>0.2</u>
1	5	<u>0.45</u>	<u>1.1</u>	<u>616.54</u>	<u>306</u>	<u>246</u>	<u>257</u>	<u>63</u>	<u>83</u>	<u>84</u>	<u>4.5</u>	<u>0.25</u>	<u>10.4</u>
2	10	<u>0.45</u>	<u>1.1</u>	<u>619.54</u>	<u>307</u>	<u>256</u>	<u>253</u>	<u>53</u>	<u>84</u>	<u>84</u>	<u>4.0</u>	<u>0.25</u>	<u>10.3</u>
3	15	<u>0.43</u>	<u>1.0</u>	<u>622.40</u>	<u>306</u>	<u>252</u>	<u>251</u>	<u>48</u>	<u>86</u>	<u>83</u>	<u>3.5</u>	<u>0.25</u>	<u>10.4</u>
4	20	<u>0.71</u>	<u>1.7</u>	<u>626.06</u>	<u>307</u>	<u>252</u>	<u>250</u>	<u>47</u>	<u>88</u>	<u>83</u>	<u>4.5</u>	<u>0.25</u>	<u>9.6</u> <u>K=240</u>
5	25	<u>0.73</u>	<u>1.8</u>	<u>629.85</u>	<u>308</u>	<u>249</u>	<u>249</u>	<u>49</u>	<u>90</u>	<u>83</u>	<u>5.0</u>	<u>0.25</u>	<u>10.3</u> <u>629.20</u>
2-1	30	<u>0.69</u>	<u>1.7</u>	<u>633.63</u>	<u>306</u>	<u>250</u>	<u>250</u>	<u>50</u>	<u>89</u>	<u>83</u>	<u>4.5</u>	<u>0.25</u>	<u>10.0</u> <u>(0.065)</u>
2	35	<u>0.73</u>	<u>1.8</u>	<u>637.48</u>	<u>307</u>	<u>245</u>	<u>250</u>	<u>51</u>	<u>91</u>	<u>84</u>	<u>5.0</u>	<u>0.25</u>	<u>10.2</u>
3	40	<u>0.70</u>	<u>1.7</u>	<u>641.22</u>	<u>308</u>	<u>248</u>	<u>250</u>	<u>51</u>	<u>92</u>	<u>84</u>	<u>5.0</u>	<u>0.25</u>	<u>9.7</u>
4	45	<u>0.60</u>	<u>1.4</u>	<u>644.64</u>	<u>308</u>	<u>251</u>	<u>250</u>	<u>52</u>	<u>93</u>	<u>85</u>	<u>4.5</u>	<u>0.25</u>	<u>9.8</u>
5	50	<u>0.67</u>	<u>1.6</u>	<u>648.22</u>	<u>308</u>	<u>249</u>	<u>249</u>	<u>53</u>	<u>92</u>	<u>85</u>	<u>5.0</u>	<u>0.25</u>	<u>10.0</u> <u>648.220</u>
3-1	55	<u>0.50</u>	<u>1.2</u>	<u>651.40</u>	<u>306</u>	<u>248</u>	<u>249</u>	<u>54</u>	<u>90</u>	<u>84</u>	<u>4.0</u>	<u>0.25</u>	<u>9.9</u> <u>(0.04)</u>
2	60	<u>0.51</u>	<u>1.2</u>	<u>654.52</u>	<u>308</u>	<u>248</u>	<u>250</u>	<u>54</u>	<u>90</u>	<u>84</u>	<u>4.0</u>	<u>0.25</u>	<u>10.3</u>
Total													
Average				<u>85.170</u>		<u>307.760</u>							

Sum of square roots. 17.3
 Circle correct bracketed units on data sheet. 3685 QA/QC P15 Date 3/18/10
2074 86.480

G-29



TEST LOCATION: FF Outlet

UNIT: 2 RUN: 3


Park on Lake / Metals TESTING
FIELD DATA SHEET

METHOD: 5729 PAGE 2 OF 2

Client <u>Whisper</u>	Project No. <u>10911</u>
Plant <u>N. Branch</u>	Date <u>3/18/10</u>
Meter Operator <u>P. Bihan</u>	
Probe Operator <u>P. Bihan</u>	

Meter Box	Sample Box No.
Meter Y _d	Meter ΔH _@
K Factor	Pitot C _p

Leak Rate Before [cfm] [Lpm] @ (in. Hg)
Leak Rate After [cfm] [Lpm] @ (in. Hg)
Pitot Leak Check Before: <input type="checkbox"/> After: Good <input type="checkbox"/> Bad <input type="checkbox"/>



Duct Dimensions (in.)			
Static Pres (in. H ₂ O)	Port Len. (in.)	Gas Flow [In] [Out]	First point all the way of page [In] [Out]

Amb. Temp. (°F)	Bar. Press. [in. Hg] [mbar]
Probe I.D. No.	
Liner Material	

Filter No.	
Thimble No.	
Nozzle Diameter	Nozzle I.D.

Start Time:	Stop Time:
-------------	------------

Traverse Point Number	Min/pt. Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. (ft ³) [L]	Stack Temp. T _s (°F)	Probe T _p (°F)		Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{out} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T _t (°F)	Notes
						Set Points	Set Points							
						270	250							
3	65	0.56	1.3	657.79	308	253	250	54	90	84	4.5	0.25	10.0	
4	70	0.65	1.6	661.41	308	251	249	54	91	84	5.0	0.25	10.0	
5	75	0.66	1.6	665.025	308	251	250	56	92	84	5.0	0.25	10.0	602.060
4-1	80	0.55	1.3	668.31	309	247	250	60	89	84	4.5	0.25	9.7	(9.035)
2	85	0.56	1.3	671.58	309	217	257	60	90	83	4.5	0.25	9.9	
3	90	0.66	1.6	675.21	310	251	250	60	90	83	5.0	0.25	10.3	
4	95	0.70	1.7	678.95	309	252	250	61	91	83	5.0	0.25	10.6	
5	100	0.72	1.7	682.670	308	250	250	63	92	84	5.0	0.25	10.2	602.740
5-1	105	0.24	0.58	684.890	307	248	250	63	89	84	3.5	0.25	10.7	(9.07)
2	110	0.61	1.5	688.24	310	247	250	56	88	83	5.0	0.25	11.0	
3	115	0.64	1.5	691.73	308	251	250	52	89	83	5.0	0.25	10.9	
4	120	0.67	1.6	695.33	308	240	244	49	88	82	5.0	0.25	11.0	
5	120	0.63	1.5	698.840	307	242	245	49	88	82	5.0	0.25	10.6	
Total														
Average														

Sum of square roots.

Circle correct bracketed units on data sheet.

QA/QC Date 3/18/10



G-30

Impinger Weight Sheet

Client Wheelabrator		Unit Name/Location Unit 2 FF Outlet	
Plant North Broward	Job No. 10955	Method	5/29

Run No. 1	Filter Type Quartz	Sample Box No. <i>M15</i>
Date <i>3/18/10</i>	Lot No.	pH
Analyst <i>B. Wilke</i>	Filter No. <i>E-115-30</i>	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty	<i>723.5</i>	<i>463.1</i>	<i>260.4</i>	
Impinger 2	100 ml 5%HNO3/10%H2O2	<i>689.7</i>	<i>543.1</i>	<i>146.6</i>	QA/QC <i>BW</i> Date <i>3/18</i>
Impinger 3	100 ml 5%HNO3/10%H2O2	<i>580.8</i>	<i>560.0</i>	<i>30.8</i>	
Impinger 4	Empty	<i>445.8</i>	<i>440.0</i>	<i>5.8</i>	
Impinger 5	100 ml 4%KMnO4/10%H2SO4	<i>541.9</i>	<i>540.1</i>	<i>1.8</i>	Total Weight (gm)
Impinger 6	100 ml 4%KMnO4/10%H2SO4	<i>562.0</i>	<i>562.2</i>	<i>-0.2</i>	<i>445.2</i>
Impinger 7	Silica Gel	<i>742.7</i>	<i>728.5</i>	<i>14.2</i>	<i>459.4</i>

Run No. 2	Filter Type Quartz	Sample Box No. <i>M10</i>
Date <i>3/18/10</i>	Lot No.	pH
Analyst <i>B. Wilke</i>	Filter No. <i>E-115-31</i>	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty	<i>720.2</i>	<i>440.9</i>	<i>279.3</i>	
Impinger 2	100 ml 5%HNO3/10%H2O2	<i>666.6</i>	<i>559.6</i>	<i>107.0</i>	QA/QC <i>BW</i> Date <i>3/18</i>
Impinger 3	100 ml 5%HNO3/10%H2O2	<i>562.4</i>	<i>539.1</i>	<i>23.3</i>	
Impinger 4	Empty	<i>454.2</i>	<i>447.6</i>	<i>6.6</i>	
Impinger 5	100 ml 4%KMnO4/10%H2SO4	<i>546.3</i>	<i>542.7</i>	<i>3.6</i>	Total Weight (gm)
Impinger 6	100 ml 4%KMnO4/10%H2SO4	<i>547.1</i>	<i>546.8</i>	<i>0.3</i>	<i>420.1</i>
Impinger 7	Silica Gel	<i>714.1</i>	<i>700.0</i>	<i>14.1</i>	<i>434.2</i>

Run No. 3	Filter Type Quartz	Sample Box No.
Date <i>3/18/10</i>	Lot No.	pH
Analyst <i>B. Wilke</i>	Filter No.	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty	<i>732.3</i>	<i>463.4</i>	<i>268.9</i>	
Impinger 2	100 ml 5%HNO3/10%H2O2	<i>677.1</i>	<i>540.4</i>	<i>136.7</i>	QA/QC <i>BW</i> Date <i>3/18</i>
Impinger 3	100 ml 5%HNO3/10%H2O2	<i>584.4</i>	<i>551.4</i>	<i>33.0</i>	
Impinger 4	Empty	<i>444.3</i>	<i>440.5</i>	<i>3.8</i>	
Impinger 5	100 ml 4%KMnO4/10%H2SO4	<i>563.6</i>	<i>539.6</i>	<i>24.0</i>	Total Weight (gm)
Impinger 6	100 ml 4%KMnO4/10%H2SO4	<i>563.6</i>	<i>563.4</i>	<i>0.2</i>	<i>444.4</i>
Impinger 7	Silica Gel	<i>711.7</i>	<i>692.5</i>	<i>19.2</i>	<i>463.6</i>




TEST LOCATION: OUTLET
 UNIT: 2 RUN: 1

Fluorine TESTING
FIELD DATA SHEET

METHOD: 13B PAGE 1 OF 2

Client Wheelabrator Project No. 10955
 Plant N. Brown Date 3.18.10
 Meter Operator N. Hitchens
 Probe Operator N. Hitchens



Amb. Temp. (°F) 60 Bar. Press. 30.05 [in. Hg] [mbar]
 Probe I.D. No. 67-8-14
 Liner Material GLASS

Meter Box 66-14 Sample Box No. B6
 Meter Y_d 0.9998 Meter ΔH_@ 1.7643
 K Factor 2.33 Pitot C_p 0.812

Filter No. NA
 Thimble No.
 Nozzle Diameter 0.268 Nozzle I.D. 0.268-1

Leak Rate Before 0.004 [cfm] [Lpm] @ 15 (in. Hg)
 Leak Rate After 0.004 [cfm] [Lpm] @ 15 (in. Hg)
 Pitot Leak Check Before: After: Good Bad

Duct Dimensions (in.)
 Static Pres (in. H₂O) -10.4 Port Len. (in.) 10 Gas Flow (In) [Out] of page First point all the way (In) [Out]

Start Time: 7:09 Stop Time: 8:24

G-32

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. [ft ³] [L]	Stack Temp. T _s (°F)	Probe T _p (°F)		Cond. Temp. T _c (°F)	DGM Inlet T _{m in} (°F)	DGM Outlet T _{m out} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T ₁ (°F)	Notes
						Set Points	Set Points						
				<u>499.215</u>		<u>250</u>	<u>250</u>					<u>165</u>	<u>O₂</u>
<u>4</u>	<u>2:30</u>	<u>0.150</u>	<u>1.2</u>	<u>500.77</u>	<u>305</u>	<u>250</u>	<u>250</u>	<u>45</u>	<u>58</u>	<u>56</u>	<u>3</u>	<u>0.3</u>	<u>10.5</u>
<u>2</u>	<u>5</u>	<u>0.47</u>	<u>1.1</u>	<u>502.26</u>	<u>307</u>	<u>250</u>	<u>250</u>	<u>44</u>	<u>58</u>	<u>56</u>	<u>3</u>	<u>0.3</u>	<u>10.0</u>
<u>3</u>	<u>7:30</u>	<u>0.45</u>	<u>1.0</u>	<u>503.35</u>	<u>307</u>	<u>250</u>	<u>250</u>	<u>42</u>	<u>60</u>	<u>56</u>	<u>3</u>	<u>0.3</u>	<u>10.0</u>
<u>4</u>	<u>10</u>	<u>0.43</u>	<u>1.0</u>	<u>505.00</u>	<u>306</u>	<u>250</u>	<u>250</u>	<u>41</u>	<u>62</u>	<u>56</u>	<u>3</u>	<u>0.3</u>	<u>10.0</u>
<u>5</u>	<u>12:30</u>	<u>0.42</u>	<u>1.0</u>	<u>506.380</u>	<u>306</u>	<u>251</u>	<u>249</u>	<u>40</u>	<u>63</u>	<u>57</u>	<u>3</u>	<u>0.3</u>	<u>10.3</u> <u>506.465</u>
<u>3-1</u>	<u>15</u>	<u>0.45</u>	<u>1.0</u>	<u>507.85</u>	<u>305</u>	<u>249</u>	<u>248</u>	<u>42</u>	<u>63</u>	<u>57</u>	<u>3</u>	<u>0.3</u>	<u>10.4</u> <u>-0.085</u>
<u>2</u>	<u>17:30</u>	<u>0.47</u>	<u>1.1</u>	<u>509.32</u>	<u>307</u>	<u>251</u>	<u>249</u>	<u>41</u>	<u>64</u>	<u>58</u>	<u>3</u>	<u>0.3</u>	<u>9.2</u>
<u>3</u>	<u>20</u>	<u>0.50</u>	<u>1.2</u>	<u>510.82</u>	<u>306</u>	<u>250</u>	<u>250</u>	<u>42</u>	<u>67</u>	<u>58</u>	<u>3</u>	<u>0.3</u>	<u>10.2</u>
<u>4</u>	<u>22:30</u>	<u>0.58</u>	<u>1.4</u>	<u>512.44</u>	<u>307</u>	<u>250</u>	<u>249</u>	<u>44</u>	<u>68</u>	<u>59</u>	<u>3</u>	<u>0.3</u>	<u>10.2</u>
<u>5</u>	<u>25</u>	<u>0.56</u>	<u>1.3</u>	<u>513.995</u>	<u>307</u>	<u>250</u>	<u>249</u>	<u>46</u>	<u>69</u>	<u>59</u>	<u>3</u>	<u>0.3</u>	<u>10.3</u> <u>514.065</u>
<u>2-1</u>	<u>27:30</u>	<u>0.63</u>	<u>1.5</u>	<u>515.73</u>	<u>306</u>	<u>249</u>	<u>249</u>	<u>50</u>	<u>68</u>	<u>60</u>	<u>3</u>	<u>0.3</u>	<u>11.0</u> <u>-0.07</u>
<u>2</u>	<u>30</u>	<u>0.60</u>	<u>1.4</u>	<u>517.35</u>	<u>308</u>	<u>250</u>	<u>250</u>	<u>51</u>	<u>70</u>	<u>60</u>	<u>3</u>	<u>0.3</u>	<u>10.4</u>
<u>3</u>	<u>32:30</u>	<u>0.60</u>	<u>1.4</u>	<u>518.95</u>	<u>307</u>	<u>250</u>	<u>249</u>	<u>54</u>	<u>71</u>	<u>60</u>	<u>3</u>	<u>0.3</u>	<u>10.3</u>
	Total	<u>18.2597</u>	<u>31.4000</u>	<u>38.985</u> <u>5B</u>	<u>7656</u>				<u>842</u> <u>1717</u>	<u>752</u> <u>1510</u>			
	Average	<u>0.7304</u>	<u>1.2560</u>	<u>38.080</u>	<u>306.2400</u>				<u>64.5400</u>				

Sum of square roots.

Circle correct bracketed units on data sheet.

TEST LOCATION: FF
OUTLET


UNIT: 2 RUN: 1

Fluoride TESTING

FIELD DATA SHEET

METHOD: 13A PAGE 2 OF 2

Client <u>Wheelabrator</u>	Project No. <u>10955</u>
Plant <u>N. Broward</u>	Date <u>3.18.10</u>
Meter Operator <u>N. Hutchins</u>	
Probe Operator <u>N. Hutchins</u>	



Amb. Temp. (°F)	Bar. Press.	[in. Hg] [mbar]
Probe I.D. No.		
Liner Material		

Meter Box <u>66-14</u>	Sample Box No. <u>BC</u>
Meter Y _d <u>0.9898</u>	Meter ΔH _@ <u>1.7643</u>
K Factor <u>2.33</u>	Pitot C _p <u>0.812</u>

Filter No.	
Thimble No.	
Nozzle Diameter	Nozzle I.D.

Leak Rate Before [cfm] [Lpm] @ (in. Hg)	
Leak Rate After [cfm] [Lpm] @ (in. Hg)	
Pitot Leak Check Before: <input type="checkbox"/> After: Good <input type="checkbox"/> Bad <input type="checkbox"/>	

Duct Dimensions (in.)			
Static Pres (in. H ₂ O)	Port Len. (in.)	Gas Flow (in) [Out]	First point all the way (in) [Out]
<u>-10.4</u>	<u>10</u>		

Start Time:	Stop Time: <u>8:24</u>
-------------	------------------------

Traverse Point Number	Min/pt <u>2:30</u> Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. (L)	Stack Temp. T _s (°F)	Probe T _p (°F)	Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{min} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T _t (°F)	Notes
						Set Points							
2-4	<u>35</u>	<u>0.68</u>	<u>1.4</u>	<u>520.70</u>	<u>305</u>	<u>290</u>	<u>249</u>	<u>63</u>	<u>73</u>	<u>61</u>	<u>3</u>	<u>0.3</u>	<u>10.7</u>
5	<u>37:30</u>	<u>0.66</u>	<u>1.5</u>	<u>522.380</u>	<u>305</u>	<u>250</u>	<u>250</u>	<u>63</u>	<u>73</u>	<u>61</u>	<u>3</u>	<u>0.3</u>	<u>11.2</u> <u>522.455</u>
1-1	<u>40</u>	<u>0.46</u>	<u>1.1</u>	<u>523.89</u>	<u>306</u>	<u>250</u>	<u>250</u>	<u>63</u>	<u>70</u>	<u>62</u>	<u>3</u>	<u>0.3</u>	<u>10.9</u> <u>-0.075</u>
2	<u>42:30</u>	<u>0.50</u>	<u>1.2</u>	<u>525.39</u>	<u>308</u>	<u>250</u>	<u>249</u>	<u>65</u>	<u>72</u>	<u>62</u>	<u>3</u>	<u>0.3</u>	<u>10.6</u>
3	<u>45</u>	<u>0.46</u>	<u>1.1</u>	<u>526.86</u>	<u>303</u>	<u>250</u>	<u>250</u>	<u>66</u>	<u>72</u>	<u>63</u>	<u>3</u>	<u>0.3</u>	<u>10.6</u>
4	<u>47:30</u>	<u>0.48</u>	<u>1.1</u>	<u>528.33</u>	<u>307</u>	<u>250</u>	<u>249</u>	<u>66</u>	<u>73</u>	<u>63</u>	<u>3</u>	<u>0.3</u>	<u>10.2</u>
5	<u>50</u>	<u>0.68</u>	<u>1.6</u>	<u>529.700</u>	<u>306</u>	<u>250</u>	<u>249</u>	<u>66</u>	<u>74</u>	<u>63</u>	<u>4</u>	<u>0.3</u>	<u>11.0</u> <u>530.195</u>
5-1	<u>52:30</u>	<u>0.30</u>	<u>0.70</u>	<u>531.35</u>	<u>306</u>	<u>249</u>	<u>249</u>	<u>62</u>	<u>71</u>	<u>64</u>	<u>2</u>	<u>0.3</u>	<u>11.0</u> <u>-0.495</u>
2	<u>55</u>	<u>0.57</u>	<u>1.3</u>	<u>532.92</u>	<u>306</u>	<u>250</u>	<u>249</u>	<u>60</u>	<u>72</u>	<u>64</u>	<u>3</u>	<u>0.3</u>	<u>11.2</u>
3	<u>57:30</u>	<u>0.66</u>	<u>1.5</u>	<u>534.60</u>	<u>307</u>	<u>251</u>	<u>250</u>	<u>59</u>	<u>74</u>	<u>65</u>	<u>3</u>	<u>0.3</u>	<u>10.9</u>
4	<u>60</u>	<u>0.70</u>	<u>1.6</u>	<u>536.33</u>	<u>306</u>	<u>250</u>	<u>249</u>	<u>58</u>	<u>75</u>	<u>65</u>	<u>3</u>	<u>0.3</u>	<u>11.4</u>
5	<u>62:30</u>	<u>0.65</u>	<u>1.5</u>	<u>538.026</u>	<u>307</u>	<u>251</u>	<u>250</u>	<u>57</u>	<u>76</u>	<u>65</u>	<u>3</u>	<u>0.3</u>	<u>10.6</u>
	Total *		<u>15.8</u>		<u>3672</u>				<u>875</u>	<u>750</u>			
	Average												

* Sum of square roots.

Circle correct bracketed units on data sheet.


TEST LOCATION: FF OUTLET
 UNIT: 2 RUN: 2

Floor: 2e

TESTING

METHOD: 13B PAGE 1 OF 2

FIELD DATA SHEET



Client <u>Wheelabrator</u>	Project No. <u>10955</u>
Plant <u>N. Broward</u>	Date <u>3.18.10</u>
Meter Operator <u>N. Hutchins</u>	
Probe Operator <u>"</u>	

Amb. Temp. (°F) <u>60</u>	Bar. Press. <u>30.05</u> (in) Hg [mbar]
Probe I.D. No. <u>67-8-14</u>	
Liner Material <u>GLASS</u>	

Meter Box <u>66-14</u>	Sample Box No. <u>B7</u>
Meter Y _d <u>0.5898</u>	Meter ΔH _@ <u>1.7643</u>
K Factor <u>2.33</u>	Pitot C _p <u>0.812</u>
Leak Rate Before <u>0.002</u> (m) [Lpm] @ <u>15</u> (in. Hg)	
Leak Rate After <u>0.002</u> (m) [Lpm] @ <u>15</u> (in. Hg)	
Pitot Leak Check Before: <input checked="" type="checkbox"/> After: Good <input checked="" type="checkbox"/> Bad <input type="checkbox"/>	

Filter No.		
Thimble No.		
Nozzle Diameter <u>0.268</u>	Nozzle I.D.	<u>0.268-1</u>

Start Time: <u>8:56</u>	Stop Time: <u>10:10</u>
-------------------------	-------------------------

G-34

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. (L)	Stack Temp. T _s (°F)	Probe T _p (°F)	Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{m in} (°F)	DGM Outlet T _{m out} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T ₁ (°F)	Notes
						Set Points							
				<u>538.420</u>		<u>250</u>	<u>250</u>					<u>IGS</u>	<u>O₂</u>
5-1	2:30	0.63	1.5	540.17	304	248	248	62	69	67	3	0.3	11.3
2	5	0.63	1.5	541.85	304	249	248	56	71	67	3	0.3	11.4
3	7:30	0.64054	1.3	543.43	302	250	248	53	72	67	3	0.3	10.3
4	10	0.51	1.2	544.94	303	250	250	50	74	67	3	0.3	11.2
5	12:30	0.46	1.1	546.405	304	250	249	48	75	68	3	0.3	9.8 546.475
4-1	15	0.45	1.0	547.86	306	249	248	49	74	68	3	0.3	10.1
2	17:30	0.45	1.0	549.25	305	249	249	49	75	68	3	0.3	11.0
3	20	0.45	1.0	550.65	305	250	249	47	76	68	3	0.3	10.1
4	22:30	0.46	1.1	552.12	305	251	249	48	77	68	3	0.3	10.2
5	25	0.46	1.1	553.595	305	250	249	48	78	69	3	0.3	10.8 553.650
3-1	27:30	0.47	1.1	555.12	305	248	249	51	76	69	3	0.3	11.2
2	30	0.42	0.99	556.49	307	250	248	49	77	69	3	0.3	9.9
3	32:30	0.42	0.99	557.87	307	251	249	49	77	70	3	0.3	9.8
	Total	<u>17.9498</u>	<u>20.9800</u>	<u>37.3850</u>	<u>7636</u>				<u>971</u>	<u>885</u>			
	Average	<u>0.7020</u>	<u>1.1592</u>	<u>305.4400</u>					<u>73.1600</u>				

Sum of square roots.
 0.105
 0.07
 0.055
 2.05
 14.88

Circle correct bracketed units on data sheet
 3962 QA/QC NH
 Date 3.18.10



TEST LOCATION: FF OUTLET

Fluv. 2e

TESTING

METHOD: 13B PAGE 2 OF 2

UNIT: 2 RUN: 2

FIELD DATA SHEET

Client <u>Wheelabrator</u>	Project No. <u>10955</u>
Plant <u>N. Broward</u>	Date <u>3.18.10</u>
Meter Operator <u>N. Hitchins</u>	
Probe Operator <u>N. Hitchins</u>	

Meter Box <u>66-14</u>	Sample Box No. <u>B7</u>
Meter Y _d <u>0.9898</u>	Meter ΔH _@ <u>1.7643</u>
K Factor <u>2.33</u>	Pitot C _p <u>0.912</u>

Leak Rate Before [cfm] [Lpm] @ (in. Hg)	
Leak Rate After [cfm] [Lpm] @ (in. Hg)	
Pitot Leak Check Before: <input type="checkbox"/> After: Good <input type="checkbox"/> Bad <input type="checkbox"/>	

Cross-Section of Test Location

↑
[N] [UP]

Duct Dimensions (in.)

Static Pres (in. H ₂ O)	Port Len. (in.)	Gas Flow [In] [Out] of page	First point all the way [In] [Out]
------------------------------------	-----------------	-----------------------------	------------------------------------

Amb. Temp. (°F)	Bar. Press. (in. Hg) [mbar]
Probe I.D. No.	
Liner Material	

Filter No.	
Thimble No.	
Nozzle Diameter	Nozzle I.D.

Start Time:	Stop Time: <u>10:10</u>
-------------	-------------------------

Traverse Point Number	Min/pt 2:30 Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. (L)	Stack Temp. T _s (°F)	Probe T _p (°F)	Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{m in} (°F)	DGM Outlet T _{m out} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T _t (°F)	Notes
						250	250					IGS	
3-4	35	0.45	1.0	559.26	306	250	249	49	78	70	3	0.3	10.0
5	37:30	0.47	1.1	560.730	306	250	249	50	79	71	3	0.3	9.8 560.780
2-1	40	0.43	1.0	562.19	305	249	250	53	76	71	3	0.3	11.1
2	42:30	0.43	1.0	563.68	306	250	249	52	78	71	3	0.3	10.0
3	45	0.50	1.2	565.10	306	257	249	51	78	71	3	0.3	10.6
4	47:30	0.59	1.4	566.73	306	257	249	51	80	71	3	0.3	11.1
5	50	0.65	1.5	568.415	307	257	248	50	81	71	3	0.3	10.1 568.520
1-1	52:30	0.45	1.0	569.95	306	250	250	54	77	72	3	0.3	11.2
2	55	0.46	1.1	571.39	306	250	249	51	78	72	3	0.3	11.0
3	57:30	0.44	1.1	572.86	306	250	249	50	80	72	3	0.3	10.8
4	60	0.51	1.2	574.38	307	250	249	50	80	72	3	0.3	11.1
5	62:30	0.63	1.5	576.085	307	250	250	50	81	72	3	0.3	10.9
Total		17.5498	14.10		3074				874.946	856			
Average		0.7020							73.1600				

Sum of square roots.

Circle correct bracketed units on data sheet.

QA/QC JB
Date 3/8




G-35

TEST LOCATION: FF OUTLET
 UNIT: 2 RUN: 3

FLUORIDE TESTING
FIELD DATA SHEET

METHOD: 13B PAGE 1 OF 2

Client <u>Wheelabrator</u>	Project No. <u>10953</u>
Plant <u>N. Broward</u>	Date <u>3.18.10</u>
Meter Operator <u>N. Hitchins</u>	
Probe Operator <u>N. Hitchins</u>	



Amb. Temp. (°F) <u>60</u>	Bar. Press. <u>30.45</u> [in. Hg] [mbar]
Probe I.D. No. <u>67-8-14</u>	
Liner Material <u>glass</u>	

Meter Box <u>66-14</u>	Sample Box No. <u>B5</u>
Meter Y _d <u>0.9898</u>	Meter ΔH _@ <u>1.7643</u>
K Factor <u>2.14</u>	Pitot C _p <u>0.812</u>

Filter No.	
Thimble No.	
Nozzle Diameter <u>0.268</u>	Nozzle I.D. <u>.268-1</u>

Leak Rate Before <u>0.004</u> (cfm) [Lpm] @ <u>15</u> (in. Hg)
Leak Rate After <u>0.003</u> (cfm) [Lpm] @ <u>12</u> (in. Hg)
Pitot Leak Check Before: <input checked="" type="checkbox"/> After: Good <input checked="" type="checkbox"/> Bad <input type="checkbox"/>

Duct Dimensions (in.) <u>96 x 96</u>			
Static Pres (in. H ₂ O) <u>-10.6</u>	Port Len. (in.) <u>10</u>	Gas Flow (in) [Out] of page <u>(in)</u>	First point all the way <u>(in)</u> [Out]

Start Time: <u>10:45</u>	Stop Time: <u>12:05</u>
--------------------------	-------------------------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. (ft) [L]	Stack Temp. T _s (°F)	Probe T _p (°F)		Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{out} (°F)	Pump Vacuum (in.Hg)	XAD Trap Temp. (°F) <u>IGS</u>	Notes
						Set Points	Set Points						
				<u>576.360</u>		<u>250</u>	<u>250</u>						<u>O₂</u>
<u>2-1</u>	<u>2:30</u>	<u>0.52</u>	<u>1.2</u>	<u>577.94</u>	<u>307</u>	<u>248</u>	<u>249</u>	<u>65</u>	<u>75</u>	<u>74</u>	<u>3</u>	<u>0.3</u>	<u>10.3</u>
<u>2</u>	<u>5</u>	<u>0.48</u>	<u>1.1</u>	<u>579.39</u>	<u>306</u>	<u>250</u>	<u>246</u>	<u>62</u>	<u>77</u>	<u>74</u>	<u>3</u>	<u>0.3</u>	<u>10.4</u>
<u>3</u>	<u>7:30</u>	<u>0.49</u>	<u>1.2</u>	<u>580.88</u>	<u>306</u>	<u>250</u>	<u>249</u>	<u>58</u>	<u>79</u>	<u>74</u>	<u>3</u>	<u>0.3</u>	<u>9.2</u>
<u>4</u>	<u>10</u>	<u>0.59</u>	<u>1.4</u>	<u>582.51</u>	<u>305</u>	<u>250</u>	<u>249</u>	<u>56</u>	<u>81</u>	<u>75</u>	<u>3</u>	<u>0.3</u>	<u>11.1</u>
<u>5</u>	<u>12:30</u>	<u>0.62</u>	<u>1.5</u>	<u>584.215</u>	<u>305</u>	<u>250</u>	<u>249</u>	<u>55</u>	<u>82</u>	<u>75</u>	<u>3</u>	<u>0.3</u>	<u>10.1</u> <u>584.320</u>
<u>1-1</u>	<u>15</u>	<u>0.44</u>	<u>1.0</u>	<u>585.73</u>	<u>305</u>	<u>250</u>	<u>248</u>	<u>61</u>	<u>81</u>	<u>76</u>	<u>3</u>	<u>0.3</u>	<u>11.3</u>
<u>2</u>	<u>17:30</u>	<u>0.46</u>	<u>1.1</u>	<u>587.21</u>	<u>305</u>	<u>250</u>	<u>249</u>	<u>57</u>	<u>83</u>	<u>77</u>	<u>3</u>	<u>0.3</u>	<u>10.6</u>
<u>3</u>	<u>20</u>	<u>0.43</u>	<u>1.0</u>	<u>588.61</u>	<u>302</u>	<u>250</u>	<u>249</u>	<u>56</u>	<u>85</u>	<u>77</u>	<u>3</u>	<u>0.3</u>	<u>10.8</u>
<u>4</u>	<u>22:30</u>	<u>0.47</u>	<u>1.0</u>	<u>590.02</u>	<u>304</u>	<u>250</u>	<u>249</u>	<u>58</u>	<u>85</u>	<u>77</u>	<u>3</u>	<u>0.3</u>	<u>10.3</u>
<u>5</u>	<u>25</u>	<u>0.62</u>	<u>1.5</u>	<u>591.725</u>	<u>305</u>	<u>250</u>	<u>250</u>	<u>61</u>	<u>86</u>	<u>78</u>	<u>3</u>	<u>0.3</u>	<u>10.2</u> <u>591.785</u>
<u>3-1</u>	<u>27:30</u>	<u>0.38</u>	<u>0.87</u>	<u>593.11</u>	<u>306</u>	<u>249</u>	<u>247</u>	<u>65</u>	<u>83</u>	<u>79</u>	<u>3</u>	<u>0.3</u>	<u>10.1</u>
<u>2</u>	<u>30</u>	<u>0.46</u>	<u>1.1</u>	<u>594.60</u>	<u>307</u>	<u>250</u>	<u>249</u>	<u>61</u>	<u>84</u>	<u>79</u>	<u>3</u>	<u>0.3</u>	<u>10.0</u>
<u>3</u>	<u>32:30</u>	<u>0.47</u>	<u>1.1</u>	<u>596.07</u>	<u>307</u>	<u>250</u>	<u>248</u>	<u>53</u>	<u>85</u>	<u>79</u>	<u>3</u>	<u>0.3</u>	<u>10.5</u>
	Total	<u>17.7857</u>	<u>30.1700</u>	<u>38.3650</u>	<u>7643</u>				<u>1066</u>	<u>994</u>			
	Average	<u>0.7114</u>	<u>1.2068</u>		<u>305.7200</u>					<u>81.1000</u>			

Sum of square roots. 15.670

Circle correct bracketed units on data sheet.

• 105
• 060
• 065
• 09
3200

3970 QA/QC NH
Date 3.18.10




G-36

TEST LOCATION: FF Outlet
 UNIT: 2 RUN: 3

FLUORIDE TESTING
FIELD DATA SHEET

METHOD: 13B PAGE 2 OF 2

Client <u>Wheelabrator</u>	Project No. <u>10955</u>
Plant <u>N. Broward</u>	Date <u>3.18.10</u>
Meter Operator <u>N. Hitchins</u>	
Probe Operator <u>N. Hitchins</u>	



Amb. Temp. (°F)	Bar. Press.	[in. Hg] [mbar]
Probe I.D. No.		
Liner Material		

Meter Box <u>66-14</u>	Sample Box No. <u>B5</u>
Meter Y _d <u>0.9898</u>	Meter ΔH _@ <u>1.7643</u>
K Factor <u>2.38</u>	Pitot C _p <u>0.812</u>

Filter No.		
Thimble No.		
Nozzle Diameter	Nozzle I.D.	

Leak Rate Before [cfm] [Lpm] @ (in. Hg)	
Leak Rate After [cfm] [Lpm] @ (in. Hg)	
Pitot Leak Check Before: <input type="checkbox"/> After: Good <input type="checkbox"/> Bad <input type="checkbox"/>	

Duct Dimensions (in.) <u>96 x 96</u>			
Static Pres (in. H ₂ O)	Port Len. (in.)	Gas Flow (in) [Out] of page	First point all the way (in) [Out]
<u>-10.6</u>	<u>10</u>		

Start Time:	Stop Time: <u>12:05</u>
-------------	-------------------------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. (ft ³) [L]	Stack Temp. T _s (°F)	Probe T _p (°F)	Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{min} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. (°F)	Notes
						Set Points						IGS	
3-4	35	0.51	1.2	597.60	306	250	250	49	85	79	3	0.3	10.8
5	37:30	0.53	1.3	599.185	306	250	248	47	86	80	3	0.3	11.0 599. 258
4-1	40	0.52	1.3	600.85	307	249	249	50	84	80	3	0.3	10.3
2	42:30	0.51	1.2	602.44	307	250	249	48	85	80	3	0.3	11.0
3	45	0.52	1.2	604 604.08	306	250	249	46	86	80	3	0.3	10.6
4	47:30	0.56	1.3	605.58	307	250	249	46	87	80	3	0.3	10.7
5	50	0.51	1.2	607.150	306	251	249	46	88	80	3	0.3	10.5 607. 240
5-1	52:30	0.25	0.60	608.35	305	249	249	60	83	81	3	0.3	11.4
2	55	0.58	1.4	609.99	306	250	249	52	85	81	3	0.3	10.7
3	57:30	0.64	1.5	611.71	306	250	250	49	86	81	3	0.3	11.2
4	60	0.64	1.5	613.37	306	250	249	46	87	81	3	0.3	10.5
5	62:30	0.58	1.4	615.045	305	250	249	46	88	82	3	0.3	11.2
Total	*								1030	965			
Average													

* Sum of square roots.

Circle correct bracketed units on data sheet.

G-37

15.1

QA/QC SB
 Date 3/18

Impinger Weight Sheet

Client Wheelabrator	Unit Name/Location Unit 2 FF Outlet
Plant North Broward	Job No. 10955 Method 13B

Run No. 1	Filter Type Teflon glass mat	Sample Box No. B6
Date 3/18/10	Lot No.	pH
Analyst R. Vicere	Filter No. NA	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)			
Impinger 1	100 mL DI H2O	645.7	547.6	98.1	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td>QA/QC SB</td></tr> <tr><td>Date 3/18</td></tr> </table>	QA/QC SB	Date 3/18
QA/QC SB							
Date 3/18							
Impinger 2	100 mL DI H2O	642.5	566.6	75.9			
Impinger 3	Empty	482.7	460.8	21.9			
Impinger 4	Silica Gel	772.2	755.7	16.5			
					Total Weight (gm)		
					195.9		
					212.4		

Run No. 2	Filter Type Teflon glass mat	Sample Box No. B7
Date 3/18/10	Lot No.	pH
Analyst R. Vicere / B. Wilkie	Filter No. NA	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)			
Impinger 1	100 mL DI H2O	676.7	542.4	134.3	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td>QA/QC SB</td></tr> <tr><td>Date 3/18</td></tr> </table>	QA/QC SB	Date 3/18
QA/QC SB							
Date 3/18							
Impinger 2	100 mL DI H2O	594.8	541.5	53.3			
Impinger 3	Empty	446.0	437.0	9.0			
Impinger 4	Silica Gel	769.2	755.9	13.3			
					Total Weight (gm)		
					196.6		
					209.9		

Run No. 3	Filter Type Teflon glass mat	Sample Box No. B5
Date 3/19/10	Lot No.	pH
Analyst R. Vicere	Filter No. NA	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)			
Impinger 1	100 mL DI H2O	678.4	538.3	140.1	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td>QA/QC SB</td></tr> <tr><td>Date 3/18</td></tr> </table>	QA/QC SB	Date 3/18
QA/QC SB							
Date 3/18							
Impinger 2	100 mL DI H2O	600.9	556.3	44.6			
Impinger 3	Empty	460.3	452.3	8.0			
Impinger 4	Silica Gel	764.5	755.6	8.9			
					Total Weight (gm)		
					192.7		
					201.6		



TEST LOCATION: OUTLET

DIOXIN TESTING

METHOD: 23 PAGE 1 OF 5


UNIT: 2 RUN: 1

FIELD DATA SHEET

Client <u>Wheelabrator</u>	Project No. <u>10955</u>
Plant <u>N. Broward</u>	Date <u>3.16.10</u>
Meter Operator <u>N. Hitchens</u>	
Probe Operator <u>N. Hitchens</u>	

Meter Box <u>46-6</u>	Sample Box No. <u>D8</u>
Meter Y _d <u>0.9901</u>	Meter ΔH @ <u>1.7870</u>
K Factor <u>2.29</u>	Pitot C _p <u>0.834</u>

Leak Rate Before <u>0.005</u> [cfm] [Lpm]	@ <u>15</u> (in. Hg)
Leak Rate After <u>0.005</u> [cfm] [Lpm]	@ <u>15</u> (in. Hg)
Pitot Leak Check Before: <input checked="" type="checkbox"/>	After: Good <input checked="" type="checkbox"/> Bad <input type="checkbox"/>



Amb. Temp. (°F) <u>72</u>	Bar. Press. [in. Hg] [mbar]
Probe I.D. No. <u>6708-17</u>	
Liner Material <u>GLASS</u>	

Filter No.	
Thimble No.	
Nozzle Diameter <u>0.264</u>	Nozzle I.D. <u>0.264-1</u>

Start Time: <u>8:44</u>	Stop Time: <u>13:36</u>
-------------------------	-------------------------

G-39

Traverse Point Number	Min/pt 5 Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. (lit) [L]	Stack Temp. T _s (°F)	Filter T _f (°F)		Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{max} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T ₁ (°F)	Notes
						250	250						
1-1	5	0.69	1.6	693.89	298	245	249	52	69	62	8	39	10.0 0.10
1	10	0.62	1.4	697.30	297	250	252	48	65	62	8	41	9.8 0.10 0.10
1-2	15	0.50	1.1	700.03	296	251	249	46	67	63	7	42	10.0 0.10 ^{1pm}
2	20	0.49	1.1	703.04	297	252	252	46	69	64	7	42	9.7 0.1
1-3	25	0.50	1.1	705.98	297	251	251	48	70	65	7	42	9.6 0.1
3	30	0.51	1.2	708.99	298	250	250	49	71	65	7	42	9.8 0.1
1-4	35	0.51	1.2	712.03	297	250	250	51	72	67	7	43	8.8 0.1
4	40	0.56	1.3	715.15	296	250	250	51	72	67	7	46	9.6 0.1
1-5	45	0.48	1.1	718.17	295	250	250	45	74	68	7	42	9.3 0.1 ^{0.2}
5	50	0.76	1.7	721.785	298	250	250	43	74	68	9	41	10.2 ^{0.1} 722.405
2-1	55	0.59	1.4	725.74	297	250	253	48	74	70	8	38	10.0 0.1
1	60	0.61	1.4	729.02	297	249	250	41	75	71	8	39	9.6 0.1
	Total	<u>38</u>	<u>38</u>	<u>160.3450</u>	<u>58</u>								
	Average	<u>0.7465</u>	<u>1.2960</u>	<u>300.6600</u>	<u>300.640</u>				<u>80.0500</u>				

Sum of square roots
0.7462 1.294

Circle correct bracketed units on data sheet.

QA/QC NH
Date 3.16.10



TEST LOCATION: OUTLET DIORIN TESTING METHOD: 23 PAGE 2 OF 5

UNIT: 2 RUN: 1

FIELD DATA SHEET

Cross-Section of Test Location



Duct Dimensions (in.)

Static Pres (in. H ₂ O)	Port Len. (in.)	Gas Flow (In) (Out)	First point all the way
-12	10	(In) (Out)	(In) (Out)

Amb. Temp. (°F)	Bar. Press.	[in. Hg] [mbar]
Probe I.D. No.		
Liner Material		

Filter No.		
Thimble No.		
Nozzle Diameter	Nozzle I.D.	

Start Time:	Stop Time:
-------------	------------

Client <u>Wheelabrator</u>	Project No. <u>10955</u>
Plant <u>N. Broward</u>	Date <u>3-16-10</u>
Meter Operator <u>M. H. Jenkins</u>	
Probe Operator <u>M. H. Jenkins</u>	

Meter Box <u>66-6</u>	Sample Box No. <u>D8</u>
Meter Y _d <u>0.9901</u>	Meter ΔH _@ <u>0.834</u>
K Factor <u>2.29</u>	Pitot C _p <u>0.834</u>

Leak Rate Before [cfm] [Lpm] @ (in. Hg)	
Leak Rate After [cfm] [Lpm] @ (in. Hg)	
Pitot Leak Check Before: <input type="checkbox"/> After: Good <input type="checkbox"/> Bad <input type="checkbox"/>	

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. (L)	Stack Temp. T _s (°F)	Probe T _p (°F)		Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{max} (°F)	Pump Vacuum (in.Hg)	XAD Trap Temp. T _t (°F)	Notes
						250	250						
2-2	65	0.61	1.4	732.30	297	249	249	45	76	72	8	40	9.6 0.1
2	70	0.64	1.5	735.97	296	253	252	43	77	72	8	42	9.2 0.1
2-3	75	0.60	1.4	739.11	297	250	251	48	79	73	8	49	9.5 0.1
3	80	0.58	1.4	742.41	297	249	250	52	80	74	9	53	9.4 0.1
2-4	85	0.60	1.4	745.77	297	250	250	54	80	75	9	55	9.5 0.1
4	90	0.53	1.2	748.93	298	249	250	59	80	75	8	55	9.6 0.1
2-5	95	0.54	1.3	752.15	296	249	248	57	80	76	8	55	9.6 0.1
5	100	0.52	1.2	755.290	296	250	250	54	81	76	8	43	9.4 0.1 755.665
3-6	105	0.63	1.5	759.06	297	249	250	53	80	77	9	43	10.2 0.1
1	110	0.63	1.5	762.50	298	249	251	49	82	78	9	46	9.7 0.1
3-2	115	0.55	1.3	765.78	298	251	249	51	83	79	9	53	9.0 0.1
2	120	0.56	1.3	769.03	297	251	250	54	84	80	9	55	10.1 0.1
	Total	*											
	Average												

* Sum of square roots.

Circle correct bracketed units on data sheet.




TEST LOCATION: OUTLET
 UNIT: 2 RUN: 1

DEXIN TESTING
FIELD DATA SHEET

METHOD: 23 PAGE 3 OF 5

Client WHEELABRATOR Project No. 10955
 Plant N. Broward Date _____
 Meter Operator N. Hitchens
 Probe Operator N. Hitchens

Meter Box 66-4 Sample Box No. DB
 Meter Y_d 0.940/ Meter ΔH_@ 1.7870
 K Factor 2.29 Pitot C_p 0.834
 Leak Rate Before [cfm] [Lpm] @ (in. Hg)
 Leak Rate After [cfm] [Lpm] @ (in. Hg)
 Pitot Leak Check Before: After: Good Bad



Amb. Temp. (°F) Bar. Press. [in. Hg] [mbar]
 Probe I.D. No.
 Liner Material

Filter No.
 Thimble No.
 Nozzle Diameter Nozzle I.D.

Start Time: Stop Time:

G-41

Traverse Point Number	Min/pt 5 Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. [ft ³] [L]	Stack Temp. T _s (°F)	Probe T _p (°F)		Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{max} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T ₁ (°F)	Notes
						250	250							
3-3	125	0.51	1.2	772.17	297	250	249	60	85	81	8	61	9.8	0.1
3	130	0.52	1.2	775.30	299	250	250	59	86	81	8	53	9.0	0.1
3-4	135	0.56	1.3	778.52	299	250	250	53	86	82	8	44	9.3	0.1
4	140	0.57	1.3	781.71	301	250	250	57	87	82	8	43	9.4	0.1
3-5	145	0.62 ^{0.62 NH}	1.4	785.06	301	250	252	47	87	83	8	44	9.3	0.1
5	150	0.63	1.5	788.485	301	250	248	47	88	84	9	42	9.3	0.1
4-1	155	0.48	1.1	791.93	304	250	252	51	86	84	8	39	10.5	0.1
1	160	0.46	1.1	794.95	304	250	253	46	87	84	8	40	9.7	0.1
4-2	165	0.45	1.0	797.79	305	250	250	46	88	85	7	42	9.0	0.1
2	170	0.48	1.1	800.69	304	252	258	48	89	85	7	44	9.3	0.1
4-3	175	0.52	1.2	803.79	304	250	252	51	89	86	8	49	9.3	0.1
3	180	0.54	1.3	806.93	305	250	251	55	90	86	8	53	9.8	0.1
Total *														
Average														

* Sum of square roots.

Circle correct bracketed units on data sheet.

TEST LOCATION: OUTLET
 UNIT: 2 RUN: 1


DIOXIN TESTING
FIELD DATA SHEET

METHOD: 23 PAGE 4 OF 5

Client WHEELABRATOR Project No. 10955
 Plant N. BROWARD Date 3-16-10
 Meter Operator N. Hutchins
 Probe Operator N. Hutchins

Meter Box 66-6 Sample Box No. DB
 Meter Y_d 0.9901 Meter ΔH_@ 1.7870
 K Factor 2.29 Pitot C_p 0.834

Leak Rate Before [cfm] [Lpm] @ (in. Hg)
 Leak Rate After [cfm] [Lpm] @ (in. Hg)
 Pitot Leak Check Before: After: Good Bad



Duct Dimensions (in.)			
Static Pres (in. H ₂ O)	Port Len. (in.)	Gas Flow [In] [Out] of page	First point all the way [In] [Out]
-12			

Amb. Temp. (°F) Bar. Press. [in. Hg] [mbar]
 Probe I.D. No.
 Liner Material

Filter No.
 Thimble No.
 Nozzle Diameter Nozzle I.D.

Start Time: Stop Time:

G-42

Traverse Point Number	Min/pt 5 Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. [ft ³] [L]	Stack Temp. T _s (°F)	Probe T _p (°F)		Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{max} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T _i (°F)	Notes	
						250	250								
4-4	185	0.52	1.2	810.10	304	249	253	60	90	86	8	NH ₂ 58	9.3	0.1	
4	190	0.53	1.2	813.05	305	250	250	63	90	87	8	60	9.8	0.1	
4-5	195	0.52	1.2	816.19	305	250	253	59	89	87	8	50	9.5	0.1	.41
5	200	0.55	1.4	819.560	305	250	250	58	89	86	9	45	9.6	0.1	819.970
5-1	205	0.52	1.2	823.03	305	250	250	60	88	86	8	51	9.5	0.1	
1	210	0.53	1.2	826.22	305	250	257	57	87	86	8	46	9.4	0.1	
5-2	215	0.55	1.3	829.43	306	252	248	48	88	86	8	40	9.6	0.1	
2	220	0.56	1.3	832.66	306	252	248	47	88	86	8	40	10.0	0.1	
5-3	225	0.62	1.4	836.03	308	250	250	47	88	86	9	41	9.0	0.1	
3	230	0.61	1.4	839.41	307	250	250	48	89	86	9	42	9.3	0.1	
5-4	235	0.64	1.5	842.89	306	249	249	50	89	86	9	45	10.0	0.1	
4	240	0.64	1.5	846.33	306	249	249	53	89	86	9	48	9.1	0.1	
	Total	*													
	Average														

* Sum of square roots.

Circle correct bracketed units on data sheet.

QA/QC 59
 Date 3/16

TEST LOCATION: OUTLET
 UNIT: 2 RUN: 2

Dioxin TESTING
FIELD DATA SHEET

METHOD: 23 PAGE 1 OF 5

Client <u>Wheelabrator</u>	Project No. <u>10955</u>
Plant <u>N. Browns</u>	Date <u>3.17.10</u>
Meter Operator <u>N. Hutchings</u>	
Probe Operator <u>N. Hutchings</u>	

Meter Box <u>66-6</u>	Sample Box No. <u>D7</u>
Meter Y _d <u>0.9901</u>	Meter ΔH _@ <u>1.7870</u>
K Factor <u>2.41</u>	Pitot C _p <u>0.834</u>

Leak Rate Before <u>0.004</u> (cfm) [Lpm]	@ <u>15</u> (in. Hg)
Leak Rate After <u>0.005</u> (cfm) [Lpm]	@ <u>18</u> (in. Hg)
Pitot Leak Check Before: <input checked="" type="checkbox"/>	After: Good <input type="checkbox"/> Bad <input type="checkbox"/>

Cross-Section of Test Location

Duct Dimensions (in.) 96 x 96

Static Pres (in. H ₂ O)	Port Len. (in.)	Gas Flow (cfm) [Out] of page	First point all the way (cfm) [Out]
<u>-12.5</u>	<u>10</u>		<u>10</u>

Amb. Temp. (°F) <u>64</u>	Bar. Press. <u>30.00</u> [in. Hg] [mbar]
Probe I.D. No. <u>67-8-17</u>	
Liner Material <u>GLASS</u>	

Filter No.	
Thimble No.	
Nozzle Diameter <u>0.264</u>	Nozzle I.D. <u>0.264-1</u>

Start Time: <u>6:54</u>	Stop Time: <u>12:19</u>
-------------------------	-------------------------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. (ft ³) [L]	Stack Temp. T _s (°F)	Probe T _p Filter T _r (°F)		Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{max} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T _t (°F)	Notes
						Set Points							
	<u>5</u>			<u>853.415</u>		<u>250</u>	<u>250</u>						<u>165 (1pm)</u>
<u>5-1</u>	<u>5</u>	<u>0.61</u>	<u>1.5</u>	<u>856.85</u>	<u>305</u>	<u>250</u>	<u>250</u>	<u>51</u>	<u>69</u>	<u>64</u>	<u>10</u>	<u>47</u>	<u>5.6</u> <u>0.1</u>
<u>1</u>	<u>10</u>	<u>0.61</u>	<u>1.5</u>	<u>860.11</u>	<u>306</u>	<u>250</u>	<u>250</u>	<u>52</u>	<u>70</u>	<u>68</u>	<u>12</u>	<u>50</u>	<u>10.1</u> <u>0.1</u>
<u>5-2</u>	<u>15</u>	<u>0.61</u>	<u>1.5</u>	<u>863.43</u>	<u>307</u>	<u>250</u>	<u>250</u>	<u>44</u>	<u>71</u>	<u>68</u>	<u>12</u>	<u>55</u>	<u>9.6</u> <u>0.1</u>
<u>2</u>	<u>20</u>	<u>0.61</u>	<u>1.5</u>	<u>866.83</u>	<u>307</u>	<u>250</u>	<u>255</u>	<u>47</u>	<u>72</u>	<u>68</u>	<u>12</u>	<u>61</u>	<u>10.0</u> <u>0.1</u>
<u>5-3</u>	<u>25</u>	<u>0.59</u>	<u>1.4</u>	<u>870.19</u>	<u>310</u>	<u>257</u>	<u>254</u>	<u>50</u>	<u>73</u>	<u>69</u>	<u>12</u>	<u>53</u>	<u>10.1</u> <u>0.1</u>
<u>3</u>	<u>30</u>	<u>0.59</u>	<u>1.4</u>	<u>873.54</u>	<u>310</u>	<u>250</u>	<u>252</u>	<u>55</u>	<u>73</u>	<u>69</u>	<u>12</u>	<u>43</u>	<u>9.3</u> <u>0.1</u>
<u>5-4</u>	<u>35</u>	<u>0.62</u>	<u>1.5</u>	<u>876.93</u>	<u>309</u>	<u>250</u>	<u>253</u>	<u>60</u>	<u>74</u>	<u>70</u>	<u>12</u>	<u>46</u>	<u>10.1</u> <u>0.1</u>
<u>4</u>	<u>40</u>	<u>0.62</u>	<u>1.5</u>	<u>880.34</u>	<u>309</u>	<u>250</u>	<u>252</u>	<u>58</u>	<u>75</u>	<u>71</u>	<u>12</u>	<u>42</u>	<u>9.8</u> <u>0.1</u>
<u>5-5</u>	<u>45</u>	<u>0.58</u>	<u>1.4</u>	<u>883.69</u>	<u>309</u>	<u>250</u>	<u>253</u>	<u>55</u>	<u>75</u>	<u>71</u>	<u>12</u>	<u>40</u>	<u>9.9</u> <u>0.1</u>
<u>5</u>	<u>50</u>	<u>0.55</u>	<u>1.3</u>	<u>886.945</u>	<u>308</u>	<u>250</u>	<u>250</u>	<u>53</u>	<u>75</u>	<u>71</u>	<u>12</u>	<u>40</u>	<u>9.5</u> <u>0.1</u> <u>587.180</u>
<u>4-1</u>	<u>55</u>	<u>0.56</u>	<u>1.3</u>	<u>890.36</u>	<u>310</u>	<u>250</u>	<u>252</u>	<u>53</u>	<u>74</u>	<u>72</u>	<u>12</u>	<u>41</u>	<u>10.5</u> <u>0.1</u>
<u>1</u>	<u>60</u>	<u>0.54</u>	<u>1.3</u>	<u>893.53</u>	<u>309</u>	<u>249</u>	<u>253</u>	<u>51</u>	<u>74</u>	<u>72</u>	<u>12</u>	<u>39</u>	<u>8.5</u> <u>0.1</u>
	<u>Total</u>			<u>171.615</u>									
	<u>Average</u>	<u>0.79826</u>	<u>1.5220</u>			<u>307.48</u>			<u>74.6100</u>				

Sum of square roots.

Circle correct bracketed units on data sheet.



G-44

TEST LOCATION:

OUTLET

Dioxin

TESTING

METHOD:

23

PAGE

2

OF

5

UNIT:

2

RUN:

2

FIELD DATA SHEET

Cross-Section of Test Location

[N] [UP]

Duct Dimensions (in.) 96 x 96

Static Pres (in. H ₂ O)	Port Len. (in.)	Gas Flow (m) [Out] of page	First point all the way (m) [Out]
-12.5	10		

Client <i>Whitelaborator</i>	Project No. 10955
Plant <i>N. Brown</i>	Date 3.11.10
Meter Operator <i>NHitchins</i>	
Probe Operator <i>NHitchins</i>	

Meter Box <i>66-6</i>	Sample Box No. <i>87</i>
Meter Yd <i>0.9901</i>	Meter ΔH _@ <i>1.7870</i>
K Factor <i>2.41 2.38</i>	Pitot C _p <i>0.834</i>
Leak Rate Before [cfm] [Lpm] @ (in. Hg)	
Leak Rate After [cfm] [Lpm] @ (in. Hg)	
Pitot Leak Check Before: <input type="checkbox"/> After: Good <input type="checkbox"/> Bad <input type="checkbox"/>	

Amb. Temp. (°F)	Bar. Press. [in. Hg] [mbar]
Probe I.D. No.	
Liner Material	

Filter No.	
Thimble No.	
Nozzle Diameter	Nozzle I.D.

Start Time:	Stop Time:
-------------	------------

Traverse Point Number	Min/pt 5 Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. (m) [L]	Stack Temp. T _s (°F)	Probe T _p (°F)		Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{m in} (°F)	DGM Outlet T _{m out} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T ₁ (°F)	Notes
						250	250							
4-2	65	0.62	1.5	896.91	311	252	253	49	77	73	12	43	9.0	0.1
2	70	0.65	1.6	900.40	312	252	252	50	77	73	13	47	9.7	0.1
4-3	75	0.63	1.5	903.87	311	251	252	53	77	73	13	52	9.8	0.1
3	80	0.63	1.5	907.315	311	250	251	57	77	74	13	52	10.1	0.1
4-4	85	0.65	1.5	910.78	308	250	252	54	74	73	13	41	9.9	0.1
4	90	0.62	1.5	914.16	308	251	250	44	74	73	13	44	9.3	0.1
4-5	95	0.77	1.8	917.84	310	250	254	46	77	73	15	47	9.4	0.1
5	100	0.73067	1.7	921.400	308	250	252	49	77	74	14	44	10.4	0.1
3-1	105	0.65	1.5	924.97	308	249	252	55	76	74	13	44	10.6	0.1
1	110	0.68	1.6	928.47	307	250	251	51	77	74	14	45	10.4	0.1
3-2	115	0.61	1.5	931.93	305	252	254	46	78	75	13	41	10.0	0.1
2	120	0.60	1.4	935.28	306	251	251	46	77	75	13	41	10.0	0.1
Total *														
Average														

G-45

165 (lpm)

2.38

9.02

590

* Sum of square roots.

Circle correct bracketed units on data sheet.



TEST LOCATION: OUTLET
 UNIT: 2 RUN: 2


Dioxin TESTING
FIELD DATA SHEET

METHOD: 23 PAGE 3 OF 5

Client Wheelabrator Project No. 10955
 Plant N. Groward Date 3.17.10
 Meter Operator N. Hitchins
 Probe Operator N. Hitchins

Meter Box 66-6 Sample Box No. D7
 Meter Y_d 0.9901 Meter ΔH_@ 1.7870
 K Factor 2.41 2.38 Pitot C_p 0.874

Leak Rate Before [cfm] [Lpm] @ (in. Hg)
 Leak Rate After [cfm] [Lpm] @ (in. Hg)
 Pitot Leak Check Before: After: Good Bad



Duct Dimensions (in.)
 Static Pres (in. H₂O) -12.5 Port Len. (in.) 10 Gas Flow (in. Hg) [Out] of page First point all the way (in. Hg) [Out]

Amb. Temp. (°F) Bar. Press. [in. Hg] [mbar]
 Probe I.D. No.
 Liner Material

Filter No.
 Thimble No.
 Nozzle Diameter Nozzle I.D.

Start Time: Stop Time:

Traverse Point Number	Min/pt. 5 Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. (lit) [L]	Stack Temp. T _s (°F)	Probe T _p (°F) Filter T _f (°F)		Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{max} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T _i (°F)	Notes
						Set Points	Set Points						
3-3	125	0.66	1.6	938.77	308	250	251	47	78	76	14	47	9.8 0.1
3	130	0.65	1.5	942.28	307	250	252	48	79	76	13	47	9.7 0.1
3-4	135	0.65	1.5	945.67	307	250	252	57	78	76	14	57	9.7 0.1
4	140	0.65	1.5	949.10	308	249	253	54	78	76	14	55	9.1 0.1
3-5	145	0.62	1.5	952.54	307	249	253	59	78	76	14	57	9.5 0.1
5	150	0.65	1.5	955.950	307	250	252	64	78	76	14	61	10.8 0.1 956.210
2-1	155	0.67	1.6	959.69	308	249	252	57	77	76	14	57	9.5 0.1
1	160	0.67	1.6	963.16	307	249	254	52	77	76	14	42	9.8 0.1
2-2	165	0.65	1.6	966.75	306	252	252	52	77	76	14	42	9.3 0.1
2	170	0.65	1.5	970.17	307	257	251	53	78	76	14	44	9.0 0.1
2-3	175	0.70	1.7	973.79	307	250	252	55	78	76	15	49	9.2 0.1
3	180	0.70	1.7	977.42	306	249	253	59	77	76	15	55	10.2 0.1
	Total	*											
	Average												

* Sum of square roots. Circle correct bracketed units on data sheet.



G-46


TEST LOCATION: OUTLET
 UNIT: 2 RUN: 2

Dioxin TESTING
FIELD DATA SHEET

METHOD: 23 PAGE 4 OF 5

Client Wheelabrator Project No: 10955
 Plant N. Broward Date 3.17.10
 Meter Operator N. Hitchins
 Probe Operator N. Hitchins

Meter Box 66-6 Sample Box No. D7
 Meter Yd 0.9901 Meter $\Delta H_{@}$ 1.7870
 K Factor 2.41 2.38 Pitot Cp 0.834
 Leak Rate Before [cfm] [Lpm] @ (in. Hg)
 Leak Rate After [cfm] [Lpm] @ (in. Hg)
 Pitot Leak Check Before: After: Good Bad



Amb. Temp. (°F) Bar. Press. [in. Hg] [mbar]
 Probe I.D. No.
 Liner Material

Filter No.
 Thimble No.
 Nozzle Diameter Nozzle I.D.

Start Time: Stop Time:

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. (L)	Stack Temp. T _s (°F)	Probe T _p (°F)	Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{max} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T ₁ (°F)	Notes
						Set Points							
						<u>250</u>	<u>250</u>						
<u>2-4</u>	<u>185</u>	<u>0.68</u>	<u>1.6</u>	<u>980.99</u>	<u>306</u>	<u>250</u>	<u>253</u>	<u>65</u>	<u>78</u>	<u>76</u>	<u>15</u>	<u>59</u>	<u>8.9 0.1</u>
<u>4</u>	<u>190</u>	<u>0.66</u>	<u>1.6</u>	<u>984.49</u>	<u>305</u>	<u>249</u>	<u>254</u>	<u>58</u>	<u>78</u>	<u>76</u>	<u>15</u>	<u>46</u>	<u>9.2 0.1</u>
<u>1-5</u>	<u>195</u>	<u>0.66</u>	<u>1.6</u>	<u>988.00</u>	<u>305</u>	<u>250</u>	<u>250</u>	<u>53</u>	<u>78</u>	<u>76</u>	<u>14</u>	<u>46</u>	<u>9.3 0.1</u>
<u>5</u>	<u>200</u>	<u>0.70</u>	<u>1.7</u>	<u>991.595</u>	<u>305</u>	<u>250</u>	<u>250</u>	<u>53</u>	<u>78</u>	<u>76</u>	<u>15</u>	<u>48</u>	<u>9.0 991.9 10.0 0.1</u>
<u>1-1</u>	<u>205</u>	<u>0.56</u>	<u>1.3</u>	<u>995.65</u>	<u>307</u>	<u>249</u>	<u>248</u>	<u>53</u>	<u>76</u>	<u>76</u>	<u>12</u>	<u>50</u>	<u>10.5 0.1</u>
<u>1</u>	<u>210</u>	<u>0.59</u>	<u>1.4</u>	<u>998.34</u>	<u>307</u>	<u>250</u>	<u>253</u>	<u>53</u>	<u>77</u>	<u>75</u>	<u>13</u>	<u>50</u>	<u>9.8 0.1</u>
<u>1-2</u>	<u>215</u>	<u>0.59</u>	<u>1.4</u>	<u>001.63</u>	<u>306</u>	<u>251</u>	<u>253</u>	<u>58</u>	<u>77</u>	<u>75</u>	<u>13</u>	<u>54</u>	<u>9.9 0.1</u>
<u>2</u>	<u>220</u>	<u>0.59</u>	<u>1.4</u>	<u>004.90</u>	<u>306</u>	<u>251</u>	<u>251</u>	<u>61</u>	<u>76</u>	<u>75</u>	<u>13</u>	<u>56</u>	<u>9.0 0.1</u>
<u>1-3</u>	<u>225</u>	<u>0.59</u>	<u>1.4</u>	<u>008.18</u>	<u>306</u>	<u>250</u>	<u>253</u>	<u>61</u>	<u>76</u>	<u>74</u>	<u>13</u>	<u>50</u>	<u>9.4 0.1</u>
<u>3</u>	<u>230</u>	<u>0.56</u>	<u>1.3</u>	<u>011.43</u>	<u>305</u>	<u>250</u>	<u>250</u>	<u>59</u>	<u>76</u>	<u>74</u>	<u>13</u>	<u>48</u>	<u>9.2 0.1</u>
<u>1-4</u>	<u>235</u>	<u>0.63</u>	<u>1.5</u>	<u>014.81</u>	<u>306</u>	<u>250</u>	<u>253</u>	<u>58</u>	<u>74</u>	<u>73</u>	<u>13</u>	<u>49</u>	<u>9.4 0.1</u>
<u>4</u>	<u>240</u>	<u>0.71</u>	<u>1.7</u>	<u>018.41</u>	<u>306</u>	<u>250</u>	<u>251</u>	<u>58</u>	<u>74</u>	<u>73</u>	<u>15</u>	<u>53</u>	<u>10.0 0.1</u>
	Total												
	Average												

* Sum of square roots. Circle correct bracketed units on data sheet.



G-47

TEST LOCATION: OUTLET
 UNIT: 2 RUN: 2


DUSTIN TESTING
FIELD DATA SHEET

METHOD: 23 PAGE 5 OF 5

Client Wheelabrator Project No. 10955
 Plant N. Broward Date 3.17.10
 Meter Operator N. Hitchins
 Probe Operator N. Hitchins

Meter Box 66-6 Sample Box No. D7
 Meter Yd 0.9901 Meter ΔH@ 1.7870
 K Factor 2.38 Pitot Cp 0.834

Leak Rate Before [cfm] [Lpm] @ (in. Hg)
 Leak Rate After [cfm] [Lpm] @ (in. Hg)
 Pitot Leak Check Before: After: Good Bad



Duct Dimensions (in.)

Static Pres (in. H ₂ O)	Port Len. (in.)	Gas Flow (In/Out) of page	First point all the way (In/Out)
<u>-12.5</u>	<u>10</u>		<u>(In) [Out]</u>

Amb. Temp. (°F) Bar. Press. [in. Hg] [mbar]
 Probe I.D. No.
 Liner Material

Filter No.
 Thimble No.
 Nozzle Diameter Nozzle I.D.

Start Time: Stop Time:

Traverse Point Number	Min/pt 5 Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. <u>(ft³) [L]</u>	Stack Temp. T _s (°F)	Probe T _p (°F)	Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{m in} (°F)	DGM Outlet T _{m out} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T _t (°F)	Notes
						Set Points							
1-5	245	0.80	1.9	022.74	307	250	250	61	72	71	16	53	8.9 0.1
5	250	0.80	1.9	026.030	308	250	256	64	71	71	17	55	9.2 0.1
Total *													
Average													

IGS (lpm)

* Sum of square roots. Circle correct bracketed units on data sheet.



G-48

TEST LOCATION: OUTLET DIOXIN TESTING METHOD: 23 PAGE 1 OF 5

UNIT: 2 RUN: 3

FIELD DATA SHEET

Cross-Section of Test Location



Duct Dimensions (in.) 96 x 96
 Static Pres (in. H₂O) -10.4 Port Len. (in.) 10 Gas Flow (In) Out First point all the way (In) Out of page

Amb. Temp. (°F) 70 Bar. Press. 30.00 [in. Hg] [mbar]
 Probe I.D. No. 67-8-17
 Liner Material GLASS

Filter No. _____
 Thimble No. _____
 Nozzle Diameter 0.264 Nozzle I.D. .264-1

Start Time: 12:53 Stop Time: _____

Client Wheelabrator Project No. 10955
 Plant N. Broward Date 3.17.10
 Meter Operator N. Hitchens
 Probe Operator N. Hitchens

Meter Box 66-24 Sample Box No. DB
 Meter Y_d 0.9904 Meter ΔH_@ 1.7516
 K Factor 2.35 Pitot C_p 0.834
 Leak Rate Before 0.005 [cfm] [Lpm] @ 16 (in. Hg)
 Leak Rate After _____ [cfm] [Lpm] @ _____ (in. Hg)
 Pitot Leak Check Before: After: Good Bad

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. (ft ³) [L]	Stack Temp. T _s (°F)	Probe T _p (°F)	Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{m in} (°F)	DGM Outlet T _{m out} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T _t (°F)	Notes
						Set Points							
	<u>5</u>			<u>277.760</u>		<u>250</u>	<u>250</u>						<u>0.2</u> <u>IGS (1pm)</u>
1-1	<u>5</u>	<u>0.48</u>	<u>1.1</u>	<u>280.78</u>	<u>308</u>	<u>250</u>	<u>250</u>	<u>58</u>	<u>67</u>	<u>69</u>	<u>8</u>	<u>60</u>	<u>10.1</u> <u>0.1</u>
1	<u>10</u>	<u>0.46</u>	<u>1.1</u>	<u>285.84</u>	<u>307</u>	<u>251</u>	<u>251</u>	<u>37</u>	<u>77</u>	<u>68</u>	<u>9</u>	<u>58</u>	<u>10.2</u> <u>0.1</u>
1-2	<u>15</u>	<u>0.62</u>	<u>1.5</u>	<u>287.29</u>	<u>308</u>	<u>251</u>	<u>255</u>	<u>37</u>	<u>72</u>	<u>68</u>	<u>10</u>	<u>52</u>	<u>10.5</u> <u>0.1</u>
2	<u>20</u>	<u>0.56</u>	<u>1.3</u>	<u>290.60</u>	<u>308</u>	<u>251</u>	<u>252</u>	<u>40</u>	<u>74</u>	<u>68</u>	<u>10</u>	<u>49</u>	<u>10.5</u> <u>0.1</u>
1-3	<u>25</u>	<u>0.63</u>	<u>1.5</u>	<u>294.04</u>	<u>307</u>	<u>250</u>	<u>254</u>	<u>40</u>	<u>75</u>	<u>68</u>	<u>11</u>	<u>49</u>	<u>10.8</u> <u>0.1</u>
3	<u>30</u>	<u>0.60</u>	<u>1.4</u>	<u>297.46</u>	<u>306</u>	<u>250</u>	<u>250</u>	<u>39</u>	<u>76</u>	<u>68</u>	<u>11</u>	<u>50</u>	<u>10.9</u> <u>0.1</u>
1-4	<u>35</u>	<u>0.70</u>	<u>1.6</u>	<u>300.30</u>	<u>308</u>	<u>250</u>	<u>250</u>	<u>41</u>	<u>76</u>	<u>68</u>	<u>12</u>	<u>50</u>	<u>10.1</u> <u>0.1</u>
4	<u>40</u>	<u>0.70</u>	<u>1.6</u>	<u>304.60</u>	<u>309</u>	<u>250</u>	<u>250</u>	<u>43</u>	<u>77</u>	<u>68</u>	<u>12</u>	<u>51</u>	<u>10.1</u> <u>0.1</u>
1-5	<u>45</u>	<u>0.76</u>	<u>1.8</u>	<u>308.36</u>	<u>308</u>	<u>250</u>	<u>250</u>	<u>48</u>	<u>77</u>	<u>68</u>	<u>13</u>	<u>53</u>	<u>10.2</u> <u>0.1</u>
5	<u>50</u>	<u>0.75</u>	<u>1.8</u>	<u>312.145</u>	<u>308</u>	<u>250</u>	<u>250</u>	<u>51</u>	<u>77</u>	<u>69</u>	<u>14</u>	<u>54</u>	<u>9.7</u> <u>312.3</u> <u>0.1</u>
2-1	<u>55</u>	<u>0.58</u>	<u>1.4</u>	<u>315.54</u>	<u>308</u>	<u>250</u>	<u>250</u>	<u>58</u>	<u>74</u>	<u>69</u>	<u>10</u>	<u>58</u>	<u>10.7</u> <u>0.1</u>
1	<u>60</u>	<u>0.55</u>	<u>1.3</u>	<u>318.77</u>	<u>307</u>	<u>250</u>	<u>250</u>	<u>62</u>	<u>74</u>	<u>68</u>	<u>10</u>	<u>59</u>	<u>10.2</u> <u>0.1</u>
	Total			<u>166.155</u>									
	Average	<u>0.7614</u>	<u>1.3680</u>			<u>307.8400</u>			<u>72.3700</u>				

Sum of square roots.

Circle correct bracketed units on data sheet.




G-49

004 @ 16

TEST LOCATION: OUTLET DIOXIN TESTING METHOD: 23 PAGE 2 OF 5

UNIT: 2 RUN: 3

FIELD DATA SHEET



Client <u>Wheela brator</u>	Project No. <u>10955</u>
Plant <u>N. BROWARD</u>	Date <u>3.17.10</u>
Meter Operator <u>N. HITCHINS</u>	
Probe Operator <u>N. HITCHINS</u>	

Amb. Temp. (°F)	Bar. Press. [in. Hg] [mbar]
Probe I.D. No.	
Liner Material	

Meter Box <u>66-24</u>	Sample Box No. <u>DB</u>
Meter Y _d <u>0.9904</u>	Meter ΔH _@ <u>1.7516</u>
K Factor <u>2.35</u>	Pitot C _p <u>0.834</u>

Filter No.	
Thimble No.	
Nozzle Diameter	Nozzle I.D.

Leak Rate Before [cfm] [Lpm] @ (in. Hg)	
Leak Rate After [cfm] [Lpm] @ (in. Hg)	
Pitot Leak Check Before: <input type="checkbox"/> After: Good <input type="checkbox"/> Bad <input type="checkbox"/>	

Start Time:	Stop Time:
-------------	------------

G-50

Traverse Point Number	Min/pt 5 Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. (ft ³) [L]	Stack Temp. T _s (°F)	Probe T _p (°F)		Cond. Temp. T _c (°F)	DGM Inlet T _{m in} (°F)	DGM Outlet T _{m out} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T _i (°F)	Notes
						250	250						
2-2	65	0.51	1.2	321.90	307	247	247	45	75	68	10	57	9.0 0.1
2	70	0.51	1.2	324.99	307	248	249	46	75	68	10	56	9.6 0.1
2-3	75	0.56	1.3	328.19	309	250	250	48	76	68	10	56	9.4 0.1
3	80	0.58	1.4	331.52	309	250	250	48	77	68	11	56	10.1 0.1
2-4	85	0.55	1.3	334.81	308	250	250	51	77	68	11	56	10.1 0.1
4	90	0.55	1.3	338.02	310	250	250	54	77	68	11	59	9.5 0.1
2-5	95	0.51	1.2	341.21	308	250	250	59	76	69	11	62	9.8 0.1
5	100	0.54	1.3	344.440	309	250	250	61	76	68	11	64	10.1 344.700 0.1
3-1	105	0.66	1.6	348.27	308	250	250	44	74	68	12	53	10.5 0.1
3-1 2 ^{NA}	110	0.62	1.5	351.79	306	250	247	42	74	68	12	51	10.1 0.1
3-2	115	0.57	1.3	355.10	308	252	252	42	74	68	11	50	10.5 0.1
2	120	0.57	1.3	358.39	308	251	254	44	75	67	11	51	10.2 0.1
Total	*												
Average													

Sum of square roots.

Circle correct bracketed units on data sheet.

QA/QC 58
Date 3/17

003 @ 17

TEST LOCATION:

Outlet

Dioxin

TESTING


METHOD: 23 PAGE 3 OF 5

UNIT: 2

RUN: 3

FIELD DATA SHEET

Cross-Section of Test Location



Duct Dimensions (in.)

Static Pres (in. H ₂ O)	Port Len. (in.)	Gas Flow (In) (Out) of page	First point all the way (In) (Out)
-10.4	10		(In) (Out)

Amb. Temp. (°F)	Bar. Press.	[in. Hg] [mbar]
Probe I.D. No.		
Liner Material		

Filter No.		
Thimble No.		
Nozzle Diameter	Nozzle I.D.	

Start Time:	Stop Time:
-------------	------------

Client <u>Wheelabrator</u>	Project No. <u>10955</u>
Plant <u>N. Broward</u>	Date <u>3.17.10</u>
Meter Operator <u>N. Hitchens</u>	
Probe Operator <u>N. Hitchens</u>	

Meter Box <u>66-24</u>	Sample Box No. <u>58</u>
Meter Y _d <u>0.9904</u>	Meter ΔH _@ <u>1.7516</u>
K Factor <u>2.35</u>	Pitot C _p <u>0.834</u>

Leak Rate Before [cfm] [Lpm] @ (in. Hg)	
Leak Rate After [cfm] [Lpm] @ (in. Hg)	
Pitot Leak Check Before: <input type="checkbox"/> After: Good <input type="checkbox"/> Bad <input type="checkbox"/>	

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. (L)	Stack Temp. T _s (°F)	Probe T _p (°F)	Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{m in} (°F)	DGM Outlet T _{m out} (°F)	Pump Vacuum (in.Hg)	XAD Trap Temp. T _t (°F)	Notes
						Set Points							
3-3	125	0.58	1.4	361.72	308	251	252	47	76	67	11	53	10.6 0.1
3	130	0.55	1.3	364.97	309	250	252	51	76	68	11	56	10.1 0.1
3-4	135	0.56	1.3	368.20	308	250	250	54	76	68	11	58	10.6 0.1
4	140	0.57	1.3	371.45	309	250	253	58	76	68	11	62	10.0 0.1
3-5	145	0.57	1.3	374.72	309	250	253	51	77	68	11	55	10.9 0.1
5	150	0.51	1.2	377.895	308	250	249	45	77	68	11	52	10.1 378.125 0.1
4-1	155	0.60	1.4	381.52	309	249	252	43	74	68	11	48	11.1 0.1
1	160	0.62	1.5	384.98	309	250	254	42	75	68	12	47	11.1 0.1
4-2	165	0.64	1.5	388.44	307	252	254	45	77	69	12	50	10.1 0.1
2	170	0.62	1.5	391.97	307	251	247	47	77	69	12	53	10.1 0.1
4-3	175	0.53	1.2	395.13	307	250	253	52	77	69	11	57	10.3 0.1
3	180	0.53	1.2	398.29	307	250	252	55	77	69	11	60	9.9 0.1
Total	*												
Average													

* Sum of square roots.

Circle correct bracketed units on data sheet.



QA/QC 88
Date 3/17

G-51

3 @ 16


TEST LOCATION: Outlet Dioxin TESTING METHOD: 23 PAGE 4 OF 5

UNIT: 2 RUN: 3

FIELD DATA SHEET

Client <u>Wheelabrator</u>	Project No. <u>10955</u>
Plant <u>N. Broward</u>	Date <u>3.17.10</u>
Meter Operator <u>N. Hutchins</u>	
Probe Operator <u>N. Hutchins</u>	

Meter Box <u>66-24</u>	Sample Box No. <u>88</u>
Meter Y _d <u>0.9904</u>	Meter ΔH _@ <u>1.7516</u>
K Factor <u>2.35</u>	Pitot C _p <u>0.834</u>
Leak Rate Before [cfm] [Lpm] @ (in. Hg)	
Leak Rate After [cfm] [Lpm] @ (in. Hg)	
Pitot Leak Check Before: <input type="checkbox"/> After: Good <input type="checkbox"/> Bad <input type="checkbox"/>	



Duct Dimensions (in.)			
Static Pres (in. H ₂ O)	Port Len. (in.)	Gas Flow (in.) [Out]	First point all the way (in.) [Out]
<u>-10.4</u>	<u>10</u>	<u>(in.)</u> of page	<u>(in.)</u> [Out]

Amb. Temp. (°F)	Bar. Press. [in. Hg] [mbar]
Probe I.D. No.	
Liner Material	

Filter No.	
Thimble No.	
Nozzle Diameter	Nozzle I.D.

Start Time:	Stop Time:
-------------	------------

G-52 4-5 4-5 5-1 1-5 5-2 6-1 5-3 3 5-4 4	Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. (L)	Stack Temp. T _s (°F)	Probe T _p (°F)	Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{out} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T _t (°F)	Notes
							Set Points							
							250	250						
	4	185	0.67	1.6	401.85	308	249	245	59	77	69	12	65	9.2 0.1
	4	190	0.63	1.5	405.38	309	250	257	53	77	69	12	62	10.2 0.1
	4	195	0.65	1.5	408.90	308	249	248	44	77	69	12	59	9.8 0.1
	4	200	0.65	1.5	412.410	308	250	249	45	77	69	12	59	10.9 412.7600.1
	5	205	0.59	1.4	416.12	310	249	257	51	77	69	11	59	10.5 0.1
	1	210	0.52	1.2	419.27	308	250	250	54	77	69	10	60	10.5 0.1
	5	215	0.50	1.2	422.41	307	257	252	58	77	69	10	64	10.2 0.1
	6	220	0.52	1.2	425.59	308	252	255	54	78	70	10	60	10.3 0.1
	5	225	0.51	1.2	428.76	306	250	250	43	79	70	10	54	10.2 0.1
	3	230	0.57	1.2	431.89	307	249	248	44	79	70	10	57	10.1 0.1
	5	235	0.54	1.3	435.08	307	250	250	47	79	71	10	50	9.9 0.1
	4	240	0.55	1.3	438.28	307	249	251	57	79	71	10	57	10.1 0.1
	Total	*												
	Average													

* Sum of square roots.

Circle correct bracketed units on data sheet.

QA/QC BB
Date 3/17



Impinger Weight Sheet

Client Wheelabrator		Unit Name/Location Unit 2 FF Outlet	
Plant North Broward	Job No. 10955	Method	23

Run No. ^{PV} 1 1	Filter Type	Sample Box No. D8
Date 3/16/10	Lot No.	pH
Analyst R. Vicer	Filter No.	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty	1532.1	633.7	898.4	
Impinger 2	100 ml HPLC H2O	483.7	551.1	-67.4	QA/QC 53 Date 3/16
Impinger 3	100 ml HPLC H2O	475.6	529.6	-54.0	
Impinger 4	Empty	440.1	437.1	3.0	
Impinger 5	Trap # T0525-001	398.7	386.3	12.4	Total Weight (gm)
Impinger 6	Silica Gel	842.6	798.5	44.1	792.4
					836.5

Run No. ^{PV} 2 2	Filter Type	Sample Box No. D7
Date 3/17/10	Lot No.	pH
Analyst R. Vicer	Filter No.	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty	1520.8	624.9	895.9	
Impinger 2	100 ml HPLC H2O	542.4	524.1	18.3	QA/QC 53 Date 3/17
Impinger 3	100 ml HPLC H2O	498.5	541.2	-42.7	
Impinger 4	Empty				
Impinger 5	Trap # T0525-002	357.6	346.2	11.4	Total Weight (gm)
Impinger 6	Silica Gel	797.0	736.0	61.0	882.9
					943.9

Run No. ^{PV} 3 3	Filter Type	Sample Box No. D8
Date 3/17/10	Lot No.	pH
Analyst R. Vicer	Filter No.	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty	1460.5	635.1	825.4	
Impinger 2	100 ml HPLC H2O	531.2	531.6	-0.4	QA/QC 53 Date 3/17
Impinger 3	100 ml HPLC H2O	541.3	540.5	0.8	
Impinger 4	Empty				
Impinger 5	Trap # T0525-003	352.7	340.9	11.8	Total Weight (gm)
Impinger 6	Silica Gel	875.1	816.0	59.1	837.6
					896.7




TEST LOCATION: FF outlet
 UNIT: 2 RUN: 1

HCL TESTING
FIELD DATA SHEET

METHOD: 26A PAGE 1 OF 1

Client <u>wheelabrator</u>	Project No. <u>10055</u>
Plant <u>N. Broward</u>	Date <u>3-17-10</u>
Meter Operator <u>A. Obuchowski</u>	
Probe Operator <u>—</u>	

Meter Box <u>66-24</u>	Sample Box No. <u>B11</u>
Meter Y _d <u>0.9904</u>	Meter ΔH _@ <u>1.7516</u>
K Factor <u>—</u>	Pitot C _p
Leak Rate Before <u>0.002</u> [cfm] [Lpm] @ <u>15</u> (in. Hg)	
Leak Rate After [cfm] [Lpm] @ (in. Hg)	
Pitot Leak Check Before: <input checked="" type="checkbox"/> After: Good <input checked="" type="checkbox"/> Bad <input type="checkbox"/>	



Amb. Temp. (°F) <u>70</u>	Bar. Press. <u>30.0</u> [in. Hg] [mbar]
Probe I.D. No. <u>67-4-3</u>	
Liner Material <u>glass</u>	

Filter No. <u>—</u>		
Thimble No. <u>—</u>		
Nozzle Diameter <u>—</u>	Nozzle I.D. <u>—</u>	

Start Time: 6:54 Stop Time: 7:54

G-55

Traverse Point Number	Min/pt 5 Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. [ft ³] [L]	Stack Temp. T _s (°F)	Probe T _p Filter T _f (°F)		Cond. Temp. T _c (°F)	DGM Inlet T _{m in} (°F)	DGM Outlet T _{m out} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T _t (°F)	Notes
						300	300						
				150.43									0.2
2	5	N/A	1.5	153.59	307	302	301	63	72	66	5	N/A	9.0
	10		1.5	157.25	307	300	300	61	72	66	5		8.8
	15		1.5	160.65	307	301	301	60	74	66	5		8.4
	20		1.5	164.15	308	300	301	59	77	67	5		9.1
	25		1.5	167.64	308	299	300	58	80	68	6		9.6
	30		1.5	171.14	313	301	301	60	81	68	6		9.5
	35		1.5	174.65	311	300	300	60	77	70	6		9.1
	40		1.5	178.18	310	300	299	61	85	71	6		9.9
	45		1.5	181.74	310	300	301	60	85	72	6		10.5
	50		1.5	185.28	311	300	300	60	86	73	6		9.6
	55		1.5	188.82	310	301	300	61	86	74	6		8.9
	60		1.5	192.380	311	300	300	62	86	74	6		8.6
	Total	*	18	411.950	3713				968	835			
	Average		(1.50)	(411.950)	(3713)				(75.1250)				

* Sum of square roots.

Circle correct bracketed units on data sheet.

TEST LOCATION: FF outlet

HCL

TESTING


METHOD: 26A PAGE 1 OF 1

UNIT: 2

RUN: 2

FIELD DATA SHEET

Cross-Section of Test Location



Duct Dimensions (in.) 96x96

Static Pres (in. H ₂ O)	Port Len. (in.)	Gas Flow (in. H ₂ O) [Out]	First point all the way [Out]
<u>-12.5</u>	<u>10</u>	<u>10</u> of page	<u>10</u> [Out]

Amb. Temp. (°F)	<u>70</u>	Bar. Press.	<u>30.0</u> [in. Hg] [mbar]
Probe I.D. No.	<u>67-4-3</u>		
Liner Material	<u>g/SS</u>		

Filter No.	<u>—</u>		
Thimble No.	<u>—</u>		
Nozzle Diameter	<u>—</u>	Nozzle I.D.	<u>—</u>

Start Time:	<u>9:02</u>	Stop Time:	<u>10:02</u>
-------------	-------------	------------	--------------

Client	<u>Wheelabrator</u>	Project No.	<u>10955</u>
Plant	<u>N. Broward</u>	Date	<u>3-17-10</u>
Meter Operator	<u>A. Obuchowski</u>		
Probe Operator	<u>—</u>		

Meter Box	<u>66-24</u>	Sample Box No.	<u>B21</u>
Meter Y _d	<u>0.9904</u>	Meter ΔH _@	<u>1.7516</u>
K Factor	<u>—</u>	Pitot C _p	<u>—</u>

Leak Rate Before	<u>0.002</u> [cfm] [Lpm]	@	<u>15</u> (in. Hg)
Leak Rate After	<u>0.002</u> [cfm] [Lpm]	@	<u>15</u> (in. Hg)
Pitot Leak Check Before:	<input checked="" type="checkbox"/>	After:	Good <input checked="" type="checkbox"/> Bad <input type="checkbox"/>

Traverse Point Number	Min/pt 5 Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. [ft ³] [L]	Stack Temp. T _s (°F)	Probe T _p (°F)	Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{max} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T _i (°F)	Notes
						Set Points							
				<u>192.710</u>		<u>300</u>	<u>300</u>						<u>0.7</u>
	<u>5</u>	<u>N/A</u>	<u>1.5</u>	<u>196.22</u>	<u>308</u>	<u>302</u>	<u>300</u>	<u>60</u>	<u>75</u>	<u>75</u>	<u>5</u>	<u>N/A</u>	<u>9.7</u>
	<u>10</u>		<u>1.5</u>	<u>199.70</u>	<u>308</u>	<u>300</u>	<u>300</u>	<u>60</u>	<u>75</u>	<u>75</u>	<u>5</u>		<u>9.8</u>
	<u>15</u>		<u>1.5</u>	<u>203.20</u>	<u>309</u>	<u>300</u>	<u>300</u>	<u>54</u>	<u>77</u>	<u>75</u>	<u>5</u>		<u>9.6</u>
	<u>20</u>		<u>1.5</u>	<u>206.69</u>	<u>308</u>	<u>301</u>	<u>300</u>	<u>56</u>	<u>80</u>	<u>75</u>	<u>5</u>		<u>9.7</u>
	<u>25</u>		<u>1.5</u>	<u>210.18</u>	<u>309</u>	<u>300</u>	<u>299</u>	<u>57</u>	<u>82</u>	<u>75</u>	<u>5</u>		<u>9.5</u>
	<u>30</u>		<u>1.5</u>	<u>213.67</u>	<u>309</u>	<u>301</u>	<u>300</u>	<u>58</u>	<u>84</u>	<u>76</u>	<u>5</u>		<u>10.2</u>
	<u>35</u>		<u>1.5</u>	<u>217.20</u>	<u>307</u>	<u>300</u>	<u>299</u>	<u>60</u>	<u>85</u>	<u>76</u>	<u>5</u>		<u>10.3</u>
	<u>40</u>		<u>1.5</u>	<u>220.74</u>	<u>308</u>	<u>300</u>	<u>300</u>	<u>60</u>	<u>86</u>	<u>76</u>	<u>5</u>		<u>10.0</u>
	<u>45</u>		<u>1.5</u>	<u>224.26</u>	<u>307</u>	<u>301</u>	<u>300</u>	<u>61</u>	<u>87</u>	<u>77</u>	<u>5</u>		<u>9.8</u>
	<u>50</u>		<u>1.5</u>	<u>227.70</u>	<u>308</u>	<u>300</u>	<u>300</u>	<u>60</u>	<u>88</u>	<u>77</u>	<u>5</u>		<u>9.8</u>
	<u>55</u>		<u>1.5</u>	<u>231.27</u>	<u>308</u>	<u>300</u>	<u>300</u>	<u>61</u>	<u>89</u>	<u>78</u>	<u>5</u>		<u>10.2</u>
	<u>60</u>		<u>1.5</u>	<u>234.775</u>	<u>308</u>	<u>300</u>	<u>300</u>	<u>59</u>	<u>89</u>	<u>79</u>	<u>5</u>		<u>10.4</u>
	Total	*	<u>1.8</u>	<u>42.0650</u>	<u>3697</u>				<u>997</u>	<u>914</u>			
	Average		<u>1.50</u>	<u>42.0650</u>	<u>308.08</u>	<u>33</u>			<u>79.6250</u>				

*Sum of square roots.

Circle correct bracketed units on data sheet.



QA/QC Q
Date 3/16

G-56

TEST LOCATION: FF outlet

HCL TESTING

METHOD: 26A PAGE 1 OF 1

UNIT: 2


RUN: 3

FIELD DATA SHEET

Cross-Section of Test Location

Client <u>Wheelabrator</u>	Project No. <u>10955</u>
Plant <u>A. Broward</u>	Date <u>3-17-10</u>
Meter Operator <u>A. Obuchowski</u>	
Probe Operator <u>-</u>	

Amb. Temp. (°F) <u>70</u>	Bar. Press. <u>30.0</u> (in. Hg) [mbar]
Probe I.D. No. <u>67-4-3</u>	
Liner Material <u>9145S</u>	



Meter Box <u>66-24</u>	Sample Box No.
Meter Yd <u>0.9904</u>	Meter ΔH ₀ <u>1.7516</u>
K Factor <u>-</u>	Pitot C _p

Filter No. <u>-</u>		
Thimble No. <u>-</u>		
Nozzle Diameter <u>-</u>	Nozzle I.D.	<u>-</u>

Leak Rate Before <u>0.002</u> (cfm) [Lpm] @ <u>15</u> (in. Hg)
Leak Rate After <u>0.003</u> (cfm) [Lpm] @ <u>15</u> (in. Hg)
Pitot Leak Check Before: <input checked="" type="checkbox"/> After: Good <input type="checkbox"/> Bad <input type="checkbox"/>

Duct Dimensions (in.) <u>96x96</u>			
Static Pres (in. H ₂ O) <u>-70.4</u>	Port Len. (in.) <u>10</u>	Gas Flow <u>10</u> [Out] of page	First point all the way <u>10</u> [Out]

Start Time: <u>10:25</u>	Stop Time: <u>11:25</u>
--------------------------	-------------------------

Traverse Point Number	Min/pt 5 Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. <u>10</u> [L]	Stack Temp. T _s (°F)	Probe T _p (°F)		Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{out} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T ₁ (°F)	Notes	
						300	300							
			1.5	235.110										
	5	0.10	1.5	238.66	308	299	305	60	81	79	5	n/a	10.3	
	10		1.5	242.15	307	300	304	53	84	79	5		10.2	
	15		1.5	245.67	307	302	303	48	88	80	6		9.8	
	20		1.5	249.17	306	300	301	49	90	80	6		9.1	
	25		1.5	252.66	307	300	301	53	91	80	6		8.7	
	30		1.5	256.13	307	300	300	55	91	81	6		9.0	
	35		1.5	259.67	306	300	300	57	92	81	6		9.2	
	40		1.5	263.20	310	301	301	59	92	82	6		8.5	
	45		1.5	266.71	307	300	301	61	92	82	6		9.0	
	50		1.5	270.27	308	300	300	62	93	83	6		9.2	
	55		1.5	273.80	308	299	300	62	93	83	6		8.2	
	60		1.5	277.350	307	300	300	63	93	83	6		9.1	
	Total	*	18	42.240	3668				1080	973				
	Average		1.50	307.333					85.5417					

* Sum of square roots.

Circle correct bracketed units on data sheet.



G-57

Impinger Weight Sheet

Client Wheelabrator		Unit Name/Location Unit 2 FF Outlet	
Plant North Broward	Job No. 10955	Method	Mod. 26A

Run No. 1	Filter Type Quartz	Sample Box No. B11
Date 3/17/10	Lot No.	pH
Analyst B. Wilke	Filter No. NA	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	50 mL 0.1N H2SO4	504.9	469.4	35.5	
Impinger 2	100 mL 01.N H2SO4	652.1	560.4	91.7	
Impinger 3	100 mL 01.N H2SO4	615.6	554.3	61.3	
Impinger 4	Empty	479.1	456.0	23.1	
Impinger 5	Silica Gel	808.5	785.4	23.1	Total Weight (gm)
					211.6
					234.7

QA/QC Bw
Date 3/17

Run No. 2	Filter Type Quartz	Sample Box No.
Date 3/17/10	Lot No.	pH
Analyst B. Wilke	Filter No. NA	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	50 mL 0.1N H2SO4	513.0	480.5	32.5	
Impinger 2	100 mL 01.N H2SO4	751.1	642.5	108.6	
Impinger 3	100 mL 01.N H2SO4	577.5	534.9	42.6	
Impinger 4	Empty	468.9	448.0	15.9	
Impinger 5	Silica Gel	718.5	695.7	22.8	Total Weight (gm)
					199.6
					222.4

QA/QC JB
Date 3/17

Run No. 3	Filter Type Quartz	Sample Box No. B11
Date 3/17/10	Lot No.	pH
Analyst B. Wilke P. Vicore	Filter No. NA	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	50 mL 0.1N H2SO4	506.8	467.8	39.0	
Impinger 2	100 mL 01.N H2SO4	683.0	561.1	121.9	
Impinger 3	100 mL 01.N H2SO4	597.3	554.6	42.7	
Impinger 4	Empty	469.8	455.7	14.1	
Impinger 5	Silica Gel	780.8	761.6	19.2	Total Weight (gm)
					217.7
					236.9

QA/QC JB
Date 3/17




TEST LOCATION: SDA INLET
 UNIT: 2 RUN: 1

HCL TESTING
FIELD DATA SHEET

METHOD: 26A PAGE 1 OF 1

Client Wheelabrator Project No. 10955
 Plant N. BLOWARD Date 3-17-10
 Meter Operator B. Arnold
 Probe Operator B. Arnold

Meter Box 61-8 Sample Box No. 816
 Meter Y_d 0.9916 Meter $\Delta H_{@}$ 1.7580
 K Factor N/A Pitot C_p
 Leak Rate Before 0.003 [cfm] [Lpm] @ 15 (in. Hg)
 Leak Rate After 0.004 [cfm] [Lpm] @ 20 (in. Hg)
 Pitot Leak Check Before: After: Good Bad



Amb. Temp. (°F) 70 Bar. Press. 30.00 [in. Hg] [mbar]
 Probe I.D. No. 6745
 Liner Material GLASS

Filter No. N/A
 Thimble No. N/A
 Nozzle Diameter N/A Nozzle I.D. N/A

Start Time: 6:54 Stop Time: 7:54

G-59

Traverse Point Number	Min/pt 5 Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V_m Init. Vol. [ft ³] [L]	Stack Temp. T_s (°F)	Probe T_p (°F)		Cond. Temp. T_c (°F)	DGM Inlet T_{min} (°F)	DGM Outlet T_{mout} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T_t (°F)	Notes
						355	355					02	
1-1	5		1.2	101.165 104.21	501	356	354	67	67	64	3.0	7.1	
	10			107.12	504	357	353	65	69	65	3.5	6.8	
	15			110.12	507	356	359	61	71	65	5.5	6.8	
	20			113.19	512	355	353	54	74	66	6.0	7.5	
	25			116.21	514	355	355	55	76	67	8.0	8.2	
	30			119.15	514	355	352	55	79	70	9.0	7.6	
	35			122.23	514	355	358	56	80	72	11.5	7.4	
	40			125.34	514	355	354	57	78	71	12.5	8.0	
	45			128.41	512	355	356	59	80	72	13.5	8.7	
	50			131.49	510	355	356	60	80	73	15.0	7.5	
	55			134.55	505	355	358	62	81	74	12.0	6.7	
	60		1.1	137.490	507	355	353	64	79	74	12.5	7.4	
	Total	*	14.3000	36.3250	6114				914	833			
	Average		11.1967	309.5000					72.7917				

* Sum of square roots.

Circle correct bracketed units on data sheet.

QA/QC BA
 Date 3-17-10



TEST LOCATION: SDA INLET
 UNIT: 2 RUN: 2


HCL TESTING
FIELD DATA SHEET

METHOD: 26A PAGE 1 OF 1

Client Whe Laboratories Project No. 10955
 Plant N. BROWARD Date 3-17-10
 Meter Operator B. ARNOLD
 Probe Operator B. ARNOLD

Meter Box 61-8 Sample Box No. 822
 Meter Y_d 0.9914 Meter ΔH_@ 1.7580
 K Factor N/A Pitot C_p

Leak Rate Before 0.003 [cfm] [Lpm] @ 15 (in. Hg)
 Leak Rate After 0.03 [cfm] [Lpm] @ 20 (in. Hg)
 Pitot Leak Check Before: After: Good Bad



Amb. Temp. (°F) 61 Bar. Press. 30.60 [(in. Hg) [mbar]]
 Probe I.D. No. 67-4-5
 Liner Material

Filter No. N/A
 Thimble No. N/A
 Nozzle Diameter N/A Nozzle I.D. N/A

Start Time: 9:02 Stop Time: 10:02

Traverse Point Number	Min/pt 5 Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m		Stack Temp. T _s (°F)	Probe T _p (°F)	Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{out} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T ₁ <u>BA</u> (°F)	Notes
				Init. Vol. [ft ³] [L]	Set Points									
				<u>138.230</u>			<u>355</u>	<u>355</u>					<u>67</u>	
<u>1-1</u>	<u>5</u>		<u>1.2</u>	<u>141.38</u>		<u>502</u>	<u>355</u>	<u>355</u>	<u>51</u>	<u>63</u>	<u>63</u>	<u>3.0</u>	<u>9.1</u>	
	<u>10</u>			<u>144.35</u>		<u>502</u>	<u>357</u>	<u>354</u>	<u>50</u>	<u>65</u>	<u>64</u>	<u>3.5</u>	<u>9.4</u>	
	<u>15</u>			<u>147.35</u>		<u>501</u>	<u>357</u>	<u>354</u>	<u>50</u>	<u>66</u>	<u>64</u>	<u>4.5</u>	<u>9.7</u>	
	<u>20</u>			<u>150.35</u>		<u>502</u>	<u>355</u>	<u>355</u>	<u>50</u>	<u>69</u>	<u>65</u>	<u>5.5</u>	<u>9.8</u>	
	<u>25</u>			<u>153.37</u>		<u>507</u>	<u>355</u>	<u>355</u>	<u>52</u>	<u>70</u>	<u>65</u>	<u>6.5</u>	<u>8.8</u>	
	<u>30</u>			<u>156.40</u>		<u>506</u>	<u>355</u>	<u>355</u>	<u>53</u>	<u>70</u>	<u>65</u>	<u>7.5</u>	<u>10.2</u>	
	<u>35</u>			<u>159.42</u>		<u>503</u>	<u>355</u>	<u>355</u>	<u>53</u>	<u>70</u>	<u>66</u>	<u>9.5</u>	<u>10.3</u>	
	<u>40</u>			<u>162.47</u>		<u>505</u>	<u>355</u>	<u>355</u>	<u>54</u>	<u>71</u>	<u>66</u>	<u>10.5</u>	<u>9.5</u>	
	<u>45</u>			<u>165.57</u>		<u>502</u>	<u>355</u>	<u>356</u>	<u>55</u>	<u>70</u>	<u>66</u>	<u>12.5</u>	<u>8.7</u>	
	<u>50</u>			<u>168.62</u>		<u>502</u>	<u>355</u>	<u>354</u>	<u>57</u>	<u>70</u>	<u>66</u>	<u>15.0</u>	<u>8.5</u>	
	<u>55</u>			<u>171.69</u>		<u>506</u>	<u>355</u>	<u>354</u>	<u>58</u>	<u>69</u>	<u>66</u>	<u>15.5</u>	<u>9.6</u>	
	<u>60</u>			<u>174.700</u>		<u>504</u>	<u>355</u>	<u>355</u>	<u>60</u>	<u>69</u>	<u>66</u>	<u>17.5</u>	<u>9.8</u>	
	Total *			<u>36.4700</u>		<u>6042</u>				<u>822</u>	<u>782</u>			
	Average					<u>803.500</u>							<u>66.8333</u>	

* Sum of square roots.

Circle correct bracketed units on data sheet.

QA/QC SB
 Date 3/17



G-60

TEST LOCATION: SDA INLET
 UNIT: 2 RUN: 3


HCL TESTING
FIELD DATA SHEET

METHOD: 26A PAGE 1 OF 1

Client Wheelabrator Project No. 10955
 Plant N. BROWARD Date 3-17-10
 Meter Operator B. ARNOLD
 Probe Operator B. ARNOLD

Meter Box 61-8 Sample Box No. B16
 Meter Y_d 0.9916 Meter ΔH@ 1.7580
 K Factor N/A Pitot C_p

Leak Rate Before 0.004 [cfm] [Lpm] @ 15 (in. Hg)
 Leak Rate After 0.004 [cfm] [Lpm] @ 18 (in. Hg)
 Pitot Leak Check Before: After: Good Bad



Amb. Temp. (°F) 62 Bar. Press. 30.00 [(in. Hg) [mbar]]
 Probe I.D. No. 67-4-5
 Liner Material GLASS

Filter No. N/A
 Thimble No. N/A
 Nozzle Diameter N/A Nozzle I.D. N/A

Start Time: 10:25 Stop Time: 11:25

G-61

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. (ft ³) [L]	Stack Temp. T _s (°F)	Probe T _p (°F)		Cond Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{min} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T ₁ (°F)	Notes
						Set Points	Set Points						
				<u>174.890</u>		<u>355</u>	<u>355</u>					<u>82.02</u>	
<u>1-1</u>	<u>5</u>		<u>1.2</u>	<u>178.02</u>	<u>507</u>	<u>354</u>	<u>360</u>	<u>59</u>	<u>65</u>	<u>64</u>	<u>3.0</u>	<u>9.9</u>	
	<u>10</u>			<u>189.97</u>	<u>505</u>	<u>358</u>	<u>364</u>	<u>52</u>	<u>66</u>	<u>64</u>	<u>3.0</u>	<u>10.1</u>	
	<u>15</u>			<u>183.98</u>	<u>504</u>	<u>357</u>	<u>360</u>	<u>51</u>	<u>68</u>	<u>64</u>	<u>3.5</u>	<u>11.0</u>	
	<u>20</u>			<u>187.00</u>	<u>499</u>	<u>355</u>	<u>356</u>	<u>52</u>	<u>69</u>	<u>64</u>	<u>5.0</u>	<u>8.6</u>	
	<u>25</u>			<u>190.00</u>	<u>502</u>	<u>355</u>	<u>355</u>	<u>54</u>	<u>70</u>	<u>65</u>	<u>7.0</u>	<u>7.1</u>	
	<u>30</u>			<u>193.07</u>	<u>503</u>	<u>355</u>	<u>356</u>	<u>54</u>	<u>70</u>	<u>65</u>	<u>8.0</u>	<u>7.5</u>	
	<u>35</u>			<u>196.07</u>	<u>501</u>	<u>354</u>	<u>356</u>	<u>56</u>	<u>70</u>	<u>65</u>	<u>9.5</u>	<u>8.4</u>	
	<u>40</u>			<u>199.08</u>	<u>505</u>	<u>355</u>	<u>356</u>	<u>57</u>	<u>70</u>	<u>65</u>	<u>11.0</u>	<u>7.8</u>	
	<u>45</u>			<u>202.10</u>	<u>498</u>	<u>354</u>	<u>354</u>	<u>59</u>	<u>70</u>	<u>66</u>	<u>12.5</u>	<u>8.5</u>	
	<u>50</u>			<u>205.15</u>	<u>498</u>	<u>355</u>	<u>353</u>	<u>60</u>	<u>70</u>	<u>66</u>	<u>14.5</u>	<u>9.0</u>	
	<u>55</u>		<u>1.1BA</u>	<u>208.19</u>	<u>499</u>	<u>355</u>	<u>357</u>	<u>60</u>	<u>70</u>	<u>66</u>	<u>16.0</u>	<u>8.2</u>	
	<u>60</u>		<u>1.1</u>	<u>211.35</u>	<u>498</u>	<u>355</u>	<u>356</u>	<u>61</u>	<u>70</u>	<u>66</u>	<u>17.0</u>	<u>9.0</u>	
	Total		<u>14.7000</u>	<u>36.2450</u>	<u>6019</u>				<u>825</u>	<u>780</u>			
	Average		<u>1.1917</u>	<u>36.2450</u>	<u>501.5833</u>				<u>67.0000</u>				

* Sum of square roots.

Circle correct bracketed units on data sheet.

QA/QC BA
 Date 3-17-10

Impinger Weight Sheet

Client Wheelabrator		Unit Name/Location Unit 2 SDA Inlet	
Plant North Broward	Job No. 10955	Method	Mod. 26A

Run No. 1	Filter Type Quartz	Sample Box No. B16
Date 3/17/10	Lot No.	pH
Analyst R. Vicere	Filter No. NA	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)			
Impinger 1	50 mL 0.1N H2SO4	477.3	455.7	21.6	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>QA/QC SB</td> </tr> <tr> <td>Date 3/17</td> </tr> </table>	QA/QC SB	Date 3/17
QA/QC SB							
Date 3/17							
Impinger 2	100 mL 01.N H2SO4	637.5	556.7	80.8			
Impinger 3	100 mL 01.N H2SO4	576.6	541.1	35.5			
Impinger 4	Empty	473.6	463.0	10.6			
Impinger 5	Silica Gel	754.2	740.9	13.3			
				Total Weight (gm)	148.5		
					161.8		

Run No. 2	Filter Type Quartz	Sample Box No. B22
Date 3/17/10	Lot No.	pH
Analyst B. Wilfong	Filter No. NA	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)			
Impinger 1	50 mL 0.1N H2SO4	501.8	471.6	30.2	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>QA/QC SB</td> </tr> <tr> <td>Date 3/17</td> </tr> </table>	QA/QC SB	Date 3/17
QA/QC SB							
Date 3/17							
Impinger 2	100 mL 01.N H2SO4	620.4	535.9	84.5			
Impinger 3	100 mL 01.N H2SO4	571.4	550.6	20.8			
Impinger 4	Empty	431.8	428.3	3.5			
Impinger 5	Silica Gel	766.4	754.2	12.2			
				Total Weight (gm)	139.0		
					151.2		

Run No. 3	Filter Type Quartz	Sample Box No. B16
Date 3/17/10	Lot No.	pH
Analyst R. Vicere	Filter No. NA	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)			
Impinger 1	50 mL 0.1N H2SO4	487.7	455.6	32.1	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>QA/QC SB</td> </tr> <tr> <td>Date 3/17</td> </tr> </table>	QA/QC SB	Date 3/17
QA/QC SB							
Date 3/17							
Impinger 2	100 mL 01.N H2SO4	643.0	560.9	82.1			
Impinger 3	100 mL 01.N H2SO4	567.7	540.3	27.4			
Impinger 4	Empty	472.5	465.4	7.1			
Impinger 5	Silica Gel	753.5	738.2	15.3			
				Total Weight (gm)	148.7		
					164.0		



TEST LOCATION:


FF Outlet

Particulate/Metals TESTING FIELD DATA SHEET

METHOD: 5122 PAGE 1 OF 2

UNIT: 3

RUN: 1



Client	Wheabrator	Project No.	1095
Plant	N. Brown	Date	3/17/10
Meter Operator	P. Bihun		
Probe Operator	P. Bihun		

Amb. Temp. (°F)	61.3	Bar. Press.	30.00 (in. Hg) [mbar]
Probe I.D. No.	67-5-4		
Liner Material	Obs		

Meter Box	166-14	Sample Box No.	M10
Meter Yr	990-990	Meter	1003
K Factor	2.35	Pitot C _p	0.505
Leak Rate Before	0.00 (cfm) [Lpm]	@	15 (in. Hg)
Leak Rate After	0.00 (cfm) [Lpm]	@	8 (in. Hg)
Pitot Leak Check Before:	<input checked="" type="checkbox"/> Good	After:	<input checked="" type="checkbox"/> Good <input type="checkbox"/> Bad

Filter No.	E-1A-26		
Thimble No.	N/A		
Nozzle Diameter	0.270	Nozzle I.D.	270-1

Start Time:	6:50	Stop Time:	9:03
-------------	------	------------	------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. (ft ³) [L]	Stack Temp. T _s (°F)	Probe T _p (°F)	Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{m in} (°F)	DGM Outlet T _{m out} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T _t (°F)	Notes	
						Set Points								
1-1	5	0.46	1.1	219.855	305	245	252	60	65	65	3.0	0.20	6.9	
2	10	0.54	1.3	275.84	305	241	257	53	65	65	3.5	0.20	6.5	
3	15	0.55	1.3	278.97	307	249	242	50	71	65	3.5	0.20	7.2	
4	20	0.50	1.2	281.98	306	240	248	49	73	65	3.5	0.20	7.1	
5	25	0.46	1.1	284.900	306	240	248	51	75	66	3.5	0.20	7.3 284.955	
2+	30	0.57	1.3	288.09	306	245	254	53	76	68	4.0	0.20	7.0 (-0.85)	
2	35	0.60	1.4	291.41	306	249	251	54	77	68	4.0	0.20	6.7	
3	40	0.48	1.1	294.32	306	250	250	54	80	69	3.5	0.20	7.2	
4	45	0.45	1.1	297.23	305	250	248	55	81	70	3.5	0.20	7.2	
5	50	0.38	0.89	299.891	305	251	249	55	81	71	3.0	0.20	7.3 299.955	
3+	55	0.51	1.2	302.98	304	246	248	55	79	71	3.5	0.20	7.0 (-0.86)	
2	60	0.54	1.3	306.19	305	249	251	56	81	72	4.0	0.20	7.3	
Total				72.290										
Average		0.6736	1.0824	303.440										75.8000

Sum of square roots.

Circle correct bracketed units on data sheet.

14.29

366 QA/QC PB Date 3/17/10

75.8000 1122



TEST LOCATION: FF Outlet
 UNIT: 3 RUN: 1

Particulates/Metals TESTING
FIELD DATA SHEET

METHOD: 5129 PAGE 2 OF 2

Cross-Section of Test Location

↑
 [N] [UP]

Duct Dimensions (in.)			
Static Pres (in. H ₂ O)	Port Len. (in.)	Gas Flow [In] [Out]	First point all the way of page [In] [Out]

Client <u>Wheelabrator</u>	Project No. <u>1095T</u>
Plant <u>N. Broward</u>	Date <u>3/17/10</u>
Meter Operator <u>P. Bihun</u>	
Probe Operator <u>P. Bihun</u>	

Meter Box	Sample Box No.
Meter Y _d	Meter ΔH _@
K Factor	Pitot C _p
Leak Rate Before [cfm] [Lpm] @ (in. Hg)	
Leak Rate After [cfm] [Lpm] @ (in. Hg)	
Pitot Leak Check Before: <input type="checkbox"/> After: Good <input type="checkbox"/> Bad <input type="checkbox"/>	

Amb. Temp. (°F)	Bar. Press. [in. Hg] [mbar]
Probe I.D. No.	
Liner Material	

Filter No.	
Thimble No.	
Nozzle Diameter	Nozzle I.D.

Start Time:	Stop Time:
-------------	------------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. [L]	Stack Temp. T _s (°F)	Probe T _p (°F)	Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{max} (°F)	Pump Vacuum (in.Hg)	XAD Trap Temp. T _t (°F)	Notes
						Set Points							
						280	282						
3	65	0.52	1.2	309.30	305	251	249	56	83	73	4.0	0.20	7.0
4	70	0.46	1.1	312.24	305	257	249	56	83	73	3.5	0.20	6.9
5	75	0.41	0.96	315.00	305	251	248	57	84	75	3.5	0.20	7.2
4-1	80	0.61	1.4	318.37	304	258	246	57	82	74	4.0	0.20	7.4
2	85	0.50	1.2	321.51	305	249	251	57	84	75	4.0	0.20	6.8
3	90	0.54	1.3	324.75	304	250	249	57	84	75	4.0	0.20	7.1
4	95	0.47	1.1	327.72	305	250	248	57	85	76	3.5	0.20	7.1
5	100	0.38	0.89	330.41	305	251	249	58	85	76	3.5	0.20	7.0
5-1	105	0.23	0.51	332.54	286	249	249	60	82	77	2.5	0.20	7.7
2	110	0.23	0.54	334.60	286	250	248	61	83	77	2.5	0.20	7.8
3	115	0.30	0.71	336.98	301	244	250	62	83	77	3.0	0.20	7.6
4	120	0.38	0.89	339.63	305	249	249	62	84	77	3.5	0.20	7.2
5	125	0.40	0.94	342.38	304	250	250	62	84	77	3.5	0.20	7.5
	Total												
	Average												

*Sum of square roots.

Circle correct bracketed units on data sheet.



G-64

TEST LOCATION:

FF Outlet

Particulate/Metals TESTING FIELD DATA SHEET

METHOD: 5729 PAGE 1 OF 2

UNIT: 3

RUN: 2

Cross-Section of Test Location



Duct Dimensions (in.) 96 x 96

Static Pres (in. H ₂ O)	Port Len. (in.)	Gas Flow (In) (Out) of page	First point all the way (In) (Out)
-11.0	10.0		(In) (Out)

Amb. Temp. (°F) 63	Bar. Press. 30.00 (in. Hg) (mbar)
Probe I.D. No. 6784	
Liner Material Glass	

Filter No. E-115-27	
Thimble No. N/A	
Nozzle Diameter 0.270	Nozzle I.D. 270-1

Start Time: 9:26	Stop Time: 11:38
------------------	------------------

Client Wheelabrator	Project No. 10955
Plant N. Brazeau	Date 3/17/00
Meter Operator P. Buhner	
Probe Operator P. Buhner	

Meter Box 66-14	Sample Box No. M41
Meter Y _d 0.9898	Meter ΔH ₀ 1.7643
K Factor 13.25 2.40	Pitot C _p 0.805
Leak Rate Before 0.003 (cm) [Lpm] @ 15 (in. Hg)	
Leak Rate After 0.003 (cm) [Lpm] @ 9 (in. Hg)	
Pitot Leak Check Before: <input checked="" type="checkbox"/> After: Good <input type="checkbox"/> Bad <input type="checkbox"/>	

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. (L)	Stack Temp. T _s (°F)	Probe T _p (°F)		Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{min} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T _t (°F)	Notes
						250	250						
1	5	0.57	1.2	345.85	302	244	247	60	77	77	3.0	0.25	7.5
2	10	0.59	1.4	349.13	306	246	251	55	79	77	3.0	0.25	7.6
3	15	0.53	1.3	352.27	305	248	247	51	81	77	3.0	0.25	7.7 K=2.35
4	20	0.53	1.3	355.47	305	249	248	51	82	77	3.0	0.25	7.8
5	25	0.48	1.1	358.370	302	250	249	52	83	77	3.0	0.25	7.5 358.440
2-1	30	0.51	1.2	361.51	302	246	249	53	82	77	3.0	0.25	7.8 (-0.07)
2	35	0.56	1.3	364.74	305	249	250	53	83	77	3.0	0.25	7.3
3	40	0.50	1.2	367.84	306	250	247	52	84	77	3.0	0.25	7.2
4	45	0.50	1.2	370.89	305	250	249	52	83	77	3.0	0.25	7.3
5	50	0.43	1.0	373.720	304	250	248	53	84	77	3.0	0.25	7.4 373.750
3-1	55	0.66	1.6	377.30	305	247	247	53	82	77	3.5	0.25	7.6 (-0.03)
2	60	0.63	1.5	380.73	305	249	250	55	83	77	3.5	0.25	7.8
Total													
Average													

Sum of square roots

Circle correct bracketed units on data sheet.



G-65

TEST LOCATION: FF outlet
 UNIT: 3 RUN: 2

Particulate/Metals TESTING
 FIELD DATA SHEET

METHOD: 5129 PAGE 2 OF 2

Client Wheelabrator Project No. 100CT
 Plant N. Broward Date 3/17/10
 Meter Operator PB Andrew R. Bihun
 Probe Operator R Bihun

Meter Box _____ Sample Box No. _____
 Meter Y_d _____ Meter ΔH_@ _____
 K Factor _____ Pitot C_p _____
 Leak Rate Before [cfm] [Lpm] @ (in. Hg) _____
 Leak Rate After [cfm] [Lpm] @ (in. Hg) _____
 Pitot Leak Check Before: After: Good Bad

Cross-Section of Test Location

↑
 [N] [UP]

Duct Dimensions (in.)

Static Pres (in. H ₂ O)	Port Len. (in.)	Gas Flow [In] [Out] of page	First point all the way / [In] [Out]
------------------------------------	-----------------	-----------------------------	--------------------------------------

Amb. Temp. (°F) _____ Bar. Press. [in. Hg] [mbar] _____
 Probe I.D. No. _____
 Liner Material _____

Filter No. _____
 Thimble No. _____
 Nozzle Diameter _____ Nozzle I.D. _____

Start Time: _____ Stop Time: _____

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. [L]	Stack Temp. T _s (°F)	Probe T _p (°F)	Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{m in} (°F)	DGM Outlet T _{m out} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp T _t (°E)	Notes
						Set Points						Ag Plan	
						280	202						02
3	65	0.52	1.2	387.85	305	210	251	55	84	77	3.5	0.25	7.1
4	70	0.57	1.2	386.92	305	251	250	56	84	77	3.5	0.25	7.1
5	75	0.42	0.99	389.725	305	281	249	56	83	77	3.0	0.25	7.2 389.760
4-1	80	0.67	1.6	393.26	305	246	249	58	82	76	4.0	0.25	7.3 (-0.035)
2	85	0.63	1.5	396.73	304	248	252	58	84	77	4.0	0.25	6.9
3	90	0.54	1.3	399.96	304	250	249	57	85	77	3.5	0.25	6.6
4	95	0.54	1.3	403.17	305	210	249	58	85	77	3.5	0.25	6.5
5	100	0.52	1.2	406.215	304	250	249	59	86	77	3.5	0.25	7.0 406.255
5-1	105	0.50	1.2	409.35	303	249	248	60	83	77	3.5	0.25	7.3 (-0.035)
2	110	0.47	1.1	412.24	303	250	249	62	85	77	3.5	0.25	6.4
3	115	0.44	1.0	415.07	301	250	250	62	86	78	3.5	0.25	6.9
4	120	0.43	1.0	417.86	303	250	250	63	86	78	3.5	0.25	6.9
5	125	0.48	1.1	420.285	303	250	250	64	87	79	3.5	0.25	7.1
	Total												
	Average												

* Sum of square roots.

Circle correct bracketed units on data sheet.

QA/QC PB
 Date 3/17/10



G-66


TEST LOCATION: FF outlet
 UNIT: 3 RUN: 3

Particulate / Metals TESTING
FIELD DATA SHEET

METHOD: 5129 PAGE 1 OF 2

Client Whelan Project No. 1095T
 Plant N. Broward Date 3/17/10
 Meter Operator P. Bihun
 Probe Operator P. Bihun

Meter Box 46-14 Sample Box No. M10
 Meter Yr 08-98 Meter ΔH@ 1.76423
 K Factor 2.35 Pitot Cp 0.905
 Leak Rate Before 0.002 (cfm) [Lpm] @ 15 (in. Hg)
 Leak Rate After 0.003 (cfm) [Lpm] @ 9 (in. Hg)
 Pitot Leak Check Before: After: Good Bad



Duct Dimensions (in.) 96x96
 Static Pres (in. H₂O) -10.3 Port Len. (in.) 10.0 Gas Flow (In) [Out] of page (In) [Out] First point at the way (In) [Out]

Amb. Temp. (°F) 67 Bar. Press. 30.00 (in. Hg) [mmbar]
 Probe I.D. No. 678-4
 Liner Material Glass

Filter No. E-115-28
 Thimble No. N/A
 Nozzle Diameter 0.270 Nozzle I.D. 2707

Start Time: 11:59 Stop Time: 14:11

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. (ft ³) [L]	Stack Temp. T _s (°F)	Probe T _p (°F)		Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{min} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T _t (°F)	Notes
						Set Points	Set Points						
1-1	5	0.54	1.3	424.105	304	247	245	58	78	77	4.0	0.25	6.8
2	10	0.50	1.2	427.41	304	242	255	53	80	77	3.5	0.25	6.9
3	15	0.46	1.1	430.34	304	246	249	49	81	77	3.5	0.25	7.2
4	20	0.45	1.1	433.23	304	248	248	49	82	77	3.5	0.25	6.8
5	25	0.43	1.0	436.05	305	249	248	50	82	77	3.0	0.25	6.6
2-1	30	0.57	1.3	439.26	305	250	249	50	81	76	3.5	0.25	7.6
2	35	0.60	1.4	442.61	304	249	250	48	82	76	4.0	0.25	7.8
3	40	0.50	1.2	445.70	305	250	251	47	84	77	3.5	0.25	7.7
4	45	0.54	1.3	448.92	305	251	248	47	83	76	3.5	0.25	8.3
5	50	0.45	1.1	451.85	305	250	247	47	83	76	3.5	0.25	8.3
3-1	55	0.61	1.4	455.15	306	247	247	49	81	76	4.0	0.25	8.2
2	60	0.60	1.4	458.45	305	249	250	48	82	76	4.0	0.25	7.5
Total				76.665	304.00								
Average		7.936	1.2104		304.040				78.5800				

Sum of square roots. 14.8

Circle correct bracketed units on data sheet.

QA/QC PS
 Date 3/17/10



G-67

TEST LOCATION:

FF Outlet

TESTING FIELD DATA SHEET

METHOD: 5129

PAGE

2 OF

2


UNIT: 3

RUN: 3

Client <u>Weyerhaeuser</u>	Project No. <u>1095T</u>
Plant <u>N. Broward</u>	Date <u>3/17/10</u>
Meter Operator <u>P. Bikner</u>	
Probe Operator <u>P. Bikner</u>	

Meter Box	Sample Box No.
Meter Y _d	Meter ΔH _@
K Factor	Pitot C _p

Leak Rate Before	[cfm] [Lpm]	@	(in. Hg)
Leak Rate After	[cfm] [Lpm]	@	(in. Hg)
Pitot Leak Check Before:	<input type="checkbox"/>	After: Good	<input type="checkbox"/> Bad <input type="checkbox"/>



Amb. Temp. (°F)	Bar. Press. [in. Hg] [mbar]
Probe I.D. No.	
Liner Material	

Filter No.		
Thimble No.		
Nozzle Diameter	Nozzle I.D.	

Start Time:	Stop Time:
-------------	------------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. [L]	Stack Temp. T _s (°F)	Probe T _p (°F)	Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{max} (°F)	Pump Vacuum (in.Hg)	XAD Trap Temp. T _t (°F)	Notes
						Set Points							
						250	250						
3	65	0.58	1.4	461.73	305	250	248	48	83	76	4.0	0.25	7.1
4	70	0.50	1.2	464.77	305	251	249	49	83	76	3.5	0.25	6.4
5	75	0.48	1.1	467.625	305	251	249	50	82	76	3.5	0.25	6.9
4-1	80	0.71	1.7	471.35	305	250	246	52	81	75	4.5	0.25	7.3
2	85	0.65	1.5	474.79	306	249	252	52	82	75	4.0	0.25	7.7
3	90	0.57	1.3	477.97	306	250	249	52	83	75	4.0	0.25	7.3
4	95	0.55	1.3	481.16	306	251	249	53	82	75	4.0	0.25	7.2
5	100	0.47	1.1	484.075	306	251	249	54	82	75	3.5	0.25	7.4
5-1	105	0.37	0.87	486.73	294	249	249	55	79	75	3.0	0.25	7.5
2	110	0.37	0.87	489.36	295	250	250	55	80	74	3.0	0.25	7.5
3	115	0.39	0.92	492.08	304	250	250	55	80	74	3.5	0.25	7.0
4	120	0.43	1.0	494.89	303	250	249	55	80	74	3.5	0.25	6.4
5	125	0.50	1.2	497.965	304	250	249	56	81	74	4.0	0.25	6.5
Total													
Average													

* Sum of square roots.

Circle correct bracketed units on data sheet.

QA/QC PS
Date 3/17/10



G-68

Impinger Weight Sheet

Client: Wheelabrator		Unit Name/Location Unit 3 FF Outlet	
Plant North Broward	Job No. 10955	Method	5/29

Run No. 1	Filter Type Quartz	Sample Box No.
Date 3/17/10	Lot No.	pH
Analyst B. Wilke	Filter No. E-115-26	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty	693.8	439.8	254.0	
Impinger 2	100 ml 5%HNO3/10%H2O2	689.5	559.5	130.0	QA/QC BW Date 3/17
Impinger 3	100 ml 5%HNO3/10%H2O2	571.6	537.6	34.0	
Impinger 4	Empty	454.0	446.4	7.6	
Impinger 5	100 ml 4%KMnO4/10%H2SO4	547.6	544.7	2.9	Total Weight (gm)
Impinger 6	100 ml 4%KMnO4/10%H2SO4	551.5	551.1	0.4	428.9
Impinger 7	Silica Gel	748.4	735.2	13.2	442.1

Run No. 2	Filter Type Quartz	Sample Box No.
Date 3/17/10	Lot No.	pH
Analyst B. Wilke	Filter No. E-115-27	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty	740.5	463.2	277.3	
Impinger 2	100 ml 5%HNO3/10%H2O2	683.5	542.1	141.4	QA/QC BW Date 3/17
Impinger 3	100 ml 5%HNO3/10%H2O2	586.5	553.5	33.0	
Impinger 4	Empty	446.1	440.0	6.1	
Impinger 5	100 ml 4%KMnO4/10%H2SO4	564.8	562.4	2.4	Total Weight (gm)
Impinger 6	100 ml 4%KMnO4/10%H2SO4	540.6	540.6	0.0	460.2
Impinger 7	Silica Gel	736.0	717.8	18.2	478.4

Run No. 3	Filter Type Quartz	Sample Box No.
Date 3/17/10	Lot No.	pH
Analyst B. Wilke	Filter No. E-115-28	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty	722.8	439.7	283.1	
Impinger 2	100 ml 5%HNO3/10%H2O2	685.9	556.9	129.0	QA/QC BW Date 3/17
Impinger 3	100 ml 5%HNO3/10%H2O2	562.6	536.0	26.6	
Impinger 4	Empty	453.5	447.5	6.0	
Impinger 5	100 ml 4%KMnO4/10%H2SO4	545.2	541.1	4.1	Total Weight (gm)
Impinger 6	100 ml 4%KMnO4/10%H2SO4	545.1	545.2	-0.1	448.7
Impinger 7	Silica Gel	700.3	684.6	15.7	464.4



TEST LOCATION: ff outlet

Fluoride


TESTING

METHOD: 13B PAGE 1 OF 2

UNIT: 3 RUN: 1

FIELD DATA SHEET

Client <u>wheelabrator</u>	Project No. <u>1055</u>
Plant <u>N. Broward</u>	Date <u>3-16-10</u>
Meter Operator <u>A. Obuchowski</u>	
Probe Operator <u>B. ARNOLD</u>	



Amb. Temp. (°F) <u>70</u>	Bar. Press. <u>30.05</u> [in. Hg] [mbar]
Probe I.D. No. <u>67-8-14</u>	
Liner Material <u>glass</u>	

Meter Box <u>66-14</u>	Sample Box No. <u>86</u>
Meter Yd <u>0.9698</u>	Meter ΔH ₀ <u>1.7647</u>
K Factor <u>2.44</u>	Pitot Cp <u>0.812</u>
Leak Rate Before <u>0.005</u> [cfm] [Lpm] @ <u>15</u> (in. Hg)	
Leak Rate After <u>0.002</u> [cfm] [Lpm] @ <u>15</u> (in. Hg)	
Pitot Leak Check Before: <input type="checkbox"/>	After: Good <input checked="" type="checkbox"/> Bad <input type="checkbox"/>

Duct Dimensions (in.) <u>46x46</u>	
Static Pres (in. H ₂ O) <u>-10.6</u>	Port Len. (in.) <u>10</u>
Gas Flow <u>[UP]</u> [Out]	First point all the way <u>[UP]</u> [Out]

Filter No.	
Thimble No.	<u>-</u>
Nozzle Diameter <u>0.268</u>	Nozzle I.D. <u>0.268-1</u>

Start Time: 11:49 Stop Time: 13:07

G-70

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. [ft ³] [L]	Stack Temp. T _s (°F)	Probe T _p (°F)		Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{out} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. O ₂ T _i % RH (°F)	Notes
						Set Points	Set Points							
	<u>2.5</u>			<u>156.30</u>		<u>250</u>	<u>250</u>							<u>O₂</u>
1-1	<u>2.5</u>	<u>0.34</u>	<u>0.83</u>	<u>157.35</u>	<u>287</u>	<u>249</u>	<u>247</u>	<u>63</u>	<u>67</u>	<u>66</u>	<u>2</u>	<u>0.3</u>	<u>10.1</u>	
-2	<u>5</u>	<u>0.34</u>	<u>0.83</u>	<u>158.74</u>	<u>286</u>	<u>249</u>	<u>246</u>	<u>61</u>	<u>67</u>	<u>66</u>	<u>2</u>	<u>0.3</u>	<u>9.4</u>	
-3	<u>7.5</u>	<u>0.34</u>	<u>0.83</u>	<u>160.14</u>	<u>293</u>	<u>250</u>	<u>248</u>	<u>60</u>	<u>67</u>	<u>66</u>	<u>2</u>	<u>0.3</u>	<u>9.6</u>	
-4	<u>10</u>	<u>0.43</u>	<u>1.0</u>	<u>161.40</u>	<u>294</u>	<u>250</u>	<u>250</u>	<u>60</u>	<u>68</u>	<u>66</u>	<u>2</u>	<u>0.3</u>	<u>9.5</u>	<u>163.00</u>
2-5	<u>12.5</u>	<u>0.47</u>	<u>1.1</u>	<u>162.73</u>	<u>299</u>	<u>250</u>	<u>248</u>	<u>59</u>	<u>69</u>	<u>67</u>	<u>2</u>	<u>0.3</u>	<u>9.3</u>	<u>162.7</u>
2-7	<u>15</u>	<u>0.53</u>	<u>1.3</u>	<u>164.39</u>	<u>298</u>	<u>250</u>	<u>247</u>	<u>59</u>	<u>69</u>	<u>67</u>	<u>2</u>	<u>0.3</u>	<u>8.8</u>	<u>162.7</u>
-7	<u>17.5</u>	<u>0.53</u>	<u>1.3</u>	<u>166.00</u>	<u>300</u>	<u>250</u>	<u>250</u>	<u>60</u>	<u>71</u>	<u>67</u>	<u>2</u>	<u>0.3</u>	<u>9.7</u>	
-3	<u>20</u>	<u>0.50</u>	<u>1.2</u>	<u>167.49</u>	<u>299</u>	<u>250</u>	<u>248</u>	<u>59</u>	<u>72</u>	<u>68</u>	<u>2</u>	<u>0.3</u>	<u>9.1</u>	
-4	<u>22.5</u>	<u>0.45</u>	<u>1.1</u>	<u>168.92</u>	<u>299</u>	<u>250</u>	<u>249</u>	<u>60</u>	<u>73</u>	<u>68</u>	<u>2</u>	<u>0.3</u>	<u>9.0</u>	
-5	<u>25</u>	<u>0.41</u>	<u>1.0</u>	<u>170.34</u>	<u>300</u>	<u>250</u>	<u>249</u>	<u>61</u>	<u>74</u>	<u>68</u>	<u>2</u>	<u>0.3</u>	<u>10.0</u>	
3-1	<u>27.5</u>	<u>0.52</u>	<u>1.3</u>	<u>171.90</u>	<u>300</u>	<u>250</u>	<u>250</u>	<u>61</u>	<u>71</u>	<u>70</u>	<u>2</u>	<u>0.3</u>	<u>9.8</u>	
-2	<u>30</u>	<u>0.50</u>	<u>1.2</u>	<u>173.48</u>	<u>301</u>	<u>250</u>	<u>247</u>	<u>62</u>	<u>75</u>	<u>70</u>	<u>2</u>	<u>0.3</u>	<u>8.9</u>	
-3	<u>32.5</u>	<u>0.52</u>	<u>1.3</u>	<u>175.07</u>	<u>300</u>	<u>250</u>	<u>248</u>	<u>62</u>	<u>76</u>	<u>70</u>	<u>2</u>	<u>0.3</u>	<u>9.8</u>	
	Total	<u>16.7633</u>	<u>27.330</u>	<u>36.80</u>	<u>7449</u>				<u>1846</u>	<u>1744</u>				
	Average	<u>0.6713</u>	<u>1.0948</u>		<u>297.960</u>				<u>67.89</u>					

Sum of square roots.

Circle correct bracketed units on data sheet.

QA/QC Q
Date 3-16-10



TEST LOCATION: ff outlet

Fluoride TESTING

METHOD: 13 B PAGE 2 OF 2

UNIT: 3 RUN: 1

FIELD DATA SHEET

Client <u>wheelabrator</u>	Project No. <u>10955</u>
Plant <u>N. BROWARD</u>	Date <u>3-16-16</u>
Meter Operator <u>A. Guehen</u>	
Probe Operator <u>B. ARLOP</u>	

Cross-Section of Test Location

↑
[N] [UP]

Duct Dimensions (in.)

Static Pres (in. H ₂ O)	Port Len. (in.)	Gas Flow [In] [Out] of page	First point all the way [In] [Out]
------------------------------------	-----------------	-----------------------------	------------------------------------

Amb. Temp. (°F)	Bar. Press. <u>30.05</u> [in. Hg] [mbar]
Probe I.D. No. <u>67</u>	
Liner Material	

Meter Box	Sample Box No.
Meter Y _d	Meter ΔH _@
K Factor	Pitot C _p
Leak Rate Before [cfm] [Lpm] @ (in. Hg)	
Leak Rate After [cfm] [Lpm] @ (in. Hg)	
Pitot Leak Check Before: <input type="checkbox"/> After: Good <input type="checkbox"/> Bad <input type="checkbox"/>	

Filter No.	
Thimble No.	
Nozzle Diameter	Nozzle I.D.

Start Time:	Stop Time:
-------------	------------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. [ft ³] [L]	Stack Temp. T _s (°F)	Probe T _p (°F)		Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{max} (°F)	Pump Vacuum (in.Hg)	XAD Trap Temp. T _i (°F)	Notes
						Set Points							
-4	35	0.50	1.2	175.76.60	300	250	247	63	77	71	2	0.30	10.0
-5	37.5	0.45	1.1	178.80.25	300	250	246	63	76	71	2	0.30	10.1
4-1	40	0.45	1.1	180.08	300	250	247	62	76	74	2	0.30	10.1
-2	42.5	0.43	1.0	181.70	300	250	248	61	78	72	2	0.30	9.4
-3	45	0.43	1.0	183.10	299	250	247	61	78	72	2	0.30	9.2
-4	47.5	0.45	1.1	184.57	299	250	249	61	78	72	2	0.30	9.9
-5	50	0.45	1.1	186.03	300	250	250	61	78	72	2	0.30	9.9
5-1	52.5	0.47	1.1	187.55	300	250	248	61	75	72	2	0.30	10.0
-2	55	0.48	1.2	189.10	300	250	248	59	77	72	2	0.30	10.1
-3	57.5	0.47	1.1	190.58	299	251	248	57	78	72	2	0.30	10.1
-4	60	0.45	1.1	192.02	299	251	250	57	78	73	2	0.30	9.9
-5	62.5	0.40	0.98	193.450	297	251	248	56	78	72	2	0.30	10.3
	Total	*	13.08		3543				927	865			
	Average												

* Sum of square roots.

Circle correct bracketed units on data sheet.



QA/QC 58
Date 3/16

G-71

10.1
0.08

TEST LOCATION: FF outlet
 UNIT: 3 RUN: 2


Fluoride TESTING
FIELD DATA SHEET

METHOD: 133 PAGE 1 OF 2

Client wheelabrator Project No. 10055
 Plant N. Boulevard Date 3-16-10
 Meter Operator A. Obuchowski
 Probe Operator B. ARNOLD

Meter Box 66-14 Sample Box No. B7
 Meter Y_d 0.924E Meter ΔH_@ 1.7643
 K Factor 2.443237 Pitot C_p 0.812

Leak Rate Before 0.003 [cfm] [Lpm] @ 15 (in. Hg)
 Leak Rate After 0.002 [cfm] [Lpm] @ 15 (in. Hg)
 Pitot Leak Check Before: After: Good Bad



Amb. Temp. (°F) 70 Bar. Press. 30.05 [inHg] [mbar]
 Probe I.D. No. 67-E-14
 Liner Material 9155

Filter No. _____
 Thimble No. _____
 Nozzle Diameter 0.26E Nozzle I.D. 26E-1

Start Time: 12:33 Stop Time: 14:44

G-23 C-3 A-3 Traverse Point Number	Min/pt 2.5 Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. [L]	Stack Temp. T _s (°F)	Probe T _p (°F) Filter T _f (°F)		Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{out} (°F)	Pump Vacuum (in.Hg)	XAD Trap Temp. T _i %id (°F)	Notes
						Set Points							
				<u>193.980</u>		<u>240</u>	<u>250</u>						<u>0.2</u>
<u>58-1</u>	<u>2.5</u>	<u>0.55</u>	<u>1.3</u>	<u>195.60</u>	<u>301</u>	<u>250</u>	<u>249</u>	<u>63</u>	<u>74</u>	<u>77</u>	<u>3</u>	<u>0.30</u>	<u>10.0</u>
<u>-2</u>	<u>5</u>	<u>0.57</u>	<u>1.4</u>	<u>197.25</u>	<u>300</u>	<u>249</u>	<u>247</u>	<u>57</u>	<u>74</u>	<u>72</u>	<u>3</u>	<u>0.30</u>	<u>10.3</u>
<u>-3</u>	<u>7.5</u>	<u>0.53</u>	<u>1.3</u>	<u>198.85</u>	<u>300</u>	<u>249</u>	<u>246</u>	<u>51</u>	<u>74</u>	<u>72</u>	<u>3</u>	<u>0.30</u>	<u>9.5</u>
<u>-4</u>	<u>10</u>	<u>0.49</u>	<u>1.2</u>	<u>200.40</u>	<u>298</u>	<u>249</u>	<u>248</u>	<u>49</u>	<u>76</u>	<u>72</u>	<u>3</u>	<u>0.30</u>	<u>10.4</u>
<u>-5</u>	<u>12.5</u>	<u>0.47</u>	<u>1.1</u>	<u>201.87</u>	<u>300</u>	<u>250</u>	<u>248</u>	<u>47</u>	<u>76</u>	<u>72</u>	<u>3</u>	<u>0.30</u>	<u>10.0</u>
<u>48-1</u>	<u>15</u>	<u>0.53</u>	<u>1.3</u>	<u>203.61</u>	<u>300</u>	<u>248</u>	<u>248</u>	<u>49</u>	<u>76</u>	<u>72</u>	<u>3</u>	<u>0.30</u>	<u>10.9</u>
<u>-2</u>	<u>17.5</u>	<u>0.57</u>	<u>1.4</u>	<u>205.26</u>	<u>301</u>	<u>250</u>	<u>248</u>	<u>46</u>	<u>78</u>	<u>73</u>	<u>3</u>	<u>0.30</u>	<u>10.3</u>
<u>-3</u>	<u>20</u>	<u>0.53</u>	<u>1.3</u>	<u>206.86</u>	<u>300</u>	<u>250</u>	<u>249</u>	<u>47</u>	<u>78</u>	<u>73</u>	<u>3</u>	<u>0.30</u>	<u>10.4</u>
<u>-4</u>	<u>22.5</u>	<u>0.50</u>	<u>1.2</u>	<u>208.41</u>	<u>300</u>	<u>250</u>	<u>248</u>	<u>47</u>	<u>79</u>	<u>73</u>	<u>3</u>	<u>0.30</u>	<u>10.4</u>
<u>-5</u>	<u>25</u>	<u>0.411</u>	<u>0.97</u>	<u>209.81</u>	<u>300</u>	<u>251</u>	<u>250</u>	<u>49</u>	<u>80</u>	<u>73</u>	<u>3</u>	<u>0.30</u>	<u>9.3</u>
<u>41-1</u>	<u>27.5</u>	<u>0.52</u>	<u>1.2</u>	<u>211.45</u>	<u>299</u>	<u>250</u>	<u>247</u>	<u>52</u>	<u>79</u>	<u>74</u>	<u>3</u>	<u>0.30</u>	<u>10.5</u>
<u>-2</u>	<u>30</u>	<u>0.52</u>	<u>1.2</u>	<u>212.99</u>	<u>300</u>	<u>250</u>	<u>250</u>	<u>51</u>	<u>80</u>	<u>74</u>	<u>3</u>	<u>0.30</u>	<u>10.0</u>
<u>-3</u>	<u>32.5</u>	<u>0.49</u>	<u>1.2</u>	<u>214.55</u>	<u>300</u>	<u>250</u>	<u>248</u>	<u>51</u>	<u>81</u>	<u>74</u>	<u>3</u>	<u>0.30</u>	<u>9.8</u>
	Total	<u>17.352</u>	<u>28.80</u>	<u>37.760</u>	<u>7486</u>				<u>1999</u>	<u>1857</u>			
	Average	<u>0.6926</u>	<u>1.1520</u>		<u>299.440</u>				<u>77.120</u>				

Sum of square roots.

Circle correct bracketed units on data sheet.



16.07

QA/QC
 Date 3/16/10

1005 907

TEST LOCATION: FF Outlet

fluoride TESTING

METHOD: 133 PAGE 2 OF 2

UNIT: 3 RUN: 2

FIELD DATA SHEET

Client <u>Wheelabrator</u>	Project No. <u>1055</u>
Plant <u>N. Broward</u>	Date <u>3-16-10</u>
Meter Operator <u>A. Chuchewski</u>	
Probe Operator <u>B. ARNOLD</u>	

Cross-Section of Test Location

↑
[N] [UP]

Duct Dimensions (in.)

Static Pres (in. H ₂ O)	Port Len. (in.)	Gas Flow [In] [Out] of page	First point all the way [In] [Out]
------------------------------------	-----------------	-----------------------------	------------------------------------

Amb. Temp. (°F)	Bar. Press. [in. Hg] [mbar]
Probe I.D. No.	
Liner Material	

Meter Box	Sample Box No.
Meter Y _d	Meter ΔH _@
K Factor <u>2.37</u>	Pitot C _p
Leak Rate Before [cfm] [Lpm] @ (in. Hg)	
Leak Rate After [cfm] [Lpm] @ (in. Hg)	
Pitot Leak Check Before: <input type="checkbox"/> After: Good <input type="checkbox"/> Bad <input type="checkbox"/>	

Filter No.	
Thimble No.	
Nozzle Diameter	Nozzle I.D.

Start Time:	Stop Time:
-------------	------------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. [ft ³] [L]	Stack Temp. T _s (°F)	Probe T _p (°F)	Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{max} (°F)	Pump Vacuum (in.Hg)	XAD Trap Temp. T _t (°F)	Notes	
						Set Points								
-4	35	0.16	1.1	216.03	300	250	249	52	82	74	3	0.70	9.7	217.61
-5	37.5	0.46	1.1	217.50	300	250	248	53	82	74	3	0.30	9.1	217.50
28-1	40	0.65	1.5	219.29	298	249	248	56	81	75	3	0.30	10.5	-0.11
-2	42.5	0.54	1.3	220.00	300	250	248	56	83	75	3	0.30	9.8	
-3	45	0.46	1.1	223.40	300	251	250	55	84	75	3	0.30	9.6	
-4	47.5	0.41	0.97	223.85	299	250	250	55	84	76	3	0.30	9.3	
-5	50	0.41	0.97	225.26	299	250	249	55	84	76	3	0.30	10.1	225.38
1-1	52.5	0.52	1.2	226.90	298	249	248	58	82	77	3	0.30	10.0	225.26
-2	55	0.30	0.71	228.19	296	250	249	56	87	77	3	0.30	8.9	-0.12
-3	57.5	0.34	0.81	228.25	298	250	250	56	83	77	3	0.30	10.0	
-4	60	0.41	0.97	230.62	299	250	250	55	83	77	3	0.30	8.9	
-5	62.5	0.43	1.0	232.27	300	250	250	54	83	77	3	0.30	9.7	
Total *														
Average														

* Sum of square roots. Circle correct bracketed units on data sheet.

QA/QC SB
Date 3/16



TEST LOCATION: FF outlet


fluoride TESTING

METHOD: 13B PAGE 1 OF 2

UNIT: 3 RUN: 3

FIELD DATA SHEET

Client	<u>Wheelabrator</u>	Project No.	<u>10955</u>
Plant	<u>N. Broward</u>	Date	<u>3-16-10</u>
Meter Operator	<u>A. Obuchowski</u>		
Probe Operator	<u>B. ARNOLD</u>		



Amb. Temp. (°F)	<u>70</u>	Bar. Press.	<u>30.05</u> [in. Hg] [mbar]
Probe I.D. No.	<u>67-E-14</u>		
Liner Material	<u>glass</u>		

Meter Box	<u>66-14</u>	Sample Box No.	<u>B5</u>
Meter Y _d	<u>0.9898</u>	Meter ΔH ₀	<u>1.7643</u>
K Factor	<u>237</u>	Pitot C _p	<u>0.812</u>
Leak Rate Before	<u>0.002</u> [cfm] [Lpm]	@	<u>15</u> (in. Hg)
Leak Rate After	<u>0.002</u> [cfm] [Lpm]	@	<u>15</u> (in. Hg)
Pitot Leak Check Before:	<input checked="" type="checkbox"/>	After: Good	<input checked="" type="checkbox"/> Bad <input type="checkbox"/>

Duct Dimensions (in.)				<u>96x96</u>
Static Pres (in. H ₂ O)	Port Len. (in.)	Gas Flow [Out] of page	First point all the way	<u>UP</u> [Out]
<u>-10.6</u>	<u>16</u>			

Filter No.		
Thimble No.	<u>—</u>	
Nozzle Diameter	<u>0.26E</u>	Nozzle I.D. <u>26E-1</u>

Start Time:	<u>15:07</u>	Stop Time:	<u>16:16</u>
-------------	--------------	------------	--------------

G-74

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. [ft ³] [L]	Stack Temp. T _s (°F)	Probe T _p (°F)	Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{out} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T _i (°F)	Notes
						Set Points							
				<u>232.60</u>		<u>250</u>	<u>25</u>						<u>0.2</u>
1-1	2.5	0.48	1.1	234.07	299	249	245	62	76	76	3	0.30	10.5
-2	5	0.29	0.69	235.34	298	246	245	55	77	76	3	0.30	9.4
-3	2.5	0.29	0.69	236.49	295	248	248	53	77	76	3	0.30	9.2
-4	10	0.36	0.85	237.81	298	248	248	52	78	76	3	0.30	9.2
-5	12.5	0.43	1.0	239.23	300	249	247	51	79	76	3	0.30	9.0
2-1	15	0.60	1.4	240.98	295	249	247	52	79	76	3	0.30	10.2
-2	17.5	0.50	1.2	242.53	301	249	247	53	81	76	3	0.30	9.0
-3	20	0.47	1.1	244.00	299	250	247	54	82	76	3	0.30	9.1
-4	22.5	0.43	1.0	245.43	300	250	246	56	82	76	3	0.30	9.1
-5	25	0.50	1.2	246.98	300	250	248	58	82	76	3	0.30	8.9
3-1	27.5	0.54	1.3	248.68	295	249	249	60	81	76	3	0.30	10.7
-2	30	0.48	1.1	250.25	300	249	247	61	82	76	3	0.30	8.5
-3	32.5	0.48	1.1	251.61	300	250	247	61	82	76	3	0.30	8.9
Total		<u>16.7532</u>	<u>26.680</u>	<u>34.580</u>	<u>7472</u>				<u>2018</u>	<u>1899</u>			
Average		<u>0.6701</u>	<u>1.0672</u>	<u>36.580</u>	<u>298.880</u>				<u>78.50</u>	<u>78</u>			

Sum of square roots.

Circle correct bracketed units on data sheet.

TEST LOCATION: IF outlet


Fluoride TESTING

METHOD: 13 B PAGE 12 OF 2

UNIT: 3 RUN: 3

FIELD DATA SHEET

Client <u>whelabrator</u>	Project No. <u>10955</u>
Plant <u>N. Broward</u>	Date <u>3-16-10</u>
Meter Operator <u>A. Obuchowski</u>	
Probe Operator <u>B. ARNOLD</u>	



Amb. Temp. (°F)	Bar. Press.	[in. Hg] [mbar]
Probe I.D. No.	_____	
Liner Material	_____	

Meter Box	Sample Box No.
Meter Y _d	Meter ΔH _@
K Factor	Pitot C _p
Leak Rate Before [cfm] [Lpm] @ (in. Hg)	
Leak Rate After [cfm] [Lpm] @ (in. Hg)	
Pitot Leak Check Before: <input type="checkbox"/> After: Good <input type="checkbox"/> Bad <input type="checkbox"/>	

Duct Dimensions (in.)			
Static Pres (in. H ₂ O)	Port Len. (in.)	Gas Flow [In] [Out] of page	First point all the way [In] [Out]

Filter No.		
Thimble No.		
Nozzle Diameter	Nozzle I.D.	

Start Time:	Stop Time:
-------------	------------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. [ft ³] [L]	Stack Temp. T _s (°F)	Probe T _p (°F)	Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{max} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T _t (°F)	Notes
						Set Points 250	250						
-4	35	0.45	1.1	253.07	299	250	250	62	82	76	3	0.30	8.9
-5	37.5	0.38	0.90	254.44	299	250	250	62	82	75	3	0.30	9.2
4-1	40	0.51	1.2	256.05	297	249	249	64	81	76	3	0.30	10.8
-2	42.5	0.55	1.3	257.60	301	249	248	57	82	76	3	0.30	9.0
-3	45	0.45	1.1	259.16	300	250	249	55	83	76	3	0.30	9.6
-4	47.5	0.43	1.0	260.37	300	251	248	55	83	76	3	0.30	9.9
-5	50	0.40	0.95	262.01	300	250	249	51	82	76	3	0.30	9.2
5-1	52.5	0.43	1.0	263.49	298	249	249	51	81	76	3	0.30	9.9
-2	55	0.50	1.2	265.14	300	249	249	49	82	76	3	0.30	9.7
-3	57.5	0.45	1.1	266.56	300	250	248	49	83	76	3	0.30	8.4
-4	60	0.47	1.1	268.09	299	250	248	49	83	76	3	0.30	8.5
-5	62.5	0.43	1.0	269.47	299	250	249	49	83	76	3	0.30	8.7
	Total	*											
	Average												

254.44
254.04
-0.05
262.07
-0.06

* Sum of square roots.

Circle correct bracketed units on data sheet.

12.95

QA/QC 58
Date 3/12

9 EC

9 11



G-75

Impinger Weight Sheet

Client Wheelabrator		Unit Name/Location Unit 3 FF Outlet	
Plant North Broward	Job No. 10955	Method	13B

Run No. 1	Filter Type Teflon glass mat	Sample Box No. B6
Date 3/16/10	Lot No.	pH
Analyst B. Wittse	Filter No. NA	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	100 mL DI H2O	657.1	545.3	111.8	QA/QC <i>PLW</i> Date 3/16
Impinger 2	100 mL DI H2O	618.0	558.1	59.9	
Impinger 3	Empty	469.7	455.2	14.5	
Impinger 4	Silica Gel	818.4	800.4	18.0	
				Total Weight (gm)	186.2
					204.2

Run No. 2	Filter Type Teflon glass mat	Sample Box No. B7
Date 3/16/10	Lot No.	pH
Analyst R. Vicere	Filter No. NA	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	100 mL DI H2O	652.2	536.6	115.6	QA/QC <i>SB</i> Date 3/16
Impinger 2	100 mL DI H2O	609.3	540.2	69.1	
Impinger 3	Empty	446.6	433.5	13.1	
Impinger 4	Silica Gel	780.9	765.0	15.9	
				Total Weight (gm)	197.8
					213.7

Run No. 3	Filter Type Teflon glass mat	Sample Box No. B5
Date 3/16/10	Lot No.	pH
Analyst R. Vicere	Filter No. NA	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	100 mL DI H2O	662.3	539.4	122.9	QA/QC <i>SB</i> Date 3/16
Impinger 2	100 mL DI H2O	598.1	543.1	55.0	
Impinger 3	Empty	462.8	448.3	14.5	
Impinger 4	Silica Gel	702.5	685.7	16.8	
				Total Weight (gm)	192.4
					209.2




TEST LOCATION: FF outlet
 UNIT: 3 RUN: 1

HLL TESTING
FIELD DATA SHEET

METHOD: 26A PAGE 1 OF 1

Cross-Section of Test Location



Client <u>Wheelabrator</u>	Project No. <u>10955</u>
Plant <u>N. Broward</u>	Date <u>3-16-10</u>
Meter Operator <u>A. Guchewski</u>	
Probe Operator <u>-</u>	

Amb. Temp. (°F) <u>70</u>	Bar. Press. <u>30.05</u> [in. Hg] [mbar]
Probe I.D. No. <u>67-4-3</u>	
Liner Material <u>glass</u>	

Meter Box <u>61-11</u>	Sample Box No. <u>B21</u>
Meter Yd <u>0.0892</u>	Meter ΔH @ <u>1.7379</u>
K Factor <u>-</u>	Pitot Cp

Filter No.		
Thimble No.	<u>-</u>	
Nozzle Diameter	<u>-</u>	Nozzle I.D. <u>-</u>

Leak Rate Before <u>0.003</u> [cfm] [Lpm] @ <u>15</u> (in. Hg)
Leak Rate After <u>0.002</u> [cfm] [Lpm] @ <u>15</u> (in. Hg)
Pitot Leak Check Before: <input checked="" type="checkbox"/> After: Good <input checked="" type="checkbox"/> Bad <input type="checkbox"/>

Duct Dimensions (in.) <u>96 x 96</u>			
Static Pres (in. H ₂ O) <u>-10.4</u>	Port Len. (in.) <u>10</u>	Gas Flow (in) [Out] of page <u>(In) [Out]</u>	First point all the way <u>(In) [Out]</u>

Start Time: <u>7:17</u>	Stop Time: <u>8:17</u>
-------------------------	------------------------

G-77

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. (ft ³) [L]	Stack Temp. T _s (°F)	Probe T _p (°F)		Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{m in} (°F)	DGM Outlet T _{m out} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T _i (°F)	*DGM INLET Notes
						300	300							
3-1	5		1.5	230.13	300	300	301	300	61	56	59	5	n/a	02
	10		1.5	236.99	300	300	300	300	60	56	59	5		8.2
	15		1.5	240.40	299	301	300	300	60	53	58	5		8.6
	20		1.5	243.84	299	301	300	300	59	51	59	5		8.9
	25		1.5	247.30	299	301	301	300	60	49	60	5		9.1
	30		1.5	250.67	299	300	301	300	60	49	61	5		8.6
	35		1.5	254.17	300	300	300	300	61	48	62	5		8.2
	40		1.5	257.50	299	300	300	300	61	49	63	5		8.3
	45		1.5	261.10	299	299	300	300	61	51	63	5		8.1
	50		1.5	264.55	299	299	300	300	60	51	64	5		8.5
	55		1.5	268.02	299	300	301	300	60	51	65	5		7.4
	60		1.5	271.470	299	300	299	300	61	51	65	5		8.5
	Total		16.0	41.340	3501.0					615	738			
	Average		1.5	30.750	299.250					61.5	73.8			

* Sum of square roots.

Circle correct bracketed units on data sheet.



TEST LOCATION: FS outlet
 UNIT: 3 RUN: 2


HCL TESTING
FIELD DATA SHEET

METHOD: 26A PAGE 1 OF 1

Client Wheelabrator Project No. 10255
 Plant N. Broward Date 3-16-10
 Meter Operator Aobuchowski
 Probe Operator -

Meter Box 61-11 Sample Box No. B11
 Meter Y_d 0.982 Meter ΔH_@ 1.7379
 K Factor - Pitot C_p

Leak Rate Before 0.002 [cfm] [Lpm] @ 15 (in. Hg)
 Leak Rate After 0.001 [cfm] [Lpm] @ 15 (in. Hg)
 Pitot Leak Check Before: After: Good Bad



Duct Dimensions (in.) 96 x 96
 Static Pres (in. H₂O) -11.2 Port Len. (in.) 16 Gas Flow 100 [Out] of page First point all the way [6] [Out]

Amb. Temp. (°F) 70 Bar. Press. 30.05 [inHg] [mbar]
 Probe I.D. No. 6741-3
 Liner Material glass

Filter No. -
 Thimble No. -
 Nozzle Diameter - Nozzle I.D. -

Start Time: 9:04 Stop Time: 10:04

Traverse Point Number	Min/pt 5 Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. <u>97</u> [L] <u>272.505</u>	Stack Temp. T _s (°F)	Probe T _p Filter T _f (°F)		Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{out} (°F)	Pump Vacuum (in.Hg)	XAD Trap Temp. T _t (°F)	Notes
						300	300						
3-1	5	n/a	1.5	276.42	304	299	299	60	62	65	5	n/a	O ₂
	10		1.5	279.80	303	300	300	62	62	65	5		8.9
	15		1.5	283.18	299	301	300	59	56	64	5		9.7
	20		1.5	286.53	300	301	300	58	55	64	5		8.9
	25		1.5	289.95	300	301	301	60	53	64	5		9.4
	30		1.5	293.41	300	300	300	61	53	65	5		9.2
	35		1.5	296.90	299	300	300	62	54	66	5		9.5
	40		1.5	300.33	300	300	300	62	54	66	5		8.8
	45		1.5	303.82	300	300	301	62	54	67	5		8.6
	50		1.5	307.30	300	300	300	62	54	67	5		9.7
	55		1.5	310.78	300	301	300	63	55	68	5		9.2
	60		1.5	314.270	299	300	301	62	56	68	5		9.0
	Total *		18.0	4134.0	305.0				668	789			
	Average		1.56	300.4167	300.33				60.7083				

* Sum of square roots.

Circle correct bracketed units on data sheet.

300.33 QA/QC
 Date 3-16

G-78




TEST LOCATION: FF outlet
 UNIT: 3 RUN: 3

HCL TESTING
FIELD DATA SHEET

METHOD: 264 PAGE 1 OF 1

Client <u>Wheelabrator</u>	Project No. <u>10055</u>
Plant <u>N. Broward</u>	Date <u>3-16-10</u>
Meter Operator <u>A. Obuchowski</u>	
Probe Operator <u>-</u>	

Meter Box <u>61-11</u>	Sample Box No.
Meter Yd <u>0.9892</u>	Meter ΔH ₀ <u>1.7379</u>
K Factor <u>-</u>	Pitot C _p
Leak Rate Before <u>1.002</u> [cfm] [Lpm] @ <u>15</u> (in. Hg)	
Leak Rate After [cfm] [Lpm] @ (in. Hg)	
Pitot Leak Check Before: <input checked="" type="checkbox"/> After: Good <input checked="" type="checkbox"/> Bad <input type="checkbox"/>	



Amb. Temp. (°F) <u>70</u>	Bar. Press. <u>30.05</u> [in. Hg] [mbar]
Probe I.D. No. <u>67-4-3</u>	
Liner Material <u>glass</u>	

Filter No.	
Thimble No.	
Nozzle Diameter <u>-</u>	Nozzle I.D. <u>-</u>

Start Time: 10:32 Stop Time: 11:32

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. [L]	Stack Temp. T _s (°F)	Probe T _p (°F)	Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{max} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T _t (°F)	Notes
						Set Points							
				<u>315.150</u>		<u>300</u>	<u>300</u>						<u>O₂</u>
<u>31</u>	<u>5</u>	<u>N/A</u>	<u>1.5</u>	<u>318.53</u>	<u>300</u>	<u>303</u>	<u>302</u>	<u>60</u>	<u>63</u>	<u>68</u>	<u>5</u>	<u>N/A</u>	<u>9.0</u>
	<u>10</u>		<u>1.5</u>	<u>321.96</u>	<u>300</u>	<u>301</u>	<u>302</u>	<u>60</u>	<u>63</u>	<u>68</u>	<u>5</u>		<u>7.8</u>
	<u>15</u>		<u>1.5</u>	<u>325.38</u>	<u>299</u>	<u>300</u>	<u>301</u>	<u>53</u>	<u>59</u>	<u>68</u>	<u>5</u>		<u>8.9</u>
	<u>20</u>		<u>1.5</u>	<u>328.97</u>	<u>299</u>	<u>301</u>	<u>300</u>	<u>55</u>	<u>58</u>	<u>69</u>	<u>5</u>		<u>9.1</u>
	<u>25</u>		<u>1.5</u>	<u>332.29</u>	<u>299</u>	<u>300</u>	<u>300</u>	<u>59</u>	<u>58</u>	<u>69</u>	<u>5</u>		<u>9.0</u>
	<u>30</u>		<u>1.5</u>	<u>335.69</u>	<u>299</u>	<u>299</u>	<u>300</u>	<u>60</u>	<u>59</u>	<u>70</u>	<u>5</u>		<u>8.4</u>
	<u>35</u>		<u>1.5</u>	<u>339.23</u>	<u>299</u>	<u>300</u>	<u>301</u>	<u>60</u>	<u>59</u>	<u>71</u>	<u>5</u>		<u>8.1</u>
	<u>40</u>		<u>1.5</u>	<u>342.68</u>	<u>299</u>	<u>300</u>	<u>300</u>	<u>61</u>	<u>59</u>	<u>72</u>	<u>5</u>		<u>9.3</u>
	<u>45</u>		<u>1.5</u>	<u>346.20</u>	<u>299</u>	<u>300</u>	<u>300</u>	<u>61</u>	<u>60</u>	<u>72</u>	<u>5</u>		<u>9.2</u>
	<u>50</u>		<u>1.5</u>	<u>349.73</u>	<u>299</u>	<u>300</u>	<u>299</u>	<u>62</u>	<u>61</u>	<u>73</u>	<u>5</u>		<u>9.0</u>
	<u>55</u>		<u>1.5</u>	<u>353.27</u>	<u>300</u>	<u>301</u>	<u>300</u>	<u>63</u>	<u>61</u>	<u>74</u>	<u>5</u>		<u>9.5</u>
	<u>60</u>		<u>1.5</u>	<u>356.755</u>	<u>299</u>	<u>300</u>	<u>300</u>	<u>63</u>	<u>63</u>	<u>74</u>	<u>5</u>		<u>8.7</u>
	Total		<u>18</u>	<u>41.6050</u>	<u>3542</u>	<u>58</u>			<u>727</u>	<u>848</u>			
	Average		<u>1.50</u>		<u>299.250</u>				<u>65.4587</u>				

* Sum of square roots.

Circle correct bracketed units on data sheet.

QA/QC U
 Date 3-16



G-79

Impinger Weight Sheet

Client Wheelabrator		Unit Name/Location: Unit 3 FF Outlet	
Plant North Broward	Job No. 10955	Method	Mod. 26A

Run No. 1	Filter Type Quartz	Sample Box No. B21
Date 3/16/10	Lot No.	pH
Analyst B. Wilke	Filter No. NA	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	50 mL 0.1N H2SO4	505.4	472.7	32.7	
Impinger 2	100 mL 0.1N H2SO4	730.5	637.4	93.1	
Impinger 3	100 mL 0.1N H2SO4	594.7	533.5	61.2	
Impinger 4	Empty	464.1	445.2	18.9	
Impinger 5	Silica Gel	760.9	731.3	29.6	Total Weight (gm)
					205.9
					235.5

QA/QC RW
 Date 3/16

Run No. 2	Filter Type Quartz	Sample Box No. B11
Date 3/16/10	Lot No.	pH
Analyst R. Vicere	Filter No. NA	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	50 mL 0.1N H2SO4	510.0	465.0	45.0	
Impinger 2	100 mL 0.1N H2SO4	669.7	558.4	111.3	
Impinger 3	100 mL 0.1N H2SO4	603.7	550.9	52.8	
Impinger 4	Empty	466.6	454.4	12.2	
Impinger 5	Silica Gel	785.7	766.3	19.4	Total Weight (gm)
					221.3
					240.7

QA/QC RV
 Date 3/16

Run No. 3	Filter Type Quartz	Sample Box No. B21
Date 3/16/10	Lot No.	pH
Analyst B. Wilke	Filter No. NA	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	50 mL 0.1N H2SO4	520.3	473.4	46.9	
Impinger 2	100 mL 0.1N H2SO4	751.2	643.1	108.1	
Impinger 3	100 mL 0.1N H2SO4	583.8	535.6	48.2	
Impinger 4	Empty	471.5	448.1	23.4	
Impinger 5	Silica Gel	780.7	760.2	20.5	Total Weight (gm)
					226.6
					247.1

QA/QC RB
 Date 3/16



TEST LOCATION: SDA INLET

HCL

TESTING

METHOD: ZGA PAGE 1 OF 1

UNIT: 3

RUN: 1

FIELD DATA SHEET

Cross-Section of Test Location



Duct Dimensions (in.) <u>105</u>			
Static Pres (in. H ₂ O)	Port Len. (in.)	Gas Flow (in.) [Out]	First point all the way (in.) [Out]
<u>-2.1</u>	<u>14"</u>		<u>(In) [Out]</u>

Amb. Temp. (°F)	<u>69</u>	Bar. Press.	<u>30.65</u>	(in. Hg) [mbar]
Probe I.D. No.	<u>67-4-5</u>			
Liner Material	<u>GLASS</u>			

Client <u>wheelabrator</u>	Project No. <u>10955</u>
Plant <u>N. Broward</u>	Date <u>3-16-10</u>
Meter Operator <u>B.A. Arnold</u>	
Probe Operator <u>B.A. Arnold</u>	

Meter Box <u>61-8</u>	Sample Box No. <u>B22</u>
Meter Y _d <u>6.9916</u>	Meter ΔH _@ <u>1.7550</u>
K Factor <u>N/A</u>	Pitot C _p
Leak Rate Before <u>0.007</u> (cfm) [Lpm]	@ <u>15</u> (in. Hg)
Leak Rate After <u>0.004</u> (cfm) [Lpm]	@ <u>17</u> (in. Hg)
Pitot Leak Check Before: <input checked="" type="checkbox"/>	After: Good <input checked="" type="checkbox"/> Bad <input type="checkbox"/>

Filter No.	<u>N/A</u>		
Thimble No.	<u>N/A</u>		
Nozzle Diameter	<u>N/A</u>	Nozzle I.D.	<u>N/A</u>

Start Time: <u>7:17</u>	Stop Time: <u>8:17</u>
-------------------------	------------------------

G-81

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. (ft ³) [L]	Stack Temp. T _s (°F)	Probe T _p (°F)	Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{m in} (°F)	DGM Outlet T _{m out} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T _t (°F)	Notes
						Set Points							
				<u>992.610</u>		<u>355</u>	<u>355</u>						
1-1	5	<u>0.50</u>	<u>1.2</u>	<u>995.70</u>	<u>501</u>	<u>356</u>	<u>350</u>	<u>63</u>	<u>67</u>	<u>66</u>	<u>3.0</u>	<u>7.2</u>	
	10	<u>0.50</u>		<u>998.55</u>	<u>501</u>	<u>358</u>	<u>351</u>	<u>61</u>	<u>68</u>	<u>66</u>	<u>3.5</u>	<u>7.7</u>	
	15	<u>0.50</u>		<u>001.49</u>	<u>500</u>	<u>357</u>	<u>356</u>	<u>60</u>	<u>69</u>	<u>67</u>	<u>4.0</u>	<u>8.3</u>	
	20	<u>0.51</u>		<u>004.48</u>	<u>502</u>	<u>358</u>	<u>354</u>	<u>60</u>	<u>71</u>	<u>67</u>	<u>6.5</u>	<u>8.4</u>	
	25	<u>0.52</u>		<u>007.47</u>	<u>506</u>	<u>356</u>	<u>353</u>	<u>59</u>	<u>73</u>	<u>68</u>	<u>8.5</u>	<u>7.4</u>	
	30	<u>0.52</u>		<u>010.48</u>	<u>505</u>	<u>355</u>	<u>355</u>	<u>60</u>	<u>74</u>	<u>69</u>	<u>10.0</u>	<u>7.1</u>	
	35	<u>0.52</u>		<u>013.45</u>	<u>505</u>	<u>356</u>	<u>360</u>	<u>61</u>	<u>75</u>	<u>69</u>	<u>10.5</u>	<u>8.0</u>	
	40	<u>0.51</u>		<u>016.48</u>	<u>505</u>	<u>355</u>	<u>351</u>	<u>62</u>	<u>75</u>	<u>69</u>	<u>12.5</u>	<u>7.4</u>	
	45	<u>0.53</u>		<u>019.50</u>	<u>504</u>	<u>355</u>	<u>354</u>	<u>63</u>	<u>75</u>	<u>70</u>	<u>14.5</u>	<u>7.7</u>	
	50	<u>0.54</u>	<u>1.1</u>	<u>022.49</u>	<u>506</u>	<u>355</u>	<u>356</u>	<u>63</u>	<u>75</u>	<u>70</u>	<u>15.5</u>	<u>7.6</u>	
	55	<u>0.49</u>	<u>1.0</u>	<u>025.39</u>	<u>502</u>	<u>355</u>	<u>355</u>	<u>64</u>	<u>74</u>	<u>70</u>	<u>14.5</u>	<u>7.0</u>	
	60	<u>0.47</u>	<u>1.0</u>	<u>028.220</u>	<u>501</u>	<u>355</u>	<u>356</u>	<u>65</u>	<u>73</u>	<u>70</u>	<u>16.5</u>	<u>8.0</u>	
	Total	<u>6.2506</u>	<u>13.958</u>	<u>356.100</u>	<u>4038</u>				<u>949</u>	<u>821</u>			
	Average	<u>6.5208</u>	<u>1.700</u>	<u>503.1667</u>					<u>14.5233</u>	<u>53</u>			

Sum of square roots 1.158

Circle correct bracketed units on data sheet.

QA/QC BA
Date 3-16-10

10.9166



TEST LOCATION: SDA INLET HCC TESTING METHOD: 26A PAGE 1 OF 1
 UNIT: 3 RUN: 2 FIELD DATA SHEET

FIELD DATA SHEET

Cross-Section of Test Location



Client <u>WALABRATOR</u>	Project No. <u>10955</u>
Plant <u>N. BROWARD</u>	Date <u>3-16-10</u>
Meter Operator <u>B. ARNOLD</u>	
Probe Operator <u>B. ARNOLD</u>	

Amb. Temp. (°F) <u>72</u>	Bar. Press. <u>30.05</u> (in. Hg) [mbar]
Probe I.D. No. <u>GLASS 67-4-5</u>	
Liner Material <u>GLASS</u>	

Meter Box <u>61-8</u>	Sample Box No. <u>B16</u>
Meter Y _d <u>0.9916</u>	Meter ΔH _@ <u>1.7550</u>
K Factor <u>N/A</u>	Pitot C _p

Filter No. <u>N/A</u>		
Thimble No. <u>N/A</u>		
Nozzle Diameter <u>N/A</u>	Nozzle I.D.	<u>N/A</u>

Duct Dimensions (in.) <u>1.05</u>			
Static Pres (in. H ₂ O) <u>-2.0</u>	Port Len. (in.) <u>14</u>	Gas Flow (In) [Out] of page <u>(In) [Out]</u>	First point all the way <u>(In) [Out]</u>

Leak Rate Before <u>0.003</u> (cfm) [Lpm] @ <u>15</u> (in. Hg)
Leak Rate After <u>0.003</u> (cfm) [Lpm] @ <u>14</u> (in. Hg)
Pitot Leak Check Before: <input checked="" type="checkbox"/> After: Good <input checked="" type="checkbox"/> Bad <input type="checkbox"/>

Start Time: <u>9:04</u>	Stop Time: <u>10:04</u>
-------------------------	-------------------------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m		Stack Temp. T _s (°F)	Probe T _p (°F)	Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{min} (°F)	DGM Outlet T _{mout} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T _t (°F)	Notes
				Init. Vol. (ft ³) [L]	Set Points									
				<u>028.865</u>			<u>355</u>	<u>355</u>					<u>BA 02</u>	
<u>1-1</u>	<u>5</u>	<u>0.55</u>	<u>1.2</u>	<u>031.92</u>	<u>508</u>	<u>354</u>	<u>356</u>	<u>58</u>	<u>70</u>	<u>69</u>	<u>2.5</u>	<u>8.1</u>		
	<u>10</u>	<u>0.51</u>		<u>034.92</u>	<u>510</u>	<u>358</u>	<u>356</u>	<u>57</u>	<u>41</u>	<u>69</u>	<u>3.0</u>	<u>7.5</u>		
	<u>15</u>	<u>0.46</u>		<u>037.95</u>	<u>508</u>	<u>358</u>	<u>357</u>	<u>56</u>	<u>72</u>	<u>70</u>	<u>4.0</u>	<u>7.9</u>		
	<u>20</u>	<u>0.56</u>		<u>040.96</u>	<u>509</u>	<u>356</u>	<u>357</u>	<u>56</u>	<u>75</u>	<u>70</u>	<u>5.0</u>	<u>7.6</u>		
	<u>25</u>	<u>0.56</u>		<u>043.95</u>	<u>510</u>	<u>355</u>	<u>355</u>	<u>57</u>	<u>76</u>	<u>71</u>	<u>6.0</u>	<u>7.6</u>		
	<u>30</u>	<u>0.61</u>		<u>046.96</u>	<u>510</u>	<u>355</u>	<u>354</u>	<u>57</u>	<u>77</u>	<u>71</u>	<u>6.5</u>	<u>8.2</u>		
	<u>35</u>	<u>0.54</u>		<u>049.97</u>	<u>508</u>	<u>355</u>	<u>354</u>	<u>58</u>	<u>77</u>	<u>71</u>	<u>8.0</u>	<u>7.8</u>		
	<u>40</u>	<u>0.46</u>		<u>052.98</u>	<u>508</u>	<u>355</u>	<u>358</u>	<u>59</u>	<u>78</u>	<u>72</u>	<u>9.0</u>	<u>7.2</u>		
	<u>45</u>	<u>0.44</u>		<u>056.02</u>	<u>509</u>	<u>355</u>	<u>353</u>	<u>60</u>	<u>78</u>	<u>72</u>	<u>10.0</u>	<u>7.1</u>		
	<u>50</u>	<u>0.60</u>		<u>059.04</u>	<u>511</u>	<u>355</u>	<u>355</u>	<u>62</u>	<u>78</u>	<u>72</u>	<u>11.0</u>	<u>8.2</u>		
	<u>55</u>	<u>0.57</u>		<u>062.07</u>	<u>514</u>	<u>355</u>	<u>355</u>	<u>63</u>	<u>78</u>	<u>72</u>	<u>12.0</u>	<u>8.2</u>		
	<u>60</u>	<u>0.47</u>		<u>065.115</u>	<u>510</u>	<u>355</u>	<u>353</u>	<u>64</u>	<u>78</u>	<u>73</u>	<u>13.0</u>	<u>7.5</u>		
	Total	<u>6.5300</u>	<u>14.4000</u>	<u>36.2500</u>	<u>6115</u>				<u>909</u>	<u>852</u>				
	Average	<u>0.5447</u>	<u>1.2000</u>			<u>509.5833</u>			<u>73.3788</u>	<u>73</u>				

Sum of square roots.

Circle correct bracketed units on data sheet

QA/QC BA
Date 3-16-10

73.333



G-82

TEST LOCATION: SDA INLET

HCL

TESTING


METHOD: 26A PAGE 1 OF 1

UNIT: 3

RUN: 3

FIELD DATA SHEET

Cross-Section of Test Location



Duct Dimensions (in.) <u>105</u>			
Static Pres (in. H ₂ O)	Port Len. (in.)	Gas Flow (l/min) [Out]	First point all the way [In] [Out]
<u>-2.2</u>	<u>14</u>	<u>10</u>	<u>(In)</u> [Out]

Client <u>WALLABCOR</u>	Project No. <u>10955</u>
Plant <u>N. BROWARD</u>	Date <u>3-16-10</u>
Meter Operator <u>B. ARNOLD</u>	
Probe Operator <u>B. ARNOLD</u>	

Meter Box <u>61-8</u>	Sample Box No. <u>822</u>
Meter Y _d <u>0.9916</u>	Meter ΔH _@ <u>1.7580</u>
K Factor <u>N/A</u>	Pitot C _p
Leak Rate Before <u>0.003</u> [cfm] [Lpm] @ <u>15</u> (in. Hg)	
Leak Rate After <u>0.003</u> [cfm] [Lpm] @ <u>17</u> (in. Hg)	
Pitot Leak Check Before: <input checked="" type="checkbox"/> After: Good <input checked="" type="checkbox"/> Bad <input type="checkbox"/>	

Amb. Temp. (°F)	Bar. Press. <u>30.05</u> [in. Hg] [mbar]
Probe I.D. No. <u>8225 BA 67-4-5</u>	
Liner Material <u>GLASS</u>	

Filter No. <u>N/A</u>	
Thimble No. <u>N/A</u>	
Nozzle Diameter <u>N/A</u>	Nozzle I.D. <u>N/A</u>

Start Time: <u>10:32</u>	Stop Time: <u>11:32</u>
--------------------------	-------------------------

G-83

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H ₂ O)	Orifice Setting ΔH (in. H ₂ O)	Gas Sample Volume V _m Init. Vol. [ft ³] [L]	Stack Temp. T _s (°F)	Probe T _p (°F)	Filter T _f (°F)	Cond. Temp. T _c (°F)	DGM Inlet T _{m in} (°F)	DGM Outlet T _{m out} (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T _t (°F)	Notes
						Set Points						T_t	
1-1	5	0.80	1.2	065.410	508	355	355	61	74	73	2.5	8.1	
	10	0.65		071.20	507	358	362	60	75	73	3.0	7.0	
	15	0.47		074.14	505	358	359	58	77	73	4.0	7.9	
	20	0.62		077.12	508	357	354	57	78	73	6.0	7.5	
	25	0.53		080.00	510	356	357	56	80	74	7.5	6.8	
	30	0.51		082.97	508	356	355	56	81	75	8.0	7.5	
	35	0.52		089.02 86.02	507	356	357	57	81	75	10.5	7.6	
	40	0.43		092.06 89.06	509	355	356	57	81	75	12.0	7.3	
	45	0.44		095.09 92.06	509	355	356	59	82	77	15.5	7.8	
	50	0.53		098.02 95.02	509	355	356	61	82	78	16.5	7.8	
	55	0.56	1.1	98.02 (assumed SB)	509	355	360	63	82	78	16.5	8.1	← MISSED Reading
	60	0.55	1.0	100.865	509	355	358	64	83	78	16.5	8.6	
	Total		14.1000	35.4550	6098				956	902			
	Average		1.1750	35.4550	508.1667				77.4167				

* Sum of square roots.

Circle correct bracketed units on data sheet.

QA/QC BA
Date 3-16-10



Impinger Weight Sheet

Client Wheelabrator		Unit Name/Location Unit 3 SDA Inlet	
Plant North Broward	Job No. 10955	Method	Mod. 26A

Run No. 1	Filter Type Quartz	Sample Box No. B22
Date 3/16/10	Lot No.	pH
Analyst R. Vicere	Filter No. NA	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)			
Impinger 1	50 mL 0.1N H2SO4	506.6	468.1	38.5	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>QA/QC SB</td> </tr> <tr> <td>Date 3/16</td> </tr> </table>	QA/QC SB	Date 3/16
QA/QC SB							
Date 3/16							
Impinger 2	100 mL 01.N H2SO4	615.6	531.2	84.4			
Impinger 3	100 mL 01.N H2SO4	566.9	548.5	18.4			
Impinger 4	Empty	431.7	426.3	5.4			
Impinger 5	Silica Gel	747.1	734.0	13.1			
				Total Weight (gm)	46.7		
					159.8		

Run No. 2	Filter Type Quartz	Sample Box No. B16
Date 3/16/10	Lot No.	pH
Analyst R. Vicere	Filter No. NA	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)			
Impinger 1	50 mL 0.1N H2SO4	504.1	451.1	53.0	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>QA/QC SB</td> </tr> <tr> <td>Date 3/16</td> </tr> </table>	QA/QC SB	Date 3/16
QA/QC SB							
Date 3/16							
Impinger 2	100 mL 01.N H2SO4	629.9	554.4	75.5			
Impinger 3	100 mL 01.N H2SO4	556.7	538.6	18.1			
Impinger 4	Empty	463.6	460.7	2.9			
Impinger 5	Silica Gel	741.3	729.2	12.1			
				Total Weight (gm)	149.5		
					161.6		

Run No. 3	Filter Type Quartz	Sample Box No. B22
Date 3/16/10	Lot No.	pH
Analyst R. Vicere	Filter No. NA	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)			
Impinger 1	50 mL 0.1N H2SO4	507.8	468.5	39.3	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>QA/QC SB</td> </tr> <tr> <td>Date 3/16</td> </tr> </table>	QA/QC SB	Date 3/16
QA/QC SB							
Date 3/16							
Impinger 2	100 mL 01.N H2SO4	610.7	534.3	76.4			
Impinger 3	100 mL 01.N H2SO4	572.1	553.2	18.9			
Impinger 4	Empty	432.4	428.3	4.1			
Impinger 5	Silica Gel	756.5	746.8	9.7			
				Total Weight (gm)	138.7		
					148.4		




EPA METHOD 22 Fugitive or Smoke Emission Inspection Outdoor Location

Job No.	10955	Date	3/18/10
Client	wheelabrator	Observer	Raina Vicere
Plant	North Broward	Affiliation	Clean Air

Industry	MWS	Process Unit	Ash Handling System
----------	-----	--------------	---------------------

Precipitation	none	Wind Direction	W
Sky Conditions	Sunny	Wind Speed	6

Sketch process unit: Indicate observer position relative to source and sun. Indicate potential emission points and/or actual emission points.



OBSERVATIONS

Comments	Clock Time	Observation Period Duration (min : sec)	Accumulated Emission Duration (min : sec)
Ash Conveyors and Bayhouse doors Ash Unloading Conveyor	Start 7:22	20:00	00:00
	Stop 7:42		
	Start 7:47	20:00	00:00
	Stop 8:07		
	Start 8:12	20:00	00:00
	Stop 8:32		
	Start 8:37		
	Stop 8:57		
	Start 9:02		
	Stop 9:22		
	Start 9:27		
	Stop 9:47		

Note: Rest breaks must be taken every 15 to 20 minutes for 5 to 10 minutes.




EPA METHOD 22 Fugitive or Smoke Emission Inspection Outdoor Location

Job No.	10955	Date	3/18/10
Client	Wheelabrator	Observer	Raina Vicore
Plant	North Broward	Affiliation	Clean Air

Industry	MWS	Process Unit	Ash Handling System
----------	-----	--------------	---------------------

Precipitation	None	Wind Direction	W
Sky Conditions	Sunny	Wind Speed	9

Sketch process unit: Indicate observer position relative to source and sun. Indicate potential emission points and/or actual emission points.



OBSERVATIONS

Comments	Clock Time	Observation Period Duration (min : sec)	Accumulated Emission Duration (min : sec)
Metals Unloading and baghouse doors Ash Conveyor / Doors to Baghouse	Start 8:43	20:00	00:00
	Stop 9:03		
	Start 9:08	20:00	00:00
	Stop 9:28		
	Start 9:33	20:00	00:00
	Stop 9:54		
	Start		
	Stop		
	Start		
	Stop		
	Start		
	Stop		

Note: Rest breaks must be taken every 15 to 20 minutes for 5 to 10 minutes.




EPA METHOD 22 Fugitive or Smoke Emission Inspection Outdoor Location

Job No.	10955	Date	3/18/10
Client	Wheelabrator	Observer	Raina Vicore
Plant	North Broward	Affiliation	Clean Air

Industry	MWS	Process Unit	Ash Handling System
----------	-----	--------------	---------------------

Precipitation	none	Wind Direction	WNW
Sky Conditions	partly cloudy	Wind Speed	14

Sketch process unit: Indicate observer position relative to source and sun. Indicate potential emission points and/or actual emission points.



OBSERVATIONS

Comments	Clock Time	Observation Period Duration (min : sec)	Accumulated Emission Duration (min : sec)
Ash Building	Start 11:10	20:00	00:00
	Stop 11:30		
Baghouse Area	Start 11:35	20:00	00:00
	Stop 11:55		
Ash Unloading / EB Conveyor	Start 12:00	20:00	00:00
	Stop 12:20		
Rolling Door / Door to Baghouse	Start		
	Stop		
	Start		
	Stop		
	Start		
	Stop		

Note: Rest breaks must be taken every 15 to 20 minutes for 5 to 10 minutes.



Visible Emissions Observation Form

CLIENT/OWNER		PROJECT NUMBER		OBSERVATION DATE				START TIME				END TIME																
Wheelerator		10955		3/17/10				10:26				11:26																
PLANT	UNIT	RUN	MIN	SEC	15	30	45	60	MIN	SEC	15	30	45	60														
North Broward		1	0	0	0	0	0	0	30	0	0	0	0	0														
PROCESS EQUIPMENT		OPERATING MODE																										
fine silo																												
CONTROL EQUIPMENT		OPERATING MODE																										
fabric filter baghouse																												
DESCRIBE EMISSION POINT			5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	
vent fabric filter baghouse			0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
HEIGHT ABOVE GROUND LEVEL	DISTANCE FROM OBSERVER																											
90	270																											
HEIGHT RELATIVE TO OBSERVER	DIRECTION FROM OBSERVER																											
90																												
DESCRIBE EMISSIONS																												
clear																												
EMISSION COLOR	PLUME TYPE	CONTINUOUS																										
clear		<input checked="" type="checkbox"/>																										
	FUGITIVE	INTERMITTENT																										
	<input type="checkbox"/>	<input type="checkbox"/>																										
WATER DROPLETS PRESENT	IF WATER DROPLET PLUME																											
YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	ATTACHED <input type="checkbox"/> DETACHED <input type="checkbox"/>																											
POINT IN PLUME AT WHICH EMISSIONS WERE DETERMINED																												
2nd vent opening																												
DESCRIBE BACKGROUND																												
Tan color unit cloudy, raining outside																												
WIND SPEED	WIND DIRECTION																											
- calm -	-																											
AMBIENT TEMPERATURE	RELATIVE HUMIDITY																											
64	69																											
LAYOUT SKETCH OF SOURCE			RANGE OF OPACITY READINGS				OBSERVER'S NAME (PRINT)				OBSERVER'S SIGNATURE				DATE													
			MINIMUM				MAXIMUM				Raine Viere				3/17/10													
			0				0				[Signature]																	
COMMENTS			CERTIFIED BY				DATE																					



Visible Emissions Observation Form

CLIENT/OWNER		PROJECT NUMBER		OBSERVATION DATE					START TIME		END TIME	
North Broadway		10955		3/17/10					11:26		11:45	
PLANT	UNIT	RUN	SEC MIN	15	30	45	60	SEC MIN	15	30	45	60
Wheelabrator			0	0	0	0	0	30				
PROCESS EQUIPMENT	OPERATING MODE											
10ms 5510												
CONTROL EQUIPMENT	OPERATING MODE											
fabr filter baghouse												
DESCRIBE EMISSION POINT			5	0	0	0	0	35				
VAT fabric filter baghouse			6	0	0	0	0	36				
			7	0	0	0	0	37				
			8	0	0	0	0	38				
HEIGHT ABOVE GROUND LEVEL	DISTANCE FROM OBSERVER		9	0	0	0	0	39				
90	270		10	0	0	0	0	40				
HEIGHT RELATIVE TO OBSERVER	DIRECTION FROM OBSERVER		11	0	0	0	0	41				
90			12	0	0	0	0	42				
DESCRIBE EMISSIONS			13	0	0	0	0	43				
Clear			14	0	0	0	0	44				
			15	0	0	0	0	45				
			16	0	0	0	0	46				
EMISSION COLOR	PLUME TYPE: CONTINUOUS <input checked="" type="checkbox"/>		17	0	0	0	0	47				
Clear	(FUGITIVE <input type="checkbox"/> INTERMITTENT <input type="checkbox"/>		18	0	0	0	0	48				
WATER DROPLETS PRESENT	IF WATER DROPLET PLUME:		19	0	0	0	0	49				
YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	ATTACHED <input type="checkbox"/> DETACHED <input checked="" type="checkbox"/>		20					50				
POINT IN PLUME AT WHICH EMISSIONS WERE DETERMINED			21					51				
2 ft after vent opening			22					52				
DESCRIBE BACKGROUND			23					53				
faint color unit cloudy & raining outside			24					54				
			25					55				
WIND SPEED	WIND DIRECTION		26					56				
6	WNW		27					57				
AMBIENT TEMPERATURE	RELATIVE HUMIDITY		28					58				
	65		29					59				
LAYOUT SKETCH OF SOURCE			RANGE OF OPACITY READINGS									
			MINIMUM			MAXIMUM						
			0			0						
			OBSERVER'S NAME (PRINT)									
			Rina Vicer									
			OBSERVER'S SIGNATURE						DATE			
			Rina Vicer						3/17/10			
			CERTIFIED BY						DATE			
COMMENTS												

This Page Intentionally Left Blank

WHEELABRATOR NORTH BROWARD, INC.
POMPANO BEACH, FL

CleanAir Project No: 10955-2

FIELD DATA PRINTOUTS

H

This Page Intentionally Left Blank

Field Data Printout

Test Method: USEPA Method 5/29
Analyte: Particulate/Metals

Location: Unit 1 FF Outlet
 Test Run: 1
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Source Area (ff): 64.00000
 Meter Operator: P. Bihun 505
 Probe Operator: P. Bihun 505

Bar. Press. (in. Hg): 30.05
 Static P: -10.0
 O₂ (dry volume %): 9.53
 CO₂ (dry volume %): 9.88
 N₂+CO (dry volume %): 80.59

Nozzle ID No: 270-1
 Nozzle Diameter (D_n): 0.270
 Probe ID No: 67-8-4
 Pitot C_p: 0.8050
 Pitot Leak Check: Pass Fail

Test Date: 3/16/10
 Start Time: 07:21
 Stop Time: 09:32
 Leak Rate Before: 0.002 cfm @ 15 "Hg
 Leak Rate After: 0.002 cfm @ 8 "Hg

H₂O (condensate, ml or gm): 413.3
 H₂O (silica, g): 18.2
 Actual Moisture (%): 20.13

Meter Box ID No: 61-6
 Meter ΔH@: 1.68200
 Meter Y_a: 0.99000

Traverse Point	Run Time 5.0 min/read	Pitot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dcf)	Stack T _s (°F)	Dry Gas Meter		√ΔP _a (calculated) (√in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)
						T _{m-in} (°F)	T _{m-out} (°F)			
	0.0			76.485						
1-01	5.0	0.43	0.96	79.290	292	59	57	0.66	2.81	99.9
1-02	10.0	0.51	1.10	82.200	293	61	57	0.71	2.91	95.1
1-03	15.0	0.57	1.30	85.410	293	64	58	0.75	3.21	98.8
1-04	20.0	0.64	1.40	88.790	294	65	58	0.80	3.38	98.2
1-05	25.0	0.64	1.40	92.180	294	66	58	0.80	3.39	98.4
LEAK CHECK	25.0			92.240						
2-01	30.0	0.57	1.30	95.510	293	66	59	0.75	3.27	100.4
2-02	35.0	0.52	1.20	98.590	294	67	60	0.72	3.08	98.9
2-03	40.0	0.52	1.20	101.690	294	68	60	0.72	3.10	99.4
2-04	45.0	0.68	1.50	105.200	294	69	61	0.82	3.51	98.3
2-05	50.0	0.60	1.30	108.455	294	70	61	0.77	3.26	96.9
LEAK CHECK	50.0			108.515						
3-01	55.0	0.63	1.40	111.870	294	68	61	0.79	3.36	97.7
3-02	60.0	0.53	1.20	115.040	293	69	61	0.73	3.17	100.4
3-03	65.0	0.58	1.30	118.300	294	68	61	0.76	3.26	98.9
3-04	70.0	0.65	1.50	121.800	294	69	61	0.81	3.50	100.3
3-05	75.0	0.68	1.50	125.290	293	69	62	0.82	3.49	97.6
LEAK CHECK	75.0			125.350						
4-01	80.0	0.61	1.40	128.670	294	69	62	0.78	3.32	98.1
4-02	85.0	0.46	1.00	131.710	294	70	62	0.68	3.04	103.2
4-03	90.0	0.42	0.94	134.510	293	70	62	0.65	2.80	99.4
4-04	95.0	0.61	1.40	137.890	295	69	62	0.78	3.38	99.9
4-05	100.0	0.68	1.50	141.415	294	70	63	0.82	3.53	98.5
LEAK CHECK	100.0			141.453						
5-01	105.0	0.45	1.00	144.350	291	69	63	0.67	2.90	99.2
5-02	110.0	0.45	1.00	147.230	292	70	63	0.67	2.88	98.6
5-03	115.0	0.47	1.10	150.200	290	71	63	0.69	2.97	99.3
5-04	120.0	0.58	1.30	153.500	292	71	63	0.76	3.30	99.5
5-05	125.0	0.69	1.50	156.945	294	71	63	0.83	3.44	95.4
Final	125.0		1.26800	80.24200	293.28000	64.38000		0.75072	80.24200	

25 points sampled
 QC-Check: Field Averages

Sq. RI ΔP	0.7507	1.2680	80.2400	293.2800	64.3800
-----------	--------	--------	---------	----------	---------

2RSD = 11.6%

Avg. OK Avg. OK Avg. OK Avg. OK Avg. OK

041310 100206

Field Data Printout

Test Method: USEPA Method 5/29
Analyte: Particulate/Metals

Location: Unit 1 FF Outlet
 Test Run: 2
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Source Area (ff): 64.00000
 Meter Operator: P. Bihun 505
 Probe Operator: P. Bihun 505
 Test Date: 3/16/10
 Start Time: 10:00
 Stop Time: 12:14
 Leak Rate Before: 0.003 cfm @ 15 "Hg
 Leak Rate After: 0.002 cfm @ 8 "Hg

Bar. Press. (in. Hg): 30.05
 Static P: -10.0
 O₂ (dry volume %): 9.46
 CO₂ (dry volume %): 9.93
 N₂+CO (dry volume %): 80.61

Nozzle ID No: 270-1
 Nozzle Diameter (Q): 0.270
 Probe ID No: 67-8-4
 Pitot C_p: 0.8050
 Pitot Leak Check: Pass Fail

H₂O (condensate, ml or gm): 413.3
 H₂O (silica, g): 18.9
 Actual Moisture (%): 20.04

Meter Box ID. No: 61-6
 Meter ΔH@: 1.68200
 Meter Y_d: 0.99000

Traverse Point	Run Time 5.0 min/read	Pitot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dcf)	Stack T _s (°F)	Dry Gas Meter		√ΔP _s (calculated) (√in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)
						T _{m-in} (°F)	T _{m-out} (°F)			
	0.0			157.285						
1-01	5.0	0.58	1.30	160.680	293	63	62	0.76	3.40	103.2
1-02	10.0	0.59	1.40	163.960	295	65	62	0.77	3.28	98.9
1-03	15.0	0.61	1.40	167.330	295	68	63	0.78	3.37	99.5
1-04	20.0	0.72	1.70	171.060	295	68	62	0.85	3.73	101.6
1-05	25.0	0.68	1.60	174.690	295	70	63	0.82	3.63	101.4
LEAK CHECK	25.0			174.740						
2-01	30.0	0.49	1.10	177.660	292	70	64	0.70	2.92	95.7
2-02	35.0	0.54	1.20	180.800	293	72	64	0.73	3.14	97.9
2-03	40.0	0.61	1.40	184.170	294	72	65	0.78	3.37	98.9
2-04	45.0	0.67	1.50	187.680	295	74	65	0.82	3.51	98.2
2-05	50.0	0.65	1.50	191.210	294	74	66	0.81	3.53	100.1
LEAK CHECK	50.0			191.265						
3-01	55.0	0.56	1.30	194.500	293	73	66	0.75	3.24	98.8
3-02	60.0	0.45	1.00	197.390	295	74	66	0.67	2.89	98.4
3-03	65.0	0.56	1.30	200.640	295	74	66	0.75	3.25	99.3
3-04	70.0	0.60	1.40	203.990	295	74	66	0.77	3.35	98.9
3-05	75.0	0.63	1.50	207.535	294	75	67	0.79	3.54	101.9
LEAK CHECK	75.0			207.580						
4-01	80.0	0.53	1.20	210.740	292	73	66	0.73	3.16	99.1
4-02	85.0	0.50	1.20	213.870	295	73	66	0.71	3.13	101.3
4-03	90.0	0.55	1.30	217.160	296	73	66	0.74	3.29	101.6
4-04	95.0	0.57	1.30	220.430	296	74	66	0.75	3.27	99.1
4-05	100.0	0.62	1.40	223.870	297	75	67	0.79	3.44	99.9
LEAK CHECK	100.0			223.915						
5-01	105.0	0.45	1.00	226.760	297	73	67	0.67	2.85	97.0
5-02	110.0	0.43	0.99	229.640	297	73	67	0.66	2.88	100.5
5-03	115.0	0.40	0.92	232.410	296	74	67	0.63	2.77	100.0
5-04	120.0	0.42	0.97	235.260	297	74	67	0.65	2.85	100.5
5-05	125.0	0.72	1.70	238.980	300	74	67	0.85	3.72	100.6
Final	125.0		1.30320	81.50000	295.04000	68.70000		0.74940	81.50000	

25 points sampled
 QC-Check: Field Averages

Sq.Rt.ΔP	0.7494	1.3032	81.5000	295.0400	68.7000
<input checked="" type="checkbox"/> Avg. OK					

2RSD = 12.2%

041310 100206
 M

Field Data Printout

Test Method: USEPA Method 5/29
Analyte: Particulate/Metals

Location: Unit 1 FF Outlet
 Test Run: 3
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Source Area (ff): 64.00000
 Meter Operator: P. Bihun 505
 Probe Operator: P. Bihun 505
 Test Date: 3/16/10
 Start Time: 12:36
 Stop Time: 14:47
 Leak Rate Before: 0.004 cfm @ 15 "Hg
 Leak Rate After: 0.003 cfm @ 8 "Hg

Bar. Press. (in. Hg): 30.05
 Static P: -10.1
 O₂ (dry volume %): 9.74
 CO₂ (dry volume %): 9.83
 N₂+CO (dry volume %): 80.43

Nozzle ID No: 270-1
 Nozzle Diameter (D): 0.270
 Probe ID No: 67-8-4
 Pitot C_p: 0.8050
 Pitot Leak Check: Pass Fail

H₂O (condensate, ml or gm): 410.8
 H₂O (silica, g): 14.2
 Actual Moisture (%): 19.89

Meter Box ID. No: 61-6
 Meter ΔH@: 1.68200
 Meter Y_d: 0.99000

Traverse Point	Run Time 5.0 min/read	Pitot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dcf)	Stack T _s (°F)	Dry Gas Meter		√ΔP _s (calculated) (√in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)
						T _{m-in} (°F)	T _{m-out} (°F)			
	0.0			239.315						
1-01	5.0	0.45	1.00	242.260	300	70	68	0.67	2.94	100.5
1-02	10.0	0.54	1.20	245.420	301	71	68	0.73	3.16	98.4
1-03	15.0	0.57	1.30	248.750	302	73	68	0.75	3.33	100.9
1-04	20.0	0.63	1.50	252.340	302	75	69	0.79	3.59	103.2
1-05	25.0	0.60	1.40	255.770	301	77	69	0.77	3.43	100.7
LEAK CHECK	25.0			255.810						
2-01	30.0	0.54	1.20	258.980	299	76	69	0.73	3.17	98.1
2-02	35.0	0.47	1.10	261.950	301	77	70	0.69	2.97	98.4
2-03	40.0	0.60	1.40	265.370	302	78	70	0.77	3.42	100.3
2-04	45.0	0.80	1.80	269.230	303	79	71	0.89	3.86	98.0
2-05	50.0	0.65	1.50	272.785	302	80	71	0.81	3.56	99.9
LEAK CHECK	50.0			272.825						
3-01	55.0	0.66	1.50	276.370	299	78	71	0.81	3.55	98.9
3-02	60.0	0.56	1.30	279.670	301	79	71	0.75	3.30	99.9
3-03	65.0	0.68	1.60	283.290	302	79	71	0.82	3.62	99.6
3-04	70.0	0.66	1.50	286.800	303	80	72	0.81	3.51	97.9
3-05	75.0	0.70	1.60	290.430	302	80	72	0.84	3.63	98.3
LEAK CHECK	75.0			290.475						
4-01	80.0	0.60	1.40	293.850	300	80	73	0.77	3.38	98.4
4-02	85.0	0.47	1.10	296.820	300	81	73	0.69	2.97	97.7
4-03	90.0	0.50	1.20	300.040	302	81	73	0.71	3.22	102.8
4-04	95.0	0.67	1.50	303.580	302	82	73	0.82	3.54	97.7
4-05	100.0	0.69	1.60	307.280	301	83	74	0.83	3.70	100.4
LEAK CHECK	100.0			307.320						
5-01	105.0	0.45	1.00	310.260	301	82	74	0.67	2.94	98.7
5-02	110.0	0.42	0.97	313.090	299	82	75	0.65	2.83	98.1
5-03	115.0	0.35	0.81	315.690	297	82	75	0.59	2.60	98.6
5-04	120.0	0.43	0.99	318.580	299	82	75	0.66	2.89	99.0
5-05	125.0	0.75	1.70	322.380	299	82	75	0.87	3.80	98.7
Final	125.0		1.32680	82.90000	300.80000	75.18000		0.75631	82.90000	

25 points sampled
 QC-Check: Field Averages

Sq.RtΔP	0.7563	1.3268	82.9000	300.8000	75.1800
	<input checked="" type="checkbox"/> Avg. OK				

2RSD = 15.3%

041310 100208
 0

USEPA Method 3 Laboratory Data

Location: Unit 1 FF Outlet
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Method: EPA Method 3
 Fuel Type: Municipal Waste
 F_o for Fuel: 1.03 to 1.3

Test Method: USEPA Method 5/29
Analyte: Particulate/Metals

Analyst: S. Brown
 Analyst Emp No: 433

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
1	1							
	2							
	3							
Avg.								
CEM or Other Avg:		9.88000		9.53000	80.59000	29.96200	1.15081	<input checked="" type="checkbox"/> F _o value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
2	1							
	2							
	3							
Avg.								
CEM or Other Avg:		9.93000		9.46000	80.61000	29.96720	1.15206	<input checked="" type="checkbox"/> F _o value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
3	1							
	2							
	3							
Avg.								
CEM or Other Avg:		9.83000		9.74000	80.43000	29.96240	1.13530	<input checked="" type="checkbox"/> F _o value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis:
	1							
	2							
	3							
Avg.								
CEM or Other Avg:								<input type="checkbox"/> F _o value within expected range.

041310 100208
 JMO@

USEPA Method 4 Laboratory Data

Location: Unit 1 FF Outlet
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955

Test Method: USEPA Method 5/29
Analyte: Particulate/Metals
 Analyst: B. Wittse
 Analyst Emp No: 561

Test Run: 1

	Contents	Gross (gm)	Tare (gm)	Net (gm)		
Impinger 1	Empty	734.9	459.3	275.6		
Impinger 2	5%HNO3/10%H2O2	655.2	544.3	110.9		
Impinger 3	5%HNO3/10%H2O2	569.3	547.7	21.6		
Impinger 4	Empty	442.7	437.8	4.9		
Impinger 5	4%KMnO4/10%H2SO4	543.8	542.6	1.2		
Impinger 6	4%KMnO4/10%H2SO4	559.3	560.2	-0.9	413.3 Liquid (gm)	<i>Field Data Check</i>
Impinger 7	Silica Gel	725.3	707.1	18.2	0.0 less rinse (gm)	
Impinger 8					413.3 Net Liquid (gm)	<input checked="" type="checkbox"/> QA/QC OK
					+ 18.2 Silica Gel (gm)	<input checked="" type="checkbox"/> QA/QC OK
					431.5 Total Vlc (gm)	<input checked="" type="checkbox"/> QA/QC OK
	Rinse:		(ml or gm)			

Test Run: 2

	Contents	Gross (gm)	Tare (gm)	Net (gm)		
Impinger 1	Empty	687.1	437.6	249.5		
Impinger 2	5%HNO3/10%H2O2	673.8	555.1	118.7		
Impinger 3	5%HNO3/10%H2O2	571.0	534.3	36.7		
Impinger 4	Empty	451.7	445.5	6.2		
Impinger 5	4%KMnO4/10%H2SO4	545.3	543.2	2.1		
Impinger 6	4%KMnO4/10%H2SO4	538.7	538.6	0.1	413.3 Liquid (gm)	<i>Field Data Check</i>
Impinger 7	Silica Gel	739.3	720.4	18.9	0.0 less rinse (gm)	
Impinger 8					413.3 Net Liquid (gm)	<input checked="" type="checkbox"/> QA/QC OK
					+ 18.9 Silica Gel (gm)	<input checked="" type="checkbox"/> QA/QC OK
					432.2 Total Vlc (gm)	<input checked="" type="checkbox"/> QA/QC OK
	Rinse:		(ml or gm)			

Test Run: 3

	Contents	Gross (gm)	Tare (gm)	Net (gm)		
Impinger 1	Empty	746.2	461.6	284.6		
Impinger 2	5%HNO3/10%H2O2	645.1	541.8	103.3		
Impinger 3	5%HNO3/10%H2O2	569.4	550.8	18.6		
Impinger 4	Empty	442.4	439.5	2.9		
Impinger 5	4%KMnO4/10%H2SO4	542.9	541.5	1.4		
Impinger 6	4%KMnO4/10%H2SO4	559.9	559.9	0.0	410.8 Liquid (gm)	<i>Field Data Check</i>
Impinger 7	Silica Gel	735.7	721.5	14.2	0.0 less rinse (gm)	
Impinger 8					410.8 Net Liquid (gm)	<input checked="" type="checkbox"/> QA/QC OK
					+ 14.2 Silica Gel (gm)	<input checked="" type="checkbox"/> QA/QC OK
					425.0 Total Vlc (gm)	<input checked="" type="checkbox"/> QA/QC OK
	Rinse:		(ml or gm)			

Test Run:

	Contents	Gross (gm)	Tare (gm)	Net (gm)		
Impinger 1	Empty					
Impinger 2	5%HNO3/10%H2O2					
Impinger 3	5%HNO3/10%H2O2					
Impinger 4	Empty					
Impinger 5	4%KMnO4/10%H2SO4					
Impinger 6	4%KMnO4/10%H2SO4				Liquid (gm)	<i>Field Data Check</i>
Impinger 7	Silica Gel				less rinse (gm)	
Impinger 8					Net Liquid (gm)	<input type="checkbox"/> QA/QC OK
					Silica Gel (gm)	<input type="checkbox"/> QA/QC OK
					Total Vlc (gm)	<input type="checkbox"/> QA/QC OK
	Rinse:		(ml or gm)			

041310 100206
 JMO

Field Data Printout

Test Method: USEPA Method 13B
Analyte: Total Fluorides

Location: Unit 1 FF Outlet
 Test Run: 1
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Source Area (ft²): 64.00000
 Meter Operator: A. Obuchowski 567
 Probe Operator: B. Arnold 770
 Test Date: 3/17/10
 Start Time: 11:46
 Stop Time: 12:56
 Leak Rate Before: 0.002 cfm @ 15 "Hg
 Leak Rate After: 0.001 cfm @ 22 "Hg

Bar. Press. (in. Hg): 30.00
 Static P.: -10.3
 O₂ (dry volume %): 10.55
 CO₂ (dry volume %): 9.11
 N₂+CO (dry volume %): 80.34

Nozzle ID No: 268-1
 Nozzle Diameter (D_n): 0.268
 Probe ID No: 67-8-14
 Pitot C_p: 0.8120
 Pitot Leak Check: Pass Fail

H₂O (condensate, ml or gm): 208.5
 H₂O (silica, g): 17.0
 Actual Moisture (%): 19.89

Meter Box ID. No: 61-6
 Meter ΔH@: 1.68200
 Meter Y_d: 0.99000

Traverse Point	Run Time 2.5 min/read	Pitot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dcf)	Stack T _s (°F)	Dry Gas Meter		√ΔP _s (calculated) (√in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)
						T _{m-in} (°F)	T _{m-out} (°F)			
	0.0			323.725						
5-01	2.5	0.54	1.20	325.330	304	62	61	0.73	1.60	102.4
5-02	5.0	0.56	1.30	326.990	301	63	61	0.75	1.66	103.7
5-03	7.5	0.63	1.40	328.640	302	65	62	0.79	1.65	97.0
5-04	10.0	0.75	1.70	330.510	304	66	61	0.87	1.87	101.0
5-05	12.5	0.79	1.80	332.410	304	68	62	0.89	1.90	99.7
LEAK CHECK	12.5			332.480						
4-01	15.0	0.69	1.60	334.280	301	68	62	0.83	1.80	100.8
4-02	17.5	0.56	1.30	335.960	304	70	63	0.75	1.68	104.3
4-03	20.0	0.66	1.50	337.640	303	71	63	0.81	1.68	95.9
4-04	22.5	0.78	1.80	339.550	303	73	64	0.88	1.91	100.1
4-05	25.0	0.76	1.70	341.450	304	74	64	0.87	1.90	100.8
LEAK CHECK	25.0			341.500						
3-01	27.5	0.59	1.40	343.180	300	74	64	0.77	1.68	100.9
3-02	30.0	0.57	1.30	344.820	304	76	65	0.75	1.64	100.1
3-03	32.5	0.65	1.50	346.450	304	76	65	0.81	1.63	93.2
3-04	35.0	0.72	1.70	348.310	303	78	65	0.85	1.86	101.1
3-05	37.5	0.69	1.60	350.150	303	76	66	0.83	1.84	102.0
LEAK CHECK	37.5			350.260						
2-01	40.0	0.64	1.50	351.990	303	73	66	0.80	1.73	99.8
2-02	42.5	0.50	1.20	353.570	302	74	66	0.71	1.58	102.9
2-03	45.0	0.46	1.10	355.070	301	74	66	0.68	1.50	101.8
2-04	47.5	0.60	1.40	356.800	302	74	66	0.77	1.73	102.9
2-05	50.0	0.70	1.60	358.550	303	75	66	0.84	1.75	96.4
LEAK CHECK	50.0			358.630						
1-01	52.5	0.51	1.20	360.190	300	73	67	0.71	1.56	100.5
1-02	55.0	0.54	1.20	361.770	303	74	67	0.73	1.58	99.0
1-03	57.5	0.54	1.20	363.320	302	75	67	0.73	1.55	97.0
1-04	60.0	0.63	1.40	365.040	302	75	67	0.79	1.72	99.7
1-05	62.5	0.77	1.80	366.970	303	76	67	0.88	1.93	101.2
Final	62.5		1.45600	42.93500	302.60000	68.28000		0.79353	42.93500	

25 points sampled
 QC-Check: Field Averages Sq.Rt.ΔP 0.7935 1.4560 42.9350 302.6000 68.2800 2RSR = 12.1%

Avg. OK
 Avg. OK
 Avg. OK
 Avg. OK
 Avg. OK

041310 100232
P

Field Data Printout

Test Method: USEPA Method 13B
 Analyte: Total Fluorides

Location: Unit 1 FF Outlet
 Test Run: 2
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Source Area (ff): 64.00000
 Meter Operator: A. Obuchowski 567
 Probe Operator: B. Arnold 770
 Test Date: 3/17/10
 Start Time: 13:15
 Stop Time: 14:27
 Leak Rate Before: 0.002 cfm @ 15 "Hg
 Leak Rate After: 0.002 cfm @ 15 "Hg

Bar. Press. (in. Hg): 30.00
 Static P: -10.4
 O₂ (dry volume %): 10.13
 CO₂ (dry volume %): 9.62
 N₂+CO (dry volume %): 80.25

Nozzle ID No: 268-1
 Nozzle Diameter (D): 0.268
 Probe ID No: 67-8-14
 Pitot C_p: 0.8120
 Pitot Leak Check: Pass Fail

H₂O (condensate, ml or gm): 213.5
 H₂O (silica, g): 18.8
 Actual Moisture (%): 20.48

Meter Box ID. No: 61-6
 Meter ΔH@: 1.68200
 Meter Y_g: 0.99000

Traverse Point	Run Time 2.5 min/read	Pitot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dcf)	Stack T _s (°F)	Dry Gas Meter T _{m-in} T _{m-out} (°F) (°F)		√ΔP _s (calculated) (√in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)
	0.0			367.345						
1-01	2.5	0.54	1.24	368.900	299	68	66	0.73	1.55	98.5
1-02	5.0	0.53	1.20	370.490	300	70	66	0.73	1.59	101.6
1-03	7.5	0.51	1.20	372.040	300	71	66	0.71	1.55	100.9
1-04	10.0	0.58	1.30	373.360	301	73	66	0.76	1.32	80.5*
1-05	12.5	0.76	1.70	375.530	301	74	66	0.87	2.17	115.5*
LEAK CHECK	12.5			375.770						
2-01	15.0	0.67	1.50	377.410	302	74	67	0.82	1.64	92.9
2-02	17.5	0.58	1.30	379.050	304	74	67	0.76	1.64	100.0
2-03	20.0	0.65	1.50	380.770	301	76	67	0.81	1.72	98.7
2-04	22.5	0.74	1.70	382.610	303	77	68	0.86	1.84	99.0
2-05	25.0	0.74	1.70	384.470	302	78	68	0.86	1.86	99.9
LEAK CHECK	25.0			384.560						
3-01	27.5	0.65	1.50	386.320	301	76	68	0.81	1.76	100.9
3-02	30.0	0.53	1.20	387.920	303	77	68	0.73	1.60	101.6
3-03	32.5	0.57	1.30	389.550	302	78	68	0.75	1.63	99.6
3-04	35.0	0.79	1.80	391.420	303	78	68	0.89	1.87	97.3
3-05	37.5	0.81	1.90	393.390	304	78	68	0.90	1.97	101.3
LEAK CHECK	37.5			393.530						
4-01	40.0	0.60	1.40	395.240	301	76	69	0.77	1.71	101.9
4-02	42.5	0.53	1.20	396.810	302	77	68	0.73	1.57	99.6
4-03	45.0	0.62	1.40	398.490	303	77	69	0.79	1.68	98.5
4-04	47.5	0.74	1.70	400.330	302	77	69	0.86	1.84	98.8
4-05	50.0	0.74	1.70	402.200	303	78	69	0.86	1.87	100.4
LEAK CHECK	50.0			402.310						
5-01	52.5	0.53	1.20	403.880	300	75	69	0.73	1.57	99.5
5-02	55.0	0.50	1.20	405.420	303	75	68	0.71	1.54	100.8
5-03	57.5	0.61	1.40	407.100	303	76	69	0.78	1.68	99.4
5-04	60.0	0.73	1.70	408.920	303	76	68	0.85	1.82	98.6
5-05	62.5	0.82	1.90	410.845	305	77	69	0.91	1.93	98.4
Final	62.5		1.47360	42.92000	302.04000	71.60000		0.79927	42.92000	

25 points sampled. Sq.Rt.ΔP
 QC-Check: Field Averages **0.7993** **1.4736** **42.9200** **302.0400** **71.6000** 2RSR = 12.9%
 Avg. OK Avg. OK Avg. OK Avg. OK Avg. OK
 Bold number is estimated. Reading was missed

Field Data Printout

Test Method: USEPA Method 13B
Analyte: Total Fluorides

Location: Unit 1 FF Outlet
 Test Run: 3

Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Source Area (ff): 64.00000
 Meter Operator: A. Obuchowski 567
 Probe Operator: B. Arnold 770

Bar. Press. (in. Hg): 30.00
 Static P: -10.4
 O₂ (dry volume %): 9.96
 CO₂ (dry volume %): 9.80
 N₂+CO (dry volume %): 80.24

Nozzle ID No: 268-1
 Nozzle Diameter (D_n): 0.268
 Probe ID No: 67-8-14
 Pitot C_p: 0.8120
 Pitot Leak Check: Pass Fail

Test Date: 3/17/10
 Start Time: 14:45
 Stop Time: 15:53
 Leak Rate Before: 0.002 cfm @ 15 "Hg
 Leak Rate After: 0.002 cfm @ 15 "Hg

H₂O (condensate, ml or gm): 208.4
 H₂O (silica, g): 23.9
 Actual Moisture (%): 20.99

Meter Box ID. No: 61-6
 Meter ΔH@: 1.68200
 Meter Y_d: 0.99000

Traverse Point	Run Time 2.5 min/read	Pitot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dcf)	Stack T _s (°F)	Dry Gas Meter		√ΔP _s (calculated) (√in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)
						T _{m-in} (°F)	T _{m-out} (°F)			
	0.0			411.340						
5-01	2.5	0.51	1.20	412.950	302	68	66	0.71	1.61	105.8
5-02	5.0	0.52	1.20	414.540	301	69	66	0.72	1.59	103.3
5-03	7.5	0.55	1.30	416.140	303	70	66	0.74	1.60	101.1
5-04	10.0	0.63	1.40	417.820	302	71	66	0.79	1.68	99.1
5-05	12.5	0.58	1.30	419.460	302	72	66	0.76	1.64	100.7
LEAK CHECK	12.5			419.540						
4-01	15.0	0.58	1.30	421.150	302	71	66	0.76	1.61	98.9
4-02	17.5	0.54	1.20	422.700	303	72	66	0.73	1.55	98.7
4-03	20.0	0.65	1.50	424.390	303	72	66	0.81	1.69	98.1
4-04	22.5	0.69	1.60	426.060	304	73	66	0.83	1.67	94.1
4-05	25.0	0.73	1.70	427.950	302	74	66	0.85	1.89	103.3
LEAK CHECK	25.0			428.030						
3-01	27.5	0.71	1.60	429.810	302	73	66	0.84	1.78	98.8
3-02	30.0	0.54	1.20	431.400	304	73	66	0.73	1.59	101.2
3-03	32.5	0.64	1.50	433.180	303	73	66	0.80	1.78	104.1
3-04	35.0	0.65	1.50	434.950	304	74	67	0.81	1.77	102.5
3-05	37.5	0.66	1.50	436.740	303	75	67	0.81	1.79	102.8
LEAK CHECK	37.5			436.790						
2-01	40.0	0.66	1.50	438.550	302	73	67	0.81	1.76	101.2
2-02	42.5	0.53	1.20	440.140	304	74	67	0.73	1.59	101.9
2-03	45.0	0.53	1.20	441.690	304	74	67	0.73	1.55	99.4
2-04	47.5	0.60	1.40	443.410	305	75	67	0.77	1.72	103.7
2-05	50.0	0.69	1.60	445.210	303	75	67	0.83	1.80	101.1
LEAK CHECK	50.0			445.300						
1-01	52.5	0.49	1.10	446.790	302	75	67	0.70	1.49	99.1
1-02	55.0	0.50	1.20	448.350	302	74	68	0.71	1.56	102.7
1-03	57.5	0.40	0.92	449.770	301	74	67	0.63	1.42	104.5
1-04	60.0	0.50	1.20	451.330	300	74	67	0.71	1.56	102.7
1-05	62.5	0.65	1.50	453.110	302	74	67	0.81	1.78	103.0
Final	62.5		1.35280	41.47000	302.60000	69.70000		0.76570	41.47000	

25 points sampled
 QC-Check: Field Averages

Sq.Rt.ΔP	0.7657	1.3528	41.4700	302.6000	69.7000
<input checked="" type="checkbox"/> Avg. OK					

2RSD = 11.0%

041310 100232

USEPA Method 3 Laboratory Data

Location: Unit 1 FF Outlet
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Method: EPA Method 3
 Fuel Type: Municipal Waste
 F_o for Fuel: 1.03 to 1.3

Test Method: USEPA Method 13B
Analyte: Total Fluorides

Analyst: _____
 Analyst Emp No: _____

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
1	1							
	2							
	3							
	Avg.							
CEM or Other Avg:		9.11000		10.55000	80.34000	29.87960	1.13611	<input checked="" type="checkbox"/> F _o value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
2	1							
	2							
	3							
	Avg.							
CEM or Other Avg:		9.62000		10.13000	80.25000	29.94440	1.11954	<input checked="" type="checkbox"/> F _o value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
3	1							
	2							
	3							
	Avg.							
CEM or Other Avg:		9.80000		9.96000	80.24000	29.96640	1.11633	<input checked="" type="checkbox"/> F _o value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis:
	1							
	2							
	3							
	Avg.							
CEM or Other Avg:								<input type="checkbox"/> F _o value within expected range.

041310 100232
 PNL@

USEPA Method 4 Laboratory Data

Location: Unit 1 FF Outlet
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955

Test Method: USEPA Method 13B
Analyte: Total Fluorides
 Analyst: B. Wiltse
 Analyst Emp No: 561

Test Run: 1

	Contents	Gross (gm)	Tare (gm)	Net (gm)
Impinger 1	DI Water	665.4	546.3	119.1
Impinger 2	DI Water	630.2	562.5	67.7
Impinger 3	Empty	480.7	459.0	21.7
Impinger 4	Silica Gel	826.4	809.4	17.0
Impinger 5				
Impinger 6				
Impinger 7				
Impinger 8				

208.5 Liquid (gm) *Field Data Check*

0.0 less rinse (gm)

208.5 Net Liquid (gm)

+ 17.0 Silica Gel (gm)

225.5 Total Vlc (gm)

208.5

17.0

225.5

QA/QC OK

QA/QC OK

QA/QC OK

Rinse: _____ (ml or gm)

Test Run: 2

	Contents	Gross (gm)	Tare (gm)	Net (gm)
Impinger 1	DI Water	658.1	542.1	116.0
Impinger 2	DI Water	621.1	544.3	76.8
Impinger 3	Empty	458.4	437.7	20.7
Impinger 4	Silica Gel	799.4	780.6	18.8
Impinger 5				
Impinger 6				
Impinger 7				
Impinger 8				

213.5 Liquid (gm) *Field Data Check*

0.0 less rinse (gm)

213.5 Net Liquid (gm)

+ 18.8 Silica Gel (gm)

232.3 Total Vlc (gm)

213.5

18.8

232.3

QA/QC OK

QA/QC OK

QA/QC OK

Rinse: _____ (ml or gm)

Test Run: 3

	Contents	Gross (gm)	Tare (gm)	Net (gm)
Impinger 1	DI Water	661.5	540.4	121.1
Impinger 2	DI Water	619.3	550.6	68.7
Impinger 3	Empty	469.1	450.5	18.6
Impinger 4	Silica Gel	765.0	741.1	23.9
Impinger 5				
Impinger 6				
Impinger 7				
Impinger 8				

208.4 Liquid (gm) *Field Data Check*

0.0 less rinse (gm)

208.4 Net Liquid (gm)

+ 23.9 Silica Gel (gm)

232.3 Total Vlc (gm)

208.4

23.9

232.3

QA/QC OK

QA/QC OK

QA/QC OK

Rinse: _____ (ml or gm)

Test Run: _____

	Contents	Gross (gm)	Tare (gm)	Net (gm)
Impinger 1	DI Water			
Impinger 2	DI Water			
Impinger 3	Empty			
Impinger 4	Silica Gel			
Impinger 5				
Impinger 6				
Impinger 7				
Impinger 8				

Liquid (gm) *Field Data Check*

less rinse (gm)

Net Liquid (gm)

Silica Gel (gm)

Total Vlc (gm)

QA/QC OK

QA/QC OK

QA/QC OK

Rinse: _____ (ml or gm)

041310 100232

PNL @

Field Data Printout

Test Method: USEPA Method 26A
Analyte: HCl

Location: Unit 1 SDA Inlet
 Test Run: 1

Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Source Area (ff): 60.13205
 Meter Operator: B. Arnold 770
 Probe Operator: B. Arnold 770

Bar. Press. (in. Hg): 30.05
 Static P: -1.9
 O₂ (dry volume %): 9.11
 CO₂ (dry volume %): 10.23
 N₂+CO (dry volume %): 80.66

Nozzle ID No: NA
 Nozzle Diameter (D_n): NA
 Probe ID No: 67-4-4
 Pitot C_p: 0.8400
 Pitot Leak Check: Pass Fail

Test Date: 3/18/10
 Start Time: 07:02
 Stop Time: 08:02
 Leak Rate Before: 0.002 cfm @ 15 "Hg
 Leak Rate After: 0.003 cfm @ 22 "Hg

H₂O (condensate, ml or gm): 150.6
 H₂O (silica, g): 21.7
 Actual Moisture (%): 17.51

Meter Box ID. No: 85-4
 Meter ΔH@: 1.77230
 Meter Y_d: 1.00850

Traverse Point	Run Time 5.0 min/read	Pitot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dcf)	Stack T _s (°F)	Dry Gas Meter		√ΔP _s (calculated) (√in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)
						T _{m-in} (°F)	T _{m-out} (°F)			
	0.0			614.080						
1-01	5.0		1.20	617.190	486	58	56		3.11	
1-01	10.0		1.20	620.240	487	59	56		3.05	
1-01	15.0		1.20	623.310	493	64	57		3.07	
1-01	20.0		1.20	626.400	493	63	58		3.09	
1-01	25.0		1.20	629.490	488	63	58		3.09	
1-01	30.0		1.20	632.570	488	63	58		3.08	
1-01	35.0		1.20	635.640	492	63	58		3.07	
1-01	40.0		1.20	638.740	490	63	58		3.10	
1-01	45.0		1.20	641.870	489	63	58		3.13	
1-01	50.0		1.20	644.980	486	63	60		3.11	
1-01	55.0		1.20	648.090	486	63	59		3.11	
1-01	60.0		1.10	651.130	488	63	59		3.04	
Final	60.0									

1 points sampled

Sq.Rt.ΔP	1.1917	37.0500	488.8333	60.1250
----------	--------	---------	----------	---------

QC-Check: Field Averages

Avg. OK Avg. OK Avg. OK Avg. OK Avg. OK

041310 100253

Field Data Printout

Test Method: USEPA Method 26A
Analyte: HCl

Location: Unit 1 SDA Inlet
 Test Run: 2
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Source Area (ff): 60.13205
 Meter Operator: B. Arnold 770
 Probe Operator: B. Arnold 770
 Test Date: 3/18/10
 Start Time: 09:26
 Stop Time: 10:37
 Leak Rate Before: 0.004 cfm @ 15 "Hg
 Leak Rate After: 0.003 cfm @ 22 "Hg

Bar. Press. (in. Hg): 30.05
 Static P: -1.7
 O₂ (dry volume %): 9.01
 CO₂ (dry volume %): 10.35
 N₂+CO (dry volume %): 80.64

Nozzle ID No: NA
 Nozzle Diameter (D_n): NA
 Probe ID No: 67-4-4
 Pitot C_p: 0.8400
 Pitot Leak Check: Pass Fail

H₂O (condensate, ml or gm): 145.8
 H₂O (silica, g): 11.3
 Actual Moisture (%): 16.87

Meter Box ID. No: 85-4
 Meter ΔH@: 1.77230
 Meter Y_d: 1.00850

Traverse Point	Run Time 5.0 min/read	Pitot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dcf)	Stack T _s (°F)	Dry Gas Meter		√ΔP _s (calculated) (√in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)
						T _{m-in} (°F)	T _{m-out} (°F)			
	0.0			655.840						
1-01	5.0		1.20	658.810	485	62	61		2.97	
1-01	10.0		1.20	661.920	485	66	63		3.11	
1-01	15.0		1.20	664.820	489	68	63		2.90	
1-01	20.0		1.20	667.790	489	69	63		2.97	
1-01	25.0		1.20	670.710	494	70	64		2.92	
LEAK CHECK	25.0			670.820						
1-01	30.0		1.20	673.910	489	65	64		3.09	
1-01	35.0		1.20	676.820	485	67	65		2.91	
1-01	40.0		1.20	679.750	487	67	65		2.93	
1-01	45.0		1.20	682.690	491	71	65		2.94	
1-01	50.0		1.20	685.780	494	72	66		3.09	
1-01	55.0		1.20	688.680	490	69	66		2.90	
1-01	60.0		1.20	691.690	491	69	66		3.01	
Final	60.0		1.20000	35.74000	489.08333	66.08333		0.00000	35.74000	

1 points sampled
 QC-Check: Field Averages

Sq.Rt.ΔP	1.2000	35.7400	489.0833	66.0833
----------	--------	---------	----------	---------

Avg. OK Avg. OK Avg. OK Avg. OK Avg. OK

041410 153810
 N

Field Data Printout

Test Method: USEPA Method 26A
Analyte: HCl

Location: Unit 1 SDA Inlet
 Test Run: 3
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Source Area (ff): 60.13205
 Meter Operator: B. Arnold 770
 Probe Operator: B. Arnold 770
 Test Date: 3/18/10
 Start Time: 11:49
 Stop Time: 12:49
 Leak Rate Before: 0.003 cfm @ 15 "Hg
 Leak Rate After: 0.003 cfm @ 18 "Hg

Bar. Press. (in. Hg): 30.05
 Static P: -1.7
 O₂ (dry volume %): 9.70
 CO₂ (dry volume %): 9.82
 N₂+CO (dry volume %): 80.48

Nozzle ID No: NA
 Nozzle Diameter (D_n): NA
 Probe ID No: 67-4-4
 Pitot C_p: 0.8400
 Pitot Leak Check: Pass Fail

H₂O (condensate, ml or gm): 138.9
 H₂O (silica, g): 11.4
 Actual Moisture (%): 16.55

Meter Box ID. No: 85-4
 Meter ΔH@: 1.77230
 Meter Y_d: 1.00850

Traverse Point	Run Time 5.0 min/read	Pitot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dcf)	Stack T _s (°F)	Dry Gas Meter		√ΔP _s (calculated) (in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)
						T _{m-in} (°F)	T _{m-out} (°F)			
	0.0			691.850						
1-01	5.0		1.20	694.830	494	72	72		2.98	
1-01	10.0		1.20	697.730	496	74	72		2.90	
1-01	15.0		1.20	700.680	491	78	73		2.95	
1-01	20.0		1.20	703.650	494	78	74		2.97	
1-01	25.0		1.20	706.630	501	78	74		2.98	
1-01	30.0		1.20	709.630	500	78	75		3.00	
1-01	35.0		1.20	712.610	502	77	75		2.98	
1-01	40.0		1.20	715.600	501	78	75		2.99	
1-01	45.0		1.20	718.580	497	79	76		2.98	
1-01	50.0		1.20	721.530	497	76	75		2.95	
1-01	55.0		1.20	724.500	494	75	75		2.97	
1-01	60.0		1.20	727.450	496	76	74		2.95	
Final	60.0		1.20000	35.60000	496.91667	75.37500		0.00000	35.60000	

1 points sampled
 QC-Check: Field Averages
 Sq.Rt ΔP: 1.2000 35.6000 496.9167 75.3750
 Avg. OK Avg. OK Avg. OK Avg. OK Avg. OK

041310 100253
 K

USEPA Method 3 Laboratory Data

Location: Unit 1 SDA Inlet
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Method: EPA Method 3
 Fuel Type: Municipal Waste
 F_o for Fuel: 1.03 to 1.3

Test Method: USEPA Method 26A
Analyte: HCl

Analyst: S. Brown
 Analyst Emp No: 433

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
1	1							
	2							
	3							
Avg.								
CEM or Other Avg:		10.23000		9.11000	80.66000	30.00120	1.15249	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
2	1							
	2							
	3							
Avg.								
CEM or Other Avg:		10.35000		9.01000	80.64000	30.01640	1.14879	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
3	1							
	2							
	3							
Avg.								
CEM or Other Avg:		9.82000		9.70000	80.48000	29.95920	1.14053	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis:
	1							
	2							
	3							
Avg.								
CEM or Other Avg:								<input type="checkbox"/> Fo value within expected range.

041310 100253
 INK @

USEPA Method 4 Laboratory Data

Location: Unit 1 SDA Inlet
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955

Test Method: USEPA Method 26A
Analyte: HCl
 Analyst: B. Wiltse
 Analyst Emp No: 561

Test Run: 1

Contents	Gross (gm)	Tare (gm)	Net (gm)
Impinger 1 50 ml 0.1N H2SO4	504.6	479.6	25.0
Impinger 2 100 ml 0.1N H2SO4	629.1	537.6	91.5
Impinger 3 100 ml 0.1N H2SO4	582.0	557.1	24.9
Impinger 4 Empty	439.9	430.7	9.2
Impinger 5 Silica Gel	775.4	753.7	21.7
Impinger 6			
Impinger 7			
Impinger 8			

Rinse: _____ (ml or gm)

150.6 Liquid (gm)	<i>Field Data Check</i>
0.0 less rinse (gm)	
150.6 Net Liquid (gm)	<u>150.6</u> <input type="checkbox"/> QA/QC OK
+ 21.7 Silica Gel (gm)	<u>21.7</u> <input type="checkbox"/> QA/QC OK
172.3 Total Vlc (gm)	<u>172.3</u> <input type="checkbox"/> QA/QC OK

Test Run: 2

Contents	Gross (gm)	Tare (gm)	Net (gm)
Impinger 1 50 ml 0.1N H2SO4	523.3	454.7	68.6
Impinger 2 100 ml 0.1N H2SO4	606.5	542.4	64.1
Impinger 3 100 ml 0.1N H2SO4	550.5	540.8	9.7
Impinger 4 Empty	466.8	463.4	3.4
Impinger 5 Silica Gel	764.5	753.2	11.3
Impinger 6			
Impinger 7			
Impinger 8			

Rinse: _____ (ml or gm)

145.8 Liquid (gm)	<i>Field Data Check</i>
0.0 less rinse (gm)	
145.8 Net Liquid (gm)	<u>145.8</u> <input type="checkbox"/> QA/QC OK
+ 11.3 Silica Gel (gm)	<u>11.3</u> <input type="checkbox"/> QA/QC OK
157.1 Total Vlc (gm)	<u>157.1</u> <input type="checkbox"/> QA/QC OK

Test Run: 3

Contents	Gross (gm)	Tare (gm)	Net (gm)
Impinger 1 50 ml 0.1N H2SO4	538.6	469.9	68.7
Impinger 2 100 ml 0.1N H2SO4	597.4	537.1	60.3
Impinger 3 100 ml 0.1N H2SO4	561.1	553.2	7.9
Impinger 4 Empty	432.6	430.6	2.0
Impinger 5 Silica Gel	722.8	711.4	11.4
Impinger 6			
Impinger 7			
Impinger 8			

Rinse: _____ (ml or gm)

138.9 Liquid (gm)	<i>Field Data Check</i>
0.0 less rinse (gm)	
138.9 Net Liquid (gm)	<u>138.9</u> <input type="checkbox"/> QA/QC OK
+ 11.4 Silica Gel (gm)	<u>11.4</u> <input type="checkbox"/> QA/QC OK
150.3 Total Vlc (gm)	<u>150.3</u> <input type="checkbox"/> QA/QC OK

Test Run: _____

Contents	Gross (gm)	Tare (gm)	Net (gm)
Impinger 1			
Impinger 2			
Impinger 3			
Impinger 4			
Impinger 5			
Impinger 6			
Impinger 7			
Impinger 8			

Rinse: _____ (ml or gm)

Liquid (gm)	<i>Field Data Check</i>
less rinse (gm)	
Net Liquid (gm)	_____ <input type="checkbox"/> QA/QC OK
Silica Gel (gm)	_____ <input type="checkbox"/> QA/QC OK
Total Vlc (gm)	_____ <input type="checkbox"/> QA/QC OK

041310 100253
 I NK @

Field Data Printout

Test Method: USEPA Method 26A
Analyte: HCl

Location: Unit 1 FF Outlet
 Test Run: 1
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Source Area (ff): 64.00000
 Meter Operator: A. Obuchowski 567
 Probe Operator:
 Test Date: 3/18/10
 Start Time: 07:02
 Stop Time: 08:02
 Leak Rate Before: 0.003 cfm @ 15 "Hg
 Leak Rate After: 0.003 cfm @ 15 "Hg

Bar. Press. (in. Hg): 30.05
 Static P: -11.1
 O₂ (dry volume %): 9.88
 CO₂ (dry volume %): 9.50
 N₂+CO (dry volume %): 80.62

Nozzle ID No: NA
 Nozzle Diameter (D_n): NA
 Probe ID No: 67-4-3
 Pitot C_p: 0.8400
 Pitot Leak Check: Pass Fail

H₂O (condensate, ml or gm): 199.8
 H₂O (silica, g): 17.6
 Actual Moisture (%): 19.93

Meter Box ID. No: 85-2
 Meter ΔH@: 1.77590
 Meter Y_d: 1.00660

Traverse Point	Run Time 5.0 min/read	Pitot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dcf)	Stack T _s (°F)	Dry Gas Meter		√ΔP _s (calculated) (√in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)
						T _{m-in} (°F)	T _{m-out} (°F)			
	0.0			269.160						
3-01	5.0		1.50	272.580	308	59	57		3.42	
3-01	10.0		1.50	275.830	309	59	57		3.25	
3-01	15.0		1.50	279.190	310	63	57		3.36	
3-01	20.0		1.50	282.440	309	65	57		3.25	
3-01	25.0		1.50	285.830	307	68	58		3.39	
3-01	30.0		1.50	289.170	307	69	58		3.34	
3-01	35.0		1.50	292.530	307	70	58		3.36	
3-01	40.0		1.50	295.890	307	70	59		3.36	
3-01	45.0		1.50	299.180	307	70	59		3.29	
3-01	50.0		1.50	302.640	307	70	60		3.46	
3-01	55.0		1.50	305.920	307	70	60		3.28	
3-01	60.0		1.50	309.265	307	70	60		3.34	
Final	60.0		1.50000	40.10500	307.66667	62.62500		0.00000	40.10500	

3 points sampled
 QC-Check: Field Averages

Sq. Rt. ΔP	1.5000	40.1050	307.6667	62.6250
------------	--------	---------	----------	---------

Avg. OK Avg. OK Avg. OK Avg. OK Avg. OK

041310 100321
 N

Field Data Printout

Test Method: USEPA Method 26A
Analyte: HCl

Location: Unit 1 FF Outlet
 Test Run: 2
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Source Area (ff): 64.00000
 Meter Operator: A. Obuchowski 567
 Probe Operator:
 Test Date: 3/18/10
 Start Time: 09:26
 Stop Time: 10:37
 Leak Rate Before: 0.002 cfm @ 15 "Hg
 Leak Rate After: 0.001 cfm @ 15 "Hg

Bar. Press. (in. Hg): 30.05
 Static P: -10.9
 O₂ (dry volume %): 9.69
 CO₂ (dry volume %): 9.67
 N₂+CO (dry volume %): 80.64

Nozzle ID No: NA
 Nozzle Diameter (D_n): NA
 Probe ID No: 67-4-3
 Pitot C_p: 0.8400
 Pitot Leak Check: Pass Fail

H₂O (condensate, ml or gm): 225.2
 H₂O (silica, g): 11.0
 Actual Moisture (%): 21.41

Meter Box ID. No: 85-2
 Meter ΔH@: 1.77590
 Meter Y_d: 1.00660

Traverse Point	Run Time 5.0 min/read	Pitot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dcf)	Stack T _s (°F)	Dry Gas Meter		√ΔP _s (calculated) (√in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)
						T _{m-in} (°F)	T _{m-out} (°F)			
	0.0			309.830						
3-01	5.0		1.50	313.180	309	61	60		3.35	
3-01	10.0		1.50	316.510	310	61	60		3.33	
3-01	15.0		1.50	319.790	309	64	60		3.28	
3-01	20.0		1.50	323.050	309	65	61		3.26	
3-01	25.0		1.50	326.390	310	67	61		3.34	
3-01	30.0		1.50	329.720	308	66	62		3.33	
3-01	35.0		1.50	333.100	305	66	62		3.38	
3-01	40.0		1.50	336.410	310	68	63		3.31	
3-01	45.0		1.50	339.290	310	69	63		2.88	
3-01	50.0		1.50	343.370	310	68	63		4.08	
3-01	55.0		1.50	346.400	309	68	63		3.03	
3-01	60.0		1.50	349.730	310	67	63		3.33	
Final	60.0		1.50000	39.90000	309.08333	63.79167		0.00000	39.90000	
3 points sampled		Sq.Rt.ΔP								
QC-Check: Field Averages				1.5000	39.9000	309.0833	63.7917			

Avg. OK Avg. OK Avg. OK Avg. OK Avg. OK

041310 100321

Field Data Printout

Test Method: USEPA Method 26A
Analyte: HCl

Location: Unit 1 FF Outlet
 Test Run: 3
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Source Area (ff): 64.00000

Bar. Press. (in. Hg): 30.05
 Static P: -11.0
 O₂ (dry volume %): 10.05
 CO₂ (dry volume %): 9.42
 N₂+CO (dry volume %): 80.53

Nozzle ID No: NA
 Nozzle Diameter (D_n): NA
 Probe ID No: 67-4-3
 Pitot C_p: 0.8400
 Pitot Leak Check: Pass Fail

Meter Operator: A. Obuchowski 567
 Probe Operator:
 Test Date: 3/18/10
 Start Time: 11:49
 Stop Time: 12:49
 Leak Rate Before: 0.006 cfm @ 15 "Hg
 Leak Rate After: 0.002 cfm @ 15 "Hg

H₂O (condensate, ml or gm): 191.9
 H₂O (silica, g): 19.2
 Actual Moisture (%): 19.64

Meter Box ID. No: 85-2
 Meter ΔH@: 1.77590
 Meter Y_d: 1.00660

Traverse Point	Run Time 5.0 min/read	Pitot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dcf)	Stack T _s (°F)	Dry Gas Meter		√ΔP _s (calculated) (√in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)
						T _{m-in} (°F)	T _{m-out} (°F)			
	0.0			351.740						
3-01	5.0		1.50	355.110	310	67	65		3.37	
3-01	10.0		1.50	358.450	310	67	65		3.34	
3-01	15.0		1.50	361.790	308	69	65		3.34	
3-01	20.0		1.50	365.120	307	72	66		3.33	
3-01	25.0		1.50	368.450	309	71	66		3.33	
3-01	30.0		1.50	371.800	311	72	67		3.35	
3-01	35.0		1.50	375.170	311	72	67		3.37	
3-01	40.0		1.50	378.590	311	74	68		3.42	
3-01	45.0		1.50	381.870	312	74	68		3.28	
3-01	50.0		1.50	385.210	310	73	68		3.34	
3-01	55.0		1.50	388.550	310	72	68		3.34	
3-01	60.0		1.50	391.895	310	73	69		3.34	
Final	60.0		1.50000	40.15500	309.91667	69.08333		0.00000	40.15500	

3 points sampled Sq. Rt. ΔP

QC-Check: Field Averages:	1.5000	40.1550	309.9167	69.0833
---------------------------	--------	---------	----------	---------

Avg. OK Avg. OK Avg. OK Avg. OK Avg. OK

041310 100321
K

USEPA Method 3 Laboratory Data

Location: Unit 1 FF Outlet
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Method: EPA Method 3
 Fuel Type: Municipal Waste
 F_o for Fuel: 1.03 to 1.3

Test Method: USEPA Method 26A
Analyte: HCI

Analyst: S. Brown
 Analyst Emp No: 433

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
1	1							
	2							
	3							
Avg.								
CEM or Other Avg:		9.50000		9.88000	80.62000	29.91520	1.16000	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
2	1							
	2							
	3							
Avg.								
CEM or Other Avg:		9.67000		9.69000	80.64000	29.93480	1.15926	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
3	1							
	2							
	3							
Avg.								
CEM or Other Avg:		9.42000		10.05000	80.53000	29.90920	1.15180	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis:
	1							
	2							
	3							
Avg.								
CEM or Other Avg:								<input type="checkbox"/> Fo value within expected range.

041310 100321
 N L K ®

USEPA Method 4 Laboratory Data

Location: Unit 1 FF Outlet
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955

Test Method: USEPA Method 26A
Analyte: HCl
 Analyst: B. Wittse
 Analyst Emp No: 561

Test Run: 1

	Contents	Gross (gm)	Tare (gm)	Net (gm)	
Impinger 1	50 ml 0.1N H2SO4	501.4	472.8	28.6	
Impinger 2	100 ml 0.1N H2SO4	741.6	642.1	99.5	
Impinger 3	100 ml 0.1N H2SO4	582.6	535.0	47.6	
Impinger 4	Empty	472.6	448.5	24.1	
Impinger 5	Silica Gel	735.2	717.6	17.6	
Impinger 6					199.8 Liquid (gm)
Impinger 7					0.0 less rinse (gm)
Impinger 8					199.8 Net Liquid (gm)
					+ 17.6 Silica Gel (gm)
					217.4 Total Vlc (gm)

		Field Data Check	
		199.8	<input checked="" type="checkbox"/> QA/QC OK
		17.6	<input checked="" type="checkbox"/> QA/QC OK
		217.4	<input checked="" type="checkbox"/> QA/QC OK

Rinse: _____ (ml or gm)

Test Run: 2

	Contents	Gross (gm)	Tare (gm)	Net (gm)	
Impinger 1	50 ml 0.1N H2SO4	524.0	460.1	63.9	
Impinger 2	100 ml 0.1N H2SO4	680.6	561.4	119.2	
Impinger 3	100 ml 0.1N H2SO4	589.0	555.6	33.4	
Impinger 4	Empty	465.1	456.4	8.7	
Impinger 5	Silica Gel	791.5	780.5	11.0	
Impinger 6					225.2 Liquid (gm)
Impinger 7					0.0 less rinse (gm)
Impinger 8					225.2 Net Liquid (gm)
					+ 11.0 Silica Gel (gm)
					236.2 Total Vlc (gm)

		Field Data Check	
		225.2	<input checked="" type="checkbox"/> QA/QC OK
		11.0	<input checked="" type="checkbox"/> QA/QC OK
		236.2	<input checked="" type="checkbox"/> QA/QC OK

Rinse: _____ (ml or gm)

Test Run: 3

	Contents	Gross (gm)	Tare (gm)	Net (gm)	
Impinger 1	50 ml 0.1N H2SO4	503.1	472.6	30.5	
Impinger 2	100 ml 0.1N H2SO4	757.7	642.0	115.7	
Impinger 3	100 ml 0.1N H2SO4	571.2	535.8	35.4	
Impinger 4	Empty	458.9	448.6	10.3	
Impinger 5	Silica Gel	735.2	716.0	19.2	
Impinger 6					191.9 Liquid (gm)
Impinger 7					0.0 less rinse (gm)
Impinger 8					191.9 Net Liquid (gm)
					+ 19.2 Silica Gel (gm)
					211.1 Total Vlc (gm)

		Field Data Check	
		191.9	<input checked="" type="checkbox"/> QA/QC OK
		19.2	<input checked="" type="checkbox"/> QA/QC OK
		211.1	<input checked="" type="checkbox"/> QA/QC OK

Rinse: _____ (ml or gm)

Test Run: _____

	Contents	Gross (gm)	Tare (gm)	Net (gm)	
Impinger 1					
Impinger 2					
Impinger 3					
Impinger 4					
Impinger 5					
Impinger 6					
Impinger 7					
Impinger 8					

		Field Data Check	
			<input type="checkbox"/> QA/QC OK
			<input type="checkbox"/> QA/QC OK
			<input type="checkbox"/> QA/QC OK

Rinse: _____ (ml or gm)

041310 100321
 N.L.K.®

Field Data Printout

Test Method: USEPA Method 5/29
Analyte: Particulate/Metals

Location: Unit 2 FF Outlet

Test Run: 1

Client: Wheelabrator North Broward, Inc.

Project No: 10955

Source Area (ft²): 64.00000

Meter Operator: P. Bihun 505

Probe Operator: P. Bihun 505

Test Date: 3/18/10

Start Time: 07:09

Stop Time: 09:22

Leak Rate Before: 0.004 cfm @ 15 "Hg

Leak Rate After: 0.004 cfm @ 8 "Hg

Bar. Press. (in. Hg): 30.05
 Static P: -10.6

O₂ (dry volume %): 10.07
 CO₂ (dry volume %): 9.25
 N₂+CO (dry volume %): 80.68

Nozzle ID No: 270-1
 Nozzle Diameter (D_n): 0.270
 Probe ID No: 67-8-4
 Pitot C_p: 0.8050
 Pitot Leak Check: Pass Fail

H₂O (condensate, ml or gm): 445.2

H₂O (silica, g): 14.2

Actual Moisture (%): 20.43

Meter Box ID. No: 66-24
 Meter ΔH@: 1.75160
 Meter Y_d: 0.99040

Traverse Point	Run Time 5.0 min/read	Pitot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dcf)	Stack T _s (°F)	Dry Gas Meter		√ΔP _s (calculated) (√in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)
						T _{m-in} (°F)	T _{m-out} (°F)			
	0.0			446.115						
5-01	5.0	0.59	1.40	449.450	308	59	57	0.77	3.33	102.9
5-02	10.0	0.48	1.10	452.360	307	61	58	0.69	2.91	99.1
5-03	15.0	0.46	1.10	455.230	308	63	58	0.68	2.87	99.7
5-04	20.0	0.50	1.20	458.320	308	66	58	0.71	3.09	102.7
5-05	25.0	0.42	0.99	461.025	308	68	59	0.65	2.70	97.8
LEAK CHECK	25.0			461.080						
4-01	30.0	0.55	1.30	464.290	307	68	60	0.74	3.21	101.3
4-02	35.0	0.54	1.30	467.470	309	71	61	0.73	3.18	101.0
4-03	40.0	0.67	1.60	471.050	309	72	61	0.82	3.58	102.1
4-04	45.0	0.70	1.70	474.720	309	74	62	0.84	3.67	102.1
4-05	50.0	0.68	1.60	478.275	309	76	63	0.82	3.55	100.0
LEAK CHECK	50.0			478.310						
3-01	55.0	0.59	1.40	481.650	308	74	64	0.77	3.34	100.9
3-02	60.0	0.53	1.30	484.860	309	76	65	0.73	3.21	102.1
3-03	65.0	0.58	1.40	488.210	309	77	66	0.76	3.35	101.6
3-04	70.0	0.66	1.60	491.810	310	78	67	0.81	3.60	102.3
3-05	75.0	0.72	1.70	495.505	309	79	67	0.85	3.69	100.4
LEAK CHECK	75.0			495.585						
2-01	80.0	0.61	1.40	498.870	308	77	68	0.78	3.29	96.9
2-02	85.0	0.87	2.00	502.810	309	79	68	0.93	3.94	97.4
2-03	90.0	0.72	1.70	506.510	309	80	69	0.85	3.70	100.3
2-04	95.0	0.82	1.90	510.390	305	81	70	0.91	3.88	98.1
2-05	100.0	0.75	1.80	514.185	307	82	70	0.87	3.79	100.4
LEAK CHECK	100.0			514.258						
1-01	105.0	0.55	1.30	517.500	305	78	71	0.74	3.24	100.2
1-02	110.0	0.60	1.40	520.860	303	81	71	0.77	3.36	99.0
1-03	115.0	0.55	1.30	524.050	303	82	72	0.74	3.19	98.0
1-04	120.0	0.58	1.40	527.400	305	82	72	0.76	3.35	100.3
1-05	125.0	0.68	1.60	531.025	306	82	72	0.82	3.63	100.4
Final	125.0		1.45960	84.66700	307.48000	69.90000		0.78189	84.66700	

25 points sampled
 QC-Check: Field Averages

Sq.RI ΔP	0.7819	1.4596	84.6700	307.4800	69.9000
----------	--------	--------	---------	----------	---------

2RSD = 13.9%

Avg. OK Avg. OK Avg. OK Avg. OK Avg. OK

041310 101033
 K

Field Data Printout

Test Method: USEPA Method 5/29
Analyte: Particulate/Metals

Location: Unit 2 FF Outlet
 Test Run: 3
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Source Area (ff): 64.00000
 Meter Operator: P. Bihun 505
 Probe Operator: P. Bihun 505
 Test Date: 3/18/10
 Start Time: 12:27
 Stop Time: 14:39
 Leak Rate Before: 0.003 cfm @ 15 "Hg
 Leak Rate After: 0.003 cfm @ 9 "Hg

Bar. Press. (in. Hg): 30.05
 Static P: -10.7
 O₂ (dry volume %): 9.89
 CO₂ (dry volume %): 9.58
 N₂+CO (dry volume %): 80.53

Nozzle ID No: 270-1
 Nozzle Diameter (D_n): 0.270
 Probe ID No: 67-8-4
 Pitot C_p: 0.8050
 Pitot Leak Check: Pass Fail

H₂O (condensate, ml or gm): 444.4
 H₂O (silica, g): 19.2
 Actual Moisture (%): 20.99

Meter Box ID. No: 66-24
 Meter ΔH@: 1.75160
 Meter Y_d: 0.99040

Traverse Point	Run Time 5.0 min/read	Pitot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dcf)	Stack T _s (°F)	Dry Gas Meter		√ΔP _s (calculated) (√in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)
						T _{m-in} (°F)	T _{m-out} (°F)			
	0.0			613.455						
1-01	5.0	0.45	1.10	616.540	306	83	84	0.67	3.08	104.3
1-02	10.0	0.45	1.10	619.540	307	84	84	0.67	3.00	101.4
1-03	15.0	0.43	1.00	622.400	306	86	83	0.66	2.86	98.7
1-04	20.0	0.71	1.70	626.060	307	88	83	0.84	3.66	98.4
1-05	25.0	0.73	1.80	629.855	308	90	83	0.85	3.80	100.5
LEAK CHECK	25.0			629.920						
2-01	30.0	0.69	1.70	633.630	306	89	83	0.83	3.71	101.0
2-02	35.0	0.73	1.80	637.480	307	91	84	0.85	3.85	101.7
2-03	40.0	0.70	1.70	641.220	308	92	84	0.84	3.74	100.9
2-04	45.0	0.60	1.40	644.640	308	93	85	0.77	3.42	99.4
2-05	50.0	0.67	1.60	648.225	308	92	85	0.82	3.59	98.7
LEAK CHECK	50.0			648.270						
3-01	55.0	0.50	1.20	651.400	306	90	84	0.71	3.13	99.8
3-02	60.0	0.51	1.20	654.582	308	90	84	0.71	3.18	100.6
3-03	65.0	0.56	1.30	657.790	308	90	84	0.75	3.21	96.8
3-04	70.0	0.65	1.60	661.410	308	91	84	0.81	3.62	101.4
3-05	75.0	0.66	1.60	665.025	308	92	84	0.81	3.62	100.4
LEAK CHECK	75.0			665.060						
4-01	80.0	0.55	1.30	668.310	309	89	84	0.74	3.25	99.1
4-02	85.0	0.56	1.30	671.580	309	90	83	0.75	3.27	98.8
4-03	90.0	0.66	1.60	675.210	310	90	83	0.81	3.63	101.2
4-04	95.0	0.70	1.70	678.950	309	91	83	0.84	3.74	101.1
4-05	100.0	0.72	1.70	682.670	308	92	84	0.85	3.72	98.9
LEAK CHECK	100.0			682.740						
5-01	105.0	0.24	0.58	684.890	307	89	84	0.49	2.15	99.0
5-02	110.0	0.61	1.50	688.240	310	88	83	0.78	3.35	97.3
5-03	115.0	0.64	1.50	691.730	308	89	83	0.80	3.49	98.7
5-04	120.0	0.67	1.60	695.330	308	88	82	0.82	3.60	99.8
5-05	125.0	0.63	1.50	698.840	307	88	82	0.79	3.51	100.2
Final	125.0		1.44320	85.17000	307.76000			0.77073	85.17000	

25 points sampled
 QC-Check: Field Averages

Sq.Rt.ΔP	0.7707	1.4432	85.1700	307.7600	86.4800	2RSd =	16.8%
----------	--------	--------	---------	----------	---------	--------	-------

Avg. OK
 Avg. OK
 Avg. OK
 Avg. OK
 Avg. OK

041310 101033
N

USEPA Method 3 Laboratory Data

Location: Unit 2 FF Outlet
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Method: EPA Method 3
 Fuel Type: Municipal Waste
 F_o for Fuel: 1.03 to 1.3

Test Method: USEPA Method 5/29
Analyte: Particulate/Metals

Analyst: S. Brown
 Analyst Emp No: 433

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
1	1							
	2							
	3							
Avg.								
CEM or Other Avg:		9.25000		10.07000	80.68000	29.88280	1.17081	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
2	1							
	2							
	3							
Avg.								
CEM or Other Avg:		9.60000		9.75000	80.65000	29.92600	1.16146	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
3	1							
	2							
	3							
Avg.								
CEM or Other Avg:		9.58000		9.89000	80.53000	29.92840	1.14927	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis:
	1							
	2							
	3							
Avg.								
CEM or Other Avg:								<input type="checkbox"/> Fo value within expected range.

041310 101033
 KLN@

USEPA Method 4 Laboratory Data

Location: Unit 2 FF Outlet
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955

Test Method: **USEPA Method 5/29**
 Analyte: **Particulate/Metals**
 Analyst: B. Wiltse
 Analyst Emp No: 561

Test Run: 1

	Contents	Gross (gm)	Tare (gm)	Net (gm)	
Impinger 1	Empty	723.5	463.1	260.4	
Impinger 2	5%HNO3/10%H2O2	689.7	543.1	146.6	
Impinger 3	5%HNO3/10%H2O2	580.8	550.0	30.8	
Impinger 4	Empty	445.8	440.0	5.8	
Impinger 5	4%KMnO4/10%H2SO4	541.9	540.1	1.8	
Impinger 6	4%KMnO4/10%H2SO4	562.0	562.2	-0.2	445.2 Liquid (gm) <i>Field Data Check</i>
Impinger 7	Silica Gel	742.7	728.5	14.2	0.0 less rinse (gm)
Impinger 8					445.2 Net Liquid (gm) <u>445.2</u> <input type="checkbox"/> QA/QC OK
					+ 14.2 Silica Gel (gm) <u>14.2</u> <input type="checkbox"/> QA/QC OK
					459.4 Total Vlc (gm) <u>459.4</u> <input type="checkbox"/> QA/QC OK

Rinse: _____ (ml or gm)

Test Run: 2

	Contents	Gross (gm)	Tare (gm)	Net (gm)	
Impinger 1	Empty	720.2	440.9	279.3	
Impinger 2	5%HNO3/10%H2O2	666.6	559.6	107.0	
Impinger 3	5%HNO3/10%H2O2	562.4	539.1	23.3	
Impinger 4	Empty	454.2	447.6	6.6	
Impinger 5	4%KMnO4/10%H2SO4	546.3	542.7	3.6	
Impinger 6	4%KMnO4/10%H2SO4	547.1	546.8	0.3	420.1 Liquid (gm) <i>Field Data Check</i>
Impinger 7	Silica Gel	714.1	700.0	14.1	0.0 less rinse (gm)
Impinger 8					420.1 Net Liquid (gm) <u>420.1</u> <input type="checkbox"/> QA/QC OK
					+ 14.1 Silica Gel (gm) <u>14.1</u> <input type="checkbox"/> QA/QC OK
					434.2 Total Vlc (gm) <u>434.2</u> <input type="checkbox"/> QA/QC OK

Rinse: _____ (ml or gm)

Test Run: 3

	Contents	Gross (gm)	Tare (gm)	Net (gm)	
Impinger 1	Empty	732.3	463.4	268.9	
Impinger 2	5%HNO3/10%H2O2	677.1	540.4	136.7	
Impinger 3	5%HNO3/10%H2O2	584.4	551.4	33.0	
Impinger 4	Empty	444.3	440.5	3.8	
Impinger 5	4%KMnO4/10%H2SO4	539.6	537.8	1.8	
Impinger 6	4%KMnO4/10%H2SO4	563.6	563.4	0.2	444.4 Liquid (gm) <i>Field Data Check</i>
Impinger 7	Silica Gel	711.7	692.5	19.2	0.0 less rinse (gm)
Impinger 8					444.4 Net Liquid (gm) <u>444.4</u> <input type="checkbox"/> QA/QC OK
					+ 19.2 Silica Gel (gm) <u>19.2</u> <input type="checkbox"/> QA/QC OK
					463.6 Total Vlc (gm) <u>463.6</u> <input type="checkbox"/> QA/QC OK

Rinse: _____ (ml or gm)

Test Run: _____

	Contents	Gross (gm)	Tare (gm)	Net (gm)	
Impinger 1	Empty				
Impinger 2	5%HNO3/10%H2O2				
Impinger 3	5%HNO3/10%H2O2				
Impinger 4	Empty				
Impinger 5	4%KMnO4/10%H2SO4				
Impinger 6	4%KMnO4/10%H2SO4				Liquid (gm) <i>Field Data Check</i>
Impinger 7	Silica Gel				less rinse (gm)
Impinger 8					Net Liquid (gm) _____ <input type="checkbox"/> QA/QC OK
					Silica Gel (gm) _____ <input type="checkbox"/> QA/QC OK
					Total Vlc (gm) _____ <input type="checkbox"/> QA/QC OK

Rinse: _____ (ml or gm)

041310 101033
 KLN@

Field Data Printout

Test Method: USEPA Method 13B
Analyte: Total Fluorides

Location: Unit 2 FF Outlet
 Test Run: 1
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Source Area (ft²): 64.00000
 Meter Operator: N. Hitchins 569
 Probe Operator: N. Hitchins 569
 Test Date: 3/18/10
 Start Time: 07:09
 Stop Time: 08:24
 Leak Rate Before: 0.004 cfm @ 15 "Hg
 Leak Rate After: 0.004 cfm @ 15 "Hg

Bar. Press. (in. Hg): 30.05
 Static P: -10.6
 O₂ (dry volume %): 10.02
 CO₂ (dry volume %): 9.29
 N₂+CO (dry volume %): 80.69

Nozzle ID No: 288-1
 Nozzle Diameter (D_n): 0.268
 Probe ID No: 67-8-14
 Pitot C_p: 0.8120
 Pitot Leak Check: Pass Fail

H₂O (condensate, ml or gm): 195.9
 H₂O (silica, g): 16.5
 Actual Moisture (%): 20.74

Meter Box ID. No: 66-14
 Meter ΔH@: 1.76430
 Meter Y_d: 0.98980

Traverse Point	Run Time 2.5 min/read	Pitot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dcf)	Stack T _s (°F)	Dry Gas Meter		√ΔP _s (calculated) (√in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)
						T _{m-in} (°F)	T _{m-out} (°F)			
	0.0			499.215						
4-01	2.5	0.50	1.20	500.770	305	58	56	0.71	1.56	105.1
4-02	5.0	0.47	1.10	502.260	307	58	56	0.69	1.49	104.0
4-03	7.5	0.45	1.00	503.350	307	60	56	0.67	1.09	77.6*
4-04	10.0	0.43	1.00	505.000	306	62	56	0.66	1.65	119.8*
4-05	12.5	0.42	1.00	506.380	308	63	57	0.65	1.38	101.2
LEAK CHECK	12.5			506.465						
3-01	15.0	0.45	1.00	507.850	305	63	57	0.67	1.39	98.0
3-02	17.5	0.47	1.10	509.320	307	65	58	0.69	1.47	101.7
3-03	20.0	0.50	1.20	510.820	306	67	58	0.71	1.50	100.4
3-04	22.5	0.58	1.40	512.440	307	68	59	0.76	1.62	100.6
3-05	25.0	0.56	1.30	513.995	307	69	59	0.75	1.55	98.1
LEAK CHECK	25.0			514.065						
2-01	27.5	0.63	1.50	515.730	306	68	60	0.79	1.66	99.0
2-02	30.0	0.60	1.40	517.350	308	70	60	0.77	1.62	98.7
2-03	32.5	0.60	1.40	518.950	307	71	60	0.77	1.60	97.3
2-04	35.0	0.68	1.60	520.700	305	73	61	0.82	1.75	99.6
2-05	37.5	0.66	1.50	522.380	305	73	61	0.81	1.68	97.0
LEAK CHECK	37.5			522.455						
1-01	40.0	0.46	1.10	523.890	306	70	62	0.68	1.43	99.4
1-02	42.5	0.50	1.20	525.390	308	72	62	0.71	1.50	99.6
1-03	45.0	0.46	1.10	526.860	303	72	63	0.68	1.47	101.3
1-04	47.5	0.48	1.10	528.330	307	73	63	0.69	1.47	99.4
1-05	50.0	0.68	1.60	529.700	306	74	63	0.82	1.37	77.8*
LEAK CHECK	50.0			530.195						
5-01	52.5	0.30	0.70	531.350	306	71	64	0.55	1.15	98.7
5-02	55.0	0.57	1.30	532.920	306	72	64	0.75	1.57	97.4
5-03	57.5	0.66	1.50	534.600	307	74	65	0.81	1.68	96.7
5-04	60.0	0.70	1.60	536.330	306	75	65	0.84	1.73	96.5
5-05	62.5	0.65	1.50	538.020	307	76	65	0.81	1.69	97.8
Final	62.5		1.25600	38.08000	306.24000	64.54000		0.73039	38.08000	

25 points sampled
 QC-Check: Field Averages

Sq. Rt. ΔP	0.7304	1.2560	38.0800	306.2400	64.5400
<input checked="" type="checkbox"/> Avg. OK					

2RSD = 14.3%

041310 101103
 N

Field Data Printout

Test Method: USEPA Method 13B
Analyte: Total Fluorides

Location: Unit 2 FF Outlet
 Test Run: 2
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Source Area (ff): 64.00000
 Meter Operator: N. Hitchins 569
 Probe Operator: N. Hitchins 569
 Test Date: 3/18/10
 Start Time: 08:56
 Stop Time: 10:10
 Leak Rate Before: 0.002 cfm @ 15 "Hg
 Leak Rate After: 0.002 cfm @ 15 "Hg

Bar. Press. (in. Hg): 30.05
 Static P: -10.6
 O₂ (dry volume %): 9.64
 CO₂ (dry volume %): 9.58
 N₂+CO (dry volume %): 80.78

Nozzle ID No: 268-1
 Nozzle Diameter (D_n): 0.268
 Probe ID No: 67-8-14
 Pitot C_p: 0.8120
 Pitot Leak Check: Pass Fail

H₂O (condensate, ml or gm): 196.6
 H₂O (silica, g): 13.3
 Actual Moisture (%): 21.12

Meter Box ID. No: 66-14
 Meter ΔH@: 1.76430
 Meter Y_d: 0.98980

Traverse Point	Run Time 2.5 min/read	Pitot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dcf)	Stack T _a (°F)	Dry Gas Meter		√ΔP _s (calculated) (in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)
						T _{m-in} (°F)	T _{m-out} (°F)			
	0.0			538.420						
5-01	2.5	0.63	1.50	540.170	304	69	67	0.79	1.75	103.6
5-02	5.0	0.63	1.50	541.850	304	71	67	0.79	1.68	99.3
5-03	7.5	0.54	1.30	543.430	302	72	67	0.73	1.58	100.6
5-04	10.0	0.51	1.20	544.940	303	74	67	0.71	1.51	98.8
5-05	12.5	0.46	1.10	546.405	304	75	68	0.68	1.46	100.8
LEAK CHECK	12.5			546.475						
4-01	15.0	0.45	1.00	547.860	306	74	68	0.67	1.38	96.5
4-02	17.5	0.45	1.00	549.250	305	75	68	0.67	1.39	96.7
4-03	20.0	0.45	1.00	550.650	305	76	68	0.67	1.40	97.3
4-04	22.5	0.46	1.10	552.120	305	77	68	0.68	1.47	101.0
4-05	25.0	0.46	1.10	553.595	305	78	69	0.68	1.48	101.1
LEAK CHECK	25.0			553.650						
3-01	27.5	0.47	1.10	555.120	305	76	69	0.69	1.47	99.9
3-02	30.0	0.42	0.99	556.490	307	77	69	0.65	1.37	98.5
3-03	32.5	0.42	0.99	557.870	307	77	70	0.65	1.38	99.1
3-04	35.0	0.45	1.00	559.260	306	78	70	0.67	1.39	96.3
3-05	37.5	0.47	1.10	560.730	306	79	71	0.69	1.47	99.5
LEAK CHECK	37.5			560.780						
2-01	40.0	0.43	1.00	562.180	305	76	71	0.66	1.40	99.3
2-02	42.5	0.43	1.00	563.680	306	78	71	0.66	1.50	106.2
2-03	45.0	0.50	1.20	565.100	306	78	71	0.71	1.42	93.3
2-04	47.5	0.59	1.40	566.730	306	80	71	0.77	1.83	98.4
2-05	50.0	0.65	1.50	568.415	307	81	71	0.81	1.68	97.0
LEAK CHECK	50.0			568.520						
1-01	52.5	0.45	1.00	569.950	306	77	72	0.67	1.43	99.0
1-02	55.0	0.46	1.10	571.390	306	78	72	0.68	1.44	98.5
1-03	57.5	0.46	1.10	572.860	306	80	72	0.68	1.47	100.4
1-04	60.0	0.51	1.20	574.380	307	80	72	0.71	1.52	98.7
1-05	62.5	0.63	1.50	576.085	307	81	72	0.79	1.71	99.6
Final	62.5		1.15920	37.38500	305.44000	73.16000		0.70199	37.38500	

25 points sampled
 QC-Check: Field Averages
 Sq.RLAP: 0.7020 1.1592 37.3850 305.4400 73.1600
 2RS D = 10.0%
 Avg. OK Avg. OK Avg. OK Avg. OK Avg. OK

041310 101103
 0

Field Data Printout

Test Method: USEPA Method 13B
Analyte: Total Fluorides

Location: Unit 2 FF Outlet

Test Run: 3

Client: Wheelabrator North Broward, Inc.

Project No: 10955

Source Area (ff): 64.00000

Meter Operator: N. Hitchins 569

Probe Operator: N. Hitchins 569

Test Date: 3/18/10

Start Time: 10:45

Stop Time: 12:05

Leak Rate Before: 0.004 cfm @ 15 "Hg

Leak Rate After: 0.003 cfm @ 12 "Hg

Bar. Press. (in. Hg): 30.05

Static P: -10.6

O₂ (dry volume %): 10.15

CO₂ (dry volume %): 9.13

N₂+CO (dry volume %): 80.72

Nozzle ID No: 268-1

Nozzle Diameter (D_n): 0.268

Probe ID No: 67-8-14

Pitot C_p: 0.8120

Pitot Leak Check: Pass Fail

H₂O (condensate, ml or gm): 192.7

H₂O (silica, g): 8.9

Actual Moisture (%): 20.27

Meter Box ID. No: 66-14

Meter ΔH@: 1.76430

Meter Y_c: 0.98980

Traverse Point	Run Time 2.5 min/read	Pitot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dcf)	Stack T _s (°F)	Dry Gas Meter		√ΔP _s (calculated) (√in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)
						T _{m-in} (°F)	T _{m-out} (°F)			
	0.0			576.360						
2-01	2.5	0.52	1.20	577.940	307	75	74	0.72	1.58	100.9
2-02	5.0	0.48	1.10	579.390	306	77	74	0.69	1.45	96.1
2-03	7.5	0.49	1.20	580.880	306	79	74	0.70	1.49	97.6
2-04	10.0	0.59	1.40	582.510	305	81	75	0.77	1.63	97.0
2-05	12.5	0.62	1.50	584.215	305	82	75	0.79	1.71	98.9
LEAK CHECK	12.5			584.320						
1-01	15.0	0.44	1.00	585.730	305	81	76	0.66	1.41	97.0
1-02	17.5	0.46	1.10	587.210	305	83	77	0.68	1.48	99.3
1-03	20.0	0.43	1.00	588.610	302	85	77	0.66	1.40	96.8
1-04	22.5	0.43	1.00	590.020	304	85	77	0.66	1.41	97.6
1-05	25.0	0.62	1.50	591.725	305	86	78	0.79	1.71	98.3
LEAK CHECK	25.0			591.785						
3-01	27.5	0.36	0.87	593.110	306	83	79	0.60	1.33	100.3
3-02	30.0	0.46	1.10	594.600	307	84	79	0.68	1.49	99.8
3-03	32.5	0.47	1.10	596.070	307	85	79	0.69	1.47	97.3
3-04	35.0	0.51	1.20	597.600	306	85	79	0.71	1.53	97.2
3-05	37.5	0.53	1.30	599.185	306	86	80	0.73	1.58	98.6
LEAK CHECK	37.5			599.250						
4-01	40.0	0.56	1.30	600.850	307	84	80	0.75	1.60	97.1
4-02	42.5	0.51	1.20	602.440	307	85	80	0.71	1.59	101.0
4-03	45.0	0.52	1.20	604.080	306	86	80	0.72	1.64	103.0
4-04	47.5	0.56	1.30	605.580	307	87	80	0.75	1.50	90.8
4-05	50.0	0.51	1.20	607.150	306	88	80	0.71	1.57	99.4
LEAK CHECK	50.0			607.240						
5-01	52.5	0.25	0.60	608.350	305	83	81	0.50	1.11	100.5
5-02	55.0	0.58	1.40	609.990	306	85	81	0.76	1.64	97.6
5-03	57.5	0.64	1.50	611.710	306	86	81	0.80	1.72	97.4
5-04	60.0	0.64	1.50	613.370	306	87	81	0.80	1.66	93.9
5-05	62.5	0.58	1.40	615.045	305	88	82	0.76	1.67	99.2
Final	62.5		1.20680	38.36500	305.72000	81.10000		0.71140	38.36500	

25 points sampled
 QC-Check: Field Averages

Sq.Rt.ΔP	0.7114	1.2068	38.3650	305.7200	81.1000
----------	--------	--------	---------	----------	---------

2RSD = 13.4%

Avg. OK Avg. OK Avg. OK Avg. OK Avg. OK

041310 101103
 N

USEPA Method 3 Laboratory Data

Location: Unit 2 FF Outlet
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Method: EPA Method 3
 Fuel Type: Municipal Waste
 F_o for Fuel: 1.03 to 1.3

Test Method: USEPA Method 13B
Analyte: Total Fluorides

Analyst: S. Brown
 Analyst Emp No: 433

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
1	1							
	2							
	3							
Avg.								
CEM or Other Avg:		9.29000		10.02000	80.69000	29.88720	1.17115	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
2	1							
	2							
	3							
Avg.								
CEM or Other Avg:		9.58000		9.64000	80.78000	29.91840	1.17537	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
3	1							
	2							
	3							
Avg.								
CEM or Other Avg:		9.13000		10.15000	80.72000	29.86680	1.17744	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis:
	1							
	2							
	3							
Avg.								
CEM or Other Avg:								<input type="checkbox"/> Fo value within expected range.

041310 101103
 NON@

USEPA Method 4 Laboratory Data

Location: Unit 2 FF Outlet
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955

Test Method: USEPA Method 13B
Analyte: Total Fluorides
 Analyst: R. Vicere
 Analyst Emp No: 563

Test Run: 1

	Contents	Gross (gm)	Tare (gm)	Net (gm)	
Impinger 1	DI Water	645.7	547.6	98.1	
Impinger 2	DI Water	642.5	566.6	75.9	
Impinger 3	Empty	482.7	460.8	21.9	
Impinger 4	Silica Gel	772.2	755.7	16.5	
Impinger 5					
Impinger 6					
Impinger 7					
Impinger 8					

195.9 Liquid (gm) *Field Data Check*
 0.0 less rinse (gm)
 195.9 Net Liquid (gm) 195.9 QA/QC OK
 + 16.5 Silica Gel (gm) 16.5 QA/QC OK
 212.4 Total Vlc (gm) 212.4 QA/QC OK

Rinse: _____ (ml or gm)

Test Run: 2

	Contents	Gross (gm)	Tare (gm)	Net (gm)	
Impinger 1	DI Water	676.7	542.4	134.3	
Impinger 2	DI Water	594.8	541.5	53.3	
Impinger 3	Empty	446.0	437.0	9.0	
Impinger 4	Silica Gel	769.2	755.9	13.3	
Impinger 5					
Impinger 6					
Impinger 7					
Impinger 8					

196.6 Liquid (gm) *Field Data Check*
 0.0 less rinse (gm)
 196.6 Net Liquid (gm) 196.6 QA/QC OK
 + 13.3 Silica Gel (gm) 13.3 QA/QC OK
 209.9 Total Vlc (gm) 209.9 QA/QC OK

Rinse: _____ (ml or gm)

Test Run: 3

	Contents	Gross (gm)	Tare (gm)	Net (gm)	
Impinger 1	DI Water	678.4	538.3	140.1	
Impinger 2	DI Water	600.9	556.3	44.6	
Impinger 3	Empty	460.3	452.3	8.0	
Impinger 4	Silica Gel	764.5	755.6	8.9	
Impinger 5					
Impinger 6					
Impinger 7					
Impinger 8					

192.7 Liquid (gm) *Field Data Check*
 0.0 less rinse (gm)
 192.7 Net Liquid (gm) 192.7 QA/QC OK
 + 8.9 Silica Gel (gm) 8.9 QA/QC OK
 201.6 Total Vlc (gm) 201.6 QA/QC OK

Rinse: _____ (ml or gm)

Test Run: _____

	Contents	Gross (gm)	Tare (gm)	Net (gm)	
Impinger 1	DI Water				
Impinger 2	DI Water				
Impinger 3	Empty				
Impinger 4	Silica Gel				
Impinger 5					
Impinger 6					
Impinger 7					
Impinger 8					

_____ Liquid (gm) *Field Data Check*
 _____ less rinse (gm)
 _____ Net Liquid (gm) _____ QA/QC OK
 _____ Silica Gel (gm) _____ QA/QC OK
 _____ Total Vlc (gm) _____ QA/QC OK

Rinse: _____ (ml or gm)

041310 101103
 NON®

Field Data Printout

Test Method: USEPA Method 23
 Analyte: PCDD/F

Location: Unit 2 FF Outlet
 Test Run: 1
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Source Area (ft²): 64.00000
 Meter Operator: N. Hitchens 569
 Probe Operator: N. Hitchens 569
 Test Date: 3/16/10
 Start Time: 08:44
 Stop Time: 13:36
 Leak Rate Before: 0.005 cfm @ 15 "Hg
 Leak Rate After: 0.005 cfm @ 15 "Hg

Bar. Press. (in. Hg): 30.00
 Static P: -12.0
 O₂ (dry volume %): 9.68
 CO₂ (dry volume %): 9.74
 N₂+CO (dry volume %): 80.58

Nozzle ID No: 264-1
 Nozzle Diameter (D_n): 0.264
 Probe ID No: 67-8-17
 Pilot C_p: 0.8340
 Pitot Leak Check: Pass Fail

H₂O (condensate, ml or gm): 792.4
 H₂O (silica, g): 44.1
 Actual Moisture (%): 20.14

Meter Box ID. No: 66-6
 Meter ΔH@: 1.78700
 Meter Y_c: 0.99010

Traverse Point	Run Time 5.0 min/read	Pilot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dscf)	Stack T _s (°F)	Dry Gas Meter		√ΔP _s (calculated) (in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)
						T _{m-in} (°F)	T _{m-out} (°F)			
	0.0			690.310						
1-01	5.0	0.69	1.60	693.890	298	65	62	0.83	3.58	101.3
1-01	10.0	0.62	1.40	697.300	297	65	62	0.79	3.41	101.6
1-02	15.0	0.50	1.10	700.030	296	67	63	0.71	2.73	90.2
1-02	20.0	0.49	1.10	703.040	297	69	64	0.70	3.01	100.3
1-03	25.0	0.50	1.10	705.980	297	70	65	0.71	2.94	96.8
1-03	30.0	0.51	1.20	708.990	298	71	65	0.71	3.01	98.1
1-04	35.0	0.51	1.20	712.030	297	72	67	0.71	3.04	98.7
1-04	40.0	0.56	1.30	715.150	296	72	67	0.75	3.12	96.6
1-05	45.0	0.48	1.10	718.170	295	74	68	0.69	3.02	100.6
1-05	50.0	0.76	1.70	721.785	298	74	68	0.87	3.62	96.1
LEAK CHECK	50.0			722.405						
2-01	55.0	0.59	1.40	725.740	297	74	70	0.77	3.34	100.3
2-01	60.0	0.61	1.40	729.020	297	75	71	0.78	3.28	96.8
2-02	65.0	0.61	1.40	732.300	297	76	72	0.78	3.28	96.6
2-02	70.0	0.64	1.50	735.970	296	77	72	0.80	3.67	105.4
2-03	75.0	0.60	1.40	739.110	297	79	73	0.77	3.14	92.9
2-03	80.0	0.58	1.40	742.410	297	80	74	0.76	3.30	99.1
2-04	85.0	0.60	1.40	745.770	297	80	75	0.77	3.36	99.1
2-04	90.0	0.53	1.20	748.930	298	80	75	0.73	3.16	99.2
2-05	95.0	0.54	1.30	752.150	296	80	76	0.73	3.22	100.0
2-05	100.0	0.52	1.20	755.290	296	81	76	0.72	3.14	99.2
LEAK CHECK	100.0			755.665						
3-01	105.0	0.63	1.50	759.060	297	80	77	0.79	3.39	97.6
3-01	110.0	0.63	1.50	762.500	298	82	78	0.79	3.44	98.7
3-02	115.0	0.55	1.30	765.780	298	83	79	0.74	3.28	100.5
3-02	120.0	0.56	1.30	769.030	297	84	80	0.75	3.25	98.4
3-03	125.0	0.51	1.20	772.170	297	85	81	0.71	3.14	99.4
3-03	130.0	0.52	1.20	775.300	299	86	81	0.72	3.13	98.2
3-04	135.0	0.56	1.30	778.520	299	86	82	0.75	3.22	97.3
3-04	140.0	0.57	1.30	781.710	301	87	82	0.75	3.19	95.6
3-05	145.0	0.62	1.40	785.060	301	87	83	0.79	3.35	96.2
3-05	150.0	0.63	1.50	788.485	301	88	84	0.79	3.43	97.4
LEAK CHECK	150.0			788.850						
4-01	155.0	0.48	1.10	791.930	304	86	84	0.69	3.08	100.6
4-01	160.0	0.46	1.10	794.950	304	87	84	0.68	3.02	100.7
4-02	165.0	0.45	1.00	797.790	305	88	85	0.67	2.84	95.6
4-02	170.0	0.48	1.10	800.690	304	89	85	0.69	2.90	94.4
4-03	175.0	0.52	1.20	803.790	304	89	86	0.72	3.10	96.9
4-03	180.0	0.54	1.30	806.930	305	90	86	0.73	3.14	96.3
4-04	185.0	0.52	1.20	810.100	304	90	86	0.72	3.17	99.0
4-04	190.0	0.53	1.20	813.050	305	90	87	0.73	2.95	91.2
4-05	195.0	0.52	1.20	816.190	305	89	87	0.72	3.14	98.1
4-05	200.0	0.59	1.40	819.560	305	89	86	0.77	3.37	99.0
LEAK CHECK	200.0			819.970						
5-01	205.0	0.52	1.20	823.030	305	88	86	0.72	3.06	95.8
5-01	210.0	0.53	1.20	826.220	305	87	86	0.73	3.19	99.0
5-02	215.0	0.55	1.30	829.430	306	88	86	0.74	3.21	97.8
5-02	220.0	0.56	1.30	832.660	306	88	86	0.75	3.23	97.5
5-03	225.0	0.62	1.40	836.030	308	88	86	0.79	3.37	96.8
5-03	230.0	0.61	1.40	839.410	307	89	86	0.78	3.38	97.7
5-04	235.0	0.66	1.50	842.890	306	89	86	0.81	3.48	96.7
5-04	240.0	0.64	1.50	846.330	306	89	86	0.80	3.44	97.1
5-05	245.0	0.47	1.10	849.390	307	88	86	0.69	3.06	100.8
5-05	250.0	0.46	1.10	852.425	306	87	86	0.68	3.03	101.1
Final	250.0		1.29400	160.34500	300.64000	80.05000		0.74616	160.34500	

25 points sampled
 QC-Check: Field Averages

SqRTLAP	0.7462	1.2940	160.3450	300.6400	80.0500
Avg. OK	<input checked="" type="checkbox"/>	Avg. OK	<input checked="" type="checkbox"/>	Avg. OK	<input checked="" type="checkbox"/>

2RSR = 8.7%

041310 101123

Field Data Printout

Test Method: USEPA Method 23
Analyte: PCDD/F

Location: Unit 2 FF Outlet
 Test Run: 2
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Source Area (ft²): 64.00000
 Meter Operator: N. Hitchins 569
 Probe Operator: N. Hitchins 569
 Test Date: 3/17/10
 Start Time: 06:54
 Stop Time: 12:19
 Leak Rate Before: 0.004 cfm @ 15 "Hg
 Leak Rate After: 0.005 cfm @ 18 "Hg

Bar. Press. (in. Hg): 30.00
 Static P: -12.5
 O₂ (dry volume %): 9.74
 CO₂ (dry volume %): 9.84
 N₂+CO (dry volume %): 80.42

Nozzle ID No: 264-1
 Nozzle Diameter (D_n): 0.264
 Probe ID No: 67-B-17
 Pitot C_p: 0.8340
 Pitot Leak Check: Pass Fail

H₂O (condensate, ml or gm): 882.9
 H₂O (silica, g): 61.0
 Actual Moisture (%): 20.83

Meter Box ID. No: 66-6
 Meter ΔH@: 1.78700
 Meter Y_d: 0.99010

Traverse Point	Run Time 5.0 min/read	Pitot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dcf)	Stack T _s (°F)	Dry Gas Meter		√ΔP _s (calculated) (√in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)
						T _{m-in} (°F)	T _{m-out} (°F)			
5-01	0.0			853.415						
5-01	5.0	0.61	1.50	856.850	305	69	66	0.78	3.44	103.8
5-01	10.0	0.61	1.50	860.110	306	70	68	0.78	3.26	98.3
5-02	15.0	0.61	1.50	863.430	307	71	68	0.78	3.32	100.1
5-02	20.0	0.61	1.50	866.830	307	72	68	0.78	3.40	102.4
5-03	25.0	0.59	1.40	870.190	310	73	69	0.77	3.36	102.9
5-03	30.0	0.59	1.40	873.540	310	73	69	0.77	3.35	102.6
5-04	35.0	0.62	1.50	876.930	309	74	70	0.79	3.39	101.0
5-04	40.0	0.62	1.50	880.360	309	75	71	0.79	3.43	102.0
5-05	45.0	0.58	1.40	883.690	309	75	71	0.76	3.33	102.4
5-05	50.0	0.55	1.30	886.945	308	75	71	0.74	3.26	102.7
LEAK CHECK	50.0			887.180						
4-01	55.0	0.56	1.30	890.360	310	74	72	0.75	3.18	99.6
4-01	60.0	0.54	1.30	893.530	309	76	72	0.73	3.17	100.8
4-02	65.0	0.62	1.50	896.910	311	77	73	0.79	3.38	100.3
4-02	70.0	0.65	1.60	900.400	312	77	73	0.81	3.49	101.2
4-03	75.0	0.63	1.50	903.870	311	77	73	0.79	3.47	102.2
4-03	80.0	0.63	1.50	907.315	311	77	74	0.79	3.45	101.3
4-04	85.0	0.65	1.50	910.780	308	74	73	0.81	3.46	100.5
4-04	90.0	0.62	1.50	914.160	308	74	73	0.79	3.38	100.4
4-05	95.0	0.77	1.80	917.840	310	77	73	0.88	3.68	98.0
4-05	100.0	0.67	1.60	921.400	308	77	74	0.82	3.56	101.4
LEAK CHECK	100.0			921.590						
3-01	105.0	0.65	1.50	924.970	308	76	74	0.81	3.38	97.8
3-01	110.0	0.68	1.60	928.470	307	77	74	0.82	3.50	98.9
3-02	115.0	0.61	1.50	931.930	305	78	75	0.78	3.46	102.8
3-02	120.0	0.80	1.40	935.280	306	77	75	0.77	3.35	100.5
3-03	125.0	0.66	1.60	938.770	308	78	76	0.81	3.49	99.8
3-03	130.0	0.65	1.50	942.280	307	79	76	0.81	3.51	101.0
3-04	135.0	0.65	1.50	945.670	307	78	76	0.81	3.39	97.6
3-04	140.0	0.65	1.50	949.100	308	78	76	0.81	3.43	98.8
3-05	145.0	0.62	1.50	952.540	307	78	76	0.79	3.44	101.4
3-05	150.0	0.65	1.50	955.950	307	78	76	0.81	3.41	98.2
LEAK CHECK	150.0			956.210						
2-01	155.0	0.67	1.60	959.690	308	77	76	0.82	3.48	98.9
2-01	160.0	0.67	1.60	963.160	307	77	76	0.82	3.47	98.5
2-02	165.0	0.66	1.60	966.750	306	77	76	0.81	3.59	102.7
2-02	170.0	0.65	1.50	970.170	307	78	76	0.81	3.42	98.5
2-03	175.0	0.70	1.70	973.790	307	78	76	0.84	3.62	100.5
2-03	180.0	0.70	1.70	977.420	306	77	76	0.84	3.63	100.8
2-04	185.0	0.68	1.60	980.990	306	78	76	0.82	3.57	100.5
2-04	190.0	0.66	1.60	984.490	305	78	76	0.81	3.50	99.9
2-05	195.0	0.66	1.60	988.000	305	78	76	0.81	3.51	100.2
2-05	200.0	0.70	1.70	991.595	305	78	76	0.84	3.60	99.7
LEAK CHECK	200.0			991.910						
1-01	205.0	0.56	1.30	995.050	307	76	76	0.75	3.14	97.6
1-01	210.0	0.59	1.40	998.340	307	77	75	0.77	3.29	99.6
1-02	215.0	0.59	1.40	1001.630	306	77	75	0.77	3.29	99.5
1-02	220.0	0.59	1.40	1004.900	306	76	75	0.77	3.27	99.0
1-03	225.0	0.59	1.40	1008.180	306	76	74	0.77	3.28	99.4
1-03	230.0	0.56	1.30	1011.430	305	76	74	0.75	3.25	101.0
1-04	235.0	0.63	1.50	1014.810	306	74	73	0.79	3.38	99.5
1-04	240.0	0.71	1.70	1018.410	306	74	73	0.84	3.60	99.8
1-05	245.0	0.80	1.90	1022.240	307	72	71	0.89	3.83	100.6
1-05	250.0	0.80	1.90	1026.030	308	71	71	0.89	3.79	99.7
Final	250.0			1.52200	171.61500	307.48000	74.61000	0.79826	171.61500	

25 points sampled
 QC-Check: Field Averages **Sq.RLAP**

0.7983	1.5220	171.6150	307.4800	74.6100
--------	--------	----------	----------	---------

 2RSR = 7.0%
 Avg. OK Avg. OK Avg. OK Avg. OK Avg. OK

041310 101123
M

Field Data Printout

Test Method: USEPA Method 23
 Analyte: PCDD/F

Location: Unit 2 FF Outlet
 Test Run: 3
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Source Area (ft²): 64.00000
 Meter Operator: N. Hitchens 569
 Probe Operator: N. Hitchens 569
 Test Date: 3/17/10
 Start Time: 12:53
 Stop Time: 17:26
 Leak Rate Before: 0.005 cfm @ 16" Hg
 Leak Rate After: 0.005 cfm @ 16" Hg

Bar. Press. (in. Hg): 30.00
 Static P: -10.4
 O₂ (dry volume %): 10.31
 CO₂ (dry volume %): 9.47
 N₂+CO (dry volume %): 80.22

Nozzle ID No: 264-1
 Nozzle Diameter (D_n): 0.264
 Probe ID No: 67-8-17
 Pitot C_p: 0.8340
 Pitot Leak Check: Pass Fail

H₂O (condensate, ml or gm): 837.6
 H₂O (silica, g): 59.1
 Actual Moisture (%): 20.45

Meter Box ID. No: 66-24
 Meter ΔH@: 1.75160
 Meter Y_c: 0.99040

Traverse Point	Run Time 5.0 min/read	Pitot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dof)	Stack T _s (°F)	Dry Gas Meter		√ΔP _s (calculated) (√in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)
						T _{m-in} (°F)	T _{m-out} (°F)			
	0.0			277.760						
1-01	5.0	0.48	1.10	280.780	308	67	69	0.69	3.02	102.2
1-01	10.0	0.46	1.10	283.840	307	77	68	0.68	3.06	104.8
1-02	15.0	0.62	1.50	287.290	308	72	68	0.79	3.45	102.4
1-02	20.0	0.56	1.30	290.600	308	74	68	0.75	3.31	103.2
1-03	25.0	0.63	1.50	294.040	307	75	68	0.79	3.44	101.0
1-03	30.0	0.60	1.40	297.460	306	76	68	0.77	3.42	102.7
1-04	35.0	0.70	1.60	301.030	308	76	68	0.84	3.57	99.4
1-04	40.0	0.70	1.60	304.600	309	77	68	0.84	3.57	99.4
1-05	45.0	0.76	1.80	308.360	308	77	68	0.87	3.76	100.4
1-05	50.0	0.75	1.80	312.145	308	77	69	0.87	3.78	101.7
LEAK CHECK	50.0			312.345						
2-01	55.0	0.58	1.40	315.540	308	74	68	0.76	3.19	97.9
2-01	60.0	0.55	1.30	318.770	307	74	68	0.74	3.23	101.5
2-02	65.0	0.51	1.20	321.900	307	75	68	0.71	3.13	102.0
2-02	70.0	0.51	1.20	324.990	307	75	68	0.71	3.09	100.7
2-03	75.0	0.56	1.30	328.190	309	76	68	0.75	3.20	99.6
2-03	80.0	0.58	1.40	331.520	309	77	68	0.76	3.33	101.8
2-04	85.0	0.55	1.30	334.810	308	77	68	0.74	3.29	103.2
2-04	90.0	0.55	1.30	338.020	310	77	68	0.74	3.21	100.8
2-05	95.0	0.51	1.20	341.210	308	76	69	0.71	3.19	103.9
2-05	100.0	0.54	1.30	344.440	309	76	68	0.73	3.23	102.4
LEAK CHECK	100.0			344.700						
3-01	105.0	0.66	1.60	348.270	308	74	68	0.81	3.57	102.6
3-01	110.0	0.62	1.50	351.790	306	74	68	0.79	3.52	104.2
3-02	115.0	0.57	1.30	355.100	308	74	68	0.75	3.31	102.3
3-02	120.0	0.57	1.30	358.390	308	75	67	0.75	3.29	101.6
3-03	125.0	0.58	1.40	361.720	308	76	67	0.76	3.33	101.9
3-03	130.0	0.55	1.30	364.970	309	76	68	0.74	3.25	102.1
3-04	135.0	0.56	1.30	368.200	308	76	68	0.75	3.23	100.5
3-04	140.0	0.57	1.30	371.450	309	76	68	0.75	3.25	100.3
3-05	145.0	0.57	1.30	374.720	309	77	68	0.75	3.27	100.8
3-05	150.0	0.51	1.20	377.895	308	77	68	0.71	3.17	103.4
LEAK CHECK	150.0			378.175						
4-01	155.0	0.60	1.40	381.520	309	74	68	0.77	3.34	100.8
4-01	160.0	0.62	1.50	384.980	308	75	68	0.79	3.46	102.5
4-02	165.0	0.64	1.50	388.440	307	77	69	0.80	3.46	100.5
4-02	170.0	0.62	1.50	391.970	307	77	69	0.79	3.53	104.2
4-03	175.0	0.53	1.20	395.130	307	77	69	0.73	3.16	100.8
4-03	180.0	0.53	1.20	398.290	307	77	69	0.73	3.16	100.8
4-04	185.0	0.67	1.60	401.850	308	77	69	0.82	3.56	101.1
4-04	190.0	0.63	1.50	405.380	309	77	69	0.79	3.53	103.5
4-05	195.0	0.65	1.50	408.900	308	77	69	0.81	3.52	101.5
4-05	200.0	0.65	1.50	412.410	308	77	69	0.81	3.51	101.2
LEAK CHECK	200.0			412.760						
5-01	205.0	0.59	1.40	416.120	310	77	69	0.77	3.36	101.8
5-01	210.0	0.52	1.20	419.270	308	77	69	0.72	3.15	101.5
5-02	215.0	0.50	1.20	422.410	307	77	69	0.71	3.14	103.1
5-02	220.0	0.52	1.20	425.590	308	78	70	0.72	3.18	102.3
5-03	225.0	0.51	1.20	428.760	306	79	70	0.71	3.17	102.7
5-03	230.0	0.51	1.20	431.890	307	79	70	0.71	3.13	101.5
5-04	235.0	0.54	1.30	435.080	307	79	71	0.73	3.19	100.4
5-04	240.0	0.55	1.30	438.280	307	79	71	0.74	3.20	99.8
5-05	245.0	0.54	1.30	441.490	306	79	71	0.73	3.21	101.0
5-05	250.0	0.69	1.60	445.005	308	78	71	0.83	3.51	98.1
Final	250.0		1.36800	166.15500	307.84000	72.37000		0.76126	166.15500	

25 points sampled
 QC-Check: Field Averages
 Sq,RLAP
 0.7611 1.3680 166.1550 307.8400 72.3700
 .2RSD = 8.8%
 Avg. OK Avg. OK Avg. OK Avg. OK Avg. OK

USEPA Method 3 Laboratory Data

Location: Unit 2 FF Outlet
 Client: Wheelabrator North Broward, Inc.

Test Method: USEPA Method 23
Analyte: PCDD/F

Project No: 10955
 Method: EPA Method 3
 Fuel Type: Municipal Waste
 F_o for Fuel: 1.03 to 1.3

Analyst: S. Brown
 Analyst Emp No: 433

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
1	1							
	2							
	3							
Avg.								
CEM or Other Avg:		9.74000		9.68000	80.58000	29.94560	1.15195	<input checked="" type="checkbox"/> F _o value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
2	1							
	2							
	3							
Avg.								
CEM or Other Avg:		9.84000		9.74000	80.42000	29.96400	1.13415	<input checked="" type="checkbox"/> F _o value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
3	1							
	2							
	3							
Avg.								
CEM or Other Avg:		9.47000		10.31000	80.22000	29.92760	1.11827	<input checked="" type="checkbox"/> F _o value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis:
	1							
	2							
	3							
Avg.								
CEM or Other Avg:								<input type="checkbox"/> F _o value within expected range.

041310 101123
 P M G @

USEPA Method 4 Laboratory Data

Location: Unit 2 FF Outlet
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955

Test Method: USEPA Method 23
Analyte: PCDD/F
Analyst: R. Vicere
Analyst Emp No: 563

Test Run: 1

	Contents	Gross (gm)	Tare (gm)	Net (gm)	
Impinger 1	Empty	1532.1	633.7	898.4	
Impinger 2	HPLC Water	483.7	551.1	-67.4	
Impinger 3	HPLC Water	475.6	529.6	-54.0	
Impinger 4	Empty	440.1	437.1	3.0	
Impinger 5	XAD Trap	398.7	386.3	12.4	
Impinger 6	Silica Gel	842.6	798.5	44.1	792.4 Liquid (gm)
Impinger 7					0.0 less rinse (gm)
Impinger 8					792.4 Net Liquid (gm)
					+ 44.1 Silica Gel (gm)
					836.5 Total Vlc (gm)

Rinse: _____ (ml or gm)

792.4	Field Data Check
792.4	<input checked="" type="checkbox"/> QA/QC OK
44.1	<input checked="" type="checkbox"/> QA/QC OK
836.5	<input checked="" type="checkbox"/> QA/QC OK

Test Run: 2

	Contents	Gross (gm)	Tare (gm)	Net (gm)	
Impinger 1	Empty	1520.8	624.9	895.9	
Impinger 2	100 ml HPLC H2O	542.4	524.1	18.3	
Impinger 3	100 ml HPLC H2O	498.5	541.2	-42.7	
Impinger 4	XAD Trap	357.6	346.2	11.4	
Impinger 5	Silica Gel	797.0	736.0	61.0	882.9 Liquid (gm)
Impinger 6					0.0 less rinse (gm)
Impinger 7					882.9 Net Liquid (gm)
Impinger 8					+ 61.0 Silica Gel (gm)
					943.9 Total Vlc (gm)

Rinse: _____ (ml or gm)

882.9	Field Data Check
882.9	<input checked="" type="checkbox"/> QA/QC OK
61.0	<input checked="" type="checkbox"/> QA/QC OK
943.9	<input checked="" type="checkbox"/> QA/QC OK

Test Run: 3

	Contents	Gross (gm)	Tare (gm)	Net (gm)	
Impinger 1	Empty	1460.5	635.1	825.4	
Impinger 2	100 ml HPLC H2O	531.2	531.6	-0.4	
Impinger 3	100 ml HPLC H2O	541.3	540.5	0.8	
Impinger 4	XAD Trap	352.7	340.9	11.8	
Impinger 5	Silica Gel	875.1	816.0	59.1	837.6 Liquid (gm)
Impinger 6					0.0 less rinse (gm)
Impinger 7					837.6 Net Liquid (gm)
Impinger 8					+ 59.1 Silica Gel (gm)
					896.7 Total Vlc (gm)

Rinse: _____ (ml or gm)

837.6	Field Data Check
837.6	<input checked="" type="checkbox"/> QA/QC OK
59.1	<input checked="" type="checkbox"/> QA/QC OK
896.7	<input checked="" type="checkbox"/> QA/QC OK

Test Run: _____

	Contents	Gross (gm)	Tare (gm)	Net (gm)	
Impinger 1	Empty				
Impinger 2	HPLC Water				
Impinger 3	HPLC Water				
Impinger 4	Empty				
Impinger 5	XAD Trap				
Impinger 6	Silica Gel				
Impinger 7					
Impinger 8					

Rinse: _____ (ml or gm)

	Liquid (gm)	Field Data Check
	less rinse (gm)	
	Net Liquid (gm)	<input type="checkbox"/> QA/QC OK
	Silica Gel (gm)	<input type="checkbox"/> QA/QC OK
	Total Vlc (gm)	<input type="checkbox"/> QA/QC OK

041310 101123
 P M G @

Field Data Printout

Test Method: USEPA Method 26A
Analyte: HCl

Location: Unit 2 SDA Inlet
 Test Run: 1
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Source Area (ft²): 60.13205
 Meter Operator: B. Arnold 770
 Probe Operator: B. Arnold 770
 Test Date: 3/17/10
 Start Time: 06:54
 Stop Time: 07:54
 Leak Rate Before: 0.003 cfm @ 15 "Hg
 Leak Rate After: 0.004 cfm @ 20 "Hg

Bar. Press. (in. Hg): 30.00
 Static P: -1.7
 O₂ (dry volume %): 8.41
 CO₂ (dry volume %): 10.86
 N₂+CO (dry volume %): 80.73

Nozzle ID No: NA
 Nozzle Diameter (D_n): NA
 Probe ID No: 67-4-5
 Pitot C_p: 0.8400
 Pitot Leak Check: Pass Fail

H₂O (condensate, ml or gm): 148.5
 H₂O (silica, g): 13.3
 Actual Moisture (%): 17.51

Meter Box ID. No: 61-8
 Meter ΔH@: 1.75800
 Meter Y_d: 0.99160

Traverse Point	Run Time 5.0 min/read	Pitot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dcf)	Stack T _a (°F)	Dry Gas Meter		√ΔP _s (calculated) (√in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)
						T _{m-in} (°F)	T _{m-out} (°F)			
	0.0			101.165						
1-01	5.0		1.20	104.210	501	67	64		3.04	
1-01	10.0		1.20	107.120	504	69	65		2.91	
1-01	15.0		1.20	110.120	507	71	65		3.00	
1-01	20.0		1.20	113.190	512	74	66		3.07	
1-01	25.0		1.20	116.210	514	76	67		3.02	
1-01	30.0		1.20	119.150	514	79	70		2.94	
1-01	35.0		1.20	122.230	514	80	72		3.08	
1-01	40.0		1.20	125.340	514	78	71		3.11	
1-01	45.0		1.20	128.410	512	80	72		3.07	
1-01	50.0		1.20	131.490	510	80	73		3.08	
1-01	55.0		1.20	134.550	505	81	74		3.06	
1-01	60.0		1.10	137.490	507	79	74		2.94	
Final	60.0		1.19167	36.32500	509.50000	72.79167		0.00000	36.32500	

1 points sampled
 QC-Check: Field Averages: Sq.Rt.ΔP 1.1917 36.3250 509.5000 72.7917

Avg. OK Avg. OK Avg. OK Avg. OK Avg. OK

041310 101149
K

Field Data Printout

Test Method: USEPA Method 26A
Analyte: HCl

Location: Unit 2 SDA Inlet
 Test Run: 2
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Source Area (ff): 60.13205

Meter Operator: B. Arnold 770
 Probe Operator: B. Arnold 770

Test Date: 3/17/10
 Start Time: 09:02
 Stop Time: 10:02
 Leak Rate Before: 0.003 cfm @ 15 "Hg
 Leak Rate After: 0.003 cfm @ 20 "Hg

Bar. Press. (in. Hg): 30.00
 Static P: -1.9
 O₂ (dry volume %): 9.29
 CO₂ (dry volume %): 10.19
 N₂+CO (dry volume %): 80.52

Nozzle ID No: NA
 Nozzle Diameter (D_n): NA
 Probe ID No: 67-4-5
 Pitot C_p: 0.8400
 Pitot Leak Check: Pass Fail

H₂O (condensate, ml or gm): 139.0
 H₂O (silica, g): 12.2
 Actual Moisture (%): 16.34

Meter Box ID. No: 61-8
 Meter ΔH@: 1.75800
 Meter Y_d: 0.99160

Traverse Point	Run Time 5.0 min/read	Pitot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dcf)	Stack T _s (°F)	Dry Gas Meter		√ΔP _s (calculated) (√in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)
						T _{m-in} (°F)	T _{m-out} (°F)			
	0.0			138.230						
1-01	5.0		1.20	141.380	502	63	63		3.15	
1-01	10.0		1.20	144.350	502	65	64		2.97	
1-01	15.0		1.20	147.350	501	66	64		3.00	
1-01	20.0		1.20	150.350	502	69	65		3.00	
1-01	25.0		1.20	153.370	507	70	65		3.02	
1-01	30.0		1.20	156.400	506	70	65		3.03	
1-01	35.0		1.20	159.420	503	70	66		3.02	
1-01	40.0		1.20	162.470	505	71	66		3.05	
1-01	45.0		1.20	165.570	502	70	66		3.10	
1-01	50.0		1.20	168.620	502	70	66		3.05	
1-01	55.0		1.20	171.690	506	69	66		3.07	
1-01	60.0		1.20	174.700	504	69	66		3.01	
Final	60.0									
			1.20000	36.47000	503.50000	66.83333		0.00000	36.47000	

1 points sampled
 QC-Check: Field Averages
 Sq.Rt.ΔP: 1.2000 36.4700 503.5000 66.8333
 Avg. OK Avg. OK Avg. OK Avg. OK Avg. OK

041310 101149
 Q

Field Data Printout

Test Method: USEPA Method 26A
 Analyte: HCl

Location: Unit 2 SDA Inlet
 Test Run: 3
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Source Area (ff): 60.13205
 Meter Operator: B. Arnold 770
 Probe Operator: B. Arnold 770

Bar. Press. (in. Hg): 30.00
 Static P: -1.9
 O₂ (dry volume %): 8.68
 CO₂ (dry volume %): 10.74
 N₂+CO (dry volume %): 80.58

Nozzle ID No: NA
 Nozzle Diameter (D_n): NA
 Probe ID No: 67-4-5
 Pitot C_p: 0.8400
 Pitot Leak Check: Pass Fail

Test Date: 3/17/10
 Start Time: 10:25
 Stop Time: 11:25
 Leak Rate Before: 0.004 cfm @ 15 "Hg
 Leak Rate After: 0.004 cfm @ 18 "Hg

H₂O (condensate, ml or gm): 148.7
 H₂O (silica, g): 15.3
 Actual Moisture (%): 17.57

Meter Box ID. No: 61-8
 Meter ΔH@: 1.75800
 Meter Y_d: 0.99160

Traverse Point	Run Time 5.0 min/read	Pitot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dcf)	Stack T _s (°F)	Dry Gas Meter		√ΔP _s (calculated) (√in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)
						T _{m-in} (°F)	T _{m-out} (°F)			
	0.0			174.890						
1-01	5.0		1.20	178.020	507	65	64		3.13	
1-01	10.0		1.20	180.970	505	66	64		2.95	
1-01	15.0		1.20	183.980	504	68	64		3.01	
1-01	20.0		1.20	187.000	499	69	64		3.02	
1-01	25.0		1.20	190.000	502	70	65		3.00	
1-01	30.0		1.20	193.070	503	70	65		3.07	
1-01	35.0		1.20	196.070	501	70	65		3.00	
1-01	40.0		1.20	199.080	505	70	65		3.01	
1-01	45.0		1.20	202.100	498	70	66		3.02	
1-01	50.0		1.20	205.150	498	70	66		3.05	
1-01	55.0		1.20	208.190	499	70	66		3.04	
1-01	60.0		1.10	211.135	498	70	66		2.94	
Final	60.0		1.19167	36.24500	501.58333	67.00000		0.00000	36.24500	

1 points sampled
 QC-Check: Field Averages

Sq.Rt.ΔP	1.1917	36.2450	501.5833	67.0000
----------	--------	---------	----------	---------

Avg. OK Avg. OK Avg. OK Avg. OK Avg. OK

041310 101149
K

USEPA Method 3 Laboratory Data

Location: Unit 2 SDA Inlet
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Method: EPA Method 3
 Fuel Type: Municipal Waste
 F_o for Fuel: 1.03 to 1.3

Test Method: USEPA Method 26A
Analyte: HCl

Analyst: S. Brown
 Analyst Emp No: 433

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
1	1							
	2							
	3							
Avg.								
CEM or Other Avg:		10.86000		8.41000	80.73000	30.07400	1.15009	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
2	1							
	2							
	3							
Avg.								
CEM or Other Avg:		10.19000		9.29000	80.52000	30.00200	1.13935	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
3	1							
	2							
	3							
Avg.								
CEM or Other Avg:		10.74000		8.68000	80.58000	30.06560	1.13780	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis:
	1							
	2							
	3							
Avg.								
CEM or Other Avg:								<input type="checkbox"/> Fo value within expected range.

D41310 101149
 KQK@

USEPA Method 4 Laboratory Data

Location: Unit 2 SDA Inlet
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955

Test Method: USEPA Method 26A
Analyte: HCl
 Analyst: R. Vicere
 Analyst Emp No: 563

Test Run: 1

	Contents	Gross (gm)	Tare (gm)	Net (gm)
Impinger 1	50 ml 0.1N H2SO4	477.3	455.7	21.6
Impinger 2	100 ml 0.1N H2SO4	637.5	556.7	80.8
Impinger 3	100 ml 0.1N H2SO4	576.6	541.1	35.5
Impinger 4	Empty	473.6	463.0	10.6
Impinger 5	Silica Gel	754.2	740.9	13.3
Impinger 6				
Impinger 7				
Impinger 8				

148.5 Liquid (gm)	<i>Field Data Check</i>
0.0 less rinse (gm)	
148.5 Net Liquid (gm)	148.5 <input type="checkbox"/> QA/QC OK
+ 13.3 Silica Gel (gm)	13.3 <input type="checkbox"/> QA/QC OK
161.8 Total Vlc (gm)	161.8 <input type="checkbox"/> QA/QC OK

Rinse: _____ (ml or gm)

Test Run: 2

	Contents	Gross (gm)	Tare (gm)	Net (gm)
Impinger 1	50 ml 0.1N H2SO4	501.8	471.6	30.2
Impinger 2	100 ml 0.1N H2SO4	620.4	535.9	84.5
Impinger 3	100 ml 0.1N H2SO4	571.4	550.6	20.8
Impinger 4	Empty	431.8	428.3	3.5
Impinger 5	Silica Gel	766.4	754.2	12.2
Impinger 6				
Impinger 7				
Impinger 8				

139.0 Liquid (gm)	<i>Field Data Check</i>
0.0 less rinse (gm)	
139.0 Net Liquid (gm)	139.0 <input type="checkbox"/> QA/QC OK
+ 12.2 Silica Gel (gm)	12.2 <input type="checkbox"/> QA/QC OK
151.2 Total Vlc (gm)	151.2 <input type="checkbox"/> QA/QC OK

Rinse: _____ (ml or gm)

Test Run: 3

	Contents	Gross (gm)	Tare (gm)	Net (gm)
Impinger 1	50 ml 0.1N H2SO4	487.7	455.6	32.1
Impinger 2	100 ml 0.1N H2SO4	643.0	560.9	82.1
Impinger 3	100 ml 0.1N H2SO4	567.7	540.3	27.4
Impinger 4	Empty	472.5	465.4	7.1
Impinger 5	Silica Gel	753.5	738.2	15.3
Impinger 6				
Impinger 7				
Impinger 8				

148.7 Liquid (gm)	<i>Field Data Check</i>
0.0 less rinse (gm)	
148.7 Net Liquid (gm)	148.7 <input type="checkbox"/> QA/QC OK
+ 15.3 Silica Gel (gm)	15.3 <input type="checkbox"/> QA/QC OK
164.0 Total Vlc (gm)	164.0 <input type="checkbox"/> QA/QC OK

Rinse: _____ (ml or gm)

Test Run: _____

	Contents	Gross (gm)	Tare (gm)	Net (gm)
Impinger 1				
Impinger 2				
Impinger 3				
Impinger 4				
Impinger 5				
Impinger 6				
Impinger 7				
Impinger 8				

Liquid (gm)	<i>Field Data Check</i>
less rinse (gm)	
Net Liquid (gm)	<input type="checkbox"/> QA/QC OK
Silica Gel (gm)	<input type="checkbox"/> QA/QC OK
Total Vlc (gm)	<input type="checkbox"/> QA/QC OK

Rinse: _____ (ml or gm)

041310 101148
K O K @

Field Data Printout

Test Method: USEPA Method 26A
Analyte: HCl

Location: Unit 2 FF Outlet
 Test Run: 1
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Source Area (ff): 64.00000
 Meter Operator: A. Obuchowski 567
 Probe Operator:
 Test Date: 3/17/10
 Start Time: 06:54
 Stop Time: 07:54
 Leak Rate Before: 0.002 cfm @ 15 "Hg
 Leak Rate After: 0.002 cfm @ 15 "Hg

Bar. Press. (in. Hg): 30.00
 Static P: -12.5
 O₂ (dry volume %): 9.65
 CO₂ (dry volume %): 9.65
 N₂+CO (dry volume %): 80.70

Nozzle ID No: NA
 Nozzle Diameter (D_n): NA
 Probe ID No: 67-4-3
 Pitot C_p: 0.8400
 Pitot Leak Check: Pass Fail

H₂O (condensate, ml or gm): 211.6
 H₂O (silica, g): 23.1
 Actual Moisture (%): 21.13

Meter Box ID. No: 66-24
 Meter ΔH@: 1.75160
 Meter Y_g: 0.99040

Traverse Point	Run Time 5.0 min/read	Pitot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dcf)	Stack T _s (°F)	Dry Gas Meter		√ΔP _s (calculated) (√in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)				
						T _{m-in} (°F)	T _{m-out} (°F)							
	0.0			150.430										
2-01	5.0		1.50	153.590	307	72	66		3.16					
2-01	10.0		1.50	157.250	307	72	66		3.66					
2-01	15.0		1.50	160.650	307	74	66		3.40					
2-01	20.0		1.50	164.150	308	77	67		3.50					
2-01	25.0		1.50	167.640	308	80	68		3.49					
2-01	30.0		1.50	171.140	313	81	68		3.50					
2-01	35.0		1.50	174.650	311	84	70		3.51					
2-01	40.0		1.50	178.180	310	85	71		3.53					
2-01	45.0		1.50	181.740	310	85	72		3.56					
2-01	50.0		1.50	185.280	311	86	73		3.54					
2-01	55.0		1.50	188.820	310	86	74		3.54					
2-01	60.0		1.50	192.380	311	86	74		3.56					
Final	60.0		1.50000	41.95000	309.41667	75.12500		0.00000	41.95000					
2 points sampled		Sq.Rt.ΔP												
QC-Check: Field Averages		<table border="1"> <tr> <td>1.5000</td> <td>41.9500</td> <td>309.4167</td> <td>75.1250</td> </tr> </table>									1.5000	41.9500	309.4167	75.1250
1.5000	41.9500	309.4167	75.1250											

Avg. OK Avg. OK Avg. OK Avg. OK Avg. OK

041310 101300
0

Field Data Printout

Test Method: USEPA Method 26A
Analyte: HCl

Location: Unit 2 FF Outlet
 Test Run: 2
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Source Area (ff): 64.00000
 Meter Operator: A. Obuchowski 567
 Probe Operator:
 Test Date: 3/17/10
 Start Time: 09:02
 Stop Time: 10:02
 Leak Rate Before: 0.002 cfm @ 15 "Hg
 Leak Rate After: 0.002 cfm @ 15 "Hg

Bar. Press. (in. Hg): 30.00
 Static P: -12.5
 O₂ (dry volume %): 10.39
 CO₂ (dry volume %): 9.14
 N₂+CO (dry volume %): 80.47

Nozzle ID No: NA
 Nozzle Diameter (D_n): NA
 Probe ID No: 67-4-3
 Pitot C_p: 0.8400
 Pitot Leak Check: Pass Fail

H₂O (condensate, ml or gm): 199.6
 H₂O (silica, g): 22.8
 Actual Moisture (%): 20.33

Meter Box ID. No: 66-24
 Meter ΔH@: 1.75160
 Meter Y_d: 0.99040

Traverse Point	Run Time 5.0 min/read	Pitot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dcf)	Stack T _s (°F)	Dry Gas Meter		√ΔP _s (calculated) (√in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)
						T _{m-in} (°F)	T _{m-out} (°F)			
	0.0			192.710						
2-01	5.0		1.50	196.220	308	75	75		3.51	
2-01	10.0		1.50	199.700	308	75	75		3.48	
2-01	15.0		1.50	203.200	309	77	75		3.50	
2-01	20.0		1.50	206.690	308	80	75		3.49	
2-01	25.0		1.50	210.180	309	82	75		3.49	
2-01	30.0		1.50	213.670	309	84	76		3.49	
2-01	35.0		1.50	217.200	307	85	76		3.53	
2-01	40.0		1.50	220.740	308	86	76		3.54	
2-01	45.0		1.50	224.260	307	87	77		3.52	
2-01	50.0		1.50	227.700	308	88	77		3.44	
2-01	55.0		1.50	231.270	308	89	78		3.57	
2-01	60.0		1.50	234.775	308	89	79		3.51	
Final	60.0		1.50000	42.06500	308.08333	79.62500		0.00000	42.06500	
2 points sampled		Sq.Rt.ΔP								
QC-Check: Field Averages			1.5000	42.0650	308.0833	79.6250				

Avg. OK
 Avg. OK
 Avg. OK
 Avg. OK
 Avg. OK

041310 101300

Field Data Printout

Test Method: USEPA Method 26A
Analyte: HCl

Location: Unit 2 FF Outlet
 Test Run: 3
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Source Area (ff): 64.00000
 Meter Operator: A. Obuchowski 567
 Probe Operator:

Bar. Press. (in. Hg): 30.00
 Static P: -10.4
 O₂ (dry volume %): 9.53
 CO₂ (dry volume %): 9.95
 N₂+CO (dry volume %): 80.52

Nozzle ID No: NA
 Nozzle Diameter (D_n): NA
 Probe ID No: 67-4-3
 Pitot C_p: 0.8400
 Pitot Leak Check: Pass Fail

Test Date: 3/17/10
 Start Time: 10:25
 Stop Time: 11:25
 Leak Rate Before: 0.002 cfm @ 15 "Hg
 Leak Rate After: 0.003 cfm @ 15 "Hg

H₂O (condensate, ml or gm): 217.7
 H₂O (silica, g): 19.2
 Actual Moisture (%): 21.49

Meter Box ID No: 66-24
 Meter ΔH@: 1.75160
 Meter Y_c: 0.99040

Traverse Point	Run Time 5.0 min/read	Pitot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dcf)	Stack T _s (°F)	Dry Gas Meter		√ΔP _s (calculated) (√in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)
						T _{m-in} (°F)	T _{m-out} (°F)			
	0.0			235.110						
2-01	5.0		1.50	238.660	308	81	79		3.55	
2-01	10.0		1.50	242.150	307	84	79		3.49	
2-01	15.0		1.50	245.670	307	88	80		3.52	
2-01	20.0		1.50	249.170	306	90	80		3.50	
2-01	25.0		1.50	252.660	307	91	80		3.49	
2-01	30.0		1.50	256.130	307	91	81		3.47	
2-01	35.0		1.50	259.670	306	92	81		3.54	
2-01	40.0		1.50	263.200	310	92	82		3.53	
2-01	45.0		1.50	266.710	307	92	82		3.51	
2-01	50.0		1.50	270.270	308	93	83		3.56	
2-01	55.0		1.50	273.800	308	93	83		3.53	
2-01	60.0		1.50	277.350	307	93	83		3.55	
Final	60.0		1.50000	42.24000	307.33333	85.54167		0.00000	42.24000	

2 points sampled.
 QC-Check: Field Averages
 Sq.Rt.ΔP: 1.5000 42.2400 307.3333 85.5417

Avg. OK Avg. OK Avg. OK Avg. OK Avg. OK

041310 101300
 P

USEPA Method 3 Laboratory Data

Location: Unit 2 FF Outlet
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Method: EPA Method 3
 Fuel Type: Municipal Waste
 F_o for Fuel: 1.03 to 1.3

Test Method: USEPA Method 26A
Analyte: HCl

Analyst: S. Brown
 Analyst Emp No: 433

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
1	1							
	2							
	3							
Avg.								
CEM or Other Avg:		9.65000		9.65000	80.70000	29.93000	1.16580	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
2	1							
	2							
	3							
Avg.								
CEM or Other Avg:		9.14000		10.39000	80.47000	29.87800	1.14989	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
3	1							
	2							
	3							
Avg.								
CEM or Other Avg:		9.95000		9.53000	80.52000	29.97320	1.14271	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis:
	1							
	2							
	3							
Avg.								
CEM or Other Avg:								<input type="checkbox"/> Fo value within expected range.

041310 101300
 O J P

USEPA Method 4 Laboratory Data

Location: Unit 2 FF Outlet
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955

Test Method: USEPA Method 26A
Analyte: HCl
Analyst: B. Wiltse
Analyst Emp No: 561

Test Run: 1

	Contents	Gross (gm)	Tare (gm)	Net (gm)	
Impinger 1	50 ml 0.1N H2SO4	504.9	469.4	35.5	
Impinger 2	100 ml 0.1N H2SO4	652.1	560.4	91.7	
Impinger 3	100 ml 0.1N H2SO4	615.6	554.3	61.3	
Impinger 4	Empty	479.1	456.0	23.1	
Impinger 5	Silica Gel	808.5	785.4	23.1	
Impinger 6					
Impinger 7					
Impinger 8					
					211.6 Liquid (gm)
					0.0 less rinse (gm)
					211.6 Net Liquid (gm)
					+ 23.1 Silica Gel (gm)
					234.7 Total Vlc (gm)

Rinse: _____ (ml or gm)

Field Data Check

211.6	<input checked="" type="checkbox"/> QA/QC OK
23.1	<input checked="" type="checkbox"/> QA/QC OK
234.7	<input checked="" type="checkbox"/> QA/QC OK

Test Run: 2

	Contents	Gross (gm)	Tare (gm)	Net (gm)	
Impinger 1	50 ml 0.1N H2SO4	513.0	480.5	32.5	
Impinger 2	100 ml 0.1N H2SO4	751.1	642.5	108.6	
Impinger 3	100 ml 0.1N H2SO4	577.5	534.9	42.6	
Impinger 4	Empty	463.9	448.0	15.9	
Impinger 5	Silica Gel	718.5	695.7	22.8	
Impinger 6					
Impinger 7					
Impinger 8					
					199.6 Liquid (gm)
					0.0 less rinse (gm)
					199.6 Net Liquid (gm)
					+ 22.8 Silica Gel (gm)
					222.4 Total Vlc (gm)

Rinse: _____ (ml or gm)

Field Data Check

199.6	<input checked="" type="checkbox"/> QA/QC OK
22.8	<input checked="" type="checkbox"/> QA/QC OK
222.4	<input checked="" type="checkbox"/> QA/QC OK

Test Run: 3

	Contents	Gross (gm)	Tare (gm)	Net (gm)	
Impinger 1	50 ml 0.1N H2SO4	506.8	467.8	39.0	
Impinger 2	100 ml 0.1N H2SO4	683.0	561.1	121.9	
Impinger 3	100 ml 0.1N H2SO4	597.3	554.6	42.7	
Impinger 4	Empty	469.8	455.7	14.1	
Impinger 5	Silica Gel	780.8	761.6	19.2	
Impinger 6					
Impinger 7					
Impinger 8					
					217.7 Liquid (gm)
					0.0 less rinse (gm)
					217.7 Net Liquid (gm)
					+ 19.2 Silica Gel (gm)
					236.9 Total Vlc (gm)

Rinse: _____ (ml or gm)

Field Data Check

217.7	<input checked="" type="checkbox"/> QA/QC OK
19.2	<input checked="" type="checkbox"/> QA/QC OK
236.9	<input checked="" type="checkbox"/> QA/QC OK

Test Run: _____

	Contents	Gross (gm)	Tare (gm)	Net (gm)	
Impinger 1					
Impinger 2					
Impinger 3					
Impinger 4					
Impinger 5					
Impinger 6					
Impinger 7					
Impinger 8					
					Liquid (gm)
					less rinse (gm)
					Net Liquid (gm)
					Silica Gel (gm)
					Total Vlc (gm)

Rinse: _____ (ml or gm)

Field Data Check

	<input type="checkbox"/> QA/QC OK
	<input type="checkbox"/> QA/QC OK
	<input type="checkbox"/> QA/QC OK

041310 101300
OJP@

Field Data Printout

Test Method: USEPA Method 5/29
Analyte: Particulate/Metals

Location: Unit 3 FF Outlet
 Test Run: 1
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Source Area (ff): 64.00000
 Meter Operator: P. Bihun 505
 Probe Operator: P. Bihun 505

Bar. Press. (in. Hg): 30.00
 Static P: -11.0
 O₂ (dry volume %): 8.71
 CO₂ (dry volume %): 10.46
 N₂+CO (dry volume %): 80.83

Nozzle ID No: 270-1
 Nozzle Diameter (D_n): 0.270
 Probe ID No: 67-8-4
 Pitot C_p: 0.8050
 Pitot Leak Check: Pass Fail

Test Date: 3/17/10
 Start Time: 06:50
 Stop Time: 09:03
 Leak Rate Before: 0.003 cfm @ 15 "Hg
 Leak Rate After: 0.000 cfm @ 8 "Hg

H₂O (condensate, ml or gm): 428.9
 H₂O (silica, g): 13.2
 Actual Moisture (%): 22.70
 Meter Box ID. No: 66-14
 Meter ΔH@: 1.76430
 Meter Y_d: 0.98980

Traverse Point	Run Time 5.0 min/read	Pitot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dcf)	Stack T _s (°F)	Dry Gas Meter		√ΔP _s (calculated) (√in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)
						T _{m-in} (°F)	T _{m-out} (°F)			
	0.0			269.855						
1-01	5.0	0.46	1.10	272.720	305	65	65	0.68	2.87	101.0
1-02	10.0	0.54	1.30	275.840	305	68	65	0.73	3.12	101.3
1-03	15.0	0.55	1.30	278.970	307	71	65	0.74	3.13	100.5
1-04	20.0	0.50	1.20	281.980	306	73	65	0.71	3.01	101.1
1-05	25.0	0.46	1.10	284.900	306	75	66	0.68	2.92	101.9
LEAK CHECK	25.0			284.955						
2-01	30.0	0.57	1.30	288.090	306	76	68	0.75	3.13	98.1
2-02	35.0	0.60	1.40	291.410	306	77	68	0.77	3.32	101.2
2-03	40.0	0.48	1.10	294.320	306	80	69	0.69	2.91	98.7
2-04	45.0	0.48	1.10	297.230	305	81	70	0.69	2.91	98.4
2-05	50.0	0.38	0.89	299.895	305	81	71	0.62	2.66	101.2
LEAK CHECK	50.0			299.955						
3-01	55.0	0.51	1.20	302.980	304	79	71	0.71	3.03	99.3
3-02	60.0	0.54	1.30	306.190	305	81	72	0.73	3.21	102.2
3-03	65.0	0.52	1.20	309.300	305	83	73	0.72	3.11	100.6
3-04	70.0	0.46	1.10	312.240	305	83	73	0.68	2.94	101.1
3-05	75.0	0.41	0.96	315.005	305	84	75	0.64	2.76	100.4
LEAK CHECK	75.0			315.065						
4-01	80.0	0.61	1.40	318.370	304	82	74	0.78	3.31	98.7
4-02	85.0	0.50	1.20	321.510	305	84	75	0.71	3.14	103.3
4-03	90.0	0.54	1.30	324.750	304	84	75	0.73	3.24	102.6
4-04	95.0	0.47	1.10	327.720	305	85	76	0.69	2.97	100.6
4-05	100.0	0.38	0.89	330.415	305	85	76	0.62	2.69	101.5
LEAK CHECK	100.0			330.475						
5-01	105.0	0.23	0.54	332.540	286	82	77	0.48	2.07	98.8
5-02	110.0	0.23	0.54	334.600	286	83	77	0.48	2.06	98.5
5-03	115.0	0.30	0.71	336.980	301	83	77	0.55	2.38	100.6
5-04	120.0	0.38	0.89	339.630	305	84	77	0.62	2.65	99.8
5-05	125.0	0.40	0.94	342.380	304	84	77	0.63	2.75	100.9
Final	125.0		1.08240	72.29000	303.44000	75.80000		0.67364	72.29000	

25 points sampled
 QC-Check: Field Averages
 Sq.RtΔP: 0.6736 1.0824 72.2900 303.4400 75.8000
 2RSD = 16.1%
 Avg. OK Avg. OK Avg. OK Avg. OK Avg. OK

041310 101418

Field Data Printout

Test Method: USEPA Method 5/29
Analyte: Particulate/Metals

Location: Unit 3 FF Outlet
 Test Run: 2
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Source Area (ff): 64.00000
 Meter Operator: P. Bihun 505
 Probe Operator: P. Bihun 505
 Test Date: 3/17/10
 Start Time: 09:28
 Stop Time: 11:38
 Leak Rate Before: 0.003 cfm @ 15 "Hg
 Leak Rate After: 0.003 cfm @ 9 "Hg

Bar. Press. (in. Hg): 30.00
 Static P: -11.0
 O₂ (dry volume %): 8.30
 CO₂ (dry volume %): 10.94
 N₂+CO (dry volume %): 80.76

Nozzle ID No: 270-1
 Nozzle Diameter (D_n): 0.270
 Probe ID No: 67-8-4
 Pitot C_p: 0.8050
 Pitot Leak Check: Pass Fail

H₂O (condensate, ml or gm): 460.2
 H₂O (silica, g): 18.2
 Actual Moisture (%): 22.90

Meter Box ID. No: 66-14
 Meter ΔH@: 1.76430
 Meter Y_d: 0.98980

Traverse Point	Run Time 5.0 min/read	Pitot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dcf)	Stack T _s (°F)	Dry Gas Meter		√ΔP _s (calculated) (√in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)
						T _{m-in} (°F)	T _{m-out} (°F)			
	0.0			342.680						
1-01	5.0	0.51	1.20	345.850	302	77	77	0.71	3.17	103.9
1-02	10.0	0.59	1.40	349.130	306	79	77	0.77	3.28	100.1
1-03	15.0	0.53	1.30	352.270	305	81	77	0.73	3.14	100.8
1-04	20.0	0.53	1.30	355.470	305	82	77	0.73	3.20	102.6
1-05	25.0	0.48	1.10	358.370	302	83	77	0.69	2.90	97.4
LEAK CHECK	25.0			358.440						
2-01	30.0	0.51	1.20	361.510	302	82	77	0.71	3.07	100.1
2-02	35.0	0.56	1.30	364.740	305	83	77	0.75	3.23	100.7
2-03	40.0	0.50	1.20	367.840	306	84	77	0.71	3.10	102.2
2-04	45.0	0.50	1.20	370.890	305	83	77	0.71	3.05	100.6
2-05	50.0	0.43	1.00	373.720	304	84	77	0.66	2.83	100.4
LEAK CHECK	50.0			373.750						
3-01	55.0	0.66	1.60	377.300	305	82	77	0.81	3.55	102.1
3-02	60.0	0.63	1.50	380.730	305	83	77	0.79	3.43	100.8
3-03	65.0	0.52	1.20	383.850	305	84	77	0.72	3.12	100.8
3-04	70.0	0.51	1.20	386.920	305	84	77	0.71	3.07	100.2
3-05	75.0	0.42	0.99	389.725	305	83	77	0.65	2.81	100.9
LEAK CHECK	75.0			389.760						
4-01	80.0	0.67	1.60	393.260	305	82	76	0.82	3.50	100.0
4-02	85.0	0.63	1.50	396.730	304	84	77	0.79	3.47	101.9
4-03	90.0	0.54	1.30	399.960	304	85	77	0.73	3.23	102.3
4-04	95.0	0.54	1.30	403.170	305	85	77	0.73	3.21	101.7
4-05	100.0	0.52	1.20	406.215	304	86	77	0.72	3.04	98.1
LEAK CHECK	100.0			406.250						
5-01	105.0	0.50	1.20	409.350	303	83	77	0.71	3.10	102.1
5-02	110.0	0.47	1.10	412.240	303	85	77	0.69	2.89	98.0
5-03	115.0	0.44	1.00	415.070	301	86	78	0.66	2.83	98.8
5-04	120.0	0.43	1.00	417.860	303	86	78	0.66	2.79	98.7
5-05	125.0	0.48	1.10	420.785	303	87	79	0.69	2.93	97.8
Final	125.0		1.23960	77.93500	304.08000	80.22000		0.72242	77.93500	

25 points sampled
 QC-Check: Field Averages

Sq.Rt.ΔP	0.7224	1.2396	77.9350	304.0800	80.2200
----------	--------	--------	---------	----------	---------

2RSR = 9.4%

Avg. OK
 Avg. OK
 Avg. OK
 Avg. OK
 Avg. OK

041310 101418
N

Field Data Printout

Test Method: USEPA Method 5/29
Analyte: Particulate/Metals

Location: Unit 3 FF Outlet
 Test Run: 3
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Source Area (ft²): 64.00000
 Meter Operator: P. Bihun 505
 Probe Operator: P. Bihun 505

Bar. Press. (in. Hg): 30.00
 Static P: -10.3
 O₂ (dry volume %): 8.72
 CO₂ (dry volume %): 10.84
 N₂+CO (dry volume %): 80.44

Nozzle ID No: 270-1
 Nozzle Diameter (D_n): 0.270
 Probe ID No: 67-8-4
 Pitot C_p: 0.8050
 Pitot Leak Check: Pass Fail

Test Date: 3/17/10
 Start Time: 11:59
 Stop Time: 14:11
 Leak Rate Before: 0.002 cfm @ 15 "Hg
 Leak Rate After: 0.003 cfm @ 9 "Hg

H₂O (condensate, ml or gm): 448.7
 H₂O (silica, g): 15.7
 Actual Moisture (%): 22.62

Meter Box ID. No: 66-14
 Meter ΔH@: 1.76430
 Meter Y_d: 0.98980

Traverse Point	Run Time 5.0 min/read	Pitot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dcf)	Stack T _s (°F)	Dry Gas Meter		√ΔP _s (calculated) (√in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)
						T _{m-in} (°F)	T _{m-out} (°F)			
	0.0			421.105						
1-01	5.0	0.54	1.30	424.330	304	78	77	0.73	3.22	102.4
1-02	10.0	0.50	1.20	427.410	304	80	77	0.71	3.08	101.4
1-03	15.0	0.46	1.10	430.310	304	81	77	0.68	2.90	99.4
1-04	20.0	0.45	1.10	433.230	304	82	77	0.67	2.92	101.1
1-05	25.0	0.43	1.00	436.055	305	82	77	0.66	2.82	100.1
LEAK CHECK	25.0			436.095						
2-01	30.0	0.57	1.30	439.260	305	81	76	0.75	3.16	97.7
2-02	35.0	0.60	1.40	442.610	304	82	76	0.77	3.35	100.6
2-03	40.0	0.50	1.20	445.700	305	84	77	0.71	3.09	101.4
2-04	45.0	0.54	1.30	448.920	305	83	76	0.73	3.22	101.9
2-05	50.0	0.45	1.10	451.855	305	83	76	0.67	2.94	101.7
LEAK CHECK	50.0			451.910						
3-01	55.0	0.61	1.40	455.150	306	81	76	0.78	3.24	96.7
3-02	60.0	0.60	1.40	458.450	305	82	76	0.77	3.30	99.2
3-03	65.0	0.58	1.40	461.730	305	83	76	0.76	3.28	100.2
3-04	70.0	0.50	1.20	464.770	305	83	76	0.71	3.04	100.0
3-05	75.0	0.48	1.10	467.675	305	82	76	0.69	2.91	97.5
LEAK CHECK	75.0			467.730						
4-01	80.0	0.71	1.70	471.350	305	81	75	0.84	3.62	100.3
4-02	85.0	0.65	1.50	474.790	306	82	75	0.81	3.44	99.5
4-03	90.0	0.57	1.30	477.970	306	83	75	0.75	3.18	98.1
4-04	95.0	0.55	1.30	481.160	306	82	75	0.74	3.19	100.3
4-05	100.0	0.47	1.10	484.075	306	82	75	0.69	2.91	99.1
LEAK CHECK	100.0			484.120						
5-01	105.0	0.37	0.87	486.730	294	79	75	0.61	2.61	99.4
5-02	110.0	0.37	0.87	489.360	295	80	74	0.61	2.63	100.2
5-03	115.0	0.39	0.92	492.080	304	80	74	0.62	2.72	101.6
5-04	120.0	0.43	1.00	494.890	303	80	74	0.66	2.81	99.9
5-05	125.0	0.50	1.20	497.965	304	81	74	0.71	3.07	101.4
Final	125.0		1.21040	76.66500	304.00000	78.58000		0.71365	76.66500	

25 points sampled
 QC-Check: Field Averages

Sq.Rt.ΔP				
0.7136	1.2104	76.6650	304.0000	78.5800
<input checked="" type="checkbox"/> Avg. OK				

2RSD = 12.1%

041310 101418
 M

USEPA Method 3 Laboratory Data

Location: Unit 3 FF Outlet
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Method: EPA Method 3
 Fuel Type: Municipal Waste
 F_o for Fuel: 1.03 to 1.3

Test Method: USEPA Method 5/29
Analyte: Particulate/Metals

Analyst: S. Brown
 Analyst Emp No: 433

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
1	1							
	2							
	3							
Avg.								
CEM or Other Avg:		10.46000		8.71000	80.83000	30.02200	1.16539	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
2	1							
	2							
	3							
Avg.								
CEM or Other Avg:		10.94000		8.30000	80.76000	30.08240	1.15174	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
3	1							
	2							
	3							
Avg.								
CEM or Other Avg:		10.84000		8.72000	80.44000	30.08320	1.12362	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis:
	1							
	2							
	3							
Avg.								
CEM or Other Avg:								<input type="checkbox"/> Fo value within expected range.

041310 101418
 INM@

USEPA Method 4 Laboratory Data

Location: Unit 3 FF Outlet
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955

Test Method: USEPA Method 5/29
Analyte: Particulate/Metals
 Analyst: B. Wiltse
 Analyst Emp No: 561

Test Run: 1

	Contents	Gross (gm)	Tare (gm)	Net (gm)		
Impinger 1	Empty	693.8	439.8	254.0		
Impinger 2	5% HNO ₃ /10% H ₂ O ₂	889.5	559.5	130.0		
Impinger 3	5% HNO ₃ /10% H ₂ O ₂	571.6	537.6	34.0		
Impinger 4	Empty	454.0	446.4	7.6		
Impinger 5	4% KMnO ₄ /10% H ₂ SO ₄	547.6	544.7	2.9		
Impinger 6	4% KMnO ₄ /10% H ₂ SO ₄	551.5	551.1	0.4	428.9 Liquid (gm)	<i>Field Data Check</i>
Impinger 7	Silica Gel	748.4	735.2	13.2	0.0 less rinse (gm)	
Impinger 8					428.9 Net Liquid (gm)	
					+ 13.2 Silica Gel (gm)	13.2 <input checked="" type="checkbox"/> QA/QC OK
					442.1 Total Vlc (gm)	442.1 <input checked="" type="checkbox"/> QA/QC OK
	Rinse:				(ml or gm)	

Test Run: 2

	Contents	Gross (gm)	Tare (gm)	Net (gm)		
Impinger 1	Empty	740.5	463.2	277.3		
Impinger 2	5% HNO ₃ /10% H ₂ O ₂	683.5	542.1	141.4		
Impinger 3	5% HNO ₃ /10% H ₂ O ₂	586.5	553.5	33.0		
Impinger 4	Empty	446.1	440.0	6.1		
Impinger 5	4% KMnO ₄ /10% H ₂ SO ₄	564.8	562.4	2.4		
Impinger 6	4% KMnO ₄ /10% H ₂ SO ₄	540.6	540.6	0.0	460.2 Liquid (gm)	<i>Field Data Check</i>
Impinger 7	Silica Gel	736.0	717.8	18.2	0.0 less rinse (gm)	
Impinger 8					460.2 Net Liquid (gm)	
					+ 18.2 Silica Gel (gm)	18.2 <input checked="" type="checkbox"/> QA/QC OK
					478.4 Total Vlc (gm)	478.4 <input checked="" type="checkbox"/> QA/QC OK
	Rinse:				(ml or gm)	

Test Run: 3

	Contents	Gross (gm)	Tare (gm)	Net (gm)		
Impinger 1	Empty	722.8	439.7	283.1		
Impinger 2	5% HNO ₃ /10% H ₂ O ₂	685.9	556.9	129.0		
Impinger 3	5% HNO ₃ /10% H ₂ O ₂	582.8	536.0	26.8		
Impinger 4	Empty	453.5	447.5	6.0		
Impinger 5	4% KMnO ₄ /10% H ₂ SO ₄	545.2	541.1	4.1		
Impinger 6	4% KMnO ₄ /10% H ₂ SO ₄	545.1	545.2	-0.1	448.7 Liquid (gm)	<i>Field Data Check</i>
Impinger 7	Silica Gel	700.3	684.6	15.7	0.0 less rinse (gm)	
Impinger 8					448.7 Net Liquid (gm)	
					+ 15.7 Silica Gel (gm)	15.7 <input checked="" type="checkbox"/> QA/QC OK
					464.4 Total Vlc (gm)	464.4 <input checked="" type="checkbox"/> QA/QC OK
	Rinse:				(ml or gm)	

Test Run:

	Contents	Gross (gm)	Tare (gm)	Net (gm)			
Impinger 1	Empty						
Impinger 2	5% HNO ₃ /10% H ₂ O ₂						
Impinger 3	5% HNO ₃ /10% H ₂ O ₂						
Impinger 4	Empty						
Impinger 5	4% KMnO ₄ /10% H ₂ SO ₄						
Impinger 6	4% KMnO ₄ /10% H ₂ SO ₄						
Impinger 7	Silica Gel						
Impinger 8							
					Liquid (gm)	<i>Field Data Check</i>	
					less rinse (gm)		
					Net Liquid (gm)		 <input type="checkbox"/> QA/QC OK
					Silica Gel (gm)		 <input type="checkbox"/> QA/QC OK
					Total Vlc (gm)		 <input type="checkbox"/> QA/QC OK
	Rinse:				(ml or gm)		

041310 101418
INM@

Field Data Printout

Test Method: USEPA Method 13B
Analyte: Total Fluorides

Location: Unit 3 FF Outlet
 Test Run: 1
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Source Area (ff): 64.00000
 Meter Operator: A. Obuchowski 567
 Probe Operator: B. Arnold 770
 Test Date: 3/16/10
 Start Time: 11:49
 Stop Time: 13:07
 Leak Rate Before: 0.005 cfm @ 15 "Hg
 Leak Rate After: 0.002 cfm @ 15 "Hg

Bar. Press. (in. Hg): 30.05
 Static P: -10.6
 O₂ (dry volume %): 9.90
 CO₂ (dry volume %): 9.71
 N₂+CO (dry volume %): 80.39

Nozzle ID No: 268-1
 Nozzle Diameter (D): 0.268
 Probe ID No: 67-8-14
 Pitot C_p: 0.8120
 Pitot Leak Check: Pass Fail

H₂O (condensate, ml or gm): 186.2
 H₂O (silica, g): 18.0
 Actual Moisture (%): 20.88

Meter Box ID No: 66-14
 Meter ΔH@: 1.76430
 Meter Y_g: 0.98980

Traverse Point	Run Time 2.5 min/read	Pitot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dcf)	Stack T _s (°F)	Dry Gas Meter T _{m-in} T _{m-out} (°F) (°F)		√ΔP _s (calculated) (√in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)
	0.0			156.300						
1-01	2.5	0.34	0.83	157.350	287	67	66	0.58	1.05	83.6*
1-02	5.0	0.34	0.83	158.740	286	67	66	0.58	1.39	110.6*
1-03	7.5	0.34	0.83	160.140	293	67	66	0.58	1.40	111.9*
1-04	10.0	0.43	1.00	161.400	294	68	66	0.66	1.26	89.6*
1-05	12.5	0.47	1.10	162.730	299	69	67	0.69	1.33	90.6
LEAK CHECK	12.5			163.000						
2-01	15.0	0.53	1.30	164.390	298	69	67	0.73	1.39	89.2*
2-02	17.5	0.53	1.30	166.000	300	71	67	0.73	1.61	103.2
2-03	20.0	0.50	1.20	167.490	299	72	68	0.71	1.49	98.1
2-04	22.5	0.45	1.10	168.920	299	73	68	0.67	1.43	99.1
2-05	25.0	0.41	1.00	170.340	300	74	68	0.64	1.42	103.0
LEAK CHECK	25.0			170.340						
3-01	27.5	0.52	1.30	171.900	300	71	70	0.72	1.56	100.7
3-02	30.0	0.50	1.20	173.480	301	75	70	0.71	1.58	103.6
3-03	32.5	0.52	1.30	175.070	300	76	70	0.72	1.59	102.1
3-04	35.0	0.50	1.20	176.600	300	77	71	0.71	1.53	100.0
3-05	37.5	0.45	1.10	178.250	300	76	71	0.67	1.65	113.8*
LEAK CHECK	37.5			178.250						
4-01	40.0	0.45	1.10	180.080	300	76	74	0.67	1.83	125.8*
4-02	42.5	0.43	1.00	181.700	300	78	72	0.66	1.62	113.9*
4-03	45.0	0.43	1.00	183.100	299	78	72	0.66	1.40	98.4
4-04	47.5	0.45	1.10	184.570	299	78	72	0.67	1.47	101.0
4-05	50.0	0.45	1.10	186.030	300	78	72	0.67	1.46	100.4
LEAK CHECK	50.0			186.110						
5-01	52.5	0.47	1.10	187.550	300	75	72	0.69	1.44	97.2
5-02	55.0	0.48	1.20	189.100	300	77	72	0.69	1.55	103.3
5-03	57.5	0.47	1.10	190.580	299	78	72	0.69	1.48	99.5
5-04	60.0	0.45	1.10	192.020	299	78	73	0.67	1.44	98.9
5-05	62.5	0.40	0.98	193.450	297	78	72	0.63	1.43	104.1
Final	62.5		1.09480	36.80000	297.96000	71.80000		0.67133	36.80000	

25 points sampled
 QC-Check: Field Averages

Sq. Rt. ΔP	0.6713	1.0948	36.8000	297.9600	71.8000
<input checked="" type="checkbox"/> Avg. OK					

2RSR = 8.5%

04/310 101437
 H

Field Data Printout

Test Method: USEPA Method 13B
 Analyte: Total Fluorides

Location: Unit 3 FF Outlet
 Test Run: 2
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Source Area (ff): 64.00000
 Meter Operator: A. Obuchowski 567
 Probe Operator: B. Arnold 770

Bar. Press. (in. Hg): 30.05
 Static P: -10.6
 O₂ (dry volume %): 9.53
 CO₂ (dry volume %): 10.04
 N₂+CO (dry volume %): 80.43

Nozzle ID No: 268-1
 Nozzle Diameter (D_n): 0.268
 Probe ID No: 67-8-14
 Pitot C_p: 0.8120
 Pitot Leak Check: Pass Fail

Test Date: 3/16/10
 Start Time: 13:33
 Stop Time: 14:44
 Leak Rate Before: 0.003 cfm @ 15 "Hg
 Leak Rate After: 0.002 cfm @ 15 "Hg

H₂O (condensate, ml or gm): 197.8
 H₂O (silica, g): 15.9
 Actual Moisture (%): 21.38

Meter Box ID. No: 66-14
 Meter ΔH@: 1.76430
 Meter Y_d: 0.98980

Traverse Point	Run Time 2.5 min/read	Pitot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dcf)	Stack T _s (°F)	Dry Gas Meter		√ΔP _s (calculated) (√in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)
						T _{m-in} (°F)	T _{m-out} (°F)			
	0.0			193.980						
5-01	2.5	0.55	1.30	195.600	301	74	73	0.74	1.62	101.7
5-02	5.0	0.57	1.40	197.250	300	74	72	0.75	1.65	101.8
5-03	7.5	0.53	1.30	198.850	300	74	72	0.73	1.60	102.4
5-04	10.0	0.49	1.20	200.400	298	76	72	0.70	1.55	102.8
5-05	12.5	0.47	1.10	201.870	300	76	72	0.69	1.47	99.7
LEAK CHECK	12.5			202.060						
4-01	15.0	0.53	1.30	203.610	300	76	72	0.73	1.55	99.0
4-02	17.5	0.57	1.40	205.260	301	78	73	0.75	1.65	101.4
4-03	20.0	0.53	1.30	206.860	300	78	73	0.73	1.60	101.9
4-04	22.5	0.50	1.20	208.410	300	79	73	0.71	1.55	101.5
4-05	25.0	0.41	0.97	209.810	300	80	73	0.64	1.40	101.1
LEAK CHECK	25.0			209.920						
3-01	27.5	0.52	1.20	211.450	299	79	74	0.72	1.53	98.1
3-02	30.0	0.52	1.20	212.990	300	80	74	0.72	1.54	98.7
3-03	32.5	0.49	1.20	214.550	300	81	74	0.70	1.56	102.9
3-04	35.0	0.46	1.10	216.030	300	82	74	0.68	1.48	100.7
3-05	37.5	0.46	1.10	217.500	300	82	74	0.68	1.47	100.0
LEAK CHECK	37.5			217.610						
2-01	40.0	0.65	1.50	219.290	298	81	75	0.81	1.68	96.1
2-02	42.5	0.54	1.30	220.900	300	83	75	0.73	1.61	100.9
2-03	45.0	0.46	1.10	223.400	300	84	75	0.68	2.50	169.6*
2-04	47.5	0.41	0.97	223.850	299	84	76	0.64	0.45	32.3*
2-05	50.0	0.41	0.97	225.260	299	84	76	0.64	1.41	101.1
LEAK CHECK	50.0			225.380						
1-01	52.5	0.52	1.20	226.900	298	82	77	0.72	1.52	96.9
1-02	55.0	0.30	0.71	228.190	296	83	77	0.55	1.29	107.9
1-03	57.5	0.34	0.81	229.250	298	83	77	0.58	1.06	83.4*
1-04	60.0	0.41	0.97	230.620	299	83	77	0.64	1.37	98.2
1-05	62.5	0.43	1.00	232.270	300	83	77	0.66	1.65	115.6*
Final	62.5									
			1.15200	37.76000	299.44000	77.12000		0.69261	37.76000	

25 points sampled
 QC-Check: Field Averages
 Sq, RLAP

0.6926	1.1520	37.7600	299.4400	77.1200
--------	--------	---------	----------	---------

 Avg. OK Avg. OK Avg. OK Avg. OK Avg. OK

2RSD = 11.4%

041310 101437
K

Field Data Printout

Test Method: USEPA Method 13B
Analyte: Total Fluorides

Location: Unit 3 FF Outlet
 Test Run: 3
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Source Area (ft²): 64.00000
 Meter Operator: A. Obuchowski 567
 Probe Operator: B. Arnold 770
 Test Date: 3/16/10
 Start Time: 15:07
 Stop Time: 16:16
 Leak Rate Before: 0.002 cfm @ 15 "Hg
 Leak Rate After: 0.002 cfm @ 15 "Hg

Bar. Press. (in. Hg): 30.05
 Static P: -10.6
 O₂ (dry volume %): 9.72
 CO₂ (dry volume %): 9.96
 N₂+CO (dry volume %): 80.32

Nozzle ID No: 268-1
 Nozzle Diameter (in): 0.268
 Probe ID No: 67-8-14
 Pitot C_p: 0.8120
 Pitot Leak Check: Pass Fail

H₂O (condensate, ml or gm): 192.4
 H₂O (silica, g): 16.8
 Actual Moisture (%): 21.60

Meter Box ID No: 66-14
 Meter ΔH@: 1.76430
 Meter Y_d: 0.98980

Traverse Point	Run Time 2.5 min/read	Pitot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dcf)	Stack T _s (°F)	Dry Gas Meter		√ΔP _s (calculated) (√in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)
						T _{m-in} (°F)	T _{m-out} (°F)			
	0.0			232.600						
1-01	2.5	0.48	1.10	234.070	299	76	76	0.69	1.47	98.4
1-02	5.0	0.29	0.89	235.340	298	77	76	0.54	1.27	109.1
1-03	7.5	0.29	0.89	236.490	295	77	76	0.54	1.15	98.6
1-04	10.0	0.36	0.85	237.810	298	78	76	0.60	1.32	101.7
1-05	12.5	0.43	1.00	239.230	300	79	76	0.66	1.42	100.2
LEAK CHECK	12.5			239.320						
2-01	15.0	0.60	1.40	240.980	295	79	76	0.77	1.66	98.9
2-02	17.5	0.50	1.20	242.530	301	81	76	0.71	1.55	101.4
2-03	20.0	0.47	1.10	244.000	299	82	76	0.69	1.47	98.9
2-04	22.5	0.43	1.00	245.430	300	82	76	0.66	1.43	100.6
2-05	25.0	0.50	1.20	246.980	300	82	76	0.71	1.55	101.2
LEAK CHECK	25.0			247.070						
3-01	27.5	0.54	1.30	248.680	295	81	76	0.73	1.61	100.9
3-02	30.0	0.48	1.10	250.250	300	82	76	0.69	1.57	104.6
3-03	32.5	0.48	1.10	251.610	300	82	76	0.69	1.36	90.6
3-04	35.0	0.45	1.10	253.070	299	82	76	0.67	1.46	100.4
3-05	37.5	0.38	0.90	254.440	299	82	75	0.62	1.37	102.5
LEAK CHECK	37.5			254.490						
4-01	40.0	0.51	1.20	256.050	297	81	76	0.71	1.56	100.7
4-02	42.5	0.55	1.30	257.600	301	82	76	0.74	1.55	96.6
4-03	45.0	0.45	1.10	259.180	300	83	76	0.67	1.56	107.2
4-04	47.5	0.43	1.00	260.370	300	83	76	0.66	1.21	85.1*
4-05	50.0	0.40	0.95	262.010	300	83	76	0.63	1.64	119.5*
LEAK CHECK	50.0			262.070						
5-01	52.5	0.43	1.00	263.490	298	81	76	0.66	1.42	99.9
5-02	55.0	0.50	1.20	265.140	300	82	76	0.71	1.65	107.7
5-03	57.5	0.45	1.10	266.560	300	83	76	0.67	1.42	97.6
5-04	60.0	0.47	1.10	268.090	299	83	76	0.69	1.53	102.8
5-05	62.5	0.43	1.00	269.470	299	83	76	0.66	1.38	96.9
Final	62.5		1.06720	36.58000	298.88000	78.50000		0.67013	36.58000	

25 points sampled
 QC-Check: Field Averages
 Sq. Rt. ΔP

0.6701	1.0672	36.5800	298.8800	78.5000
--------	--------	---------	----------	---------

 Avg. OK Avg. OK Avg. OK Avg. OK Avg. OK

2RSD = 11.0%

041410 154321

USEPA Method 3 Laboratory Data

Location: Unit 3 FF Outlet
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Method: EPA Method 3
 Fuel Type: Municipal Waste
 F_o for Fuel: 1.03 to 1.3

Test Method: USEPA Method 13B
Analyte: Total Fluorides

Analyst: S. Brown
Analyst Emp No: 433

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
1	1							
	2							
	3							
Avg.								
CEM or Other Avg:		9.71000		9.90000	80.39000	29.94960	1.13285	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
2	1							
	2							
	3							
Avg.								
CEM or Other Avg:		10.04000		9.53000	80.43000	29.98760	1.13247	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
3	1							
	2							
	3							
Avg.								
CEM or Other Avg:		9.96000		9.72000	80.32000	29.98240	1.12249	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis:
	1							
	2							
	3							
Avg.								
CEM or Other Avg:								<input type="checkbox"/> Fo value within expected range.

041310 101437
 HKL @

USEPA Method 4 Laboratory Data

Location: Unit 3 FF Outlet
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955

Test Method: USEPA Method 13B
Analyte: Total Fluorides
 Analyst: R. Vicere
 Analyst Emp No: 563

Test Run: 1

	Contents	Gross (gm)	Tare (gm)	Net (gm)	
Impinger 1	DI Water	657.1	545.3	111.8	
Impinger 2	DI Water	618.0	558.1	59.9	
Impinger 3	Empty	469.7	455.2	14.5	
Impinger 4	Silica Gel	818.4	800.4	18.0	
Impinger 5					
Impinger 6					
Impinger 7					
Impinger 8					

186.2 Liquid (gm)	<i>Field Data Check</i>
0.0 less rinse (gm)	
186.2 Net Liquid (gm)	186.2 <input checked="" type="checkbox"/> QA/QC OK
+ 18.0 Silica Gel (gm)	18.0 <input checked="" type="checkbox"/> QA/QC OK
204.2 Total Vlc (gm)	204.2 <input checked="" type="checkbox"/> QA/QC OK

Rinse: _____ (ml or gm)

Test Run: 2

	Contents	Gross (gm)	Tare (gm)	Net (gm)	
Impinger 1	DI Water	652.2	536.6	115.6	
Impinger 2	DI Water	609.3	540.2	69.1	
Impinger 3	Empty	446.6	433.5	13.1	
Impinger 4	Silica Gel	780.9	765.0	15.9	
Impinger 5					
Impinger 6					
Impinger 7					
Impinger 8					

197.8 Liquid (gm)	<i>Field Data Check</i>
0.0 less rinse (gm)	
197.8 Net Liquid (gm)	197.8 <input checked="" type="checkbox"/> QA/QC OK
+ 15.9 Silica Gel (gm)	15.9 <input checked="" type="checkbox"/> QA/QC OK
213.7 Total Vlc (gm)	213.7 <input checked="" type="checkbox"/> QA/QC OK

Rinse: _____ (ml or gm)

Test Run: 3

	Contents	Gross (gm)	Tare (gm)	Net (gm)	
Impinger 1	DI Water	662.3	539.4	122.9	
Impinger 2	DI Water	598.1	543.1	55.0	
Impinger 3	Empty	462.8	448.3	14.5	
Impinger 4	Silica Gel	702.5	685.7	16.8	
Impinger 5					
Impinger 6					
Impinger 7					
Impinger 8					

192.4 Liquid (gm)	<i>Field Data Check</i>
0.0 less rinse (gm)	
192.4 Net Liquid (gm)	192.4 <input checked="" type="checkbox"/> QA/QC OK
+ 16.8 Silica Gel (gm)	16.8 <input checked="" type="checkbox"/> QA/QC OK
209.2 Total Vlc (gm)	209.2 <input checked="" type="checkbox"/> QA/QC OK

Rinse: _____ (ml or gm)

Test Run: _____

	Contents	Gross (gm)	Tare (gm)	Net (gm)	
Impinger 1	DI Water				
Impinger 2	DI Water				
Impinger 3	Empty				
Impinger 4	Silica Gel				
Impinger 5					
Impinger 6					
Impinger 7					
Impinger 8					

Liquid (gm)	<i>Field Data Check</i>
less rinse (gm)	
Net Liquid (gm)	<input type="checkbox"/> QA/QC OK
Silica Gel (gm)	<input type="checkbox"/> QA/QC OK
Total Vlc (gm)	<input type="checkbox"/> QA/QC OK

Rinse: _____ (ml or gm)

041310 101437
 H KL @

Field Data Printout

Test Method: USEPA Method 26A
Analyte: HCl

Location: Unit 3 SDA Inlet
 Test Run: 1
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Source Area (ff): 60.13205

Bar. Press. (in. Hg): 30.05
 Static P: -2.1

Nozzle ID No: NA
 Nozzle Diameter (D_n): NA
 Probe ID No: 67-4-5
 Pitot C_p: 0.8400

Meter Operator: B. Arnold 770
 Probe Operator: B. Arnold 770

O₂ (dry volume %): 8.59
 CO₂ (dry volume %): 10.72
 N₂+CO (dry volume %): 80.69

Pitot Leak Check: Pass Fail

Test Date: 3/16/10
 Start Time: 07:17
 Stop Time: 08:17

H₂O (condensate, ml or gm): 146.7

Meter Box ID. No: 61-8

Leak Rate Before: 0.003 cfm @ 15 "Hg
 Leak Rate After: 0.004 cfm @ 17 "Hg

H₂O (silica, g): 13.1
 Actual Moisture (%): 17.53

Meter ΔH@: 1.75800
 Meter Y_d: 0.99160

Traverse Point	Run Time 5.0 min/read	Pitot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dcf)	Stack T _s (°F)	Dry Gas Meter		√ΔP _s (calculated) (√in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)
						T _{m-in} (°F)	T _{m-out} (°F)			
	0.0			992.610						
1-01	5.0		1.20	995.700	501	67	66		3.09	
1-01	10.0		1.20	998.550	501	68	66		2.85	
1-01	15.0		1.20	1001.490	500	69	67		2.94	
1-01	20.0		1.20	1004.480	502	71	67		2.99	
1-01	25.0		1.20	1007.470	506	73	68		2.99	
1-01	30.0		1.20	1010.480	505	74	69		3.01	
1-01	35.0		1.20	1013.450	505	75	69		2.97	
1-01	40.0		1.20	1016.480	505	75	69		3.03	
1-01	45.0		1.20	1019.500	504	75	70		3.02	
1-01	50.0		1.10	1022.490	506	75	70		2.99	
1-01	55.0		1.00	1025.390	502	74	70		2.90	
1-01	60.0		1.00	1028.220	501	73	70		2.83	
Final	60.0									
			1.15833	35.61000	503.16667	70.41667		0.00000	35.61000	

1 points sampled
 QC-Check: Field Averages
 Sq.Rt.ΔP: 1.1580 35.6100 503.1667 70.4166

Avg. OK Avg. OK Avg. OK Avg. OK Avg. OK

041310 101501
 N

Field Data Printout

Test Method: USEPA Method 26A
Analyte: HCl

Location: Unit 3 SDA Inlet
 Test Run: 2
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Source Area (ft²): 60.13205
 Meter Operator: B. Arnold 770
 Probe Operator: B. Arnold 770
 Test Date: 3/16/10
 Start Time: 09:04
 Stop Time: 10:04
 Leak Rate Before: 0.003 cfm @ 15 "Hg
 Leak Rate After: 0.003 cfm @ 14 "Hg

Bar. Press. (in. Hg): 30.05
 Static P: -2.0
 O₂ (dry volume %): 8.21
 CO₂ (dry volume %): 11.07
 N₂+CO (dry volume %): 80.72

Nozzle ID No: NA
 Nozzle Diameter (D): NA
 Probe ID No: 67-4-5
 Pitot C_p: 0.8400
 Pitot Leak Check: Pass Fail

H₂O (condensate, ml or gm): 149.5
 H₂O (silica, g): 12.1
 Actual Moisture (%): 17.51

Meter Box ID. No: 61-8
 Meter ΔH@: 1.75800
 Meter Y_d: 0.99160

Traverse Point	Run Time 5.0 min/read	Pitot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dcf)	Stack T _a (°F)	Dry Gas Meter		√ΔP _s (calculated) (√in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)
						T _{m-in} (°F)	T _{m-out} (°F)			
	0.0			28.865						
1-01	5.0		1.20	31.920	508	70	69		3.06	
1-01	10.0		1.20	34.920	510	71	69		3.00	
1-01	15.0		1.20	37.950	508	72	70		3.03	
1-01	20.0		1.20	40.960	509	75	70		3.01	
1-01	25.0		1.20	43.950	510	76	71		2.99	
1-01	30.0		1.20	46.960	510	77	71		3.01	
1-01	35.0		1.20	49.970	508	77	71		3.01	
1-01	40.0		1.20	52.980	508	78	72		3.01	
1-01	45.0		1.20	56.020	509	78	72		3.04	
1-01	50.0		1.20	59.040	511	78	72		3.02	
1-01	55.0		1.20	62.070	514	78	72		3.03	
1-01	60.0		1.20	65.115	510	78	73		3.04	
Final	60.0									
1 points sampled				Sq.Rt.ΔP						
QC-Check: Field Averages				1.2000	36.2500	509.5833	73.3333	0.00000	36.25000	

Avg. OK Avg. OK Avg. OK Avg. OK Avg. OK

041410 154452
J

Field Data Printout

Test Method: USEPA Method 26A
Analyte: HCl

Location: Unit 3 SDA Inlet

Test Run: 3

Client: Wheelabrator North Broward, Inc.

Project No: 10955

Source Area (ff): 60.13205

Meter Operator: B. Arnold 770
 Probe Operator: B. Arnold 770

Test Date: 3/16/10

Start Time: 10:32

Stop Time: 11:32

Leak Rate Before: 0.003 cfm @ 15 "Hg
 Leak Rate After: 0.003 cfm @ 17 "Hg

Bar. Press. (in. Hg): 30.05

Static P: -2.2

O₂ (dry volume %): 8.07

CO₂ (dry volume %): 11.16

N₂+CO (dry volume %): 80.77

Nozzle ID No: NA

Nozzle Diameter (D_n): NA

Probe ID No: 67-4-5

Pitot C_p: 0.8400

Pitot Leak Check: Pass Fail

H₂O (condensate, ml or gm): 138.7

H₂O (silica, g): 9.7

Actual Moisture (%): 16.72

Meter Box ID. No: 61-8

Meter ΔH@: 1.75800

Meter Y_d: 0.99180

Traverse Point	Run Time 5.0 min/read	Pitot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dcf)	Stack T _s (°F)	Dry Gas Meter		√ΔP _s (calculated) (√in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)
						T _{m-in} (°F)	T _{m-out} (°F)			
1-01	5.0	1.20	1.20	65.410	508	74	73		2.91	
1-01	10.0	1.20	1.20	71.200	507	75	73		2.88	
1-01	15.0	1.20	1.20	74.140	505	77	73		2.94	
1-01	20.0	1.20	1.20	77.120	508	78	73		2.98	
1-01	25.0	1.20	1.20	80.000	510	80	74		2.88	
1-01	30.0	1.20	1.20	82.970	508	81	75		2.97	
1-01	35.0	1.20	1.20	88.020	507	81	75		3.05	
1-01	40.0	1.20	1.20	89.020	509	81	75		3.00	
1-01	45.0	1.20	1.20	92.060	509	82	77		3.04	
1-01	50.0	1.20	1.20	95.020	509	82	78		2.96	
1-01	55.0	1.10	1.10	98.020	509	82	78		3.00	
1-01	60.0	1.00	1.00	100.865	509	83	78		2.85	
Final	60.0		1.17500	35.45500	508.16667	77.41667		0.00000	35.45500	

1 points sampled
 QC-Check: Field Averages

Sq.RIΔP	1.1750	35.4550	508.1667	77.4167
---------	--------	---------	----------	---------

Avg. OK Avg. OK Avg. OK Avg. OK Avg. OK

041310 101501

USEPA Method 3 Laboratory Data

Location: Unit 3 SDA Inlet
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Method: EPA Method 3
 Fuel Type: Municipal Waste
 F_o for Fuel: 1.03 to 1.3

Test Method: USEPA Method 26A
Analyte: HCI

Analyst: S. Brown
 Analyst Emp No: 433

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
1	1							
	2							
	3							
Avg.								
CEM or Other Avg:		10.72000		8.59000	80.69000	30.05880	1.14832	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
2	1							
	2							
	3							
Avg.								
CEM or Other Avg:		11.07000		8.21000	80.72000	30.09960	1.14634	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
3	1							
	2							
	3							
Avg.								
CEM or Other Avg:		11.16000		8.07000	80.77000	30.10840	1.14964	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis:
	1							
	2							
	3							
Avg.								
CEM or Other Avg:								<input type="checkbox"/> Fo value within expected range.

041310 101501
 NSJ@

USEPA Method 4 Laboratory Data

Location: Unit 3 SDA Inlet
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955

Test Method: USEPA Method 26A
Analyte: HCl
Analyst: B. Wiltse
Analyst Emp No: 561

Test Run: 1

	Contents	Gross (gm)	Tare (gm)	Net (gm)	
Impinger 1	50 ml 0.1N H2SO4	506.6	468.1	38.5	
Impinger 2	100 ml 0.1N H2SO4	615.6	531.2	84.4	
Impinger 3	100 ml 0.1N H2SO4	566.9	548.5	18.4	
Impinger 4	Empty	431.7	426.3	5.4	
Impinger 5	Silica Gel	747.1	734.0	13.1	
Impinger 6					146.7 Liquid (gm)
Impinger 7					0.0 less rinse (gm)
Impinger 8					146.7 Net Liquid (gm)
					+ 13.1 Silica Gel (gm)
					159.8 Total Vlc (gm)

		Field Data Check	
		146.7	<input type="checkbox"/> QA/QC OK
		13.1	<input type="checkbox"/> QA/QC OK
		159.8	<input type="checkbox"/> QA/QC OK

Rinse: _____ (ml or gm)

Test Run: 2

	Contents	Gross (gm)	Tare (gm)	Net (gm)	
Impinger 1	50 ml 0.1N H2SO4	504.1	451.1	53.0	
Impinger 2	100 ml 0.1N H2SO4	629.9	554.4	75.5	
Impinger 3	100 ml 0.1N H2SO4	556.7	538.6	18.1	
Impinger 4	Empty	463.6	460.7	2.9	
Impinger 5	Silica Gel	741.3	729.2	12.1	
Impinger 6					149.5 Liquid (gm)
Impinger 7					0.0 less rinse (gm)
Impinger 8					149.5 Net Liquid (gm)
					+ 12.1 Silica Gel (gm)
					161.6 Total Vlc (gm)

		Field Data Check	
		149.5	<input type="checkbox"/> QA/QC OK
		12.1	<input type="checkbox"/> QA/QC OK
		161.6	<input type="checkbox"/> QA/QC OK

Rinse: _____ (ml or gm)

Test Run: 3

	Contents	Gross (gm)	Tare (gm)	Net (gm)	
Impinger 1	50 ml 0.1N H2SO4	507.8	468.5	39.3	
Impinger 2	100 ml 0.1N H2SO4	610.7	534.3	76.4	
Impinger 3	100 ml 0.1N H2SO4	572.1	553.2	18.9	
Impinger 4	Empty	432.4	428.3	4.1	
Impinger 5	Silica Gel	756.5	746.8	9.7	
Impinger 6					138.7 Liquid (gm)
Impinger 7					0.0 less rinse (gm)
Impinger 8					138.7 Net Liquid (gm)
					+ 9.7 Silica Gel (gm)
					148.4 Total Vlc (gm)

		Field Data Check	
		138.7	<input type="checkbox"/> QA/QC OK
		9.7	<input type="checkbox"/> QA/QC OK
		148.4	<input type="checkbox"/> QA/QC OK

Rinse: _____ (ml or gm)

Test Run: _____

	Contents	Gross (gm)	Tare (gm)	Net (gm)	
Impinger 1					
Impinger 2					
Impinger 3					
Impinger 4					
Impinger 5					
Impinger 6					
Impinger 7					
Impinger 8					

		Field Data Check	
			<input type="checkbox"/> QA/QC OK
			<input type="checkbox"/> QA/QC OK
			<input type="checkbox"/> QA/QC OK

Rinse: _____ (ml or gm)

041310 101501
 NSJ

Field Data Printout

Test Method: USEPA Method 26A
Analyte: HCl

Location: Unit 3 FF Outlet
 Test Run: 1
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Source Area (ff): 64.00000
 Meter Operator: A. Obuchowski 567
 Probe Operator:
 Test Date: 3/16/10
 Start Time: 07:17
 Stop Time: 08:17
 Leak Rate Before: 0.003 cfm @ 15 "Hg
 Leak Rate After: 0.002 cfm @ 15 "Hg

Bar. Press. (in. Hg): 30.05
 Static P: -10.4
 O₂ (dry volume %): 9.03
 CO₂ (dry volume %): 10.27
 N₂+CO (dry volume %): 80.70

Nozzle ID No: NA
 Nozzle Diameter (D): NA
 Probe ID No: 67-4-3
 Pitot C_p: 0.8400
 Pitot Leak Check: Pass Fail

H₂O (condensate, ml or gm): 205.9
 H₂O (silica, g): 29.6
 Actual Moisture (%): 20.83

Meter Box ID. No: 61-11
 Meter ΔH@: 1.73790
 Meter Y_g: 0.98920

Traverse Point	Run Time 5.0 min/read	Pitot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dcf)	Stack T _s (°F)	Dry Gas Meter		√ΔP _s (calculated) (√in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)
						T _{m-in} (°F)	T _{m-out} (°F)			
	0.0			230.130						
3-01	5.0		1.50	233.540	300	56	59		3.41	
3-01	10.0		1.50	236.990	300	56	59		3.45	
3-01	15.0		1.50	240.400	299	53	58		3.41	
3-01	20.0		1.50	243.840	299	51	59		3.44	
3-01	25.0		1.50	247.300	299	49	60		3.46	
3-01	30.0		1.50	250.670	299	49	61		3.37	
3-01	35.0		1.50	254.170	300	48	62		3.50	
3-01	40.0		1.50	257.500	299	49	63		3.33	
3-01	45.0		1.50	261.100	299	51	63		3.60	
3-01	50.0		1.50	264.550	299	51	64		3.45	
3-01	55.0		1.50	268.020	299	51	65		3.47	
3-01	60.0		1.50	271.470	299	51	65		3.45	
Final	60.0		1.50000	41.34000	299.25000	56.37500		0.00000	41.34000	

3 points sampled...
 QC-Check: Field Averages. Sq. Rt. ΔP

1.5000	41.3400	299.2500	56.3750
--------	---------	----------	---------

Avg. OK Avg. OK Avg. OK Avg. OK Avg. OK

041310 101520

Field Data Printout

Test Method: USEPA Method 26A
Analyte: HCl

Location: Unit 3 FF Outlet
 Test Run: 2
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Source Area (ff): 64.00000
 Meter Operator: A. Obuchowski 567
 Probe Operator:

Bar. Press. (in. Hg): 30.05
 Static P: -11.2
 O₂ (dry volume %): 9.10
 CO₂ (dry volume %): 10.22
 N₂+CO (dry volume %): 80.68

Nozzle ID No: NA
 Nozzle Diameter (D_n): NA
 Probe ID No: 67-4-3
 Pitot C_p: 0.8400
 Pitot Leak Check: Pass Fail

Test Date: 3/16/10
 Start Time: 09:04
 Stop Time: 10:04
 Leak Rate Before: 0.002 cfm @ 15 "Hg
 Leak Rate After: 0.001 cfm @ 15 "Hg

H₂O (condensate, ml or gm): 221.3
 H₂O (silica, g): 19.4
 Actual Moisture (%): 21.33

Meter Box ID. No: 61-11
 Meter ΔH@: 1.73790
 Meter Y_d: 0.98920

Traverse Point	Run Time 5.0 min/read	Pitot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dcf)	Stack T _s (°F)	Dry Gas Meter		√ΔP _s (calculated) (√in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)
						T _{m-in} (°F)	T _{m-out} (°F)			
	0.0			272.930						
3-01	5.0		1.50	276.420	304	62	65		3.49	
3-01	10.0		1.50	279.800	303	62	65		3.38	
3-01	15.0		1.50	283.180	299	56	64		3.38	
3-01	20.0		1.50	286.530	300	55	64		3.35	
3-01	25.0		1.50	289.950	300	53	64		3.42	
3-01	30.0		1.50	293.410	300	53	65		3.46	
3-01	35.0		1.50	296.900	299	54	66		3.49	
3-01	40.0		1.50	300.330	300	54	66		3.43	
3-01	45.0		1.50	303.820	300	54	67		3.49	
3-01	50.0		1.50	307.300	300	54	67		3.48	
3-01	55.0		1.50	310.780	300	55	68		3.48	
3-01	60.0		1.50	314.270	299	56	68		3.49	
Final	60.0		1.50000	41.34000	300.33333	60.70833		0.00000	41.34000	

3 points sampled
 QC-Check: Field Averages

Sq.Rt.ΔP	1.5000	41.3400	300.3333	60.7083
----------	--------	---------	----------	---------

Avg. OK Avg. OK Avg. OK Avg. OK Avg. OK

041410 154528
 R

Field Data Printout

Test Method: USEPA Method 26A
Analyte: HCl

Location: Unit 3 FF Outlet
 Test Run: 3
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Source Area (ft²): 64.00000
 Meter Operator: A. Obuchowski 567
 Probe Operator:
 Test Date: 3/16/10
 Start Time: 10:32
 Stop Time: 11:32
 Leak Rate Before: 0.002 cfm @ 15 "Hg
 Leak Rate After: 0.002 cfm @ 15 "Hg

Bar. Press. (in. Hg): 30.05
 Static P: -10.7
 O₂ (dry volume %): 8.92
 CO₂ (dry volume %): 10.38
 N₂+CO (dry volume %): 80.70

Nozzle ID No: NA
 Nozzle Diameter (D_n): NA
 Probe ID No: 67-4-3
 Pitot C_p: 0.8400
 Pitot Leak Check: Pass Fail

H₂O (condensate, ml or gm): 226.6
 H₂O (silica, g): 20.5
 Actual Moisture (%): 21.82

Meter Box ID No: 61-11
 Meter ΔH@: 1.73790
 Meter Y_d: 0.98920

Traverse Point	Run Time 5.0 min/read	Pitot ΔP _s (in. H ₂ O)	Sample ΔH (in. H ₂ O)	Metered (dcf)	Stack T _s (°F)	Dry Gas Meter		√ΔP _s (calculated) (√in. H ₂ O)	Volume (calculated) (ft ³)	Isokinetics (calculated) (%)
						T _{m-in} (°F)	T _{m-out} (°F)			
	0.0			315.150						
3-01	5.0		1.50	318.530	300	63	68		3.38	
3-01	10.0		1.50	321.960	300	63	68		3.43	
3-01	15.0		1.50	325.380	299	59	68		3.42	
3-01	20.0		1.50	328.970	299	58	69		3.59	
3-01	25.0		1.50	332.290	299	58	69		3.32	
3-01	30.0		1.50	335.690	299	59	70		3.40	
3-01	35.0		1.50	339.230	299	59	71		3.54	
3-01	40.0		1.50	342.680	299	59	72		3.45	
3-01	45.0		1.50	346.200	299	60	72		3.52	
3-01	50.0		1.50	349.730	299	61	73		3.53	
3-01	55.0		1.50	353.240	300	61	74		3.51	
3-01	60.0		1.50	356.755	299	63	74		3.51	
Final	60.0		1.50000	41.60500	299.25000	65.45833		0.00000	41.60500	

3 points sampled
 QC-Check: Field Averages
 Sq.Rt.ΔP: 1.5000 41.6050 299.2500 65.4583
 Avg. OK Avg. OK Avg. OK Avg. OK Avg. OK

041310 101620
 K

USEPA Method 3 Laboratory Data

Location: Unit 3 FF Outlet
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955
 Method: EPA Method 3
 Fuel Type: Municipal Waste
 F_o for Fuel: 1.03 to 1.3

Test Method: USEPA Method 26A
Analyte: HCl

Analyst: S. Brown
Analyst Emp No: 433

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
1	1							
	2							
	3							
Avg.								
CEM or Other Avg:		10.27000		9.03000	80.70000	30.00440	1.15579	<input checked="" type="checkbox"/> F _o value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
2	1							
	2							
	3							
Avg.								
CEM or Other Avg:		10.22000		9.10000	80.68000	29.99920	1.15460	<input checked="" type="checkbox"/> F _o value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis: CEM
3	1							
	2							
	3							
Avg.								
CEM or Other Avg:		10.38000		8.92000	80.70000	30.01760	1.15414	<input checked="" type="checkbox"/> F _o value within expected range.

Run Number	Trial	Percent CO ₂	Percent O ₂ +CO ₂	Percent O ₂	Percent N ₂	Dry Mol. Weight	F _o	Method of Analysis:
	1							
	2							
	3							
Avg.								
CEM or Other Avg:								<input type="checkbox"/> F _o value within expected range.

041310 101520
 LNK@

USEPA Method 4 Laboratory Data

Location: Unit 3 FF Outlet
 Client: Wheelabrator North Broward, Inc.
 Project No: 10955

Test Method: **USEPA Method 26A**
 Analyte: **HCl**
 Analyst: **B. Wiltse**
 Analyst Emp No: **561**

Test Run: **1**

	Contents	Gross (gm)	Tare (gm)	Net (gm)	
Impinger 1	50 ml 0.1N H2SO4	505.4	472.7	32.7	
Impinger 2	100 ml 0.1N H2SO4	730.5	637.4	93.1	
Impinger 3	100 ml 0.1N H2SO4	594.7	533.5	61.2	
Impinger 4	Empty	464.1	445.2	18.9	
Impinger 5	Silica Gel	780.9	731.3	29.6	
Impinger 6					
Impinger 7					
Impinger 8					
					205.9 Liquid (gm)
					0.0 less rinse (gm)
					205.9 Net Liquid (gm)
					+ 29.6 Silica Gel (gm)
					235.5 Total Vlc (gm)

Rinse: _____ (ml or gm)

Field Data Check

205.9	<input checked="" type="checkbox"/> QA/QC OK
29.6	<input checked="" type="checkbox"/> QA/QC OK
235.5	<input checked="" type="checkbox"/> QA/QC OK

Test Run: **2**

	Contents	Gross (gm)	Tare (gm)	Net (gm)	
Impinger 1	50 ml 0.1N H2SO4	510.0	465.0	45.0	
Impinger 2	100 ml 0.1N H2SO4	689.7	558.4	111.3	
Impinger 3	100 ml 0.1N H2SO4	603.7	550.9	52.8	
Impinger 4	Empty	466.6	454.4	12.2	
Impinger 5	Silica Gel	785.7	766.3	19.4	
Impinger 6					
Impinger 7					
Impinger 8					
					221.3 Liquid (gm)
					0.0 less rinse (gm)
					221.3 Net Liquid (gm)
					+ 19.4 Silica Gel (gm)
					240.7 Total Vlc (gm)

Rinse: _____ (ml or gm)

Field Data Check

221.3	<input checked="" type="checkbox"/> QA/QC OK
19.4	<input checked="" type="checkbox"/> QA/QC OK
240.7	<input checked="" type="checkbox"/> QA/QC OK

Test Run: **3**

	Contents	Gross (gm)	Tare (gm)	Net (gm)	
Impinger 1	50 ml 0.1N H2SO4	520.3	473.4	46.9	
Impinger 2	100 ml 0.1N H2SO4	751.2	643.1	108.1	
Impinger 3	100 ml 0.1N H2SO4	583.8	535.6	48.2	
Impinger 4	Empty	471.5	448.1	23.4	
Impinger 5	Silica Gel	780.7	760.2	20.5	
Impinger 6					
Impinger 7					
Impinger 8					
					228.6 Liquid (gm)
					0.0 less rinse (gm)
					228.6 Net Liquid (gm)
					+ 20.5 Silica Gel (gm)
					247.1 Total Vlc (gm)

Rinse: _____ (ml or gm)

Field Data Check

228.6	<input checked="" type="checkbox"/> QA/QC OK
20.5	<input checked="" type="checkbox"/> QA/QC OK
247.1	<input checked="" type="checkbox"/> QA/QC OK

Test Run: _____

	Contents	Gross (gm)	Tare (gm)	Net (gm)	
Impinger 1					
Impinger 2					
Impinger 3					
Impinger 4					
Impinger 5					
Impinger 6					
Impinger 7					
Impinger 8					
					Liquid (gm)
					less rinse (gm)
					Net Liquid (gm)
					Silica Gel (gm)
					Total Vlc (gm)

Rinse: _____ (ml or gm)

Field Data Check

	<input type="checkbox"/> QA/QC OK
	<input type="checkbox"/> QA/QC OK
	<input type="checkbox"/> QA/QC OK

041310 101520
 LNK®

Wheelabrator
CleanAir Project No. 10955
North Broward
SDA Inlet, FF Outlet

March 16, 2010
 Start Time 11:46
 Stop time 12:20
IGS Bag Analysis

	Channel 1	Channel 2
	CO2	O2
	%dv	%dv
Calibration Checks		
C _{oi} Initial zero	0.055	0.031
C _{ul} Initial upscale	5.930	14.164
C _{of} Final zero	0.052	0.020
C _{uf} Final upscale	5.911	14.111
C _{ma} Actual gas value	5.910	14.100
Linearity gas value	13.900	6.010
Analyzer Averages (concentrations)		
C _{AVG} Average conc.	10.25	9.06
C _{Gas} Bias adjusted	10.27	9.03
Analyzer Averages (concentrations)		
C _{AVG} Average conc.	10.20	9.13
C _{Gas} Bias adjusted	10.22	9.10
Analyzer Averages (concentrations)		
C _{AVG} Average conc.	10.36	8.96
C _{Gas} Bias adjusted	10.38	8.92
Analyzer Averages (concentrations)		
C _{AVG} Average conc.	10.70	8.62
C _{Gas} Bias adjusted	10.72	8.59
Analyzer Averages (concentrations)		
C _{AVG} Average conc.	11.04	8.24
C _{Gas} Bias adjusted	11.07	8.21
Analyzer Averages (concentrations)		
C _{AVG} Average conc.	11.13	8.10
C _{Gas} Bias adjusted	11.16	8.07
Analyzer Averages (concentrations)		
C _{AVG} Average conc.	9.86	9.57
C _{Gas} Bias adjusted	9.88	9.53
Analyzer Averages (concentrations)		
C _{AVG} Average conc.	9.91	9.49
C _{Gas} Bias adjusted	9.93	9.46

Clock Time (at end of sample period)

032910 145749	11:47:57	0.055	0.031
	11:48:12	0.054	2.352

Wheelabrator
CleanAir Project No. 10955
North Broward
SDA Inlet, FF Outlet

March 16, 2010
 Start Time 11:46
 Stop time 12:20
IGS Bag Analysis

	Channel 1	Channel 2	
	CO2	O2	
	%dv	%dv	
11:48:27	0.997	17.891	
11:48:42	2.099	14.181	
11:47:57	0.055	0.031	zero
11:48:12	0.054	2.352	
11:48:27	0.997	17.891	
11:48:42	2.099	14.181	
11:48:57	5.861	14.171	
11:49:12	5.634	14.152	
11:49:27	5.912	14.173	
11:49:42	5.922	14.164	
11:49:57	5.930	14.164	span
11:50:12	5.586	15.142	
11:50:27	1.058	19.321	
11:50:42	12.047	7.041	
11:50:57	13.813	6.070	
11:51:12	13.852	6.050	
11:51:27	13.869	6.038	linearity
11:51:42	13.879	6.058	
11:51:57	8.965	13.254	
11:52:12	0.387	20.776	
11:52:27	0.198	20.890	
11:52:42	0.079	20.460	
11:52:57	8.179	10.359	
11:53:12	10.193	9.083	
11:53:27	8.580	9.043	
11:53:42	8.828	8.418	
11:53:57	9.093	8.302	
11:54:12	9.633	7.944	
11:54:27	10.247	9.060	
11:54:42	10.250	9.060	U3 R1 M26A Out
11:54:57	9.630	10.816	
11:55:12	1.050	20.336	
11:55:27	0.430	19.948	
11:55:42	8.808	9.972	
11:55:57	10.175	9.152	
11:56:12	10.195	9.129	U3 R2 M26A Out
11:56:27	10.203	9.124	
11:56:42	8.220	12.792	
11:56:57	0.531	20.626	
11:57:12	5.931	12.747	
11:57:27	10.302	9.008	
11:57:42	10.351	8.968	
11:57:57	10.358	8.958	U3 R3 M26A Out
11:58:12	10.364	8.956	
11:58:27	7.881	13.269	
11:58:42	0.437	20.691	
11:58:57	3.369	15.792	
11:59:12	10.510	8.769	

Wheelabrator
 CleanAir Project No. 10955
 North Broward
 SDA Inlet, FF Outlet

March 16, 2010
 Start Time 11:46
 Stop time 12:20
IGS Bag Analysis

	Channel 1	Channel 2	
	CO2	O2	
	%dv	%dv	
11:59:27	10.677	8.669	
11:59:42	10.690	8.652	
11:59:57	10.698	8.622	U3 R1 M26A Inlet
12:00:12	10.700	8.630	
12:00:27	10.704	8.639	
12:00:42	4.095	17.884	
12:00:57	0.296	20.704	
12:01:12	5.342	13.457	
12:01:27	10.926	8.339	
12:01:42	11.012	8.288	
12:01:57	11.031	8.269	
12:02:12	11.036	8.241	
12:02:27	11.042	8.238	U3 R2 M26A Inlet
12:02:42	11.045	8.248	
12:02:57	11.046	8.235	
12:03:12	4.728	17.206	
12:03:27	0.259	20.802	
12:03:42	0.209	20.856	
12:03:57	2.003	17.322	
12:04:12	10.716	8.334	
12:04:27	11.111	8.118	
12:04:42	11.133	8.099	U3 R3 M26A Inlet
12:04:57	11.142	8.091	
12:05:12	11.146	8.089	
12:05:27	4.240	17.787	
12:05:42	0.304	20.420	
12:05:57	7.913	10.810	
12:06:12	9.835	9.570	
12:06:27	9.862	9.568	U1 R1 M5/29
12:06:42	9.872	9.562	
12:06:57	8.241	12.715	
12:07:12	0.558	20.631	<- Paused at 12:07:33 -
12:15:13	0.140	20.923	
12:15:28	1.715	17.916	
12:15:43	9.504	9.714	
12:15:58	9.889	9.500	
12:16:13	9.909	9.492	U1 R2 M5/29
12:16:28	9.870	9.956	
12:16:43	2.067	19.709	
12:16:58	0.816	19.503	
12:17:13	5.548	14.313	
12:17:28	5.891	14.117	
12:17:43	5.887	14.109	
12:17:58	5.911	14.111	span
12:18:13	5.240	15.561	
12:18:28	0.473	13.097	
12:18:43	0.095	0.281	
12:18:58	0.043	0.052	

Wheelabrator
CleanAir Project No. 10955
North Broward
SDA Inlet, FF Outlet

March 16, 2010
Start Time 11:46
Stop time 12:20
IGS Bag Analysis

	Channel 1	Channel 2	
	CO2	O2	
	%dv	%dv	
12:19:13	0.060	0.021	
12:19:28	0.052	0.020	Zero
12:19:43	0.064	6.117	
12:19:58	0.138	20.451	
12:20:13	0.140	20.859	

Wheelabrator
CleanAir Project No. 10955
North Broward
SDA Inlet, FF Outlet

March 16, 2010
 Start Time 16:04
 Stop time 16:25
IGS Bag Analysis

	Channel 1 CO2 %dv	Channel 2 O2 %dv	
Calibration Checks			
C _{oi} Initial zero	0.057	0.108	
C _{ui} Initial upscale	5.926	14.080	
C _{of} Final zero	0.067	0.106	
C _{uf} Final upscale	5.943	14.128	
C _{ma} Actual gas value	5.910	14.100	
Linearity gas value	13.900	6.010	
Analyzer Averages (concentrations)			
	U1 R3 5/29		
C _{Avg} Average conc.	9.83	9.78	
C _{Gas} Bias adjusted	9.83	9.74	
Analyzer Averages (concentrations)			
	U2 R1 M23		
C _{Avg} Average conc.	9.74	9.72	
C _{Gas} Bias adjusted	9.74	9.68	
Analyzer Averages (concentrations)			
	U3 R1 M13B		
C _{Avg} Average conc.	9.71	9.94	
C _{Gas} Bias adjusted	9.71	9.90	
Analyzer Averages (concentrations)			
	U3 R2 M13B		
C _{Avg} Average conc.	10.04	9.56	
C _{Gas} Bias adjusted	10.04	9.53	
Analyzer Averages (concentrations)			
	U3 R3 M13B		
C _{Avg} Average conc.	9.96	9.76	
C _{Gas} Bias adjusted	9.96	9.72	

Clock Time (at end of sample period)

032910 145749				
	16:05:32	0.038	0.154	
	16:05:47	0.040	0.119	
	16:06:02	0.057	0.108	
	16:05:32	0.038	0.154	
	16:05:47	0.040	0.119	
	16:06:02	0.057	0.108	zero
	16:06:17	0.057	2.464	
	16:06:32	0.111	19.561	
	16:06:47	1.148	18.780	
	16:07:02	5.525	14.167	
	16:07:17	5.839	14.057	
	16:07:32	5.906	14.073	
	16:07:47	5.926	14.080	span
	16:08:02	5.689	14.863	
	16:08:17	0.749	20.467	

Wheelabrator
CleanAir Project No. 10955
North Broward
SDA Inlet, FF Outlet

March 16, 2010
 Start Time 16:04
 Stop time 16:25
IGS Bag Analysis

	Channel 1	Channel 2	
	CO2	O2	
	%dv	%dv	
16:08:32	2.664	16.635	
16:08:47	13.495	6.328	
16:09:02	13.932	6.071	
16:09:17	13.962	6.060	linearity
16:09:32	13.969	6.050	
16:09:47	11.148	10.822	
16:10:02	0.606	20.559	
16:10:17	2.063	17.524	
16:10:32	9.494	9.961	
16:10:47	9.808	9.787	
16:11:02	9.830	9.776	U1 R3 5/29
16:11:17	9.846	9.779	
16:11:32	9.845	9.950	
16:11:47	2.633	19.252	
16:12:02	0.192	20.821	
16:12:17	2.751	16.600	
16:12:32	9.524	9.838	
16:12:47	9.723	9.726	
16:13:02	9.740	9.719	U2 R1 M23
16:13:17	9.749	9.711	
16:13:32	6.749	14.549	
16:13:47	0.323	20.761	
16:14:02	3.790	15.442	
16:14:17	9.501	10.006	
16:14:32	9.697	9.949	
16:14:47	9.706	9.945	
16:15:02	9.715	9.938	U3 R1 M13B
16:15:17	9.722	9.935	
16:15:32	9.717	10.081	
16:15:47	2.674	19.243	
16:16:02	0.228	20.729	
16:16:17	6.796	12.014	
16:16:32	9.981	9.616	
16:16:47	10.021	9.577	
16:17:02	10.036	9.577	
16:17:17	10.039	9.574	
16:17:32	10.043	9.565	U3 R2 M13B
16:17:47	10.045	9.566	
16:18:02	10.044	9.569	
16:18:17	10.045	9.575	
16:18:32	5.333	16.371	
16:18:47	0.255	20.818	
16:19:02	0.174	20.879	
16:19:17	0.156	20.895	
16:19:32	0.148	20.900	
16:19:47	0.140	20.907	
16:20:02	3.628	15.645	
16:20:17	9.805	9.848	

Wheelabrator
CleanAir Project No. 10955
North Broward
SDA Inlet, FF Outlet

March 16, 2010
 Start Time 16:04
 Stop time 16:25
IGS Bag Analysis

	Channel 1	Channel 2	
	CO2	O2	
	%dv	%dv	
16:20:32	9.942	9.774	
16:20:47	9.959	9.755	U3 R3 M13B
16:21:02	9.950	9.752	
16:21:17	8.599	12.490	
16:21:32	1.748	18.574	
16:21:47	5.757	14.236	
16:22:02	5.933	14.146	
16:22:17	5.941	14.147	
16:22:32	5.943	14.128	span
16:22:47	5.942	14.141	
16:23:02	4.717	16.300	
16:23:17	0.346	11.283	
16:23:32	0.097	0.278	
16:23:47	0.079	0.131	
16:24:02	0.067	0.106	zero
16:24:17	0.063	0.091	
16:24:32	0.055	0.070	
16:24:47	0.057	1.116	
16:25:02	0.114	18.846	
16:25:17	0.123	20.801	

Wheelabrator
CleanAir Project No. 10955
North Broward
SDA Inlet, FF Outlet

March 17, 2010
 Start Time 11:51
 Stop time 12:18
IGS Bag Analysis

	Channel 1	Channel 2
	CO2	O2
	%dv	%dv
Calibration Checks		
C _{oi} Initial zero	0.046	0.077
C _{ui} Initial upscale	5.929	14.157
C _{of} Final zero	0.077	0.087
C _{uf} Final upscale	5.935	14.160
C _{ma} Actual gas value	5.910	14.100
Linearity gas value	13.900	6.010
Analyzer Averages (concentrations)		
	U3 R1 M5/29	
C _{Avg} Average conc.	10.45	8.77
C _{Gas} Bias adjusted	10.46	8.71
Analyzer Averages (concentrations)		
	U3 R2 M5/29	
C _{Avg} Average conc.	10.93	8.37
C _{Gas} Bias adjusted	10.94	8.30
Analyzer Averages (concentrations)		
	U2 R1 M26A Out	
C _{Avg} Average conc.	9.65	9.72
C _{Gas} Bias adjusted	9.65	9.65
Analyzer Averages (concentrations)		
	U2 R2 M26A Out	
C _{Avg} Average conc.	9.14	10.45
C _{Gas} Bias adjusted	9.14	10.39
Analyzer Averages (concentrations)		
	U2 R3 M26A Out	
C _{Avg} Average conc.	9.94	9.60
C _{Gas} Bias adjusted	9.95	9.53
Analyzer Averages (concentrations)		
	U2 R1 M26A In	
C _{Avg} Average conc.	10.85	8.48
C _{Gas} Bias adjusted	10.86	8.41
Analyzer Averages (concentrations)		
	U2 R2 M26A In	
C _{Avg} Average conc.	10.19	9.36
C _{Gas} Bias adjusted	10.19	9.29
Analyzer Averages (concentrations)		
	U2 R3 M26A In	
C _{Avg} Average conc.	10.73	8.75
C _{Gas} Bias adjusted	10.74	8.68

Clock Time (at end of sample period)

032910 145749			
	11:52:28	0.044	0.216
	11:52:43	0.049	0.125

Wheelabrator
CleanAir Project No. 10955
North Broward
SDA Inlet, FF Outlet

March 17, 2010
 Start Time 11:51
 Stop time 12:18
IGS Bag Analysis

	Channel 1	Channel 2	
	CO2	O2	
	%dv	%dv	
11:52:28	0.044	0.216	
11:52:43	0.049	0.125	
11:52:58	0.048	0.098	
11:53:13	0.025	0.062	
11:53:28	0.046	0.077	Zero
11:53:43	0.041	0.099	
11:53:58	0.120	16.619	
11:54:13	1.998	17.844	
11:54:28	5.909	14.118	
11:54:43	6.003	14.095	
11:54:58	5.917	14.127	
11:55:13	5.923	14.146	
11:55:28	5.929	14.157	span
11:55:43	5.939	14.162	
11:55:58	4.753	16.248	
11:56:13	0.292	20.738	
11:56:28	0.860	19.105	
11:56:43	12.462	6.834	
11:56:58	13.814	6.079	
11:57:13	13.853	6.055	
11:57:28	13.876	6.069	linearity
11:57:43	13.893	6.098	
11:57:58	4.650	17.976	
11:58:13	-4.940	20.681	
11:58:28	0.198	20.866	
11:58:43	-1.575	20.888	
11:58:58	-0.333	20.899	
11:59:13	0.182	20.710	
11:59:28	7.805	10.622	
11:59:43	10.403	8.789	
11:59:58	10.442	8.782	
12:00:13	10.454	8.773	U3 R1 M5/29
12:00:28	10.195	9.909	
12:00:43	1.535	20.037	
12:00:58	1.621	18.032	
12:01:13	10.380	8.709	
12:01:28	10.905	8.391	
12:01:43	10.923	8.374	
12:01:58	10.933	8.368	U3 R2 M5/29
12:02:13	10.927	8.608	
12:02:28	2.861	19.158	
12:02:43	0.252	20.840	
12:02:58	0.196	20.881	
12:03:13	0.581	19.673	
12:03:28	8.566	10.388	
12:03:43	9.615	9.751	
12:03:58	9.649	9.728	
12:04:13	9.648	9.717	U2 R1 M26A Out

Wheelabrator
 CleanAir Project No. 10955
 North Broward
 SDA Inlet, FF Outlet

March 17, 2010
 Start Time 11:51
 Stop time 12:18
IGS Bag Analysis

	Channel 1	Channel 2	
	CO2	O2	
	%dv	%dv	
12:04:28	9.636	9.711	
12:04:43	9.640	9.709	
12:04:58	9.668	9.714	
12:05:13	6.081	15.295	
12:05:28	0.355	20.751	
12:05:43	5.006	14.038	
12:05:58	9.074	10.499	
12:06:13	9.133	10.462	
12:06:28	9.141	10.453	U2 R2 M26A Out
12:06:43	9.145	10.452	
12:06:58	9.150	10.452	
12:07:13	4.732	16.889	
12:07:28	0.290	20.817	
12:07:43	0.364	20.183	
12:07:58	8.272	10.669	
12:08:13	9.902	9.626	
12:08:28	9.935	9.612	
12:08:43	9.943	9.596	U2 R3 M26A Out
12:08:58	9.949	9.592	
12:09:13	4.850	16.902	
12:09:28	0.364	20.427	
12:09:43	8.520	10.034	
12:09:58	10.794	8.509	
12:10:13	10.832	8.488	
12:10:28	10.842	8.480	
12:10:43	10.849	8.476	U2 R1 M26A In
12:10:58	10.852	8.471	
12:11:13	9.313	11.600	
12:11:28	0.889	20.279	
12:11:43	5.267	13.726	
12:11:58	10.117	9.409	
12:12:13	10.168	9.367	
12:12:28	10.173	9.361	
12:12:43	10.186	9.359	U2 R2 M26A In
12:12:58	10.201	9.355	
12:13:13	8.830	12.138	
12:13:28	0.753	20.509	
12:13:43	2.975	16.273	
12:13:58	10.359	8.887	
12:14:13	10.709	8.763	
12:14:28	10.725	8.749	
12:14:43	10.733	8.746	U2 R3 M26A In
12:14:58	10.680	8.732	
12:15:13	4.452	17.479	
12:15:28	0.288	20.814	
12:15:43	0.556	19.946	
12:15:58	5.399	14.447	
12:16:13	5.920	14.160	

Wheelabrator
CleanAir Project No. 10955
North Broward
SDA Inlet, FF Outlet

March 17, 2010
Start Time 11:51
Stop time 12:18
IGS Bag Analysis

	Channel 1	Channel 2	
	CO2	O2	
	%dv	%dv	
12:16:28	5.935	14.160	span
12:16:43	5.850	14.613	
12:16:58	1.072	12.268	
12:17:13	0.122	0.327	
12:17:28	0.098	0.124	
12:17:43	0.081	0.102	
12:17:58	0.077	0.087	zero
12:18:13	0.084	2.631	
12:18:28	0.180	19.672	

Wheelabrator
CleanAir Project No. 10955
North Broward
SDA Inlet, FF Outlet

March 17, 2010
 Start Time 17:12
 Stop time 17:33

IGS Bag Analysis

	Channel 1 CO2 %dv	Channel 2 O2 %dv
Calibration Checks		
C _{oi} Initial zero	0.045	0.046
C _{ui} Initial upscale	5.927	14.068
C _{of} Final zero	0.074	0.094
C _{uf} Final upscale	5.942	14.161
C _{ma} Actual gas value	5.910	14.100
Linearity gas value	13.900	6.010
Analyzer Averages (concentrations)		
	U3 R3 M5/29	
C _{Avg} Average conc.	10.84	8.76
C _{Gas} Bias adjusted	10.84	8.72
Analyzer Averages (concentrations)		
	U1 R1 M13B	
C _{Avg} Average conc.	9.12	10.57
C _{Gas} Bias adjusted	9.11	10.55
Analyzer Averages (concentrations)		
	U1 R2 M13B	
C _{Avg} Average conc.	9.63	10.16
C _{Gas} Bias adjusted	9.62	10.13
Analyzer Averages (concentrations)		
	U1 R3 M13B	
C _{Avg} Average conc.	9.80	9.99
C _{Gas} Bias adjusted	9.80	9.96
Analyzer Averages (concentrations)		
	U2 R2 M23	
C _{Avg} Average conc.	9.84	9.77
C _{Gas} Bias adjusted	9.84	9.74
Analyzer Averages (concentrations)		
	U2 R3 M23	
C _{Avg} Average conc.	9.47	10.34
C _{Gas} Bias adjusted	9.47	10.31

Clock Time (at end of sample period)

032910 145749

17:13:05	0.066	2.094	
17:13:20	0.052	0.289	
17:13:05	0.066	2.094	
17:13:20	0.052	0.289	
17:13:35	0.047	0.126	
17:13:50	0.051	0.068	
17:14:05	0.044	0.043	
17:14:20	0.045	0.046	zero
17:14:35	0.055	4.700	
17:14:50	0.126	19.829	

Wheelabrator
CleanAir Project No. 10955
North Broward
SDA Inlet, FF Outlet

March 17, 2010
 Start Time 17:12
 Stop time 17:33
IGS Bag Analysis

	Channel 1	Channel 2	
	CO2	O2	
	%dv	%dv	
17:15:05	4.352	14.706	
17:15:20	5.645	13.916	
17:15:35	5.735	14.077	
17:15:50	5.900	14.075	
17:16:05	5.916	14.069	
17:16:20	5.911	14.068	
17:16:35	5.927	14.068	span
17:16:50	5.906	14.075	
17:17:05	2.461	18.425	
17:17:20	11.722	7.289	
17:17:35	13.952	6.054	
17:17:50	13.983	6.042	
17:18:05	14.000	6.033	linearity
17:18:20	14.009	6.030	
17:18:35	13.820	7.094	
17:18:50	2.179	19.806	
17:19:05	0.203	20.809	
17:19:20	7.597	11.026	
17:19:35	10.790	8.779	
17:19:50	10.830	8.764	
17:20:05	10.840	8.758	U3 R3 M5/29
17:20:20	10.844	8.755	
17:20:35	6.142	15.638	
17:20:50	0.252	20.854	
17:21:05	6.017	12.921	
17:21:20	9.063	10.599	
17:21:35	9.103	10.583	
17:21:50	9.115	10.574	U1 R1 M13B
17:22:05	9.121	10.589	
17:22:20	4.651	17.060	
17:22:35	0.197	20.882	
17:22:50	0.204	20.504	
17:23:05	7.846	11.207	
17:23:20	9.576	10.154	
17:23:35	9.613	10.159	
17:23:50	9.625	10.159	U1 R2 M13B
17:24:05	9.629	10.152	
17:24:20	6.198	15.376	
17:24:35	0.258	20.844	
17:24:50	1.069	18.890	
17:25:05	9.210	10.299	
17:25:20	9.788	9.994	
17:25:35	9.799	9.987	U1 R3 M13B
17:25:50	9.823	9.994	
17:26:05	7.648	13.186	
17:26:20	0.355	20.738	
17:26:35	0.086	20.920	
17:26:50	0.152	20.943	

Wheelabrator
CleanAir Project No. 10955
North Broward
SDA Inlet, FF Outlet

March 17, 2010
 Start Time 17:12
 Stop time 17:33
IGS Bag Analysis

	Channel 1	Channel 2	
	CO2	O2	
	%dv	%dv	
17:27:05	0.685	19.425	
17:27:20	9.018	10.228	
17:27:35	9.791	9.791	
17:27:50	9.821	9.782	
17:28:05	9.816	9.769	
17:28:20	9.842	9.773	U2 R2 M23
17:28:35	9.847	9.768	
17:28:50	8.581	12.439	
17:29:05	0.570	20.694	
17:29:20	0.819	19.334	
17:29:35	8.803	10.724	
17:29:50	9.447	10.362	
17:30:05	9.462	10.341	
17:30:20	9.471	10.338	U2 R3 M23
17:30:35	9.473	10.349	
17:30:50	3.160	18.617	
17:31:05	4.901	14.765	
17:31:20	5.934	14.160	
17:31:35	5.942	14.161	span
17:31:50	5.249	15.662	
17:32:05	0.420	20.784	
17:32:20	0.138	9.619	
17:32:35	0.100	0.208	
17:32:50	0.091	0.119	
17:33:05	0.074	0.094	zero
17:33:20	0.077	0.087	
17:33:35	0.091	7.573	
17:33:50	0.122	20.655	

Wheelabrator
CleanAir Project No. 10955
North Broward
SDA Inlet, FF Outlet

March 18, 2010
 Start Time 14:19
 Stop time 14:56
IGS Bag Analysis

	Channel 1	Channel 2
	CO2	O2
	%dv	%dv
Calibration Checks		
C _{oi} Initial zero	0.004	-0.014
C _{ui} Initial upscale	5.898	14.197
C _{of} Final zero	0.042	0.013
C _{uf} Final upscale	5.894	14.158
C _{ma} Actual gas value	5.910	14.100
Linearity gas value	13.900	6.010
Analyzer Averages (concentrations)		
	U2 R1 M13B	
C _{Avg} Average conc.	9.25	10.07
C _{Gas} Bias adjusted	9.29	10.02
Analyzer Averages (concentrations)		
	U2 R2 M13B	
C _{Avg} Average conc.	9.54	9.69
C _{Gas} Bias adjusted	9.58	9.64
Analyzer Averages (concentrations)		
	U2 R3 M13B	
C _{Avg} Average conc.	9.10	10.21
C _{Gas} Bias adjusted	9.13	10.15
Analyzer Averages (concentrations)		
	U1 R1 M26A Out	
C _{Avg} Average conc.	9.46	9.93
C _{Gas} Bias adjusted	9.50	9.88
Analyzer Averages (concentrations)		
	U1 R2 M26A Out	
C _{Avg} Average conc.	9.63	9.75
C _{Gas} Bias adjusted	9.67	9.69
Analyzer Averages (concentrations)		
	U1 R3 M26A Out	
C _{Avg} Average conc.	9.38	10.11
C _{Gas} Bias adjusted	9.42	10.05
Analyzer Averages (concentrations)		
	U1 R1 M26A In	
C _{Avg} Average conc.	10.19	9.16
C _{Gas} Bias adjusted	10.23	9.11
Analyzer Averages (concentrations)		
	U1 R2 M26A In	
C _{Avg} Average conc.	10.30	9.06
C _{Gas} Bias adjusted	10.35	9.01
Analyzer Averages (concentrations)		
	U1 R3 M26A In	
C _{Avg} Average conc.	9.78	9.75
C _{Gas} Bias adjusted	9.82	9.70

Wheelabrator
CleanAir Project No. 10955
North Broward
SDA Inlet, FF Outlet

March 18, 2010
 Start Time 14:19
 Stop time 14:56
IGS Bag Analysis

	Channel 1	Channel 2
	CO2	O2
	%dv	%dv
Analyzer Averages (concentrations)		
	U2 R1 M5/29	
C _{Avg} Average conc.	9.22	10.12
C _{Gas} Bias adjusted	9.25	10.07
Analyzer Averages (concentrations)		
	U2 R2 M5/29	
C _{Avg} Average conc.	9.57	9.80
C _{Gas} Bias adjusted	9.60	9.75
Analyzer Averages (concentrations)		
	U2 R3 M5/29	
C _{Avg} Average conc.	9.54	9.94
C _{Gas} Bias adjusted	9.58	9.89

Clock Time (at end of sample period)

032910 145749			
14:20:01	0.042	0.206	
14:20:16	0.035	-0.058	
14:20:01	0.042	0.206	
14:20:16	0.035	-0.058	
14:20:31	0.044	-0.083	
14:20:46	0.044	-0.097	
14:21:01	0.049	-0.106	
14:21:16	0.037	-0.048	
14:21:31	0.015	-0.022	
14:21:46	0.014	-0.009	
14:22:01	0.004	-0.014	zero
14:22:16	0.021	5.537	
14:22:31	2.717	16.702	
14:22:46	6.010	14.229	
14:23:01	5.984	14.135	
14:23:16	5.915	14.143	
14:23:31	5.937	14.157	
14:23:46	5.940	14.161	
14:24:01	5.914	14.167	
14:24:16	5.904	14.190	
14:24:31	5.898	14.197	span
14:24:46	4.986	16.027	
14:25:01	0.340	20.872	
14:25:16	0.119	21.004	
14:25:31	6.715	12.063	
14:25:46	13.805	6.058	
14:26:01	13.901	6.012	
14:26:16	13.948	6.014	linearity
14:26:31	13.967	6.034	
14:26:46	4.680	18.026	
14:27:01	0.198	20.959	

Wheelabrator
CleanAir Project No. 10955
North Broward
SDA Inlet, FF Outlet

March 18, 2010
 Start Time 14:19
 Stop time 14:56

IGS Bag Analysis

	Channel 1	Channel 2	
	CO2	O2	
	%dv	%dv	
14:27:16	5.451	13.325	
14:27:31	9.197	10.108	
14:27:46	9.230	10.080	
14:28:01	9.255	10.071	U2 R1 M13B
14:28:16	8.556	11.910	
14:28:31	0.793	20.562	
14:28:46	1.973	17.576	
14:29:01	9.233	9.873	
14:29:16	9.517	9.707	
14:29:31	9.533	9.697	
14:29:46	9.542	9.691	U2 R2 M13B
14:30:01	9.543	9.702	
14:30:16	3.232	18.659	
14:30:31	0.164	20.957	
14:30:46	5.063	13.742	
14:31:01	9.200	10.047	
14:31:16	9.199	10.084	
14:31:31	9.097	10.206	U2 R3 M13B
14:31:46	8.994	10.307	
14:32:01	8.889	10.744	
14:32:16	1.935	19.821	
14:32:31	0.160	20.950	
14:32:46	6.251	12.411	
14:33:01	9.410	9.967	
14:33:16	9.455	9.942	
14:33:31	9.461	9.935	U1 R1 M26A Out
14:33:46	9.469	9.995	
14:34:01	2.827	19.103	
14:34:16	1.539	18.206	
14:34:31	9.236	9.967	
14:34:46	9.632	9.746	U1 R2 M26A Out
14:35:01	9.652	9.733	
14:35:16	9.661	9.827	
14:35:31	2.762	19.187	
14:35:46	0.252	20.795	
14:36:01	6.507	12.206	
14:36:16	9.353	10.140	
14:36:31	9.375	10.114	
14:36:46	9.382	10.106	U1 R3 M26A Out
14:37:01	9.336	10.592	
14:37:16	1.873	19.869	
14:37:31	0.213	20.888	
14:37:46	6.336	12.267	
14:38:01	10.136	9.200	
14:38:16	10.168	9.171	
14:38:31	10.193	9.162	U1 R1 M26A In
14:38:46	10.114	9.145	
14:39:01	10.137	9.154	

Wheelabrator
CleanAir Project No. 10955
North Broward
SDA Inlet, FF Outlet

March 18, 2010
 Start Time 14:19
 Stop time 14:56
IGS Bag Analysis

	Channel 1	Channel 2	
	CO2	O2	
	%dv	%dv	
14:39:16	10.198	9.154	
14:39:31	3.860	17.989	
14:39:46	0.188	20.768	
14:40:01	7.706	10.804	
14:40:16	10.264	9.075	
14:40:31	10.298	9.060	
14:40:46	10.304	9.058	U1 R2 M26A In
14:41:01	10.287	9.403	
14:41:16	2.334	19.601	
14:41:31	0.165	20.947	
14:41:46	5.210	13.665	
14:42:01	9.738	9.784	
14:42:16	9.783	9.749	U1 R3 M26A In
14:42:31	9.804	9.741	
14:42:46	9.793	9.739	
14:43:01	3.941	17.936	
14:43:16	0.203	20.913	
14:43:31	0.329	20.154	
14:43:46	7.960	10.880	
14:44:01	9.187	10.151	
14:44:16	9.205	10.135	
14:44:31	9.217	10.125	U2 R1 M5/29
14:44:46	9.218	10.121	
14:45:01	5.205	16.260	
14:45:16	0.214	20.907	<-- Paused at 14:45:22 -
14:49:04	0.094	21.004	
14:49:19	0.129	20.799	
14:49:34	7.222	11.369	
14:49:49	9.519	9.845	
14:50:04	9.555	9.810	
14:50:19	9.567	9.800	U2 R2 M5/29
14:50:34	9.572	9.797	
14:50:49	3.524	18.362	
14:51:04	0.195	20.892	
14:51:19	2.073	17.538	
14:51:34	9.241	10.117	
14:51:49	9.519	9.956	
14:52:04	9.536	9.949	
14:52:19	9.544	9.941	U2 R3 M5/29
14:52:34	9.439	10.622	
14:52:49	1.628	20.057	
14:53:04	0.242	20.523	
14:53:19	5.022	14.663	
14:53:34	5.880	14.159	
14:53:49	5.894	14.158	
14:54:04	5.894	14.158	span
14:54:19	5.125	15.781	
14:54:34	0.372	13.231	

**Wheelabrator
CleanAir Project No. 10955
North Broward
SDA Inlet, FF Outlet**

March 18, 2010
Start Time 14:19
Stop time 14:56
IGS Bag Analysis

	Channel 1	Channel 2	
	CO2	O2	
	%dv	%dv	
14:54:49	0.065	0.277	
14:55:04	0.054	0.058	
14:55:19	0.051	0.034	
14:55:34	0.042	0.013	zero
14:55:49	0.046	7.507	
14:56:04	0.098	20.670	

WHEELABRATOR NORTH BROWARD, INC.

Clean Air Project No: 10955

Location: Ash Conveyor/Doors to Baghouse

Date (2009): March 12

Start Time: 7:22

End Time: 8:32

METHOD 22 FIELD DATA PRINTOUT

Run	Clock Time (start)	Observation Period (minutes)	Opacity (%)
1	7:22 7:42	20	0
2	7:47 8:07	20	0
3	8:12 8:32	20	0
Minimum			0
Average			0
Maximum			0

WHEELABRATOR NORTH BROWARD, INC.

Clean Air Project No: 10735

Location: Ash Unloading/Conveyor

Date (2009): March 12

Start Time: 8:43

End Time: 9:54

METHOD 22 FIELD DATA PRINTOUT

Run	Clock Time (start)	Observation Period (minutes)	Opacity (%)
1	8:43 9:03	20	0
2	9:08 9:28	20	0
3	9:33 9:54	20	0
Minimum			0
Average			0
Maximum			0

WHEELABRATOR NORTH BROWARD, INC.

Clean Air Project No: 10735

Location: Rolling Door/Door to Baghouse

Date (2009): March 12

Start Time: 11:10

End Time: 12:20

METHOD 22 FIELD DATA PRINTOUT

Run	Clock Time (start)	Observation Period (minutes)	Opacity (%)
1	11:10 11:30	20	0
2	11:35 11:55	20	0
3	12:00 12:20	20	0
Minimum			0
Average			0
Maximum			0

This Page Intentionally Left Blank

WHEELABRATOR NORTH BROWARD, INC.
POMPANO BEACH, FL

CleanAir Project No: 10955-2

LABORATORY DATA

I

This Page Intentionally Left Blank

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10955
 Unit 1 FF Outlet

USEPA Method 5/29 Gravimetric Laboratory Data Summary

Run No.	Blank	1	2	3
Date (2010) <input type="checkbox"/> Draft Lab Data		Mar 16	Mar 16	Mar 16
Start Time (approx.)		07:21	10:00	12:36
Stop Time (approx.)		09:32	12:14	14:47

Filter(s) <input type="checkbox"/> Allow Negative Filter Sum				
m_{f1}	Filter No. 1 residue mass (g)	<0.00010	<0.00010	<0.00010
m_{f2}	Filter No. 2 residue mass (g)	[REDACTED]		
m_{f3}	Filter No. 3 residue mass (g)	[REDACTED]		
m_{f4}	Filter No. 4 residue mass (g)	[REDACTED]		
m_{fr}	Total filter residue (g)	<0.00010	<0.00010	<0.00010
m_{filter}	Particulate on filter(s) (g)	<0.00010	<0.00010	<0.00010

First Solvent Rinse

Acetone

ρ_1	Density (g/ml)	0.785			
v_{s1}	Rinse volume (ml)		88.0	90.0	86.0
v_{a1}	Aliquot size (ml)	139.0	88.0	90.0	86.0
r_{a1}	Aliquot residue mass (g)	0.00080	0.00100	0.00270	0.00050
r_{s1}	Sample residue mass (g)		0.00100	0.00270	0.00050
m_{b1}	Allowable blank correction (g)		0.00051	0.00052	0.00049
m_1	Net residue (g)	0.00080	0.00049	0.00218	0.00001

Second Solvent Rinse

N/A

ρ_2	Density (g/ml)	[REDACTED]			
v_{s2}	Rinse volume (ml)	[REDACTED]			
v_{a2}	Aliquot size (ml)	[REDACTED]			
r_{a2}	Aliquot residue mass (g)	[REDACTED]			
r_{s2}	Sample residue mass (g)	[REDACTED]			
m_{b2}	Allowable blank correction (g)				
m_2	Net residue (g)	0.00000	0.00000	0.00000	

Third Solvent Rinse

N/A

ρ_3	Density (g/ml)	[REDACTED]			
v_{s3}	Rinse volume (ml)	[REDACTED]			
v_{a3}	Aliquot size (ml)	[REDACTED]			
r_{a3}	Aliquot residue mass (g)	[REDACTED]			
r_{s3}	Sample residue mass (g)	[REDACTED]			
m_{b3}	Allowable blank correction (g)				
m_3	Net residue (g)	0.00000	0.00000	0.00000	
m_s	Total Solvent Residue (g)	0.00049	0.00218	0.00001	
m_T	Total Gravimetric Result (g)	0.00049	0.00218	0.00011	
m_D	Minimum Detection Limit (g)	0.00020	0.00020	0.00020	
m_n	Total Particulate Matter (g)	0.00049	0.00218	<0.00020	

041310 102858

P

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10955
 Unit 2 FF Outlet

USEPA Method 5/29 Gravimetric Laboratory Data Summary

Run No.	Blank	1	2	3
Date (2010) <input type="checkbox"/> Draft Lab Data		Mar 18	Mar 18	Mar 18
Start Time (approx.)		07:09	09:49	12:27
Stop Time (approx.)		09:22	12:02	14:39

Filter(s) Allow Negative Filter Sum

m_{f1}	Filter No. 1 residue mass (g)	0.00180	0.00100	0.00090
m_{f2}	Filter No. 2 residue mass (g)			
m_{f3}	Filter No. 3 residue mass (g)			
m_{f4}	Filter No. 4 residue mass (g)			
m_f	Total filter residue (g)	0.00180	0.00100	0.00090
m_{filter}	Particulate on filter(s) (g)	0.00180	0.00100	0.00090

First Solvent Rinse
Acetone

ρ_1	Density (g/ml)	0.785		
V_{s1}	Rinse volume (ml)	98.0	67.0	84.0
V_{a1}	Aliquot size (ml)	139.0	98.0	67.0
r_{a1}	Aliquot residue mass (g)	0.00080	0.00280	0.00170
r_{s1}	Sample residue mass (g)	0.00280	0.00170	0.00210
m_{b1}	Allowable blank correction (g)	0.00056	0.00039	0.00048
m_1	Net residue (g)	0.00080	0.00224	0.00131

Second Solvent Rinse
N/A

ρ_2	Density (g/ml)			
V_{s2}	Rinse volume (ml)			
V_{a2}	Aliquot size (ml)			
r_{a2}	Aliquot residue mass (g)			
r_{s2}	Sample residue mass (g)			
m_{b2}	Allowable blank correction (g)	0.00000	0.00000	0.00000
m_2	Net residue (g)	0.00000	0.00000	0.00000

Third Solvent Rinse
N/A

ρ_3	Density (g/ml)			
V_{s3}	Rinse volume (ml)			
V_{a3}	Aliquot size (ml)			
r_{a3}	Aliquot residue mass (g)			
r_{s3}	Sample residue mass (g)			
m_{b3}	Allowable blank correction (g)	0.00000	0.00000	0.00000
m_3	Net residue (g)	0.00000	0.00000	0.00000

m_s	Total Solvent Residue (g)	0.00224	0.00131	0.00162
m_T	Total Gravimetric Result (g)	0.00404	0.00231	0.00252
m_D	Minimum Detection Limit (g)	0.00020	0.00020	0.00020
m_n	Total Particulate Matter (g)	0.00404	0.00231	0.00252

041310 103114

K

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10955
 Unit 3 FF Outlet

USEPA Method 5/29 Gravimetric Laboratory Data Summary

Run No.	Blank	1	2	3
Date (2010) <input type="checkbox"/> Draft Lab Data		Mar 17	Mar 17	Mar 17
Start Time (approx.)		06:50	09:26	11:59
Stop Time (approx.)		09:03	11:38	14:11

	Filter(s) <input type="checkbox"/> Allow Negative Filter Sum	Blank	1	2	3
m_{f1}	Filter No. 1 residue mass (g)		0.00040	<0.00010	0.00100
m_{f2}	Filter No. 2 residue mass (g)				
m_{f3}	Filter No. 3 residue mass (g)				
m_{f4}	Filter No. 4 residue mass (g)				
m_{fr}	Total filter residue (g)		0.00040	<0.00010	0.00100
m_{filter}	Particulate on filter(s) (g)		0.00040	<0.00010	0.00100

First Solvent Rinse

<u>Acetone</u>					
ρ_1	Density (g/ml)	0.785			
v_{s1}	Rinse volume (ml)		96.0	70.0	81.0
v_{a1}	Aliquot size (ml)	139.0	96.0	70.0	81.0
r_{a1}	Aliquot residue mass (g)	0.00080	0.00130	0.00170	0.00170
r_{s1}	Sample residue mass (g)		0.00130	0.00170	0.00170
m_{b1}	Allowable blank correction (g)		0.00055	0.00040	0.00047
m_1	Net residue (g)	0.00080	0.00075	0.00130	0.00123

Second Solvent Rinse

<u>N/A</u>					
ρ_2	Density (g/ml)				
v_{s2}	Rinse volume (ml)				
v_{a2}	Aliquot size (ml)				
r_{a2}	Aliquot residue mass (g)				
r_{s2}	Sample residue mass (g)				
m_{b2}	Allowable blank correction (g)				
m_2	Net residue (g)		0.00000	0.00000	0.00000

Third Solvent Rinse

<u>N/A</u>					
ρ_3	Density (g/ml)				
v_{s3}	Rinse volume (ml)				
v_{a3}	Aliquot size (ml)				
r_{a3}	Aliquot residue mass (g)				
r_{s3}	Sample residue mass (g)				
m_{b3}	Allowable blank correction (g)				
m_3	Net residue (g)		0.00000	0.00000	0.00000
m_s	Total Solvent Residue (g)		0.00075	0.00130	0.00123
m_T	Total Gravimetric Result (g)		0.00115	0.00130	0.00223
m_D	Minimum Detection Limit (g)		0.00020	0.00020	0.00020
m_n	Total Particulate Matter (g)		0.00115	0.00130	0.00223

041310 103125

0

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10955
 Unit 1 FF Outlet

USEPA Method 5/29 Mercury (Hg) Laboratory Parameters

Detection Limits

m _{1b-DL}	Fraction 1B Detection Limit (µg)	0.0000
m _{2b-DL}	Fraction 2B Detection Limit (µg)	0.0000
m _{3a-DL}	Fraction 3A Detection Limit (µg)	0.0000
m _{3b-DL}	Fraction 3B Detection Limit (µg)	0.0000
m _{3c-DL}	Fraction 3C Detection Limit (µg)	0.0000

Blank Analysis

m _{1b-B}	Fraction 1B Blank (µg)	<0.1000
m _{2b-B}	Fraction 2B Blank (µg)	<0.2000
m _{3a-B}	Fraction 3A Blank (µg)	<0.2000
m _{3b-B}	Fraction 3B Blank (µg)	<0.5000
m _{3c-B}	Fraction 3C Blank (µg)	<0.4000
m _{total-B}	Total Blank Amount (µg)	<1.4000

Run No.

	1	2	3
Date (2010)	Mar 16	Mar 16	Mar 16
Start Time (approx.)	07:21	10:00	12:36
Stop Time (approx.)	09:32	12:14	14:47

Sample Analysis

m _{1b-S}	Fraction 1B Sample (µg)	<0.1000	<0.1000	<0.1000
m _{2b-S}	Fraction 2B Sample (µg)	7.7629	8.8151	9.7549
m _{3a-S}	Fraction 3A Sample (µg)	<0.2000	<0.2000	<0.2000
m _{3b-S}	Fraction 3B Sample (µg)	<0.5000	<0.5000	<0.5000
m _{3c-S}	Fraction 3C Sample (µg)	<0.4000	<0.4000	<0.4000
m _{total-S}	Total Sample Amount (µg)	7.7629	8.8151	9.7549

Allowable Blank

m _{T-B-allow}	Total Allowable Blank (µg)	0.0000	0.0000	0.0000
------------------------	----------------------------	--------	--------	--------

Sample Corrected for Blank

m _n	Total Sample Amount (µg)	7.7629	8.8151	9.7549
----------------	--------------------------	--------	--------	--------

Sample Corrected for Blank

m _{n-1b}	Fraction 1B (µg)	<0.1000	<0.1000	<0.1000
m _{n-2b}	Fraction 2B (µg)	7.7629	8.8151	9.7549
m _{n-3a}	Fraction 3A (µg)	<0.2000	<0.2000	<0.2000
m _{n-3b}	Fraction 3B (µg)	<0.5000	<0.5000	<0.5000
m _{n-3c}	Fraction 3C (µg)	<0.4000	<0.4000	<0.4000

041310 103125
 J

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10955
 Unit 1 FF Outlet

**USEPA Method 5/29
 Beryllium (Be) Laboratory Parameters**

Run No.	1	2	3
Date (2010)	Mar 16	Mar 16	Mar 16
Start Time (approx.)	07:21	10:00	12:36
Stop Time (approx.)	09:32	12:14	14:47
Combined Front and Back Analyses			
m_{F-DL} Front half detection limit (μg)	0.0000	0.0000	0.0000
m_{FS} Matter collected in front half sample (μg)	<0.0500	<0.0500	<0.0500
m_{FB} Matter collected in front half blank (μg)	<0.0500	<0.0500	<0.0500
$m_{FB-allow}$ Allowable front half blank correction (μg)	0.0000	0.0000	0.0000
m_n Total matter corrected for allowable blanks (μg)	<0.0500	<0.0500	<0.0500

041310 103125
 L

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10955
 Unit 1 FF Outlet

**USEPA Method 5/29
 Cadmium (Cd) Laboratory Parameters**

Run No.		1	2	3
Date (2010)		Mar 16	Mar 16	Mar 16
Start Time (approx.)		07:21	10:00	12:36
Stop Time (approx.)		09:32	12:14	14:47
Combined Front and Back Analyses				
m_{F-DL}	Front half detection limit (μg)	0.0000	0.0000	0.0000
m_{FS}	Matter collected in front half sample (μg)	<0.2000	0.2093	<0.2000
m_{FB}	Matter collected in front half blank (μg)	<0.2000	<0.2000	<0.2000
$m_{FB-allow}$	Allowable front half blank correction (μg)	0.0000	0.0000	0.0000
m_n	Total matter corrected for allowable blanks (μg)	<0.2000	0.2093	<0.2000

041310 103125
 L

Wheelabrator North Broward, Inc.
Clean Air Project No: 10955
Unit 1 FF Outlet

**USEPA Method 5/29
Lead (Pb) Laboratory Parameters**

Run No.	1	2	3
Date (2010)	Mar 16	Mar 16	Mar 16
Start Time (approx.)	07:21	10:00	12:36
Stop Time (approx.)	09:32	12:14	14:47
Combined Front and Back Analyses			
m_{F-DL} Front half detection limit (μg)	0.0000	0.0000	0.0000
m_{FS} Matter collected in front half sample (μg)	1.5388	1.5965	1.7279
m_{FB} Matter collected in front half blank (μg)	0.4541	0.4541	0.4541
$m_{FB-allow}$ Allowable front half blank correction (μg)	0.4541	0.4541	0.4541
m_n Total matter corrected for allowable blanks (μg)	1.0847	1.1424	1.2738

041310 103125
L

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10955
 Unit 2 FF Outlet

**USEPA Method 5/29
 Mercury (Hg) Laboratory Parameters**

Detection Limits

m _{1b-DL}	Fraction 1B Detection Limit (µg)	0.1000
m _{2b-DL}	Fraction 2B Detection Limit (µg)	0.2000
m _{3a-DL}	Fraction 3A Detection Limit (µg)	0.2000
m _{3b-DL}	Fraction 3B Detection Limit (µg)	0.5000
m _{3c-DL}	Fraction 3C Detection Limit (µg)	0.4000

Blank Analysis

m _{1b-B}	Fraction 1B Blank (µg)	<0.1000
m _{2b-B}	Fraction 2B Blank (µg)	<0.2000
m _{3a-B}	Fraction 3A Blank (µg)	<0.2000
m _{3b-B}	Fraction 3B Blank (µg)	<0.5000
m _{3c-B}	Fraction 3C Blank (µg)	<0.4000
m _{total-B}	Total Blank Amount (µg)	<1.4000

Run No.	1	2	3
Date (2010)	Mar 18	Mar 18	Mar 18
Start Time (approx.)	07:09	09:49	12:27
Stop Time (approx.)	09:22	12:02	14:39

Sample Analysis

m _{1b-S}	Fraction 1B Sample (µg)	<0.1000	<0.1000	<0.1000
m _{2b-S}	Fraction 2B Sample (µg)	9.1977	9.2740	10.1318
m _{3a-S}	Fraction 3A Sample (µg)	<0.2000	<0.2000	<0.2000
m _{3b-S}	Fraction 3B Sample (µg)	<0.5000	<0.5000	<0.5000
m _{3c-S}	Fraction 3C Sample (µg)	<0.4000	<0.4000	<0.4000
m _{total-S}	Total Sample Amount (µg)	9.1977	9.2740	10.1318

Allowable Blank

m _{T-B-allow}	Total Allowable Blank (µg)	0.0000	0.0000	0.0000
------------------------	----------------------------	--------	--------	--------

Sample Corrected for Blank

m _n	Total Sample Amount (µg)	9.1977	9.2740	10.1318
----------------	--------------------------	--------	--------	---------

Sample Corrected for Blank

m _{n-1b}	Fraction 1B (µg)	<0.1000	<0.1000	<0.1000
m _{n-2b}	Fraction 2B (µg)	9.1977	9.2740	10.1318
m _{n-3a}	Fraction 3A (µg)	<0.2000	<0.2000	<0.2000
m _{n-3b}	Fraction 3B (µg)	<0.5000	<0.5000	<0.5000
m _{n-3c}	Fraction 3C (µg)	<0.4000	<0.4000	<0.4000

D41310 103648
M

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10955
 Unit 2 FF Outlet

**USEPA Method 5/29
 Beryllium (Be) Laboratory Parameters**

Run No.		1	2	3
Date (2010)		Mar 18	Mar 18	Mar 18
Start Time (approx.)		07:09	09:49	12:27
Stop Time (approx.)		09:22	12:02	14:39
Combined Front and Back Analyses				
m_{F-DL}	Front half detection limit (μg)	0.0500	0.0500	0.0500
m_{FS}	Matter collected in front half sample (μg)	<0.0500	<0.0500	<0.0500
m_{FB}	Matter collected in front half blank (μg)	<0.0500	<0.0500	<0.0500
$m_{FB-allow}$	Allowable front half blank correction (μg)	0.0000	0.0000	0.0000
m_n	Total matter corrected for allowable blanks (μg)	<0.0500	<0.0500	<0.0500

041310 103648
 N

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10955
 Unit 2 FF Outlet

**USEPA Method 5/29
 Cadmium (Cd) Laboratory Parameters**

Run No.		1	2	3
Date (2010)		Mar 18	Mar 18	Mar 18
Start Time (approx.)		07:09	09:49	12:27
Stop Time (approx.)		09:22	12:02	14:39
Combined Front and Back Analyses				
m_{F-DL}	Front half detection limit (μg)	0.2000	0.2000	0.2000
m_{FS}	Matter collected in front half sample (μg)	0.4679	<0.2000	<0.2000
m_{FB}	Matter collected in front half blank (μg)	<0.2000	<0.2000	<0.2000
$m_{FB-allow}$	Allowable front half blank correction (μg)	0.0000	0.0000	0.0000
m_n	Total matter corrected for allowable blanks (μg)	0.4679	<0.2000	<0.2000

041310 103648
 N

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10955
 Unit 2 FF Outlet

**USEPA Method 5/29
 Lead (Pb) Laboratory Parameters**

Run No.	1	2	3
Date (2010)	Mar 18	Mar 18	Mar 18
Start Time (approx.)	07:09	09:49	12:27
Stop Time (approx.)	09:22	12:02	14:39
Combined Front and Back Analyses			
m_{F-DL} Front half detection limit (μg)	0.2000	0.2000	0.2000
m_{FS} Matter collected in front half sample (μg)	2.8948	0.3759	0.4443
m_{FB} Matter collected in front half blank (μg)	0.4541	0.4541	0.4541
$m_{FB-allow}$ Allowable front half blank correction (μg)	0.4541	0.4541	0.4541
m_n Total matter corrected for allowable blanks (μg)	2.4408	<0.2000	<0.2000

041310 103648
 N

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10955
 Unit 3 FF Outlet

USEPA Method 5/29 Mercury (Hg) Laboratory Parameters

Detection Limits

m _{1b-DL}	Fraction 1B Detection Limit (µg)	0.1000
m _{2b-DL}	Fraction 2B Detection Limit (µg)	0.2000
m _{3a-DL}	Fraction 3A Detection Limit (µg)	0.2000
m _{3b-DL}	Fraction 3B Detection Limit (µg)	0.5000
m _{3c-DL}	Fraction 3C Detection Limit (µg)	0.4000

Blank Analysis

m _{1b-B}	Fraction 1B Blank (µg)	<0.1000
m _{2b-B}	Fraction 2B Blank (µg)	<0.2000
m _{3a-B}	Fraction 3A Blank (µg)	<0.2000
m _{3b-B}	Fraction 3B Blank (µg)	<0.5000
m _{3c-B}	Fraction 3C Blank (µg)	<0.4000
m _{total-B}	Total Blank Amount (µg)	<1.4000

Run No.	1	2	3
Date (2010)	Mar 17	Mar 17	Mar 17
Start Time (approx.)	06:50	09:26	11:59
Stop Time (approx.)	09:03	11:38	14:11

Sample Analysis

m _{1b-S}	Fraction 1B Sample (µg)	<0.1000	<0.1000	<0.1000
m _{2b-S}	Fraction 2B Sample (µg)	8.8257	8.9307	7.6261
m _{3a-S}	Fraction 3A Sample (µg)	<0.2000	<0.2000	<0.2000
m _{3b-S}	Fraction 3B Sample (µg)	<0.5000	<0.5000	<0.5000
m _{3c-S}	Fraction 3C Sample (µg)	<0.4000	<0.4000	<0.4000
m _{total-S}	Total Sample Amount (µg)	8.8257	8.9307	7.6261

Allowable Blank

m _{T-B-allow}	Total Allowable Blank (µg)	0.0000	0.0000	0.0000
------------------------	----------------------------	--------	--------	--------

Sample Corrected for Blank

m _n	Total Sample Amount (µg)	8.8257	8.9307	7.6261
----------------	--------------------------	--------	--------	--------

Sample Corrected for Blank

m _{n-1b}	Fraction 1B (µg)	<0.1000	<0.1000	<0.1000
m _{n-2b}	Fraction 2B (µg)	8.8257	8.9307	7.6261
m _{n-3a}	Fraction 3A (µg)	<0.2000	<0.2000	<0.2000
m _{n-3b}	Fraction 3B (µg)	<0.5000	<0.5000	<0.5000
m _{n-3c}	Fraction 3C (µg)	<0.4000	<0.4000	<0.4000

041310 103848
 N

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10955
 Unit 3 FF Outlet

**USEPA Method 5/29
 Beryllium (Be) Laboratory Parameters**

Run No.		1	2	3
Date (2010)		Mar 17	Mar 17	Mar 17
Start Time (approx.)		06:50	09:26	11:59
Stop Time (approx.)		09:03	11:38	14:11
Combined Front and Back Analyses				
m_{F-DL}	Front half detection limit (μg)	0.0500	0.0500	0.0500
m_{FS}	Matter collected in front half sample (μg)	<0.0500	<0.0500	<0.0500
m_{FB}	Matter collected in front half blank (μg)	<0.0500	<0.0500	<0.0500
$m_{FB-allow}$	Allowable front half blank correction (μg)	0.0000	0.0000	0.0000
m_n	Total matter corrected for allowable blanks (μg)	<0.0500	<0.0500	<0.0500

041310 103648
 L

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10955
 Unit 3 FF Outlet

**USEPA Method 5/29
 Cadmium (Cd) Laboratory Parameters**

Run No.		1	2	3
Date (2010)		Mar 17	Mar 17	Mar 17
Start Time (approx.)		06:50	09:26	11:59
Stop Time (approx.)		09:03	11:38	14:11
Combined Front and Back Analyses				
m_{F-DL}	Front half detection limit (μg)	0.2000	0.2000	0.2000
m_{FS}	Matter collected in front half sample (μg)	<0.2000	<0.2000	<0.2000
m_{FB}	Matter collected in front half blank (μg)	<0.2000	<0.2000	<0.2000
$m_{FB-allow}$	Allowable front half blank correction (μg)	0.0000	0.0000	0.0000
m_n	Total matter corrected for allowable blanks (μg)	<0.2000	<0.2000	<0.2000

041310 103648
 L

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10955
 Unit 3 FF Outlet

**USEPA Method 5/29
 Lead (Pb) Laboratory Parameters**

Run No.		1	2	3
Date (2010)		Mar 17	Mar 17	Mar 17
Start Time (approx.)		06:50	09:26	11:59
Stop Time (approx.)		09:03	11:38	14:11
Combined Front and Back Analyses				
m_{F-DL}	Front half detection limit (μg)	0.2000	0.2000	0.2000
m_{FS}	Matter collected in front half sample (μg)	0.7301	0.6771	0.8289
m_{FB}	Matter collected in front half blank (μg)	0.4541	0.4541	0.4541
$m_{FB-allow}$	Allowable front half blank correction (μg)	0.4541	0.4541	0.4541
m_n	Total matter corrected for allowable blanks (μg)	0.2760	0.2230	0.3748

041310 103648
 L

This Page Intentionally Left Blank


Clean Air Engineering, Inc.
500 West Wood Street
Palatine, IL 60067

Project Number: 10955

Particulate Matter, Beryllium,
Cadmium, Lead and Mercury

EPA Methods 5 & 29 Analyses

Analytical Report
14211



Element One, Inc.
5022-C Wrightsville Av., Wilmington, NC 28403
910-793-0128 FAX: 910-792-6853 e1lab@e1lab.com

The following data for Analytical Report 14211
has been reviewed for completeness, accuracy,
adherence to method protocol,
and compliance with quality assurance guidelines.

Review by:


Ana White
April 2, 2010

Report Reviewed and Finalized By:


Ken Smith, Laboratory Director
April 2, 2010

elementOne

14211 CAE M29 Report Packet Rev 4.8.10
Page 2 of 39

SUMMARY OF RESULTS

elementOne

14211 CAE M29 Report Packet Rev 4.8.10
Page 3 of 39

This Page Intentionally Left Blank

Summary of Analysis

Unit 1 - Summary of Method 29 Mercury Analysis

Run Number	Average Total Catch, µg	Front half µg	H ₂ O ₂ /HNO ₃ µg	Empty Impinger µg	KMnO ₄ µg	HCl µg
U1 FF Outlet R1 #1	7.76	< 0.1	7.79	< 0.2	< 0.5	< 0.4
#2		< 0.1	7.73	< 0.2	< 0.5	< 0.4
U1 FF Outlet R2 #1	8.82	< 0.1	8.92	< 0.2	< 0.5	< 0.4
#2		< 0.1	8.71	< 0.2	< 0.5	< 0.4
U1 FF Outlet R3 #1	9.75	< 0.1	9.77	< 0.2	< 0.5	< 0.4
#2		< 0.1	9.74	< 0.2	< 0.5	< 0.4

Unit 1 - Summary of Method 5 Particulate Analysis

Fraction	U1 FF O R1 e14211-1 Catch, mg	U1 FF O R2 e14211-2 Catch, mg	U1 FF O R3 e14211-3 Catch, mg
Filter	< 0.1	< 0.1	< 0.1
Rinse	1.0	2.7	0.5
Total PM	1.0	2.7	0.5

Unit 1 - Summary of Method 29 Metals Analysis

Element	U1 FF O R1 e14211-1 Total µg	U1 FF O R2 e14211-2 Total µg	U1 FF O R2 e14211-2 dup Total µg	U1 FF O R3 e14211-3 Total µg
Beryllium	< 0.05	< 0.05	< 0.05	< 0.05
Cadmium	< 0.2	0.208	0.211	< 0.2
Lead	1.54	1.60	1.60	1.73

Summary of Analysis

Unit 2 - Summary of Method 29 Mercury Analysis

Run Number	Average Total Catch, μg	Front half μg	H_2O_2 / HNO_3 μg	Empty Impinger μg	KMnO_4 μg	HCl μg
U2 FF Outlet R1 #1	9.20	< 0.1	9.25	< 0.2	< 0.5	< 0.4
#2		< 0.1	9.14	< 0.2	< 0.5	< 0.4
U2 FF Outlet R2 #1	9.27	< 0.1	9.28	< 0.2	< 0.5	< 0.4
#2		< 0.1	9.27	< 0.2	< 0.5	< 0.4
U2 FF Outlet R3 #1	10.1	< 0.1	10.2	< 0.2	< 0.5	< 0.4
#2		< 0.1	10.1	< 0.2	< 0.5	< 0.4

Unit 2 - Summary of Method 5 Particulate Analysis

Fraction	U2 FF O R1 e14211-4 Catch, mg	U2 FF O R2 e14211-5 Catch, mg	U2 FF O R3 e14211-6 Catch, mg
Filter	1.8	1.0	0.9
Rinse	2.8	1.7	2.1
Total PM	4.6	2.7	3.0

Unit 2 - Summary of Method 29 Metals Analysis

Element	U2 FF O R1 e14211-4 Total μg	U2 FF O R2 e14211-5 Total μg	U2 FF O R2 e14211-5 dup Total μg	U2 FF O R3 e14211-6 Total μg
Beryllium	< 0.05	< 0.05	< 0.05	< 0.05
Cadmium	0.468	< 0.2	< 0.2	< 0.2
Lead	2.89	0.382	0.370	0.444

Summary of Analysis

Unit 3 - Summary of Method 29 Mercury Analysis

Run Number	Average Total Catch, μg	Front half μg	H_2O_2 / HNO_3 μg	Empty Impinger μg	KMnO_4 μg	HCl μg
U3 FF Outlet R1 #1	8.83	< 0.1	8.80	< 0.2	< 0.5	< 0.4
#2		< 0.1	8.85	< 0.2	< 0.5	< 0.4
U3 FF Outlet R2 #1	8.93	< 0.1	8.97	< 0.2	< 0.5	< 0.4
#2		< 0.1	8.89	< 0.2	< 0.5	< 0.4
U3 FF Outlet R3 #1	7.63	< 0.1	7.64	< 0.2	< 0.5	< 0.4
#2		< 0.1	7.61	< 0.2	< 0.5	< 0.4
Field Blank #1	< 0.5	< 0.1	< 0.3	< 0.2	< 0.5	< 0.4
#2		< 0.1	< 0.3	< 0.2	< 0.5	< 0.4
Reagent Blank #1	< 0.5	< 0.1	< 0.2	< 0.2	< 0.5	< 0.4
#2		< 0.1	< 0.2	< 0.2	< 0.5	< 0.4
Reagent Blank 03.17.10 #1	< 0.5	NA	NA	NA	< 0.5	NA
#2		NA	NA	NA	< 0.5	NA
Reagent Blank 03.18.10 #1	< 0.5	NA	NA	NA	< 0.5	NA
#2		NA	NA	NA	< 0.5	NA

Summary of Analysis

Unit 3 - Summary of Method 5 Particulate Analysis

Fraction	U3 FF O R1 e14211-7 Catch, mg	U3 FF O R2 e14211-8 Catch, mg	U3 FF O R3 e14211-9 Catch, mg
Filter	0.4	< 0.1	1.0
Rinse	1.3	1.7	1.7
Total PM	1.7	1.7	2.7

Unit 3 - Summary of Method 29 Metals Analysis

Element	U3 FF O R1 e14211-7 Total µg	U3 FF O R2 e14211-8 Total µg	U3 FF O R2 e14211-8 dup Total µg	U3 FF O R3 e14211-9 Total µg
Beryllium	< 0.05	< 0.05	< 0.05	< 0.05
Cadmium	< 0.2	< 0.2	< 0.2	< 0.2
Lead	0.730	0.700	0.654	0.829

Summary of Analysis

Summary of Method 5 Particulate Analysis

Fraction	Reagent Blank e14211-11 Catch, mg
Filter	0.5
Rinse	0.8
Total PM	1.3

Summary of Method 29 Metals Analysis

Element	Field Blank e14211-10 Total µg	Reagent Blank e14211-11 Total µg
Beryllium	< 0.05	< 0.05
Cadmium	< 0.2	< 0.2
Lead	0.290	0.454

This Page Intentionally Left Blank

ANALYTICAL NARRATIVE

This Page Intentionally Left Blank

Element One Analytical Narrative

Client	Clean Air, IL	Element One #	14211
Client ID	Wheelabrator North Broward	Analyst	ESS, RDT & KMS
Method	Method 5/29	Dates Received	03/22/2010
Analytes	PM, Be, Cd, Pb & Hg	Dates Analyzed	03/25-29/2010

Summary of Analysis

The Method 5 particulate samples were analyzed in accordance with EPA Method 5 guidelines. The Method 29 samples were digested, prepared, and analyzed according to Method 29 protocol. Samples were analyzed for mercury on a PerkinElmer FIMS-100 CVAA mercury analyzer. The samples were analyzed for the other metals on a PerkinElmer ELAN 6100 ICP-MS.

Detection Limits

The FIMS-100 CVAA instrument reporting limit for mercury was 0.004 µg per aliquot analyzed. The ICP-MS instrument reporting limits were 0.25µg/L for beryllium and 1.0µg/L for the other metals.

Analysis QA/QC

Duplicate analyses relative percent difference (RPD), spike sample recovery, and second source calibration verification data are summarized in the Quality Control Section. All QA/QC data was within the criteria of the method.

The audit results are summarized in the Quality Control Summary section. Copies of the audit reporting forms are included in the analytical data section.

Additional Comments

The reported results have not been corrected for any blank or spike recovery values. The Method 5 blank correction factor has not been implemented. The ICP analysis of the Field Blank and Reagent Blank samples revealed detectable concentrations of lead. Subsequent analysis produced equivalent results.

This Page Intentionally Left Blank

QUALITY CONTROL SUMMARY

This Page Intentionally Left Blank

Summary of Quality Control Data

Mercury Duplicate Analysis RPD

(Method 29 QC limits: < %10 for RPD)

Run Number	Front half	H ₂ O ₂ /HNO ₃	Empty Imp	KMnO ₄	HCl
U1 FF Outlet R1	NA	0.8%	NA	NA	NA
U1 FF Outlet R2	NA	2.5%	NA	NA	NA
U1 FF Outlet R3	NA	0.3%	NA	NA	NA
U2 FF Outlet R1	NA	1.2%	NA	NA	NA
U2 FF Outlet R2	NA	0.1%	NA	NA	NA
U2 FF Outlet R3	NA	0.6%	NA	NA	NA
U3 FF Outlet R1	NA	0.6%	NA	NA	NA
U3 FF Outlet R2	NA	0.8%	NA	NA	NA
U3 FF Outlet R3	NA	0.5%	NA	NA	NA
Field Blank	NA	NA	NA	NA	NA
Reagent Blank	NA	NA	NA	NA	NA

Mercury Spike Recoveries

(Method 29 QC limits: ±25% for Spike Recoveries)

Run Number		Front half	H ₂ O ₂ /HNO ₄	Empty Imp	KMnO ₄	HCl
U1 FF Outlet R3	#1	102%	98%	93%	106%	102%
	#2	102%	96%	94%	106%	102%
U2 FF Outlet R3	#1	102%	99%	103%	88%	101%
	#2	102%	98%	102%	86%	99%
U3 FF Outlet R3	#1	103%	94%	103%	89%	96%
	#2	103%	92%	96%	91%	95%

Summary of Quality Control Data

Metals Duplicate Analysis RPD

(Method 29 QC limits: < 20% for RPD)

Element	U1 FF O R2 RPD	U2 FF O R2 RPD	U3 FF O R2 RPD
Beryllium	NA	NA	NA
Cadmium	1.3%	NA	NA
Lead	0.1%	3.1%	6.8%

Metals Analysis Spike Recoveries

(Method 29 QC limits: ±25% for Spike Recoveries)

Element	U1 FF O R3 Recovery	U2 FF O R3 Recovery	U3 FF O R3 Recovery
Beryllium	85%	85%	87%
Cadmium	86%	87%	88%
Lead	97%	100%	102%

Second Source Calibration Check Recoveries

(Method 29 QC limits: ±10% for Second Source Continuing Check Standard*)

Element	0.25 ppb	1 ppb	50 ppb	100 ppb*	250 ppb
Beryllium	98%	97%	98%	101%	97%
Cadmium		97%	95%	99%	94%
Lead		92%	97%	100%	94%

Summary of Quality Control Data

Summary of Method 29 Mercury Audit Results

Element	HG-6117 e14211-14 Total µg
Mercury	20.4

Summary of Method 29 Metals Audit Results

Element	Fil-6057 e14211-15 Total µg	Filter Blank e14211-16 Total µg
Beryllium	16.3	< 0.025
Cadmium	28.0	< 0.1
Lead	229	0.323

This Page Intentionally Left Blank

SAMPLE CUSTODY

elementOne

14211 CAE M29 Report Packet Rev 4.8.10

Page 15 of 39

I - 39

This Page Intentionally Left Blank

CHAIN OF CUSTODY FORM

14211

M5/29-NB-10955-001

CLIENT <u>Wheelabrator North Broward</u> PROJECT NO. <u>10955</u> PLANT <u>Same</u> DEPT. <u>66</u> PROJECT MANAGER <u>Scott Brown</u>					NO. OF CONTAINERS	ORIGINAL VOLUME	ANALYSIS REQUESTED				ADDITIONAL INFORMATION
							Hg, Be, Cd, Pb	Particulate			
CLEANAIR LAB NO.	RUN NO.	TEST LOCATION	DATE	SAMPLE MATRIX							
	1	Unit 1 FF Outlet	16-Mar	Filter e115-35	1		X	X			
	1		16-Mar	Acetone Rinse	1		X	X			
	1		16-Mar	Front-Half 0.1N HNO3 Rinse	1		X				
	1		16-Mar	Imp. 1,2,3 + 0.1N HNO3 Rinse	1		X				
	1		16-Mar	Imp. 4 + 0.1N HNO3 Rinse	1		X				
	1		16-Mar	Imp. 5,6 KMnO4+H2O Rinse	1		X				
	1		16-Mar	Imp. 5,6 HCl Rinse	1		X				
	2		16-Mar	Filter e99-23	1		X	X			
	2		16-Mar	Acetone Rinse	1		X	X			
	2		16-Mar	Front-Half 0.1N HNO3 Rinse	1		X				
	2		16-Mar	Imp. 1,2,3 + 0.1N HNO3 Rinse	1		X				
	2		16-Mar	Imp. 4 + 0.1N HNO3 Rinse	1		X				
	2		16-Mar	Imp. 5,6 KMnO4+H2O Rinse	1		X				
	2	V	16-Mar	Imp. 5,6 HCl Rinse			X				
Relinquished by: (Signature)			Date / Time	Received by: (Signature)		Date / Time	Relinquished by: (Signature)		Date / Time		
<i>Scott Brown</i>			3/19/10 11:00								
Courier:			Date / Time	Relinquished by: (Signature)		Date / Time	Received for Analysis by:		Date / Time		
							<i>Scott Brown</i>		3/22/10 0917		
Special Handling Instructions				This form was completed by:				 500 West Wood Street Palatine, IL 60067 (800) 627-0033 ph (847) 991-3385 fax www.cleanair.com			
Forwarding Lab: <u>Element One</u>				Scott Brown							
<u>Wilmington, NC 28403</u>				Signature _____ Date <u>3/19/10</u>							
PO Number: _____											

All samples received in good condition in Fisherbrand + QEC Level 2 containers.
 No empty container received. ZFB

CHAIN OF CUSTODY FORM

14211 M5/29-NB-10955-003

CLIENT <u>Wheelabrator North Broward</u>				PROJECT NO. <u>10955</u>		NO. OF CONTAINERS	ORIGINAL VOLUME	ANALYSIS REQUESTED				ADDITIONAL INFORMATION				
PLANT <u>Same</u>				DEPT. <u>66</u>				<table border="1" style="width:100%; height: 40px;"> <tr> <td style="width: 25%; text-align: center;">Hg, Be, Cd, Pb</td> <td style="width: 25%; text-align: center;">Particulate</td> <td style="width: 25%;"></td> <td style="width: 25%;"></td> </tr> </table>					Hg, Be, Cd, Pb	Particulate		
Hg, Be, Cd, Pb	Particulate															
PROJECT MANAGER <u>Scott Brown</u>																
CLEANAIR																
LAB NO.	RUN NO.	TEST LOCATION	DATE	SAMPLE MATRIX												
	1	Unit 2 FF Outlet	18-Mar	Filter e115-30	1		X	X								
	1		18-Mar	Acetone Rinse	1		X	X								
	1		18-Mar	Front-Half 0.1N HNO3 Rinse	1		X									
	1		18-Mar	Imp. 1,2,3 + 0.1N HNO3 Rinse	1		X									
	1		18-Mar	Imp. 4 + 0.1N HNO3 Rinse	1		X									
	1		18-Mar	Imp. 5,6 KMnO4+H2O Rinse	1		X									
	1		18-Mar	Imp. 5,6 HCl Rinse	1		X									
	2		18-Mar	Filter e115-31	1		X	X								
	2		18-Mar	Acetone Rinse	1		X	X								
	2		18-Mar	Front-Half 0.1N HNO3 Rinse	1		X									
	2		18-Mar	Imp. 1,2,3 + 0.1N HNO3 Rinse	1		X									
	2		18-Mar	Imp. 4 + 0.1N HNO3 Rinse	1		X									
	2		18-Mar	Imp. 5,6 KMnO4+H2O Rinse	1		X									
	2	V	18-Mar	Imp. 5,6 HCl Rinse			X									
Relinquished by: (Signature) <i>Scott Brown</i>			Date / Time 3/19/10 11:40		Received by: (Signature) <i>Scott Brown</i>			Date / Time 3/22/10 097		Relinquished by: (Signature)		Date / Time				
Courier:			Date / Time		Relinquished by: (Signature)			Date / Time		Received for Analysis by: <i>Scott Brown</i>		Date / Time				
Special Handling Instructions					This form was completed by: Scott Brown Signature <i>Scott Brown</i> Date 3/19/10			 <p>500 West Wood Street Palatine, IL 60067 (800) 627-0033 ph (847) 991-3385 fax www.cleanair.com</p> <p><small>LD5001A_1-COC Petrolco_M08_Jul 2002 Copyright©2002 Clean Air Engineering Inc</small></p>								
Forwarding Lab: <u>Element One</u> <u>Wilmington, NC 28403</u>					PO Number: _____											

CHAIN OF CUSTODY FORM

14211 M5/29-NB-10955-005

CLIENT <u>Wheelabrator North Broward</u>	PROJECT NO. <u>10955</u>	NO. OF CONTAINERS	ORIGINAL VOLUME	ANALYSIS REQUESTED				ADDITIONAL INFORMATION
PLANT <u>Same</u>	DEPT. <u>66</u>							
PROJECT MANAGER <u>Scott Brown</u>								

CLEANAIR		TEST LOCATION	DATE	SAMPLE MATRIX	NO. OF CONTAINERS	ORIGINAL VOLUME	ANALYSIS REQUESTED				ADDITIONAL INFORMATION
LAB NO.	RUN NO.						Hg, Be, Cd, Pb	Particulate			
	1	Unit 3 FF Outlet	17-Mar	Filter e115-26	1		X	X			
	1		17-Mar	Acetone Rinse	1		X	X			
	1		17-Mar	Front-Half 0.1N HNO3 Rinse	1		X				
	1		17-Mar	Imp. 1,2,3 + 0.1N HNO3 Rinse	1		X				
	1		17-Mar	Imp. 4 + 0.1N HNO3 Rinse	1		X				
	1		17-Mar	Imp. 5,6 KMnO4+H2O Rinse	1		X				
	1		17-Mar	Imp. 5,6 HCl Rinse	1		X				
	2		17-Mar	Filter e115-27	1		X	X			
	2		17-Mar	Acetone Rinse	1		X	X			
	2		17-Mar	Front-Half 0.1N HNO3 Rinse	1		X				Per Scott via phone
	2		17-Mar	Imp. 1,2,3 + 0.1N HNO3 Rinse	1		X				03-23-10, use Run #
	2		17-Mar	Imp. 4 + 0.1N HNO3 Rinse	1		X				on lid. <i>SB</i>
	2		17-Mar	Imp. 5,6 KMnO4+H2O Rinse	1		X				
	2	V	17-Mar	Imp. 5,6 HCl Rinse			X				

Relinquished by: (Signature) <i>Scott Brown</i>	Date / Time 3/19/10 11:00	Received by: (Signature) <i>Scott Brown</i>	Date / Time 3/19/10	Relinquished by: (Signature) <i>Scott Brown</i>	Date / Time 3/22/10 09:17
Courier:	Date / Time	Relinquished by: (Signature)	Date / Time	Received for Analysis by: <i>Scott Brown</i>	Date / Time

Special Handling Instructions	This form was completed by: Scott Brown Signature <i>Scott Brown</i> Date 3/19/10	 CleanAir ENGINEERING <small>LD5001A_1-COC Palatine_M29_AJ 2002 Copyright © 2007 Clean Air Engineering Inc</small>
Forwarding Lab: <u>Element One</u> <u>Wilmington, NC 28403</u>		500 West Wood Street Palatine, IL 60067 (800) 627-0033 ph (847) 991-3385 fax www.cleanair.com
PO Number: _____		

CHAIN OF CUSTODY FORM

14211 M5/29-NB-10955-006

CLIENT <u>Wheelabrator North Broward</u>	PROJECT NO. <u>10955</u>	NO. OF CONTAINERS	ORIGINAL VOLUME	ANALYSIS REQUESTED				ADDITIONAL INFORMATION
PLANT <u>Same</u>	DEPT. <u>66</u>			Hg, Be, Cd, Pb	Particulate			
PROJECT MANAGER <u>Scott Brown</u>								

CLEANAIR LAB NO.	RUN NO.	TEST LOCATION	DATE	SAMPLE MATRIX					
	3	Unit 3 FF Outlet	17-Mar	Filter e115-	1		X	X	
	3		17-Mar	Acetone Rinse	1		X	X	
	3		17-Mar	Front-Half 0.1N HNO3 Rinse	1		X		
	3		17-Mar	Imp. 1,2,3 + 0.1N HNO3 Rinse	1		X		
	3		17-Mar	Imp. 4 + 0.1N HNO3 Rinse	1		X		
	3		17-Mar	Imp. 5,6 KMnO4+H2O Rinse	1		X		
	3	V	17-Mar	Imp. 5,6 HCl Rinse	1		X		
	NA	Reagent Blank	17-Mar	4% KMnO4 / 10% H2SO4	1		X		
	NA	Reagent Blank	18-Mar	4% KMnO4 / 10% H2SO4	1		X		

Relinquished by: (Signature) <i>Scott Brown</i>	Date / Time 3/19/10 11:00	Received by: (Signature) <i>Scott Brown</i>	Date / Time 3/19/10	Relinquished by: (Signature)	Date / Time
Counter:	Date / Time	Relinquished by: (Signature)	Date / Time	Received for Analysis by: <i>Scott Brown</i>	Date / Time 3/22/10 09:17

Special Handling Instructions	This form was completed by: Scott Brown Signature _____ Date 3/19/10	 500 West Wood Street Palatine, IL 60067 (800) 627-0033 ph (847) 991-3385 fax www.cleanair.com
Forwarding Lab: <u>Element One</u> <u>Wilmington, NC 28403</u>	PO Number: _____	

CHAIN OF CUSTODY FORM

14211

M5/28-NB-10955-007

CLIENT Wheelabrator North Broward
 PLANT Same
 PROJECT MANAGER Scott Brown

PROJECT NO. 10955
 DEPT. 66

NO. OF CONTAINERS

ORIGINAL VOLUME

ANALYSIS REQUESTED

Hg, Be, Cd, Pb

ADDITIONAL INFORMATION

CLEANAIR

LAB NO.	RUN NO.	TEST LOCATION	DATE	SAMPLE MATRIX
	NA	Field Blank	16-Mar	Filter e115-29
	NA		16-Mar	Front Half Acetone Rinse
	NA		16-Mar	Front-Half 0.1N HNO3 Rinse
	NA		16-Mar	Imp. 1,2,3 + 0.1N HNO3 Rinse
	NA		16-Mar	Imp. 4 + 0.1N HNO3 Rinse
	NA		16-Mar	Imp. 5,6 KMnO4+H2O Rinse
	NA	V	16-Mar	Imp. 5,6 HCl Rinse
	NA	Reagent Blanks	16-Mar	4% KMnO4 / 10% H2SO4
	NA		16-Mar	3 Quartz Filters
	NA		16-Mar	0.1 N HNO3
	NA		16-Mar	DI H2O
	NA		16-Mar	5% HNO3 / 10% H2O2
	NA		16-Mar	Acetone
	NA	V	16-Mar	8N HCl / DI H2O

Relinquished by: (Signature): <i>Scott Brown</i>	Date / Time 3/19/10 11:07	Received by: (Signature)	Date / Time	Relinquished by: (Signature)	Date / Time
Courier:	Date / Time	Relinquished by: (Signature)	Date / Time	Received for Analysis by: <i>Scott Brown</i>	Date / Time 3/22/10 09:17

Special Handling Instructions	This form was completed by: Scott Brown Signature: <i>Scott B</i> Date: 3/19/10	 500 West Wood Street Palatine, IL 60067 (800) 627-0033 ph (847) 991-3385 fax www.cleanair.com
Forwarding Lab: Element One Wilmington, NC 28403	PO Number:	

ANALYTICAL DATA

elementOne

14211 CAE M29 Report Packet Rev 4.8.10

Page 24 of 39

1 - 49

This Page Intentionally Left Blank

Analytical Calculations

Metals-

$$\text{Element Results } (\mu\text{g}) = \text{ICP Results } (\mu\text{g/L}) * \text{Dilution} * \text{Final Volume (L)}$$

Where-

ICP Results= Raw sample concentration (ppb)--*ICP-Data Sheet*

Dilution= $\frac{\text{Diluted Volume}}{\text{Aliquot}}$ --*ICP-MS Run Sheet*

Final Volume= FH= Final Volume (FV)--*Sample Submission*

BH= $\frac{\text{Received Volume (BV)} * \text{Final Volume (FV)}}{\text{Aliquot (Used)}}$ --*Sample Submission*

Combined Results= FH+BH

Mercury-

$$\text{Mercury Results } (\mu\text{g}) = \frac{\text{CVAA Results } (\mu\text{g}) * \text{Final Volume (ml)}}{\text{Aliquot (ml)}}$$

Where-

CVAA Results= Raw sample reading (μg)--*Hg-Data Sheet*

Aliquot= Sample Aliquot (Alq.)--*Hg-Data Sheet*

Final Volume= Final Volume (FV)*--*Sample Submission*

* With the exception of the BH fraction where-
= Received Volume (BV)--*Sample Submission*

Analytical Calculations

Spike Recovery-

$$\text{Spike (\%)} = \frac{(\text{Spiked Result } (\mu\text{g/L}) - \text{Sample Result } (\mu\text{g/L}))}{\text{Spike Amount } (\mu\text{g/L})} \times 100$$

Where-

Spike Result = Raw sample concentration (ppb)--*ICP-Data Sheet*

Sample Result = Raw sample concentration (ppb)--*ICP-Data Sheet*

Spike Amount--*ICP-MS Spike Table*

Duplicate Analysis RPD-

$$\text{RPD (\%)} = \frac{(\text{Duplicate Result } (\mu\text{g/L}) - \text{Sample Result } (\mu\text{g/L}))}{\text{Average } (\mu\text{g/L})} \times 100$$

Where-

Sample Result and Duplicate Results=Raw sample concentration (ppb)--*ICP-Data Sheet*

$$\text{Average} = \frac{(\text{Duplicate} + \text{Sample Results})}{2}$$

elementOne AIR TESTING SAMPLE SUBMISSION FORM Lab ID 14211



Analysis Due Date 03.29.10
QA/QC/Report Due Date 03.31.10

Client	Clean Air IL
Project No	10955

Date Rec	03.22.10
Time Rec	0917

HNO ₃ Lot: 1109630	HF Lot: 5108072	HCl Lot: 4109630	Ref. Method: 29 / 5
Volume Marked <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	Volume Loss Y / <input type="checkbox"/> N?		

Sample Identification

1	U1 FF Outlet R1	4	U2 FF Outlet R1	7	U3 FF Outlet R1
2	U1 FF Outlet R2	5	U2 FF Outlet R2	8	U3 FF Outlet R2
	U1 FF Outlet R2 Duplicate		U2 FF Outlet R2 Duplicate		U3 FF Outlet R2 Duplicate
3	U1 FF Outlet R3	6	U2 FF Outlet R3	9	U3 FF Outlet R3
	U1 FF Outlet R3 Spike		U2 FF Outlet R3 Spike		U3 FF Outlet R3 Spike

10	Field Blank	12	Reagent Blank 03.17.10 (p.2)	14	M29-4437-02/HG-6117 (p.2)
11	Reagent Blank (p.2)	13	Reagent Blank 03.18.10 (p.2)	15	M29-4437-01/Fil-6057 (p.2)
				16	Audit Filter Blank (p.2)

Analyses Requested	Samples 1-14	Hg
	Samples 1-18, 15-16	Be, Cd, Pb
	Samples 1-11	PM

Runs / FB	Fil / Ace (FH)		HNO ₃ (FH)			5% HNO ₃ /10% H ₂ O ₂ (BH)			HNO ₃ (A)		KMnO ₄ (B)		HCl (C)		
	pH <2.0	Y / N	pH <2.0	Y / N		pH <2.0	Y / N		pH <2.0	Y / N	pH <2.0	Y / N	pH <2.0	Y / N	
Lab ID	Fil ID	BV ml	BV ml	FV ml	BV ml	Used	FV ml	BV ml	FV ml	BV ml	FV ml	BV ml	FV ml	BV ml	FV ml
1	115-35		160	100	720	360	50	109	200	380	500	230	400		
2.D	115-36		150		720	360		110		375		230			
3.S	115-37		130		710	355		109		372.5		230			
4	115-30		150		750	375		110		370		230			
5.D	115-31		148		710	355		112		410		230			
6.S	115-32		150		760	380		109		380		230			
7	115-26		160		756	375		110		380		230			
8.D	115-27		130		780	390		110		387.5		230			
9.S	115-28		135		750	375		110		375		230			
10	115-29		150		300	150		112		380		230			

Lab Communications

Per Scott via phone, use Run number on lid. LLB 02.23.10 1135.

SS Page 1 of 2
3/23/2010 3:52:42 PM
SS by LLB
Labeled By/Date 3-23-10 GSS

FH Prep By/Date 3-25-10 ES
BH/FH Prep By/Date 3-25-10 ES
PM Prep By / Date 3-25-10 GSS

A Prep By/Date ES 3-24-10
B Prep By/Date MGM 3/24/10
C Prep By/Date ES 3-26-10
ID Verification By/Date MGM 3/24/10

14211-14

**Method 29 Compliance Audit Material
(Mercury Acidified Aqueous Solution)**

REPORTING FORM: To be completed by laboratory

Request Number/Sample Number: M29-4437-02/HG-6117 Date Issued: 03/10/10

Auditee:

Company: Element One, Inc.
5022-C Wrightsville Av.
Address: Wilmington, NC 28403
Phone 910-793-0128 - FAX 792-6853
Attention of: e1lab@e1lab.com Phone: _____

Requestor:

Agency: Florida DEP - SED
Address: 400 N. Congress Avenue, Suite 200, West Palm Beach, FL 33401
Attention of: Lee C. Hoefert Phone: 561-681-6626

Project Name: Wheelabrator North Broward

Audit Results (Results in µg)

<u>Compound</u>	<u>Result</u>
Mercury	20.4 Total µg

**Method 29 Audit Material
(Multi-Metals Spiked Filter)**

14211 - 15
14211 - 16

REPORTING FORM: To be completed by laboratory

Request Number/Sample Number: M29-4437-01/Fil-6057 Date Issued: 03/10/10

Auditee:

Company: Element One, Inc.
5022-C Wrightsville Av.
Address: Wilmington, NC 28403
Attention of: Phone 910-793-0128 - FAX 792-6853 Phone: _____
e1lab@e1lab.com

Requestor:

Agency: Florida DEP - SED
Address: 400 N. Congress Avenue, Suite 200, West Palm Beach, FL 33401
Attention of: Lee C. Hoefert Phone: 561-681-6626

Project Name: Wheelabrator North Broward

Audit Results (Results in µg)

Analyte	Audit Sample Result	Blank Filter Result
Beryllium	16.3 Total µg	< 0.025 Total µg
Cadmium	28.0 Total µg	< 0.1 Total µg
Lead	229 Total µg	0.323 Total µg

elementOne

Method 5 Particulate

Lab # 14211

Clean AIR

Page 1 of 2

Balance checks Date: 3-26-10 2 g = 0.0488
 Date: 3-27-10 2g = 0.0488
 Date:

Acetone Concentration
 3.28E-05 mg/mg

Filters											
Sample ID#	Filter ID	Bag ID	A		B		B		B		Catch Description and Loading
			Bag Tare, g	Date - 3/26/10 Initials - RDT		Date - 3/27/10 Initials - RDT		Date initials			
				Time	Bag & Filter Weight, g	Time	Bag & Filter Weight, g	Time	Bag & Filter Weight, g		
14211-1	e115-35	85	4.1326	5:30	4.4812	3:30	4.4813				
14211-2	e115-36	1988	3.8453	5:30	4.2098	3:30	4.2101				
14211-3	e115-37	2335	4.0360	5:30	4.3844	3:30	4.3846				
14211-4	e115-30	1474	3.9655	5:30	4.3287	3:30	4.3287				
14211-5	e115-31	210	4.0561	5:30	4.4037	3:30	4.4038				
14211-6	e115-32	801	3.5038	5:30	3.8699	3:30	3.8698				
Client Blk HERE	e115-39	50	4.2837	5:30	4.6443	3:30	4.6440				
E1 Blank											

Acetone Rinses											
Sample ID#	Sample Volume, ml	Bag ID	C		D		D		D		Catch Description and Loading
			Bag Tare, g	Date - 3/26/10 Initials - RDT		Date - 3/27/10 Initials - RDT		Date initials			
				Time	Bag & Sample Weight, g	Time	Bag & Sample Weight, g	Time	Bag & Sample Weight, g		
14211-1	88	41	4.4040	5:30	4.4052	3:30	4.4050				
14211-2	90	3822	3.7405	5:30	3.7433	3:30	3.7432				
14211-3	88	1	4.5024	5:30	4.5033	3:30	4.5029				
14211-4	98	227	3.7629	5:30	3.7658	3:30	3.7657				
14211-5	87	785	4.1118	5:30	4.1140	3:30	4.1135				
14211-6	84	205	3.7688	5:30	3.7689	3:30	3.7689				
Client Ace Blk HERE	139	2414	3.3056	5:30	3.3064	3:30	3.3066				
E1 Acetone Blank	100	1032	4.0256	5:30	4.0260	3:30	4.0262				

Total Catches										
Sample ID#	Filter ID	Filter Tare, g	Final Filter + Catch, g	Filter Catch, mg	Acetone Bag ID	Bag Tare, g	Final Bag + Acetone Weight, g	Acetone blank, mg	Acetone Catch, mg	Total Catch, mg
14211-1	e115-35	0.3487	4.4812	< 0.1	41	4.404	4.4050	0.0	1.0	1.0
14211-2	e115-36	0.3653	4.2098	< 0.1	3822	3.7405	3.7432	0.0	2.7	2.7
14211-3	e115-37	0.3494	4.3844	< 0.1	1	4.5024	4.5029	0.0	0.5	0.5
14211-4	e115-30	0.3614	4.3287	1.8	227	3.7629	3.7657	0.0	2.8	4.6
14211-5	e115-31	0.3485	4.4038	1.0	785	4.1118	4.1135	0.0	1.7	2.7
14211-6	e115-32	0.3649	3.8698	0.9	205	3.7688	3.7689	0.0	2.1	3.0
Client Ace Blk HERE	e115-39	0.3598	4.6440	0.5	2414	3.3056	3.3064	0.0	0.8	1.3
E1 Acetone					1032	4.0256	4.0260	0.0	0.4	0.4

Element One, Inc. Form 123 - Revision 1.10.23.07

elementOne

14211 CAE M29 Report Packet Rev 4.8.10

Page 31 of 39

1 - 57

elementOne

Method 5 Particulate

Lab # 14211

Clean Air

Page 2 of 2

Balance checks Date: 3-26-10 2 g = 0.0498
 Date: 3-27-10 2g = 0.0498
 Date:

Acetone Concentration
 3.28E-05 mg/mg

Filters										
Sample ID #	Filter ID	Bag ID	A	B		B		B		Catch Description and Loading
			Bag Tare, g	Date - 3/26/10 Intake - RDT		Date - 3/27/10 Intake - RDT		Date Intake		
				Time	Bag & Filter Weight, g	Time	Bag & Filter Weight, g	Time	Bag & Filter Weight, g	
14211-7	e115-26	2381	3.7098	5:30	4.0807	3:30	4.0802			
14211-8	e115-27	908	4.0480	5:30	4.3971	3:30	4.3974			
14211-9	e115-28	23	4.5980	5:30	4.9716	3:30	4.9715			
14211-10	e115-29	201	4.0587	5:30	4.4074	3:30	4.4071			
Client Blk HERE	e115-39	50	4.2837	5:30	4.6443	3:30	4.6440			
E1 Blank										

Acetone Rinses										
Sample ID #	Sample Volume, ml	Bag ID	C	D		D		D		Catch Description and Loading
			Bag Tare, g	Date - 3/26/10 Intake - RDT		Date - 3/27/10 Intake - RDT		Date Intake		
				Time	Bag & Sample Weight, g	Time	Bag & Sample Weight, g	Time	Bag & Sample Weight, g	
14211-7	98	922	3.7252	5:30	3.7265	3:30	3.7265			
14211-8	70	912	4.0102	5:30	4.0119	3:30	4.0119			
14211-9	81	2377	3.6975	5:30	3.6997	3:30	3.6992			
14211-10	78	1026	4.0320	5:30	4.0340	3:30	4.0340			
Client Ace Blk HERE	139	2414	3.3058	5:30	3.3064	3:30	3.3066			
E1 Acetone Blank	100	1032	4.0258	5:30	4.0260	3:30	4.0262			

Total Catches										
Sample ID #	Filter ID	Filter Tare, g	Final Filter + Catch, g	Filter Catch, mg	Acetone Bag ID	Bag Tare, g	Final Bag + Acetone Weight, g	Acetone blank, mg	Acetone Catch, mg	Total Catch, mg
14211-7	e115-26	0.3700	4.0802	0.4	922	3.7252	3.7265	0.0	1.3	1.7
14211-8	e115-27	0.3520	4.3971	< 0.1	912	4.0102	4.0119	0.0	1.7	1.7
14211-9	e115-28	0.3745	4.6715	1.0	2377	3.6975	3.6992	0.0	1.7	2.7
Client Ace Blk HERE	e115-39	0.3598	4.044	0.5	2414	3.3058	3.3064	0.0	0.8	1.3
E1 Acetone					1032	4.0258	4.0260	0.0	0.4	0.4

Element One, Inc. Form 123 - Revision 1.10.23.07

elementOne

14211 CAE M29 Report Packet Rev 4.9.10

Page 32 of 39

1 - 58

Sample/Batch Report

User Name: icp

Computer Name: D8D4DWD1

Sample File: C:\elandata_icp\Sample\7.sam

Report Date/Time: Tuesday, March 30, 2010 09:07:56

A/S Loc.	Batch ID	Sample ID	Description	Sample Type	Init. Quant.	Prep. Vol.	Aliquot Vol.	Diluted Vol.	Solids Ratio
	5	QC Std 2	CAE	Sample					
62	X1	14211-1	CAE	Sample					
63	X1	14211-2	CAE	Sample					
64	X1d	14211-2	CAE	Duplicate of 3					
65	X1	14211-3	CAE	Sample					
66	X1s	14211-3	CAE	Spike - 1 of 5					
67	X1	14211-4	CAE	Sample					
68	X1	14211-5	CAE	Sample					
69	X1d	14211-5	CAE	Duplicate of 8					
70	X1	14211-6	CAE	Sample					
71	X1s	14211-6	CAE	Spike - 1 of 10					
72	X1	14211-7	CAE	Sample					
73	X1	14211-8	CAE	Sample					
74	X1d	14211-8	CAE	Duplicate of 13					
75	X1	14211-9	CAE	Sample					
76	X1s	14211-9	CAE	Spike - 1 of 15					
77	X1	14211-10	CAE	Sample					
78	x1	14211-11	CAE	Sample					
79	x5	14211-15	CAE	Sample					
80	x20	14211-15	CAE	Sample					
81	x50	14211-15	CAE	Sample					
82	x1	14211-16	CAE	Sample					
11	Be DL	Be DL 0.25	CAE	Sample					

Dataset Report

User Name: icp
Computer Name: D8D4DWD1
Dataset File Path: C:\elandata_icp\DataSet\032910-2\
Report Date/Time: Tuesday, March 30, 2010 09:07:45

Autosampler Position: 3

The Dataset

Time	Sample ID	Batch ID	Read Type	Description	Init. Quant	Prep. Vol.	Aliquot. Vol.	Diluted V
16:39:29 Mon 29-Mar-10	Blank		Blank					
16:41:25 Mon 29-Mar-10	Standard 1		Standard #1					
16:43:22 Mon 29-Mar-10	Standard 2		Standard #2					
16:45:20 Mon 29-Mar-10	Standard 3		Standard #3					
16:47:17 Mon 29-Mar-10	QC Std 1		QC Std #1					
16:49:15 Mon 29-Mar-10	QC Std 2		QC Std #2					
16:51:13 Mon 29-Mar-10	QC Std 3		QC Std #3					
16:53:10 Mon 29-Mar-10	QC Std 4		QC Std #4					
16:55:07 Mon 29-Mar-10	QC Std 5		QC Std #5					
16:57:04 Mon 29-Mar-10	QC Std 6		QC Std #6					
16:59:02 Mon 29-Mar-10	QC Std 7		QC Std #7					
17:01:00 Mon 29-Mar-10	QC Std 8		QC Std #8					
17:02:59 Mon 29-Mar-10	QC Std 9		QC Std #9					
17:04:58 Mon 29-Mar-10	QC Std 10		QC Std #10					
17:06:57 Mon 29-Mar-10	QC Std 2		Sample	CAE				
17:08:55 Mon 29-Mar-10	14211-1	X1	Sample	CAE				
17:10:53 Mon 29-Mar-10	14211-2	X1	Sample	CAE				
17:12:52 Mon 29-Mar-10	14211-2	X1d	Duplicate of 17	CAE				
17:14:50 Mon 29-Mar-10	14211-3	X1	Sample	CAE				
17:16:48 Mon 29-Mar-10	14211-3	X1s	Spike - 1 of 19	CAE				
17:18:46 Mon 29-Mar-10	14211-4	X1	Sample	CAE				
17:20:44 Mon 29-Mar-10	14211-5	X1	Sample	CAE				
17:22:42 Mon 29-Mar-10	14211-5	X1d	Duplicate of 22	CAE				
17:24:41 Mon 29-Mar-10	14211-6	X1	Sample	CAE				
17:26:39 Mon 29-Mar-10	14211-6	X1s	Spike - 1 of 24	CAE				
17:28:43 Mon 29-Mar-10	14211-7	X1	Sample	CAE				
17:30:42 Mon 29-Mar-10	14211-8	X1	Sample	CAE				
17:32:41 Mon 29-Mar-10	14211-8	X1d	Duplicate of 27	CAE				
17:34:39 Mon 29-Mar-10	14211-9	X1	Sample	CAE				
17:36:38 Mon 29-Mar-10	14211-9	X1s	Spike - 1 of 29	CAE				
17:38:36 Mon 29-Mar-10	14211-10	X1	Sample	CAE				
18:03:52 Mon 29-Mar-10	14211-11	x1	Sample	CAE				
18:05:50 Mon 29-Mar-10	14211-15	x5	Sample	CAE				
18:07:49 Mon 29-Mar-10	14211-15	x20	Sample	CAE				
18:09:47 Mon 29-Mar-10	14211-15	x50	Sample	CAE				
18:11:45 Mon 29-Mar-10	14211-16	x1	Sample	CAE				
18:13:44 Mon 29-Mar-10	Be DL 0.25	Be DL	Sample	CAE				
18:15:41 Mon 29-Mar-10	QC Std 1		QC Std #1					
18:17:38 Mon 29-Mar-10	QC Std 4		QC Std #4					

elementOne
Analyst:-KMS--

ICP-MS RUN SHEET
3/30/2010

Job Number:
~~14211~~
14211 *des*

A/S Loc.	Dilution	Sample ID	Client	Type	Weight (g)	Prep Vol (ml)
5		QC Std 2	CAE	Sample		
62	X1	14211-1	CAE	Sample		
63	X1	14211-2	CAE	Sample		
64	X1d	14211-2	CAE	Duplicate of 3		
65	X1	14211-3	CAE	Sample		
66	X1s	14211-3	CAE	Spike - 1 of 5		
67	X1	14211-4	CAE	Sample		
68	X1	14211-5	CAE	Sample		
69	X1d	14211-5	CAE	Duplicate of 8		
70	X1	14211-6	CAE	Sample		
71	X1s	14211-6	CAE	Spike - 1 of 10		
72	X1	14211-7	CAE	Sample		
73	X1	14211-8	CAE	Sample		
74	X1d	14211-8	CAE	Duplicate of 13		
75	X1	14211-9	CAE	Sample		
76	X1s	14211-9	CAE	Spike - 1 of 15		
77	X1	14211-10	CAE	Sample		
78	x1	14211-11	CAE	Sample		
79	x5	14211-15	CAE	Sample		
80	x20	14211-15	CAE	Sample		
81	x50	14211-15	CAE	Sample		
82	x1	14211-16	CAE	Sample		
11	Be DL	Be DL 0.25	CAE	Sample		

Spikes are post at 0.02mL of 25ppm spiking solutions lot 021410-ABCD & F in a final volume of 10mL						
Submitted for QC by:	Date/Time:		QC Review By:	Date/Time:		
KMS	3/30/10 9:11		<i>des</i>	3	31	10 4:20 pm
Re-Test Required:	No:	Yes:	Comments:			
Resubmitted for QC by:	Date/Time:		QC Review:	By:	Date/Time:	

ElementOne Instrument Control Session - [Quantitative Analysis Method - C:\data\data_tcp\Method02.mth(Modified)]

File Edit Analysis Options Automation Window Help

Method Sample Dataset Realtime Interactive CallView RptOption RptView SmartTune Optimize Tuning Instrument Devices Scheduler

Timing Processing Equation Calibration Sampling QC

Sample	Mass (amu)	Spike Table 1 (Conc.)	Spike Table 1 Det. Limit (Conc.)	Spike Table 2 (Conc.)	Spike Table 2 Det. Limit (Conc.)	Spike Table 3 (Conc.)	Spike Table 3 Det. Limit (Conc.)	Spike Table 4 (Conc.)	Spike Table 4 Det. Limit (Conc.)	Spike Table 5 (Conc.)
1	9.11127	50	1	25	1	100	1			
2	44.0259	50	1	25	1	100	1			
3	110.901	50	1	25	1	100	1			
4	115.934	50	1	25	1	100	1			
5	207.097	50	1	25	1	100	1			
6	82.011									

QC Stds. QC Measurement Frequency QC Std. Int. Stds. Calibration Stds. Sample Int. Stds. Sample Spike Dilution Duplicate Spike Tables QC Action Controls Autosampler

Tuesday, Mar 30, 2010 09:08 AM

ICP Standards and QC Standards Values Table

Element or Test	Mass	Symbol	Std.#1 ppb	Std.#2 ppb	Std.#3 ppb	QC #1	QC #2	QC #3	QC #4	QC #6 A	QC #7 AB	QC #8 .25	QC #9 LRB	QC #10 LRB+	QC #11 LRB+
Lithium	6	<i>Li</i>													
Lithium	7	Li	1	100	500	0	1	250	100				0	50	100
Beryllium	9	Be	1	100	500	0	1	250	100			0.25	0	50	100
Boron	10	<i>B</i>	1	50	100	0	1	250	100				0	50	100
Boron	11	B	1	50	100	0	1	250	100				0	50	100
Sodium	23	Na	20	1100	5500	0	21	2500	1100				0	718	
Magnesium	24	Mg	20	1100	5500	0	21	2500	1100				0	550	
Magnesium	25	<i>Mg</i>	20	1100	5500	0	21	2500	1100				0	550	
Aluminum	27	Al	1	100	500	0	1	250	100				0	50	100
Phosphorus	31	P	20	1000	5000	0	20	2500	1000				0	200	
Potassium	39	K	20	1100	5500	0	21	2500	1100				0	500	
Calcium	44	Ca	50	1100	5500	0	21	2500	1100				0	550	
Scandium	45														
Titanium	47	Ti	1	100	500	0	1	250	100				0	50	100
Titanium	49	Ti	1	100	500	0	1	250	100				0	50	100
Vanadium	51	V	1	100	500	0	1	250	100	0	20		0	50	100
Vanadium	51	V	1	100	500	0	1	250	100	0	20		0	50	100
Chromium	52	Cr	1	100	500	0	1	250	100		10		0	50	100
Chromium	53	<i>Cr</i>	1	100	500	0	1	250	100		10		0	50	100
Iron	54	Fe	20	1100	5500	0	21	2500	1100	0			0		
Manganese	55	Mn	1	100	500	0	1	250	100	0	10		0	50	100
Iron	57	Fe	20	1100	5500	0	21	2500	1100	0			0		
Cobalt	59	Co	1	100	500	0	1	250	100	0	20		0	50	100
Nickel	60	Ni	1	100	500	0	1	250	100	0	20		0	50	100
Copper	63	Cu	1	100	500	0	1	250	100	0	10		0	50	100
Copper	65	Cu	1	100	500	0	1	250	100	0	10		0	50	100
Zinc	66	Zn	1	100	500	0	1	250	100	0	10		0	50	100
Zinc	67	Zn	1	100	500	0	1	250	100	0	10		0	50	100
Zinc	68	Zn	1	100	500	0	1	250	100	0	10		0	50	100
Germanium	72	Ge	1	100	500	0	1	250	100				0	50	100
Arsenic	75	As	1	100	500	0	1	250	100	0	10		0	50	100
Selenium	77	<i>Se</i>	1	100	500	0	1	250	100	0	10		0	50	100
Selenium	82	Se	1	100	500	0	1	250	100	0	10		0	50	100
Strontium	88	Sr	1	100	500	0	1	250	100	0			0	50	100
Molybdenum	95	Mo	1	100	500	0	1	250	100				0	50	100
Molybdenum	97	Mo	1	100	500	0	1	250	100				0	50	100
Molybdenum	98	Mo	1	100	500	0	1	200	100				0	50	100
Rhodium	103														
Silver	107	Ag	1	100	500	0	1	250	100	0	10		0	50	100
Silver	109	<i>Ag</i>	1	100	500	0	1	250	100	0	10		0	50	100
Cadmium	111	Cd	1	100	500	0	1	250	100	0	5		0	50	100
Cadmium	114	<i>Cd</i>	1	100	500	0	1	250	100	0	5		0	50	100
Tin	118	Sn	1	100	500	0	1	250	100	0			0	50	100
Antimony	121	<i>Sb</i>	1	100	500	0	1	250	100	0			0	50	100
Antimony	123	Sb	1	100	500	0	1	250	100	0			0	50	100
Tellurium	128	Te	1	100	500	0	1	250	100				0	50	100
Cesium	133														
Barium	135	Ba	1	100	500	0	1	250	100	0			0	50	100
Barium	137	Ba	1	100	500	0	1	250	100	0			0	50	100
Lanthanum	139	La	1	100	500	0	1	250	100				0	50	100
Tantalum	159	Ta	1	100	500	0	1	250	100				0	50	100
Platinum	195	Pt	1	100	500	0	1	250	100				0	50	100
Gold	181	Au	1	100	500	0	1	250	100				0	50	100
Thallium	205	Tl	1	100	500	0	1	250	100	0			0	50	100
Lead	208	Pb	1	100	500	0	1	250	100	0			0	50	100
Bismuth	209	Bi	1	100	500	0	1	250	100				0	50	100
Thorium	232	Th	1	100	500	0	1	250	100				0	50	100
Uranium	238	U	1	100	500	0	1	250	100				0	50	100
Krypton	83														

elementOne

elementOne

PerkinElmer ELAN 6100 ICP-MS

Method 6020 & 200.8 Metals Summary Report

Sample ID: Blank

Sample Da Monday, March 29, 2010 16:39:29

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear	Report Unit
>	Li	6	92482			ppb
-	Be	9	38			ppb
-	Sc	45	111219.3			ppb
>	Rh	103	222036.4			ppb
	Cd	111	81			ppb
-	Cd	114	168			ppb
>	Ho	165	586633.1			ppb
-	Pb	208	4897.9			ppb
	Kr	83	66			mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: Standard 1

Sample Da Monday, March 29, 2010 16:41:25

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear	Report Unit
>	Li	6	92095.5			ppb
-	Be	9	669.4	1.05733		ppb
-	Sc	45	109956.1			ppb
>	Rh	103	217718.8			ppb
	Cd	111	1573.5	1.06964		ppb
-	Cd	114	3728.7	1.06369		ppb
>	Ho	165	582695.7			ppb
-	Pb	208	30663.5	0.98355		ppb
	Kr	83	-21.7			mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: Standard 2

Sample Da Monday, March 29, 2010 16:43:22

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear	Report Unit
>	Li	6	93035.4			ppb
-	Be	9	60365.9	99.9701		ppb
-	Sc	45	110698.1			ppb
>	Rh	103	215160.7			ppb
	Cd	111	138336.6	100.0882		ppb
-	Cd	114	333001.3	100.46945		ppb
>	Ho	165	585685.3			ppb
-	Pb	208	2698241.9	102.14655		ppb
	Kr	83	-7409.9			mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: Standard 3

Sample Da Monday, March 29, 2010 16:45:20

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear	Report Unit
>	Li	6	88875.7			ppb
-	Be	9	288197.2	500.00586		ppb
-	Sc	45	107029.8			ppb
>	Rh	103	206245.5			ppb
	Cd	111	662077.6	499.98222		ppb
-	Cd	114	1587626.7	499.90598		ppb
>	Ho	165	560391.9			ppb
-	Pb	208	12607860	499.57072		ppb
	Kr	83	-35080.1			mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 1

Sample Da Monday, March 29, 2010 16:47:17

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear	Report Unit
>	Li	6	92788.9			ppb
-	Be	9	140	0.17075		ppb
-	Sc	45	110172.7			ppb
>	Rh	103	216223.8			ppb
	Cd	111	324.4	0.1785		ppb
-	Cd	114	775.1	0.18518		ppb
>	Ho	165	573210.1			ppb
-	Pb	208	11390.9	0.2581		ppb
	Kr	83	71.8			mg/L

PerkinElmer ELAN 6100 ICP-MS

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 2

Sample Da Monday, March 29, 2010 16:49:15

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear	Report Unit
>	Li	6	92596.2			ppb
T	Be	9	619.4	0.96811		ppb
T	Sc	45	109720.1			ppb
>	Rh	103	213245.2			ppb
	Cd	111	1410.1	0.97394		ppb
T	Cd	114	3347.7	0.97067		ppb
>	Ho	165	570935			ppb
T	Pb	208	28478.9	0.92276		ppb
	Kr	83	-9.9			mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 3

Sample Da Monday, March 29, 2010 16:51:13

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear	Report Unit
>	Li	6	95487.7			ppb
T	Be	9	150360.6	242.73219		ppb
T	Sc	45	122357.7			ppb
>	Rh	103	242891.5			ppb
	Cd	111	366564.8	235.07024		ppb
T	Cd	114	869031	232.36393		ppb
>	Ho	165	628377			ppb
T	Pb	208	6647084.9	234.77879		ppb
	Kr	83	-20139.9			mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 4

Sample Da Monday, March 29, 2010 16:53:10

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear	Report Unit
>	Li	6	95574.7			ppb
T	Be	9	62641.4	101.01059		ppb
T	Sc	45	121224.7			ppb
>	Rh	103	239326.1			ppb
	Cd	111	152095.5	98.93661		ppb
T	Cd	114	364093.2	98.75665		ppb
>	Ho	165	621297.5			ppb
T	Pb	208	2804876.3	100.09037		ppb
	Kr	83	-8299.4			mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 5

Sample Da Monday, March 29, 2010 16:55:07

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear	Report Unit
>	Li	6	91968.5			ppb
T	Be	9	29313.2	49.08931		ppb
T	Sc	45	116398.5			ppb
>	Rh	103	229948.8			ppb
	Cd	111	70546.9	47.73789		ppb
T	Cd	114	167710.8	47.32513		ppb
>	Ho	165	593099.2			ppb
T	Pb	208	1297718.8	48.4203		ppb
	Kr	83	89.2			mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 6

Sample Da Monday, March 29, 2010 16:57:04

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear	Report Unit
>	Li	6	91524			ppb
T	Be	9	43.7	0.01025		ppb
T	Sc	45	116191.1			ppb
>	Rh	103	215284.4			ppb
	Cd	111	432.2	0.25592		ppb
T	Cd	114	2922.6	0.8325		ppb
>	Ho	165	571724			ppb
T	Pb	208	11953.4	0.27907		ppb
	Kr	83	25.4			mg/L

PerkinElmer ELAN 6100 ICP-MS

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 7

Sample Da Monday, March 29, 2010 16:59:02

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear	Report Unit
∇	Li	6	89712.8			ppb
∇	Be	9	33.7	-0.00548		ppb
∇	Sc	45	114001			ppb
∇	Rh	103	210435			ppb
∇	Cd	111	6560.7	4.79909		ppb
∇	Cd	114	17843	5.45817		ppb
∇	Ho	165	559679.1			ppb
∇	Pb	208	5116.6	0.0177		ppb
	Kr	83	72.3			mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 9

Sample Da Monday, March 29, 2010 17:02:59

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear	Report Unit
∇	Li	6	87951.9			ppb
∇	Be	9	13.7	-0.03938		ppb
∇	Sc	45	110295.6			ppb
∇	Rh	103	223636.7			ppb
∇	Cd	111	115.4	0.02362		ppb
∇	Cd	114	248.8	0.02335		ppb
∇	Ho	165	581646.5			ppb
∇	Pb	208	16846.8	0.45805		ppb
	Kr	83	45.7			mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 10

Sample Da Monday, March 29, 2010 17:04:58

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear	Report Unit
∇	Li	6	85751.8			ppb
∇	Be	9	22663.3	40.68508		ppb
∇	Sc	45	111856.3			ppb
∇	Rh	103	225410.2			ppb
∇	Cd	111	56185.8	38.80519		ppb
∇	Cd	114	134170.6	38.63721		ppb
∇	Ho	165	577914.6			ppb
∇	Pb	208	1094137.5	41.89907		ppb
	Kr	83	46.8			mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 2

Sample Da Monday, March 29, 2010 17:06:57

Sample De CAE

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear	Report Unit
∇	Li	6	92867.4			ppb
∇	Be	9	619.4	0.96548		ppb
∇	Sc	45	126014.9			ppb
∇	Rh	103	246988.7			ppb
∇	Cd	111	1539.9	0.91558		ppb
∇	Cd	114	3718.7	0.92893		ppb
∇	Ho	165	607392.2			ppb
∇	Pb	208	28643.1	0.86242		ppb
	Kr	83	-19.9			mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: 14211-1

Sample Da Monday, March 29, 2010 17:08:55

Sample De CAE

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear	Report Unit
∇	Li	6	82675.4			ppb
∇	Be	9	15.7	-0.03405		ppb
∇	Sc	45	214673.5			ppb
∇	Rh	103	219687.2			ppb
∇	Cd	111	1071.3	0.70255		ppb
∇	Cd	114	1526.1	0.40203		ppb
∇	Ho	165	579926.8			ppb
∇	Pb	208	205723.2	7.69412		ppb
	Kr	83	161.8			mg/L

PerkinElmer ELAN 6100 ICP-MS

Method 6020 & 200.8 Metals Summary Report

Sample ID: 14211-2

Sample Da Monday, March 29, 2010 17:10:53

Sample De CAE

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear Report Unit
>	Li	6	73317.8		ppb
-	Be	9	20.3	-0.02048	ppb
-	Sc	45	168822.8		ppb
>	Rh	103	192037.2		ppb
	Cd	111	1352.3	1.03964	ppb
-	Cd	114	2306.4	0.73085	ppb
>	Ho	165	532016.5		ppb
-	Pb	208	195652.4	7.98659	ppb
	Kr	83	148.7		mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: 14211-2

Sample Da Monday, March 29, 2010 17:12:52

Sample De CAE

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear Report Unit
>	Li	6	72767.7		ppb
-	Be	9	23.3	-0.01382	ppb
-	Sc	45	163569.9		ppb
>	Rh	103	184916.8		ppb
	Cd	111	1316.8	1.05317	ppb
-	Cd	114	2155.5	0.70963	ppb
>	Ho	165	525672.9		ppb
-	Pb	208	193195.7	7.97831	ppb
	Kr	83	105.3		mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: 14211-3

Sample Da Monday, March 29, 2010 17:14:50

Sample De CAE

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear Report Unit
>	Li	6	80190.5		ppb
-	Be	9	19.3	-0.02587	ppb
-	Sc	45	125736.9		ppb
>	Rh	103	201415.4		ppb
	Cd	111	1073.7	0.77348	ppb
-	Cd	114	1421.1	0.40902	ppb
>	Ho	165	561017.9		ppb
-	Pb	208	222864.9	8.6396	ppb
	Kr	83	35.7		mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: 14211-3

Sample Da Monday, March 29, 2010 17:16:48

Sample De CAE

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear Report Unit
>	Li	6	77810.4		ppb
-	Be	9	21581.6	42.704	ppb
-	Sc	45	122583.8		ppb
>	Rh	103	191433.7		ppb
	Cd	111	53146	43.20387	ppb
-	Cd	114	125571.7	42.56716	ppb
>	Ho	165	538296.6		ppb
-	Pb	208	1390745.4	57.21744	ppb
	Kr	83	102.6		mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: 14211-4

Sample Da Monday, March 29, 2010 17:18:46

Sample De CAE

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear Report Unit
>	Li	6	79913		ppb
-	Be	9	22.7	-0.01924	ppb
-	Sc	45	109668.4		ppb
>	Rh	103	196803.1		ppb
	Cd	111	3027	2.3393	ppb
-	Cd	114	6291.7	2.02785	ppb
>	Ho	165	556331.2		ppb
-	Pb	208	367089.9	14.47422	ppb
	Kr	83	33.4		mg/L

PerkinElmer ELAN 6100 ICP-MS

Method 6020 & 200.8 Metals Summary Report

Sample ID: 14211-5

Sample Da Monday, March 29, 2010 17:20:44

Sample De CAE

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Meas Report Unit
>	Li	6	81335.8		ppb
-	Be	9	18.3	-0.02852	ppb
-	Sc	45	185274.8		ppb
>	Rh	103	190441		ppb
	Cd	111	474.8	0.33159	ppb
-	Cd	114	241.9	0.03331	ppb
>	Ho	165	540865.3		ppb
-	Pb	208	50984.8	1.90816	ppb
	Kr	83	208.6		mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: 14211-5

Sample Da Monday, March 29, 2010 17:22:42

Sample De CAE

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Meas Report Unit
>	Li	6	83279.2		ppb
-	Be	9	19.3	-0.02766	ppb
-	Sc	45	181681.6		ppb
>	Rh	103	194449.9		ppb
	Cd	111	484.6	0.3314	ppb
-	Cd	114	269	0.04014	ppb
>	Ho	165	554227.9		ppb
-	Pb	208	50793.5	1.85036	ppb
	Kr	83	200.1		mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: 14211-6

Sample Da Monday, March 29, 2010 17:24:41

Sample De CAE

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Meas Report Unit
>	Li	6	77500.4		ppb
-	Be	9	16	-0.03153	ppb
-	Sc	45	101076.3		ppb
>	Rh	103	178480		ppb
	Cd	111	386.2	0.28024	ppb
-	Cd	114	114.1	-0.00616	ppb
>	Ho	165	521398.9		ppb
-	Pb	208	56497.5	2.22142	ppb
	Kr	83	84.2		mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: 14211-6

Sample Da Monday, March 29, 2010 17:26:39

Sample De CAE

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Meas Report Unit
>	Li	6	76261		ppb
-	Be	9	21085.1	42.57492	ppb
-	Sc	45	100597.1		ppb
>	Rh	103	177068.4		ppb
	Cd	111	49600.3	43.5694	ppb
-	Cd	114	116858.4	42.80747	ppb
>	Ho	165	510232.7		ppb
-	Pb	208	1200129.6	52.06152	ppb
	Kr	83	32.3		mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: 14211-7

Sample Da Monday, March 29, 2010 17:28:43

Sample De CAE

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Meas Report Unit
>	Li	6	76722		ppb
-	Be	9	31	-0.0009	ppb
-	Sc	45	91466.1		ppb
>	Rh	103	179260.5		ppb
	Cd	111	569.6	0.43864	ppb
-	Cd	114	150.6	0.00456	ppb
>	Ho	165	515112.1		ppb
-	Pb	208	88958.6	3.65046	ppb
	Kr	83	3.1		mg/L

PerkinElmer ELAN 6100 ICP-MS

Method 6020 & 200.8 Metals Summary Report

Sample ID: 14211-8

Sample Da Monday, March 29, 2010 17:30:42

Sample De CAE

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Meas Report Unit
▷	Li	6	85160.3		ppb
-	Be	9	16	-0.03449	ppb
-	Sc	45	228222.9		ppb
▷	Rh	103	219075		ppb
-	Cd	111	601.3	0.37072	ppb
-	Cd	114	706.9	0.16038	ppb
▷	Ho	165	598378.7		ppb
-	Pb	208	99303.2	3.50064	ppb
	Kr	83	19.1		mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: 14211-8

Sample Da Monday, March 29, 2010 17:32:41

Sample De CAE

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Meas Report Unit
▷	Li	6	85035.7		ppb
-	Be	9	17.7	-0.03118	ppb
-	Sc	45	215272.3		ppb
▷	Rh	103	219070.1		ppb
-	Cd	111	541.9	0.32839	ppb
-	Cd	114	478.4	0.0928	ppb
▷	Ho	165	601665.4		ppb
-	Pb	208	93595.6	3.27055	ppb
	Kr	83	28.4		mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: 14211-9

Sample Da Monday, March 29, 2010 17:34:39

Sample De CAE

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Meas Report Unit
▷	Li	6	75398.2		ppb
-	Be	9	17.3	-0.02784	ppb
-	Sc	45	247873.4		ppb
▷	Rh	103	192686.5		ppb
-	Cd	111	545	0.38319	ppb
-	Cd	114	223.8	0.02649	ppb
▷	Ho	165	541302.7		ppb
-	Pb	208	105524.2	4.1446	ppb
	Kr	83	267.3		mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: 14211-9

Sample Da Monday, March 29, 2010 17:36:38

Sample De CAE

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Meas Report Unit
▷	Li	6	77666.6		ppb
-	Be	9	21901.1	43.41592	ppb
-	Sc	45	238916.4		ppb
▷	Rh	103	193512.7		ppb
-	Cd	111	54475.1	43.79773	ppb
-	Cd	114	129439	43.39996	ppb
▷	Ho	165	548211.5		ppb
-	Pb	208	1366327.3	55.17142	ppb
	Kr	83	293.6		mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: 14211-10

Sample Da Monday, March 29, 2010 17:38:36

Sample De CAE

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Meas Report Unit
▷	Li	6	81115.8		ppb
-	Be	9	23	-0.01936	ppb
-	Sc	45	100846.5		ppb
▷	Rh	103	201515		ppb
-	Cd	111	302.4	0.1771	ppb
-	Cd	114	-183.4	-0.11166	ppb
▷	Ho	165	561327.7		ppb
-	Pb	208	41304.5	1.4493	ppb
	Kr	83	-35.5		mg/L

PerkinElmer ELAN 6100 ICP-MS

Method 6020 & 200.8 Metals Summary Report

Sample ID: 14211-11

Sample Da Monday, March 29, 2010 18:03:52

Sample De CAE

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear	Report Unit
Y	Li	6	85453.4			ppb
T	Be	9	21.3	-0.02451		ppb
T	Sc	45	106693.9			ppb
Y	Rh	103	209523.8			ppb
I	Cd	111	371.9	0.21983		ppb
T	Cd	114	66.1	-0.02953		ppb
Y	Ho	165	556366.5			ppb
T	Pb	208	61499.7	2.27043		ppb
	Kr	83	-63.4			mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: 14211-15

Sample Da Monday, March 29, 2010 18:07:49

Sample De CAE

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear	Report Unit
Y	Li	6	87177.8			ppb
T	Be	9	4641.9	8.14725		ppb
T	Sc	45	106547.6			ppb
Y	Rh	103	201730.4			ppb
I	Cd	111	18227.9	14.0205		ppb
T	Cd	114	43505.4	13.95844		ppb
Y	Ho	165	541336.5			ppb
T	Pb	208	2800923.4	114.73106		ppb
	Kr	83	40.5			mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: 14211-16

Sample Da Monday, March 29, 2010 18:11:45

Sample De CAE

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear	Report Unit
Y	Li	6	79707.3			ppb
T	Be	9	39	0.01201		ppb
T	Sc	45	96974.8			ppb
Y	Rh	103	184990.3			ppb
I	Cd	111	-65.9	-0.14814		ppb
T	Cd	114	460.4	0.11323		ppb
Y	Ho	165	516375.7			ppb
T	Pb	208	79248.5	3.22583		ppb
	Kr	83	-255.2			mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: Be DL 0.25

Sample Da Monday, March 29, 2010 18:13:44

Sample De CAE

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear	Report Unit
Y	Li	6	88753.5			ppb
T	Be	9	177	0.24417		ppb
T	Sc	45	100855.4			ppb
Y	Rh	103	197969.9			ppb
I	Cd	111	367.1	0.23171		ppb
T	Cd	114	900.3	0.24621		ppb
Y	Ho	165	534070.9			ppb
T	Pb	208	9220.8	0.19815		ppb
	Kr	83	32.3			mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 1

Sample Da Monday, March 29, 2010 18:15:41

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear	Report Unit
Y	Li	6	90189.3			ppb
T	Be	9	18.7	-0.03155		ppb
T	Sc	45	105180.6			ppb
Y	Rh	103	200632.5			ppb
I	Cd	111	45.6	-0.02134		ppb
T	Cd	114	86.7	-0.02105		ppb
Y	Ho	165	542424.4			ppb
T	Pb	208	2722.2	-0.07389		ppb
	Kr	83	48.2			mg/L

PerkinElmer ELAN 6100 ICP-MS

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 4

Sample Date: Monday, March 29, 2010 18:17:38

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Inten	Conc.	Meas	Report Unit
V	Li	6	89110.3			ppb
T	Be	9	57131.3	98.80924		ppb
T	Sc	45	102055.7			ppb
V	Rh	103	193567.5			ppb
I	Cd	111	126118	101.43338		ppb
T	Cd	114	300775.8	100.8684		ppb
V	Ho	165	538190.5			ppb
T	Pb	208	2480169.3	102.1755		ppb
	Kr	83	-6735.2			mg/L


ANALYTICAL PERSPECTIVES

13 April 2010

Scott Brown
 Clean Air Engineering
 500 West Wood Street
 Palatine, IL 60067

Ph.: 847-991-3300
 Email: scott_brown@cleanair.com

Subject: Certificate of Results - Amended

Dear Scott;

Attached to this narrative are the analytical results you requested on samples submitted for the determination of polychlorinated dibenzo-*p*-dioxins and dibenzofurans. The insert below summarizes the relevant information pertaining to your project. In particular, QC annotations bring to your attention specific analytical observations and assessments made during the sample handling and data interpretation phases. A brief description of the report's components is provided. Results reported relate only to the items tested.

Project Information Summary	When applicable, see QC Annotations for details
Client Project No.	10955
AP Project No.	P2096
Analytical Protocol	Method 23
No. Samples Submitted	5 & 1 audit
No. Samples Analyzed	5 & 1 audit
No. Laboratory Method Blanks	1
No. OPRs / Batch CS3	1
No. Outstanding Samples	none
Date Received	21-Mar-2010
Condition Received	good
Temperature upon Receipt (C)	2 (XAD, filters), 17-19 (solvents)
Extraction within Holding Time	yes
Analysis within Holding Time	yes
Data meet QA/QC Requirements	yes
Exceptions	see below
Analytical Difficulties	see below

2714 EXCHANGE DRIVE
 WILMINGTON, NC 28405
 PH.: 910-794-1613
 1 / 3



QC Annotations:

1. See Appendix A&B for data qualifier, data attributes, and lab identifier information.
2. The letter has been amended to include a new topsheet for sample 004.

Analytical Perspectives remains committed to serving you in the most effective manner. Should you have any questions or need additional information and technical support, please do not hesitate to contact us. Thank you for choosing Analytical Perspectives as part of your analytical support team.

Sincerely,

A handwritten signature in black ink, appearing to read "Kimberly Mace", with a horizontal line extending to the right.

Kimberly Mace, Ph.D.
Project Manager

2714 EXCHANGE DRIVE
WILMINGTON, NC 28405
PH.: 910-794-1613
2 / 3

The electronic version of this report contains 329 pages.
(add one page in count for the NELAC compliance statement) (+1)

P2096

ANALYTICAL PERSPECTIVES

Part 1

Narrative

25 pgs

- ✓ Letter
- ✓ QC Annotations
- ✓ Project Information

ANALYTICAL PERSPECTIVES

Part 2

Path

22 pgs

- ✓ Overview
- ✓ Protocol
- ✓ Extraction
- ✓ Analysis
- ✓ Spike Profile
- ✓ SOPs
- ✓ QC
- ✓ Reporting
- ✓ Special Requirements

Extraction
Tracking Sheets

Fractionation
Tracking Sheets

Injection
Tracking Sheets

ANALYTICAL PERSPECTIVES

Part 3

Results

102 pgs

- ✓ Summary Topsheets
- ✓ Raw Data
- ✓ SICPs
- ✓ Areas
- ✓ Retention Times
- ✓ S/N
- ✓ Ion Abundance Ratios

ANALYTICAL PERSPECTIVES

Part 4

Performance

45 pgs

System Checks

- ✓ Mass Spectrometry
- ✓ Gas Chromatography
- ✓ Initial Calibration
- ✓ Continuing Calibration
- ✓ BCS₃, OPR

Part 4D
ICAL
94 pgs

Part 4E
Audit
17 pgs

STATE CERTIFICATION ID #s	
ARKANSAS	88-0628
CALIFORNIA	2640
FLORIDA	E87608
LOUISIANA	04024
MICHIGAN	9951
NEW JERSEY	NC005
NORTH CAROLINA	37783
PENNSYLVANIA	68-01849
SOUTH CAROLINA	99054
WASHINGTON	C2027

THIS REPORT SHALL NOT BE REPRODUCED EXCEPT FOR IN FULL
WITHOUT THE ORIGINAL APPROVAL OF THE LABORATORY

Picture File 23 pgs


ANALYTICAL PERSPECTIVES

APPENDIX A: DATA QUALIFIERS / DATA ATTRIBUTES	
*	The reported concentration exceeds the calibration range (upper point of the calibration curve). ¹
>	Indicates high recoveries. Shown with the numeric value at the top of the range. ¹
B	The analyte is found in the method blank, at a level that is $\leq 10\times$ the sample concentration.
C	Two or more congeners co-elute. In EDDs C denotes the lowest IUPAC congener in a co-elution group and additional co-eluters for the group are shown with the number of the lowest IUPAC co-eluter.
E	The reported concentration exceeds the calibration range (upper point of the calibration curve).
EMPC	Represents an Estimated Maximum Possible Concentration. EMPC's arise in cases where the signal/noise ratio is not sufficient for peak identification (the determined ion-abundance ratio is outside the allowed theoretical range), where there is a co-eluting interference, or where a single ion is utilized for quantitation due to PFK interference.
ETH	Indicates the presence of a diphenyl ether that appears to interfere with the quantitation of a furan. The reported concentration is the maximum.
H/h	If the standard recovery is below the method or SOP specified value "H" is assigned. If the obtained value is less than half the specified value "h" is assigned. ¹
J	Indicates that an analyte has a concentration below the reporting limit (lowest point of the calibration curve).
ND	Indicates a non-detect.
NR	Indicates a value that is not reportable.
PR	Due to interference, the associated congener is poorly resolved.
QI	Indicates the presence of a quantitative interference.
Ra	The new ratio – [Ra] -- for 2,3,7,8-TCDD following the ³⁷ Cl ₄ -2,3,7,8-TCDD correction is shown between squared brackets in the DL column. ¹
SI	Denotes "Single Ion Mode" and is utilized for PCBs where the secondary ion trace has a significantly elevated noise level due to background PFK. Responses for such peaks are calculated using an EMPC approach based solely on the primary ion area(s) and may be considered estimates. ¹
U	The analyte was not detected. The estimated detection limit (EDL) may be reported for this analyte.
V	The labeled standard recovery was found to be outside of the method control limits.
X	Indicates results reported from reinjection, refractionation, or repeat analyses.
APPENDIX B: LAB ID IDENTIFIERS	
AR	Indicates use of the archived portion of the sample extract.
CU	Indicates a sample that required additional clean-up prior to MS injection/processing.
D	Indicates a dilution of the sample extract. The number that follows the "D" indicates the dilution factor.
DE	Indicates a dilution performed with the addition of ES (extraction standard) solution.
DUP	Designation for a duplicate sample.
MS	Designation for a matrix spike.
MSD	Designation for a matrix spike duplicate.
RJ	Indicates a reinjection of the sample extract.
S	Indicates a sample split. The number that follows the "S" indicates the split factor.

¹Denotes data qualifiers/attributes whose use will be phased out over time

P2096 - TEQ

Project ID: 10955

Sample Summary		ANALYTICAL PERSPECTIVES				Method 23	
Part 1		0_7679_MB001	Field Blank	Unit 2 FF Outlet Run 1	Unit 2 FF Outlet Run 2	Unit 2 FF Outlet Run 3	Reagent Blank
Method 23		pg	pg	pg	pg	pg	pg
2,3,7,8-TCDD	(1.46)	(1.39)	[3.64]	[2.21]	[3.21]	(1.3)	
1,2,3,7,8-PeCDD	(1.79)	(1.82)	5.58	[4.52]	8.62	(1.7)	
1,2,3,4,7,8-HxCDD	(2.66)	(1.83)	(2.09)	5.7	5.91	(2.2)	
1,2,3,6,7,8-HxCDD	(2.48)	(1.93)	6.15	13	11	(2.16)	
1,2,3,7,8,9-HxCDD	(2.79)	(2.08)	(2.31)	8.47	9.54	(2.45)	
1,2,3,4,6,7,8-HpCDD	(2.74)	4.71	44.1	67.6	70	(2.81)	
OCDD	14.1	14.8	76.7	122	127	(4.36)	
2,3,7,8-TCDF	(1.07)	(0.973)	15.8	18.4	20.5	(0.86)	
1,2,3,7,8-PeCDF	(1.09)	(1.07)	15.3	19.8	17	(1.14)	
2,3,4,7,8-PeCDF	(1.03)	(1.02)	14.5	20.4	20.3	(1.19)	
1,2,3,4,7,8-HxCDF	(1.78)	(1.44)	9.14	16.9	19.4	(1.68)	
1,2,3,6,7,8-HxCDF	(1.66)	(1.36)	12	20.7	19.3	(1.55)	
2,3,4,6,7,8-HxCDF	(1.78)	(1.44)	9.38	18	17.2	(1.7)	
1,2,3,7,8,9-HxCDF	(2.42)	(1.93)	(2.04)	(3.04)	(2.53)	(2.31)	
1,2,3,4,6,7,8-HpCDF	(1.69)	3.19	20.1	49.4	50.6	(1.65)	
1,2,3,4,7,8,9-HpCDF	(2.53)	(2.05)	(2.25)	4.95	6.18	(2.25)	
OCDF	(3.41)	6.16	[5.38]	[14.5]	24.2	(3.57)	
ITEF TEQ (ND=0; EMPC=0)	0.0141	0.0999	16.8	22.7	27.0	0.00	
ITEF TEQ (ND=0; EMPC=EMPC)	0.0141	0.0999	20.4	27.2	30.2	0.00	
ITEF TEQ (ND=DL/2; EMPC=0)	2.34	2.19	17.8	24.7	28.2	2.18	
ITEF TEQ (ND=DL/2; EMPC=EMPC)	2.34	2.19	20.8	27.3	30.3	2.18	
ITEF TEQ (ND=DL; EMPC=EMPC)	4.67	4.28	21.1	27.5	30.5	4.37	
Checkcode	681-930	318-336	744-657	544-695	487-158	493-202	
Lab ID	MB1 7679 DF SDS	P2096 7679 001	P2096 7679 002	P2096 7679 003	P2096 7679 004	P2096 7679 005	

1-76

() = DL
[] = EMPC

P2096 - WHO-2005-TEQ

Project ID: 10955

Sample Summary Part 1



Method 23

Analyte	0_7679_MB001	Field Blank	Unit 2 FF Outlet Run 1	Unit 2 FF Outlet Run 2	Unit 2 FF Outlet Run 3	Reagent Blank
	pg	pg	pg	pg	pg	pg
2,3,7,8-TCDD	(1.46)	(1.39)	[3.64]	[2.21]	[3.21]	(1.3)
1,2,3,7,8-PeCDD	(1.79)	(1.82)	5.58	[4.52]	8.62	(1.7)
1,2,3,4,7,8-HxCDD	(2.66)	(1.83)	(2.09)	5.7	5.91	(2.2)
1,2,3,6,7,8-HxCDD	(2.48)	(1.93)	6.15	13	11	(2.16)
1,2,3,7,8,9-HxCDD	(2.79)	(2.08)	(2.31)	8.47	9.54	(2.45)
1,2,3,4,6,7,8-HpCDD	(2.74)	4.71	44.1	67.6	70	(2.81)
OCDD	14.1	14.8	76.7	122	127	(4.36)
2,3,7,8-TCDF	(1.07)	(0.973)	15.8	18.4	20.5	(0.86)
1,2,3,7,8-PeCDF	(1.09)	(1.07)	15.3	19.8	17	(1.14)
2,3,4,7,8-PeCDF	(1.03)	(1.02)	14.5	20.4	20.3	(1.19)
1,2,3,4,7,8-HxCDF	(1.78)	(1.44)	9.14	16.9	19.4	(1.68)
1,2,3,6,7,8-HxCDF	(1.66)	(1.36)	12	20.7	19.3	(1.55)
2,3,4,6,7,8-HxCDF	(1.78)	(1.44)	9.38	18	17.2	(1.7)
1,2,3,7,8,9-HxCDF	(2.42)	(1.93)	(2.04)	(3.04)	(2.53)	(2.31)
1,2,3,4,6,7,8-HpCDF	(1.69)	3.19	20.1	49.4	50.6	(1.65)
1,2,3,4,7,8,9-HpCDF	(2.53)	(2.05)	(2.25)	4.95	6.18	(2.25)
OCDF	(3.41)	6.16	[5.38]	[14.5]	24.2	(3.57)
WHO-2005 TEQ (ND=0; EMPC=0)	0.00422	0.0852	16.3	18.1	26.8	0.00
WHO-2005 TEQ (ND=0; EMPC=EMPC)	0.00422	0.0852	19.9	24.8	30.0	0.00
WHO-2005 TEQ (ND=DL/2; EMPC=0)	2.67	2.52	17.3	20.9	28.0	2.48
WHO-2005 TEQ (ND=DL/2; EMPC=EMPC)	2.67	2.52	20.3	25.0	30.2	2.48
WHO-2005 TEQ (ND=DL; EMPC=EMPC)	5.33	4.95	20.6	25.1	30.3	4.95
Checkcode	681-930	318-336	744-657	544-695	487-158	493-202
Lab ID	MB1 7679 DF SDS	P2096 7679 001	P2096 7679 002	P2096 7679 003	P2096 7679 004	P2096 7679 005

() = DL
[] = EMPC

P2096 - Totals
Project ID: 10955

Sample Summary
Part 2



Method 23

Analyte	0_7679_MB001	Field Blank	Unit 2 FF Outlet Run 1	Unit 2 FF Outlet Run 2	Unit 2 FF Outlet Run 3	Reagent Blank
	pg	pg	pg	pg	pg	pg
Totals						
TCDDs	0	2.73	59.6	81.8	71.7	0
PeCDDs	0	0	68.5	53.4	103	0
HxCDDs	0	0	116	180	154	0
HpCDDs	0	4.71	91.4	132	142	0
OCDD	14.1	14.8	76.7	122	127	0
TCDFs	0	0	496	426	567	0
PeCDFs	0	0	251	275	275	0
HxCDFs	0	0	79.4	165	142	0
HpCDFs	0	3.19	22.8	72.6	67.9	0
OCDF	0	6.16	5.38	14.5	24.2	0
Total PCDD/Fs (ND=0; EMPC=0)	14.1	31.6	1,260	1,510	1,670	0.00
Total PCDD/Fs (ND=0; EMPC=EMPC)	16.3	37.9	1,350	1,760	1,850	0.00
Total PCDD/Fs (2378-X ND=DL; EMPC=EMPC)	48.7	58.3	1,360	1,770	1,860	34.9
Total 2378s (ND=DL; EMPC=DL)	14.1	28.0	229	386	427	0.00
Total 2378s (ND=DL; EMPC=EMPC)	30.3	31.1	235	197	260	17.4
Total 2378s (ND=DL; EMPC=DL)	46.4	49.3	242	399	432	24.9
Total 2378s (ND=DL; EMPC=DL)	28.1	57.0	467	733	858	0.00
Total 2378s (ND=0; EMPC=DL)	30.3	39.9	242	408	432	17.4
Total 2378s (ND=DL; EMPC=DL)	48.7	58.2	247	410	433	34.9
Checkcode	681-930	318-336	744-657	544-695	487-158	493-202
Lab ID	MB1_7679_DF_SDS	P2096_7679_001	P2096_7679_002	P2096_7679_003	P2096_7679_004	P2096_7679_005

1-78

() = DL
[] = EMPC

P2096 - Others

Project ID: 10955

Analyte	ANALYTICAL PERSPECTIVES						Method 23
	0_7679_MB001	Field Blank	Unit 2 FF Outlet Run 1	Unit 2 FF Outlet Run 2	Unit 2 FF Outlet Run 3	Reagent Blank	
	pg	pg	pg	pg	pg	pg	
Other PCDD/Fs (ND=0, EMPC=0)							
Other TCDD	0	2.73	59.6	81.8	71.7	0	
Other PeCDD	0	0	62.9	53.4	94.2	0	
Other HxCDD	0	0	110	152	127	0	
Other HpCDD	0	0	47.3	64.6	71.6	0	
Other TCDF	0	0	480	407	546	0	
Other PeCDF	0	0	221	235	238	0	
Other HxCDF	0	0	48.9	109	85.6	0	
Other HpCDF	0	0	2.72	18.3	11.1	0	
Other PCDD/Fs (ND=0, EMPC=EMPC)							
Other TCDD	2.25	2.73	72.5	104	97	0	
Other PeCDD	0	0	89.8	104	117	0	
Other HxCDD	0	0	110	166	165	0	
Other HpCDD	0	4.03	47.3	64.6	71.6	0	
Other TCDF	0	0	509	501	557	0	
Other PeCDF	0	0	221	283	279	0	
Other HxCDF	0	2.28	53	116	112	0	
Other HpCDF	0	0	5.76	18.3	21.1	0	
Checkcode	681-930	318-336	744-657	544-695	487-158	493-202	
Lab ID	MB1_7679_DF_SDS	P2096_7679_001	P2096_7679_002	P2096_7679_003	P2096_7679_004	P2096_7679_005	

1-79

() = DL
 [] = EMPC

P2096 - DLs

Project ID: 10955

Sample Summary Part 5




Method 23

Analyte	0_7679_MB001	Field Blank	Unit 2 FF Outlet Run 1	Unit 2 FF Outlet Run 2	Unit 2 FF Outlet Run 3	Reagent Blank
	pg	pg	pg	pg	pg	pg
2,3,7,8-TCDD	1.46	1.39	1.41	2.07	2.04	1.3
1,2,3,7,8-PeCDD	1.79	1.82	1.81	3.2	2.32	1.7
1,2,3,4,7,8-HxCDD	2.66	1.83	2.09	2.73	2.41	2.2
1,2,3,6,7,8-HxCDD	2.48	1.93	2.16	2.82	2.29	2.16
1,2,3,7,8,9-HxCDD	2.79	2.08	2.31	3.01	2.56	2.45
1,2,3,4,6,7,8-HpCDD	2.74	2.24	2.6	3.81	3.98	2.81
OCDD	4.41	3.97	4.01	5.54	4.87	4.36
2,3,7,8-TCDF	1.07	0.973	1.15	1.52	1.45	0.86
1,2,3,7,8-PeCDF	1.09	1.07	1.47	2.11	1.53	1.14
2,3,4,7,8-PeCDF	1.03	1.02	1.33	2.11	1.54	1.19
1,2,3,4,7,8-HxCDF	1.78	1.44	1.59	2.22	1.95	1.68
1,2,3,6,7,8-HxCDF	1.66	1.36	1.46	2.2	1.86	1.55
2,3,4,6,7,8-HxCDF	1.78	1.44	1.59	2.27	1.89	1.7
1,2,3,7,8,9-HxCDF	2.42	1.93	2.04	3.04	2.53	2.31
1,2,3,4,6,7,8-HpCDF	1.69	1.42	1.51	2.05	2.14	1.65
1,2,3,4,7,8,9-HpCDF	2.53	2.05	2.25	2.93	3.29	2.25
OCDF	3.41	3.09	2.9	4.36	4.27	3.57
Total TCDD	1.46	1.39	1.41	2.07	2.04	1.3
Total PeCDD	1.79	1.82	1.81	3.2	2.32	1.7
Total HxCDD	2.64	1.94	2.18	2.85	2.41	2.26
Total HpCDD	2.74	2.24	2.6	3.81	3.98	2.81
Total TCDF	1.07	0.973	1.15	1.52	1.45	0.86
Total PeCDF	1.06	1.04	1.4	2.11	1.53	1.17
Total HxCDF	1.89	1.52	1.65	2.41	2.04	1.79
Total HpCDF	2.07	1.71	1.85	2.46	2.67	1.92
Checkcode	681-930	318-336	744-657	544-695	487-158	493-202
Lab ID	MB1 7679 DF SDS	P2096 7679 001	P2096 7679 002	P2096 7679 003	P2096 7679 004	P2096 7679 005

08-1

ITEF-TEQ
Project ID: 10955
P2096

- ▣ ND=0; EMPC=0
- ▤ ND=0; EMPC=EMPC
- ▥ ND=DL/2; EMPC=0
- ▦ ND=DL/2; EMPC=EMPC
- ▧ ND=DL; EMPC=EMPC




WHO-2005-TEQ

Project ID: 10955


P2096

- ▨ ND=0; EMPC=0
- ▨ ND=0; EMPC=EMPC
- ND=DL/2; EMPC=0
- ND=DL/2; EMPC=EMPC
- ▨ ND=DL; EMPC=EMPC




Totals
Project ID: 10955
P2096

- ▨ Total PCDD/Fs (ND=0; EMPC=0)
- Total PCDD/Fs (ND=0; EMPC=EMPC)
- ▩ Total PCDD/Fs (2378-X ND=DL; EMPC=EMPC)




Mean Recoveries of Sampling Standards (N=5)
Project ID: 10955
P2096

▨ Mean □ Std. Dev.




Method Specification Limits: Tetra-Octa SS: 70-130% (F = fail)

Mean Recoveries of Extraction Standards (N=6)
Project ID: 10955
P2096




Method Specification Limits: Tetra-Hexa ES: 40-130%, Hepta-Octa ES: 25-130% (F = fail)


ANALYTICAL PERSPECTIVES




ANALYTICAL PERSPECTIVES




ANALYTICAL PERSPECTIVES




ANALYTICAL PERSPECTIVES




ANALYTICAL PERSPECTIVES




ANALYTICAL PERSPECTIVES



ANALYTICAL PERSPECTIVES



ANALYTICAL PERSPECTIVES



Sample ID: 0_7679_MB001

Method 23

<u>Client Data</u>		<u>Sample Data</u>		<u>Laboratory Data</u>			
Name:	Clean Air Engineering	Matrix:	Air	Lab Project ID:	P2096	Date Received:	n/a
Project ID:	10955	Weight/Volume:	1	Lab Sample ID:	MB1_7679_DF_SDS	Date Extracted:	06 Apr 2010
Date Collected:	n/a	Split:	2	QC Batch No:	7679	Date Analyzed:	09 Apr 2010
				Dilution:	-	Time Analyzed:	09:07:26
Analyte	Conc. (pg)	DL (pg)	EMPC (pg)	Qualifiers	Standard	ES Recoveries	Qualifiers
2378-TCDD	ND	1.46			ES 2378-TCDD	88.6	
12378-PeCDD	ND	1.79			ES 12378-PeCDD	88.9	
123478-HxCDD	ND	2.66			ES 123478-HxCDD	91.1	
123678-HxCDD	ND	2.48			ES 123678-HxCDD	92.8	
123789-HxCDD	ND	2.79			ES 123789-HxCDD	94.1	
1234678-HpCDD	ND	2.74			ES 1234678-HpCDD	91.2	
OCDD	14.1			J	ES OCDD	89.2	
2378-TCDF	ND	1.07			ES 2378-TCDF	89.1	
12378-PeCDF	ND	1.09			ES 12378-PeCDF	91.1	
23478-PeCDF	ND	1.03			ES 23478-PeCDF	91.7	
123478-HxCDF	ND	1.78			ES 123478-HxCDF	95.6	
123678-HxCDF	ND	1.66			ES 123678-HxCDF	94.2	
234678-HxCDF	ND	1.78			ES 234678-HxCDF	92.9	
123789-HxCDF	ND	2.42			ES 123789-HxCDF	83.4	
1234678-HpCDF	ND	1.69			ES 1234678-HpCDF	89.9	
1234789-HpCDF	ND	2.53			ES 1234789-HpCDF	86.2	
OCDF	ND	3.41			ES OCDF	86.9	
Totals					Standard	SS/AS Recoveries	
Total TCDD	ND		2.25		SS-37Cl-2378-TCDD	98.5	
Total PeCDD	ND	1.79	ND		SS 12347-PeCDD	101	
Total HxCDD	ND	2.64	ND		SS 12346-PeCDF	94.8	
Total HpCDD	ND	2.74	ND		SS 123469-HxCDF	98.9	
Total TCDF	ND	1.07	ND		SS 1234689-HpCDF	100	
Total PeCDF	ND	1.06	ND		AS 1368-TCDD	88.8	
Total HxCDF	ND	1.89	ND		AS 1368-TCDF	90.7	
Total HpCDF	ND	2.07	ND				
Total PCDD/Fs:	14.1		16.3				
ITEF TEQs							
TEQ: ND=0	0.0141		0.0141		 ANALYTICAL PERSPECTIVES 2714 Exchange Drive Wilmington, NC 28405, USA info@ultratrace.com www.ultratrace.com		
TEQ: ND=DL/2	2.34		2.34				
TEQ: ND=DL	4.67		4.67				

68-1

Sample ID: Field Blank

Method 23

Client Data		Sample Data		Laboratory Data			
Name:	Clean Air Engineering	Matrix:	Air	Lab Project ID:	P2096	Date Received:	20 Mar 2010
Project ID:	10955	Weight/Volume:	1	Lab Sample ID:	P2096_7679_001	Date Extracted:	06 Apr 2010
Date Collected:	18 Mar 2010	Split:	2	QC Batch No:	7679	Date Analyzed:	09 Apr 2010
				Dilution:	-	Time Analyzed:	09:57:56

Analyte	Conc. (pg)	DL (pg)	EMPC (pg)	Qualifiers	Standard	ES Recoveries	Qualifiers
2378-TCDD	ND	1.39			ES 2378-TCDD	86.3	
12378-PeCDD	ND	1.82			ES 12378-PeCDD	89.5	
123478-HxCDD	ND	1.83			ES 123478-HxCDD	90.9	
123678-HxCDD	ND	1.93			ES 123678-HxCDD	96.6	
123789-HxCDD	ND	2.08			ES 123789-HxCDD	94.6	
1234678-HpCDD	4.71			J	ES 1234678-HpCDD	92.4	
OCDD	14.8			J B	ES OCDD	91.7	
2378-TCDF	ND	0.973			ES 2378-TCDF	88.6	
12378-PeCDF	ND	1.07			ES 12378-PeCDF	92.4	
23478-PeCDF	ND	1.02			ES 23478-PeCDF	93.6	
123478-HxCDF	ND	1.44			ES 123478-HxCDF	94.2	
123678-HxCDF	ND	1.36			ES 123678-HxCDF	92.7	
234678-HxCDF	ND	1.44			ES 234678-HxCDF	91.2	
123789-HxCDF	ND	1.93			ES 123789-HxCDF	83.1	
1234678-HpCDF	3.19			J	ES 1234678-HpCDF	91.2	
1234789-HpCDF	ND	2.05			ES 1234789-HpCDF	88.6	
OCDF	6.16			J	ES OCDF	89.9	
Totals					Standard	SS/AS Recoveries	
Total TCDD	2.73		2.73		SS 37Cl-2378-TCDD	98.1	
Total PeCDD	ND	1.82	ND		SS 12347-PeCDD	97.9	
Total HxCDD	ND	1.94	ND		SS 12346-PeCDF	90.9	
Total HpCDD	4.71		8.73		SS 123469-HxCDF	97.6	
Total TCDF	ND	0.973	ND		SS 1234689-HpCDF	98	
Total PeCDF	ND	1.04	ND		AS 1368-TCDD	82.7	
Total HxCDF	ND		2.28		AS 1368-TCDF	80.9	
Total HpCDF	3.19		3.19				
Total PCDD/Fs	31.6		37.9				
ITEF TEQs							
TEQ: ND=0	0.0999		0.0999		2714 Exchange Drive ANALYTICAL PERSPECTIVES Wilmington, NC 28405, USA info@ultratrace.com www.ultratrace.com Tel: +1 910 794-1613 (Fax: -3919); Toll-Free 866 846-8296		
TEQ: ND=DL/2	2.19		2.19				
TEQ: ND=DL	4.28		4.28				

Sample ID: Unit 1 FF Outlet Run 1

Method 23

Client Data		Sample Data		Laboratory Data		Date Received: 20 Mar 2010	
Name:	Clean Air Engineering	Matrix:	Air	Lab Project ID:	P2096	Date Extracted:	06 Apr 2010
Project ID:	10955	Weight/Volume:	1	Lab Sample ID:	P2096_7679_002	Date Analyzed:	09 Apr 2010
Date Collected:	16 Mar 2010	Split:	2	QC Batch No:	7679	Time Analyzed:	10:48:24
				Dilution:	-		

Analyte	Conc. (pg)	DL (pg)	EMPC (pg)	Qualifiers	Standard	ES Recoveries	Qualifiers
2378-TCDD	EMPC	[Ra=0.98]	3.64	J	ES 2378-TCDD	83.1	
12378-PeCDD	5.58			J	ES 12378-PeCDD	88.6	
123478-HxCDD	ND	2.09			ES 123478-HxCDD	82.5	
123678-HxCDD	6.15			J	ES 123678-HxCDD	86.2	
123789-HxCDD	ND	2.31			ES 123789-HxCDD	82.9	
1234678-HpCDD	44.1			J	ES 1234678-HpCDD	85.3	
OCDD	76.7			J B	ES OCDD	84.7	
2378-TCDF	15.8				ES 2378-TCDF	84.6	
12378-PeCDF	15.3			J	ES 12378-PeCDF	89.3	
23478-PeCDF	14.5			J	ES 23478-PeCDF	92.7	
123478-HxCDF	9.14			J	ES 123478-HxCDF	86.9	
123678-HxCDF	12			J	ES 123678-HxCDF	84.3	
234678-HxCDF	9.38			J	ES 234678-HxCDF	82.6	
123789-HxCDF	ND	2.04			ES 123789-HxCDF	78.4	
1234678-HpCDF	20.1			J	ES 1234678-HpCDF	82.9	
1234789-HpCDF	ND	2.25			ES 1234789-HpCDF	82.6	
OCDF	EMPC		5.38	J	ES OCDF	84.2	

Totals					Standard	SS/AS Recoveries	
Total TCDD	59.6		76.2		SS 37Cl-2378-TCDD	98.1	
Total PeCDD	68.5		95.4		SS 12347-PeCDD	98.3	
Total HxCDD	116		116		SS 12346-PeCDF	97.8	
Total HpCDD	91.4		91.4		SS 123469-HxCDF	101	
Total TCDF	496		525		SS 1234689-HpCDF	103	
Total PeCDF	251		251		AS 1368-TCDD	82.3	
Total HxCDF	79.4		83.6		AS 1368-TCDF	80	
Total HpCDF	22.8		25.9				
Total PCDD/Fs	1260		1350				
ITEF TEQs							
TEQ: ND=0	16.8		20.4				
TEQ: ND=DL/2	17.8		20.8				
TEQ: ND=DL	18.8		21.1				


ANALYTICAL PERSPECTIVES 2714 Exchange Drive
 Wilmington, NC 28405, USA
 info@ultratrace.com
 Tel: +1 910 794-1613 (Fax: -3919); Toll-Free 866 846-8290 www.ultratrace.com

16-1-91

Sample ID: Unit 1 FF Outlet Run 2

Method 23

Client Data		Sample Data		Laboratory Data			
Name:	Clean Air Engineering	Matrix:	Air	Lab Project ID:	P2096	Date Received:	20 Mar 2010
Project ID:	10955	Weight/Volume:	1	Lab Sample ID:	P2096_7679_003	Date Extracted:	06 Apr 2010
Date Collected:	17 Mar 2010	Split:	2	QC Batch No:	7679	Date Analyzed:	09 Apr 2010
				Dilution:	-	Time Analyzed:	11:38:53
Analyte	Conc. (pg)	DL (pg)	EMPC (pg)	Qualifiers	Standard	ES Recoveries	Qualifiers
2378-TCDD	EMPC	[Ra=1.20]	2.21	J	ES 2378-TCDD	86.3	
12378-PeCDD	EMPC		4.52	J	ES 12378-PeCDD	82.9	
123478-HxCDD	5.7			J	ES 123478-HxCDD	82.1	
123678-HxCDD	13			J	ES 123678-HxCDD	84.3	
123789-HxCDD	8.47			J	ES 123789-HxCDD	84.4	
1234678-HpCDD	67.6				ES 1234678-HpCDD	84.1	
OCDD	122			B	ES OCDD	82.8	
2378-TCDF	18.4				ES 2378-TCDF	88.6	
12378-PeCDF	19.8			J	ES 12378-PeCDF	85.4	
23478-PeCDF	20.4			J	ES 23478-PeCDF	85.2	
123478-HxCDF	16.9			J	ES 123478-HxCDF	84.3	
123678-HxCDF	20.7			J	ES 123678-HxCDF	82.7	
234678-HxCDF	18			J	ES 234678-HxCDF	84.9	
123789-HxCDF	ND	3.04			ES 123789-HxCDF	77.9	
1234678-HpCDF	49.4			J	ES 1234678-HpCDF	79.7	
1234789-HpCDF	4.95			J	ES 1234789-HpCDF	81.6	
OCDF	EMPC		14.5	J	ES OCDF	80.2	
Totals					Standard	SS/AS Recoveries	
Total TCDD	81.8		106		SS 37Cl-2378-TCDD	98.4	
Total PeCDD	53.4		109		SS 12347-PeCDD	101	
Total HxCDD	180		194		SS 12346-PeCDF	100	
Total HpCDD	132		132		SS 123469-HxCDF	101	
Total TCDF	426		519		SS 1234689-HpCDF	98.7	
Total PeCDF	275		323		AS 1368-TCDD	89.9	
Total HxCDF	165		171		AS 1368-TCDF	91.5	
Total HpCDF	72.6		72.6				
Total PCDD/Fs	1510		1760				
ITEF TEQs							
TEQ: ND=0	22.7		27.2				
TEQ: ND=DL/2	24.7		27.3				
TEQ: ND=DL	26.7		27.5				


ANALYTICAL PERSPECTIVES 2714 Exchange Drive
 Wilmington, NC 28405, USA
 info@ultratrace.com
 Tel: +1 910 794-1613 (Fax: -3919); Toll-Free 866 846-8290 www.ultratrace.com

1 - 92

Sample ID: Unit 1 FF Outlet Run 3

Method 23

Client Data		Sample Data		Laboratory Data		Date Received: 20 Mar 2010	
Name:	Clean Air Engineering	Matrix:	Air	Lab Project ID:	P2096	Date Extracted:	06 Apr 2010
Project ID:	10955	Weight/Volume:	1	Lab Sample ID:	P2096_7679_004	Date Analyzed:	09 Apr 2010
Date Collected:	17 Mar 2010	Split:	2	QC Batch No:	7679	Time Analyzed:	12:29:27
				Dilution:	-		

Analyte	Conc. (pg)	DL (pg)	EMPC (pg)	Qualifiers	Standard	ES Recoveries	Qualifiers
2378-TCDD	EMPC	[Ra=0.89]	3.21	J	ES 2378-TCDD	85.6	
12378-PeCDD	8.62			J	ES 12378-PeCDD	82.5	
123478-HxCDD	5.91			J	ES 123478-HxCDD	80	
123678-HxCDD	11			J	ES 123678-HxCDD	85.5	
123789-HxCDD	9.54			J	ES 123789-HxCDD	86	
1234678-HpCDD	70				ES 1234678-HpCDD	82.8	
OCDD	127			B	ES OCDD	81.9	
2378-TCDF	20.5				ES 2378-TCDF	87.7	
12378-PeCDF	17			J	ES 12378-PeCDF	87.3	
23478-PeCDF	20.3			J	ES 23478-PeCDF	85.3	
123478-HxCDF	19.4			J	ES 123478-HxCDF	81.6	
123678-HxCDF	19.3			J	ES 123678-HxCDF	81.9	
234678-HxCDF	17.2			J	ES 234678-HxCDF	83.6	
123789-HxCDF	ND	2.53			ES 123789-HxCDF	77.3	
1234678-HpCDF	50.6				ES 1234678-HpCDF	79.1	
1234789-HpCDF	6.18			J	ES 1234789-HpCDF	80	
OCDF	24.2			J	ES OCDF	79.4	

Totals					Standard	SS/AS/FS/TS Recoveries	
Total TCDD	71.7		100		SS 37CI-2378-TCDD	96.1	
Total PeCDD	103		125		SS 12347-PeCDD	99.1	
Total HxCDD	154		191		SS 12346-PeCDF	93	
Total HpCDD	142		142		SS 123469-HxCDF	100	
Total TCDF	567		577		SS 1234689-HpCDF	102	
Total PeCDF	275		316		AS 1368-TCDD	88.7	
Total HxCDF	142		171		AS 1368-TCDF	89.2	
Total HpCDF	67.9		77.9				
Total PCDD/Fs	1670		1850				
ITEF TEQs							
TEQ: ND=0	27		30.2		2714 Exchange Drive ANALYTICAL PERSPECTIVES Wilmington, NC 28405, USA info@ultratrace.com www.ultratrace.com		
TEQ: ND=DL/2	28.2		30.3				
TEQ: ND=DL	29.3		30.5				

1-93

Sample ID: Reagent Blank

Method 23

Client Data		Sample Data		Laboratory Data			
Name:	Clean Air Engineering	Matrix:	Air	Lab Project ID:	P2096	Date Received:	20 Mar 2010
Project ID:	10955	Weight/Volume:	1	Lab Sample ID	P2096_7679_005	Date Extracted:	06 Apr 2010
Date Collected:	16 Mar 2010	Split:	2	QC Batch No:	7679	Date Analyzed:	09 Apr 2010
				Dilution:	-	Time Analyzed:	13:19:56

Analyte	Conc. (pg)	DL (pg)	EMPC (pg)	Qualifiers	Standard	ES Recoveries	Qualifiers
2378-TCDD	ND	1.3			ES 2378-TCDD	94.3	
12378-PeCDD	ND	1.7			ES 12378-PeCDD	97.8	
123478-HxCDD	ND	2.2			ES 123478-HxCDD	97.3	
123678-HxCDD	ND	2.16			ES 123678-HxCDD	98.7	
123789-HxCDD	ND	2.45			ES 123789-HxCDD	100	
1234678-HpCDD	ND	2.81			ES 1234678-HpCDD	96.9	
OCDD	ND	4.36			ES OCDD	92.6	
2378-TCDF	ND	0.86			ES 2378-TCDF	95.4	
12378-PeCDF	ND	1.14			ES 12378-PeCDF	97.3	
23478-PeCDF	ND	1.19			ES 23478-PeCDF	97.3	
123478-HxCDF	ND	1.68			ES 123478-HxCDF	99.9	
123678-HxCDF	ND	1.55			ES 123678-HxCDF	98	
234678-HxCDF	ND	1.7			ES 234678-HxCDF	98.2	
123789-HxCDF	ND	2.31			ES 123789-HxCDF	91.1	
1234678-HpCDF	ND	1.65			ES 1234678-HpCDF	95.9	
1234789-HpCDF	ND	2.25			ES 1234789-HpCDF	92.7	
OCDF	ND	3.57			ES OCDF	91	

Totals					Standard	SS/AS Recoveries	
Total TCDD	ND	1.3	ND		SS 37Cl-2378-TCDD	na	
Total PeCDD	ND	1.7	ND		SS 12347-PeCDD	na	
Total HxCDD	ND	2.26	ND		SS 12346-PeCDF	na	
Total HpCDD	ND	2.81	ND		SS 123469-HxCDF	na	
Total TCDF	ND	0.86	ND		SS 1234689-HpCDF	na	
Total PeCDF	ND	1.17	ND		AS 1368-TCDD	93	
Total HxCDF	ND	1.79	ND		AS 1368-TCDF	90.9	
Total HpCDF	ND	1.92	ND				
Total PCDD/Fs	ND		ND				
ITEF TEQs							
TEQ: ND=0	0		0		2714 Exchange Drive ANALYTICAL PERSPECTIVES Wilmington, NC 28405, USA info@ultratrace.com Tel: +1 910 794-1613 (Fax: -3919); Toll-Free 866 846-8290 www.ultratrace.com		
TEQ: ND=DL/2	2.18		2.18				
TEQ: ND=DL	4.37		4.37				

1 - 94

Sample ID: M23-4435-01-Audit

Method 23

<u>Client Data</u>		<u>Sample Data</u>		<u>Laboratory Data</u>			
Name:	Clean Air Engineering	Matrix:	Air	Lab Project ID:	P2096	Date Received:	20 Mar 2010
Project ID:	10955	Weight/Volume:	1	Lab Sample ID:	P2096_7679_006	Date Extracted:	06 Apr 2010
Date Collected:	nr	Split:	2	QC Batch No:	7679	Date Analyzed:	09 Apr 2010
				Dilution:	-	Time Analyzed:	14:10:25


Analyte	Conc. (pg)	DL (pg)	EMPC (pg)	Qualifiers	Standard	ES Recoveries	Qualifiers
2378-TCDD	152	[Ra=0.80]			ES 2378-TCDD	81.6	
12378-PeCDD	150				ES 12378-PeCDD	86.6	
123478-HxCDD	146				ES 123478-HxCDD	89.4	
123678-HxCDD	140				ES 123678-HxCDD	92.3	
123789-HxCDD	150				ES 123789-HxCDD	94.5	
1234678-HpCDD	140				ES 1234678-HpCDD	96.3	
OCDD	291				ES OCDD	93.7	
2378-TCDF	172				ES 2378-TCDF	83.6	
12378-PeCDF	142				ES 12378-PeCDF	88.5	
23478-PeCDF	284				ES 23478-PeCDF	88.5	
123478-HxCDF	195				ES 123478-HxCDF	91.2	
123678-HxCDF	195				ES 123678-HxCDF	90.4	
234678-HxCDF	180				ES 234678-HxCDF	90.8	
123789-HxCDF	283				ES 123789-HxCDF	83.1	
1234678-HpCDF	132				ES 1234678-HpCDF	91.3	
1234789-HpCDF	92.9				ES 1234789-HpCDF	92.4	
OCDF	284				ES OCDF	90.9	

Totals					Standard	SS/AS Recoveries	
Total TCDD	347		347		SS 37Cl-2378-TCDD	na	
Total PeCDD	358		358		SS 12347-PeCDD	na	
Total HxCDD	647		647		SS 12346-PeCDF	na	
Total HpCDD	240		240		SS 123469-HxCDF	na	
Total TCDF	357		357		SS 1234689-HpCDF	na	
Total PeCDF	618		618		AS 1368-TCDD	76.7	
Total HxCDF	959		959		AS 1368-TCDF	75.1	
Total HpCDF	309		309				

Total PCDD/Fs	4410		4410				
ITEF TEQs							
TEQ: ND=0	527		527		2714 Exchange Drive		
TEQ: ND=DL/2	527		527		ANALYTICAL PERSPECTIVES Wilmington, NC 28405, USA		
TEQ: ND=DL	527		527		info@ultratrace.com		
				Tel: +1 910 794-1613 (Fax: -3919); Toll-Free 866 846-8290 www.ultratrace.com			

1 - 95

USEPA Stationary Compliance Audit Program Dioxin/Furan Audit Form

Auditor: _____
Agency: _____
Agency Address: _____
Agency Phone #: _____
Date Analyzed: 09 Apr 2010
Auditee Company: Analytical Perspectives (Ph. 910 794-1613)
Auditee Address: 2714 Exchange Drive, Wilmington, NC 28405
Date Audit Sam Rec'd: 20 Mar 2010
Audit Sample #: M23-4435-01-Audit P2096_7679_006
Confirmation Analysis Used: Yes _____ No X
Auditee's Name: Dr. Yves Tondeur
Signature:  Dr. Kimberly Mau for Dr. Tondeur

Compound	Auditee Result (ng/sample)	Compound	Auditee Result (ng/sample)
2378-TCDD	0.152	2378-TCDF	0.172
Other TCDD	0.195	Other TCDF	0.185
12378-PeCDD	0.150	12378-PeCDF	0.142
Other PeCDD	0.207	23478-PeCDF	0.284
123478-HxCDD	0.146	Other PeCDF	0.192
123678-HxCDD	0.140	123478-HxCDF	0.195
123789-HxCDD	0.150	123678-HxCDF	0.195
Other HxCDD	0.210	123789-HxCDF	0.283
1234678-HpCDD	0.140	234678-HxCDF	0.180
Other HpCDD	0.100	Other-HxCDF	0.105
OCDD	0.291	1234678-HpCDF	0.132
		1234789-HpCDF	0.093
		Other HpCDF	0.084
		OCDF	0.284

* 1,2,3,7,8,9-HxCDF co-elutes with and is inseparable from the the last eluting HxCDF isomer. The reported value is a combined result of the two isomers.

P2096



ANALYTICAL PERSPECTIVES

PART 2

SAMPLE PATH


**DOCUMENTATION FOR THE ANALYSIS
OF
POLYCHLORINATED DIBENZO-*p*-DIOXINS & DIBENZOFURANS**

This Page Intentionally Left Blank

SAMPLE PATH

AP PROJECT No.: P2096
PROTOCOL: 23

SAMPLE PROCESSING



DIF: A&B SPIKE PROFILE

A_x: 400 PG (400 μL; 0.001 NG/ μL) FOR BCS₃ ONLY (PREPARED W/ TRAPS)

ES: 4 NG (400 μL; 0.01 NG/ μL)

SS: 4 NG (40 μL; 0.1 NG/ μL; 0.04 NG/ μL OR 1.6 NG FOR TCDD)

AS: 4 NG (400 μL; 0.01 NG/ μL)

JS: 2 NG (200 μL; 0.01 NG/ μL)


SOPS

EXTRACTION: AP-SPE
FRACTIONATION: AP-SP-CU
ANALYSIS: AP-SP-A
CONCENTRATION: AP-SP-N
FORTIFICATION: AP-SP-F
DATA VALIDATION: AP-SP-R


QC PROFILE

LMB: ALWAYS REQUIRED
BCS₃: ALWAYS REQUIRED

SAMPLE EXTRACTION



SAMPLE ANALYSIS



SPECIAL REQUIREMENTS

MONO-OCTA: YES **NO**

SUPPLIES IDS

SAND	
TOLUENE	094090
ACID SILICA	03302010
BASE SILICA	02052010
SILICA	03292010
FLORISIL	03262010
HEXANE	02525
CH ₂ CL ₂	07648
TETRADECANE	10792008
AGNO ₃	0102010

SAMPLE PATH

AP PROJECT NO: P2096
PROTOCOL: 23 PCDD/F

Probe Rinse
Ac/MC/Tol
↓
Concentration

Filter

XAD Pre-Spiked
(4 ng PCDD/F SS)
Sampling Modules Prep. Project No.: T0525

Add PCDD/F ES
Vol.: 40 μ L; Conc.: 0.1 ng/ μ L

SDS 16 H Toluene

Concentrate & Solvent Exchange
Add PCDD/F AS Vol.: 40 μ L; Conc.: 0.1 ng/ μ L

(1/2)

ASECS

Add M23 JS
Vol.: 20 μ L; Conc.: 0.1 ng/ μ L

HRGC - HRMS
M23; FV 20 μ L

(1/2)

Archive

Project: P2096

Extraction Batch: 7679

Extraction Group: EPA Method 23

Handwritten notes: 4/6/10, 4/6/10, 4/7/10, 4/8/10

SDS Number	AP Sample ID	Client Sample ID	Observations	ES	A Ax B	SDS	AS	SPLIT 1/4	ASECS (Td)	JS
—	0_7679_BCS3	—	Std	400ul	400ul	701	400ul	(1/2)	40ul	200 ul
3	0_7679_MB001	—	Prespiked XAO	Q	Q	Q	all	all	max	3 Am
4	P2096_7679_001	Field Blank	} see obs. sheet	Q	—	Q	all	all	max	4 Am
5	P2096_7679_002	Unit 1 FF Outlet Run 1		Q	—	Q	all	all	max	5 Am
6	P2096_7679_003	Unit 1 FF Outlet Run 2		Q	—	Q	all	all	max	6 Am
7	P2096_7679_004	Unit 1 FF Outlet Run 3		Q	—	Q	all	all	max	7 Am
8	P2096_7679_005	Reagent Blank		Q	—	Q	all	all	max	8 Am
9	P2096_7679_006	M23-4435-01-Audit		Q	—	Q	all	all	max	14 Am

4/6/10 4/6/10 4-7-10 4-7-10 4-7-10 4-8-10

AxB: 01262009
 w/0.05ul
 01/26/11
 SIL 9-2-2

TRANSFER: 4/8/10
 RECEIVED: [Signature] 4/8/10

ES ID: CUL D/F ES
 ES (conc.): 10 psul
 ES (exp.): 3/20/15
 Vial #: SIL 4-30-2
 400 0.01
 ES: 23 20ul @ 0.2ng/ul

Ax ID: 07012007
 Ax (conc.): 0.001
 Ax (exp.): 12/30/10
 Vial #: SIL 9-82-1
 400 0.001
 Ax: 23 20ul @ 0.2ng/ul

AS ID: 07012007E-AS
 AS (conc.): 10 psul
 AS (exp.): 3/14/11
 Vial #: SIL 10-3-1
 400 0-01
 AS: 23 20ul @ 0.2ng/ul

JS ID: 07012007N-JS
 JS (conc.): 10 psul
 JS (exp.): 3/5/11
 Vial #: SIL 10-4-2
 200 0.01
 JS: 23 10ul @ 0.2ng/ul

Cycle Time: 4/6/10
 Start: 3:00 PM
 Stop: 9:30 PM
4/7/10

Check Out: [Signature] 4/6/10
 Chemist:
 Check-In: 1/2 to/acc 1
 Chemist:



SAMPLE PATH

AP PROJECT No.: P2096

VERSION B

SPIKE PROFILE & OBSERVATIONS

SPIKE PROFILE PCDD/F ONLY SAMPLING TRAIN OR PUF

Analyte	Spiked Compounds	Spiked Amount	Spiked Volume	Spiking Solution Conc.	Split Factor Factor	Final Volume	Final Solvent
PCDD/F <i>ee Ad 4/13/10</i>	SS/AS	4 ng	40 µL	0.1 ng/µL	2	20 µL	Td
	ES	4 ng	400 µL	0.01 ng/µL			
	JS	2 ng	200 µL	0.01 ng/µL			
	Ax Batch CS3 <i>A:B</i>	0.4 ng	400 µL	0.001 ng/µL	2	40 µL	Td
	Td Batch CS3	-	-	40 µL	-	40 µL	-

Sample ID	Rinses	Filter	XAD Resin	glasswool	Others
001	<i>clean, clear</i>	<i>C, WH, D</i>	<i>C, WH, D, F</i>	<i>WH, C, D</i>	
002	<i>see 001</i>	<i>see 001</i>	<i>C, WH, M, S</i>	<i>M, WH, C</i>	
003	<i>see 001</i>	<i>see 001</i>	<i>see 002</i>	<i>see 002</i>	
004	<i>see 001</i>	<i>see 001</i>	<i>see 002</i>	<i>see 002</i>	
005	<i>see 001</i>	<i>sent 2 - C, WH, D</i>	_____	_____	
006	_____	_____	<i>C, WH, D, F</i>	_____	
007					
008					
009					
010					
011					
012					
013					
014					

[Signature]
3/6/10

W = wet; S = sticky; C = clean; D = dry; F = free-flowing; WH = white; M = moist; B = bullseye; BE = beige; BK = black; YW = yellow; GY = grey; PM = particulates

1-102



ANALYTICAL PERSPECTIVES

SAMPLE PATH

AP PROJECT No.: P2096

COMMUNICATIONS

M23-4435-01

Mar '10

<p>T0525_MB000_2 CLEAN AIR ENGINEER <small>ANALYTICAL PERSPECTIVES</small> PREP: 12 MAR 2010 ADV. EXP: 26 MAR 2010 4 NG Sampling Standard PCDD/F AL KVK</p>
--

Am
4/6/10

ee to
4/13/10



M23 / M0023A PCDD/F SPIKE PROFILE

ANALYTE	SAMPLING STANDARDS AMOUNT SPIKED (NG)
³⁷ Cl ₄ -2,3,7,8-TCDD	1.6
¹³ C ₁₂ -1,2,3,4,7-PeCDD	4
¹³ C ₁₂ -1,2,3,4,6-PeCDF	4
¹³ C ₁₂ -1,2,3,4,6,9-HxCDF	4
¹³ C ₁₂ -1,2,3,4,6,8,9-HpCDF	4

COMPOUND	INJECTION STANDARDS AMOUNT SPIKED NG
¹³ C ₁₂ -1,2,3,4-TCDD	2
¹³ C ₁₂ -1,2,3,4-TCDF	2
¹³ C ₁₂ -1,2,3,4,6,7-HxCDD	1

COMPOUND	ALTERNATE STANDARD AMOUNT SPIKED NG
¹³ C ₁₂ -1,3,6,8-TCDD	4
¹³ C ₁₂ -1,3,6,8-TCDF	4

COMPOUND	EXTRACTION STANDARDS AMOUNT SPIKED NG
¹³ C ₁₂ -2,3,7,8-TCDD	4
¹³ C ₁₂ -1,2,3,7,8-PeCDD	4
¹³ C ₁₂ -1,2,3,4,7,8-HxCDD	4
¹³ C ₁₂ -1,2,3,6,7,8-HxCDD	4
¹³ C ₁₂ -1,2,3,7,8,9-HxCDD	4
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDD	4
¹³ C ₁₂ -OCDD	8
¹³ C ₁₂ -2,3,7,8-TCDF	4
¹³ C ₁₂ -1,2,3,7,8-PeCDF	4
¹³ C ₁₂ -2,3,4,7,8-PeCDF	4
¹³ C ₁₂ -1,2,3,4,7,8-HxCDF	4
¹³ C ₁₂ -1,2,3,6,7,8-HxCDF	4
¹³ C ₁₂ -2,3,4,6,7,8-HxCDF	4
¹³ C ₁₂ -1,2,3,7,8,9-HxCDF	4
¹³ C ₁₂ -1,2,3,4,7,8,9-HpCDF	4
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDF	4
¹³ C ₁₂ -OCDF	8

8290B/23 ICAL (pg/μL)

ANALYTICAL PERSPECTIVES	CS0	CS1	CS2	CS3	CS4	CS5	CS6
Unlabeled Analytes							
2,3,7,8-TCDD	0.25	0.5	2	10	40	200	500
2,3,7,8-TCDF	0.25	0.5	2	10	40	200	500
1,2,3,7,8-PeCDD	1.25	2.5	10	50	200	1000	2500
1,2,3,7,8-PeCDF	1.25	2.5	10	50	200	1000	2500
2,3,4,7,8-PeCDF	1.25	2.5	10	50	200	1000	2500
1,2,3,4,7,8-HxCDD	1.25	2.5	10	50	200	1000	2500
1,2,3,6,7,8-HxCDD	1.25	2.5	10	50	200	1000	2500
1,2,3,7,8,9-HxCDD	1.25	2.5	10	50	200	1000	2500
1,2,3,4,7,8-HxCDF	1.25	2.5	10	50	200	1000	2500
1,2,3,6,7,8-HxCDF	1.25	2.5	10	50	200	1000	2500
1,2,3,7,8,9-HxCDF	1.25	2.5	10	50	200	1000	2500
2,3,4,6,7,8-HxCDF	1.25	2.5	10	50	200	1000	2500
1,2,3,4,6,7,8-HpCDD	1.25	2.5	10	50	200	1000	2500
1,2,3,4,6,7,8-HpCDF	1.25	2.5	10	50	200	1000	2500
1,2,3,4,7,8,9-HpCDF	1.25	2.5	10	50	200	1000	2500
OCDD	2.5	5	20	100	400	2000	5000
OCDF	2.5	5	20	100	400	2000	5000
Extraction Standards							
¹² C ₁₂ -2,3,7,8-TCDD	100	100	100	100	100	100	100
¹³ C ₁₂ -2,3,7,8-TCDF	100	100	100	100	100	100	100
¹² C ₁₂ -1,2,3,7,8-PeCDD	100	100	100	100	100	100	100
¹³ C ₁₂ -1,2,3,7,8-PeCDF	100	100	100	100	100	100	100
¹² C ₁₂ -2,3,4,7,8-PeCDF	100	100	100	100	100	100	100
¹³ C ₁₂ -1,2,3,4,7,8-HxCDD	100	100	100	100	100	100	100
¹² C ₁₂ -1,2,3,6,7,8-HxCDD	100	100	100	100	100	100	100
¹³ C ₁₂ -1,2,3,7,8,9-HxCDD	100	100	100	100	100	100	100
¹² C ₁₂ -1,2,3,4,7,8-HxCDF	100	100	100	100	100	100	100
¹³ C ₁₂ -1,2,3,6,7,8-HxCDF	100	100	100	100	100	100	100
¹² C ₁₂ -2,3,4,6,7,8-HxCDF	100	100	100	100	100	100	100
¹³ C ₁₂ -1,2,3,7,8,9-HxCDF	100	100	100	100	100	100	100
¹² C ₁₂ -1,2,3,4,6,7,8-HpCDD	100	100	100	100	100	100	100
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDF	100	100	100	100	100	100	100
¹² C ₁₂ -1,2,3,4,7,8,9-HpCDF	100	100	100	100	100	100	100
¹³ C ₁₂ -OCDD	200	200	200	200	200	200	200
¹³ C ₁₂ -OCDF	200	200	200	200	200	200	200
Cleanup Standards							
²⁷ Cl ₁ -2,3,7,8-TCDD	-	0.5	2	10	40	200	-
¹² C ₁₂ -1,2,3,4,7-PeCDD	100	100	100	100	100	100	100
¹² C ₁₂ -1,2,3,4,6-PeCDF	100	100	100	100	100	100	100
¹² C ₁₂ -1,2,3,4,6,9-HxCDF	100	100	100	100	100	100	100
¹³ C ₁₂ -1,2,3,4,6,8,9-HpCDF	100	100	100	100	100	100	100
Alternate Standards							
¹² C ₁₂ -1,3,6,8-TCDD				100			
¹³ C ₁₂ -1,3,6,8-TCDF				100			
Injection Standards							
¹² C ₁₂ -1,2,3,4-TCDD	100	100	100	100	100	100	100
¹³ C ₁₂ -1,2,3,4-TCDF	100	100	100	100	100	100	100
¹² C ₁₂ -1,2,3,4,6,7-HxCDD	50	50	50	50	50	50	50

ANALYTICAL PERSPECTIVES *Sample Inventory Report: MMS Sampling Train*

Project No.: P2096 Date Rec.: 21-Mar-10 ✓ Project Name: 10955 ✓

Lab. Sample ID	Collection Date	Client Sample ID	Component ID
001	18-Mar-10 ✓	Field Blank ✓	Acetone
	18-Mar-10		Filter
	18-Mar-10		T0525-004 ✓
	18-Mar-10		Toluene
	18-Mar-10		XAD
002	16-Mar-10 ✓	Unit 1 FF Outlet Run 1 ✓	Acetone
	16-Mar-10		Filter
	16-Mar-10		T0525-001 ✓
	16-Mar-10		Toluene
	16-Mar-10		XAD
003	17-Mar-10 ✓	Unit 1 FF Outlet Run 2 ✓	Acetone
	17-Mar-10		Filter
	17-Mar-10		T0525-002 ✓
	17-Mar-10		Toluene
	17-Mar-10		XAD
004	17-Mar-10 ✓	Unit 1 FF Outlet Run 3 ✓	Acetone
	17-Mar-10		Filter
	17-Mar-10		T0525-003 ✓
	17-Mar-10		Toluene
	17-Mar-10		XAD
005	16-Mar-10 ✓	Reagent Blank ✓	Acetone
	16-Mar-10		Filter
	16-Mar-10		Toluene
006		M23-4435-01-Audit ✓	XAD

I - 106

OK
AD 3/21/10

CHAIN OF CUSTODY FORM

M23-NB-10955-001

CLIENT Wheelabrator North Broward
 PLANT Same
 PROJECT MANAGER Scott Brown

PROJECT NO. 10955
 DEPT. 66

ANALYSIS REQUESTED P2096 1/2

CLEANAIR

LAB NO.	RUN NO.	TEST LOCATION	DATE	SAMPLE MATRIX	NO. OF CONTAINERS	ORIGINAL VOLUME	PCDD/PCDF	ANALYSIS REQUESTED	ADDITIONAL INFORMATION
	1	Unit ^{3A} FF Outlet	3/16/2010	Filter	1		X		
	1		3/16/2010	Acetone Rinse	1		X		
	1		3/16/2010	Toluene Rinse	1		X		
	1	V	3/16/2010	Trap #T0525_001	1		X		
	2	Unit ^{3B} FF Outlet	3/16/2010	Filter	1		X		
	2		3/16/2010	Acetone Rinse	1		X		
	2		3/16/2010	Toluene Rinse	1		X		
	2	V	3/16/2010	Trap #T0525_002	1		X		
	NA	Audit Sample	17-Mar	4435-01	1		X		

Relinquished by: (Signature) <i>[Signature]</i>	Date / Time 3/19/10 11:00	Received by: (Signature) <i>[Signature]</i>	Date / Time 20 Mar 10 10:20	Relinquished by: (Signature)	Date / Time
Courier:	Date / Time	Relinquished by: (Signature)	Date / Time	Received for Analysis by:	Date / Time

Special Handling Instructions	This form was completed by: Scott Brown Signature <i>[Signature]</i> Date 3/19/10	 500 West Wood Street Palatine, IL 60067 (800) 627-0033 ph (847) 991-3365 fax www.cleanair.com
Forwarding Lab: <u>Analytical Perspectives</u>	PO Number: _____	

1-107

CHAIN OF CUSTODY FORM

M23-NB-10955-002

CLIENT Wheelabrator North Broward
 PLANT Same
 PROJECT MANAGER Scott Brown

PROJECT NO. 10955
 DEPT. 66

NO. OF CONTAINERS	ORIGINAL VOLUME	ANALYSIS REQUESTED				ADDITIONAL INFORMATION
		PCDD/PCDF				

CLEANAIR

LAB NO.	RUN NO.	TEST LOCATION	DATE	SAMPLE MATRIX	NO. OF CONTAINERS	ORIGINAL VOLUME	PCDD/PCDF	ADDITIONAL INFORMATION
	3	Unit ³⁰ EFF Outlet	3/18/10	Filter	1		X	
	3		↓	Acetone Rinse	1		X	
	3		↓	Toluene Rinse	1		X	
	3	V	↓	Trap # T0525_003	1		X	
	NA	Field Blank	3/18/2010	Filter	1		X	
	NA		3/18/2010	Acetone Rinse	1		X	
	NA		3/18/2010	Toluene Rinse	1		X	
	NA	V	3/18/2010	Trap # T0525_004	1		X	
	RB	NA	3/16/2010	Filter Reagent Blank				
	RB	NA	3/16/2010	Acetone Reagent Blank				
	RB	NA	3/16/2010	Toluene Reagent Blank				

Relinquished by: (Signature) <i>Scott Brown</i>	Date / Time 3/19/10 11:00	Received by: (Signature) <i>M Russell White</i>	Date / Time 20 Mar 10 10:20	Relinquished by: (Signature)	Date / Time
Courier:	Date / Time	Relinquished by: (Signature)	Date / Time	Received for Analysis by:	Date / Time

Special Handling Instructions Forwarding Lab: <u>Analytical Perspectives</u> PO Number: _____	This form was completed by: Scott Brown Signature _____ Date _____	 <p style="font-size: small;">500 West Wood Street Palatine, IL 60067 (800) 627-0033 ph (847) 991-3385 fax www.cleanair.com</p> <p style="font-size: x-small;">LD5001A_2-COC Palatine_M23_Jul 2002 Copyright © 2002 Clean Air Engineering Inc.</p>
---	--	--

1 - 108

INSTRUCTIONS FOR CONDUCTING A METHOD 23 DIOXIN/FURAN PERFORMANCE AUDIT

Auditor/Requestor Information

A dioxin/furan performance audit sample is provided for Method 23 analysis by the selected laboratory. Upon receipt of the audit material and forms, the auditor/requestor (or auditor/requestor's representative) should verify that the proper audit material(s), instructions, and data form(s) have been received and that the shipping material package has not been opened or has not been damaged. The auditor/requestor should not open the inner protective covering of the audit materials or alter the numbers on the audit materials. The auditor/requestor is responsible for forwarding the audit material with accompanying instructions and forms to the auditee (or auditee representative). The intent of the performance audit material is to provide quality assurance for the relative accuracy of the dioxin and furan analysis. The audit sample should be processed and analyzed in the same manner as the field samples. Upon completion of the performance audit analysis, the audit results shall be reported on the attached **Dioxin/Furan Audit Reporting Form** by the audited laboratory and then forwarded to the auditor/requestor. The auditor/requestor is to enter the audit results into the Stationary Source Audit Program (SSAP) electronic database. A dioxin/furan audit report will be developed and forwarded to the auditor within 10 work days after receipt of the report in the database. The auditor/requestor will not be informed as to which specific isomer data failed, or were acceptable, only that the results met either a 90% confidence limit or a 50% confidence limit. The auditor/requestor is responsible for providing a copy of the audit report to the tester as well as the laboratory. If, necessary, the auditor/requestor can obtain additional data quality information by contacting the SSAP staff.

Auditee Information

The auditee laboratory shall analyze the performance audit sample at the same time and in the same manner as the dioxin/furan field samples. If confirmation analysis (2,3,7,8-TCDF) is conducted and results reported for the field samples, the identical analytical procedures must be performed and results reported for the audit sample. If an isomer is not detected, the auditee should enter "0" in the appropriate space. The auditee is responsible for preparing the **Dioxin/Furan Audit Reporting Form** and forwarding the **Reporting Form** to the auditor/requestor. The auditee should carefully follow the enclosed reporting instructions listed on the attached page 3 of 4. The dioxin/furan data must be entered in the format as instructed. The **Dioxin/Furan Audit Reporting Form** has been designed to allow calculation of toxic equivalencies. The auditee may provide as many significant figures as desired. However, the database input is two significant figures. The auditee should retain a copy of the results to ensure that the audit values have been reported correctly. The auditee will not be informed as to which specific isomers are outside the confidence limits.

INSTRUCTIONS (Continued)

The dioxin/furan audit material you have received contains 17 low level dioxin/furan congeners spiked onto 20 grams of XAD-2[®] adsorbent. To extract and process the dioxin/furan audit sample, follow the steps below.

- 1) Remove the XAD-2[®] adsorbent from the container, and place in a Soxhlet apparatus extraction thimble. Thoroughly rinse the container with toluene, and place the rinses into the extraction thimble. (**Note:** There are no Container No. 1 filter or Container No. 2 acetone and methylene chloride rinse fractions to be incorporated.)
- 2) Place the extraction thimble into the extractor. Extract the contents of the extraction thimble for ~16 hours using the directions in Section 5.1.5 of Method 23.
- 3) Following extraction, transfer the toluene extract to a rotary evaporator and concentrate the sample to approximately 10 mL.
- 4) Split the concentrate sample: If the field sample concentrates are split, an identical audit concentrate split shall be performed in the same manner as the field samples. To separate the sample, split and store one/half of the fraction, and analyze the remaining fraction according to procedures in Sections 5.2 and 5.3 of Method 23.
- 5) Record the results on the **Dioxin/Furan Audit Reporting Form** in units of ng/sample per the instructions listed on page 3 of 4.
- 6) Submit the dioxin/furan audit results recorded on the **Reporting Form** to the designated agent.

INSTRUCTIONS FOR REPORTING METHOD 23 DIOXIN/FURAN PERFORMANCE AUDIT RESULTS

Note: Method 23 Dioxin/Furan Audit Samples are currently ordered using the Stationary Source Audit Program (SSAP) automated electronic database. Requestors use the *SSAP Automated Sample Request and Information System* to request audit samples and to enter the audit sample data results (answers) into the database for evaluation.

1) Please use the enclosed **Dioxin/Furan Audit Reporting Form** (page 4 of 4) as a template for reporting the dioxin/furan audit data results. The format of the form duplicates the electronic database entry table for dioxin/furan audit data results.

2) Two important components of the template are:

- Results for congeners are reported in units of **nanograms/sample**. The database will not convert other units into nanograms.
- Please note that "**Other**" is shown at the end of each congener class. Results must be reported as **other, and not as total**, congeners. For example, 1,2,3,7,8 -pentachlorodibenzofuran (PCDF) and 2,3,4,7,8 - PCDF are followed on the form by **Other PCDF**. "Other" DOES NOT include the individual compound values listed in 1,2,3,7,8 - and 2,3,4,7,8 - PCDF.

[Total PCDF] minus [1,2,3,7,8-PCDF] minus [2,3,4,7,8-PCDF] = **Other PCDF**

3) Please contact Thomas Mckenzie at Eastern Research Group, telephone (919) 468-7920, or Ray Merrill (919) 468-7887 with questions you may have. Their fax number is (919) 468-7803.

Dioxin/Furan Audit Reporting Form

Auditor:			
Agency:			
Agency Address:			
Agency Phone #:			
Date Analyzed:			
Auditee Company:			
Auditee Address:			
Date Audit Sam Rec'd:			
Audit Sample #:	M23-4435-01		
Confirmation Analysis Used:	Yes ____ No ____		
Auditee's Name:			
Signature:			
Compound	Auditee Result (ng/sample)	Compound	Auditee Result (ng/sample)
2378-TCDD		2378-TCDF	
Other TCDD		Other TCDF	
12378-PeCDD		12378-PCDF	
Other PeCDD		23478-PCDF	
123478-HxCDD		Other PCDF	
123678-HxCDD		123478-HxCDF	
123789-HxCDD		123678-HxCDF	
Other HxCDD		123789-HxCDF	
1234678-HpCDD		234678-HxCDF	
Other HpCDD		Other HxCDF	
OCDD		1234678-HpCDF	
		1234789-HpCDF	
		Other HpCDF	
		OCDF	

CLIENT SAMPLE ID	Field Blank	Unit 1 FF Outlet Row 1	Unit 1 FF Outlet Row 2	Unit 1 FF Outlet Row 3
LAB SAMPLE #	P2096-001	-002	-003	-004
DATE SAMPLED	3/18/10	3/16/10	3/17/10	3/17/10
OBSERVATIONS				
COMPONENTS	QUANTITY	QUANTITY	QUANTITY	QUANTITY
FILTER				
XAD				
TRAP PREP#	T0525-004	T0525-001	T0525-002	T0525-003
ACETONE / CH ₂ Cl ₂ FH/BH RINSE				
TOLUENE FH/BH RINSE				
OTHER (IMPINGERS, ETC...)				
TRAP SOURCE	<input type="checkbox"/> AP <input checked="" type="checkbox"/> CLIENT			
CLIENT SAMPLE ID	Reagent Blank	m23-4435-01-Audit		
LAB SAMPLE #	P2096-005	-006		
DATE SAMPLED	3/16/10			
OBSERVATIONS				
COMPONENTS	QUANTITY	QUANTITY	QUANTITY	QUANTITY
FILTER				
XAD				
TRAP PREP#				
ACETONE / CH ₂ Cl ₂ FH/BH RINSE				
TOLUENE FH/BH RINSE				
OTHER (IMPINGERS, ETC...)				
TRAP SOURCE	<input type="checkbox"/> AP <input type="checkbox"/> CLIENT			

UNUSED TRAPS: T0525-006, 005

METHOD 23 PCDD/PCDFs

1-113

TYPE & NO. OF APPARATUS

QUANTITY OF XAD: 12

RESIN BATCH NO.: 51311

QUANTITY OF PUF: 0

RESIN BATCH NO.: N/A

FILTER SIZE 82.6

QUANTITY OF FILTERS: 14

FILTER BATCH #: 02112010

QUANTITY PETRI DISHES: 0

JARS AND/OR BOTTLES: 0

CLIENT SPECIFIC INSTRUCTIONS

Hi, Please put 6 traps in one cooler and 6 in another cooler. I will be shipping the North samples on

SPIKE PROFILE

*#MB/BCS3 NEEDED:

VOL. PCDD/F: 40 µl
SOLUTION ID: 07012007A CS/SS
VIAL ID: SK 7-23-7 EXP: 06/24/10

VOL. HR_PAH:
SOLUTION ID: _____
VIAL ID: _____ EXP: _____

VOL. HR_PCB:
SOLUTION ID: _____
VIAL ID: _____ EXP: _____

SAMPLING MODULE REQUEST FORM

AP PROJECT #:

T0525

FOLLOWING SAMPLE RECOVERY, PLEASE RETURN THIS FORM IF NECESSARY WITH THE FIELD SAMPLES TO:



2714 EXCHANGE DRIVE
WILMINGTON, NC 28405
PH: 910-794-1613
FAX: 910-794-3919

TYPE OF ANALYSIS & TAT

DIOXIN: yes | TAT: 30_days
PAH: no
PCB: no
OTHER: no | DESC.:

INITIAL BELOW

PREP BY: AL KVC
SPIKE BY: JM
WITNESS: KVC DATE: 3/12/10

CLIENT INFORMATION

COMPANY/ORG: UNITED STATES OF AMERICA
CONTACT: SCOTT BROWN

CLIENT PROJECT ID: 10955

CLIENT POS: 10955
P2096 1/2

DATE OF REQUEST: 22/02/2010,

ARRIVAL DATE: 15/03/2010

SHIP TO:
Wheelabrator North Broward
2680 NW 48th Street

Pompano Beach
FL 33073
United States of America
954-971-8701

sbrown@cleanair.com

**ALL PROJECTS ARE SHIPPED
PRIORITY OVERNIGHT VIA FEDEX**

ADDITIONAL NOTES

7933 5118 3509
AIRWAY BILL #: 7933 5118 3406

DATE SHIPPED: 12-march-10

AP INVOICE #: 11594

AP RENTAL TRAPS: N/A

QUANTITY: N/A

1-114

P2096 2/2

TRAP BATCH

TOS25

INITIAL & DATE BELOW FOR EACH TRAP

SPIKING TRAPS

ONLY FILL OUT APPLICABLE TABLE

514.23.3

SOLUTION ID: 0702007A CS/SS	
SPIKE VOLUME: 40 μ l	
TRAP ID	PCDD/Fs
MB-000	KVK KVK
BCS3	KVK KVK
001	KVK
002	KVK
003	KVK
004	KVK
005	KVK
006	KVK
007	KVK
008	KVK
009	KVK
010	KVK
011	KVK
012	KVK
013	
014	
015	

03/12/10 KVK

SOLUTION ID:	
SPIKE VOLUME:	
TRAP ID	HRPCBs
MB-000	
BCS3	
001	
002	
003	
004	
005	
006	
007	
008	
009	
010	
011	
012	
013	
014	
015	

SOLUTION ID:	
SPIKE VOLUME:	
TRAP ID	HRPAHs
MB-000	
BCS3	
001	
002	
003	
004	
005	
006	
007	
008	
009	
010	
011	
012	
013	
014	
015	

SOLUTION ID:	
SPIKE VOLUME:	
TRAP ID	OTHER
MB-000	
BCS3	
001	
002	
003	
004	
005	
006	
007	
008	
009	
010	
011	
012	
013	
014	
015	

SAMPLE LOG-IN FORM Box# 1

Client Project / Job ID:
10955

Date Samples Arrived: 22 Mar 10 Initials: nm

Time / Date logged in: 9:14 22 Mar 10 Refrigerator: F2 Initials: NM

Samples Arrived By: (circle one) FedEx UPS Airborne Express DHL Emery
Freezer Truck Company Courier Other _____

PO #:
10955

AP Project ID: P2096

CHAIN OF CUSTODY ANOMALY FORM

Shipping Preservation: Traps & Filters: Ice / Blue Ice / Dry Ice / None Temp °C _____

The following items were omitted from the COC

Solvents: Ice / Blue Ice / Dry Ice / None Temp °C 17° VAD

Project ID and/or PO#:

Shipping Documentation Present? (circle one) Shipping Label or Airbill

Sampler:

of boxes: 1 # of coolers: 0 Tracking #s: 8620 7138 4541

Relinquished By:

Shipping Container(s) intact? YES If no, describe condition:

Date:

Container Custody Seals Present & Intact? N/A If not intact, describe condition:

Time:

Sample Custody Seals Present & Intact? N/A If not intact, describe condition:

Sample ID:

of Seals: 0 or Seal #: 0

Sample Date:

Sample Container Intact? YES If no, indicate sample condition:

Sample Collection Times:

Chain of Custody (COC) / Sample Documentation Present? YES Exceptions? N/A

Sample Description:

If not, complete COC Anomaly Form

Analysis Requested:

Shipping Containers: Coolers: Client or AP Return Retain Dispose

Container Qty.:

Boxes: Client or AP Return Retain Dispose

Container Type:

Sample Control Log In/Out Completed? YES

Other:

FILL BELOW IF APPLICABLE

COMMENTS

Have all the samples arrived? YES If no, complete the following.

Shipment #: _____ Date of Arrival: _____ Condition: _____ Temp °C _____

Delivered by: _____ Tracking #s _____

COC Present? _____ Acceptable? _____ If no, document on COC Anomaly Form additional shipment comments.

Container Intact? _____ Samples Intact? _____ If no, describe:

Do we expect another shipment? _____ If yes, start a new log-in sheet. ☺

1-116

SAMPLE LOG-IN FORM Bou # 2

Client Project / Job ID:

10955

PO #:

10955

AP Project ID: P2096

CHAIN OF CUSTODY ANOMALY FORM

The following items were omitted from the COC

Project ID and/or PO#:

Sampler:

Relinquished By:

Date:

Time:

Sample ID:

Sample Date:

Sample Collection Times:

Sample Description:

Analysis Requested:

Container Qty.:

Container Type:

Other:

COMMENTS

Date Samples Arrived: 22 Mar 10 Initials: NM

Time / Date logged in: 9:17 22 Mar 10 Refrigerator: F2 Initials: NM

Samples Arrived By: (circle one) FedEx UPS Airborne Express DHL Emery
Freezer Truck Company Courier Other _____

Shipping Preservation: Traps & Filters: Ice / Blue Ice / Dry Ice / None Temp °C _____

Solvents: Ice / Blue Ice / Dry Ice / None Temp °C 19° VAD

Shipping Documentation Present? (circle one) Shipping Label or Airbill

of boxes: 1 # of coolers: 1 Tracking #s: 8620 7138 4611

Shipping Container(s) intact? yes If no, describe condition:

Container Custody Seals Present & Intact? NA If not intact, describe condition:

Sample Custody Seals Present & Intact? NA If not intact, describe condition:

of Seals: 0 or Seal #: 0

Sample Container Intact? yes If no, indicate sample condition:

Chain of Custody (COC) / Sample Documentation Present? yes Exceptions? NA

If not, complete COC Anomaly Form

Shipping Containers: Coolers: Client or AP Return Retain Dispose

Boxes: Client or AP Return Retain Dispose

Sample Control Log In/Out Completed? yes

FILL BELOW IF APPLICABLE

Have all the samples arrived? yes If no, complete the following.

Shipment #: _____ Date of Arrival: _____ Condition: _____ Temp °C _____

Delivered by: _____ Tracking #s: _____

COC Present? _____ Acceptable? _____ If no, document on COC Anomaly Form additional shipment comments.

Container Intact? _____ Samples Intact? _____ If no, describe:

Do we expect another shipment? _____ If yes, start a new log-in sheet. ☺

SAMPLE LOG-IN FORM Cooler # 1

Client Project / Job ID:

10955

PO #:

10955

Date Samples Arrived: 20 Mar 10 Initials: NM

Time / Date logged in: 10:20 22 Mar 10 Refrigerator: E2 Initials: NM

Samples Arrived By: (circle one) FedEx UPS Airborne Express DHL Emery
Freezer Truck Company Courier Other _____

AP Project ID: P2096

CHAIN OF CUSTODY ANOMALY FORM

Shipping Preservation: Traps & Filters: (Ice) Blue Ice / Dry Ice / None Temp °C 2° VAD

The following items were omitted from the COC

Solvents: Ice / Blue Ice / Dry Ice / None Temp °C _____

Project ID and/or PO#:

Shipping Documentation Present? (circle one) Shipping Label or (Airbill)

Sampler:

of boxes: 0 # of coolers: 1 Tracking #: 8620 7138 4530

Relinquished By:

Shipping Container(s) intact? yes If no, describe condition:

Date:

Container Custody Seals Present & Intact? NA If not intact, describe condition:

Time:

Sample Custody Seals Present & Intact? NA If not intact, describe condition:

Sample ID:

of Seals: 0 or Seal #: 0

Sample Date:

Sample Container Intact? yes If no, indicate sample condition:

Sample Collection Times: missing on COC

Chain of Custody (COC) / Sample Documentation Present? NO Exceptions? NIA

Sample Description:

If not, complete COC Anomaly Form

Analysis Requested:

Shipping Containers: Coolers: Client or (AP) Return (Retain) Dispose

Container Qty.:

Boxes: Client or AP Return Retain Dispose

Container Type:

Sample Control Log In/Out Completed? yes

Other:

FILL BELOW IF APPLICABLE

COMMENTS

Have all the samples arrived? NO If no, complete the following. missing Solvents

Sample Collection times missing on samples

Shipment #: _____ Date of Arrival: _____ Condition: _____ Temp °C _____

Delivered by: _____ Tracking #s _____

COC Present? _____ Acceptable? _____ If no, document on COC Anomaly Form additional shipment comments.

Run 2 & Run 3

Container Intact? _____ Samples Intact? _____ If no, describe: SM date time does not match

Do we expect another shipment? _____ If yes, start a new log-in sheet. ☺

COC SM

Analytical Perspectives — Injection Log

Created: 09-Apr-2010 16:20

User: MC

SW: AP UltraTrace-Pro V4.21

Expt: DF_CL4-8A

GC: DB5MS_60M

Project: P2096_7679_DF

#	Datafile	Vial#	Lab ID	Client ID	Analyst	Acq Date	Acq Time
1	100409P1-01	46	BCS3_7679_DF_PA	BCS3_7679_DF_PA	MC	9-APR-2010	07:26:36
3	100409P1-03	47	MB1_7679_DF_SDS	0_7679_MB001	MC	9-APR-2010	09:07:26
4	100409P1-04	48	P2096_7679_001	Field Blank	MC	9-APR-2010	09:57:56
5	100409P1-05	49	P2096_7679_002	Unit 1 FF Outlet Run 1	MC	9-APR-2010	10:48:24
6	100409P1-06	50	P2096_7679_003	Unit 1 FF Outlet Run 2	MC	9-APR-2010	11:38:53
7	100409P1-07	51	P2096_7679_004	Unit 1 FF Outlet Run 3	MC	9-APR-2010	12:29:27
8	100409P1-08	52	P2096_7679_005	Reagent Blank	MC	9-APR-2010	13:19:56
9	100409P1-09	53	P2096_7679_006	M23-4435-01-Audit	MC	9-APR-2010	14:10:25
10	100409P1-10	46	BCS3_7679_DF_PB	BCS3_7679_DF_PB	MC	9-APR-2010	15:00:55

REVIEWED
By Michael D.H. Chu at 4:20 pm, Apr 09, 2010

REVIEWED
By Kimberly Mace at 3:37 pm, Apr 12, 2010

Analytical Perspectives — Injection Log

Created: 09-Apr-2010 16:20

User: MC

S/W: AP UltraTrace-Pro V4.21

Expt: DF_CL4-8A

GC: DB5MS_60M

Project: P2096_7679_DF

#	Datafile	Vial#	Lab ID	Client ID	Analyst	Acq Date	Acq Time
1	100409P1-01	46	BCS3_7679_DF_PA	BCS3_7679_DF_PA	MC	9-APR-2010	07:26:36
3	100409P1-03	47	MB1_7679_DF_SDS	0_7679_MB001	MC	9-APR-2010	09:07:26
4	100409P1-04	48	P2096_7679_001	Field Blank	MC	9-APR-2010	09:57:56
5	100409P1-05	49	P2096_7679_002	Unit 1 FF Outlet Run 1	MC	9-APR-2010	10:48:24
6	100409P1-06	50	P2096_7679_003	Unit 1 FF Outlet Run 2	MC	9-APR-2010	11:38:53
7	100409P1-07	51	P2096_7679_004	Unit 1 FF Outlet Run 3	MC	9-APR-2010	12:29:27
8	100409P1-08	52	P2096_7679_005	Reagent Blank	MC	9-APR-2010	13:19:56
9	100409P1-09	53	P2096_7679_006	M23-4435-01-Audit	MC	9-APR-2010	14:10:25
10	100409P1-10	46	BCS3_7679_DF_PB	BCS3_7679_DF_PB	MC	9-APR-2010	15:00:55

REVIEWED
By Michael D.H. Chu at 4:20 pm, Apr 09, 2010

REVIEWED
By Kimberly Mace at 8:11 pm, Apr 12, 2010

P2096



PART 3

ANALYTICAL RESULTS

**DOCUMENTATION FOR THE ANALYSIS
OF
POLYCHLORINATED DIBENZO-*p*-DIOXINS & DIBENZOFURANS**

This Page Intentionally Left Blank

Samples processed against BCS3. KAM 12 Apr 10

Lab ID: MB1_7679_DF_SDS
 Client ID: 0_7679_MB001
 Datafile: 100409P1-03

Acq'd: 09 Apr 2010 09:07 MC
 UTP: 09-Apr-2010 15:51 MC
 Report: 09 Apr 2010 15:53 MC

Wt/Vol: 1
 J-level: 10 pg
 ES spike: 4000 pg

Cal: BCS3_7679_DF_PAB
 Checkcode: 681-930

Split: 2

Name	Act RT	QC	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Conc.	Noise	DL
2378-TCDD	Not Fnd		1.0008	-		-	-	-	0.99	-	1226	1.46
12378-PeCDD	Not Fnd		1.0006	-		-	-	-	0.93	-	1290	1.79
123478-HxCDD	Not Fnd		1.0004	-		-	-	-	1.04	-	1414	2.66
123678-HxCDD	Not Fnd		1.0034	-		-	-	-	0.95	-	1414	2.48
123789-HxCDD	Not Fnd		1.0116	-		-	-	-	0.93	-	1414	2.79
1234678-HpCDD	Not Fnd		1.0003	-		-	-	-	0.96	-	1204	2.74
OCDD	43.56		1.0004	1.0004	0	5.63E+04	1.02	Y	1.00	14.1	1314	4.41
2378-TCDF	Not Fnd		1.0009	-		-	-	-	1.08	-	1324	1.07
12378-PeCDF	Not Fnd		1.0006	-		-	-	-	1.00	-	1141	1.09
23478-PeCDF	Not Fnd		1.0005	-		-	-	-	1.04	-	1141	1.03
123478-HxCDF	Not Fnd		1.0004	-		-	-	-	1.14	-	1444	1.78
123678-HxCDF	Not Fnd		1.0005	-		-	-	-	1.13	-	1444	1.66
234678-HxCDF	Not Fnd		1.0005	-		-	-	-	1.14	-	1444	1.78
123789-HxCDF	Not Fnd		1.0005	-		-	-	-	1.12	-	1444	2.42
1234678-HpCDF	Not Fnd		1.0003	-		-	-	-	1.38	-	1248	1.69
1234789-HpCDF	Not Fnd		1.0003	-		-	-	-	1.33	-	1248	2.53
OCDF	Not Fnd		1.0004	-		-	-	-	0.96	-	1282	3.41

Name	Act RT	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Rec. %
ES 2378-TCDD	26.87	1.0259	1.0258	-0.2	3.50E+07	0.81	Y	1.01	88.6
ES 12378-PeCDD	32.48	1.2404	1.2399	-0.8	2.72E+07	1.61	Y	0.78	88.9
ES 123478-HxCDD	36.44	0.9917	0.9918	+0.2	2.19E+07	1.34	Y	0.99	91.1
ES 123678-HxCDD	36.55	0.9947	0.9948	+0.2	2.40E+07	1.22	Y	1.07	92.8
ES 123789-HxCDD	36.84	1.0028	1.0028	0	2.49E+07	1.24	Y	1.09	94.1
ES 1234678-HpCDD	40.04	1.0902	1.0897	-1.1	2.00E+07	1.06	Y	0.90	91.2
ES OCDD	43.55	1.1862	1.1852	-2.2	3.20E+07	0.91	Y	0.74	89.2
ES 2378-TCDF	25.94	1.0585	1.0584	-0.1	5.03E+07	0.80	Y	1.00	89.1
ES 12378-PeCDF	30.98	1.2646	1.2640	-0.9	3.87E+07	1.57	Y	0.75	91.1
ES 23478-PeCDF	32.12	1.3113	1.3106	-1.0	3.87E+07	1.59	Y	0.74	91.7
ES 123478-HxCDF	35.46	0.9651	0.9652	+0.2	2.76E+07	0.52	Y	1.19	95.6
ES 123678-HxCDF	35.60	0.9689	0.9691	+0.4	3.08E+07	0.53	Y	1.35	94.2
ES 234678-HxCDF	36.26	0.9867	0.9868	+0.2	2.89E+07	0.53	Y	1.28	92.9
ES 123789-HxCDF	37.21	1.0129	1.0129	0	2.42E+07	0.52	Y	1.20	83.4
ES 1234678-HpCDF	38.89	1.0589	1.0586	-0.7	2.07E+07	0.44	Y	0.95	89.9
ES 1234789-HpCDF	40.60	1.1057	1.1051	-1.3	1.71E+07	0.44	Y	0.82	86.2
ES OCDF	43.78	1.1926	1.1915	-2.4	4.04E+07	0.89	Y	0.96	86.9

Lab ID: MB1_7679_DF_SDS

Client ID: 0_7679_MB001

Datafile: 100409P1-03

Acq'd: 09 Apr 2010 09:07 MC

UTP: 09-Apr-2010 15:51 MC

Report: 09 Apr 2010 15:53 MC

Wt/Vol: 1

J-level: 10 pg

ES spike: 4000 pg

Cal: BCS3_7679_DF_PAB

Checkcode: 681-930

Split: 2

Name	Act RT	QC	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Rec. %
JS 1234-TCDD	26.20		-	-	-	3.92E+07	0.81	Y	-	-
JS 1234-TCDF	24.51		-	-	-	5.66E+07	0.80	Y	-	-
JS 123467-HxCDD	36.74		-	-	-	1.21E+07	1.28	Y	-	-
CS 37C1-2378-TCDD	26.89		1.0268	1.0267	-0.2	1.58E+07	n/a	-	1.16	87.2
CS 12347-PeCDD	31.97		1.2209	1.2204	-0.8	2.78E+07	1.61	Y	0.79	89.7
CS 12346-PeCDF	30.44		1.2424	1.2421	-0.4	3.86E+07	1.58	Y	0.79	86.4
CS 123469-HxCDF	35.91		0.9773	0.9775	+0.4	2.77E+07	0.53	Y	1.23	93.1
CS 1234689-HpCDF	39.37		1.0720	1.0716	-0.9	1.88E+07	0.43	Y	0.86	90.2
SS 37C1-2378-TCDD	26.89		1.0268	1.0267	-0.2	1.58E+07	n/a	-	1.14	98.5
SS 12347-PeCDD	31.97		1.2209	1.2204	-0.8	2.78E+07	1.61	Y	1.01	101
SS 12346-PeCDF	30.44		1.2424	1.2421	-0.4	3.86E+07	1.58	Y	1.05	94.8
SS 123469-HxCDF	35.91		0.9773	0.9775	+0.4	2.77E+07	0.53	Y	0.91	98.9
SS 1234689-HpCDF	39.37		1.0720	1.0716	-0.9	1.88E+07	0.43	Y	0.91	100
AS 1368-TCDD	22.92		0.8731	0.8751	+3.1	3.76E+07	0.79	Y	1.08	88.8
AS 1368-TCDF	20.79		0.8447	0.8485	+5.6	6.64E+07	0.79	Y	1.29	90.7
FS 1278-TCDD	NotFnd		1.0131							
FS 12478-PeCDD	NotFnd		0.9617							
FS 123468-HxCDD	NotFnd		0.9713							
FS 1234679-HpCDD	39.22		0.9794	0.9795	+0.2	1.46E+05	1.02	Y	0.01	95.1
TS 1378-TCDD	NotFnd		0.9345							

FS na
KAM 12 Apr 10

Totals	Conc	EMPC
Total TCDD	0	2.25
Total PeCDD	0	0
Total HxCDD	0	0
Total HpCDD	0	0
Total Tetra-Octa Dioxins	14.1	16.3
Total TCDF	0	0
Total PeCDF	0	0
Total HxCDF	0	0
Total HpCDF	0	0
Total Tetra-Octa Furans	0	0
Total Tetra-Octa Dioxins & Furans	14.1	16.3

Lab ID: MB1_7679_DF_SDS
 Client ID: 0_7679_MB001
 Datafile: 100409P1-03

Acq'd: 09 Apr 2010 09:07 MC
 UTP: 09-Apr-2010 15:51 MC
 Report: 09 Apr 2010 15:53 MC

Wt/Vol: 1
 J-level: 10 pg
 ES spike: 4000 pg

Cal: BCS3_7679_DF_PAB
 Checkcode: 681-930

Name	Act RT	QC	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Conc.	Noise	DL
1368-TCDD	22.96		0.8539	0.8544	+0.8	1.96E+04	0.59	N	0.99	2.25	1226	1.46
1379-TCDD	Not Fnd		0.8685						0.99		1226	1.46
1369-TCDD	Not Fnd		0.8863						0.99		1226	1.46
1469-TCDD	Not Fnd		0.9189						0.99		1226	1.46
1247/1246/1248/1249-TCDD	Not Fnd		0.9276						0.99		1226	1.46
1378-TCDD	Not Fnd		0.9351						0.99		1226	1.46
1268-TCDD	Not Fnd		0.9430						0.99		1226	1.46
1478-TCDD	Not Fnd		0.9517						0.99		1226	1.46
1279-TCDD	Not Fnd		0.9598						0.99		1226	1.46
1234/1269-TCDD	Not Fnd		0.9740						0.99		1226	1.46
1236-TCDD	Not Fnd		0.9801						0.99		1226	1.46
1237/1238-TCDD	Not Fnd		0.9895						0.99		1226	1.46
1239-TCDD	Not Fnd		0.9952						0.99		1226	1.46
2378-TCDD	Not Fnd		1.0008						0.99		1226	1.46
1278-TCDD	Not Fnd		1.0138						0.99		1226	1.46
1267-TCDD	Not Fnd		1.0194						0.99		1226	1.46
1289-TCDD	Not Fnd		1.0396						0.99		1226	1.46
12479/12468-PeCDD	Not Fnd		0.9210						0.93		1290	1.79
12469-PeCDD	Not Fnd		0.9382						0.93		1290	1.79
12368-PeCDD	Not Fnd		0.9556						0.93		1290	1.79
12478-PeCDD	Not Fnd		0.9614						0.93		1290	1.79
12379-PeCDD	Not Fnd		0.9649						0.93		1290	1.79
12369/12467/12489-PeCDD	Not Fnd		0.9732						0.93		1290	1.79
12346/12347-PeCDD	Not Fnd		0.9850						0.93		1290	1.79
12378-PeCDD	Not Fnd		1.0006						0.93		1290	1.79
12367-PeCDD	Not Fnd		1.0037						0.93		1290	1.79
12389-PeCDD	Not Fnd		1.0146						0.93		1290	1.79
124679/124689-HxCDD	Not Fnd		0.9534						0.97		1414	2.64
123468-HxCDD	Not Fnd		0.9717						0.97		1414	2.64
123679/123689-HxCDD	Not Fnd		0.9793						0.97		1414	2.64
123469-HxCDD	Not Fnd		0.9833						0.97		1414	2.64
123478-HxCDD	Not Fnd		1.0004						1.04		1414	2.66
123678-HxCDD	Not Fnd		1.0034						0.95		1414	2.48
123467-HxCDD	Not Fnd		1.0088						0.97		1414	2.64
123789-HxCDD	Not Fnd		1.0116						0.93		1414	2.79

1 - 125

Lab ID: MB1_7679_DF_SDS

Client ID: 0_7679_MB001

Datafile: 100409P1-03

Acq'd: 09 Apr 2010 09:07 MC

UTP: 09-Apr-2010 15:51 MC

Report: 09 Apr 2010 15:53 MC

Wt/Vol: 1

J-level: 10 pg

ES spike: 4000 pg

Cal: BCS3_7679_DF_PAB

Checkcode: 681-930

Split: 2

Name	Act RT	QC	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Conc.	Noise	DL
1234679-HpCDD	NotFnd		0.9794						0.96		1204	2.74
1234678-HpCDD	NotFnd		1.0003						0.96		1204	2.74
OCDD	43.56		1.0004	1.0004	0	5.63E+04	1.02	Y	1.00	14.1	1314	4.41
OCDD-a	NotFnd		1.0003						0.06		1475	81.1
1368-TCDF	NotFnd		0.8012						1.08		1324	1.07
1468-TCDF	NotFnd		0.8216						1.08		1324	1.07
2468-TCDF	NotFnd		0.8461						1.08		1324	1.07
1346/1246-TCDF	NotFnd		0.8607						1.08		1324	1.07
1347/1378/1247-TCDF	NotFnd		0.8672						1.08		1324	1.07
1348-TCDF	NotFnd		0.8792						1.08		1324	1.07
1248/1367/1379-TCDF	NotFnd		0.8846						1.08		1324	1.07
1268-TCDF	NotFnd		0.9011						1.08		1324	1.07
1467-TCDF	NotFnd		0.9067						1.08		1324	1.07
1478-TCDF	NotFnd		0.9137						1.08		1324	1.07
1369/1237-TCDF	NotFnd		0.9293						1.08		1324	1.07
2467-TCDF	NotFnd		0.9348						1.08		1324	1.07
2368-TCDF	NotFnd		0.9408						1.08		1324	1.07
1238/1234/1678/1469/1236-TCDF	NotFnd		0.9445						1.08		1324	1.07
1278-TCDF	NotFnd		0.9641						1.08		1324	1.07
1349-TCDF	NotFnd		0.9693						1.08		1324	1.07
1267-TCDF	NotFnd		0.9755						1.08		1324	1.07
2346/1249-TCDF	NotFnd		0.9834						1.08		1324	1.07
2347/1279-TCDF	NotFnd		0.9922						1.08		1324	1.07
2348-TCDF	NotFnd		0.9966						1.08		1324	1.07
2378-TCDF	NotFnd		1.0009						1.08		1324	1.07
2367/3467-TCDF	NotFnd		1.0164						1.08		1324	1.07
1269-TCDF	NotFnd		1.0260						1.08		1324	1.07
1239-TCDF	NotFnd		1.0375						1.08		1324	1.07
1289-TCDF	NotFnd		1.0834						1.08		1324	1.07
13468/12468-PeCDF	NotFnd		0.9057						1.02		1465	1.36
13678/13467/12467-PeCDF	NotFnd		0.9581						1.02		1141	1.06
12368/13478/12478-PeCDF	NotFnd		0.9620						1.02		1141	1.06
14678-PeCDF	NotFnd		0.9667						1.02		1141	1.06
13479-PeCDF	NotFnd		0.9702						1.02		1141	1.06
13469/12479-PeCDF	NotFnd		0.9781						1.02		1141	1.06
12346-PeCDF	NotFnd		0.9829						1.02		1141	1.06

Lab ID: MB1_7679_DF_SDS

Client ID: 0_7679_MB001

Datafile: 100409P1-03

Acq'd: 09 Apr 2010 09:07 MC

UTP: 09-Apr-2010 15:51 MC

Report: 09 Apr 2010 15:53 MC

Wt/Vol: 1

J-level: 10 pg

ES spike: 4000 pg

Cal: BCS3_7679_DF_PAB

Checkcode: 681-930






Name	Act RT	QC	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Conc.	Noise	DL
23468/12469-PeCDF	NotFnd		0.9858						1.02		1141	1.06
12347-PeCDF	NotFnd		0.9881						1.02		1141	1.06
12348-PeCDF	NotFnd		0.9936						1.02		1141	1.06
12378-PeCDF	NotFnd		1.0006						1.00		1141	1.09
12678/12367-PeCDF	NotFnd		1.0104						1.02		1141	1.06
12379-PeCDF	NotFnd		1.0151						1.02		1141	1.06
12679-PeCDF	NotFnd		0.9925						1.02		1141	1.06
23467/12369-PeCDF	NotFnd		0.9981						1.02		1141	1.06
23478-PeCDF	NotFnd		1.0005						1.04		1141	1.03
23478/12489-PeCDF	NotFnd		1.0006						1.04		1141	1.03
12489-PeCDF	NotFnd		1.0023						1.02		1141	1.06
12349-PeCDF	NotFnd		1.0110						1.02		1141	1.06
12389-PeCDF	NotFnd		1.0350						1.02		1141	1.06
123468-HxCDF	NotFnd		0.9609						1.13		1444	1.89
124678/134678-HxCDF	NotFnd		0.9668						1.13		1444	1.89
134679-HxCDF	NotFnd		0.9733						1.13		1444	1.89
124679-HxCDF	NotFnd		0.9788						1.13		1444	1.89
124689-HxCDF	NotFnd		0.9851						1.13		1444	1.89
123467-HxCDF	NotFnd		0.9968						1.13		1444	1.89
123478-HxCDF	NotFnd		1.0004						1.14		1444	1.78
123678-HxCDF	NotFnd		1.0005						1.13		1444	1.66
123479-HxCDF	NotFnd		1.0048						1.13		1444	1.89
123469-HxCDF	NotFnd		1.0090						1.13		1444	1.89
123679-HxCDF	NotFnd		0.9943						1.13		1444	1.89
234678-HxCDF	NotFnd		1.0005						1.14		1444	1.78
234678/123689-HxCDF	NotFnd		1.0004						1.14		1444	1.78
123689-HxCDF	NotFnd		1.0009						1.13		1444	1.89
123789-HxCDF	NotFnd		1.0005						1.12		1444	2.42
123789/123489-HxCDF	NotFnd		1.0012						1.12		1444	2.42
123489-HxCDF	NotFnd		1.0017						1.13		1444	1.89
1234678-HpCDF	NotFnd		1.0003						1.38		1248	1.69
1234679-HpCDF	NotFnd		1.0083						1.36		1248	2.07
1234689-HpCDF	NotFnd		1.0132						1.36		1248	2.07
1234789-HpCDF	NotFnd		1.0003						1.33		1248	2.53
OCDF	NotFnd		1.0004						0.96		1282	3.41
OCDF-a	NotFnd		1.0002						0.05		1627	76






1 - 127

AP Lab ID: MB1_7679_DF_SDS
Instr: AutoSpec-Ultima MM1

Sample ID: 0_7679_MB001
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 47

Acq: 9-APR-2010 09:07:26
User: MC Datafile: 100409P1-03










AP Lab ID: MB1_7679_DF_SDS
Instr: AutoSpec-Ultima MM1

Sample ID: 0_7679_MB001
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 47






Acq: 9-APR-2010 09:07:26
User: MC Datafile: 100409P1-03













AP Lab ID: MB1_7679_DF_SDS
Instr: AutoSpec-Ultima MM1

Sample ID: 0_7679_MB001
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 47

Acq: 9-APR-2010 09:07:26
User: MC Datafile: 100409P1-03












AP Lab ID: MB1_7679_DF_SDS
Instr: AutoSpec-Ultima MM1

Sample ID: 0_7679_MB001
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 47

Acq: 9-APR-2010 09:07:26
User: MC Datafile: 100409P1-03






1-134

AP Lab ID: MB1_7679_DF_SDS
Instr: AutoSpec-Ultima MM1

Sample ID: 0_7679_MB001
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 47






Acq: 9-APR-2010 09:07:26
User: MC Datafile: 100409P1-03



AP Lab ID: MB1_7679_DF_SDS
Instr: AutoSpec-Ultima MM1

Sample ID: 0_7679_MB001
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 47

Acq: 9-APR-2010 09:07:26
User: MC Datafile: 100409P1-03








Results: P:\P2000_P2099\IP2096\2096_7679_DfResources\MB1_7679_DF_SDS.utp_res, saved 09-Apr-2010 16:00 (MC)
AP UltraTrace-Pro V4.21 User/System: MC/MC17-047 cc: 0628, 9222, 2064 scc: 681-930






Peak annotation: Areas, Centroids
Revised: 09-Apr-2010 11:50:43 (MC) Printed: 09-Apr-2010 16:04:32 Page 9 of 12






AP Lab ID: MB1_7679_DF_SDS
Instr: AutoSpec-Ultima MM1

Sample ID: 0_7679_MB001
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 47

Acq: 9-APR-2010 09:07:26
User: MC Datafile: 100409P1-03







1 - 139

Lab ID: P2096_7679_001

Client ID: Field Blank

Datafile: 100409P1-04

Acq'd: 09 Apr 2010 09:57 MC

UTP: 09-Apr-2010 15:51 MC

Report: 09 Apr 2010 15:53 MC

Wt/Vol: 1

J-level: 10 pg

ES spike: 4000 pg

Cal: BCS3_7679_DF_PAB

Checkcode: 318-336

Split: 2

Name	Act RT	QC	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Conc.	Noise	DL
2378-TCDD	NotFnd		1.0008	-		-	-	-	0.99	-	1291	1.39
12378-PeCDD	NotFnd		1.0006	-		-	-	-	0.93	-	1425	1.82
123478-HxCDD	NotFnd		1.0004	-		-	-	-	1.04	-	1287	1.83
123678-HxCDD	NotFnd		1.0034	-		-	-	-	0.95	-	1287	1.93
123789-HxCDD	NotFnd		1.0116	-		-	-	-	0.93	-	1287	2.08
1234678-HpCDD	40.06		1.0003	1.0005	+0.5	2.75E+04	0.96	Y	0.96	4.71	1172	2.24
OCDD	43.55		1.0004	1.0002	-0.5	7.35E+04	0.94	Y	1.00	14.8	1553	3.97
2378-TCDF	NotFnd		1.0009	-		-	-	-	1.08	-	1306	0.973
12378-PeCDF	NotFnd		1.0006	-		-	-	-	1.00	-	1309	1.07
23478-PeCDF	NotFnd		1.0005	-		-	-	-	1.04	-	1309	1.02
123478-HxCDF	NotFnd		1.0004	-		-	-	-	1.14	-	1423	1.44
123678-HxCDF	NotFnd		1.0005	-		-	-	-	1.13	-	1423	1.36
234678-HxCDF	NotFnd		1.0005	-		-	-	-	1.14	-	1423	1.44
123789-HxCDF	NotFnd		1.0005	-		-	-	-	1.12	-	1423	1.93
1234678-HpCDF	38.91		1.0003	1.0004	+0.2	2.76E+04	1.08	Y	1.38	3.19	1252	1.42
1234789-HpCDF	NotFnd		1.0003	-		-	-	-	1.33	-	1252	2.05
OCDF	43.79		1.0004	1.0003	-0.3	3.72E+04	0.82	Y	0.96	6.16	1361	3.09

Name	Act RT	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Rec. %
ES 2378-TCDD	26.86	1.0259	1.0258	-0.2	3.92E+07	0.81	Y	1.01	86.3
ES 12378-PeCDD	32.47	1.2404	1.2402	-0.3	3.15E+07	1.61	Y	0.78	89.5
ES 123478-HxCDD	36.43	0.9917	0.9917	0	2.63E+07	1.27	Y	0.99	90.9
ES 123678-HxCDD	36.54	0.9947	0.9947	0	3.00E+07	1.27	Y	1.07	96.6
ES 123789-HxCDD	36.84	1.0028	1.0028	0	3.01E+07	1.28	Y	1.09	94.6
ES 1234678-HpCDD	40.03	1.0902	1.0897	-1.1	2.43E+07	1.03	Y	0.90	92.4
ES OCDD	43.54	1.1862	1.1852	-2.2	3.95E+07	0.89	Y	0.74	91.7
ES 2378-TCDF	25.93	1.0585	1.0585	0	5.65E+07	0.81	Y	1.00	88.6
ES 12378-PeCDF	30.97	1.2646	1.2643	-0.4	4.43E+07	1.56	Y	0.75	92.4
ES 23478-PeCDF	32.11	1.3113	1.3109	-0.6	4.45E+07	1.59	Y	0.74	93.6
ES 123478-HxCDF	35.46	0.9651	0.9652	+0.2	3.27E+07	0.51	Y	1.19	94.2
ES 123678-HxCDF	35.60	0.9689	0.9690	+0.2	3.64E+07	0.52	Y	1.35	92.7
ES 234678-HxCDF	36.25	0.9867	0.9868	+0.2	3.41E+07	0.52	Y	1.28	91.2
ES 123789-HxCDF	37.21	1.0129	1.0129	0	2.90E+07	0.52	Y	1.20	83.1
ES 1234678-HpCDF	38.89	1.0589	1.0586	-0.7	2.52E+07	0.45	Y	0.95	91.2
ES 1234789-HpCDF	40.60	1.1057	1.1051	-1.3	2.11E+07	0.42	Y	0.82	88.6
ES OCDF	43.78	1.1926	1.1915	-2.4	5.02E+07	0.91	Y	0.96	89.9

Lab ID: P2096_7679_001

Client ID: Field Blank

Datafile: 100409P1-04

Acq'd: 09 Apr 2010 09:57 MC

UTP: 09-Apr-2010 15:51 MC

Report: 09 Apr 2010 15:53 MC

Wt/Vol: 1

J-level: 10 pg

ES spike: 4000 pg

Cal: BCS3_7679_DF_PAB

Checkcode: 318-336

Split: 2

Name	Act RT	QC	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Rec. %
JS 1234-TCDD	26.19		-	-	-	4.50E+07	0.80	Y	-	-
JS 1234-TCDF	24.50		-	-	-	6.40E+07	0.79	Y	-	-
JS 123467-HxCDD	36.74		-	-	-	1.45E+07	1.27	Y	-	-
CS 37C1-2378-TCDD	26.88		1.0268	1.0267	-0.2	1.76E+07	n/a	-	1.16	84.6
CS 12347-PeCDD	31.96		1.2209	1.2206	-0.5	3.12E+07	1.59	Y	0.79	87.6
CS 12346-PeCDF	30.43		1.2424	1.2422	-0.3	4.24E+07	1.56	Y	0.79	84.1
CS 123469-HxCDF	35.91		0.9773	0.9774	+0.2	3.23E+07	0.50	Y	1.23	90.4
CS 1234689-HpCDF	39.37		1.0720	1.0717	-0.7	2.24E+07	0.44	Y	0.86	89.4
SS 37C1-2378-TCDD	26.88		1.0268	1.0267	-0.2	1.76E+07	n/a	-	1.14	98.1
SS 12347-PeCDD	31.96		1.2209	1.2206	-0.5	3.12E+07	1.59	Y	1.01	97.9
SS 12346-PeCDF	30.43		1.2424	1.2422	-0.3	4.24E+07	1.56	Y	1.05	90.9
SS 123469-HxCDF	35.91		0.9773	0.9774	+0.2	3.23E+07	0.50	Y	0.91	97.6
SS 1234689-HpCDF	39.37		1.0720	1.0717	-0.7	2.24E+07	0.44	Y	0.91	98
AS 1368-TCDD	22.91		0.8731	0.8750	+3.0	4.02E+07	0.80	Y	1.08	82.7
AS 1368-TCDF	20.76		0.8447	0.8475	+4.1	6.68E+07	0.79	Y	1.29	80.9
FS 1278-TCDD	NotFnd		1.0131							
FS 12478-PeCDD	NotFnd		0.9617							
FS 123468-HxCDD	NotFnd		0.9713							
FS 1234679-HpCDD	39.21		0.9794	0.9795	+0.2	1.85E+05	1.13	Y	0.01	98.8
TS 1378-TCDD	NotFnd		0.9345							

FS na
KAM 12 Apr 10

Totals	Conc	EMPC
Total TCDD	2.73	2.73
Total PeCDD	0	0
Total HxCDD	0	0
Total HpCDD	4.71	8.73
Total Tetra-Octa Dioxins	22.3	26.3
Total TCDF	0	0
Total PeCDF	0	0
Total HxCDF	0	2.28
Total HpCDF	3.19	3.19
Total Tetra-Octa Furans	9.35	11.6
Total Tetra-Octa Dioxins & Furans	31.6	37.9

Lab ID: P2096_7679_001

Client ID: Field Blank

Datafile: 100409P1-04

Acq'd: 09 Apr 2010 09:57 MC

UTP: 09-Apr-2010 15:51 MC

Report: 09 Apr 2010 15:53 MC

Wt/Vol: 1

J-level: 10 pg

ES spike: 4000 pg

Cal: BCS3_7679_DF_PAB

Checkcode: 318-336

Split: 2

Name	Act RT	QC	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Conc.	Noise	DL
1368-TCDD	22.95		0.8539	0.8544	+0.8	2.66E+04	0.81	Y	0.99	2.73	1291	1.39
1379-TCDD	Not Fnd		0.8685						0.99		1291	1.39
1369-TCDD	Not Fnd		0.8863						0.99		1291	1.39
1469-TCDD	Not Fnd		0.9189						0.99		1291	1.39
1247/1246/1248/1249-TCDD	Not Fnd		0.9276						0.99		1291	1.39
1378-TCDD	Not Fnd		0.9351						0.99		1291	1.39
1268-TCDD	Not Fnd		0.9430						0.99		1291	1.39
1478-TCDD	Not Fnd		0.9517						0.99		1291	1.39
1279-TCDD	Not Fnd		0.9598						0.99		1291	1.39
1234/1269-TCDD	Not Fnd		0.9740						0.99		1291	1.39
1236-TCDD	Not Fnd		0.9801						0.99		1291	1.39
1237/1238-TCDD	Not Fnd		0.9895						0.99		1291	1.39
1239-TCDD	Not Fnd		0.9952						0.99		1291	1.39
2378-TCDD	Not Fnd		1.0008						0.99		1291	1.39
1278-TCDD	Not Fnd		1.0138						0.99		1291	1.39
1267-TCDD	Not Fnd		1.0194						0.99		1291	1.39
1289-TCDD	Not Fnd		1.0396						0.99		1291	1.39
12479/12468-PeCDD	Not Fnd		0.9210						0.93		1425	1.82
12469-PeCDD	Not Fnd		0.9382						0.93		1425	1.82
12368-PeCDD	Not Fnd		0.9556						0.93		1425	1.82
12478-PeCDD	Not Fnd		0.9614						0.93		1425	1.82
12379-PeCDD	Not Fnd		0.9649						0.93		1425	1.82
12369/12467/12489-PeCDD	Not Fnd		0.9732						0.93		1425	1.82
12346/12347-PeCDD	Not Fnd		0.9850						0.93		1425	1.82
12378-PeCDD	Not Fnd		1.0006						0.93		1425	1.82
12367-PeCDD	Not Fnd		1.0037						0.93		1425	1.82
12389-PeCDD	Not Fnd		1.0146						0.93		1425	1.82
124679/124689-HxCDD	Not Fnd		0.9534						0.97		1287	1.94
123468-HxCDD	Not Fnd		0.9717						0.97		1287	1.94
123679/123689-HxCDD	Not Fnd		0.9793						0.97		1287	1.94
123469-HxCDD	Not Fnd		0.9833						0.97		1287	1.94
123478-HxCDD	Not Fnd		1.0004						1.04		1287	1.83
123678-HxCDD	Not Fnd		1.0034						0.95		1287	1.93
123467-HxCDD	Not Fnd		1.0088						0.97		1287	1.94
123789-HxCDD	Not Fnd		1.0116						0.93		1287	2.08

I-142

Lab ID: P2096_7679_001

Client ID: Field Blank

Datafile: 100409P1-04

Acq'd: 09 Apr 2010 09:57 MC

UTP: 09-Apr-2010 15:51 MC

Report: 09 Apr 2010 15:53 MC

Wt/Vol: 1

J-level: 10 pg

ES spike: 4000 pg

Cal: BCS3_7679_DF_PAB

Checkcode: 318-336

Name	Act RT	QC	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Conc.	Noise	DL	Split: 2
1234679-HpCDD	39.22		0.9794	0.9796	+0.5	2.36E+04	0.86	N	0.96	4.03	1172	2.24	
1234678-HpCDD	40.06		1.0003	1.0005	+0.5	2.75E+04	0.96	Y	0.96	4.71	1172	2.24	
OCDD	43.55		1.0004	1.0002	-0.5	7.35E+04	0.94	Y	1.00	14.8	1553	3.97	
OCDD-a	NotFnd		1.0003						0.06		1769	74.1	
1368-TCDF	NotFnd		0.8012						1.08		1306	0.973	
1468-TCDF	NotFnd		0.8216						1.08		1306	0.973	
2468-TCDF	NotFnd		0.8461						1.08		1306	0.973	
1346/1246-TCDF	NotFnd		0.8607						1.08		1306	0.973	
1347/1378/1247-TCDF	NotFnd		0.8672						1.08		1306	0.973	
1348-TCDF	NotFnd		0.8792						1.08		1306	0.973	
1248/1367/1379-TCDF	NotFnd		0.8846						1.08		1306	0.973	
1268-TCDF	NotFnd		0.9011						1.08		1306	0.973	
1467-TCDF	NotFnd		0.9067						1.08		1306	0.973	
1478-TCDF	NotFnd		0.9137						1.08		1306	0.973	
1369/1237-TCDF	NotFnd		0.9293						1.08		1306	0.973	
2467-TCDF	NotFnd		0.9348						1.08		1306	0.973	
2368-TCDF	NotFnd		0.9408						1.08		1306	0.973	
1238/1234/1678/1469/1236-TCDF	NotFnd		0.9445						1.08		1306	0.973	
1278-TCDF	NotFnd		0.9641						1.08		1306	0.973	
1349-TCDF	NotFnd		0.9693						1.08		1306	0.973	
1267-TCDF	NotFnd		0.9755						1.08		1306	0.973	
2346/1249-TCDF	NotFnd		0.9834						1.08		1306	0.973	
2347/1279-TCDF	NotFnd		0.9922						1.08		1306	0.973	
2348-TCDF	NotFnd		0.9966						1.08		1306	0.973	
2378-TCDF	NotFnd		1.0009						1.08		1306	0.973	
2367/3467-TCDF	NotFnd		1.0164						1.08		1306	0.973	
1269-TCDF	NotFnd		1.0260						1.08		1306	0.973	
1239-TCDF	NotFnd		1.0375						1.08		1306	0.973	
1289-TCDF	NotFnd		1.0834						1.08		1306	0.973	
13468/12468-PeCDF	NotFnd		0.9057						1.02		1349	1.07	
13678/13467/12467-PeCDF	NotFnd		0.9581						1.02		1309	1.04	
12368/13478/12478-PeCDF	NotFnd		0.9620						1.02		1309	1.04	
14678-PeCDF	NotFnd		0.9667						1.02		1309	1.04	
13479-PeCDF	NotFnd		0.9702						1.02		1309	1.04	
13469/12479-PeCDF	NotFnd		0.9781						1.02		1309	1.04	
12346-PeCDF	NotFnd		0.9829						1.02		1309	1.04	

Analytical Perspectives

RT/QC Sheet 4 of 5

Lab ID: P2096_7679_001

Client ID: Field Blank

Datafile: 100409P1-04

Acq'd: 09 Apr 2010 09:57 MC

UTP: 09-Apr-2010 15:51 MC

Report: 09 Apr 2010 15:53 MC

Wt/Vol: 1

J-level: 10 pg

ES spike: 4000 pg

Cal: BCS3_7679_DF_PAB

Checkcode: 318-336

Split: 2

Name	Act RT	QC	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Conc.	Noise	DL
23468/12469-PeCDF	NotFnd		0.9858						1.02		1309	1.04
12347-PeCDF	NotFnd		0.9881						1.02		1309	1.04
12348-PeCDF	NotFnd		0.9936						1.02		1309	1.04
12378-PeCDF	NotFnd		1.0006						1.00		1309	1.07
12678/12367-PeCDF	NotFnd		1.0104						1.02		1309	1.04
12379-PeCDF	NotFnd		1.0151						1.02		1309	1.04
12679-PeCDF	NotFnd		0.9925						1.02		1309	1.04
23467/12369-PeCDF	NotFnd		0.9981						1.02		1309	1.04
23478-PeCDF	NotFnd		1.0005						1.04		1309	1.02
23478/12489-PeCDF	NotFnd		1.0006						1.04		1309	1.02
12489-PeCDF	NotFnd		1.0023						1.02		1309	1.04
12349-PeCDF	NotFnd		1.0110						1.02		1309	1.04
12389-PeCDF	NotFnd		1.0350						1.02		1309	1.04
123468-HxCDF	NotFnd		0.9609						1.13		1423	1.52
124678/134678-HxCDF	34.28		0.9668	0.9668	0	2.13E+04	1.04	N	1.13	2.28	1423	1.52
134679-HxCDF	NotFnd		0.9733						1.13		1423	1.52
124679-HxCDF	NotFnd		0.9788						1.13		1423	1.52
124689-HxCDF	NotFnd		0.9851						1.13		1423	1.52
123467-HxCDF	NotFnd		0.9968						1.13		1423	1.52
123478-HxCDF	NotFnd		1.0004						1.14		1423	1.44
123678-HxCDF	NotFnd		1.0005						1.13		1423	1.36
123479-HxCDF	NotFnd		1.0048						1.13		1423	1.52
123469-HxCDF	NotFnd		1.0090						1.13		1423	1.52
123679-HxCDF	NotFnd		0.9943						1.13		1423	1.52
234678-HxCDF	NotFnd		1.0005						1.14		1423	1.44
234678/123689-HxCDF	NotFnd		1.0004						1.14		1423	1.44
123689-HxCDF	NotFnd		1.0009						1.13		1423	1.52
123789-HxCDF	NotFnd		1.0005						1.12		1423	1.93
123789/123489-HxCDF	NotFnd		1.0012						1.12		1423	1.93
123489-HxCDF	NotFnd		1.0017						1.13		1423	1.52
1234678-HpCDF	38.91		1.0003	1.0004	+0.2	2.76E+04	1.08	Y	1.38	3.19	1252	1.42
1234679-HpCDF	NotFnd		1.0083						1.36		1252	1.71
1234689-HpCDF	NotFnd		1.0132						1.36		1252	1.71
1234789-HpCDF	NotFnd		1.0003						1.33		1252	2.05
OCDF	43.79		1.0004	1.0003	-0.3	3.72E+04	0.82	Y	0.96	6.16	1361	3.09
OCDF-a	NotFnd		1.0002						0.05		1677	66.7






Analytical Perspectives






RT/QC Sheet 5 of 5

AP Lab ID: P2096_7679_001
Instr: AutoSpec-Ultima MM1

Sample ID: Field Blank
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 48

Acq: 9-APR-2010 09:57:56
User: MC Datafile: 100409P1-04















AP Lab ID: P2096_7679_001
Instr: AutoSpec-Ultima MM1

Sample ID: Field Blank
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 48

Acq: 9-APR-2010 09:57:56
User: MC Datafile: 100409P1-04



1-147













unintegrated peaks either na or do not meet
signal/noise ratio criteria KAM 12 Apr 10

AP Lab ID: P2096_7679_001
Instr: AutoSpec-Ultima MM1

Sample ID: Field Blank
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 48

Acq: 9-APR-2010 09:57:56
User: MC Datafile: 100409P1-04










AP Lab ID: P2096_7679_001
Instr: AutoSpec-Ultima MM1

Sample ID: Field Blank
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 48




Acq: 9-APR-2010 09:57:56
User: MC Datafile: 100409P1-04



AP Lab ID: P2096_7679_001
Instr: AutoSpec-Ultima MM1

Sample ID: Field Blank
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 48






Acq: 9-APR-2010 09:57:56
User: MC Datafile: 100409P1-04








AP Lab ID: P2096_7679_001
Instr: AutoSpec-Ultima MM1

Sample ID: Field Blank
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 48

Acq: 9-APR-2010 09:57:56
User: MC Datafile: 100409P1-04










I - 154

AP Lab ID: P2096_7679_001
Instr: AutoSpec-Ultima MM1

Sample ID: Field Blank
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 48

Acq: 9-APR-2010 09:57:56
User: MC Datafile: 100409P1-04








1-155

AP Lab ID: P2096_7679_001
Instr: AutoSpec-Ultima MM1

Sample ID: Field Blank
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 48

Acq: 9-APR-2010 09:57:56
User: MC Datafile: 100409P1-04



Lab ID: P2096_7679_002
 Client ID: Unit 1 FF Outlet Run 1
 Datafile: 100409P1-05

Acq'd: 09 Apr 2010 10:48 MC
 UTP: 12-Apr-2010 15:49 MC
 Report: 12 Apr 2010 15:50 MC

Wt/Vol: 1
 J-level: 10 pg
 ES spike: 4000 pg

Cal: BCS3_7679_DF_PAB
 Checkcode: 744-657
 Split: 2

Name	Act RT	QC	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Conc.	Noise	DL
2378-TCDD	26.89		1.0008	1.0009	+0.2	3.40E+04	0.98	N	0.99	3.64	1222	1.41
12378-PeCDD	32.49		1.0006	1.0003	-0.6	4.03E+04	1.63	Y	0.93	5.58	1470	1.81
123478-HxCDD	NotFnd		1.0004	-		-	-	-	1.04	-	1449	2.09
123678-HxCDD	36.56		1.0034	1.0034	0	4.13E+04	1.20	Y	0.95	6.15	1449	2.16
123789-HxCDD	NotFnd		1.0116	-		-	-	-	0.93	-	1449	2.31
1234678-HpCDD	40.05		1.0003	1.0003	0	2.52E+05	0.91	Y	0.96	44.1	1393	2.6
OCDD	43.56		1.0004	1.0004	0	3.71E+05	0.86	Y	1.00	76.7	1451	4.01
2378-TCDF	25.96		1.0009	1.0009	0	2.30E+05	0.81	Y	1.08	15.8	1468	1.15
12378-PeCDF	31.00		1.0006	1.0006	0	1.65E+05	1.59	Y	1.00	15.3	1695	1.47
23478-PeCDF	32.14		1.0005	1.0005	0	1.67E+05	1.40	Y	1.04	14.5	1695	1.33
123478-HxCDF	35.48		1.0004	1.0004	0	8.32E+04	1.22	Y	1.14	9.14	1538	1.59
123678-HxCDF	35.62		1.0005	1.0005	0	1.20E+05	1.10	Y	1.13	12	1538	1.46
234678-HxCDF	36.27		1.0005	1.0005	0	8.74E+04	1.07	Y	1.14	9.38	1538	1.59
123789-HxCDF	NotFnd		1.0005	-		-	-	-	1.12	-	1538	2.04
1234678-HpCDF	38.91		1.0003	1.0004	+0.2	1.68E+05	1.00	Y	1.38	20.1	1336	1.51
1234789-HpCDF	NotFnd		1.0003	-		-	-	-	1.33	-	1336	2.25
OCDF	43.80		1.0004	1.0006	+0.5	3.22E+04	0.67	N	0.96	5.38	1373	2.9

Name	Act RT	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Rec. %
ES 2378-TCDD	26.87	1.0259	1.0258	-0.2	3.76E+07	0.81	Y	1.01	83.1
ES 12378-PeCDD	32.48	1.2404	1.2401	-0.5	3.10E+07	1.58	Y	0.78	88.6
ES 123478-HxCDD	36.44	0.9917	0.9917	0	2.52E+07	1.31	Y	0.99	82.5
ES 123678-HxCDD	36.55	0.9947	0.9947	0	2.83E+07	1.23	Y	1.07	86.2
ES 123789-HxCDD	36.85	1.0028	1.0027	-0.2	2.79E+07	1.26	Y	1.09	82.9
ES 1234678-HpCDD	40.04	1.0902	1.0895	-1.5	2.37E+07	1.07	Y	0.90	85.3
ES OCDD	43.54	1.1862	1.1850	-2.6	3.86E+07	0.90	Y	0.74	84.7
ES 2378-TCDF	25.93	1.0585	1.0584	-0.1	5.39E+07	0.80	Y	1.00	84.6
ES 12378-PeCDF	30.98	1.2646	1.2646	0	4.28E+07	1.56	Y	0.75	89.3
ES 23478-PeCDF	32.12	1.3113	1.3109	-0.6	4.41E+07	1.58	Y	0.74	92.7
ES 123478-HxCDF	35.46	0.9651	0.9651	0	3.19E+07	0.52	Y	1.19	86.9
ES 123678-HxCDF	35.60	0.9689	0.9689	0	3.50E+07	0.52	Y	1.35	84.3
ES 234678-HxCDF	36.26	0.9867	0.9867	0	3.26E+07	0.51	Y	1.28	82.6
ES 123789-HxCDF	37.22	1.0129	1.0128	-0.2	2.89E+07	0.52	Y	1.20	78.4
ES 1234678-HpCDF	38.89	1.0589	1.0584	-1.1	2.42E+07	0.45	Y	0.95	82.9
ES 1234789-HpCDF	40.60	1.1057	1.1049	-1.8	2.07E+07	0.44	Y	0.82	82.6
ES OCDF	43.78	1.1926	1.1913	-2.9	4.97E+07	0.89	Y	0.96	84.2

Lab ID: P2096_7679_002
 Client ID: Unit 1 FF Outlet Run 1
 Datafile: 100409P1-05

Acq'd: 09 Apr 2010 10:48 MC
 UTP: 12-Apr-2010 15:49 MC
 Report: 12 Apr 2010 15:50 MC

Wt/Vol: 1
 J-level: 10 pg
 ES spike: 4000 pg

Cal: BCS3_7679_DF_PAB
 Checkcode: 744-657
 Split: 2

Name	Act RT	QC	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Rec. %
JS 1234-TCDD	26.19		-	-	-	4.48E+07	0.81	Y	-	-
JS 1234-TCDF	24.50		-	-	-	6.39E+07	0.80	Y	-	-
JS 123467-HxCDD	36.75		-	-	-	1.54E+07	1.25	Y	-	-
CS 37C1-2378-TCDD	26.89		1.0268	1.0267	-0.2	1.69E+07	n/a	-	1.16	81.5
CS 12347-PeCDD	31.97		1.2209	1.2207	-0.3	3.09E+07	1.62	Y	0.79	87.1
CS 12346-PeCDF	30.45		1.2424	1.2429	+0.7	4.40E+07	1.56	Y	0.79	87.3
CS 123469-HxCDF	35.91		0.9773	0.9773	0	3.20E+07	0.51	Y	1.23	84.8
CS 1234689-HpCDF	39.37		1.0720	1.0715	-1.1	2.26E+07	0.44	Y	0.86	85.1
SS 37C1-2378-TCDD	26.89		1.0268	1.0267	-0.2	1.69E+07	n/a	-	1.14	98.1
SS 12347-PeCDD	31.97		1.2209	1.2207	-0.3	3.09E+07	1.62	Y	1.01	98.3
SS 12346-PeCDF	30.45		1.2424	1.2429	+0.7	4.40E+07	1.56	Y	1.05	97.8
SS 123469-HxCDF	35.91		0.9773	0.9773	0	3.20E+07	0.51	Y	0.91	101
SS 1234689-HpCDF	39.37		1.0720	1.0715	-1.1	2.26E+07	0.44	Y	0.91	103
AS 1368-TCDD	22.92		0.8731	0.8752	+3.3	3.98E+07	0.80	Y	1.08	82.3
AS 1368-TCDF	20.82		0.8447	0.8497	+7.4	6.60E+07	0.78	Y	1.29	80
FS 1278-TCDD	NotFnd		1.0131							
FS 12478-PeCDD	NotFnd		0.9617							
FS 123468-HxCDD	NotFnd		0.9713							
FS 1234679-HpCDD	39.21		0.9794	0.9794	0	1.47E+05	1.10	Y	0.01	80.1
TS 1378-TCDD	NotFnd		0.9345							

FS na
 KAM 12 Apr 10

Totals	Conc	EMPC
Total TCDD	59.6	76.2
Total PeCDD	68.5	95.4
Total HxCDD	116	116
Total HpCDD	91.4	91.4
Total Tetra-Octa Dioxins	413	456
Total TCDF	496	525
Total PeCDF	251	251
Total HxCDF	79.4	83.6
Total HpCDF	22.8	25.9
Total Tetra-Octa Furans	849	891
Total Tetra-Octa Dioxins & Furans	1260	1350

Lab ID: P2096_7679_002
 Client ID: Unit 1 FF Outlet Run 1
 Datafile: 100409P1-05

Acq'd: 09 Apr 2010 10:48 MC
 UTP: 12-Apr-2010 15:49 MC
 Report: 12 Apr 2010 15:50 MC

Wt/Vol: 1
 J-level: 10 pg
 ES spike: 4000 pg

Cal: BCS3_7679_DF_PAB
 Checkcode: 744-657
 Split: 2

Name	Act RT	QC	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Conc.	Noise	DL
1368-TCDD	22.95		0.8539	0.8543	+0.6	2.32E+05	0.77	Y	0.99	24.9	1222	1.41
1379-TCDD	23.36		0.8685	0.8695	+1.6	8.62E+04	0.67	Y	0.99	9.24	1222	1.41
1369-TCDD	23.82		0.8863	0.8866	+0.5	2.61E+04	1.02	N	0.99	2.8	1222	1.41
1469-TCDD	NotFnd		0.9189						0.99		1222	1.41
1247/1246/1248/1249-TCDD	24.93		0.9276	0.9278	+0.3	6.82E+04	0.64	N	0.99	7.31	1222	1.41
1378-TCDD	25.13		0.9351	0.9354	+0.5	6.55E+04	0.83	Y	0.99	7.02	1222	1.41
1268-TCDD	25.36		0.9430	0.9438	+1.3	2.63E+04	1.21	N	0.99	2.82	1222	1.41
1478-TCDD	25.60		0.9517	0.9530	+2.1	1.85E+04	0.83	Y	0.99	1.99	1222	1.41
1279-TCDD	25.79		0.9598	0.9601	+0.5	3.05E+04	0.81	Y	0.99	3.27	1222	1.41
1234/1269-TCDD	26.18		0.9740	0.9744	+0.6	2.76E+04	0.78	Y	0.99	2.96	1222	1.41
1236-TCDD	NotFnd		0.9801						0.99		1222	1.41
1237/1238-TCDD	26.58		0.9895	0.9894	-0.2	5.29E+04	0.73	Y	0.99	5.67	1222	1.41
1239-TCDD	NotFnd		0.9952						0.99		1222	1.41
2378-TCDD	26.89		1.0008	1.0009	+0.2	3.40E+04	0.98	N	0.99	3.64	1222	1.41
1278-TCDD	27.23		1.0138	1.0135	-0.5	4.26E+04	0.73	Y	0.99	4.56	1222	1.41
1267-TCDD	NotFnd		1.0194						0.99		1222	1.41
1289-TCDD	NotFnd		1.0396						0.99		1222	1.41
12479/12468-PeCDD	29.94		0.9210	0.9218	+1.6	1.94E+05	1.79	N	0.93	26.9	1470	1.81
12469-PeCDD	30.47		0.9382	0.9383	+0.2	2.71E+04	1.40	Y	0.93	3.75	1470	1.81
12368-PeCDD	31.04		0.9556	0.9558	+0.4	1.53E+05	1.44	Y	0.93	21.2	1470	1.81
12478-PeCDD	31.24		0.9614	0.9619	+1.0	4.40E+04	1.52	Y	0.93	6.09	1470	1.81
12379-PeCDD	31.35		0.9649	0.9651	+0.4	7.79E+04	1.45	Y	0.93	10.8	1470	1.81
12369/12467/12489-PeCDD	31.61		0.9732	0.9731	-0.2	5.84E+04	1.42	Y	0.93	8.09	1470	1.81
12346/12347-PeCDD	32.00		0.9850	0.9851	+0.2	4.88E+04	1.46	Y	0.93	6.76	1470	1.81
12378-PeCDD	32.49		1.0006	1.0003	-0.6	4.03E+04	1.63	Y	0.93	5.58	1470	1.81
12367-PeCDD	32.60		1.0037	1.0036	-0.2	1.66E+04	1.34	Y	0.93	2.3	1470	1.81
12389-PeCDD	32.95		1.0146	1.0146	0	2.84E+04	1.41	Y	0.93	3.94	1470	1.81
124679/124689-HxCDD	34.75		0.9534	0.9536	+0.4	8.84E+04	1.21	Y	0.97	13.4	1449	2.18
123468-HxCDD	35.41		0.9717	0.9717	0	4.69E+05	1.28	Y	0.97	71	1449	2.18
123679/123689-HxCDD	35.70		0.9793	0.9796	+0.7	1.71E+05	1.09	Y	0.97	25.9	1449	2.18
123469-HxCDD	NotFnd		0.9833						0.97		1449	2.18
123478-HxCDD	NotFnd		1.0004						1.04		1449	2.09
123678-HxCDD	36.56		1.0034	1.0034	0	4.13E+04	1.20	Y	0.95	6.15	1449	2.16
123467-HxCDD	NotFnd		1.0088						0.97		1449	2.18
123789-HxCDD	NotFnd		1.0116						0.93		1449	2.31

1-159

Lab ID: P2096_7679_002
 Client ID: Unit 1 FF Outlet Run 1
 Datafile: 100409P1-05

Acq'd: 09 Apr 2010 10:48 MC
 UTP: 12-Apr-2010 15:49 MC
 Report: 12 Apr 2010 15:50 MC

Wt/Vol: 1
 J-level: 10 pg
 ES spike: 4000 pg

Cal: BCS3_7679_DF_PAB
 Checkcode: 744-657
 Split: 2

Name	Act RT	QC	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Conc.	Noise	DL
1234679-HpCDD	39.22		0.9794	0.9796	+0.5	2.71E+05	1.04	Y	0.96	47.3	1393	2.6
1234678-HpCDD	40.05		1.0003	1.0003	0	2.52E+05	0.91	Y	0.96	44.1	1393	2.6
OCDD	43.56		1.0004	1.0004	0	3.71E+05	0.86	Y	1.00	76.7	1451	4.01
OCDD-a	NotFnd		1.0003						0.06		1594	72.2
1368-TCDF	20.84		0.8012	0.8038	+4.0	7.77E+05	0.76	Y	1.08	53.4	1468	1.15
1468-TCDF	21.37		0.8216	0.8240	+3.7	2.98E+05	0.79	Y	1.08	20.5	1468	1.15
2468-TCDF	21.97		0.8461	0.8473	+1.9	1.64E+05	0.84	Y	1.08	11.3	1468	1.15
1346/1246-TCDF	22.39		0.8607	0.8633	+4.0	1.33E+05	1.34	N	1.08	9.13	1468	1.15
1347/1378/1247-TCDF	22.53		0.8672	0.8688	+2.5	1.32E+06	0.72	Y	1.08	90.5	1468	1.15
1348-TCDF	22.82		0.8792	0.8801	+1.4	2.04E+05	0.62	N	1.08	14	1468	1.15
1248/1367/1379-TCDF	22.96		0.8846	0.8852	+0.9	6.30E+05	0.75	Y	1.08	43.3	1468	1.15
1268-TCDF	23.39		0.9011	0.9017	+0.9	2.54E+05	0.81	Y	1.08	17.4	1468	1.15
1467-TCDF	23.53		0.9067	0.9074	+1.1	1.96E+05	0.82	Y	1.08	13.5	1468	1.15
1478-TCDF	23.71		0.9137	0.9143	+0.9	4.20E+05	0.78	Y	1.08	28.9	1468	1.15
1369/1237-TCDF	24.10		0.9293	0.9294	+0.2	2.66E+05	0.86	Y	1.08	18.3	1468	1.15
2467-TCDF	24.25		0.9348	0.9350	+0.3	2.74E+05	0.77	Y	1.08	18.8	1468	1.15
2368-TCDF	24.41		0.9408	0.9411	+0.5	3.34E+05	0.80	Y	1.08	23	1468	1.15
1238/1234/1678/1469/1236-TCDF	24.54		0.9445	0.9462	+2.6	5.77E+05	0.75	Y	1.08	39.7	1468	1.15
1278-TCDF	25.02		0.9641	0.9646	+0.8	4.07E+05	0.84	Y	1.08	28	1468	1.15
1349-TCDF	25.14		0.9693	0.9695	+0.3	4.78E+04	0.81	Y	1.08	3.29	1468	1.15
1267-TCDF	25.30		0.9755	0.9757	+0.3	1.54E+05	0.79	Y	1.08	10.6	1468	1.15
2346/1249-TCDF	25.51		0.9834	0.9837	+0.5	1.56E+05	0.74	Y	1.08	10.8	1468	1.15
2347/1279-TCDF	25.73		0.9922	0.9922	0	2.06E+05	0.75	Y	1.08	14.2	1468	1.15
2348-TCDF	25.85		0.9966	0.9966	0	9.07E+04	0.90	N	1.08	6.24	1468	1.15
2378-TCDF	25.96		1.0009	1.0009	0	2.30E+05	0.81	Y	1.08	15.8	1468	1.15
2367/3467-TCDF	26.35		1.0164	1.0161	-0.5	4.44E+05	0.78	Y	1.08	30.5	1468	1.15
1269-TCDF	26.61		1.0260	1.0261	+0.2	2.81E+04	0.67	Y	1.08	1.93	1468	1.15
1239-TCDF	26.89		1.0375	1.0371	-0.6	3.10E+04	0.85	Y	1.08	2.13	1468	1.15
1289-TCDF	NotFnd		1.0834						1.08		1468	1.15
13468/12468-PeCDF	28.11		0.9057	0.9072	+2.8	3.99E+05	1.67	Y	1.02	35.9	1406	1.16
13678/13467/12467-PeCDF	29.72		0.9581	0.9592	+2.0	4.89E+05	1.39	Y	1.02	44	1695	1.4
12368/13478/12478-PeCDF	29.87		0.9620	0.9641	+3.9	6.03E+05	1.45	Y	1.02	54.3	1695	1.4
14678-PeCDF	29.98		0.9667	0.9675	+1.5	1.32E+05	1.40	Y	1.02	11.8	1695	1.4
13479-PeCDF	30.07		0.9702	0.9703	+0.2	5.25E+04	1.33	Y	1.02	4.72	1695	1.4
13469/12479-PeCDF	30.31		0.9781	0.9783	+0.4	6.68E+04	1.34	Y	1.02	6.01	1695	1.4
12346-PeCDF	30.48		0.9829	0.9837	+1.5	6.26E+04	1.54	Y	1.02	5.63	1695	1.4

I - 160

Lab ID: P2096_7679_002

Acq'd: 09 Apr 2010 10:48 MC

Wt/Vol: 1

Cal: BCS3_7679_DF_PAB

Client ID: Unit 1 FF Outlet Run 1

UTP: 12-Apr-2010 15:49 MC

J-level: 10 pg

Checkcode: 744-657

Datafile: 100409P1-05

Report: 12 Apr 2010 15:50 MC

ES spike: 4000 pg

Split: 2






Name	Act RT	QC	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Conc.	Noise	DL
23468/12469-PeCDF	30.56		0.9858	0.9862	+0.7	1.47E+05	1.51	Y	1.02	13.2	1695	1.4
12347-PeCDF	30.64		0.9881	0.9888	+1.3	5.35E+04	1.69	Y	1.02	4.82	1695	1.4
12348-PeCDF	30.79		0.9936	0.9937	+0.2	6.06E+04	1.40	Y	1.02	5.46	1695	1.4
12378-PeCDF	31.00		1.0006	1.0006	0	1.65E+05	1.59	Y	1.00	15.3	1695	1.47
12678/12367-PeCDF	31.28		1.0104	1.0095	-1.7	2.13E+05	1.45	Y	1.02	19.2	1695	1.4
12379-PeCDF	NotFnd		1.0151						1.02		1695	1.4
12679-PeCDF	NotFnd		0.9925						1.02		1695	1.4
23467/12369-PeCDF	32.01		0.9981	0.9967	-2.7	1.77E+05	1.48	Y	1.02	16	1695	1.4
23478-PeCDF	32.14		1.0005	1.0005	0	1.67E+05	1.40	Y	1.04	14.5	1695	1.33
23478/12489-PeCDF	NotFnd		1.0006						1.04		1695	1.33
12489-PeCDF	NotFnd		1.0023						1.02		1695	1.4
12349-PeCDF	NotFnd		1.0110						1.02		1695	1.4
12389-PeCDF	NotFnd		1.0350						1.02		1695	1.4
123468-HxCDF	34.08		0.9609	0.9611	+0.4	6.38E+04	1.39	Y	1.13	7.01	1538	1.65
124678/134678-HxCDF	34.29		0.9668	0.9668	0	2.93E+05	1.19	Y	1.13	32.2	1538	1.65
134679-HxCDF	34.52		0.9733	0.9733	0	2.47E+04	0.97	N	1.13	2.72	1538	1.65
124679-HxCDF	34.72		0.9788	0.9789	+0.2	1.32E+04	0.75	N	1.13	1.45	1538	1.65
124689-HxCDF	NotFnd		0.9851						1.13		1538	1.65
123467-HxCDF	35.36		0.9968	0.9972	+0.9	8.76E+04	1.11	Y	1.13	9.62	1538	1.65
123478-HxCDF	35.48		1.0004	1.0004	0	8.32E+04	1.22	Y	1.14	9.14	1538	1.59
123678-HxCDF	35.62		1.0005	1.0005	0	1.20E+05	1.10	Y	1.13	12	1538	1.46
123479-HxCDF	NotFnd		1.0048						1.13		1538	1.65
123469-HxCDF	NotFnd		1.0090						1.13		1538	1.65
123679-HxCDF	NotFnd		0.9943						1.13		1538	1.65
234678-HxCDF	36.27		1.0005	1.0005	0	8.74E+04	1.07	Y	1.14	9.38	1538	1.59
234678/123689-HxCDF	NotFnd		1.0004						1.14		1538	1.59
123689-HxCDF	NotFnd		1.0009						1.13		1538	1.65
123789-HxCDF	NotFnd		1.0005						1.12		1538	2.04
123789/123489-HxCDF	NotFnd		1.0012						1.12		1538	2.04
123489-HxCDF	NotFnd		1.0017						1.13		1538	1.65
1234678-HpCDF	38.91		1.0003	1.0004	+0.2	1.68E+05	1.00	Y	1.38	20.1	1336	1.51
1234679-HpCDF	39.22		1.0083	1.0085	+0.5	2.07E+04	1.17	Y	1.36	2.72	1336	1.85
1234689-HpCDF	39.38		1.0132	1.0126	-1.4	2.31E+04	0.85	N	1.36	3.04	1336	1.85
1234789-HpCDF	NotFnd		1.0003						1.33		1336	2.25
OCDF	43.80		1.0004	1.0006	+0.5	3.22E+04	0.67	N	0.96	5.38	1373	2.9
OCDF-a	NotFnd		1.0002						0.05		1414	52.4

1-161

AP Lab ID: P2096_7679_002
Instr: AutoSpec-Ultima MM1

Sample ID: Unit 1 FF Outlet Run 1
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 49






Acq: 9-APR-2010 10:48:24
User: MC Datafile: 100409P1-05



AP Lab ID: P2096_7679_002
 Instr: AutoSpec-Ultima MM1

Sample ID: Unit 1 FF Outlet Run 1
 SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 49

Acq: 9-APR-2010 10:48:24
 User: MC Datafile: 100409P1-05








1 - 163

AP Lab ID: P2096_7679_002
Instr: AutoSpec-Ultima MM1

Sample ID: Unit 1 FF Outlet Run 1
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 49






Acq: 9-APR-2010 10:48:24
User: MC Datafile: 100409P1-05



AP Lab ID: P2096_7679_002
Instr: AutoSpec-Ultima MM1

Sample ID: Unit 1 FF Outlet Run 1
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 49




Acq: 9-APR-2010 10:48:24
User: MC Datafile: 100409P1-05



AP Lab ID: P2096_7679_002
Instr: AutoSpec-Ultima MM1



Sample ID: Unit 1 FF Outlet Run 1
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 49

Acq: 9-APR-2010 10:48:24
User: MC Datafile: 100409P1-05



ok KAM 12 Apr 10
$$C(1234678\text{HpCDD}) = \frac{(1.20e5 + 1.32e5) * 2000^2 \text{ pg}}{(1.23e7 + 1.15e7) * 0.96} = 44.1 \text{ pg}$$






MC 09-Apr-2010 16:01



AP Lab ID: P2096_7679_002
Instr: AutoSpec-Ultima MM1

Sample ID: Unit 1 FF Outlet Run 1
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 49






Acq: 9-APR-2010 10:48:24
User: MC Datafile: 100409P1-05



AP Lab ID: P2096_7679_002
Instr: AutoSpec-Ultima MM1

Sample ID: Unit 1 FF Outlet Run 1
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 49

Acq: 9-APR-2010 10:48:24
User: MC Datafile: 100409P1-05






Results: P:\P2000_P2099\P2096\P2096_7679_DF\Resources\P2096_7679_002.utp_res, saved 12-Apr-2010 15:49 (MC)
AP UltraTrace-Pro V4.21 User/System: MC/MC17-047 cc: 4661, 0868, 4749 scc: 744-657

Peak annotation: Areas, Centroids
Revised: 09-Apr-2010 11:53:47 (MC) Printed: 12-Apr-2010 15:52:39 Page 7 of 12

AP Lab ID: P2096_7679_002
Instr: AutoSpec-Ultima MM1

Sample ID: Unit 1 FF Outlet Run 1
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 49






Acq: 9-APR-2010 10:48:24
User: MC Datafile: 100409P1-05



AP Lab ID: P2096_7679_002
Instr: AutoSpec-Ultima MM1

Sample ID: Unit 1 FF Outlet Run 1
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 49






Acq: 9-APR-2010 10:48:24
User: MC Datafile: 100409P1-05



AP Lab ID: P2096_7679_002
Instr: AutoSpec-Ultima MM1

Sample ID: Unit 1 FF Outlet Run 1
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 49

Acq: 9-APR-2010 10:48:24
User: MC Datafile: 100409P1-05








1 - 171

AP Lab ID: P2096_7679_002
Instr: AutoSpec-Ultima MM1

Sample ID: Unit 1 FF Outlet Run 1
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 49

Acq: 9-APR-2010 10:48:24
User: MC Datafile: 100409P1-05








1 - 172

AP Lab ID: P2096_7679_002
Instr: AutoSpec-Ultima MM1

Sample ID: Unit 1 FF Outlet Run 1
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 49

Acq: 9-APR-2010 10:48:24
User: MC Datafile: 100409P1-05



Lab ID: P2096_7679_003

Acq'd: 09 Apr 2010 11:38 MC

Wt/Vol: 1

Cal: BCS3_7679_DF_PAB

Client ID: Unit 1 FF Outlet Run 2

UTP: 12-Apr-2010 15:49 MC

J-level: 10 pg

Checkcode: 544-695

Datafile: 100409P1-06

Report: 12 Apr 2010 15:50 MC

ES spike: 4000 pg

Split: 2

Name	Act RT	QC	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Conc.	Noise	DL
2378-TCDD	26.89		1.0008	1.0010	+0.3	1.42E+04	1.20	N	0.99	2.21	1222	2.07
12378-PeCDD	32.50		1.0006	1.0008	+0.4	2.02E+04	2.42	N	0.93	4.52	1515	3.2
123478-HxCDD	36.44		1.0004	1.0001	-0.7	2.42E+04	1.37	Y	1.04	5.7	1239	2.73
123678-HxCDD	36.56		1.0034	1.0034	0	5.54E+04	1.39	Y	0.95	13	1239	2.82
123789-HxCDD	36.86		1.0116	1.0117	+0.2	3.62E+04	1.08	Y	0.93	8.47	1239	3.01
1234678-HpCDD	40.04		1.0003	1.0003	0	2.47E+05	1.05	Y	0.96	67.6	1231	3.81
OCDD	43.55		1.0004	1.0003	-0.3	3.74E+05	0.93	Y	1.00	122	1274	5.54
2378-TCDF	25.96		1.0009	1.0013	+0.6	1.85E+05	0.74	Y	1.08	18.4	1390	1.52
12378-PeCDF	30.99		1.0006	1.0006	0	1.34E+05	1.35	Y	1.00	19.8	1550	2.11
23478-PeCDF	32.13		1.0005	1.0005	0	1.42E+05	1.66	Y	1.04	20.4	1550	2.11
123478-HxCDF	35.47		1.0004	1.0004	0	9.66E+04	1.32	Y	1.14	16.9	1428	2.22
123678-HxCDF	35.62		1.0005	1.0005	0	1.31E+05	1.16	Y	1.13	20.7	1428	2.2
234678-HxCDF	36.27		1.0005	1.0005	0	1.12E+05	1.29	Y	1.14	18	1428	2.27
123789-HxCDF	Not Fnd		1.0005	-	-	-	-	-	1.12	-	1428	3.04
1234678-HpCDF	38.90		1.0003	1.0004	+0.2	2.57E+05	1.00	Y	1.38	49.4	1086	2.05
1234789-HpCDF	40.61		1.0003	1.0003	0	2.19E+04	1.00	Y	1.33	4.95	1086	2.93
OCDF	43.79		1.0004	1.0005	+0.3	5.33E+04	1.06	N	0.96	14.5	1262	4.36

Name	Act RT	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Rec. %
ES 2378-TCDD	26.86	1.0259	1.0258	-0.2	2.58E+07	0.80	Y	1.01	86.3
ES 12378-PeCDD	32.47	1.2404	1.2400	-0.6	1.92E+07	1.58	Y	0.78	82.9
ES 123478-HxCDD	36.43	0.9917	0.9917	0	1.63E+07	1.27	Y	0.99	82.1
ES 123678-HxCDD	36.54	0.9947	0.9947	0	1.80E+07	1.27	Y	1.07	84.3
ES 123789-HxCDD	36.84	1.0028	1.0028	0	1.84E+07	1.27	Y	1.09	84.4
ES 1234678-HpCDD	40.03	1.0902	1.0897	-1.1	1.52E+07	1.05	Y	0.90	84.1
ES OCDD	43.54	1.1862	1.1851	-2.4	2.44E+07	0.88	Y	0.74	82.8
ES 2378-TCDF	25.93	1.0585	1.0584	-0.1	3.73E+07	0.78	Y	1.00	88.6
ES 12378-PeCDF	30.97	1.2646	1.2642	-0.6	2.70E+07	1.53	Y	0.75	85.4
ES 23478-PeCDF	32.11	1.3113	1.3107	-0.9	2.67E+07	1.54	Y	0.74	85.2
ES 123478-HxCDF	35.46	0.9651	0.9652	+0.2	2.00E+07	0.52	Y	1.19	84.3
ES 123678-HxCDF	35.60	0.9689	0.9690	+0.2	2.23E+07	0.52	Y	1.35	82.7
ES 234678-HxCDF	36.25	0.9867	0.9868	+0.2	2.17E+07	0.51	Y	1.28	84.9
ES 123789-HxCDF	37.21	1.0129	1.0129	0	1.86E+07	0.51	Y	1.20	77.9
ES 1234678-HpCDF	38.89	1.0589	1.0586	-0.7	1.51E+07	0.45	Y	0.95	79.7
ES 1234789-HpCDF	40.60	1.1057	1.1051	-1.3	1.33E+07	0.45	Y	0.82	81.6
ES OCDF	43.77	1.1926	1.1914	-2.6	3.06E+07	0.88	Y	0.96	80.2

Lab ID: P2096_7679_003
 Client ID: Unit 1 FF Outlet Run 2
 Datafile: 100409P1-06

Acq'd: 09 Apr 2010 11:38 MC
 UTP: 12-Apr-2010 15:49 MC
 Report: 12 Apr 2010 15:50 MC

Wt/Vol: 1
 J-level: 10 pg
 ES spike: 4000 pg

Cal: BCS3_7679_DF_PAB
 Checkcode: 544-695
 Split: 2

Name	Act RT	QC	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Rec. %
JS 1234-TCDD	26.19		-	-	-	2.96E+07	0.80	Y	-	-
JS 1234-TCDF	24.50		-	-	-	4.21E+07	0.80	Y	-	-
JS 123467-HxCDD	36.74		-	-	-	9.97E+06	1.23	Y	-	-
CS 37C1-2378-TCDD	26.89		1.0268	1.0267	-0.2	1.16E+07	n/a	-	1.16	84.9
CS 12347-PeCDD	31.96		1.2209	1.2206	-0.5	1.96E+07	1.60	Y	0.79	83.8
CS 12346-PeCDF	30.44		1.2424	1.2425	+0.1	2.84E+07	1.56	Y	0.79	85.4
CS 123469-HxCDF	35.91		0.9773	0.9774	+0.2	2.05E+07	0.52	Y	1.23	83.8
CS 1234689-HpCDF	39.37		1.0720	1.0716	-0.9	1.35E+07	0.45	Y	0.86	78.7
SS 37C1-2378-TCDD	26.89		1.0268	1.0267	-0.2	1.16E+07	n/a	-	1.14	98.4
SS 12347-PeCDD	31.96		1.2209	1.2206	-0.5	1.96E+07	1.60	Y	1.01	101
SS 12346-PeCDF	30.44		1.2424	1.2425	+0.1	2.84E+07	1.56	Y	1.05	100
SS 123469-HxCDF	35.91		0.9773	0.9774	+0.2	2.05E+07	0.52	Y	0.91	101
SS 1234689-HpCDF	39.37		1.0720	1.0716	-0.9	1.35E+07	0.45	Y	0.91	98.7
AS 1368-TCDD	22.92		0.8731	0.8752	+3.3	2.88E+07	0.79	Y	1.08	89.9
AS 1368-TCDF	20.80		0.8447	0.8491	+6.5	4.98E+07	0.79	Y	1.29	91.5
FS 1278-TCDD	NotFnd		1.0131							
FS 12478-PeCDD	NotFnd		0.9617							
FS 123468-HxCDD	NotFnd		0.9713							
FS 1234679-HpCDD	39.21		0.9794	0.9795	+0.2	1.12E+05	1.00	Y	0.01	95.4
TS 1378-TCDD	NotFnd		0.9345							

FS na
 KAM 12 Apr 10

Totals	Conc	EMPC
Total TCDD	81.8	106
Total PeCDD	53.4	109
Total HxCDD	180	194
Total HpCDD	132	132
Total Tetra-Octa Dioxins	569	663
Total TCDF	426	519
Total PeCDF	275	323
Total HxCDF	165	171
Total HpCDF	72.6	72.6
Total Tetra-Octa Furans	938	1100
Total Tetra-Octa Dioxins & Furans	1510	1760

Lab ID: P2096_7679_003

Client ID: Unit 1 FF Outlet Run 2

Datafile: 100409P1-06

Acq'd: 09 Apr 2010 11:38 MC

UTP: 12-Apr-2010 15:49 MC

Report: 12 Apr 2010 15:50 MC

Wt/Vol: 1

J-level: 10 pg

ES spike: 4000 pg

Cal: BCS3_7679_DF_PAB

Checkcode: 544-695

Split: 2

Name	Act RT	QC	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Conc.	Noise	DL
1368-TCDD	22.95		0.8539	0.8543	+0.6	2.52E+05	0.79	Y	0.99	39.3	1222	2.07
1379-TCDD	23.36		0.8685	0.8694	+1.5	1.00E+05	0.80	Y	0.99	15.6	1222	2.07
1369-TCDD	23.82		0.8863	0.8866	+0.5	2.50E+04	0.93	N	0.99	3.9	1222	2.07
1469-TCDD	NotFnd		0.9189						0.99		1222	2.07
1247/1246/1248/1249-TCDD	24.92		0.9276	0.9276	0	5.43E+04	0.87	Y	0.99	8.47	1222	2.07
1378-TCDD	25.11		0.9351	0.9347	-0.6	6.56E+04	0.77	Y	0.99	10.2	1222	2.07
1268-TCDD	25.32		0.9430	0.9427	-0.5	2.18E+04	1.20	N	0.99	3.4	1222	2.07
1478-TCDD	NotFnd		0.9517						0.99		1222	2.07
1279-TCDD	25.80		0.9598	0.9605	+1.1	2.76E+04	0.84	Y	0.99	4.31	1222	2.07
1234/1269-TCDD	26.19		0.9740	0.9750	+1.6	2.95E+04	0.63	N	0.99	4.6	1222	2.07
1236-TCDD	26.34		0.9801	0.9804	+0.5	1.53E+04	0.90	N	0.99	2.39	1222	2.07
1237/1238-TCDD	26.58		0.9895	0.9894	-0.2	4.41E+04	1.04	N	0.99	6.88	1222	2.07
1239-TCDD	26.73		0.9952	0.9952	0	6.95E+03	0.65	N	0.99	1.08	1222	2.07
2378-TCDD	26.89		1.0008	1.0010	+0.3	1.42E+04	1.20	N	0.99	2.21	1222	2.07
1278-TCDD	27.22		1.0138	1.0134	-0.6	2.51E+04	0.72	Y	0.99	3.92	1222	2.07
1267-TCDD	NotFnd		1.0194						0.99		1222	2.07
1289-TCDD	NotFnd		1.0396						0.99		1222	2.07
12479/12468-PeCDD	29.93		0.9210	0.9218	+1.6	1.68E+05	1.59	Y	0.93	37.5	1515	3.2
12469-PeCDD	NotFnd		0.9382						0.93		1515	3.2
12368-PeCDD	31.03		0.9556	0.9557	+0.2	1.33E+05	1.31	N	0.93	29.8	1515	3.2
12478-PeCDD	31.22		0.9614	0.9614	0	3.41E+04	1.47	Y	0.93	7.62	1515	3.2
12379-PeCDD	31.34		0.9649	0.9651	+0.4	6.48E+04	1.26	N	0.93	14.5	1515	3.2
12369/12467/12489-PeCDD	31.60		0.9732	0.9733	+0.2	3.05E+04	1.11	N	0.93	6.82	1515	3.2
12346/12347-PeCDD	31.99		0.9850	0.9851	+0.2	3.67E+04	1.73	Y	0.93	8.22	1515	3.2
12378-PeCDD	32.50		1.0006	1.0008	+0.4	2.02E+04	2.42	N	0.93	4.52	1515	3.2
12367-PeCDD	NotFnd		1.0037						0.93		1515	3.2
12389-PeCDD	NotFnd		1.0146						0.93		1515	3.2
124679/124689-HxCDD	34.74		0.9534	0.9536	+0.4	5.96E+04	1.49	N	0.97	14	1239	2.85
123468-HxCDD	35.40		0.9717	0.9717	0	4.66E+05	1.27	Y	0.97	109	1239	2.85
123679/123689-HxCDD	35.69		0.9793	0.9797	+0.9	1.58E+05	1.13	Y	0.97	37.1	1239	2.85
123469-HxCDD	NotFnd		0.9833						0.97		1239	2.85
123478-HxCDD	36.44		1.0004	1.0001	-0.7	2.42E+04	1.37	Y	1.04	5.7	1239	2.73
123678-HxCDD	36.56		1.0034	1.0034	0	5.54E+04	1.39	Y	0.95	13	1239	2.82
123467-HxCDD	36.76		1.0088	1.0091	+0.7	2.67E+04	1.16	Y	0.97	6.26	1239	2.85
123789-HxCDD	36.86		1.0116	1.0117	+0.2	3.62E+04	1.08	Y	0.93	8.47	1239	3.01

I-176

Lab ID: P2096_7679_003
 Client ID: Unit 1 FF Outlet Run 2
 Datafile: 100409P1-06

Acq'd: 09 Apr 2010 11:38 MC
 UTP: 12-Apr-2010 15:49 MC
 Report: 12 Apr 2010 15:50 .MC

Wt/Vol: 1
 J-level: 10 pg
 ES spike: 4000 pg

Cal: BCS3_7679_DF_PAB
 Checkcode: 544-695

Name	Act RT	QC	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Conc.	Noise	DL
1234679-HpCDD	39.21		0.9794	0.9796	+0.5	2.36E+05	1.06	Y	0.96	64.6	1231	3.81
1234678-HpCDD	40.04		1.0003	1.0003	0	2.47E+05	1.05	Y	0.96	67.6	1231	3.81
OCDD	43.55		1.0004	1.0003	-0.3	3.74E+05	0.93	Y	1.00	122	1274	5.54
OCDD-a	NotFnd		1.0003						0.06		1453	103
1368-TCDF	20.83		0.8012	0.8033	+3.3	5.69E+05	0.77	Y	1.08	56.6	1390	1.52
1468-TCDF	21.36		0.8216	0.8236	+3.1	1.82E+05	0.80	Y	1.08	18.1	1390	1.52
2468-TCDF	21.96		0.8461	0.8469	+1.2	8.76E+04	0.94	N	1.08	8.72	1390	1.52
1346/1246-TCDF	22.39		0.8607	0.8635	+4.4	1.25E+05	1.01	N	1.08	12.5	1390	1.52
1347/1378/1247-TCDF	22.53		0.8672	0.8688	+2.5	8.04E+05	0.75	Y	1.08	80	1390	1.52
1348-TCDF	22.82		0.8792	0.8801	+1.4	1.22E+05	1.02	N	1.08	12.1	1390	1.52
1248/1367/1379-TCDF	22.95		0.8846	0.8852	+0.9	3.78E+05	0.90	N	1.08	37.6	1390	1.52
1268-TCDF	23.38		0.9011	0.9018	+1.1	1.25E+05	1.10	N	1.08	12.4	1390	1.52
1467-TCDF	23.53		0.9067	0.9073	+0.9	6.68E+04	1.37	N	1.08	6.65	1390	1.52
1478-TCDF	23.71		0.9137	0.9143	+0.9	2.52E+05	0.81	Y	1.08	25.1	1390	1.52
1369/1237-TCDF	24.09		0.9293	0.9290	-0.5	1.90E+05	0.79	Y	1.08	18.9	1390	1.52
2467-TCDF	24.24		0.9348	0.9348	0	2.04E+05	0.84	Y	1.08	20.3	1390	1.52
2368-TCDF	24.41		0.9408	0.9412	+0.6	2.21E+05	0.80	Y	1.08	22	1390	1.52
1238/1234/1678/1469/1236-TCDF	24.54		0.9445	0.9464	+3.0	4.21E+05	0.84	Y	1.08	41.9	1390	1.52
1278-TCDF	25.01		0.9641	0.9646	+0.8	2.65E+05	0.81	Y	1.08	26.4	1390	1.52
1349-TCDF	25.13		0.9693	0.9692	-0.2	4.90E+04	0.75	Y	1.08	4.87	1390	1.52
1267-TCDF	25.29		0.9755	0.9754	-0.2	1.45E+05	0.87	Y	1.08	14.5	1390	1.52
2346/1249-TCDF	25.51		0.9834	0.9836	+0.3	1.43E+05	0.86	Y	1.08	14.2	1390	1.52
2347/1279-TCDF	25.73		0.9922	0.9921	-0.2	1.94E+05	0.81	Y	1.08	19.4	1390	1.52
2348-TCDF	25.84		0.9966	0.9967	+0.2	1.06E+05	0.81	Y	1.08	10.5	1390	1.52
2378-TCDF	25.96		1.0009	1.0013	+0.6	1.85E+05	0.74	Y	1.08	18.4	1390	1.52
2367/3467-TCDF	26.35		1.0164	1.0162	-0.3	2.94E+05	0.82	Y	1.08	29.2	1390	1.52
1269-TCDF	26.60		1.0260	1.0257	-0.5	3.30E+04	0.81	Y	1.08	3.28	1390	1.52
1239-TCDF	26.90		1.0375	1.0374	-0.2	2.02E+04	0.85	Y	1.08	2.02	1390	1.52
1289-TCDF	28.11		1.0834	1.0842	+1.2	3.42E+04	1.23	N	1.08	3.4	1390	1.52
13468/12468-PeCDF	28.10		0.9057	0.9072	+2.8	3.07E+05	1.51	Y	1.02	44.7	1568	2.13
13678/13467/12467-PeCDF	29.70		0.9581	0.9590	+1.7	3.71E+05	1.56	Y	1.02	54	1550	2.11
12368/13478/12478-PeCDF	29.85		0.9620	0.9639	+3.5	4.23E+05	1.57	Y	1.02	61.6	1550	2.11
14678-PeCDF	29.96		0.9667	0.9672	+0.9	1.08E+05	1.71	Y	1.02	15.8	1550	2.11
13479-PeCDF	30.05		0.9702	0.9701	-0.2	5.32E+04	1.41	Y	1.02	7.75	1550	2.11
13469/12479-PeCDF	30.30		0.9781	0.9784	+0.6	6.36E+04	1.20	N	1.02	9.25	1550	2.11
12346-PeCDF	30.46		0.9829	0.9835	+1.1	3.82E+04	1.93	N	1.02	5.56	1550	2.11

Lab ID: P2096_7679_003
 Client ID: Unit 1 FF Outlet Run 2
 Datafile: 100409P1-06

Acq'd: 09 Apr 2010 11:38 MC
 UTP: 12-Apr-2010 15:49 MC
 Report: 12 Apr 2010 15:50 MC

Wt/Vol: 1
 J-level: 10 pg
 ES spike: 4000 pg

Cal: BCS3_7679_DF_PAB
 Checkcode: 544-695
 Split: 2






Name	Act RT	QC	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Conc.	Noise	DL
23468/12469-PeCDF	30.54		0.9858	0.9859	+0.2	1.47E+05	1.44	Y	1.02	21.4	1550	2.11
12347-PeCDF	30.62		0.9881	0.9888	+1.3	5.73E+04	1.41	Y	1.02	8.34	1550	2.11
12348-PeCDF	30.78		0.9936	0.9939	+0.6	4.76E+04	1.83	N	1.02	6.92	1550	2.11
12378-PeCDF	30.99		1.0006	1.0006	0	1.34E+05	1.35	Y	1.00	19.8	1550	2.11
12678/12367-PeCDF	31.28		1.0104	1.0098	-1.1	1.45E+05	1.31	N	1.02	21.1	1550	2.11
12379-PeCDF	31.43		1.0151	1.0148	-0.6	3.25E+04	1.09	N	1.02	4.73	1550	2.11
12679-PeCDF	31.87		0.9925	0.9926	+0.2	1.72E+04	1.57	Y	1.02	2.5	1550	2.11
23467/12369-PeCDF	32.01		0.9981	0.9967	-2.7	1.30E+05	1.40	Y	1.02	18.9	1550	2.11
23478-PeCDF	32.13		1.0005	1.0005	0	1.42E+05	1.66	Y	1.04	20.4	1550	2.11
23478/12489-PeCDF	NotFnd		1.0006						1.04		1550	2.11
12489-PeCDF	NotFnd		1.0023						1.02		1550	2.11
12349-PeCDF	NotFnd		1.0110						1.02		1550	2.11
12389-PeCDF	NotFnd		1.0350						1.02		1550	2.11
123468-HxCDF	34.07		0.9609	0.9610	+0.2	1.00E+05	1.27	Y	1.13	17.1	1428	2.41
124678/134678-HxCDF	34.28		0.9668	0.9668	0	2.98E+05	1.21	Y	1.13	50.9	1428	2.41
134679-HxCDF	34.51		0.9733	0.9733	0	2.95E+04	1.26	Y	1.13	5.03	1428	2.41
124679-HxCDF	34.71		0.9788	0.9789	+0.2	3.90E+04	0.96	N	1.13	6.66	1428	2.41
124689-HxCDF	34.92		0.9851	0.9849	-0.4	2.63E+04	1.13	Y	1.13	4.49	1428	2.41
123467-HxCDF	35.36		0.9968	0.9971	+0.6	9.64E+04	1.13	Y	1.13	16.5	1428	2.41
123478-HxCDF	35.47		1.0004	1.0004	0	9.66E+04	1.32	Y	1.14	16.9	1428	2.22
123678-HxCDF	35.62		1.0005	1.0005	0	1.31E+05	1.16	Y	1.13	20.7	1428	2.2
123479-HxCDF	35.77		1.0048	1.0047	-0.2	2.68E+04	1.30	Y	1.13	4.58	1428	2.41
123469-HxCDF	35.93		1.0090	1.0093	+0.6	2.83E+04	1.29	Y	1.13	4.83	1428	2.41
123679-HxCDF	36.05		0.9943	0.9944	+0.2	3.29E+04	1.32	Y	1.13	5.61	1428	2.41
234678-HxCDF	36.27		1.0005	1.0005	0	1.12E+05	1.29	Y	1.14	18	1428	2.27
234678/123689-HxCDF	NotFnd		1.0004						1.14		1428	2.27
123689-HxCDF	NotFnd		1.0009						1.13		1428	2.41
123789-HxCDF	NotFnd		1.0005						1.12		1428	3.04
123789/123489-HxCDF	NotFnd		1.0012						1.12		1428	3.04
123489-HxCDF	NotFnd		1.0017						1.13		1428	2.41
1234678-HpCDF	38.90		1.0003	1.0004	+0.2	2.57E+05	1.00	Y	1.38	49.4	1086	2.05
1234679-HpCDF	39.22		1.0083	1.0085	+0.5	4.03E+04	0.91	Y	1.36	8.37	1086	2.46
1234689-HpCDF	39.39		1.0132	1.0128	-0.9	4.78E+04	0.93	Y	1.36	9.93	1086	2.46
1234789-HpCDF	40.61		1.0003	1.0003	0	2.19E+04	1.00	Y	1.33	4.95	1086	2.93
OCDF	43.79		1.0004	1.0005	+0.3	5.33E+04	1.06	N	0.96	14.5	1262	4.36
OCDF-a	NotFnd		1.0002						0.05		1466	88.8

1-178

AP Lab ID: P2096_7679_003
Instr: AutoSpec-Ultima MM1

Sample ID: Unit 1 FF Outlet Run 2
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 50

Acq: 9-APR-2010 11:38:53
User: MC Datafile: 100409P1-06








1-179

AP Lab ID: P2096_7679_003
Instr: AutoSpec-Ultima MM1

Sample ID: Unit 1 FF Outlet Run 2
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 50






Acq: 9-APR-2010 11:38:53
User: MC Datafile: 100409P1-06



AP Lab ID: P2096_7679_003
Instr: AutoSpec-Ultima MM1

Sample ID: Unit 1 FF Outlet Run 2
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 50






Acq: 9-APR-2010 11:38:53
User: MC Datafile: 100409P1-06



AP Lab ID: P2096_7679_003
Instr: AutoSpec-Ultima MM1

Sample ID: Unit 1 FF Outlet Run 2
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 50

Acq: 9-APR-2010 11:38:53
User: MC Datafile: 100409P1-06








1-182

AP Lab ID: P2096_7679_003
Instr: AutoSpec-Ultima MM1

Sample ID: Unit 1 FF Outlet Run 2
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 50

Acq: 9-APR-2010 11:38:53
User: MC Datafile: 100409P1-06








1-183

AP Lab ID: P2096_7679_003
Instr: AutoSpec-Ultima MM1

Sample ID: Unit 1 FF Outlet Run 2
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 50

Acq: 9-APR-2010 11:38:53
User: MC Datafile: 100409P1-06








I - 184

AP Lab ID: P2096_7679_003
Instr: AutoSpec-Ultima MM1

Sample ID: Unit 1 FF Outlet Run 2
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 50




Acq: 9-APR-2010 11:38:53
User: MC Datafile: 100409P1-06



AP Lab ID: P2096_7679_003
Instr: AutoSpec-Ultima MM1

Sample ID: Unit 1 FF Outlet Run 2
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 50

Acq: 9-APR-2010 11:38:53
User: MC Datafile: 100409P1-06








I - 186

AP Lab ID: P2096_7679_003
Instr: AutoSpec-Ultima MM1

Sample ID: Unit 1 FF Outlet Run 2
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 50

Acq: 9-APR-2010 11:38:53
User: MC Datafile: 100409P1-06








1 - 187

AP Lab ID: P2096_7679_003
Instr: AutoSpec-Ultima MM1

Sample ID: Unit 1 FF Outlet Run 2
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 50






Acq: 9-APR-2010 11:38:53
User: MC Datafile: 100409P1-06



AP Lab ID: P2096_7679_003
Instr: AutoSpec-Ultima MM1

Sample ID: Unit 1 FF Outlet Run 2
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 50

Acq: 9-APR-2010 11:38:53
User: MC Datafile: 100409P1-06








1 - 189

AP Lab ID: P2096_7679_003
Instr: AutoSpec-Ultima MM1

Sample ID: Unit 1 FF Outlet Run 2
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 50

Acq: 9-APR-2010 11:38:53
User: MC Datafile: 100409P1-06



Lab ID: P2096_7679_004
 Client ID: Unit 1 FF Outlet Run 3
 Datafile: 100409P1-07

Acq'd: 09 Apr 2010 12:29 MC
 UTP: 12-Apr-2010 17:24 GG
 Report: 12 Apr 2010 17:37 GG

Wt/Vol: 1
 J-level: 10 pg
 ES spike: 4000 pg

Cal: BCS3_7679_DF_PAB
 Checkcode: 487-158
 Split: 2

Name	Act RT	QC	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Conc.	Noise	DL
2378-TCDD	26.87		1.0008	1.0004	-0.6	2.28E+04	0.89	N	0.99	3.21	1361	2.04
12378-PeCDD	32.49		1.0006	1.0006	0	4.28E+04	1.49	Y	0.93	8.62	1294	2.32
123478-HxCDD	36.45		1.0004	1.0005	+0.2	2.71E+04	1.22	Y	1.04	5.91	1173	2.41
123678-HxCDD	36.56		1.0034	1.0034	0	5.28E+04	1.13	Y	0.95	11	1173	2.29
123789-HxCDD	36.86		1.0116	1.0116	0	4.63E+04	1.18	Y	0.93	9.54	1173	2.56
1234678-HpCDD	40.05		1.0003	1.0004	+0.2	2.80E+05	1.09	Y	0.96	70	1431	3.98
OCDD	43.55		1.0004	1.0004	0	4.30E+05	1.00	Y	1.00	127	1373	4.87
2378-TCDF	25.95		1.0009	1.0007	-0.3	2.27E+05	0.75	Y	1.08	20.5	1400	1.45
12378-PeCDF	30.99		1.0006	1.0005	-0.2	1.31E+05	1.32	Y	1.00	17	1349	1.53
23478-PeCDF	32.14		1.0005	1.0007	+0.4	1.58E+05	1.69	Y	1.04	20.3	1349	1.54
123478-HxCDF	35.48		1.0004	1.0005	+0.2	1.20E+05	1.10	Y	1.14	19.4	1378	1.95
123678-HxCDF	35.62		1.0005	1.0006	+0.2	1.34E+05	1.17	Y	1.13	19.3	1378	1.86
234678-HxCDF	36.26		1.0005	1.0003	-0.4	1.17E+05	1.38	Y	1.14	17.2	1378	1.89
123789-HxCDF	Not Fnd		1.0005	-	-	-	-	-	1.12	-	1378	2.53
1234678-HpCDF	38.90		1.0003	1.0003	0	2.91E+05	1.07	Y	1.38	50.6	1405	2.14
1234789-HpCDF	40.60		1.0003	1.0001	-0.5	2.99E+04	1.11	Y	1.33	6.18	1405	3.29
OCDF	43.77		1.0004	1.0002	-0.5	9.85E+04	0.91	Y	0.96	24.2	1348	4.27

Name	Act RT	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Rec. %
ES 2378-TCDD	26.86	1.0259	1.0259	0	2.86E+07	0.79	Y	1.01	85.6
ES 12378-PeCDD	32.48	1.2404	1.2403	-0.2	2.13E+07	1.58	Y	0.78	82.5
ES 123478-HxCDD	36.43	0.9917	0.9917	0	1.76E+07	1.25	Y	0.99	80
ES 123678-HxCDD	36.54	0.9947	0.9947	0	2.03E+07	1.26	Y	1.07	85.5
ES 123789-HxCDD	36.84	1.0028	1.0028	0	2.09E+07	1.24	Y	1.09	86
ES 1234678-HpCDD	40.03	1.0902	1.0896	-1.3	1.66E+07	1.08	Y	0.90	82.8
ES OCDD	43.54	1.1862	1.1850	-2.6	2.69E+07	0.90	Y	0.74	81.9
ES 2378-TCDF	25.93	1.0585	1.0586	+0.1	4.11E+07	0.80	Y	1.00	87.7
ES 12378-PeCDF	30.98	1.2646	1.2648	+0.3	3.07E+07	1.58	Y	0.75	87.3
ES 23478-PeCDF	32.12	1.3113	1.3112	-0.1	2.98E+07	1.57	Y	0.74	85.3
ES 123478-HxCDF	35.46	0.9651	0.9652	+0.2	2.16E+07	0.52	Y	1.19	81.6
ES 123678-HxCDF	35.60	0.9689	0.9690	+0.2	2.45E+07	0.52	Y	1.35	81.9
ES 234678-HxCDF	36.25	0.9867	0.9868	+0.2	2.38E+07	0.52	Y	1.28	83.6
ES 123789-HxCDF	37.21	1.0129	1.0129	0	2.06E+07	0.52	Y	1.20	77.3
ES 1234678-HpCDF	38.89	1.0589	1.0585	-0.9	1.67E+07	0.43	Y	0.95	79.1
ES 1234789-HpCDF	40.60	1.1057	1.1050	-1.5	1.45E+07	0.45	Y	0.82	80
ES OCDF	43.77	1.1926	1.1913	-2.9	3.38E+07	0.89	Y	0.96	79.4

Lab ID: P2096_7679_004
 Client ID: Unit 1 FF Outlet Run 3
 Datafile: 100409P1-07

Acq'd: 09 Apr 2010 12:29 MC
 UTP: 12-Apr-2010 17:24 GG
 Report: 12 Apr 2010 17:37 GG

Wt/Vol: 1
 J-level: 10 pg
 ES spike: 4000 pg

Cal: BCS3_7679_DF_PAB
 Checkcode: 487-158
 Split: 2

Name	Act RT	QC	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Rec. %
JS 1234-TCDD	26.18		-	-	-	3.31E+07	0.79	Y	-	-
JS 1234-TCDF	24.49		-	-	-	4.70E+07	0.79	Y	-	-
JS 123467-HxCDD	36.74		-	-	-	1.11E+07	1.27	Y	-	-
CS 37C1-2378-TCDD	26.89		1.0268	1.0268	0	1.26E+07	n/a	-	1.16	82.2
CS 12347-PeCDD	31.97		1.2209	1.2208	-0.2	2.14E+07	1.63	Y	0.79	81.7
CS 12346-PeCDF	30.45		1.2424	1.2430	+0.9	3.01E+07	1.55	Y	0.79	81.2
CS 123469-HxCDF	35.91		0.9773	0.9774	+0.2	2.23E+07	0.53	Y	1.23	82
CS 1234689-HpCDF	39.37		1.0720	1.0716	-0.9	1.55E+07	0.44	Y	0.86	81.1
SS 37C1-2378-TCDD	26.89		1.0268	1.0268	0	1.26E+07	n/a	-	1.14	96.1
SS 12347-PeCDD	31.97		1.2209	1.2208	-0.2	2.14E+07	1.63	Y	1.01	99.1
SS 12346-PeCDF	30.45		1.2424	1.2430	+0.9	3.01E+07	1.55	Y	1.05	93
SS 123469-HxCDF	35.91		0.9773	0.9774	+0.2	2.23E+07	0.53	Y	0.91	100
SS 1234689-HpCDF	39.37		1.0720	1.0716	-0.9	1.55E+07	0.44	Y	0.91	102
AS 1368-TCDD	22.91		0.8731	0.8750	+3.0	3.17E+07	0.80	Y	1.08	88.7
AS 1368-TCDF	20.80		0.8447	0.8491	+6.5	5.41E+07	0.79	Y	1.29	89.2
FS 1278-TCDD	NotFnd		1.0131							
FS 12478-PeCDD	NotFnd		0.9617							
FS 123468-HxCDD	NotFnd		0.9713							
FS 1234679-HpCDD	39.21		0.9794	0.9794	0	1.07E+05	1.37	N	0.01	83.5
TS 1378-TCDD	NotFnd		0.9345							

FS na
 KAM 12 Apr 10

Totals	Conc	EMPC
Total TCDD	71.7	100
Total PeCDD	103	125
Total HxCDD	154	191
Total HpCDD	142	142
Total Tetra-Octa Dioxins	597	686
Total TCDF	567	577
Total PeCDF	275	316
Total HxCDF	142	171
Total HpCDF	67.9	77.9
Total Tetra-Octa Furans	1080	1170
Total Tetra-Octa Dioxins & Furans	1670	1850

Lab ID: P2096_7679_004

Client ID: Unit 1 FF Outlet Run 3

Datafile: 100409P1-07

Acq'd: 09 Apr 2010 12:29 MC

UTP: 12-Apr-2010 17:24 GG

Report: 12 Apr 2010 17:37 GG

Wt/Vol: 1

J-level: 10 pg

ES spike: 4000 pg

Cal: BCS3_7679_DF_PAB

Checkcode: 487-158

Split: 2

Name	Act RT	QC	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Conc.	Noise	DL
1368-TCDD	22.94		0.8539	0.8540	+0.2	2.77E+05	0.77	Y	0.99	39	1361	2.04
1379-TCDD	23.35		0.8685	0.8691	+1.0	9.21E+04	0.82	Y	0.99	13	1361	2.04
1369-TCDD	23.81		0.8863	0.8865	+0.3	3.55E+04	1.08	N	0.99	5.01	1361	2.04
1469-TCDD	NotFnd		0.9189						0.99		1361	2.04
1247/1246/1248/1249-TCDD	24.92		0.9276	0.9277	+0.2	5.84E+04	0.82	Y	0.99	8.24	1361	2.04
1378-TCDD	25.11		0.9351	0.9349	-0.3	5.54E+04	1.05	N	0.99	7.82	1361	2.04
1268-TCDD	25.33		0.9430	0.9431	+0.2	2.70E+04	1.01	N	0.99	3.8	1361	2.04
1478-TCDD	25.60		0.9517	0.9530	+2.1	1.77E+04	0.77	Y	0.99	2.49	1361	2.04
1279-TCDD	25.79		0.9598	0.9600	+0.3	2.37E+04	0.98	N	0.99	3.34	1361	2.04
1234/1269-TCDD	26.17		0.9740	0.9744	+0.6	2.54E+04	1.00	N	0.99	3.58	1361	2.04
1236-TCDD	NotFnd		0.9801						0.99		1361	2.04
1237/1238-TCDD	26.58		0.9895	0.9896	+0.2	4.24E+04	0.80	Y	0.99	5.98	1361	2.04
1239-TCDD	26.73		0.9952	0.9952	0	1.28E+04	0.93	N	0.99	1.8	1361	2.04
2378-TCDD	26.87		1.0008	1.0004	-0.6	2.28E+04	0.89	N	0.99	3.21	1361	2.04
1278-TCDD	27.23		1.0138	1.0135	-0.5	2.10E+04	0.73	Y	0.99	2.96	1361	2.04
1267-TCDD	NotFnd		1.0194						0.99		1361	2.04
1289-TCDD	NotFnd		1.0396						0.99		1361	2.04
12479/12468-PeCDD	29.93		0.9210	0.9217	+1.4	2.00E+05	1.50	Y	0.93	40.3	1294	2.32
12469-PeCDD	30.47		0.9382	0.9381	-0.2	1.88E+04	1.74	Y	0.93	3.78	1294	2.32
12368-PeCDD	31.04		0.9556	0.9558	+0.4	1.48E+05	1.61	Y	0.93	29.9	1294	2.32
12478-PeCDD	31.23		0.9614	0.9616	+0.4	3.32E+04	1.87	N	0.93	6.68	1294	2.32
12379-PeCDD	31.34		0.9649	0.9650	+0.2	7.87E+04	1.27	N	0.93	15.9	1294	2.32
12369/12467/12489-PeCDD	31.61		0.9732	0.9733	+0.2	5.06E+04	1.42	Y	0.93	10.2	1294	2.32
12346/12347-PeCDD	31.98		0.9850	0.9849	-0.2	4.95E+04	1.41	Y	0.93	9.96	1294	2.32
12378-PeCDD	32.49		1.0006	1.0006	0	4.28E+04	1.49	Y	0.93	8.62	1294	2.32
12367-PeCDD	NotFnd		1.0037						0.93		1294	2.32
12389-PeCDD	NotFnd		1.0146						0.93		1294	2.32
124679/124689-HxCDD	34.74		0.9534	0.9536	+0.4	6.88E+04	1.20	Y	0.97	14.4	1173	2.41
123468-HxCDD	35.41		0.9717	0.9718	+0.2	5.03E+05	1.23	Y	0.97	105	1173	2.41
123679/123689-HxCDD	35.69		0.9793	0.9796	+0.7	1.62E+05	1.03	N	0.97	34.1	1173	2.41
123469-HxCDD	35.82		0.9833	0.9831	-0.4	1.67E+04	0.97	N	0.97	3.5	1173	2.41
123478-HxCDD	36.45		1.0004	1.0005	+0.2	2.71E+04	1.22	Y	1.04	5.91	1173	2.41
123678-HxCDD	36.56		1.0034	1.0034	0	5.28E+04	1.13	Y	0.95	11	1173	2.29
123467-HxCDD	36.76		1.0088	1.0088	0	3.42E+04	1.21	Y	0.97	7.18	1173	2.41
123789-HxCDD	36.86		1.0116	1.0116	0	4.63E+04	1.18	Y	0.93	9.54	1173	2.56

1 - 193

Lab ID: P2096_7679_004

Client ID: Unit 1 FF Outlet Run 3

Datafile: 100409P1-07

Acq'd: 09 Apr 2010 12:29 MC

UTP: 12-Apr-2010 17:24 GG

Report: 12 Apr 2010 17:37 GG

Wt/Vol: 1

J-level: 10 pg

ES spike: 4000 pg

Cal: BCS3_7679_DF_PAB

Checkcode: 487-158

Split: 2

Name	Act RT	QC	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Conc.	Noise	DL
1234679-HpCDD	39.21		0.9794	0.9795	+0.2	2.87E+05	1.08	Y	0.96	71.6	1431	3.98
1234678-HpCDD	40.05		1.0003	1.0004	+0.2	2.80E+05	1.09	Y	0.96	70	1431	3.98
OCDD	43.55		1.0004	1.0004	0	4.30E+05	1.00	Y	1.00	127	1373	4.87
OCDD-a	NotFnd		1.0003						0.06		1650	95.9
1368-TCDF	20.82		0.8012	0.8031	+3.0	6.12E+05	0.73	Y	1.08	55.2	1400	1.45
1468-TCDF	21.35		0.8216	0.8234	+2.8	2.36E+05	0.80	Y	1.08	21.3	1400	1.45
2468-TCDF	21.95		0.8461	0.8467	+0.9	1.08E+05	0.78	Y	1.08	9.75	1400	1.45
1346/1246-TCDF	22.36		0.8607	0.8625	+2.8	1.75E+05	0.77	Y	1.08	15.8	1400	1.45
1347/1378/1247-TCDF	22.52		0.8672	0.8685	+2.0	9.77E+05	0.77	Y	1.08	88.1	1400	1.45
1348-TCDF	22.80		0.8792	0.8795	+0.5	2.07E+05	0.82	Y	1.08	18.7	1400	1.45
1248/1367/1379-TCDF	22.95		0.8846	0.8850	+0.6	5.22E+05	0.79	Y	1.08	47.1	1400	1.45
1268-TCDF	23.36		0.9011	0.9010	-0.2	2.12E+05	0.83	Y	1.08	19.1	1400	1.45
1467-TCDF	23.52		0.9067	0.9070	+0.5	1.67E+05	0.74	Y	1.08	15	1400	1.45
1478-TCDF	23.70		0.9137	0.9141	+0.6	3.21E+05	0.77	Y	1.08	29	1400	1.45
1369/1237-TCDF	24.10		0.9293	0.9295	+0.3	2.34E+05	0.78	Y	1.08	21.1	1400	1.45
2467-TCDF	24.25		0.9348	0.9351	+0.5	2.00E+05	0.85	Y	1.08	18	1400	1.45
2368-TCDF	24.39		0.9408	0.9408	0	2.47E+05	0.81	Y	1.08	22.2	1400	1.45
1238/1234/1678/1469/1236-TCDF	24.53		0.9445	0.9460	+2.3	5.03E+05	0.78	Y	1.08	45.4	1400	1.45
1278-TCDF	25.00		0.9641	0.9642	+0.2	3.26E+05	0.78	Y	1.08	29.4	1400	1.45
1349-TCDF	25.12		0.9693	0.9688	-0.8	5.84E+04	0.89	N	1.08	5.27	1400	1.45
1267-TCDF	25.30		0.9755	0.9758	+0.5	1.37E+05	0.67	Y	1.08	12.3	1400	1.45
2346/1249-TCDF	25.51		0.9834	0.9840	+0.9	1.50E+05	0.88	Y	1.08	13.6	1400	1.45
2347/1279-TCDF	25.72		0.9922	0.9918	-0.6	1.85E+05	0.79	Y	1.08	16.7	1400	1.45
2348-TCDF	25.83		0.9966	0.9961	-0.8	1.27E+05	0.71	Y	1.08	11.5	1400	1.45
2378-TCDF	25.95		1.0009	1.0007	-0.3	2.27E+05	0.75	Y	1.08	20.5	1400	1.45
2367/3467-TCDF	26.35		1.0164	1.0162	-0.3	3.49E+05	0.76	Y	1.08	31.4	1400	1.45
1269-TCDF	26.61		1.0260	1.0262	+0.3	2.68E+04	0.80	Y	1.08	2.42	1400	1.45
1239-TCDF	26.88		1.0375	1.0368	-1.1	3.33E+04	0.70	Y	1.08	3.01	1400	1.45
1289-TCDF	28.11		1.0834	1.0843	+1.4	5.58E+04	1.32	N	1.08	5.04	1400	1.45
13468/12468-PeCDF	28.10		0.9057	0.9070	+2.4	3.74E+05	1.49	Y	1.02	48.3	1261	1.43
13678/13467/12467-PeCDF	29.71		0.9581	0.9590	+1.7	3.93E+05	1.55	Y	1.02	50.8	1349	1.53
12368/13478/12478-PeCDF	29.86		0.9620	0.9640	+3.7	5.16E+05	1.60	Y	1.02	66.6	1349	1.53
14678-PeCDF	29.97		0.9667	0.9673	+1.1	1.08E+05	1.19	N	1.02	13.9	1349	1.53
13479-PeCDF	30.05		0.9702	0.9701	-0.2	6.11E+04	1.43	Y	1.02	7.89	1349	1.53
13469/12479-PeCDF	30.31		0.9781	0.9784	+0.6	5.89E+04	1.28	N	1.02	7.61	1349	1.53
12346-PeCDF	30.47		0.9829	0.9835	+1.1	3.31E+04	1.19	N	1.02	4.28	1349	1.53

Lab ID: P2096_7679_004

Acq'd: 09 Apr 2010 12:29 MC

Wt/Vol: 1

Cal: BCS3_7679_DF_PAB

Client ID: Unit 1 FF Outlet Run 3

UTP: 12-Apr-2010 17:24 GG

J-level: 10 pg

Checkcode: 487-158

Datafile: 100409P1-07

Report: 12 Apr 2010 17:37 GG

ES spike: 4000 pg

Split: 2






Name	Act RT	QC	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Conc.	Noise	DL
23468/12469-PeCDF	30.54		0.9858	0.9858	0	1.44E+05	1.64	Y	1.02	18.6	1349	1.53
12347-PeCDF	30.61		0.9881	0.9882	+0.2	7.19E+04	1.31	N	1.02	9.28	1349	1.53
12348-PeCDF	30.79		0.9936	0.9938	+0.4	4.79E+04	1.29	N	1.02	6.18	1349	1.53
12378-PeCDF	30.99		1.0006	1.0005	-0.2	1.31E+05	1.32	Y	1.00	17	1349	1.53
12678/12367-PeCDF	31.28		1.0104	1.0097	-1.3	2.01E+05	1.39	Y	1.02	25.9	1349	1.53
12379-PeCDF	NotFnd		1.0151						1.02		1349	1.53
12679-PeCDF	NotFnd		0.9925						1.02		1349	1.53
23467/12369-PeCDF	32.01		0.9981	0.9968	-2.5	1.52E+05	1.46	Y	1.02	19.7	1349	1.53
23478-PeCDF	32.14		1.0005	1.0007	+0.4	1.58E+05	1.69	Y	1.04	20.3	1349	1.54
23478/12489-PeCDF	NotFnd		1.0006						1.04		1349	1.54
12489-PeCDF	NotFnd		1.0023						1.02		1349	1.53
12349-PeCDF	NotFnd		1.0110						1.02		1349	1.53
12389-PeCDF	NotFnd		1.0350						1.02		1349	1.53
123468-HxCDF	34.08		0.9609	0.9610	+0.2	1.12E+05	1.14	Y	1.13	17.5	1378	2.04
124678/134678-HxCDF	34.28		0.9668	0.9667	-0.2	3.54E+05	1.20	Y	1.13	55.1	1378	2.04
134679-HxCDF	34.51		0.9733	0.9732	-0.2	2.81E+04	1.12	Y	1.13	4.38	1378	2.04
124679-HxCDF	34.71		0.9788	0.9787	-0.2	3.34E+04	1.05	N	1.13	5.21	1378	2.04
124689-HxCDF	34.94		0.9851	0.9853	+0.4	2.31E+04	1.09	Y	1.13	3.6	1378	2.04
123467-HxCDF	35.36		0.9968	0.9971	+0.6	8.16E+04	1.54	N	1.13	12.7	1378	2.04
123478-HxCDF	35.48		1.0004	1.0005	+0.2	1.20E+05	1.10	Y	1.14	19.4	1378	1.95
123678-HxCDF	35.62		1.0005	1.0006	+0.2	1.34E+05	1.17	Y	1.13	19.3	1378	1.86
123479-HxCDF	35.77		1.0048	1.0049	+0.2	2.66E+04	0.96	N	1.13	4.15	1378	2.04
123469-HxCDF	35.91		1.0090	1.0089	-0.2	3.20E+04	1.25	Y	1.13	4.98	1378	2.04
123679-HxCDF	36.03		0.9943	0.9939	-0.9	2.93E+04	1.53	N	1.13	4.56	1378	2.04
234678-HxCDF	36.26		1.0005	1.0003	-0.4	1.17E+05	1.38	Y	1.14	17.2	1378	1.89
234678/123689-HxCDF	NotFnd		1.0004						1.14		1378	1.89
123689-HxCDF	NotFnd		1.0009						1.13		1378	2.04
123789-HxCDF	NotFnd		1.0005						1.12		1378	2.53
123789/123489-HxCDF	37.26		1.0012	1.0013	+0.2	1.84E+04	1.93	N	1.12	3.2	1378	2.53
123489-HxCDF	NotFnd		1.0017						1.13		1378	2.04
1234678-HpCDF	38.90		1.0003	1.0003	0	2.91E+05	1.07	Y	1.38	50.6	1405	2.14
1234679-HpCDF	39.21		1.0083	1.0083	0	5.88E+04	0.97	Y	1.36	11.1	1405	2.67
1234689-HpCDF	39.38		1.0132	1.0125	-1.6	5.28E+04	0.88	N	1.36	10	1405	2.67
1234789-HpCDF	40.60		1.0003	1.0001	-0.5	2.99E+04	1.11	Y	1.33	6.18	1405	3.29
OCDF	43.77		1.0004	1.0002	-0.5	9.85E+04	0.91	Y	0.96	24.2	1348	4.27
OCDF-a	NotFnd		1.0002						0.05		1651	91.7

1 - 195

AP Lab ID: P2096_7679_004
Instr: AutoSpec-Ultima MM1

Sample ID: Unit 1 FF Outlet Run 3
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 51






Acq: 9-APR-2010 12:29:27
User: MC Datafile: 100409P1-07



AP Lab ID: P2096_7679_004
Instr: AutoSpec-Ultima MM1

Sample ID: Unit 1 FF Outlet Run 3
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 51






Acq: 9-APR-2010 12:29:27
User: MC Datafile: 100409P1-07



AP Lab ID: P2096_7679_004
Instr: AutoSpec-Ultima MM1

Sample ID: Unit 1 FF Outlet Run 3
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 51






Acq: 9-APR-2010 12:29:27
User: MC Datafile: 100409P1-07



AP Lab ID: P2096_7679_004
Instr: AutoSpec-Ultima MM1

Sample ID: Unit 1 FF Outlet Run 3
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 51

Acq: 9-APR-2010 12:29:27
User: MC Datafile: 100409P1-07








1 - 199

AP Lab ID: P2096_7679_004
Instr: AutoSpec-Ultima MM1

Sample ID: Unit 1 FF Outlet Run 3
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 51

Acq: 9-APR-2010 12:29:27
User: MC Datafile: 100409P1-07








1 - 200

AP Lab ID: P2096_7679_004
Instr: AutoSpec-Ultima MM1

Sample ID: Unit 1 FF Outlet Run 3
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 51






Acq: 9-APR-2010 12:29:27
User: MC Datafile: 100409P1-07



AP Lab ID: P2096_7679_004
Instr: AutoSpec-Ultima MM1

Sample ID: Unit 1 FF Outlet Run 3
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 51




Acq: 9-APR-2010 12:29:27
User: MC Datafile: 100409P1-07



AP Lab ID: P2096_7679_004
Instr: AutoSpec-Ultima MM1

Sample ID: Unit 1 FF Outlet Run 3
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 51






Acq: 9-APR-2010 12:29:27
User: MC Datafile: 100409P1-07



AP Lab ID: P2096_7679_004
Instr: AutoSpec-Ultima MM1

Sample ID: Unit 1 FF Outlet Run 3
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 51

Acq: 9-APR-2010 12:29:27
User: MC Datafile: 100409P1-07



Results: P:\P2000_P2099\P2096\P2096_7679 DFResources\P2096_7679_004.utp_res, saved 12-Apr-2010 17:24 (GG)
AP UltraTrace-Pro V4.2 User/System: GG/GG17-048 cc: 8220, 5794, 7743 scc: 487-158






Peak annotation: Areas, Centroids
Revised: 09-Apr-2010 13:25:25 (MC) Printed: 12-Apr-2010 17:25:28 Page 9 of 12

I - 204

AP Lab ID: P2096_7679_004
Instr: AutoSpec-Ultima MM1

Sample ID: Unit 1 FF Outlet Run 3
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 51






Acq: 9-APR-2010 12:29:27
User: MC Datafile: 100409P1-07



AP Lab ID: P2096_7679_004
Instr: AutoSpec-Ultima MM1

Sample ID: Unit 1 FF Outlet Run 3
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 51






Acq: 9-APR-2010 12:29:27
User: MC Datafile: 100409P1-07



AP Lab ID: P2096_7679_004
Instr: AutoSpec-Ultima MM1

Sample ID: Unit 1 FF Outlet Run 3
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 51

Acq: 9-APR-2010 12:29:27
User: MC Datafile: 100409P1-07



Lab ID: P2096_7679_005
 Client ID: Reagent Blank
 Datafile: 100409P1-08

Acq'd: 09 Apr 2010 13:19 MC
 UTP: 09-Apr-2010 15:51 MC
 Report: 09 Apr 2010 15:54 MC

Wt/Vol: 1
 J-level: 10 pg
 ES spike: 4000 pg

Cal: BCS3_7679_DF_PAB
 Checkcode: 493-202
 Split: 2

Name	Act RT	QC	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Conc.	Noise	DL
2378-TCDD	NotFnd		1.0008	-		-	-	-	0.99	-	981	1.3
12378-PeCDD	NotFnd		1.0006	-		-	-	-	0.93	-	1138	1.7
123478-HxCDD	NotFnd		1.0004	-		-	-	-	1.04	-	1240	2.2
123678-HxCDD	NotFnd		1.0034	-		-	-	-	0.95	-	1240	2.16
123789-HxCDD	NotFnd		1.0116	-		-	-	-	0.93	-	1240	2.45
1234678-HpCDD	NotFnd		1.0003	-		-	-	-	0.96	-	1289	2.81
OCDD	NotFnd		1.0004	-		-	-	-	1.00	-	1317	4.36
2378-TCDF	NotFnd		1.0009	-		-	-	-	1.08	-	1008	0.86
12378-PeCDF	NotFnd		1.0006	-		-	-	-	1.00	-	1205	1.14
23478-PeCDF	NotFnd		1.0005	-		-	-	-	1.04	-	1205	1.19
123478-HxCDF	NotFnd		1.0004	-		-	-	-	1.14	-	1387	1.68
123678-HxCDF	NotFnd		1.0005	-		-	-	-	1.13	-	1387	1.55
234678-HxCDF	NotFnd		1.0005	-		-	-	-	1.14	-	1387	1.7
123789-HxCDF	NotFnd		1.0005	-		-	-	-	1.12	-	1387	2.31
1234678-HpCDF	NotFnd		1.0003	-		-	-	-	1.38	-	1122	1.65
1234789-HpCDF	NotFnd		1.0003	-		-	-	-	1.33	-	1122	2.25
OCDF	NotFnd		1.0004	-		-	-	-	0.96	-	1362	3.57

Name	Act RT	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Rec. %
ES 2378-TCDD	26.86	1.0259	1.0259	0	3.24E+07	0.79	Y	1.01	94.3
ES 12378-PeCDD	32.47	1.2404	1.2403	-0.2	2.60E+07	1.58	Y	0.78	97.8
ES 123478-HxCDD	36.43	0.9917	0.9918	+0.2	2.19E+07	1.27	Y	0.99	97.3
ES 123678-HxCDD	36.54	0.9947	0.9948	+0.2	2.38E+07	1.27	Y	1.07	98.7
ES 123789-HxCDD	36.83	1.0028	1.0028	0	2.48E+07	1.28	Y	1.09	100
ES 1234678-HpCDD	40.03	1.0902	1.0897	-1.1	1.98E+07	1.04	Y	0.90	96.9
ES OCDD	43.53	1.1862	1.1851	-2.4	3.10E+07	0.90	Y	0.74	92.6
ES 2378-TCDF	25.92	1.0585	1.0585	0	4.73E+07	0.80	Y	1.00	95.4
ES 12378-PeCDF	30.97	1.2646	1.2644	-0.3	3.62E+07	1.57	Y	0.75	97.3
ES 23478-PeCDF	32.11	1.3113	1.3110	-0.4	3.60E+07	1.55	Y	0.74	97.3
ES 123478-HxCDF	35.45	0.9651	0.9653	+0.4	2.69E+07	0.53	Y	1.19	99.9
ES 123678-HxCDF	35.59	0.9689	0.9690	+0.2	2.99E+07	0.51	Y	1.35	98
ES 234678-HxCDF	36.25	0.9867	0.9868	+0.2	2.85E+07	0.53	Y	1.28	98.2
ES 123789-HxCDF	37.21	1.0129	1.0129	0	2.47E+07	0.53	Y	1.20	91.1
ES 1234678-HpCDF	38.88	1.0589	1.0586	-0.7	2.06E+07	0.44	Y	0.95	95.9
ES 1234789-HpCDF	40.59	1.1057	1.1050	-1.5	1.71E+07	0.44	Y	0.82	92.7
ES OCDF	43.76	1.1926	1.1914	-2.6	3.94E+07	0.89	Y	0.96	91

Lab ID: P2096_7679_005

Client ID: Reagent Blank

Datafile: 100409P1-08

Acq'd: 09 Apr 2010 13:19 MC

UTP: 09-Apr-2010 15:51 MC

Report: 09 Apr 2010 15:54 MC

Wt/Vol: 1

J-level: 10 pg

ES spike: 4000 pg

Cal: BCS3_7679_DF_PAB

Checkcode: 493-202

Split: 2

Name	Act RT	QC	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Rec. %
JS 1234-TCDD	26.18		-	-	-	3.40E+07	0.81	Y	-	-
JS 1234-TCDF	24.49		-	-	-	4.96E+07	0.80	Y	-	-
JS 123467-HxCDD	36.73		-	-	-	1.13E+07	1.25	Y	-	-
CS 37C1-2378-TCDD	NotFnd		1.0268				n/a	-		
CS 12347-PeCDD	NotFnd		1.2209							
CS 12346-PeCDF	NotFnd		1.2424							
CS 123469-HxCDF	NotFnd		0.9773							
CS 1234689-HpCDF	NotFnd		1.0720							
SS 37C1-2378-TCDD	NotFnd		1.0268				n/a	-		
SS 12347-PeCDD	NotFnd		1.2209							
SS 12346-PeCDF	NotFnd		1.2424							
SS 123469-HxCDF	NotFnd		0.9773							
SS 1234689-HpCDF	NotFnd		1.0720							
AS 1368-TCDD	22.91		0.8731	0.8750	+3.0	3.42E+07	0.80	Y	1.08	93
AS 1368-TCDF	20.78		0.8447	0.8486	+5.7	5.83E+07	0.79	Y	1.29	90.9
FS 1278-TCDD	NotFnd		1.0131							
FS 12478-PeCDD	31.24		0.9617	0.9620	+0.6	1.85E+04	+3.2	N	1.00	0.0711
FS 123468-HxCDD	NotFnd		0.9713							
FS 1234679-HpCDD	39.2		0.9794	0.9793	-0.2	1.70E+05	1.08	Y	0.01	111
TS 1378-TCDD	NotFnd		0.9345							

FS and TS
KAM 12 Apr 10

Totals	Conc	EMPC
Total TCDD	0	0
Total PeCDD	0	0
Total HxCDD	0	0
Total HpCDD	0	0
Total Tetra-Octa Dioxins	0	0
Total TCDF	0	0
Total PeCDF	0	0
Total HxCDF	0	0
Total HpCDF	0	0
Total Tetra-Octa Furans	0	0
Total Tetra-Octa Dioxins & Furans	0	0

Lab ID: P2096_7679_005

Client ID: Reagent Blank

Datafile: 100409P1-08

Acq'd: 09 Apr 2010 13:19 MC

UTP: 09-Apr-2010 15:51 MC

Report: 09 Apr 2010 15:54 MC

Wt/Vol: 1

J-level: 10 pg

ES spike: 4000 pg

Cal: BCS3_7679_DF_PAB

Checkcode: 493-202

Split: 2

Name	Act RT	QC	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Conc.	Noise	DL
1368-TCDD	NotFnd		0.8539						0.99		981	1.3
1379-TCDD	NotFnd		0.8685						0.99		981	1.3
1369-TCDD	NotFnd		0.8863						0.99		981	1.3
1469-TCDD	NotFnd		0.9189						0.99		981	1.3
1247/1246/1248/1249-TCDD	NotFnd		0.9276						0.99		981	1.3
1378-TCDD	NotFnd		0.9351						0.99		981	1.3
1268-TCDD	NotFnd		0.9430						0.99		981	1.3
1478-TCDD	NotFnd		0.9517						0.99		981	1.3
1279-TCDD	NotFnd		0.9598						0.99		981	1.3
1234/1269-TCDD	NotFnd		0.9740						0.99		981	1.3
1236-TCDD	NotFnd		0.9801						0.99		981	1.3
1237/1238-TCDD	NotFnd		0.9895						0.99		981	1.3
1239-TCDD	NotFnd		0.9952						0.99		981	1.3
2378-TCDD	NotFnd		1.0008						0.99		981	1.3
1278-TCDD	NotFnd		1.0138						0.99		981	1.3
1267-TCDD	NotFnd		1.0194						0.99		981	1.3
1289-TCDD	NotFnd		1.0396						0.99		981	1.3
12479/12468-PeCDD	NotFnd		0.9210						0.93		1138	1.7
12469-PeCDD	NotFnd		0.9382						0.93		1138	1.7
12368-PeCDD	NotFnd		0.9556						0.93		1138	1.7
12478-PeCDD	NotFnd		0.9614						0.93		1138	1.7
12379-PeCDD	NotFnd		0.9649						0.93		1138	1.7
12369/12467/12489-PeCDD	NotFnd		0.9732						0.93		1138	1.7
12346/12347-PeCDD	NotFnd		0.9850						0.93		1138	1.7
12378-PeCDD	NotFnd		1.0006						0.93		1138	1.7
12367-PeCDD	NotFnd		1.0037						0.93		1138	1.7
12389-PeCDD	NotFnd		1.0146						0.93		1138	1.7
124679/124689-HxCDD	NotFnd		0.9534						0.97		1240	2.26
123468-HxCDD	NotFnd		0.9717						0.97		1240	2.26
123679/123689-HxCDD	NotFnd		0.9793						0.97		1240	2.26
123469-HxCDD	NotFnd		0.9833						0.97		1240	2.26
123478-HxCDD	NotFnd		1.0004						1.04		1240	2.2
123678-HxCDD	NotFnd		1.0034						0.95		1240	2.16
123467-HxCDD	NotFnd		1.0088						0.97		1240	2.26
123789-HxCDD	NotFnd		1.0116						0.93		1240	2.45

I-210

Lab ID: P2096_7679_005

Client ID: Reagent Blank

Datafile: 100409P1-08

Acq'd: 09 Apr 2010 13:19 MC

UTP: 09-Apr-2010 15:51 MC

Report: 09 Apr 2010 15:54 MC

Wt/Vol: 1

J-level: 10 pg

ES spike: 4000 pg

Cal: BCS3_7679_DF_PAB

Checkcode: 493-202

Name	Act RT	QC	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Conc.	Noise	DL
1234679-HpCDD	NotFnd		0.9794						0.96		1289	2.81
1234678-HpCDD	NotFnd		1.0003						0.96		1289	2.81
OCDD	NotFnd		1.0004						1.00		1317	4.36
OCDD-a	NotFnd		1.0003						0.06		1496	81.2
1368-TCDF	NotFnd		0.8012						1.08		1008	0.86
1468-TCDF	NotFnd		0.8216						1.08		1008	0.86
2468-TCDF	NotFnd		0.8461						1.08		1008	0.86
1346/1246-TCDF	NotFnd		0.8607						1.08		1008	0.86
1347/1378/1247-TCDF	NotFnd		0.8672						1.08		1008	0.86
1348-TCDF	NotFnd		0.8792						1.08		1008	0.86
1248/1367/1379-TCDF	NotFnd		0.8846						1.08		1008	0.86
1268-TCDF	NotFnd		0.9011						1.08		1008	0.86
1467-TCDF	NotFnd		0.9067						1.08		1008	0.86
1478-TCDF	NotFnd		0.9137						1.08		1008	0.86
1369/1237-TCDF	NotFnd		0.9293						1.08		1008	0.86
2467-TCDF	NotFnd		0.9348						1.08		1008	0.86
2368-TCDF	NotFnd		0.9408						1.08		1008	0.86
1238/1234/1678/1469/1236-TCDF	NotFnd		0.9445						1.08		1008	0.86
1278-TCDF	NotFnd		0.9641						1.08		1008	0.86
1349-TCDF	NotFnd		0.9693						1.08		1008	0.86
1267-TCDF	NotFnd		0.9755						1.08		1008	0.86
2346/1249-TCDF	NotFnd		0.9834						1.08		1008	0.86
2347/1279-TCDF	NotFnd		0.9922						1.08		1008	0.86
2348-TCDF	NotFnd		0.9966						1.08		1008	0.86
2378-TCDF	NotFnd		1.0009						1.08		1008	0.86
2367/3467-TCDF	NotFnd		1.0164						1.08		1008	0.86
1269-TCDF	NotFnd		1.0260						1.08		1008	0.86
1239-TCDF	NotFnd		1.0375						1.08		1008	0.86
1289-TCDF	NotFnd		1.0834						1.08		1008	0.86
13468/12468-PeCDF	NotFnd		0.9057						1.02		1465	1.42
13678/13467/12467-PeCDF	NotFnd		0.9581						1.02		1205	1.17
12368/13478/12478-PeCDF	NotFnd		0.9620						1.02		1205	1.17
14678-PeCDF	NotFnd		0.9667						1.02		1205	1.17
13479-PeCDF	NotFnd		0.9702						1.02		1205	1.17
13469/12479-PeCDF	NotFnd		0.9781						1.02		1205	1.17
12346-PeCDF	NotFnd		0.9829						1.02		1205	1.17

Lab ID: P2096_7679_005

Client ID: Reagent Blank

Datafile: 100409P1-08

Acq'd: 09 Apr 2010 13:19 MC

UTP: 09-Apr-2010 15:51 MC

Report: 09 Apr 2010 15:54 MC

Wt/Vol: 1

J-level: 10 pg

ES spike: 4000 pg

Cat: BCS3_7679_DF_PAB

Checkcode: 493-202

Split: 2






Name	Act RT	QC	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Conc.	Noise	DL
23468/12469-PeCDF	NotFnd		0.9858						1.02		1205	1.17
12347-PeCDF	NotFnd		0.9881						1.02		1205	1.17
12348-PeCDF	NotFnd		0.9936						1.02		1205	1.17
12378-PeCDF	NotFnd		1.0006						1.00		1205	1.14
12678/12367-PeCDF	NotFnd		1.0104						1.02		1205	1.17
12379-PeCDF	NotFnd		1.0151						1.02		1205	1.17
12679-PeCDF	NotFnd		0.9925						1.02		1205	1.17
23467/12369-PeCDF	NotFnd		0.9981						1.02		1205	1.17
23478-PeCDF	NotFnd		1.0005						1.04		1205	1.19
23478/12489-PeCDF	NotFnd		1.0006						1.04		1205	1.19
12489-PeCDF	NotFnd		1.0023						1.02		1205	1.17
12349-PeCDF	NotFnd		1.0110						1.02		1205	1.17
12389-PeCDF	NotFnd		1.0350						1.02		1205	1.17
123468-HxCDF	NotFnd		0.9609						1.13		1387	1.79
124678/134678-HxCDF	NotFnd		0.9668						1.13		1387	1.79
134679-HxCDF	NotFnd		0.9733						1.13		1387	1.79
124679-HxCDF	NotFnd		0.9788						1.13		1387	1.79
124689-HxCDF	NotFnd		0.9851						1.13		1387	1.79
123467-HxCDF	NotFnd		0.9968						1.13		1387	1.79
123478-HxCDF	NotFnd		1.0004						1.14		1387	1.68
123678-HxCDF	NotFnd		1.0005						1.13		1387	1.55
123479-HxCDF	NotFnd		1.0048						1.13		1387	1.79
123469-HxCDF	NotFnd		1.0090						1.13		1387	1.79
123679-HxCDF	NotFnd		0.9943						1.13		1387	1.79
234678-HxCDF	NotFnd		1.0005						1.14		1387	1.7
234678/123689-HxCDF	NotFnd		1.0004						1.14		1387	1.7
123689-HxCDF	NotFnd		1.0009						1.13		1387	1.79
123789-HxCDF	NotFnd		1.0005						1.12		1387	2.31
123789/123489-HxCDF	NotFnd		1.0012						1.12		1387	2.31
123489-HxCDF	NotFnd		1.0017						1.13		1387	1.79
1234678-HpCDF	NotFnd		1.0003						1.38		1122	1.65
1234679-HpCDF	NotFnd		1.0083						1.36		1122	1.92
1234689-HpCDF	NotFnd		1.0132						1.36		1122	1.92
1234789-HpCDF	NotFnd		1.0003						1.33		1122	2.25
OCDF	NotFnd		1.0004						0.96		1362	3.57
OCDF-a	NotFnd		1.0002						0.05		1452	66.8

1-212

AP Lab ID: P2096_7679_005
Instr: AutoSpec-Ultima MM1

Sample ID: Reagent Blank
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 52

Acq: 9-APR-2010 13:19:56
User: MC Datafile: 100409P1-08








1 - 213

AP Lab ID: P2096_7679_005
Instr: AutoSpec-Ultima MM1

Sample ID: Reagent Blank
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 52






Acq: 9-APR-2010 13:19:56
User: MC Datafile: 100409P1-08








AP Lab ID: P2096_7679_005
Instr: AutoSpec-Ultima MM1

Sample ID: Reagent Blank
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 52

Acq: 9-APR-2010 13:19:56
User: MC Datafile: 100409P1-08















AP Lab ID: P2096_7679_005
Instr: AutoSpec-Ultima MM1

Sample ID: Reagent Blank
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 52

Acq: 9-APR-2010 13:19:56
User: MC Datafile: 100409P1-08










I - 218

AP Lab ID: P2096_7679_005
Instr: AutoSpec-Ultima MM1

Sample ID: Reagent Blank
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 52




Acq: 9-APR-2010 13:19:56
User: MC DataFile: 100409P1-08



AP Lab ID: P2096_7679_005
Instr: AutoSpec-Ultima MM1

Sample ID: Reagent Blank
SiR expt: DF_CL4-8A GC: DB5MS_60M Vial: 52

Acq: 9-APR-2010 13:19:56
User: MC Datafile: 100409P1-08








1 - 220

AP Lab ID: P2096_7679_005
Instr: AutoSpec-Ultima MM1

Sample ID: Reagent Blank
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 52

Acq: 9-APR-2010 13:19:56
User: MC Datafile: 100409P1-08








1-221

AP Lab ID: P2096_7679_005
Instr: AutoSpec-Ultima MM1

Sample ID: Reagent Blank
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 52






Acq: 9-APR-2010 13:19:56
User: MC Datafile: 100409P1-08



AP Lab ID: P2096_7679_005
Instr: AutoSpec-Ultima MM1

Sample ID: Reagent Blank
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 52

Acq: 9-APR-2010 13:19:56
User: MC Datafile: 100409P1-08








1 - 223

AP Lab ID: P2096_7679_005
Instr: AutoSpec-Ultima MM1

Sample ID: Reagent Blank
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 52

Acq: 9-APR-2010 13:19:56
User: MC Datafile: 100409P1-08



1-224

P2096



ANALYTICAL PERSPECTIVES

PART 4

SYSTEM PERFORMANCE

MS & GC

BCS₃ - CONCAL

DOCUMENTATION FOR THE ANALYSIS

OF

POLYCHLORINATED DIBENZO-*p*-DIOXINS & DIBENZOFURANS

This Page Intentionally Left Blank

Dioxin/Furan BCS3 Summary

ANALYTICAL PERSPECTIVES

Report Created: 09-Apr-2010 15:52 MC

Name	BCS3_7679_DF_PA 09-APR-2010 07:26 100409P1-01			BCS3_7679_DF_PB 09-APR-2010 15:00 100409P1-10			BCS3_7679_DF_PAB ICAL: MM1_DF_122509						
	RT	Response	Ra	RT	Response	Ra	ICAL	RRF(A)	RRF(B)	AB Avg	A-I	B-I	AB RPD
2378-TCDD	26.88	2.60E+06	0.77 Y	26.87	2.70E+06	0.81 Y	1.23	0.99	0.99	0.99	-19%	-19%	0%
12378-PeCDD	32.48	9.50E+06	1.55 Y	32.47	9.72E+06	1.58 Y	1.14	0.93	0.93	0.93	-18%	-18%	0%
123478-HxCDD	36.44	8.88E+06	1.25 Y	36.43	9.32E+06	1.24 Y	1.19	1.06	1.03	1.04	-12%	-14%	3%
123678-HxCDD	36.55	8.86E+06	1.25 Y	36.54	8.96E+06	1.25 Y	1.09	0.95	0.95	0.95	-13%	-13%	0%
123789-HxCDD	36.85	8.76E+06	1.23 Y	36.84	9.12E+06	1.21 Y	1.08	0.92	0.94	0.93	-15%	-13%	2%
1234678-HpCDD	40.04	7.30E+06	1.03 Y	40.03	8.05E+06	1.02 Y	1.04	0.96	0.96	0.96	-7%	-7%	0%
OCDD	43.55	1.30E+07	0.89 Y	43.54	1.31E+07	0.91 Y	1.10	1.01	0.99	1.00	-7%	-9%	2%
2378-TCDF	25.94	4.05E+06	0.74 Y	25.94	4.18E+06	0.73 Y	1.13	1.08	1.08	1.08	-4%	-4%	0%
12378-PeCDF	30.98	1.43E+07	1.53 Y	30.97	1.44E+07	1.53 Y	1.16	0.99	1.01	1.00	-15%	-13%	2%
23478-PeCDF	32.12	1.48E+07	1.53 Y	32.11	1.49E+07	1.52 Y	1.13	1.04	1.05	1.04	-9%	-8%	1%
123478-HxCDF	35.47	1.16E+07	1.24 Y	35.46	1.24E+07	1.22 Y	1.26	1.13	1.15	1.14	-10%	-9%	1%
123678-HxCDF	35.61	1.33E+07	1.25 Y	35.60	1.36E+07	1.23 Y	1.25	1.15	1.11	1.13	-8%	-11%	4%
234678-HxCDF	36.26	1.27E+07	1.26 Y	36.25	1.30E+07	1.28 Y	1.18	1.15	1.13	1.14	-2%	-4%	2%
123789-HxCDF	37.22	1.16E+07	1.25 Y	37.21	1.20E+07	1.25 Y	1.20	1.13	1.11	1.12	-6%	-8%	2%
1234678-HpCDF	38.89	1.12E+07	1.03 Y	38.88	1.18E+07	1.03 Y	1.39	1.37	1.39	1.38	-2%	0%	2%
1234789-HpCDF	40.60	9.35E+06	1.06 Y	40.59	9.81E+06	1.04 Y	1.42	1.34	1.32	1.33	-6%	-7%	2%
OCDF	43.78	1.57E+07	0.91 Y	43.77	1.68E+07	0.91 Y	1.01	0.96	0.97	0.96	-5%	-5%	1%
ES 2378-TCDD	26.85	2.62E+07	0.81 Y	26.85	2.72E+07	0.79 Y	1.04	1.01	1.01	1.01	-3%	-3%	0%
ES 12378-PeCDD	32.47	2.04E+07	1.65 Y	32.46	2.09E+07	1.59 Y	0.96	0.79	0.78	0.78	-18%	-19%	1%
ES 123478-HxCDD	36.43	1.68E+07	1.26 Y	36.42	1.82E+07	1.28 Y	1.01	1.01	0.98	0.99	0%	-3%	3%
ES 123678-HxCDD	36.54	1.87E+07	1.28 Y	36.53	1.89E+07	1.27 Y	1.14	1.12	1.02	1.07	-1%	-11%	10%
ES 123789-HxCDD	36.83	1.91E+07	1.26 Y	36.82	1.94E+07	1.25 Y	1.14	1.14	1.04	1.09	0%	-9%	9%
ES 1234678-HpCDD	40.03	1.52E+07	1.06 Y	40.02	1.67E+07	1.06 Y	0.98	0.91	0.90	0.90	-7%	-9%	1%
ES OCDD	43.53	2.57E+07	0.90 Y	43.52	2.64E+07	0.88 Y	0.76	0.77	0.71	0.74	1%	-7%	8%
ES 2378-TCDF	25.92	3.76E+07	0.80 Y	25.92	3.88E+07	0.80 Y	0.94	0.99	1.00	1.00	6%	7%	1%
ES 12378-PeCDF	30.96	2.89E+07	1.59 Y	30.95	2.84E+07	1.57 Y	0.95	0.76	0.74	0.75	-19%	-22%	4%
ES 23478-PeCDF	32.10	2.86E+07	1.56 Y	32.09	2.83E+07	1.55 Y	0.90	0.76	0.73	0.74	-16%	-18%	3%
ES 123478-HxCDF	35.45	2.05E+07	0.52 Y	35.44	2.15E+07	0.52 Y	1.50	1.23	1.16	1.19	-18%	-23%	6%
ES 123678-HxCDF	35.59	2.31E+07	0.52 Y	35.58	2.44E+07	0.51 Y	1.63	1.39	1.31	1.35	-15%	-19%	5%
ES 234678-HxCDF	36.24	2.21E+07	0.52 Y	36.24	2.31E+07	0.51 Y	1.50	1.33	1.24	1.28	-12%	-17%	7%
ES 123789-HxCDF	37.20	2.05E+07	0.52 Y	37.19	2.17E+07	0.53 Y	1.32	1.23	1.17	1.20	-7%	-12%	5%
ES 1234678-HpCDF	38.88	1.64E+07	0.44 Y	38.87	1.70E+07	0.45 Y	1.11	0.98	0.92	0.95	-12%	-18%	7%
ES 1234789-HpCDF	40.59	1.39E+07	0.44 Y	40.58	1.48E+07	0.45 Y	0.92	0.83	0.80	0.82	-9%	-13%	5%
ES OCDF	43.77	3.28E+07	0.90 Y	43.75	3.47E+07	0.89 Y	1.07	0.98	0.93	0.96	-8%	-13%	5%

Dioxin/Furan BCS3 Summary

ANALYTICAL PERSPECTIVES

Report Created: 09-Apr-2010 15:52 MC

Name	BCS3_7679_DF_PA 09-APR-2010 07:26 100409P1-01			BCS3_7679_DF_PB 09-APR-2010 15:00 100409P1-10			BCS3_7679_DF_PAB ICAL: MM1_DF_122509						
	RT	Response	Ra	RT	Response	Ra	ICAL	RRF(A)	RRF(B)	AB Avg	A-I	B-I	AB RPD
JS 1234-TCDD	26.18	1.29E+07	0.81 Y	26.17	1.35E+07	0.79 Y	-						
JS 1234-TCDF	24.49	1.89E+07	0.80 Y	24.49	1.93E+07	0.79 Y	-						
JS 123467-HxCDD	36.73	4.16E+06	1.21 Y	36.72	4.65E+06	1.29 Y	-						
CS 37C1-2378-TCDD	26.88	1.19E+07	-	26.87	1.26E+07	-	1.11	1.15	1.17	1.16	3%	5%	2%
CS 12347-PeCDD	31.95	2.06E+07	1.65 Y	31.94	2.12E+07	1.62 Y	1.03	0.80	0.79	0.79	-23%	-24%	1%
CS 12346-PeCDF	30.42	3.03E+07	1.56 Y	30.41	3.01E+07	1.55 Y	0.92	0.80	0.78	0.79	-13%	-15%	3%
CS 123469-HxCDF	35.90	2.12E+07	0.53 Y	35.89	2.19E+07	0.51 Y	1.31	1.28	1.18	1.23	-2%	-10%	8%
CS 1234689-HpCDF	39.36	1.47E+07	0.44 Y	39.35	1.57E+07	0.45 Y	0.91	0.88	0.84	0.86	-3%	-7%	5%
SS 37C1-2378-TCDD	26.88	1.19E+07	-	26.87	1.26E+07	-	1.07	1.13	1.16	1.14	6%	8%	2%
SS 12347-PeCDD	31.95	2.06E+07	1.65 Y	31.94	2.12E+07	1.62 Y	1.08	1.01	1.01	1.01	-6%	-6%	0%
SS 12346-PeCDF	30.42	3.03E+07	1.56 Y	30.41	3.01E+07	1.55 Y	0.97	1.05	1.06	1.05	8%	9%	1%
SS 123469-HxCDF	35.90	2.12E+07	0.53 Y	35.89	2.19E+07	0.51 Y	0.81	0.92	0.90	0.91	14%	11%	2%
SS 1234689-HpCDF	39.36	1.47E+07	0.44 Y	39.35	1.57E+07	0.45 Y	0.81	0.90	0.92	0.91	10%	13%	3%
AS 1368-TCDD	22.90	2.83E+07	0.79 Y	22.91	2.87E+07	0.81 Y	1.09	1.09	1.07	1.08	0%	-2%	3%
AS 1368-TCDF	20.74	4.89E+07	0.80 Y	20.75	5.00E+07	0.80 Y	1.12	1.29	1.29	1.29	15%	15%	0%
FS 1278-TCDD	NotFnd	-	-	NotFnd	-	-	-						
FS 12478-PeCDD	NotFnd	-	-	NotFnd	-	-	-						
FS 123468-HxCDD	NotFnd	-	-	NotFnd	-	-	-						
FS 1234679-HpCDD	39.21	1.03E+05	1.39 N	39.20	1.44E+05	1.01 Y	-	0.01	0.01	0.01			24%
TS 1378-TCDD	NotFnd	-	-	NotFnd	-	-	-						
OCDD-a	43.55	7.83E+05	2.57 Y	43.53	8.09E+05	2.27 Y	0.07	0.06	0.06	0.06	-9%	-9%	1%
OCDF-a	43.78	8.92E+05	2.57 Y	43.77	9.60E+05	2.44 Y	0.06	0.05	0.06	0.05	-9%	-7%	1%
Total TCDD	-	-	-	-	-	-	1.23	0.99	0.99	0.99	-19%	-19%	0%
Total PeCDD	-	-	-	-	-	-	1.14	0.93	0.93	0.93	-18%	-18%	0%
Total HxCDD	-	-	-	-	-	-	1.12	0.97	0.97	0.97	-13%	-13%	0%
Total HpCDD	-	-	-	-	-	-	1.04	0.96	0.96	0.96	-7%	-7%	0%
Total TCDF	-	-	-	-	-	-	1.13	1.08	1.08	1.08	-4%	-4%	0%
Total PeCDF	-	-	-	-	-	-	1.15	1.01	1.03	1.02	-12%	-10%	2%
Total HxCDF	-	-	-	-	-	-	1.22	1.14	1.13	1.13	-7%	-8%	2%
Total HpCDF	-	-	-	-	-	-	1.41	1.36	1.36	1.36	-4%	-4%	0%

1-228

BCS3_7679_DF_PA
09-APR-2010 07:26
100409P1-01

BCS3_7679_DF_PB
09-APR-2010 15:00
100409P1-10

BCS3_7679_DF_PAB
ICAL: MM1_DF_122509

Name	RT	RT
Window Defining Standards Results		
First Eluting Isomer		
1368-TCDD	22.93	22.94
12479/12468-PeCDD	29.90	29.90
124679/124689-HxCDD	34.74	34.73
1234679-HpCDD	39.21	39.20
1368-TCDF	20.77	20.78
13468/12468-PeCDF	28.04	28.04
123468-HxCDF	34.07	34.06
1234678-HpCDF	38.89	38.88
Last Eluting Isomer		
1289-TCDD	27.91	27.91
12389-PeCDD	32.94	32.93
123789-HxCDD	36.85	36.84
1234678-HpCDD	40.04	40.03
1289-TCDF	28.08	28.07
12389-PeCDF	33.22	33.22
123789-HxCDF	37.22	37.21
1234789-HpCDF	40.60	40.59
Isomer Specificity Test Standard Results		
1239-TCDD	26.73	26.72
2378-TCDD	26.88	26.87
2348-TCDF	25.83	25.83
2378-TCDF	25.94	25.94

METHOD 23

PCDD/F CALIBRATION VERIFICATION

FORM 4A

Lab Name: Analytical Perspectives
 Initial Calibration: ICAL: MM1_DF_122509
 Instrument ID: MM1 GC Column ID: ZB-5ms
 VER Data Filename: 100409P1-01 Analysis Date: 09-APR-2010 07:26:36

NATIVE ANALYTES	M/Z's FORMING RATIO	ION ABUND. RATIO	QC LIMITS	OK	CONC. FOUND	RANGE (ng/mL)	OK
2,3,7,8-TCDD	M/M+2	0.77	0.65 - 0.89	Y	10	8 - 12	Y
1,2,3,7,8-PeCDD	M+2/M+4	1.55	1.32 - 1.78	Y	50.1	40 - 60	Y
1,2,3,4,7,8-HxCDD	M+2/M+4	1.25	1.05 - 1.43	Y	50.7	40 - 60	Y
1,2,3,6,7,8-HxCDD	M+2/M+4	1.25	1.05 - 1.43	Y	50.1	40 - 60	Y
1,2,3,7,8,9-HxCDD	M+2/M+4	1.23	1.05 - 1.43	Y	49.4	40 - 60	Y
1,2,3,4,6,7,8-HpCDD	M+2/M+4	1.03	0.88 - 1.20	Y	50	40 - 60	Y
OCDD	M+2/M+4	0.89	0.76 - 1.02	Y	101	80 - 120	Y
2,3,7,8-TCDF	M/M+2	0.74	0.65 - 0.89	Y	9.99	8 - 12	Y
1,2,3,7,8-PeCDF	M+2/M+4	1.53	1.32 - 1.78	Y	49.4	40 - 60	Y
2,3,4,7,8-PeCDF	M+2/M+4	1.53	1.32 - 1.78	Y	49.7	40 - 60	Y
1,2,3,4,7,8-HxCDF	M+2/M+4	1.24	1.05 - 1.43	Y	49.7	40 - 60	Y
1,2,3,6,7,8-HxCDF	M+2/M+4	1.25	1.05 - 1.43	Y	50.9	40 - 60	Y
2,3,4,6,7,8-HxCDF	M+2/M+4	1.26	1.05 - 1.43	Y	50.5	40 - 60	Y
1,2,3,7,8,9-HxCDF	M+2/M+4	1.25	1.05 - 1.43	Y	50.5	40 - 60	Y
1,2,3,4,6,7,8-HpCDF	M+2/M+4	1.03	0.88 - 1.20	Y	49.6	40 - 60	Y
1,2,3,4,7,8,9-HpCDF	M+2/M+4	1.06	0.88 - 1.20	Y	50.4	40 - 60	Y
OCDF	M+2/M+4	0.91	0.76 - 1.02	Y	99.7	80 - 120	Y

1-230

METHOD 23

PCDD/F CALIBRATION VERIFICATION










FORM 4B

Lab Name: Analytical Perspectives
 Initial Calibration: ICAL: MM1_DF_122509
 Instrument ID: MM1 GC Column ID: ZB-5ms
 VER Data Filename: 100409P1-01 Analysis Date: 09-APR-2010 07:26:36









LABELLED ANALYTES	M/Z's FORMING RATIO	ION ABUND. RATIO	QC LIMITS	OK	CONC. FOUND	RANGE (ng/mL)	OK
13C-2,3,7,8-TCDD	M/M+2	0.81	0.65 - 0.89	Y	100	70 - 130	Y
13C-1,2,3,7,8-PeCDD	M+2/M+4	1.65	1.32 - 1.78	Y	101	70 - 130	Y
13C-1,2,3,4,7,8-HxCDD	M+2/M+4	1.26	1.05 - 1.43	Y	102	70 - 130	Y
13C-1,2,3,6,7,8-HxCDD	M+2/M+4	1.28	1.05 - 1.43	Y	105	70 - 130	Y
13C-1,2,3,7,8,9-HxCDD	M+2/M+4	1.26	1.05 - 1.43	Y	105	70 - 130	Y
13C-1,2,3,4,6,7,8-HpCDD	M+2/M+4	1.06	0.88 - 1.20	Y	101	70 - 130	Y
13C-OCDD	M+2/M+4	0.90	0.76 - 1.02	Y	208	140 - 260	Y
13C-2,3,7,8-TCDF	M/M+2	0.80	0.65 - 0.89	Y	99.6	70 - 130	Y
13C-1,2,3,7,8-PeCDF	M+2/M+4	1.59	1.32 - 1.78	Y	102	70 - 130	Y
13C-2,3,4,7,8-PeCDF	M+2/M+4	1.56	1.32 - 1.78	Y	102	70 - 130	Y
13C-1,2,3,4,7,8-HxCDF	M/M+2	0.52	0.43 - 0.59	Y	103	70 - 130	Y
13C-1,2,3,6,7,8-HxCDF	M/M+2	0.52	0.43 - 0.59	Y	103	70 - 130	Y
13C-2,3,4,6,7,8-HxCDF	M/M+2	0.52	0.43 - 0.59	Y	103	70 - 130	Y
13C-1,2,3,7,8,9-HxCDF	M/M+2	0.52	0.43 - 0.59	Y	103	70 - 130	Y
13C-1,2,3,4,6,7,8-HpCDF	M/M+2	0.44	0.37 - 0.51	Y	104	70 - 130	Y
13C-1,2,3,4,7,8,9-HpCDF	M/M+2	0.44	0.37 - 0.51	Y	102	70 - 130	Y
13C-OCDF	M+2/M+4	0.90	0.76 - 1.02	Y	205	140 - 260	Y
SURROGATE STANDARDS							
37Cl-2,3,7,8-TCDD	n/a				39.6	28 - 52	Y
13C-1,2,3,4,7-PeCDD	M+2/M+4	1.65	1.32 - 1.78	Y	100	70 - 130	Y
13C-1,2,3,4,6-PeCDF	M+2/M+4	1.56	1.32 - 1.78	Y	99.4	70 - 130	Y
13C-1,2,3,4,6,9-HxCDF	M/M+2	0.53	0.43 - 0.59	Y	101	70 - 130	Y
13C-1,2,3,4,6,8,9-HpCDF	M/M+2	0.44	0.37 - 0.51	Y	98.7	70 - 130	Y

Processed: 09 Apr 2010 15:52 Analyst: MC









Peak Locate Examination: 9-APR-2010:07:21 File:MM1 RES_CHECK
Experiment:DF_CL4-8A Function:1 Reference:PFK2










Peak Locate Examination: 9-APR-2010:07:22 File:MM1_RES_CHECK
Experiment:DF_CL4-8A Function:2 Reference:PFK2











Peak Locate Examination: 9-APR-2010:07:23 File:MM1_RES_CHECK
Experiment:DF_CL4-8A Function:3 Reference:PFK2












Peak Locate Examination: 9-APR-2010:07:24 File:MM1_RES_CHECK
Experiment:DF_CL4-8A Function:4 Reference:PFK2











Peak Locate Examination: 9-APR-2010:07:25 File:MM1_RES_CHECK
Experiment:DF_CL4-8A Function:5 Reference:pFK2











Peak Locate Examination: 9-APR-2010:15:54 File:MM1_RES_CHECK
Experiment:DF_CL4-8A Function:1 Reference:PFK2










Peak Locate Examination: 9-APR-2010:15:54 File:MM1_RES_CHECK
Experiment:DF_CL4-8A Function:2 Reference:PFK2











Peak Locate Examination: 9-APR-2010:15:55 File:MM1 RES_CHECK
Experiment:DF_CL4-8A Function:3 Reference:PFK2



Peak Locate Examination: 9-APR-2010:15:56 File:MM1_RES_CHECK
Experiment:DF_CL4-8A Function:4 Reference:PFK2





Peak Locate Examination: 9-APR-2010:15:57 File:MM1 RES_CHECK
Experiment:DF_CL4-8A Function:5 Reference:PFK2



AP Lab ID: BCS3_7679_DF_PA
Instr: AutoSpec-Ultima MM1

Sample ID: BCS3_7679_DF_PA
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 46

Acq: 9-APR-2010 07:26:36
User: MC Datafile: 100409P1-01



Results: P:\P2000_P2099\P2096\P2096_7679_DF\Resources\BCS3_7679_DF_PA.utp_res, saved 09-Apr-2010 15:58 (MC)
AP UltraTrace-Pro V4.21 User/System: MC/MC17-047



Peak annotation: Areas, Centroids
Revised: 09-Apr-2010 10:56:18 (MC) Printed: 09-Apr-2010 15:58:26

1-242

AP Lab ID: BCS3_7679_DF_PA
Instr: AutoSpec-Ultima MM1

Sample ID: BCS3_7679_DF_PA
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 46

Acq: 9-APR-2010 07:26:36
User: MC Datafile: 100409P1-01








1-243

AP Lab ID: BCS3_7679_DF_PA
Instr: AutoSpec-Ultima MM1

Sample ID: BCS3_7679_DF_PA
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 46

Acq: 9-APR-2010 07:26:36
User: MC Datafile: 100409P1-01








Results: P:\P2000_P2099\P2096\P2096_7679_DF\Resources\BCS3_7679_DF_PA.utp_res, saved 09-Apr-2010 15:58 (MC)
AP UltraTrace-Pro V4.21 User/System: MC/MC17-047 scc: 480-564

Peak annotation: Areas, Centroids
PKD: n/a Printed: 09-Apr-2010 16:02:03 Page 1 of 12

AP Lab ID: BCS3_7679_DF_PA
Instr: AutoSpec-Ultima MM1

Sample ID: BCS3_7679_DF_PA
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 46






Acq: 9-APR-2010 07:26:36
User: MC Datafile: 100409P1-01



AP Lab ID: BCS3_7679_DF_PA
Instr: AutoSpec-Ultima MM1

Sample ID: BCS3_7679_DF_PA
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 46


Acq: 9-APR-2010 07:26:36
User: MC Datafile: 100409P1-01



AP Lab ID: BCS3_7679_DF_PA
Instr: AutoSpec-Ultima MM1

Sample ID: BCS3_7679_DF_PA
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 46

Acq: 9-APR-2010 07:26:36
User: MC Datafile: 100409P1-01








1 - 247

AP Lab ID: BCS3_7679_DF_PA
Instr: AutoSpec-Ultima MM1

Sample ID: BCS3_7679_DF_PA
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 46

Acq: 9-APR-2010 07:26:36
User: MC Datafile: 100409P1-01








1-248

AP Lab ID: BCS3_7679_DF_PA
Instr: AutoSpec-Ultima MM1

Sample ID: BCS3_7679_DF_PA
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 46

Acq: 9-APR-2010 07:26:36
User: MC Datafile: 100409P1-01








1 - 249

AP Lab ID: BCS3_7679_DF_PA
Instr: AutoSpec-Ultima MM1

Sample ID: BCS3_7679_DF_PA
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 46




Acq: 9-APR-2010 07:26:36
User: MC Datafile: 100409P1-01



AP Lab ID: BCS3_7679_DF_PA
Instr: AutoSpec-Ultima MM1

Sample ID: BCS3_7679_DF_PA
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 46






Acq: 9-APR-2010 07:26:36
User: MC Datafile: 100409P1-01



AP Lab ID: BCS3_7679_DF_PA
Instr: AutoSpec-Ultima MM1

Sample ID: BCS3_7679_DF_PA
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 46

Acq: 9-APR-2010 07:26:36
User: MC Datafile: 100409P1-01








1 - 262

AP Lab ID: BCS3_7679_DF_PA
Instr: AutoSpec-Ultima MM1

Sample ID: BCS3_7679_DF_PA
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 46

Acq: 9-APR-2010 07:26:36
User: MC Datafile: 100409P1-01




Results: P:\P2000_P2099\P2096\P2096_7679_DF\Resources\BCS3_7679_DF_PA.utp_res, saved 09-Apr-2010 15:58 (MC)
AP UltraTrace-Pro V4.21 User/System: MC/MCI7-047 cc: 3930, 9124, 4337 scc: 480-564

Peak annotation: Areas, Centroids
Revised: 09-Apr-2010 10:56:39 (MC) Printed: 09-Apr-2010 16:03:12 Page 10 of 12

AP Lab ID: BCS3_7679_DF_PA
Instr: AutoSpec-Ultima MM1

Sample ID: BCS3_7679_DF_PA
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 46

Acq: 9-APR-2010 07:26:36
User: MC Datafile: 100409P1-01








I - 254

AP Lab ID: BCS3_7679_DF_PA
Instr: AutoSpec-Ultima MM1

Sample ID: BCS3_7679_DF_PA
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 46

Acq: 9-APR-2010 07:26:36
User: MC Datafile: 100409P1-01



METHOD 23

PCDD/F CALIBRATION VERIFICATION

FORM 4A

Lab Name: Analytical Perspectives
 Initial Calibration: ICAL: MM1_DF_122509
 Instrument ID: MM1 GC Column ID: ZB-5ms
 VER Data Filename: 100409P1-10 Analysis Date: 09-APR-2010 15:00:55

NATIVE ANALYTES	M/Z's FORMING RATIO	ION ABUND. RATIO	QC LIMITS	OK	CONC. FOUND	RANGE (ng/mL)	OK
2,3,7,8-TCDD	M/M+2	0.81	0.65 - 0.89	Y	9.99	8 - 12	Y
1,2,3,7,8-PeCDD	M+2/M+4	1.58	1.32 - 1.78	Y	49.9	40 - 60	Y
1,2,3,4,7,8-HxCDD	M+2/M+4	1.24	1.05 - 1.43	Y	49.3	40 - 60	Y
1,2,3,6,7,8-HxCDD	M+2/M+4	1.25	1.05 - 1.43	Y	49.9	40 - 60	Y
1,2,3,7,8,9-HxCDD	M+2/M+4	1.21	1.05 - 1.43	Y	50.6	40 - 60	Y
1,2,3,4,6,7,8-HpCDD	M+2/M+4	1.02	0.88 - 1.20	Y	50	40 - 60	Y
OCDD	M+2/M+4	0.91	0.76 - 1.02	Y	98.9	80 - 120	Y
2,3,7,8-TCDF	M/M+2	0.73	0.65 - 0.89	Y	10	8 - 12	Y
1,2,3,7,8-PeCDF	M+2/M+4	1.53	1.32 - 1.78	Y	50.6	40 - 60	Y
2,3,4,7,8-PeCDF	M+2/M+4	1.52	1.32 - 1.78	Y	50.3	40 - 60	Y
1,2,3,4,7,8-HxCDF	M+2/M+4	1.22	1.05 - 1.43	Y	50.3	40 - 60	Y
1,2,3,6,7,8-HxCDF	M+2/M+4	1.23	1.05 - 1.43	Y	49.1	40 - 60	Y
2,3,4,6,7,8-HxCDF	M+2/M+4	1.28	1.05 - 1.43	Y	49.5	40 - 60	Y
1,2,3,7,8,9-HxCDF	M+2/M+4	1.25	1.05 - 1.43	Y	49.5	40 - 60	Y
1,2,3,4,6,7,8-HpCDF	M+2/M+4	1.03	0.88 - 1.20	Y	50.4	40 - 60	Y
1,2,3,4,7,8,9-HpCDF	M+2/M+4	1.04	0.88 - 1.20	Y	49.6	40 - 60	Y
OCDF	M+2/M+4	0.91	0.76 - 1.02	Y	100	80 - 120	Y

1-256

METHOD 23

PCDD/F CALIBRATION VERIFICATION

FORM 4B

Lab Name:

Analytical Perspectives

Initial Calibration:

ICAL: MM1_DF_122509

Instrument ID:

MM1

GC Column ID:

ZB-5ms

VER Data Filename:

100409P1-10

Analysis Date:

09-APR-2010 15:00:55

LABELLED ANALYTES	M/Z's FORMING RATIO	ION ABUND. RATIO	QC LIMITS	OK	CONC. FOUND	RANGE (ng/mL)	OK
13C-2,3,7,8-TCDD	M/M+2	0.79	0.65 - 0.89	Y	99.9	70 - 130	Y
13C-1,2,3,7,8-PeCDD	M+2/M+4	1.59	1.32 - 1.78	Y	99.3	70 - 130	Y
13C-1,2,3,4,7,8-HxCDD	M+2/M+4	1.28	1.05 - 1.43	Y	98.3	70 - 130	Y
13C-1,2,3,6,7,8-HxCDD	M+2/M+4	1.27	1.05 - 1.43	Y	95.2	70 - 130	Y
13C-1,2,3,7,8,9-HxCDD	M+2/M+4	1.25	1.05 - 1.43	Y	95.4	70 - 130	Y
13C-1,2,3,4,6,7,8-HpCDD	M+2/M+4	1.06	0.88 - 1.20	Y	99.3	70 - 130	Y
13C-OCDD	M+2/M+4	0.88	0.76 - 1.02	Y	192	140 - 260	Y
13C-2,3,7,8-TCDF	M/M+2	0.80	0.65 - 0.89	Y	100	70 - 130	Y
13C-1,2,3,7,8-PeCDF	M+2/M+4	1.57	1.32 - 1.78	Y	98.1	70 - 130	Y
13C-2,3,4,7,8-PeCDF	M+2/M+4	1.55	1.32 - 1.78	Y	98.4	70 - 130	Y
13C-1,2,3,4,7,8-HxCDF	M/M+2	0.52	0.43 - 0.59	Y	97	70 - 130	Y
13C-1,2,3,6,7,8-HxCDF	M/M+2	0.51	0.43 - 0.59	Y	97.3	70 - 130	Y
13C-2,3,4,6,7,8-HxCDF	M/M+2	0.51	0.43 - 0.59	Y	96.6	70 - 130	Y
13C-1,2,3,7,8,9-HxCDF	M/M+2	0.53	0.43 - 0.59	Y	97.3	70 - 130	Y
13C-1,2,3,4,6,7,8-HpCDF	M/M+2	0.45	0.37 - 0.51	Y	96.4	70 - 130	Y
13C-1,2,3,4,7,8,9-HpCDF	M/M+2	0.45	0.37 - 0.51	Y	97.7	70 - 130	Y
13C-OCDF	M+2/M+4	0.89	0.76 - 1.02	Y	195	140 - 260	Y
SURROGATE STANDARDS							
37Cl-2,3,7,8-TCDD	n/a				40.4	28 - 52	Y
13C-1,2,3,4,7-PeCDD	M+2/M+4	1.62	1.32 - 1.78	Y	100	70 - 130	Y
13C-1,2,3,4,6-PeCDF	M+2/M+4	1.55	1.32 - 1.78	Y	101	70 - 130	Y
13C-1,2,3,4,6,9-HxCDF	M/M+2	0.51	0.43 - 0.59	Y	98.8	70 - 130	Y
13C-1,2,3,4,6,8,9-HpCDF	M/M+2	0.45	0.37 - 0.51	Y	101	70 - 130	Y



Processed: 09 Apr 2010 15:52

Analyst: MC

AP Lab ID: BCS3_7679_DF_PB
Instr: AutoSpec-Ultima MM1

Sample ID: BCS3_7679_DF_PB
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 46

Acq: 9-APR-2010 15:00:55
User: MC Datafile: 100409P1-10




1-258


AP Lab ID: BCS3_7679_DF_PB
Instr: AutoSpec-Ultima MM1

Sample ID: BCS3_7679_DF_PB
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 46

Acq: 9-APR-2010 15:00:55
User: MC Datafile: 100409P1-10



I - 259








Results: P:\VP2000_P2099\VP2096\VP2096_7679_DF\Resources\BCS3_7679_DF_PB.utp_res, saved 09-Apr-2010 15:51 (MC)
AP UltraTrace-Pro V4.21 User/System: MC/MC17-047

Peak annotation: Areas, Centroids
Revised: 09-Apr-2010 15:50:24 (MC) Printed: 09-Apr-2010 15:59:11

AP Lab ID: BCS3_7679_DF_PB
Instr: AutoSpec-Ultima MM1

Sample ID: BCS3_7679_DF_PB
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 46






Acq: 9-APR-2010 15:00:55
User: MC Datafile: 100409P1-10



AP Lab ID: BCS3_7679_DF_PB
Instr: AutoSpec-Ultima MM1

Sample ID: BCS3_7679_DF_PB
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 46

Acq: 9-APR-2010 15:00:55
User: MC Datafile: 100409P1-10








1 - 261

AP Lab ID: BCS3_7679_DF_PB
Instr: AutoSpec-Ultima MM1

Sample ID: BCS3_7679_DF_PB
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 46

Acq: 9-APR-2010 15:00:55
User: MC Datafile: 100409P1-10








1-262

AP Lab ID: BCS3_7679_DF_PB
Instr: AutoSpec-Ultima MM1

Sample ID: BCS3_7679_DF_PB
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 46

Acq: 9-APR-2010 15:00:55
User: MC Datafile: 100409P1-10








1-263

AP Lab ID: BCS3_7679_DF_PB
Instr: AutoSpec-Ultima MM1

Sample ID: BCS3_7679_DF_PB
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 46






Acq: 9-APR-2010 15:00:55
User: MC Datafile: 100409P1-10



AP Lab ID: BCS3_7679_DF_PB
Instr: AutoSpec-Ultima MM1

Sample ID: BCS3_7679_DF_PB
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 46

Acq: 9-APR-2010 15:00:55
User: MC Datafile: 100409P1-10








1 - 265

AP Lab ID: BCS3_7679_DF_PB
Instr: AutoSpec-Ultima MM1

Sample ID: BCS3_7679_DF_PB
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 46

Acq: 9-APR-2010 15:00:55
User: MC Datafile: 100409P1-10






Results: P:\P2000_P2099VP2096P2096_7679 DFResources\BCS3_7679_DF_PB.utp_res, saved 09-Apr-2010 15:51 (MC)
AP UltraTrace-Pro V4.21 User/System: MC/MC17-047 cc: 9824, 8117, 9989 scc: 559-021

Peak annotation: Areas, Centroids
Revised: 09-Apr-2010 15:50:24 (MC) Printed: 09-Apr-2010 16:14:35 Page 7 of 12

AP Lab ID: BCS3_7679_DF_PB
Instr: AutoSpec-Ultima MM1

Sample ID: BCS3_7679_DF_PB
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 46

Acq: 9-APR-2010 15:00:55
User: MC Datafile: 100409P1-10








1 - 267

AP Lab ID: BCS3_7679_DF_PB
Instr: AutoSpec-Ultima MM1

Sample ID: BCS3_7679_DF_PB
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 46

Acq: 9-APR-2010 15:00:55
User: MC Datafile: 100409P1-10








1-268

AP Lab ID: BCS3_7679_DF_PB
Instr: AutoSpec-Ultima MM1

Sample ID: BCS3_7679_DF_PB
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 46

Acq: 9-APR-2010 15:00:55
User: MC Datafile: 100409P1-10








1-269

AP Lab ID: BCS3_7679_DF_PB
Instr: AutoSpec-Ultima MM1

Sample ID: BCS3_7679_DF_PB
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 46

Acq: 9-APR-2010 15:00:55
User: MC Datafile: 100409P1-10








1-270

AP Lab ID: BCS3_7679_DF_PB
Instr: AutoSpec-Ultima MM1

Sample ID: BCS3_7679_DF_PB
SIR expt: DF_CL4-8A .GC: DB5MS_60M Vial: 46

Acq: 9-APR-2010 15:00:55
User: MC Datafile: 100409P1-10



1-271

This Page Intentionally Left Blank

P2096



ANALYTICAL PERSPECTIVES

PART 4D

SYSTEM PERFORMANCE

“INITIAL CALIBRATION”

**DOCUMENTATION FOR THE ANALYSIS
OF**

POLYCHLORINATED DIBENZO-*p*-DIOXINS & DIBENZOFURANS

This Page Intentionally Left Blank

Dioxin/Furan ICAL Summary

Analytical Perspectives

Processed: 26 Dec 2009 09:12

ICAL: MM1_ical_122509
Data Acquired: 25-Dec-2009

Name	Mean	% RSD	091225P1-01	091225P1-02	091225P1-03	091225P1-04	091225P1-05	091225P1-06	091225P1-07
			0.25 CS0	0.5 CS1	2.0 CS2	10 CS3	40 CS4	200 CS5	500 CS6
2378-TCDD	1.23	5.3%	1.36	1.17	1.19	1.17	1.24	1.23	1.23
12378-PeCDD	1.14	3.9%	1.22	1.13	1.07	1.12	1.14	1.14	1.15
123478-HxCDD	1.19	3.6%	1.10	1.21	1.18	1.23	1.21	1.22	1.21
123678-HxCDD	1.09	4.5%	1.19	1.11	1.06	1.05	1.08	1.07	1.07
123789-HxCDD	1.08	1.3%	1.10	1.06	1.07	1.07	1.09	1.09	1.08
1234678-HpCDD	1.04	4.6%	0.94	1.06	1.02	1.05	1.06	1.09	1.05
OCDD	1.10	4.2%	1.19	1.07	1.07	1.05	1.09	1.08	1.12
2378-TCDF	1.13	2.9%	1.18	1.16	1.11	1.08	1.11	1.12	1.13
12378-PeCDF	1.16	2.1%	1.21	1.14	1.14	1.14	1.18	1.17	1.16
23478-PeCDF	1.13	1.7%	1.12	1.15	1.11	1.11	1.16	1.15	1.14
123478-HxCDF	1.26	2.7%	1.21	1.26	1.23	1.25	1.31	1.26	1.28
123678-HxCDF	1.25	2.8%	1.33	1.22	1.24	1.24	1.25	1.25	1.25
234678-HxCDF	1.18	2.9%	1.12	1.22	1.15	1.19	1.21	1.18	1.19
123789-HxCDF	1.20	2.9%	1.17	1.24	1.15	1.17	1.23	1.22	1.22
1234678-HpCDF	1.39	2.8%	1.39	1.31	1.39	1.41	1.41	1.40	1.42
1234789-HpCDF	1.42	2.4%	1.45	1.38	1.38	1.41	1.46	1.45	1.42
OCDF	1.01	1.8%	1.02	1.00	0.98	1.02	1.01	1.03	1.03
ES 2378-TCDD	1.04	1.8%	1.04	1.02	1.02	1.05	1.04	1.06	1.07
ES 12378-PeCDD	0.96	4.2%	0.97	0.94	0.92	0.91	0.93	0.99	1.03
ES 123478-HxCDD	1.01	7.0%	1.01	0.94	0.99	0.93	1.04	1.01	1.14
ES 123678-HxCDD	1.14	6.2%	1.13	1.09	1.10	1.05	1.17	1.14	1.27
ES 123789-HxCDD	1.14	6.7%	1.14	1.07	1.13	1.06	1.17	1.13	1.29
ES 1234678-HpCDD	0.98	7.1%	0.98	0.91	0.98	0.92	0.99	0.96	1.12
ES OCDD	0.76	8.1%	0.75	0.73	0.72	0.70	0.76	0.79	0.89
ES 2378-TCDF	0.94	1.7%	0.94	0.92	0.91	0.94	0.94	0.95	0.95
ES 12378-PeCDF	0.95	3.8%	0.96	0.91	0.91	0.93	0.93	0.98	1.00
ES 23478-PeCDF	0.90	3.5%	0.91	0.88	0.87	0.88	0.87	0.93	0.95
ES 123478-HxCDF	1.50	4.4%	1.50	1.42	1.51	1.42	1.50	1.49	1.62
ES 123678-HxCDF	1.63	5.6%	1.61	1.54	1.62	1.53	1.66	1.63	1.81
ES 234678-HxCDF	1.50	5.5%	1.49	1.43	1.50	1.40	1.53	1.49	1.66
ES 123789-HxCDF	1.32	7.0%	1.42	1.24	1.27	1.22	1.32	1.31	1.47
ES 1234678-HpCDF	1.11	5.7%	1.11	1.07	1.11	1.03	1.12	1.13	1.23
ES 1234789-HpCDF	0.92	7.6%	0.90	0.86	0.92	0.85	0.91	0.91	1.06
ES OCDF	1.07	10.9%	1.04	0.99	1.00	0.96	1.09	1.11	1.31

1-275

Dioxin/Furan ICAL Summary

Analytical Perspectives

Processed: 26 Dec 2009 09:12

ICAL: MM1_ical_122509
Data Acquired: 18-Jun-2009

Name	Mean	% RSD	091225P1-01	091225P1-02	091225P1-03	091225P1-04	091225P1-05	091225P1-06	091225P1-07
			0.25 CS0	0.5 CS1	2.0 CS2	10 CS3	40 CS4	200 CS5	500 CS6
CS 37C1-2378-TCDD	1.11	6.6%	-	1.03	1.03	1.15	1.17	1.18	-
CS 12347-PeCDD	1.03	2.3%	1.08	1.05	1.03	1.01	1.02	1.03	1.02
CS 12346-PeCDF	0.92	1.6%	0.95	0.91	0.92	0.91	0.91	0.93	0.91
CS 123469-HxCDF	1.31	3.9%	1.34	1.29	1.35	1.28	1.37	1.22	1.31
CS 1234689-HpCDF	0.91	3.9%	0.92	0.94	0.93	0.86	0.94	0.85	0.89
SS 37C1-2378-TCDD	1.07	5.2%	-	1.01	1.01	1.09	1.13	1.11	-
SS 12347-PeCDD	1.08	4.5%	1.11	1.12	1.11	1.11	1.10	1.04	0.99
SS 12346-PeCDF	0.97	3.6%	0.99	1.00	1.01	0.98	0.98	0.95	0.91
SS 123469-HxCDF	0.81	5.7%	0.83	0.83	0.84	0.84	0.83	0.75	0.73
SS 1234689-HpCDF	0.81	6.6%	0.83	0.88	0.84	0.84	0.83	0.76	0.72
AS 1368-TCDD	1.09	-	-	-	-	1.09	-	-	-
AS 1368-TCDF	1.12	-	-	-	-	1.12	-	-	-
OCDD-a	0.07	5.3%	-	-	-	0.06	0.07	0.07	0.07
OCDF-a	0.06	2.2%	-	-	-	0.06	0.06	0.06	0.06
Totals									
Total TCDD	1.23	5.3%	1.36	1.17	1.19	1.17	1.24	1.23	1.23
Total PeCDD	1.14	3.9%	1.22	1.13	1.07	1.12	1.14	1.14	1.15
Total HxCDD	1.12	0.8%	1.13	1.13	1.10	1.12	1.13	1.13	1.12
Total HpCDD	1.04	4.6%	0.94	1.06	1.02	1.05	1.06	1.09	1.05
Total TCDF	1.13	2.9%	1.18	1.16	1.11	1.08	1.11	1.12	1.13
Total PeCDF	1.15	1.4%	1.16	1.15	1.13	1.13	1.17	1.16	1.15
Total HxCDF	1.22	1.6%	1.21	1.23	1.19	1.21	1.25	1.23	1.24
Total HpCDF	1.41	2.3%	1.42	1.34	1.39	1.41	1.44	1.43	1.42

1-276

P2096



ANALYTICAL PERSPECTIVES

PART 4E

SYSTEM PERFORMANCE

“AUDIT SAMPLE”

DOCUMENTATION FOR THE ANALYSIS
OF
POLYCHLORINATED DIBENZO-*p*-DIOXINS & DIBENZOFURANS

This Page Intentionally Left Blank

Lab ID: P2096_7679_006

Client ID: M23-4435-01-Audit

Datafile: 100409P1-09

Acq'd: 09 Apr 2010 14:10 MC

UTP: 09-Apr-2010 15:51 MC

Report: 09 Apr 2010 15:55 MC

Wt/Vol: 1

J-level: 10 pg

ES spike: 4000 pg

Cal: BCS3_7679_DF_PAB

Checkcode: 025-176

Split: 2

Name	Act RT	QC	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Conc.	Noise	DL
2378-TCDD	26.88		1.0008	1.0009	+0.2	1.30E+06	0.80	Y	0.99	152	1096	1.39
12378-PeCDD	32.49		1.0006	1.0006	0	9.95E+05	1.58	Y	0.93	150	1272	1.67
123478-HxCDD	36.44		1.0004	1.0004	0	9.39E+05	1.16	Y	1.04	146	1419	2.08
123678-HxCDD	36.55		1.0034	1.0034	0	9.10E+05	1.27	Y	0.95	140	1419	2.16
123789-HxCDD	36.84		1.0116	1.0115	-0.2	1.00E+06	1.23	Y	0.93	150	1419	2.16
1234678-HpCDD	40.04		1.0003	1.0004	+0.2	8.15E+05	1.05	Y	0.96	140	1126	2.09
OCDD	43.54		1.0004	1.0003	-0.3	1.40E+06	0.88	Y	1.00	291	1243	3.53

2378-TCDF	25.94		1.0009	1.0009	0	2.33E+06	0.78	Y	1.08	172	1224	0.989
12378-PeCDF	30.98		1.0006	1.0006	0	1.42E+06	1.54	Y	1.00	142	1189	1.08
23478-PeCDF	32.12		1.0005	1.0005	0	2.93E+06	1.53	Y	1.04	284	1189	1.01
123478-HxCDF	35.47		1.0004	1.0005	+0.2	1.68E+06	1.25	Y	1.14	195	1718	1.83
123678-HxCDF	35.61		1.0005	1.0005	0	1.87E+06	1.20	Y	1.13	195	1718	1.7
234678-HxCDF	36.26		1.0005	1.0005	0	1.66E+06	1.24	Y	1.14	180	1718	1.86
123789-HxCDF	37.23		1.0005	1.0008	+0.7	2.19E+06	1.24	Y	1.12	283	1718	2.29
1234678-HpCDF	38.89		1.0003	1.0003	0	1.09E+06	1.00	Y	1.38	132	1383	1.72
1234789-HpCDF	40.60		1.0003	1.0003	0	6.47E+05	1.05	Y	1.33	92.9	1383	2.25
OCDF	43.78		1.0004	1.0003	-0.3	1.65E+06	0.93	Y	0.96	284	1205	2.75

Name	Act RT	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Rec. %
ES 2378-TCDD	26.85	1.0259	1.0259	0	3.46E+07	0.79	Y	1.01	81.6
ES 12378-PeCDD	32.47	1.2404	1.2403	-0.2	2.84E+07	1.63	Y	0.78	86.6
ES 123478-HxCDD	36.43	0.9917	0.9917	0	2.46E+07	1.27	Y	0.99	89.4
ES 123678-HxCDD	36.54	0.9947	0.9947	0	2.74E+07	1.26	Y	1.07	92.3
ES 123789-HxCDD	36.83	1.0028	1.0028	0	2.87E+07	1.22	Y	1.09	94.5
ES 1234678-HpCDD	40.02	1.0902	1.0896	-1.3	2.41E+07	1.07	Y	0.90	96.3
ES OCDD	43.53	1.1862	1.1850	-2.6	3.84E+07	0.92	Y	0.74	93.7

ES 2378-TCDF	25.92	1.0585	1.0586	+0.1	5.01E+07	0.80	Y	1.00	83.6
ES 12378-PeCDF	30.96	1.2646	1.2647	+0.1	3.99E+07	1.57	Y	0.75	88.5
ES 23478-PeCDF	32.11	1.3113	1.3114	+0.1	3.95E+07	1.57	Y	0.74	88.5
ES 123478-HxCDF	35.45	0.9651	0.9651	0	3.01E+07	0.52	Y	1.19	91.2
ES 123678-HxCDF	35.59	0.9689	0.9690	+0.2	3.38E+07	0.51	Y	1.35	90.4
ES 234678-HxCDF	36.24	0.9867	0.9867	0	3.23E+07	0.52	Y	1.28	90.8
ES 123789-HxCDF	37.20	1.0129	1.0128	-0.2	2.76E+07	0.52	Y	1.20	83.1
ES 1234678-HpCDF	38.88	1.0589	1.0585	-0.9	2.40E+07	0.45	Y	0.95	91.3
ES 1234789-HpCDF	40.59	1.1057	1.1049	-1.8	2.09E+07	0.42	Y	0.82	92.4
ES OCDF	43.76	1.1926	1.1914	-2.6	4.83E+07	0.89	Y	0.96	90.9

Lab ID: P2096_7679_006

Client ID: M23-4435-01-Audit

Datafile: 100409P1-09

Acq'd: 09 Apr 2010 14:10 MC

UTP: 09-Apr-2010 15:51 MC

Report: 09 Apr 2010 15:55 MC

Wt/Vol: 1

J-level: 10 pg

ES spike: 4000 pg

Cal: BCS3_7679_DF_PAB

Checkcode: 025-176

Split: 2

Name	Act RT	QC	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Rec. %
JS 1234-TCDD	26.18		-	-	-	4.20E+07	0.81	Y	-	-
JS 1234-TCDF	24.48		-	-	-	6.01E+07	0.80	Y	-	-
JS 123467-HxCDD	36.73		-	-	-	1.39E+07	1.42	Y	-	-
CS 37C1-2378-TCDD	NotFnd		1.0268				n/a	-		
CS 12347-PeCDD	NotFnd		1.2209							
CS 12346-PeCDF	NotFnd		1.2424							
CS 123469-HxCDF	NotFnd		0.9773							
CS 1234689-HpCDF	NotFnd		1.0720							
SS 37C1-2378-TCDD	NotFnd		1.0268				n/a	-		
SS 12347-PeCDD	NotFnd		1.2209							
SS 12346-PeCDF	NotFnd		1.2424							
SS 123469-HxCDF	NotFnd		0.9773							
SS 1234689-HpCDF	NotFnd		1.0720							
AS 1368-TCDD	22.90		0.8731	0.8747	+2.5	3.48E+07	0.81	Y	1.08	76.7
AS 1368-TCDF	20.75		0.8447	0.8474	+4.0	5.83E+07	0.79	Y	1.29	75.1
FS 1278-TCDD	NotFnd		1.0131							
FS 12478-PeCDD	NotFnd		0.9617							
FS 123468-HxCDD	NotFnd		0.9713							
FS 1234679-HpCDD	39.2		0.9794	0.9795	+0.2	1.79E+05	1.26	N	0.01	96
TS 1378-TCDD	NotFnd		0.9345							

FS na
KAM 12 Apr 10

Totals	Conc	EMPC
Total TCDD	347	347
Total PeCDD	358	358
Total HxCDD	647	647
Total HpCDD	240	240
Total Tetra-Octa Dioxins	1880	1880
Total TCDF	357	357
Total PeCDF	618	618
Total HxCDF	959	959
Total HpCDF	309	309
Total Tetra-Octa Furans	2530	2530
Total Tetra-Octa Dioxins & Furans	4410	4410

Lab ID: P2096_7679_006

Client ID: M23-4435-01-Audit

Datafile: 100409P1-09

Acq'd: 09 Apr 2010 14:10 MC

UTP: 09-Apr-2010 15:51 MC

Report: 09 Apr 2010 15:55 MC

Wt/Vol: 1

J-level: 10 pg

ES spike: 4000 pg

Cal: BCS3_7679_DF_PAB

Checkcode: 025-176

Split: 2

Name	Act RT	QC	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Conc.	Noise	DL
1368-TCDD	22.93		0.8539	0.8538	-0.2	7.78E+05	0.77	Y	0.99	90.5	1096	1.39
1379-TCDD	NotFnd		0.8685						0.99		1096	1.39
1369-TCDD	NotFnd		0.8863						0.99		1096	1.39
1469-TCDD	NotFnd		0.9189						0.99		1096	1.39
1247/1246/1248/1249-TCDD	NotFnd		0.9276						0.99		1096	1.39
1378-TCDD	NotFnd		0.9351						0.99		1096	1.39
1268-TCDD	NotFnd		0.9430						0.99		1096	1.39
1478-TCDD	NotFnd		0.9517						0.99		1096	1.39
1279-TCDD	NotFnd		0.9598						0.99		1096	1.39
1234/1269-TCDD	NotFnd		0.9740						0.99		1096	1.39
1236-TCDD	NotFnd		0.9801						0.99		1096	1.39
1237/1238-TCDD	NotFnd		0.9895						0.99		1096	1.39
1239-TCDD	NotFnd		0.9952						0.99		1096	1.39
2378-TCDD	26.88		1.0008	1.0009	+0.2	1.30E+06	0.80	Y	0.99	152	1096	1.39
1278-TCDD	NotFnd		1.0138						0.99		1096	1.39
1267-TCDD	NotFnd		1.0194						0.99		1096	1.39
1289-TCDD	27.92		1.0396	1.0397	+0.2	9.01E+05	0.77	Y	0.99	105	1096	1.39
12479/12468-PeCDD	29.91		0.9210	0.9213	+0.6	6.95E+05	1.51	Y	0.93	105	1272	1.67
12469-PeCDD	NotFnd		0.9382						0.93		1272	1.67
12368-PeCDD	NotFnd		0.9556						0.93		1272	1.67
12478-PeCDD	NotFnd		0.9614						0.93		1272	1.67
12379-PeCDD	NotFnd		0.9649						0.93		1272	1.67
12369/12467/12489-PeCDD	NotFnd		0.9732						0.93		1272	1.67
12346/12347-PeCDD	NotFnd		0.9850						0.93		1272	1.67
12378-PeCDD	32.49		1.0006	1.0006	0	9.95E+05	1.58	Y	0.93	150	1272	1.67
12367-PeCDD	NotFnd		1.0037						0.93		1272	1.67
12389-PeCDD	32.94		1.0146	1.0146	0	6.79E+05	1.58	Y	0.93	102	1272	1.67
124679/124689-HxCDD	34.74		0.9534	0.9536	+0.4	7.60E+05	1.27	Y	0.97	116	1419	2.13
123468-HxCDD	NotFnd		0.9717						0.97		1419	2.13
123679/123689-HxCDD	NotFnd		0.9793						0.97		1419	2.13
123469-HxCDD	NotFnd		0.9833						0.97		1419	2.13
123478-HxCDD	36.44		1.0004	1.0004	0	9.39E+05	1.16	Y	1.04	146	1419	2.08
123678-HxCDD	36.55		1.0034	1.0034	0	9.10E+05	1.27	Y	0.95	140	1419	2.16
123467-HxCDD	36.75		1.0088	1.0088	0	6.11E+05	1.19	Y	0.97	93.5	1419	2.13
123789-HxCDD	36.84		1.0116	1.0115	-0.2	1.00E+06	1.23	Y	0.93	150	1419	2.16

1-281

Lab ID: P2096_7679_006

Client ID: M23-4435-01-Audit

Datafile: 100409P1-09

Acq'd: 09 Apr 2010 14:10 MC

UTP: 09-Apr-2010 15:51 MC

Report: 09 Apr 2010 15:55 MC

Wt/Vol: 1

J-level: 10 pg

ES spike: 4000 pg

Cal: BCS3_7679_DF_PAB

Checkcode: 025-176

Split: 2

Name	Act RT	QC	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Conc.	Noise	DL
1234679-HpCDD	39.21		0.9794	0.9796	+0.5	5.81E+05	1.10	Y	0.96	100	1126	2.09
1234678-HpCDD	40.04		1.0003	1.0004	+0.2	8.15E+05	1.05	Y	0.96	140	1126	2.09
OCDD	43.54		1.0004	1.0003	-0.3	1.40E+06	0.88	Y	1.00	291	1243	3.53
OCDD-a	NotFnd		1.0003						0.06		1481	69
1368-TCDF	20.77		0.8012	0.8015	+0.5	1.29E+06	0.80	Y	1.08	95.2	1224	0.989
1468-TCDF	NotFnd		0.8216						1.08		1224	0.989
2468-TCDF	NotFnd		0.8461						1.08		1224	0.989
1346/1246-TCDF	NotFnd		0.8607						1.08		1224	0.989
1347/1378/1247-TCDF	NotFnd		0.8672						1.08		1224	0.989
1348-TCDF	NotFnd		0.8792						1.08		1224	0.989
1248/1367/1379-TCDF	NotFnd		0.8846						1.08		1224	0.989
1268-TCDF	NotFnd		0.9011						1.08		1224	0.989
1467-TCDF	NotFnd		0.9067						1.08		1224	0.989
1478-TCDF	NotFnd		0.9137						1.08		1224	0.989
1369/1237-TCDF	NotFnd		0.9293						1.08		1224	0.989
2467-TCDF	NotFnd		0.9348						1.08		1224	0.989
2368-TCDF	NotFnd		0.9408						1.08		1224	0.989
1238/1234/1678/1469/1236-TCDF	NotFnd		0.9445						1.08		1224	0.989
1278-TCDF	NotFnd		0.9641						1.08		1224	0.989
1349-TCDF	NotFnd		0.9693						1.08		1224	0.989
1267-TCDF	NotFnd		0.9755						1.08		1224	0.989
2346/1249-TCDF	NotFnd		0.9834						1.08		1224	0.989
2347/1279-TCDF	NotFnd		0.9922						1.08		1224	0.989
2348-TCDF	NotFnd		0.9966						1.08		1224	0.989
2378-TCDF	25.94		1.0009	1.0009	0	2.33E+06	0.78	Y	1.08	172	1224	0.989
2367/3467-TCDF	NotFnd		1.0164						1.08		1224	0.989
1269-TCDF	NotFnd		1.0260						1.08		1224	0.989
1239-TCDF	NotFnd		1.0375						1.08		1224	0.989
1289-TCDF	28.09		1.0834	1.0838	+0.6	1.21E+06	0.77	Y	1.08	89.4	1224	0.989
13468/12468-PeCDF	28.06		0.9057	0.9061	+0.7	1.10E+06	1.72	Y	1.02	109	1477	1.3
13678/13467/12467-PeCDF	NotFnd		0.9581						1.02		1189	1.04
12368/13478/12478-PeCDF	NotFnd		0.9620						1.02		1189	1.04
14678-PeCDF	NotFnd		0.9667						1.02		1189	1.04
13479-PeCDF	NotFnd		0.9702						1.02		1189	1.04
13469/12479-PeCDF	NotFnd		0.9781						1.02		1189	1.04
12346-PeCDF	NotFnd		0.9829						1.02		1189	1.04

Lab ID: P2096_7679_006
 Client ID: M23-4435-01-Audit
 Datafile: 100409P1-09

Acq'd: 09 Apr 2010 14:10 MC
 UTP: 09-Apr-2010 15:51 MC
 Report: 09 Apr 2010 15:55 MC

Wt/Vol: 1
 J-level: 10 pg
 ES spike: 4000 pg

Cal: BCS3_7679_DF_PAB
 Checkcode: 025-176
 Split: 2






Name	Act RT	QC	Pred. RRT	Act. RRT	ΔSecs	Response	Ra	OK	RRF	Conc.	Noise	DL
23468/12469-PeCDF	NotFnd		0.9858						1.02		1189	1.04
12347-PeCDF	NotFnd		0.9881						1.02		1189	1.04
12348-PeCDF	NotFnd		0.9936						1.02		1189	1.04
12378-PeCDF	30.98		1.0006	1.0006	0	1.42E+06	1.54	Y	1.00	142	1189	1.08
12678/12367-PeCDF	NotFnd		1.0104						1.02		1189	1.04
12379-PeCDF	NotFnd		1.0151						1.02		1189	1.04
12679-PeCDF	NotFnd		0.9925						1.02		1189	1.04
23467/12369-PeCDF	NotFnd		0.9981						1.02		1189	1.04
23478-PeCDF	32.12		1.0005	1.0005	0	2.93E+06	1.53	Y	1.04	284	1189	1.01
23478/12489-PeCDF	NotFnd		1.0006						1.04		1189	1.01
12489-PeCDF	NotFnd		1.0023						1.02		1189	1.04
12349-PeCDF	NotFnd		1.0110						1.02		1189	1.04
12389-PeCDF	33.23		1.0350	1.0350	0	8.43E+05	1.61	Y	1.02	83	1189	1.04
123468-HxCDF	34.07		0.9609	0.9611	+0.4	9.23E+05	1.27	Y	1.13	105	1718	1.9
124678/134678-HxCDF	NotFnd		0.9668						1.13		1718	1.9
134679-HxCDF	NotFnd		0.9733						1.13		1718	1.9
124679-HxCDF	NotFnd		0.9788						1.13		1718	1.9
124689-HxCDF	NotFnd		0.9851						1.13		1718	1.9
123467-HxCDF	NotFnd		0.9968						1.13		1718	1.9
123478-HxCDF	35.47		1.0004	1.0005	+0.2	1.68E+06	1.25	Y	1.14	195	1718	1.83
123678-HxCDF	35.61		1.0005	1.0005	0	1.87E+06	1.20	Y	1.13	195	1718	1.7
123479-HxCDF	NotFnd		1.0048						1.13		1718	1.9
123469-HxCDF	NotFnd		1.0090						1.13		1718	1.9
123679-HxCDF	NotFnd		0.9943						1.13		1718	1.9
234678-HxCDF	36.26		1.0005	1.0005	0	1.66E+06	1.24	Y	1.14	180	1718	1.86
234678/123689-HxCDF	NotFnd		1.0004						1.14		1718	1.86
123689-HxCDF	NotFnd		1.0009						1.13		1718	1.9
123789-HxCDF	37.23		1.0005	1.0008	+0.7	2.19E+06	1.24	Y	1.12	283	1718	2.29
123789/123489-HxCDF	NotFnd		1.0012						1.12		1718	2.29
123489-HxCDF	NotFnd		1.0017						1.13		1718	1.9
1234678-HpCDF	38.89		1.0003	1.0003	0	1.09E+06	1.00	Y	1.38	132	1383	1.72
1234679-HpCDF	NotFnd		1.0083						1.36		1383	1.97
1234689-HpCDF	39.37		1.0132	1.0127	-1.2	6.43E+05	1.01	Y	1.36	84.5	1383	1.97
1234789-HpCDF	40.60		1.0003	1.0003	0	6.47E+05	1.05	Y	1.33	92.9	1383	2.25
OCDF	43.78		1.0004	1.0003	-0.3	1.65E+06	0.93	Y	0.96	284	1205	2.75
OCDF-a	43.77		1.0002	1.0001	-0.3	3.30E+04	5.01	N	0.05	99.4	1474	59.1

1 - 283

AP Lab ID: P2096_7679_006
Instr: AutoSpec-Ultima MM1

Sample ID: M23-4435-01-Audit
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 53

Acq: 9-APR-2010 14:10:25
User: MC Datafile: 100409P1-09








I - 284

AP Lab ID: P2096_7679_006
Instr: AutoSpec-Ultima MM1

Sample ID: M23-4435-01-Audit
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 53

Acq: 9-APR-2010 14:10:25
User: MC Datafile: 100409P1-09








1 - 285

AP Lab ID: P2096_7679_006
Instr: AutoSpec-Ultima MM1

Sample ID: M23-4435-01-Audit
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 53

Acq: 9-APR-2010 14:10:25
User: MC Datafile: 100409P1-09








1-286

AP Lab ID: P2096_7679_006
Instr: AutoSpec-Ultima MM1

Sample ID: M23-4435-01-Audit
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 53

Acq: 9-APR-2010 14:10:25
User: MC Datafile: 100409P1-09




1 - 287

AP Lab ID: P2096_7679_006
Instr: AutoSpec-Ultima MM1

Sample ID: M23-4435-01-Audit
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 53

Acq: 9-APR-2010 14:10:25
User: MC Datafile: 100409P1-09




1-288

AP Lab ID: P2096_7679_006
Instr: AutoSpec-Ultima MM1

Sample ID: M23-4435-01-Audit
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 53

Acq: 9-APR-2010 14:10:25
User: MC Datafile: 100409P1-09








1 - 289

AP Lab ID: P2096_7679_006
Instr: AutoSpec-Ultima MM1

Sample ID: M23-4435-01-Audit
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 53

Acq: 9-APR-2010 14:10:25
User: MC Datafile: 100409P1-09






1 - 290

AP Lab ID: P2096_7679_006
Instr: AutoSpec-Ultima MM1

Sample ID: M23-4435-01-Audit
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 53

Acq: 9-APR-2010 14:10:25
User: MC Datafile: 100409P1-09




I - 291

AP Lab ID: P2096_7679_006
Instr: AutoSpec-Ultima MM1

Sample ID: M23-4435-01-Audit
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 53

Acq: 9-APR-2010 14:10:25
User: MC Datafile: 100409P1-09








1-292

AP Lab ID: P2096_7679_006
Instr: AutoSpec-Ultima MM1

Sample ID: M23-4435-01-Audit
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 53

Acq: 9-APR-2010 14:10:25
User: MC Datafile: 100409P1-09








1 - 293

AP Lab ID: P2096_7679_006
Instr: AutoSpec-Ultima MM1

Sample ID: M23-4435-01-Audit
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 53

Acq: 9-APR-2010 14:10:25
User: MC Datafile: 100409P1-09








I - 294

AP Lab ID: P2096_7679_006
Instr: AutoSpec-Ultima MM1

Sample ID: M23-4435-01-Audit
SIR expt: DF_CL4-8A GC: DB5MS_60M Vial: 53

Acq: 9-APR-2010 14:10:25
User: MC Datafile: 100409P1-09



1 - 295

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10955
 Unit 1 SDA Inlet

USEPA Method 26A Chloride Laboratory Data Summary

Run No.	Blank	1	2	3
Date (2010)		Mar 18	Mar 18	Mar 18
Start Time (approx.)		07:02	09:26	11:49
Stop Time (approx.)		08:02	10:37	12:49

DRAFT LAB DATA

MDL Min. detectable limit (mg Cl⁻/liter)

HCl as Total Chloride

B_{Cl} Blank concentration (mg Cl⁻/liter)

S _{Cl-1}	Fraction 1 concentration (mg Cl ⁻ /liter)	917.4200	1066.7800	920.9000	
S _{Cl-2}	Fraction 2 concentration (mg Cl ⁻ /liter)				
v ₁	Fraction 1 sample volume (ml)	837.0	802.0	700.0	
v ₂	Fraction 2 sample volume (ml)				
m _{HCl}	HCl collected before blank subtraction (mg)	789.3812	879.5132	662.6796	
m _b	Allowable blank subtraction (mg)	0.0000	0.0000	0.0000	
m _{nb}	HCl collected after blank subtraction (mg)	789.3812	879.5132	662.6796	
m _{MDL}	Minimum detectable HCl (mg)	0.0129	0.0124	0.0108	
m _n	Total HCl used in emission calculations (mg)	789.3812	879.5132	662.6796	

042210 100819
 @

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10955
 Unit 1 FF Outlet

USEPA Method 26A Chloride Laboratory Data Summary

Run No.	Blank	1	2	3
Date (2010)		Mar 18	Mar 18	Mar 18
Start Time (approx.)		07:02	09:26	11:49
Stop Time (approx.)		08:02	10:37	12:49

DRAFT LAB DATA

MDL Min. detectable limit (mg Cl⁻/liter)

HCl as Total Chloride

B_{Cl} Blank concentration (mg Cl⁻/liter)

S _{Cl-1}	Fraction 1 concentration (mg Cl ⁻ /liter)	35.0100	30.2700	33.5900
S _{Cl-2}	Fraction 2 concentration (mg Cl ⁻ /liter)			
v ₁	Fraction 1 sample volume (ml)	847.0	808.0	766.0
v ₂	Fraction 2 sample volume (ml)			
m _{HCl}	HCl collected before blank subtraction (mg)	30.4838	25.1430	26.4504
m _b	Allowable blank subtraction (mg)	0.0000	0.0000	0.0000
m _{nb}	HCl collected after blank subtraction (mg)	30.4838	25.1430	26.4504
m _{MDL}	Minimum detectable HCl (mg)	0.0131	0.0125	0.0118
m _n	Total HCl used in emission calculations (mg)	30.4838	25.1430	26.4504

042210 100928

@

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10955
 Unit 2 FF Outlet

USEPA Method 26A Chloride Laboratory Data Summary

Run No.	Blank	1	2	3
Date (2010)		Mar 17	Mar 17	Mar 17
Start Time (approx.)		06:54	09:02	10:25
Stop Time (approx.)		07:54	10:02	11:25

DRAFT LAB DATA

MDL Min. detectable limit (mg Cl⁻/liter) 0.0150

HCl as Total Chloride

B_{Cl} Blank concentration (mg Cl⁻/liter) <0.0770

S _{Cl-1}	Fraction 1 concentration (mg Cl ⁻ /liter)	32.2600	24.0400	28.3500
S _{Cl-2}	Fraction 2 concentration (mg Cl ⁻ /liter)			
v ₁	Fraction 1 sample volume (ml)	897.0	861.0	797.0
v ₂	Fraction 2 sample volume (ml)			
m _{HCl}	HCl collected before blank subtraction (mg)	29.7475	21.2780	23.2276
m _b	Allowable blank subtraction (mg)	0.0000	0.0000	0.0000
m _{nb}	HCl collected after blank subtraction (mg)	29.7475	21.2780	23.2276
m _{MDL}	Minimum detectable HCl (mg)	0.0138	0.0133	0.0123
m _n	Total HCl used in emission calculations (mg)	29.7475	21.2780	23.2276

042210 100954
@

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10955
 Unit 2 SDA Inlet

USEPA Method 26A Chloride Laboratory Data Summary

Run No.	Blank	1	2	3
Date (2010)		Mar 17	Mar 17	Mar 17
Start Time (approx.)		06:54	09:02	10:25
Stop Time (approx.)		07:54	10:02	11:25

DRAFT LAB DATA

MDL Min. detectable limit (mg Cl⁻/liter) 0.0150

HCl as Total Chloride

B_{Cl} Blank concentration (mg Cl⁻/liter) <0.0770

S _{Cl-1}	Fraction 1 concentration (mg Cl ⁻ /liter)	898.8100	728.0000	796.5900
S _{Cl-2}	Fraction 2 concentration (mg Cl ⁻ /liter)			
V ₁	Fraction 1 sample volume (ml)	737.0	868.0	790.0
V ₂	Fraction 2 sample volume (ml)			
m _{HCl}	HCl collected before blank subtraction (mg)	680.9708	649.5973	646.9267
m _b	Allowable blank subtraction (mg)	0.0000	0.0000	0.0000
m _{nb}	HCl collected after blank subtraction (mg)	680.9708	649.5973	646.9267
m _{MDL}	Minimum detectable HCl (mg)	0.0114	0.0134	0.0122
m _n	Total HCl used in emission calculations (mg)	680.9708	649.5973	646.9267

042210 101012
 ®

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10955
 Unit 2 SDA Inlet

USEPA Method 26A Chloride Laboratory Data Summary

Run No.	Blank	1	2	3
Date (2010)		Mar 17	Mar 17	Mar 17
Start Time (approx.)		06:54	09:02	10:25
Stop Time (approx.)		07:54	10:02	11:25

DRAFT LAB DATA

MDL Min. detectable limit (mg Cl⁻/liter)

HCl as Total Chloride

B_{Cl} Blank concentration (mg Cl⁻/liter)

S _{Cl-1}	Fraction 1 concentration (mg Cl ⁻ /liter)	898.8100	728.0000	796.5900
S _{Cl-2}	Fraction 2 concentration (mg Cl ⁻ /liter)			
v ₁	Fraction 1 sample volume (ml)	737.0	868.0	790.0
v ₂	Fraction 2 sample volume (ml)			
m _{HCl}	HCl collected before blank subtraction (mg)	680.9708	649.5973	646.9267
m _b	Allowable blank subtraction (mg)	0.0000	0.0000	0.0000
m _{nb}	HCl collected after blank subtraction (mg)	680.9708	649.5973	646.9267
m _{MDL}	Minimum detectable HCl (mg)	0.0136	0.0161	0.0146
m _n	Total HCl used in emission calculations (mg)	680.9708	649.5973	646.9267

042210 100723
 @

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10955
 Unit 3 SDA Inlet

USEPA Method 26A Chloride Laboratory Data Summary

Run No.	Blank	1	2	3
Date (2010)		Mar 16	Mar 16	Mar 16
Start Time (approx.)		07:17	09:04	10:32
Stop Time (approx.)		08:17	10:04	11:32

DRAFT LAB DATA

MDL Min. detectable limit (mg Cl⁻/liter)

HCl as Total Chloride

B_{Cl} Blank concentration (mg Cl⁻/liter)

S _{Cl-1}	Fraction 1 concentration (mg Cl ⁻ /liter)	1154.2300	1129.2900	1225.4200
S _{Cl-2}	Fraction 2 concentration (mg Cl ⁻ /liter)			
v ₁	Fraction 1 sample volume (ml)	725.0	701.0	723.0
v ₂	Fraction 2 sample volume (ml)			
m _{HCl}	HCl collected before blank subtraction (mg)	860.2476	813.7980	910.7861
m _b	Allowable blank subtraction (mg)	0.0000	0.0000	0.0000
m _{nb}	HCl collected after blank subtraction (mg)	860.2476	813.7980	910.7861
m _{MDL}	Minimum detectable HCl (mg)	0.0112	0.0108	0.0111
m _n	Total HCl used in emission calculations (mg)	860.2476	813.7980	910.7861

042210 101340
 @

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10955
 Unit 3 FF Outlet

USEPA Method 26A Chloride Laboratory Data Summary

Run No.	Blank	1	2	3
Date (2010)		Mar 16	Mar 16	Mar 16
Start Time (approx.)		07:17	09:04	10:32
Stop Time (approx.)		08:17	10:04	11:32

DRAFT LAB DATA

MDL Min. detectable limit (mg Cl⁻/liter)

HCl as Total Chloride

B_{Cl} Blank concentration (mg Cl⁻/liter)

S _{Cl-1}	Fraction 1 concentration (mg Cl ⁻ /liter)	29.9300	33.4400	28.9700
S _{Cl-2}	Fraction 2 concentration (mg Cl ⁻ /liter)			
v ₁	Fraction 1 sample volume (ml)	848.0	956.0	802.0
v ₂	Fraction 2 sample volume (ml)			
m _{HCl}	HCl collected before blank subtraction (mg)	26.0913	32.8638	23.8845
m _b	Allowable blank subtraction (mg)	0.0000	0.0000	0.0000
m _{nb}	HCl collected after blank subtraction (mg)	26.0913	32.8638	23.8845
m _{MDL}	Minimum detectable HCl (mg)	0.0131	0.0147	0.0124
m _n	Total HCl used in emission calculations (mg)	26.0913	32.8638	23.8845

042210 101254
 @

CleanAir.

CleanAir Engineering
500 W. Wood Street
Palatine, IL 60067-4975
800-627-0033
www.cleanair.com



CleanAir®

CleanAir Engineering, Inc.

500 West Wood Street
Palatine, IL 60067

Laboratory Report

Customer Reference No: 10955

Laboratory Project No: 28557

Analytes

Chloride

Customer

Palatine Engineering Group
500 W Wood St
Palatine, IL 60067

Revision 0 - Dated: 04/09/2010

Revision 1 - Dated: 04/22/2010

This Page Intentionally Left Blank

Analysis Case Narrative
Ion Chromatography Analysis

Client Name:	Palatine Engineering Group	Date Received:	3/29/2010
Plant/Facility:	Wheelabrator North Broward	Date Reported:	4/22/2010
Laboratory Project No:	28557	Sample Type:	Varied
Customer Reference No:	10955	Parameters:	Chloride
Sample Numbers:	1-22	Received From:	Scott Brown
Applicable Analytical Method	U.S. EPA Method 26A		

Summary of Analysis

This report summarizes the results of the analysis performed on samples received on: 03/29/10
The samples were analyzed following procedures found in U.S. EPA Method 26A and U.S. EPA Method 300.1.

Detection Limits

Method Detection Limits have been determined in accordance with procedures in 40 CFR 136, Appendix B. Documentation showing the determination of detection limits are included with this report.

Sample Preparation

Samples were prepared according to the procedures listed in the EPA Method above. Each sample was analyzed at full strength and a dilution was prepared if necessary to achieve a concentration that was within calibration range limits.

Standard Tracability

Each calibration standard has been prepared in accordance with US EPA Method 300.1 and US EPA Method 26 and has been designated an original lot number. This number can be used to trace back to the original dry salts used in the preparation of these standards. This number is included on the calibration page of this report.

Instrument Calibration

Instrument calibration followed regulations found in US EPA Method 300.1 and U.S. EPA Method 26A. Calibration standards were prepared from ACS grade dry salts as per section 7.3 of US EPA Method 300.1. As per section 4.2.2 of US EPA CTM-027, a series of 6 diluted standards are prepared from the original calibration standard and run through the column in duplicate from lowest concentration to highest. The average peak area for each calibration point is gathered and plotted against the expected solution concentration. In accordance with section 7.2.3 of EPA Method 9057, a least-squares regression with an r^2 value of .995 or greater must be produced from the resulting curve. In accordance with US EPA Method 26 a full post-test calibration is performed. The pre test calibration and post test calibration average peak area for any standard must agree within $\pm 5\%$ of any observed area.

Chromatograms

All chromatograms are included as an appendix of this report. Please note: Chromatograms marked as "End" are place markers meant to signify the end of a batch run and are purposely left blank as no data was acquired for that run.

Analysis QA/QC

Many elements of various EPA methods have been combined and are adhered to:

EPA Method 300.1 quality procedures:

- 1 Before the first sample was analyzed and every twenty samples thereafter (and before the post-test calibration) a laboratory blank and a Continuing Calibration Verification (CCV) were analyzed. The CCV is prepared from the same calibration standard as used to create the 7 diluted standards that make up the calibration curve. The laboratory blank must show a regression concentration of zero, and the CCV must show a regression concentration within 10 percent of the expected concentration
- 2 After the first ten samples and every twenty there after, a Quality Control (QC) sample was analyzed.

Analysis Case Narrative

Ion Chromatography Analysis

Client Name:	Palatine Engineering Group	Date Received:	3/29/2010
Plant/Facility:	Wheelabrator North Broward	Date Reported:	4/22/2010
Laboratory Project No:	28557	Sample Type:	Varied
Customer Reference No:	10955	Parameters:	Chloride
Sample Numbers:	1-22	Received From:	Scott Brown
Applicable Analytical Method	U.S. EPA Method 26A		

The QC sample was created using ACS grade dry salts from a different manufacturer and or lot number than for the salts used to create the calibration standards.

The QC must meet the same acceptance criteria as noted for the CCV above.

- 3 A matrix spike analysis was performed on ten percent of the total number of samples. This sample was prepared with equal amounts of a sample and a calibration standard whose concentration was known to be larger than that of the sample.

The matrix spike is acceptable when the recovery is found to be 100 ± 10 percent.

- 4 As a measure of precision, all matrix spikes were prepared and analyzed in duplicate. The average area count of two identical matrix spikes may not have a relative percent difference of more than 10 percent.

EPA Method 26 quality procedure:

- 1 As per section 11.1.3, every sample was analyzed in duplicate and the mean area count used to determine the concentration. The duplicate area counts must have a relative percent difference of no greater than five percent. If this was the case, a third injection was made and the average of the three injections was used to determine the concentration.

EPA Method 7E quality procedures:

- 1 Each point on the calibration curve should be within ± 2 percent of the calibration span of the curve used.

Other CleanAir quality procedures:

- 1 The observed concentration value of each point on the calibration curve should have a relative percent difference of no more than 10 percent from its expected concentration.

Additional Comments

This report shall in no way be reproduced except in full without the prior written approval of Clean Air Analytical Laboratory management.

CleanAir Lab Services is accredited by NELAC through the state of Texas for this analysis. Our certificate number is T104704431-09-TX and expires 6/10/2010.

Audit sample L3586 did not pass with the originally reported result. An investigation into this failed audit sample analysis determined that the result was most likely caused by erroneously contaminated glassware. All samples were reanalyzed and both audit samples were found to have passing results. In addition, sample number 28557-07 was found to have a value differing greatly from its original reported value of 47.71 mg/L. This difference is also believed to have stemmed from the above-mentioned erroneously contaminated glassware.

CERTIFICATE OF ANALYSIS

Client Name: Palatine Engineering Group
Plant/Facility: Wheelabrator North Broward
Lab Project No: 28557
Sample Numbers: 1-22

Date Received: 3/29/2010
Date Reported: 4/22/2010
Sample Type: Varied
Parameters: Chloride

Laboratory Number	Sample Identification	Sample Volume (ml)	Chloride Sample Conc. (mg/L)	Detection Limit (mg/L)	Reporting Limit (mg/L)
Reagent Blanks					
28557-01	DI H2O Blank	300	<	0.015	0.077
28557-02	0.1N H2SO4 Blank	300	<	0.015	0.077
Unit 1					
28557-03	U1 SDA Inlet R1	837	917.42	0.015	0.077
28557-04	U1 SDA Inlet R2	802	1,066.78	0.015	0.077
28557-05	U1 SDA Inlet R3	700	920.90	0.015	0.077
28557-06	U1 FF Outlet R1	847	35.01	0.015	0.077
28557-07	U1 FF Outlet R2	808	30.27	0.015	0.077
28557-08	U1 FF Outlet R3	766	33.59	0.015	0.077
Unit 2					
28557-09	U2 SDA Inlet R1	737	898.81	0.015	0.077
28557-10	U2 SDA Inlet R2	868	728.00	0.015	0.077
28557-11	U2 SDA Inlet R3	790	796.59	0.015	0.077
28557-12	U2 FF Outlet R1	897	32.26	0.015	0.077
28557-13	U2 FF Outlet R2	861	24.04	0.015	0.077
28557-14	U2 FF Outlet R3	797	28.35	0.015	0.077
Unit 3					
28557-15	U3 SDA Inlet R1	725	1,154.23	0.015	0.077
28557-16	U3 SDA Inlet R2	701	1,129.29	0.015	0.077
28557-17	U3 SDA Inlet R3	723	1,225.42	0.015	0.077
28557-18	U3 FF Outlet R1	848	29.93	0.015	0.077
28557-19	U3 FF Outlet R2	956	33.44	0.015	0.077
28557-20	U3 FF Outlet R3	802	28.97	0.015	0.077
Audit Samples					
28557-21	Audit Sample L3937	500	32.96	0.015	0.077
28557-22	Audit Sample L3586	500	142.64	0.015	0.077

To the best of our knowledge, the data presented in this report are accurate, complete, error free, legible and representative of the samples received by the laboratory.

Analyst: Eric Ewing
 Eric Ewing
 email: eewing@cleanair.com
 Ph: 847-654-4519

Team Leader, Lab Services: Douglas D. Rhoades
 Douglas D. Rhoades
 email: drhoades@cleanair.com
 Ph: 847-654-4504



Differences Between Current Revision and Originally Reported Data
Ion Chromatography Analysis

Customer:	Wheelabrator N. Broward	Lab Project No:	28557	Analyst:	Eric Ewing
Plant:	North Broward	Customer Reference No:	10959		
Received:	3/29/10	Method:	EPA Method 26A		

Laboratory Sample Identification Number	Sample Identification	Sample Volume (mL)	Originally Reported Sample Concentration (mg/L)	Revised Sample Concentration (mg/L)	Difference in Reported Sample Concentrations (%)
Reagent Blanks					
28557-01	DI H2O Blank	300	<	<	
28557-02	0.1N H2SO4 Blank	300	<	<	
Unit 1					
28557-03	U1 SDA Inlet R1	837	895.2	917.4	2.5%
28557-04	U1 SDA Inlet R2	802	1,120	1,066.8	4.8%
28557-05	U1 SDA Inlet R3	700	884.4	920.9	4.0%
28557-06	U1 FF Outlet R1	847	34.35	35.01	1.9%
28557-07	U1 FF Outlet R2	808	47.71	30.27	44.7%
28557-08	U1 FF Outlet R3	766	35.22	33.59	4.7%
Unit 2					
28557-09	U2 SDA Inlet R1	737	857.2	898.8	4.7%
28557-10	U2 SDA Inlet R2	868	737.0	728.0	1.2%
28557-11	U2 SDA Inlet R3	790	763.0	796.6	4.3%
28557-12	U2 FF Outlet R1	897	30.69	32.26	5.0%
28557-13	U2 FF Outlet R2	861	22.74	24.04	5.6%
28557-14	U2 FF Outlet R3	797	29.53	28.35	4.1%
Unit 3					
28557-15	U3 SDA Inlet R1	725	1,204	1,154	4.2%
28557-16	U3 SDA Inlet R2	701	1,079	1,129	4.5%
28557-17	U3 SDA Inlet R3	723	1,192	1,225	2.7%
28557-18	U3 FF Outlet R1	848	30.69	29.93	2.5%
28557-19	U3 FF Outlet R2	956	32.23	33.44	3.7%
28557-20	U3 FF Outlet R3	802	29.60	28.97	2.1%
Audit Samples					
28557-21	Audit Sample L3937	500	32.44	32.96	1.6%
28557-22	Audit Sample L3586	500	158.1	142.64	10.3%

CleanAir

CHROMATOGRAPHIC DATA REDUCTION

Client Palatine Engineering Group
 Lab Project No: 28557
 Analyte Chloride
 Date 4/22/2010
 Stock Standard 1008.91 mg/l
 Lot Number 04151002-64-00000-01
 Working Stock Conc. 10.0891 mg/l
 CCV 1.01 mg/l
 QC 209.28 mg/l
 Lot Number 03261002-64-00000-07

Analyte:

Chloride Standards Calibration Data

Calibration Point	Date of Injection	1	2	3	4	5	6	7
Conc. (mg/l)		0.0000	0.1513	0.4036	0.8071	1.2611	1.6142	2.5223
Cal 1 Trial 1	04/15/2010	0.0000	0.1401	0.3729	0.7090	1.0475	1.3417	2.1125
Cal 1 Trial 2		0.0000	0.1340	0.3799	0.6879	1.0590	1.3316	2.0868
Cal 2 Trial 1	04/16/2010		0.1456					
Cal 2 Trial 2			0.1441					
Cal 3 Trial 1	04/18/2010							2.1989
Cal 3 Trial 2								2.2174
Cal 4 Trial 1	04/18/2010		0.1353					
Cal 4 Trial 2			0.1423					
Cal 5 Trial 1	04/21/2010		0.1359	0.3885	0.7367	1.0944	1.3607	2.1559
Cal 5 Trial 2			0.1420	0.3726	0.7452	1.0912	1.3582	2.2020

n	2	8	4	4	4	4	6
Average	0.0000	0.1399	0.3785	0.7197	1.0730	1.3481	2.1623
Standard Deviation	0.0000	0.0043	0.0075	0.0262	0.0233	0.0138	0.0532
%RSD	0.00	3.11	1.98	3.65	2.18	1.03	2.46

Measured Area Counts	Actual Concentration (mg/L)	Regression Concentration (mg/L)
0.0000	0.000	-0.017
0.1399	0.151	0.148
0.3785	0.404	0.430
0.7197	0.807	0.833
1.0730	1.261	1.251
1.3481	1.614	1.576
2.1623	2.522	2.538

Regression Constants

Slope m = 1.1817
 Intercept b = -0.0171
 Coeff. R² = 0.9993

Quality Control Checks


Difference pt-Line (% Scale)	Is Difference Less Than 2% of Scale?	Difference pt-Line (Relative %)	Is Relative Difference Less Than 10%?
0.68%	Yes	0.00%	Yes
0.12%	Yes	2.02%	Yes
-1.06%	Yes	-6.60%	Yes
-1.04%	Yes	-3.26%	Yes
0.40%	Yes	0.81%	Yes
1.52%	Yes	2.38%	Yes
-0.63%	Yes	-0.63%	Yes

Is Coefficient of Regression > 0.995?
 Yes

CHROMATOGRAPHIC DATA REDUCTION

Client Palatine Engineering Group
Lab Project No: 28557
Analyte Chloride
Date 4/22/2010

Chloride Calibration Curve



CleanAir

CHROMATOGRAPHIC DATA REDUCTION

Client Palatine Engineering Group

Lab Project No: 28557

Analyte Chloride

Date 4/22/2010

MDL= 0.015 mg/L

Average Flow Rate

MRL= 0.077 mg/L

0.80 mL/min

Sample Location	Sample Identification Number	Sample Identification	Date of Injection	Area Counts Trial 1	Area Counts Trial 2	Area Count Average	DF (Analysis Dilution Factor)	V _{stdn} (Total Sample Volume, mL)	C _{Reg} (Concentration, mg/L from Reg Curve)	M _{analyte} Total Amount of Analyte (mg)
Reagent Blank	28557-01	DI H2O Blank	04/19/10	0.0000	0.0000	0.0000	1	300.0	<	<0.023
Reagent Blank	28557-02	0.1N H2SO4 Blank	04/19/10	0.0000	0.0000	0.0000	1	300.0	<	<0.023
U1 SDA Inlet	28557-03	U1 SDA Inlet R1	04/19/10	0.7969	0.7847	0.7908	1000	836.6	917.42	767.51
U1 SDA Inlet	28557-04	U1 SDA Inlet R2	04/19/10	0.9003	0.9341	0.9172	1000	801.9	1,066.78	855.45
U1 SDA Inlet	28557-05	U1 SDA Inlet R3	04/19/10	0.7840	0.8035	0.7938	1000	700.0	920.90	644.63
U1 FF Outlet	28557-06	U1 FF Outlet R1	04/20/10	0.5968	0.6171	0.6070	50	847.0	35.01	29.65
U1 FF Outlet	28557-07	U1 FF Outlet R2	04/20/10	0.5202	0.5333	0.5268	50	807.8	30.27	24.45
U1 FF Outlet	28557-08	U1 FF Outlet R3	04/20/10	0.5809	0.5849	0.5829	50	766.0	33.59	25.73
U2 SDA Inlet	28557-09	U2 SDA Inlet R1	04/20/10	0.7673	0.7828	0.7751	1000	737.0	898.81	662.42
U2 SDA Inlet	28557-10	U2 SDA Inlet R2	04/20/10	0.6154	0.6456	0.6305	1000	867.9	728.00	631.83
U2 SDA Inlet	28557-11	U2 SDA Inlet R3	04/20/10	0.6953	0.6818	0.6886	1000	790.0	796.59	629.31
U2 FF Outlet	28557-12	U2 FF Outlet R1	04/20/10	0.5624	0.5584	0.5604	50	898.8	32.26	28.92
U2 FF Outlet	28557-13	U2 FF Outlet R2	04/20/10	0.4163	0.4264	0.4214	50	861.4	24.04	20.71
U2 FF Outlet	28557-14	U2 FF Outlet R3	04/20/10	0.4895	0.4991	0.4943	50	797.0	28.35	22.60
U3 SDA Inlet	28557-15	U3 SDA Inlet R1	04/20/10	0.9827	0.9997	0.9912	1000	725.0	1,154.23	836.81
U3 SDA Inlet	28557-16	U3 SDA Inlet R2	04/20/10	0.9882	0.9520	0.9701	1000	701.0	1,129.29	791.63
U3 SDA Inlet	28557-17	U3 SDA Inlet R3	04/20/10	1.0625	1.0404	1.0515	1000	723.0	1,225.42	885.98
U3 FF Outlet	28557-18	U3 FF Outlet R1	04/20/10	0.5309	0.5112	0.5211	50	848.0	29.93	25.38
U3 FF Outlet	28557-19	U3 FF Outlet R2	04/20/10	0.5753	0.5856	0.5805	50	956.0	33.44	31.97
U3 FF Outlet	28557-20	U3 FF Outlet R3	04/20/10	0.5121	0.4975	0.5048	50	802.0	28.97	23.24
Audit Sample	28557-21	Audit Sample L3937	04/20/10	0.5825	0.5622	0.5724	50	500.0	32.96	16.48
Audit Sample	28557-22	Audit Sample L3586	04/20/10	0.6088	0.6272	0.6180	200	500.0	142.64	71.32

CHROMATOGRAPHIC DATA REDUCTION

Client Palatine Engineering Group
 Lab Project No: 28557
 Analyte Chloride
 Date 4/22/2010

QUALITY CONTROL CHECKS

Sample Location	Sample Identification Number	Sample Identification	Date of Injection	Area Counts Trial 1	Area Counts Trial 2	Area Count Average	Area Count Duplicate Difference	Duplicate Relative Difference (%)
Reagent Blank	28557-01	DI H2O Blank	04/19/10	0.0000	0.0000	0.0000	na	na
Reagent Blank	28557-02	0.1N H2SO4 Blank	04/19/10	0.0000	0.0000	0.0000	na	na
U1 SDA Inlet	28557-03	U1 SDA Inlet R1	04/19/10	0.7969	0.7847	0.7908	0.0122	1.5%
U1 SDA Inlet	28557-04	U1 SDA Inlet R2	04/19/10	0.9003	0.9341	0.9172	0.0338	3.7%
U1 SDA Inlet	28557-05	U1 SDA Inlet R3	04/19/10	0.7840	0.8035	0.7938	0.0195	2.5%
U1 FF Outlet	28557-06	U1 FF Outlet R1	04/20/10	0.5968	0.6171	0.6070	0.0203	3.3%
U1 FF Outlet	28557-07	U1 FF Outlet R2	04/20/10	0.5202	0.5333	0.5268	0.0131	2.5%
U1 FF Outlet	28557-08	U1 FF Outlet R3	04/20/10	0.5809	0.5849	0.5829	0.0040	0.7%
U2 SDA Inlet	28557-09	U2 SDA Inlet R1	04/20/10	0.7673	0.7828	0.7751	0.0155	2.0%
U2 SDA Inlet	28557-10	U2 SDA Inlet R2	04/20/10	0.6154	0.6456	0.6305	0.0302	4.8%
U2 SDA Inlet	28557-11	U2 SDA Inlet R3	04/20/10	0.6953	0.6818	0.6886	0.0135	2.0%
U2 FF Outlet	28557-12	U2 FF Outlet R1	04/20/10	0.5624	0.5584	0.5604	0.0040	0.7%
U2 FF Outlet	28557-13	U2 FF Outlet R2	04/20/10	0.4163	0.4264	0.4214	0.0101	2.4%
U2 FF Outlet	28557-14	U2 FF Outlet R3	04/20/10	0.4895	0.4991	0.4943	0.0096	1.9%
U3 SDA Inlet	28557-15	U3 SDA Inlet R1	04/20/10	0.9827	0.9997	0.9912	0.0170	1.7%
U3 SDA Inlet	28557-16	U3 SDA Inlet R2	04/20/10	0.9882	0.9520	0.9701	0.0362	3.7%
U3 SDA Inlet	28557-17	U3 SDA Inlet R3	04/20/10	1.0625	1.0404	1.0515	0.0221	2.1%
U3 FF Outlet	28557-18	U3 FF Outlet R1	04/20/10	0.5309	0.5112	0.5211	0.0197	3.8%
U3 FF Outlet	28557-19	U3 FF Outlet R2	04/20/10	0.5753	0.5856	0.5805	0.0103	1.8%
U3 FF Outlet	28557-20	U3 FF Outlet R3	04/20/10	0.5121	0.4975	0.5048	0.0146	2.9%
Audit Sample	28557-21	Audit Sample L3937	04/20/10	0.5825	0.5622	0.5724	0.0203	3.5%
Audit Sample	28557-22	Audit Sample L3586	04/20/10	0.6088	0.6272	0.6180	0.0184	3.0%

CleanAir

CHROMATOGRAPHIC DATA REDUCTION

Client Palatine Engineering Group
 Lab Project No: 28557
 Analyte Chloride
 Date 4/22/2010

MDL=	0.015 mg/L	Average Flow Rate	QC Dilution Factor
MRL=	0.077 mg/L	0.80 mL/min	200

QUALITY CONTROL CHECKS (CONT)

Sample Location	Sample Identification Number	Sample Identification	Date of Injection	Area Counts Trial 1	Area Counts Trial 2	Area Count Average	Area Count Duplicate Difference	Duplicate Relative Difference (%)	C _{Reg} (Concentration, mg/L from Reg Curve)	Percent Difference from Actual Value (%)
CleanAir	28557-00	CCB	04/19/10	0.0000	0.0000	0.0000	na	na	<	
CleanAir	28557-990	CCV	04/19/10	0.9241	0.9110	0.9176	0.0131	1.4%	1.07	5.78%
CleanAir	28557-991	QC	04/20/10	0.9302	0.8928	0.9115	0.0374	4.1%	212.01	1.30%
CleanAir	28557-00	CCB	04/20/10	0.0000	0.0000	0.0000	na	na	<	
CleanAir	28557-992	CCV	04/20/10	0.8978	0.9352	0.9165	0.0374	4.1%	1.07	5.65%
Matrix Spike Recoveries										
									<u>Precision</u>	<u>Spike Recovery</u>
Matrix Spike	28557-05	U1 SDA Inlet R:	04/20/10	1.5481	1.5870	1.5676	0.0389	2.5%		107.8%
Matrix Spike	28557-05	U1 SDA Inlet R:	04/20/10	1.5834	1.5810	1.5822	0.0024	0.2%	0.9%	109.2%
Matrix Spike	28557-20	U3 FF Outlet R:	04/21/10	1.4216	1.4261	1.4239	0.0045	0.3%		108.7%
Matrix Spike	28557-20	U3 FF Outlet R:	04/21/10	1.4140	1.3650	1.3895	0.0490	3.5%	2.4%	105.5%
Matrix Spike	28557-21	Audit Sample L3E	04/21/10	1.3853	1.4529	1.4191	0.0676	4.8%		105.3%

CHROMATOGRAPHIC DATA REDUCTION

Client Palatine Engineering Group
 Lab Project No: 28557
 Analyte Chloride
 Date 4/22/2010

Determination of Detection Limit

(in accordance with 40 CFR 136, Appendix B)

Analyte	Chloride
Area Count	
Trial 1	0.1401
Trial 2	0.1340
Trial 3	0.1456
Trial 4	0.1441
Trial 5	0.1353
Trial 6	0.1423
Trial 7	0.1359
Trial 8	0.1420
Average	0.1399
Std Dev	0.0043
RMS Dev	3.11%

n	t _(n-1,0.99)
7	3.143
8	2.998
9	2.896
10	2.821
11	2.764
16	2.602
21	2.528

Average % Recovery	97.98%
Measured Concentration (mg/l)	
Trial 1	0.149
Trial 2	0.141
Trial 3	0.155
Trial 4	0.153
Trial 5	0.143
Trial 6	0.151
Trial 7	0.144
Trial 8	0.151
Average	0.148
Std Dev	0.0051
RMS Dev	3.46%
t _(n-1,0.99)	2.998
Det Lim (mg/l)	0.015
Rep Lim (mg/L)	0.077

Is the spike level higher than the MDL? Yes
 Does the spike level exceed ten times the MDL? NO
 Is the Avg Recovery between 90% < Ra < 110% ? Yes

Actual Conc 0.1513
 Slope 1.18E+00
 Intercept -0.0171
 Coeff of Corr 0.9993

Sample Calculations

Customer:	Palatine Engineering Group	Lab Project No:	28557	Analyst	Eric Ewing
Plant:	Wheelabrator North Broward	Customer Ref No:	10955	Method	U.S. EPA Method 26A

Calibration Point No: 3
 Sample No: 28557-03
 Sample Location: U1 SDA Inlet

1. Difference between duplicate injections for pre-test calibration (Pre Cal 1).

$$\Delta_{Injection} = |Area_{Trial\ 2} - Area_{Trial\ 1}|$$

Where:

$\Delta_{Injection}$ = Area count difference between duplicate injections

$Area_{Trial2}$ = Area count for injection Trial 2

$Area_{Trial1}$ = Area count for injection Trial 1

$$\Delta_{Injection} = 0.0070$$

$$Area_{Trial2} = 0.3799$$

$$Area_{Trial1} = 0.3729$$

2. Average area count value for duplicate injections for pre-test calibration (Pre Cal 1).

$$Avg_{PreInj} = \frac{(Area_{Trial1} + Area_{Trial2})}{2}$$

Where:

Avg_{PreInj} = Average of duplicate injection area counts

$Area_{Trial2}$ = Area count for injection Trial 2

$Area_{Trial1}$ = Area count for injection Trial 1

2 = Constant (number of values)

$$Avg_{Inj} = 0.3764$$

$$Area_{Trial2} = 0.3799$$

$$Area_{Trial1} = 0.3729$$

Sample Calculations

Customer:	Palatine Engineering Group	Lab Project No:	28557	Analyst	Eric Ewing
Plant:	Wheelabrator North Broward	Customer Ref No:	10955	Method	U.S. EPA Method 26A

Calibration Point No: 3
 Sample No: 28557-03
 Sample Location: U1 SDA Inlet

3. Difference between individual injection and average area count for pre-test calibration.

$$\Delta_{PreMean\%} = \frac{|Area_{Trial2} - Avg_{PreInj}|}{Avg_{PreInj}} 100$$

Where:

- $\Delta_{PreMean\%}$ = Difference between individual injection and average area count (%).
- Avg_{PreInj} = Average of duplicate injection area counts
- $Area_{Trial2}$ = Area count for injection Trial 2
- 100 = Constant (conversion factor for percentage)

$$\begin{aligned} \Delta_{PreMean\%} &= 0.9213 \\ Avg_{PreInj} &= 0.3764 \\ Area_{Trial2} &= 0.3799 \end{aligned}$$

Note: EPA Method 26 requires $\Delta_{PreMean\%}$ to be less than 5%.

4. Average of all area count values for a given calibration point.

$$\bar{X} = \frac{\sum_{i=1}^n x_i}{n}$$

Where:

- \bar{X} = Average of all area count values for a given calibration point.
- x_i = Individual area count values for each individual injection.
- i = Iteration value.
- n = Number of injections for the calibration point under question.

$$\begin{aligned} \bar{X} &= 0.3785 \\ x_1 &= 0.3729 \\ x_2 &= 0.3799 \\ n &= 4.0000 \end{aligned}$$

Sample Calculations

Customer: Palatine Engineering Group	Lab Project No: 28557	Analyst: Eric Ewing
Plant: Wheelabrator North Broward	Customer Ref No: 10955	Method: U.S. EPA Method 26A

Calibration Point No: 3
 Sample No: 28557-03
 Sample Location: U1 SDA Inlet

5. Average of all concentration values for used in generating calibration curve.

$$\bar{Y}_{All} = \frac{\sum_{i=1}^n y_i}{n}$$

Where:

- \bar{Y}_{All} = Average of all area concentration values.
- y_i = Individual concentration values for each individual injection.
- n = Number of injections.

$$\begin{aligned} \bar{Y}_{All} &= 0.9657 \\ y_1 &= 0.0000 \\ y_2 &= 0.1513 \\ n &= 7.0000 \end{aligned}$$

6. Average of all area count values for the calibration curve.

$$\bar{X}_{All} = \frac{\sum_{i=1}^n x_i}{n}$$

Where:

- \bar{X}_{All} = Average of all area count values.
- x_i = Individual area count values.
- i = Iteration value.
- n = Number of injections.

$$\begin{aligned} \bar{X}_{All} &= 0.8803 \\ x_1 &= 0.3729 \\ x_2 &= 0.3799 \\ n &= 32.0000 \end{aligned}$$

Sample Calculations

Customer: Palatine Engineering Group	Lab Project No: 28557	Analyst: Eric Ewing
Plant: Wheelabrator North Broward	Customer Ref No: 10955	Method: U.S. EPA Method 26A

Calibration Point No: 3
 Sample No: 28557-03
 Sample Location: U1 SDA Inlet

7. Determination of slope (least-squares regression) value for calibration curve.

$$m = \frac{\sum_{i=1}^n (x_i - \bar{x})(y_i - \bar{y})}{\sum_{i=1}^n (x_i - \bar{x})^2}$$

Where:

- m = Slope of least-squares regression curve.
- x_i = Individual area count values for each individual injection.
- \bar{x} = Average of all area count values = \bar{X}_{All}
- y_i = Actual area concentration values for each individual injection.
- \bar{y} = Average of all concentration values = \bar{Y}_{All}
- i = Iteration value.
- n = Number of injections.

- m = 1.18168
- x_1 = 0.3729
- x_2 = 0.3799
- \bar{x} = 0.8803
- y_1 = 0.0000
- y_2 = 0.1513
- \bar{y} = 0.9657
- n = 32.0000

8. Determination of y-intercept (least-squares regression) value for calibration curve.

$$b = \bar{y} - m \bar{x}$$

Where:

- b = Y-axis intercept.
- \bar{x} = Average of all area count values = \bar{X}_{All}
- \bar{y} = Average of all concentration values = \bar{Y}_{All}

- b = -0.01705
- m = 1.18168
- \bar{x} = 0.8803
- \bar{y} = 0.9657

Sample Calculations

Customer: Palatine Engineering Group	Lab Project No: 28557	Analyst: Eric Ewing
Plant: Wheelabrator North Broward	Customer Ref No: 10955	Method: U.S. EPA Method 26A

Calibration Point No: 3
 Sample No: 28557-03
 Sample Location: U1 SDA Inlet

\bar{y}

9. Determination of coefficient of correlation (least-squares regression) value for calibration curve.

$$r = \frac{\sum_{i=1}^n (x_i - \bar{x})(y_i - \bar{y})}{\sqrt{\sum_{i=1}^n (x_i - \bar{x})^2 \sum_{i=1}^n (y_i - \bar{y})^2}}$$

Where:

- r^2 = Square of the Pearson product moment correlation coefficient through data points in known y's and known x's.
- r = Pearson product moment correlation coefficient through data points in known y's and known x's.
- x_i = Individual area count values for each individual injection.
- y_i = Actual area concentration values for each individual injection.
- \bar{x} = Average of all area count values = \bar{X}_{All}
- \bar{y} = Average of all concentration values = \bar{Y}_{All}
- i = Iteration value.
- n = Number of injections.

- r^2 = 0.99928
- r = 0.99964
- x_1 = 0.3729
- x_2 = 0.3799
- \bar{x} = 0.8803
- y_1 = 0.0000
- y_2 = 0.1513
- \bar{y} = 0.9657
- n = 32.0000

Sample Calculations

Customer:	Palatine Engineering Group	Lab Project No:	28557	Analyst	Eric Ewing
Plant:	Wheelabrator North Broward	Customer Ref No:	10955	Method	U.S. EPA Method 26A

Calibration Point No: 3
 Sample No: 28557-03
 Sample Location: U1 SDA Inlet

10. Determination of average sample area counts from duplicate injections.

$$Avg_{Sample} = \frac{(Area_{Trial1} + Area_{Trial2})}{2}$$

Where:

- Avg_{Sample} = Average of duplicate injection area counts
- $Area_{Trial2}$ = Area count for injection Trial 2
- $Area_{Trial1}$ = Area count for injection Trial 1
- 2 = Constant (number of injections)

Avg_{inj} = 0.7908
 $Area_{Trial2}$ = 0.7847
 $Area_{Trial1}$ = 0.7969

11. Difference between duplicate injections for the sample.

$$\Delta_{Injection} = |Area_{Trial2} - Area_{Trial1}|$$

Where:

- $\Delta_{Injection}$ = Area count difference between duplicate injections
- $Area_{Trial2}$ = Area count for injection Trial 2
- $Area_{Trial1}$ = Area count for injection Trial 1

$\Delta_{Injection}$ = 0.0122
 $Area_{Trial2}$ = 0.7847
 $Area_{Trial1}$ = 0.7969

Sample Calculations

Customer:	Palatine Engineering Group	Lab Project No:	28557	Analyst	Eric Ewing
Plant:	Wheelabrator North Broward	Customer Ref No:	10955	Method	U.S. EPA Method 26A

Calibration Point No: 3
 Sample No: 28557-03
 Sample Location: U1 SDA Inlet

12. Difference between individual injection and average area count for the sample.

$$\Delta_{Injection} = \frac{|Area_{Trial2} - Avg_{Inj}|}{Avg_{Inj}} 100$$

Where:

- $\Delta_{Injection}$ = Difference between individual injection and average area count (%).
- Avg_{Inj} = Average of duplicate injection area counts
- $Area_{Trial2}$ = Area count for injection Trial 2
- 100 = Constant (conversion factor for percentage)

- $\Delta_{Injection}$ = 0.8%
- Avg_{Inj} = 0.7908
- $Area_{Trial2}$ = 0.7847

Note: EPA Method 26 requires $\Delta_{Injection}$ to be less than 5%.

13. Determination of sample concentration from least-squares regression curve (mg/L).

$$C_{Reg} = DF [m(Avg_{Inj}) + b]$$

Where:

- C_{Reg} = Sample concentration determined using the regression curve (mg/L)
- DF = Sample dilution factor
- Avg_{Inj} = Average of duplicate injection area counts.
- m = Slope of least-squares regression curve.
- b = Y-intercept of least-squares regression curve.

- C_{Reg} = 917.42
- DF = 1000.0000
- Avg_{Inj} = 0.7908
- m = 1.1817
- b = -0.0171

Sample Calculations

Customer: Palatine Engineering Group	Lab Project No: 28557	Analyst: Eric Ewing
Plant: Wheelabrator North Broward	Customer Ref No: 10955	Method: U.S. EPA Method 26A

Calibration Point No: 3
 Sample No: 28557-03
 Sample Location: U1 SDA Inlet

14. Determination of total amount of analyte in sample (total mg).

$$M_{Analyte} = \frac{(C_{Reg})(V_{Soln})}{1000}$$

Where:

- $M_{Analyte}$ = Amount of analyte in sample (total mg)
- C_{Reg} = Sample concentration determined using the response factor (mg/L)
- V_{Soln} = Sample volume (ml)
- 1000 = Conversion constant (ml to L)

- $M_{Analyte}$ = 767.51
- C_{Reg} = 917.4185
- V_{Soln} = 836.6000

15. Determination of Method Detection Limits (MDL).

15a. Determination of average spike result.

$$AvgM_{f-i} = \frac{\sum_{i=1}^n M_{f-i}}{n}$$

Where:

- $AvgM_{f-i}$ = Average of spike result (mg/L)
- M_{f-i} = Net results recorded for each iteration (mg/L)
- n = Number of iterations.
- i = Placeholder for iteration.

- $AvgM_{f-i}$ = 0.148
- M_{f_1} = 0.149 M_{f_5} = 0.143
- M_{f_2} = 0.141 M_{f_6} = 0.151
- M_{f_3} = 0.155 M_{f_7} = 0.144
- M_{f_4} = 0.153 M_{f_8} = 0.151
- n = 8

Sample Calculations

Customer: Palatine Engineering Group	Lab Project No: 28557	Analyst: Eric Ewing
Plant: Wheelabrator North Broward	Customer Ref No: 10955	Method: U.S. EPA Method 26A

Calibration Point No: 3
 Sample No: 28557-03
 Sample Location: U1 SDA Inlet

15b. Determination of standard deviation of spike result.

$$\sigma_{f-i} = \sqrt{\frac{\sum_{i=1}^n (M_{f-i} - AvgM_{f-i})^2}{(n-1)}}$$

Where:

- σ_{f-i} = Standard deviation of spike result.
- $AvgM_{f-i}$ = Average of spike result net weights (g)
- M_{f-i} = Net weights recorded for each iteration (g)
- n = Number of iterations.
- i = Placeholder for iteration.

σ_{f-i}	=	0.0051		
$AvgM_{f-i}$	=	0.148		
M_{f-1}	=	0.149	M_{f-5}	= 0.143
M_{f-2}	=	0.141	M_{f-6}	= 0.151
M_{f-3}	=	0.155	M_{f-7}	= 0.144
M_{f-4}	=	0.153	M_{f-8}	= 0.151
n	=	8		

15c. Determination of variance of spike result.

$$V_{f-i} = (\sigma_{f-i})^2$$

Where:

- V_{f-i} = Variance of spike result.
- σ_{f-i} = Standard deviation of spike result.

V_{f-i}	=	2.64E-05
σ_{f-i}	=	0.0051

Sample Calculations

Customer:	Palatine Engineering Group	Lab Project No:	28557	Analyst	Eric Ewing
Plant:	Wheelabrator North Broward	Customer Ref No:	10955	Method	U.S. EPA Method 26A

Calibration Point No: 3
 Sample No: 28557-03
 Sample Location: U1 SDA Inlet

15d. Determination of RMS deviation of spike result.

$$RMS_{f-i} = 100 \frac{\sigma_{f-i}}{AvgM_{f-i}}$$

Where:

- RMS_{f-i} = RMS deviation of spike results (%)
- σ_{f-i} = Standard deviation of spike result
- AvgM_{f-i} = Average of spike result net weights (g)
- 100 = Conversion constant (fraction to percent)

- RMS_{f-i} = 0.0346
- σ_{f-i} = 0.0051
- AvgM_{f-i} = 0.1483

15e. Determination of average spike recovery.

$$R_f = 100 \frac{AvgM_{f-i}}{RA}$$

Where:

- R_f = Average spike recovery (%)
- AvgM_{f-i} = Average of spike result net weights (g)
- RA = Amount of spike residue added (g)
- 100 = Conversion constant (fraction to percent)

- R_f = 98.0%
- AvgM_{f-i} = 0.14828
- RA = 0.15134

Sample Calculations

Customer:	Palatine Engineering Group	Lab Project No:	28557	Analyst	Eric Ewing
Plant:	Wheelabrator North Broward	Customer Ref No:	10955	Method	U.S. EPA Method 26A

Calibration Point No: 3
 Sample No: 28557-03
 Sample Location: U1 SDA Inlet

15f. Determination of $t_{(n-1, 0.99)}$.

Value taken from the following Table:

n	$t_{(n-1, 0.99)}$
7	3.143
8	2.998
9	2.896
10	2.821
11	2.764
16	2.602
21	2.528

Where:

$t_{(n-1, 0.99)}$ = Students' t value appropriate for a 99% confidence level and a standard deviation estimate with n-1 degrees of freedom.

n = Number of iterations.

$t_{(n-1, 0.99)}$ = 2.998

n = 8

15g. Determination of Method Detection Limit (MDL).

$$MDL = \sigma_{f_i} t_{(n-1, 0.99)}$$

Where:

MDL = Method detection limit (mg/L)

$t_{(n-1, 0.99)}$ = Students' t value appropriate for a 99% confidence level and a standard deviation estimate with n-1 degrees of freedom.

σ_{f_i} = Standard deviation of spike result.

MDL = 0.015

$t_{(n-1, 0.99)}$ = 2.998

σ_{f_i} = 0.0051

Sample Calculations

Customer:	Palatine Engineering Group	Lab Project No:	28557	Analyst	Eric Ewing
Plant:	Wheelabrator North Broward	Customer Ref No:	10955	Method	U.S. EPA Method 26A

Calibration Point No: 3
Sample No: 28557-03
Sample Location: U1 SDA Inlet

15h. Determination of Method Reporting Limit (MRL).

$$MRL = 5(MDL)$$

Where:

MRL = Method reporting limit (mg/L)

MDL = Method detection Limit (mg/L)

5 = Constant

MRL = 0.077

MDL = 0.015

**Method 26A Audit Material
(Cl- Spiked Aqueous Solution)**

REPORTING FORM: To be completed by laboratory

Request Number/Sample Number: M26A-4436-02/L3937 Date Issued: 03/10/10

Auditee:

Company: Clean Air Engineering
Address: 500 W Wood St Palatine, IL 60067
Attention of: Eric Ewing Phone: 847-654-4519

Requestor:

Agency: Florida DEP - SED
Address: 400 N. Congress Avenue, Suite 200, West Palm Beach, FL 33401
Attention of: Lee C. Hoefert Phone: 561-681-6626

Project Name: Wheelabrator North Broward

Audit Results (Results in mg/L) *Reanalyzed*

<u>Analyte</u>	<u>Result</u>
Chloride concentration	<u>32.96 mg/L</u>

**Method 26A Audit Material
(Cl- Spiked Aqueous Solution)**

REPORTING FORM: To be completed by laboratory

Request Number/Sample Number: M26A-4436-01/L3586 Date Issued: 03/10/10

Auditee:

Company: Clean Air Engineering
Address: 500 W Wood St Palatine, IL, 60067
Attention of: Eric Ewins Phone: 847-654-4519

Requestor:

Agency: Florida DEP - SED
Address: 400 N. Congress Avenue, Suite 200, West Palm Beach, FL 33401
Attention of: Lee C. Hoefert Phone: 561-681-6626

Project Name: Wheelabrator North Broward

<u>Analyte</u>	<u>Result</u>
Chloride concentration	<u>142.64 mg/L</u>

Reanalyzed

**Method 26A Audit Material
(Cl- Spiked Aqueous Solution)**

REPORTING FORM: To be completed by laboratory

Request Number/Sample Number: M26A-4436-02/L3937 Date Issued: 03/10/10

Auditee:

Company: Clean Air Engineering
Address: 500 West Wood St Palatine, IL 60067
Attention of: Eric Ewing Phone: 847-654-4519

Requestor:

Agency: Florida DEP - SED
Address: 400 N. Congress Avenue, Suite 200, West Palm Beach, FL 33401
Attention of: Lee C. Hoefert Phone: 561-681-6626

Project Name: Wheelabrator North Broward

Audit Results (Results in mg/L) *initial*

<u>Analyte</u>	<u>Result</u>
Chloride concentration	<u>32.44 mg/L</u>

**Method 26A Audit Material
(Cl- Spiked Aqueous Solution)**

REPORTING FORM: To be completed by laboratory

Request Number/Sample Number: M26A-4436-01/L3586 Date Issued: 03/10/10

Auditee:

Company: Clean Air Engineering
Address: 500 west Wood St Palatine, IL 60067
Attention of: Eric Ewing Phone: 847-654-4519

Requestor:


Agency: Florida DEP - SED
Address: 400 N. Congress Avenue, Suite 200, West Palm Beach, FL 33401
Attention of: Lee C. Hoefert Phone: 561-681-6626

Project Name: Wheelabrator North Broward

Audit Results (Results in mg/L)


<u>Analyte</u>	<u>Result</u>
Chloride concentration	<u>158.15 mg/L</u>

11 Cal 04		
CleanAir		
Sample Name:	Cal 04	Sample Vo. 1.0 mL
Vial Number:	6	Channel: ECD_1
Sample Type:	standard	ICS Condu 49.221
Control Program:	AS40Inj1	ICS Pressu 1249.28
Quantif. Method:	default	Dilution Fa: 1.0X
Run Time (min):	20.00	Sample ID:
		Replicate II




No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	6.58	Chloride	1.0475	100.00	BM *	0.93
Total:			1.047	100.000	0.00	

12 Cal 04		
CleanAir		
Sample Name:	Cal 04	Sample Vo. 1.0 mL
Vial Number:	6	Channel: ECD_1
Sample Type:	standard	ICS Condu 49.130
Control Program:	AS40Inj2	ICS Pressu 1252.86
Quantif. Method:	default	Dilution Fac 1.0X
Run Time (min):	20.00	Sample ID:
		Replicate II




No.	Ret. Time min	Peak Name	Area µS*min	Rel. Area %	Type	PGF
1	6.58	Chloride	1.0590	100.00	BM *	0.93
Total:			1.059	100.000	0.00	

13 Cal 05		
CleanAir		
Sample Name:	Cal 05	Sample Vo. 1.0 mL
Vial Number:	1	Channel: ECD_1
Sample Type:	standard	ICS Condu 48.981
Control Program:	AS40Inj1	ICS Pressu 1250.48
Quantif. Method:	default	Dilution Fac 1.0X
Run Time (min):	20.00	Sample ID:
		Replicate II




No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	6.58	Chloride	1.3417	100.00	BM *	0.92
Total:			1.342	100.000	0.00	

14 Cal 05		
CleanAir		
Sample Name:	Cal 05	Sample Vo. 1.0 mL
Vial Number:	1	Channel: ECD_1
Sample Type:	standard	ICS Condu 48.904
Control Program:	AS40Inj2	ICS Pressu 1249.35
Quantif. Method:	default	Dilution Fa 1.0X
Run Time (min):	20.00	Sample ID:
		Replicate II




No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	6.59	Chloride	1.3316	100.00	BM *	0.92
Total:			1.332	100.000	0.00	

15 Cal 06		
CleanAir		
Sample Name:	Cal 06	Sample Vol. 1.0 mL
Vial Number:	2	Channel: ECD_1
Sample Type:	standard	ICS Condu 48.924
Control Program:	AS40Inj1	ICS Pressu 1245.44
Quantif. Method:	default	Dilution Fac 1.0X
Run Time (min):	20.00	Sample ID:
		Replicate II




No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	6.61	Chloride	2.1125	100.00	BM *	0.92
Total:			2.113	100.000	0.00	

16 Cal 06		
CleanAir		
Sample Name:	Cal 06	Sample Vol: 1.0 mL
Vial Number:	2	Channel: ECD_1
Sample Type:	standard	ICS Condu 48.928
Control Program:	AS40Inj2	ICS Pressu 1245.96
Quantif. Method:	default	Dilution Fa: 1.0X
Run Time (min):	20.00	Sample ID:
		Replicate II




No.	Ret. Time min	Peak Name	Area µS*min	Rel. Area %	Type	PGF
1	6.61	Chloride	2.0868	100.00	BM *	0.93
Total:			2.087	100.000	0.00	

46 Cal 01		
CleanAir		
Sample Name:	Cal 01	Sample Vo. 1.0 mL
Vial Number:	2	Channel: ECD_1
Sample Type:	standard	ICS Condu 52.182
Control Program:	AS40Inj1	ICS Pressu 1264.49
Quantif. Method:	default	Dilution Fa 1.0X
Run Time (min):	20.00	Sample ID:
		Replicate II




No.	Ret. Time min	Peak Name	Area µS*min	Rel. Area %	Type	PGF
1	6.69	Chloride	0.1456	100.00	BMB*	0.94
Total:			0.146	100.000	0.00	

189 CCV	
CleanAir	
Sample Name:	CCV
Vial Number:	4
Sample Type:	validate
Control Program:	AS40Inj2
Quantif. Method:	default
Run Time (min):	20.00
Sample Vol:	1.0 mL
Channel:	ECD_1
ICS Condu:	57.711
ICS Pressu:	1407.61
Dilution Fa:	1.0X
Sample ID:	Replicate II




No.	Ret. Time min	Peak Name	Area µS*min	Rel. Area %	Type	PGF
1	7.63	Chloride	0.9110	100.00	BMB*	0.95
Total:			0.911	100.000	0.00	

194 0.1N H2SO4 Blank		
Reagent Blank		
Sample Name:	0.1N H2SO4 Blank	Sample Vo: 300.0 mL
Vial Number:	2	Channel: ECD_1
Sample Type:	unknown	ICS Condu 58.051
Control Program:	AS40Inj1	ICS Pressu 1409.28
Quantif. Method:	default	Dilution Fa: 1.0X
Run Time (min):	20.00	Sample ID: 28557-002
		Replicate II




No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	3.59	Fluoride	0.0544	0.00	BM	n.a.
2	5.69	n.a.	0.3474	0.03	BMB	1.23
3	8.70	n.a.	0.4915	0.04	Ru^	n.a.
4	8.88	n.a.	1.7266	0.13	MB^	0.56
5	16.33	Sulfate	1344.6083	99.81	BMB	1.51
Total:			1347.228	100.000	0.00	

195 0.1N H2SO4 Blank		
Reagent Blank		
Sample Name:	0.1N H2SO4 Blank	Sample Vo. 300.0 mL
Vial Number:	2	Channel: ECD_1
Sample Type:	unknown	ICS Condu 69.771
Control Program:	AS40Inj2	ICS Pressu 1388.48
Quantif. Method:	default	Dilution Fa 1.0X
Run Time (min):	20.00	Sample ID:
		Replicate II 28557-002




No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	5.66	n.a.	0.4416	0.03	BM	1.21
2	8.89	n.a.	2.3431	0.17	BMB^	0.93
3	16.26	Sulfate	1346.2704	99.79	BMB	1.51
Total:			1349.055	100.000	0.00	

197 U1 SDA Inlet R1		
U1 SDA Inlet		
Sample Name:	U1 SDA Inlet R1	Sample Vol. 836.6 mL
Vial Number:	3	Channel: ECD_1
Sample Type:	unknown	ICS Condu 56.851
Control Program:	AS40Inj2	ICS Pressu 1397.04
Quantif. Method:	default	Dilution Fa: 1000.0X
Run Time (min):	20.00	Sample ID:
		Replicate Il 28557-003




No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	7.55	Chloride	0.7847	38.41	BMB*	0.97
2	10.88	n.a.	0.0310	1.52	BMB	0.84
3	18.09	n.a.	1.2272	60.07	BMB	1.01
Total:			2.043	100.000	0.00	

198 U1 SDA Inlet R2	
U1 SDA Inlet	
Sample Name:	U1 SDA Inlet R2
Vial Number:	3
Sample Type:	unknown
Control Program:	AS40Inj1
Quantif. Method:	default
Run Time (min):	20.00
Sample Vol:	801.9 mL
Channel:	ECD_1
ICS Condu:	56.662
ICS Pressu:	1398.24
Dilution Fa:	1000.0X
Sample ID:	28557-004
Replicate:	11



No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	5.69	n.a.	0.0702	2.97	BMB	0.87
2	7.57	Chloride	0.9003	38.10	BM *	0.94
3	18.15	n.a.	1.3922	58.92	BMB	1.02
Total:			2.363	100.000	0.00	

199 U1 SDA Inlet R2		
U1 SDA Inlet		
Sample Name:	U1 SDA Inlet R2	Sample Vo. 801.9 mL
Vial Number:	3	Channel: ECD_1
Sample Type:	unknown	ICS Condu 56.683
Control Program:	AS40Inj2	ICS Pressu 1398.86
Quantif. Method:	default	Dilution Fa 1000.0X
Run Time (min):	20.00	Sample ID:
		Replicate IL 28557-004




No.	Ret.Time min	Peak Name	Area μ S*min	Rel.Area %	Type	PGF
1	5.77	n.a.	0.0809	3.56	BMB	0.93
2	7.65	Chloride	0.9341	41.14	BM *	0.91
3	11.63	n.a.	0.0408	1.80	BMB	0.93
4	18.34	n.a.	1.2150	53.51	BMB	0.95
Total:			2.271	100.000	0.00	

201 U1 SDA Inlet R3


U1 SDA Inlet

Sample Name:	U1 SDA Inlet R3	Sample Vo:	700.0 mL
Vial Number:	4	Channel:	ECD_1
Sample Type:	unknown	ICS Condu:	56.916
Control Program:	AS40Inj2	ICS Pressu:	1406.16
Quantif. Method:	default	Dilution Fa:	1000.OX
Run Time (min):	20.00	Sample ID:	
		Replicate Il:	28557-005




No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	7.77	Chloride	0.8035	35.19	BMB*	0.93
2	18.52	n.a.	1.4796	64.81	BMB	0.93
Total:			2.283	100.00	0.00	

203 U1 FF Outlet R1		
U1 FF Outlet		
Sample Name:	U1 FF Outlet R1	Sample Vo. 847.0 mL
Vial Number:	5	Channel: ECD_1
Sample Type:	unknown	ICS Condu 56.902
Control Program:	AS40Inj2	ICS Pressu 1411.29
Quantif. Method:	default	Dilution Fa: 50.0X
Run Time (min):	20.00	Sample ID:
		Replicate II 28557-006




No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	7.81	Chloride	0.6171	2.90	BMB*	0.95
2	18.66	n.a.	20.6775	97.10	BMB	0.98
Total:			21.295	100.000	0.00	

206 U1 FF Outlet R3		
U1 FF Outlet		
Sample Name:	U1 FF Outlet R3	Sample Vol: 766.0 mL
Vial Number:	1	Channel: ECD_1
Sample Type:	unknown	ICS Condu: 57.280
Control Program:	AS40Inj1	ICS Pressu: 1408.47
Quantif. Method:	default	Dilution Fa: 50.0X
Run Time (min):	20.00	Sample ID: 28557-008
		Replicate II




No.	Ret.Time min	Peak Name	Area μS*min	Rel.Area %	Type	PGF
1	7.86	Chloride	0.5809	2.44	BM *	0.92
2	18.79	n.a.	23.2082	97.56	BMB	0.99
Total:			23.789	100.000	0.00	

207 U1 FF Outlet R3		
U1 FF Outlet		
Sample Name:	U1 FF Outlet R3	Sample Vol: 766.0 mL
Vial Number:	1	Channel: ECD_1
Sample Type:	unknown	ICS Condu: 57.313
Control Program:	AS40Inj2	ICS Pressu: 1408.00
Quantif. Method:	default	Dilution Fa: 50.0X
Run Time (min):	20.00	Sample ID:
		Replicate #: 28557-008




No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	7.93	Chloride	0.5849	2.47	BM *	0.84
2	18.86	n.a.	23.1246	97.53	BMB	0.99
Total:			23.710	100.000	0.00	

208 U2 SDA Inlet R1		
U2 SDA Inlet		
Sample Name:	U2 SDA Inlet R1	Sample Vol: 737.0 mL
Vial Number:	2	Channel: ECD_1
Sample Type:	unknown	ICS Condu: 57.253
Control Program:	AS40Inj1	ICS Pressu: 1409.84
Quantif. Method:	default	Dilution Fac: 1000.0X
Run Time (min):	20.00	Sample ID: 28557-009
		Replicate II




No.	Ret.Time min	Peak Name	Area μ S*min	Rel.Area %	Type	PGF
1	7.91	Chloride	0.7673	37.11	BMB*	0.97
2	18.91	n.a.	1.3001	62.89	BMB	1.02
Total:			2.067	100.000	0.00	

218 U2 SDA Inlet R3		
U2 SDA Inlet		
Sample Name:	U2 SDA Inlet R3	Sample Vol: 790.0 mL
Vial Number:	1	Channel: ECD_1
Sample Type:	unknown	ICS Condu: 58.892
Control Program:	AS40Inj1	ICS Pressu: 1390.08
Quantif. Method:	default	Dilution Fa: 1000.0X
Run Time (min):	20.00	Sample ID: 28557-011
		Replicate II




No.	Ret. Time min	Peak Name	Area µS*min	Rel. Area %	Type	PGF
1	7.40	Chloride	0.6953	37.49	BMB*	0.93
2	17.86	n.a.	1.1595	62.51	BMB	0.99
Total:			1.855	100.000	0.00	

219 U2 SDA Inlet R3		
U2 SDA Inlet		
Sample Name:	U2 SDA Inlet R3	Sample Vol: 790.0 mL
Vial Number:	1	Channel: ECD_1
Sample Type:	unknown	ICS Condu: 58.534
Control Program:	AS40Inj2	ICS Pressu: 1383.44
Quantif. Method:	default	Dilution Fa: 1000.0X
Run Time (min):	20.00	Sample ID:
		Replicate II: 28557-011




No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	0.93	n.a.	0.0589	3.01	BMB	0.98
2	7.31	Chloride	0.6818	34.85	BMB*	0.96
3	17.84	n.a.	1.2158	62.14	BMB	0.95
Total:			1.957	100.000	0.00	

220 U2 FF Outlet R1		
U2 FF Outlet		
Sample Name:	U2 FF Outlet R1	Sample Vol: 896.6 mL
Vial Number:	2	Channel: ECD_1
Sample Type:	unknown	ICS Condu: 59.130
Control Program:	AS40Inj1	ICS Pressu: 1390.05
Quantif. Method:	default	Dilution Fa: 50.0X
Run Time (min):	20.00	Sample ID: 28557-012
		Replicate II




No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	7.48	Chloride	0.5624	3.06	BMB*	0.99
2	18.12	n.a.	17.8130	96.94	BMB	0.99
Total:			18.375	100.000	0.00	

221 U2 FF Outlet R1		
U2 FF Outlet		
Sample Name:	U2 FF Outlet R1	Sample Vol: 896.6 mL
Vial Number:	2	Channel: ECD_1
Sample Type:	unknown	ICS Condu: 59.001
Control Program:	AS40Inj2	ICS Pressu: 1393.89
Quantif. Method:	default	Dilution Fa: 50.0X
Run Time (min):	20.00	Sample ID:
		Replicate #: 28557-012




No.	Ret. Time min	Peak Name	Area μS*min	Rel. Area %	Type	PGF
1	7.48	Chloride	0.5584	3.00	BMB*	0.98
2	18.10	n.a.	18.0757	97.00	BMB	0.99
Total:			18.634	100.000	0.00	

222 U2 FF Outlet R2		
U2 FF Outlet		
Sample Name:	U2 FF Outlet R2	Sample Vo.861.4 mL
Vial Number:	3	Channel: ECD_1
Sample Type:	unknown	ICS Condu.58.746
Control Program:	AS40Inj1	ICS Pressu.1393.42
Quantif. Method:	default	Dilution Fa.50.0X
Run Time (min):	20.00	Sample ID: 28557-013
		Replicate II



No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	7.36	Chloride	0.4163	2.14	BMB*	0.99
2	17.82	n.a.	19.0109	97.86	BMB	0.99
Total:			19.427	100.000	0.00	

223 U2 FF Outlet R2		
U2 FF Outlet		
Sample Name:	U2 FF Outlet R2	Sample Vol: 861.4 mL
Vial Number:	3	Channel: ECD_1
Sample Type:	unknown	ICS Condu: 58.925
Control Program:	AS40Inj2	ICS Pressu: 1389.47
Quantif. Method:	default	Dilution Fac: 50.0X
Run Time (min):	20.00	Sample ID:
		Replicate #: 28557-013




No.	Ret. Time min	Peak Name	Area $\mu\text{S} \cdot \text{min}$	Rel. Area %	Type	PGF
1	6.28	n.a.	0.0424	0.21	BMB	1.24
2	7.47	Chloride	0.4264	2.16	MB*	0.98
3	18.08	n.a.	19.2553	97.62	BMB	0.99
Total:			19.724	100.000	0.00	

226 U3 SDA Inlet R1

U3 SDA Inlet

Sample Name:	U3 SDA Inlet R1	Sample Vol:	725.0 mL
Vial Number:	5	Channel:	ECD_1
Sample Type:	unknown	ICS Condu:	59.071
Control Program:	AS40Inj1	ICS Pressu:	1385.87
Quantif. Method:	default	Dilution Fa:	1000.0X
Run Time (min):	20.00	Sample ID:	28557-015
		Replicate:	II




No.	Ret. Time min	Peak Name	Area µS*min	Rel. Area %	Type	PGF
1	7.52	Chloride	0.9827	44.42	BM *	0.94
2	18.16	n.a.	1.2294	55.58	BMB	1.00
Total:			2.212	100.000	0.00	

227 U3 SDA Inlet R1

U3 SDA Inlet

Sample Name:	U3 SDA Inlet R1	Sample Vo.725.0 mL
Vial Number:	5	Channel: ECD_1
Sample Type:	unknown	ICS Condu.58.797
Control Program:	AS40Inj2	ICS Pressu 1389.74
Quantif. Method:	default	Dilution Fac 1000.0X
Run Time (min):	20.00	Sample ID:
		Replicate II 28557-016




No.	Ret.Time min	Peak Name	Area μ S*min	Rel.Area %	Type	PGF
1	7.46	Chloride	0.9997	43.49	BMB*	0.92
2	9.07	n.a.	0.0449	1.96	BMB	1.35
3	18.17	n.a.	1.2539	54.55	BMB	0.99
Total:			2.299	100.000	0.00	

229 U3 SDA Inlet R2


U3 SDA Inlet

Sample Name:	U3 SDA Inlet R2	Sample Vol:	701.0 mL
Vial Number:	6	Channel:	ECD_1
Sample Type:	unknown	ICS Condu:	58.572
Control Program:	AS40Inj2	ICS Pressu:	1386.00
Quantif. Method:	default	Dilution Fa:	1000.0X
Run Time (min):	20.00	Sample ID:	
		Replicate #:	28557-015




No.	Ret. Time min	Peak Name	Area µS*min	Rel. Area %	Type	PGF
1	7.39	Chloride	0.9520	39.65	BMB*	0.96
2	17.96	n.a.	1.4487	60.35	BMB	1.01
Total:			2.401	100.000	0.00	

234 U3 FF Outlet R2		
U3 FF Outlet		
Sample Name:	U3 FF Outlet R2	Sample Vol: 956.0 mL
Vial Number:	3	Channel: ECD_1
Sample Type:	unknown	ICS Condu: 59.416
Control Program:	AS40Inj1	ICS Pressu: 1391.93
Quantif. Method:	default	Dilution Fa: 50.0X
Run Time (min):	20.00	Sample ID: 28557-019
		Replicate II




No.	Ret. Time min	Peak Name	Area μS*min	Rel. Area %	Type	PGF
1	7.55	Chloride	0.5753	3.29	BMB*	0.99
2	18.21	n.a.	16.9045	96.71	BMB	0.99
Total:			17.480	100.000	0.00	

235 U3 FF Outlet R2		
U3 FF Outlet		
Sample Name:	U3 FF Outlet R2	Sample Vol: 956.0 mL
Vial Number:	3	Channel: ECD_1
Sample Type:	unknown	ICS Condu: 58.712
Control Program:	AS40Inj2	ICS Pressu: 1389.05
Quantif. Method:	default	Dilution Fa: 50.0X
Run Time (min):	20.00	Sample ID:
		Replicate #: 28557-019




No.	Ret. Time min	Peak Name	Area µS*min	Rel. Area %	Type	PGF
1	5.71	n.a.	0.0754	0.42	BMB	1.19
2	7.54	Chloride	0.5856	3.24	BMB*	0.97
3	18.31	n.a.	17.4210	96.34	BMB	0.99
Total:			18.082	100.000	0.00	

241 CCV	
CleanAir	
Sample Name:	CCV
Vial Number:	6
Sample Type:	validate
Control Program:	AS40Inj2
Quantif. Method:	default
Run Time (min):	20.00
Sample Vol:	1.0 mL
Channel:	ECD_1
ICS Condu:	58.900
ICS Pressu:	1383.39
Dilution Fax:	1.0X
Sample ID:	
Replicate:	II




No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	7.55	Chloride	0.9352	100.00	BMB*	0.94
Total:			0.935	100.000	0.00	

244 Audit Sample L3937		
Audit Sample		
Sample Name:	Audit Sample L3937	Sample Vol. 500.0 mL
Vial Number:	2	Channel: ECD_1
Sample Type:	unknown	ICS Condu. 59.067
Control Program:	AS40Inj1	ICS Pressu 1385.31
Quantif. Method:	default	Dilution Fac 50.0X
Run Time (min):	20.00	Sample ID: 28557-021
		Replicate II




No.	Ret. Time min	Peak Name	Area µS*min	Rel. Area %	Type	PGF
1	6.10	n.a.	0.0903	10.80	BMB	1.58
2	7.57	Chloride	0.5825	69.65	BMB*	0.96
3	18.41	n.a.	0.1635	19.55	BMB	1.00
Total:			0.836	100.000	0.00	

245 Audit Sample L3937		
Audit Sample		
Sample Name:	Audit Sample L3937	Sample Vol: 500.0 mL
Vial Number:	2	Channel: ECD_1
Sample Type:	unknown	ICS Condu: 59.349
Control Program:	AS40Inj2	ICS Pressu: 1389.02
Quantif. Method:	default	Dilution Fac: 50.0X
Run Time (min):	20.00	Sample ID:
		Replicate #: 28557-021




No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	7.59	Chloride	0.5622	85.35	BMB*	1.00
2	18.26	n.a.	0.0965	14.65	BMB	1.07
Total:			0.659	100.00	0.00	

246 Audit Sample L3586		
Audit Sample		
Sample Name:	Audit Sample L3586	Sample Vol: 500.0 mL
Vial Number:	3	Channel: ECD_1
Sample Type:	unknown	ICS Condu: 58.802
Control Program:	AS40Inj1	ICS Pressu: 1384.01
Quantif. Method:	default	Dilution Fa: 200.0X
Run Time (min):	20.00	Sample ID: 28557-022
		Replicate II



No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	7.55	Chloride	0.6088	100.00	BMB*	0.98
Total:			0.609	100.000	0.00	

247 Audit Sample L3586		
Audit Sample		
Sample Name:	Audit Sample L3586	Sample Vol. 500.0 mL
Vial Number:	3	Channel: ECD_1
Sample Type:	unknown	ICS Condu. 58.864
Control Program:	AS40Inj2	ICS Pressu 1385.76
Quantif. Method:	default	Dilution Fac 200.0X
Run Time (min):	20.00	Sample ID:
		Replicate II 28557-022




No.	Ret. Time min	Peak Name	Area $\mu\text{S} \cdot \text{min}$	Rel. Area %	Type	PGF
1	7.56	Chloride	0.6272	88.93	BMB*	0.97
2	18.43	n.a.	0.0780	11.07	BMB	0.85
Total:			0.705	100.000	0.00	

258 Matrix Spike

U1 SDA Inlet

Sample Name:	Matrix Spike	Sample Vol: 700.0 mL
Vial Number:	3	Channel: ECD_1
Sample Type:	spiked	ICS Condu: 58.913
Control Program:	AS40Inj1	ICS Pressu: 1395.27
Quantif. Method:	default	Dilution Fac: 1000.0X
Run Time (min):	20.00	Sample ID: 28557-005
		Replicate II




No.	Ret. Time min	Peak Name	Area $\mu\text{S} \cdot \text{min}$	Rel. Area %	Type	PGF
1	2.19	n.a.	0.0397	1.68	BMB	1.13
2	6.33	n.a.	0.0712	3.02	BMB	n.a.
3	7.95	Chloride	1.5481	65.64	BMB*	0.96
4	19.23	n.a.	0.6996	29.66	BMB	1.01
Total:			2.359	100.000	0.00	

259 Matrix Spike


U1 SDA Inlet

Sample Name:	Matrix Spike	Sample Vo.	700.0 mL
Vial Number:	3	Channel:	ECD_1
Sample Type:	spiked	ICS Condu.	58.752
Control Program:	AS40Inj2	ICS Pressu	1391.13
Quantif. Method:	default	Dilution Fac	1000.0X
Run Time (min):	20.00	Sample ID:	
		Replicate II	28557-005




No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	6.91	n.a.	0.1580	6.77	BMB	1.73
2	8.06	Chloride	1.5870	67.97	BMB*	0.95
3	19.45	n.a.	0.5899	25.26	BMB	1.09
Total:			2.335	100.000	0.00	

260 Matrix Spike		
U1 SDA Inlet		
Sample Name:	Matrix Spike	Sample Vo:700.0 mL
Vial Number:	4	Channel: ECD_1
Sample Type:	spiked	ICS Condu:58.938
Control Program:	AS40Inj1	ICS Pressu:1384.96
Quantif. Method:	default	Dilution Fa:1000.0X
Run Time (min):	20.00	Sample ID: 28557-005
		Replicate II




No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	8.12	Chloride	1.5834	73.29	BMB*	0.96
2	19.55	n.a.	0.5771	26.71	BMB	1.16
Total:			2.161	100.000	0.00	

261 Matrix Spike		
U1 SDA Inlet		
Sample Name:	Matrix Spike	Sample Vol: 700.0 mL
Vial Number:	4	Channel: ECD_1
Sample Type:	spiked	ICS Condu: 58.844
Control Program:	AS40Inj2	ICS Pressu: 1384.65
Quantif. Method:	default	Dilution Fa: 1000.0X
Run Time (min):	20.00	Sample ID:
		Replicate #: 28557-005




No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	8.19	Chloride	1.5810	84.80	BMB*	0.98
2	19.76	n.a.	0.2834	15.20	BMB	1.23
Total:			1.864	100.000	0.00	

262 Matrix Spike		
U3 FF Outlet		
Sample Name:	Matrix Spike	Sample Vo.802.0 mL
Vial Number:	5	Channel: ECD_1
Sample Type:	spiked	ICS Condu.61.041
Control Program:	AS40Inj1	ICS Pressu.1429.66
Quantif. Method:	default	Dilution Fac.50.0X
Run Time (min):	20.00	Sample ID: 28557-020
		Replicate II




No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	2.40	n.a.	0.0907	0.70	BMB	1.34
2	3.18	n.a.	0.0765	0.59	BM	n.a.
3	3.53	Fluoride	0.0886	0.69	MB	n.a.
4	6.95	n.a.	0.0678	0.53	BMB	1.08
5	7.75	Chloride	1.4216	11.02	BMB*	1.00
6	8.73	n.a.	0.3271	2.54	BMB	0.47
7	9.63	n.a.	0.1983	1.54	BM	n.a.
8	10.11	n.a.	0.1902	1.47	M	n.a.
9	10.57	n.a.	0.1036	0.80	M	n.a.
10	11.06	n.a.	0.0398	0.31	MB	0.95
11	17.01	n.a.	0.0534	0.41	BMB	1.23

264 Matrix Spike		
U3 FF Outlet		
Sample Name:	Matrix Spike	Sample Vol: 802.0 mL
Vial Number:	6	Channel: ECD_1
Sample Type:	spiked	ICS Condu: 61.224
Control Program:	AS40Inj1	ICS Pressu: 1424.69
Quantif. Method:	default	Dilution Fac: 50.0X
Run Time (min):	20.00	Sample ID: 28557-020
		Replicate II




No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	0.92	n.a.	0.0605	0.46	BMB	1.18
2	1.37	n.a.	0.0477	0.36	BM	n.a.
3	1.73	n.a.	0.1117	0.84	MB	n.a.
4	2.45	n.a.	0.1102	0.83	BMB	1.36
5	3.17	n.a.	0.1074	0.81	BMB	1.34
6	7.15	n.a.	0.0732	0.55	BMB	1.17
7	7.93	Chloride	1.4140	10.66	BMB*	1.02
8	10.03	n.a.	0.0435	0.33	BMB	1.14
9	10.75	n.a.	0.0818	0.62	BM	n.a.
10	11.24	n.a.	0.2918	2.20	MB	n.a.
11	12.90	n.a.	0.0870	0.66	BMB	1.25

266 Matrix Spike		
Audit Sample		
Sample Name:	Matrix Spike	Sample Vol: 500.0 mL
Vial Number:	1	Channel: ECD_1
Sample Type:	spiked	ICS Condu: 61.429
Control Program:	AS40Inj1	ICS Pressu: 1430.71
Quantif. Method:	default	Dilution Fac: 50.0X
Run Time (min):	20.00	Sample ID: 28557-021
		Replicate II




No.	Ret. Time min	Peak Name	Area µS*min	Rel. Area %	Type	PGF
1	3.28	n.a.	0.0572	2.27	BM	1.09
2	3.64	Fluoride	0.1568	6.21	MB	1.16
3	6.37	n.a.	0.1277	5.06	BMB	0.81
4	6.80	n.a.	0.0412	1.63	BMB	0.90
5	7.80	Chloride	1.3853	54.91	BMB*	1.02
6	11.50	n.a.	0.0727	2.88	BMB	0.97
7	12.70	n.a.	0.1814	7.19	BM	n.a.
8	13.00	n.a.	0.0473	1.88	MB	n.a.
9	13.30	n.a.	0.0342	1.36	BMB	1.13
10	15.52	Sulfate	0.0915	3.63	BM	n.a.
11	17.34	n.a.	0.2303	9.13	BM	n.a.

267 Matrix Spike		
Audit Sample		
Sample Name:	Matrix Spike	Sample Vol: 500.0 mL
Vial Number:	1	Channel: ECD_1
Sample Type:	spiked	ICS Condu: 61.771
Control Program:	AS40Inj2	ICS Pressu: 1432.12
Quantif. Method:	default	Dilution Fac: 50.0X
Run Time (min):	20.00	Sample ID:
		Replicate #: 28557-021




No.	Ret.Time min	Peak Name	Area μ S*min	Rel.Area %	Type	PGF
1	2.55	n.a.	0.2371	11.96	BMB	1.31
2	3.84	Fluoride	0.0354	1.79	BM	1.23
3	8.18	Chloride	1.4529	73.28	BMB*	0.99
4	9.16	n.a.	0.0649	3.27	BMB*	1.09
5	13.97	n.a.	0.0742	3.74	BMB	1.22
6	14.71	n.a.	0.0836	4.22	BMB	0.87
7	19.35	n.a.	0.0346	1.74	BMB	1.03
Total:			1.983	100.000	0.00	

271 Cal 01		
CleanAir		
Sample Name:	Cal 01	Sample Vol: 1.0 mL
Vial Number:	6	Channel: ECD_1
Sample Type:	standard	ICS Condu: 54.036
Control Program:	AS40Inj2	ICS Pressu: 1453.92
Quantif. Method:	default	Dilution Fac: 1.0X
Run Time (min):	20.00	Sample ID:
		Replicate II




No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	7.95	Chloride	0.1420	100.00	BMB*	1.01
Total:			0.142	100.000	0.00	

272 Cal 02		
CleanAir		
Sample Name:	Cal 02	Sample Vol: 1.0 mL
Vial Number:	1	Channel: ECD_1
Sample Type:	standard	ICS Condu: 54.014
Control Program:	AS40Inj1	ICS Pressu: 1453.97
Quantif. Method:	default	Dilution Fac: 1.0X
Run Time (min):	20.00	Sample ID:
		Replicate II




No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	6.17	n.a.	0.0688	15.05	BMB	1.57
2	7.94	Chloride	0.3885	84.95	BMB*	0.98
Total:			0.457	100.000	0.00	

274 Cal 03		
CleanAir		
Sample Name:	Cal 03	Sample Vo.1.0 mL
Vial Number:	2	Channel: ECD_1
Sample Type:	standard	ICS Condu.53.970
Control Program:	AS40Inj1	ICS Pressu 1448.22
Quantif. Method:	default	Dilution Fac 1.0X
Run Time (min):	20.00	Sample ID:
		Replicate II




No.	Ret.Time min	Peak Name	Area $\mu\text{S}\cdot\text{min}$	Rel.Area %	Type	PGF
1	7.82	Chloride	0.7367	95.74	BMB*	0.96
2	16.59	Sulfate	0.0328	4.26	BMB	0.73
Total:			0.770	100.000	0.00	

275 Cal 03		
CleanAir		
Sample Name:	Cal 03	Sample Vol: 1.0 mL
Vial Number:	2	Channel: ECD_1
Sample Type:	standard	ICS Condu: 53.883
Control Program:	AS40Inj2	ICS Pressu: 1444.31
Quantif. Method:	default	Dilution Fa: 1.0X
Run Time (min):	20.00	Sample ID:
		Replicate II




No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	7.72	Chloride	0.7452	100.00	BMB*	0.96
Total:			0.745	100.000	0.00	

276 Cal 04		
CleanAir		
Sample Name:	Cal 04	Sample Vol: 1.0 mL
Vial Number:	3	Channel: ECD_1
Sample Type:	standard	ICS Condu: 54.100
Control Program:	AS40Inj1	ICS Pressu: 1444.94
Quantif. Method:	default	Dilution Fac: 1.0X
Run Time (min):	20.00	Sample ID:
		Replicate II




No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	7.65	Chloride	1.0944	100.00	BMB*	0.95
Total:			1.094	100.000	0.00	

277 Cal 04		
CleanAir		
Sample Name:	Cal 04	Sample Vo.1.0 mL
Vial Number:	3	Channel: ECD_1
Sample Type:	standard	ICS Condu.53.886
Control Program:	AS40Inj2	ICS Pressu 1445.27
Quantif. Method:	default	Dilution Fa 1.0X
Run Time (min):	20.00	Sample ID:
		Replicate II



No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	7.53	Chloride	1.0912	100.00	BMB*	0.95
Total:			1.091	100.000	0.00	

279 Cal 05		
CleanAir		
Sample Name:	Cal 05	Sample Vo.1.0 mL
Vial Number:	4	Channel: ECD_1
Sample Type:	standard	ICS Condu.54.470
Control Program:	AS40Inj2	ICS Pressu 1423.80
Quantif. Method:	default	Dilution Fa:1.0X
Run Time (min):	20.00	Sample ID:
		Replicate II



No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	7.16	Chloride	1.3582	100.00	BMB*	0.95
Total:			1.358	100.000	0.00	

CHAIN OF CUSTODY FORM

M26A-NB-10955-002

CLIENT <u>Wheelabrator North Broward</u>	PROJECT NO. <u>10955</u>	NO. OF CONTAINERS	ORIGINAL VOLUME	ANALYSIS REQUESTED				ADDITIONAL INFORMATION
PLANT <u>Same</u>	DEPT. <u>66</u>							
PROJECT MANAGER <u>Scott Brown</u>								

CLEANAIR LAB NO.	RUN NO.	TEST LOCATION	DATE	SAMPLE MATRIX	NO. OF CONTAINERS	ORIGINAL VOLUME	ANALYSIS REQUESTED	ADDITIONAL INFORMATION
R	1	Unit 1 FF Outlet	3/18/2010	Imp. 1,2,3 Catch + Rinse	1		X	
R	2		3/18/2010	Imp. 1,2,3 Catch + Rinse	1		X	
R	3	V	3/18/2010	Imp. 1,2,3 Catch + Rinse	1		X	
R	1	Unit 2 FF Outlet	3/17/2010	Imp. 1,2,3 Catch + Rinse	1		X	
R	2		3/17/2010	Imp. 1,2,3 Catch + Rinse	1		X	
R	3	V	3/17/2010	Imp. 1,2,3 Catch + Rinse	1		X	
R	1	Unit 3 FF Outlet	3/16/2010	Imp. 1,2,3 Catch + Rinse	1		X	
R	2		3/16/2010	Imp. 1,2,3 Catch + Rinse	1		X	
R	3	V	3/16/2010	Imp. 1,2,3 Catch + Rinse	1		X	
R	NA	Audit Sample	17-Mar	4436-01	1		X	L3586
R	NA	Audit Sample	17-Mar	4436-02	1		X	L3937

Relinquished by: (Signature) <i>Scott Brown</i>	Date / Time 3/28/10	Received by: (Signature) <i>[Signature]</i>	Date / Time 3/29/10 1200	Relinquished by: (Signature)	Date / Time
Courier:	Date / Time	Relinquished by: (Signature)	Date / Time	Received for Analysis by:	Date / Time

Special Handling Instructions	This form was completed by: Scott Brown	<p>500 West Wood Street Palatine, IL 60067 (800) 627-0033 ph (847) 991-3385 fax www.cleanair.com</p> <p><small>LDS001A-COC Palatine, Jul 2002 Copyright © 2002 Clean Air Engineering Inc.</small></p>
Forwarding Lab: <u>Palatine</u>	Signature <i>Scott Brown</i>	
PO Number: _____	Date 3/18/10	

1-380 Box 2

CHAIN OF CUSTODY FORM

M26A-NB-10955-001

CLIENT Wheelabrator North Broward
 PLANT Same
 PROJECT MANAGER Scott Brown

PROJECT NO. 10955
 DEPT. 66

NO. OF CONTAINERS	ORIGINAL VOLUME	ANALYSIS REQUESTED				ADDITIONAL INFORMATION
		HCl				
		X				
		X				
		X				
		X				
		X				
		X				
		X				
		X				
		X				
		X				

CLEANAIR LAB NO.	RUN NO.	TEST LOCATION	DATE	SAMPLE MATRIX	NO. OF CONTAINERS	ORIGINAL VOLUME	HCl				ADDITIONAL INFORMATION
R	1	Unit 1 Inlet	3/18/2010	Imp. 1,2,3 Catch + Rinse	1		X				
R	2		3/18/2010	Imp. 1,2,3 Catch + Rinse	1		X				
R	3	V	3/18/2010	Imp. 1,2,3 Catch + Rinse	1		X				
R	1	Unit 2 Inlet	3/17/2010	Imp. 1,2,3 Catch + Rinse	1		X				
R	2		3/17/2010	Imp. 1,2,3 Catch + Rinse	1		X				
R	3	V	3/17/2010	Imp. 1,2,3 Catch + Rinse	1		X				
R	1	Unit 3 Inlet	3/16/2010	Imp. 1,2,3 Catch + Rinse	1		X				
R	2		3/16/2010	Imp. 1,2,3 Catch + Rinse	1		X				
R	3	V	3/16/2010	Imp. 1,2,3 Catch + Rinse	1		X				
R	NA	Reagent Blank	16-Mar	0.1 N H2SO4	1		X				
R	NA	Reagent Blank	16-Mar	DI H2O	1		X				

Relinquished by: (Signature)	Date / Time	Received by: (Signature)	Date / Time	Relinquished by: (Signature)	Date / Time
		<i>[Signature]</i>	3/21/10 1:00		
Courier:	Date / Time	Relinquished by: (Signature)	Date / Time	Received for Analysis by:	Date / Time

Special Handling Instructions Forwarding Lab: <u>Palatine</u> PO Number: _____	This form was completed by: Scott Brown Signature _____ Date _____	 500 West Wood Street Palatine, IL 60067 (800) 627-0033 ph (847) 991-3385 fax www.cleanair.com <small>LDS001A-COC Palatine, Jul 2002 Copyright © 2002 Clean Air Engineering Inc.</small>
--	--	--

I - 381

CHAIN OF CUSTODY FORM

M13B-NB-10955--001.

CLIENT <u>Wheelabrator North Broward</u>	PROJECT NO. <u>10955</u>	NO. OF CONTAINERS	ORIGINAL VOLUME	ANALYSIS REQUESTED				ADDITIONAL INFORMATION						
PLANT <u>Same</u>	DEPT. <u>66</u>			<table border="1" style="width: 100%; height: 100px;"> <tr> <td style="width: 10%; text-align: center;">Fluorides</td> <td style="width: 15%;"></td> </tr> </table>					Fluorides					
Fluorides														
PROJECT MANAGER <u>Scott Brown</u>														

CLEANAIR LAB NO.	RUN NO.	TEST LOCATION	DATE	SAMPLE MATRIX	NO. OF CONTAINERS	ORIGINAL VOLUME	ANALYSIS REQUESTED				ADDITIONAL INFORMATION	
R	1	Unit 1 FF Outlet	3/17/2010	Imp. 1,2 ,3 Catch + Rinse	1		X					
R	2		3/17/2010	Imp. 1,2 ,3 Catch + Rinse	1		X					
R	3	V	3/17/2010	Imp. 1,2 ,3 Catch + Rinse	1		X					
D	1	Unit 2 FF Outlet	3/18/2010	Imp. 1,2 ,3 Catch + Rinse	1		X					
R	2		3/18/2010	Imp. 1,2 ,3 Catch + Rinse	1		X					
R	3	V	3/18/2010	Imp. 1,2 ,3 Catch + Rinse	1		X					
R	1	Unit 3 FF Outlet	3/16/2010	Imp. 1,2 ,3 Catch + Rinse	1		X					
R	2		3/16/2010	Imp. 1,2 ,3 Catch + Rinse	1		X					
R	3	V	3/16/2010	Imp. 1,2 ,3 Catch + Rinse	1		X					
R	NA	Reagent Blank	17-Mar	DI H2O			X					

Relinquished by: (Signature)	Date / Time	Received by: (Signature)	Date / Time	Relinquished by: (Signature)	Date / Time
		<i>[Signature]</i>	5/24/10 12:00		
Courier:	Date / Time	Relinquished by: (Signature)	Date / Time	Received for Analysis by:	Date / Time

Special Handling Instructions Forwarding Lab: <u>Palatine</u> PO Number: _____	This form was completed by: Scott Brown Signature _____ Date _____	 <p style="font-size: small;">LDS001A-COC Palatine, Jul 2002 Copyright © 2002 Clean Air Engineering Inc.</p>	500 West Wood Street Palatine, IL 60067 (800) 627-0033 ph (847) 991-3385 fax www.cleanair.com
--	--	---	---

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10955
 Unit 1 FF Outlet

USEPA Method 13B Fluoride Laboratory Data Summary

Run No.	Blank	1	2	3
Date (2010)		Mar 17	Mar 17	Mar 17
Start Time (approx.)		11:46	13:15	14:45
Stop Time (approx.)		12:56	14:27	15:53

DRAFT LAB DATA

MDL Min. detectable limit (mg F⁻/liter) 0.0080

HF as Total Fluoride

B_F Blank concentration (mg F⁻/liter) <0.0380

S _{F-1}	Fraction 1 concentration (mg F ⁻ /liter)	<0.0380	<0.0380	<0.0380
S _{F-2}	Fraction 2 concentration (mg F ⁻ /liter)			
V ₁	Fraction 1 sample volume (ml)	920.0	846.0	972.0
V ₂	Fraction 2 sample volume (ml)			
m _{HF}	HF collected before blank subtraction (mg)	<0.0368	<0.0339	<0.0389
m _b	Allowable blank subtraction (mg)	0.0000	0.0000	0.0000
m _{nb}	HF collected after blank subtraction (mg)	<0.0368	<0.0339	<0.0389
m _{MDL}	Minimum detectable HF (mg)	0.0078	0.0071	0.0082
m _n	Total HF used in emission calculations (mg)	<0.0368	<0.0339	<0.0389

041310 104014
 N

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10955
 Unit 2 FF Outlet

USEPA Method 13B Fluoride Laboratory Data Summary

Run No.	Blank	1	2	3
Date (2010)		Mar 18	Mar 18	Mar 18
Start Time (approx.)		07:09	08:56	10:45
Stop Time (approx.)		08:24	10:10	12:05

DRAFT LAB DATA

MDL Min. detectable limit (mg F⁻/liter) 0.0080

HF as Total Fluoride

B_F Blank concentration (mg F⁻/liter) <0.0380

S _{F-1}	Fraction 1 concentration (mg F ⁻ /liter)	<0.0380	<0.0380	<0.0380
S _{F-2}	Fraction 2 concentration (mg F ⁻ /liter)			
v ₁	Fraction 1 sample volume (ml)	900.0	862.0	884.0
v ₂	Fraction 2 sample volume (ml)			
m _{HF}	HF collected before blank subtraction (mg)	<0.0360	<0.0345	<0.0354
m _b	Allowable blank subtraction (mg)	0.0000	0.0000	0.0000
m _{nb}	HF collected after blank subtraction (mg)	<0.0360	<0.0345	<0.0354
m _{MDL}	Minimum detectable HF (mg)	0.0076	0.0073	0.0074
m _n	Total HF used in emission calculations (mg)	<0.0360	<0.0345	<0.0354

041310 104021
L

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10955
 Unit 3 FF Outlet

USEPA Method 13B Fluoride Laboratory Data Summary

Run No.	Blank	1	2	3
Date (2010)		Mar 16	Mar 16	Mar 16
Start Time (approx.)		11:49	13:33	15:07
Stop Time (approx.)		13:07	14:44	16:16

DRAFT LAB DATA

MDL Min. detectable limit (mg F⁻/liter) 0.0080

HF as Total Fluoride

B_F Blank concentration (mg F⁻/liter) <0.0380

S _{F-1}	Fraction 1 concentration (mg F ⁻ /liter)	<0.0380	<0.0380	<0.0380
S _{F-2}	Fraction 2 concentration (mg F ⁻ /liter)			
v ₁	Fraction 1 sample volume (ml)	897.0	870.0	815.0
v ₂	Fraction 2 sample volume (ml)			
m _{HF}	HF collected before blank subtraction (mg)	<0.0359	<0.0348	<0.0326
m _b	Allowable blank subtraction (mg)	0.0000	0.0000	0.0000
m _{nb}	HF collected after blank subtraction (mg)	<0.0359	<0.0348	<0.0326
m _{MDL}	Minimum detectable HF (mg)	0.0076	0.0073	0.0069
m _n	Total HF used in emission calculations (mg)	<0.0359	<0.0348	<0.0326

041310 104026
P

This Page Intentionally Left Blank

CleanAir.

CleanAir Engineering
500 W. Wood Street
Palatine, IL 60067-4975
800-627-0033
www.cleanair.com



CleanAir®

CleanAir Engineering, Inc.
500 West Wood Street
Palatine, IL 60067

Laboratory Report

Customer Reference No: 10955

Laboratory Project No: 28557

Analytes

Fluoride

Customer

Palatine Engineering Group
500 W Wood St
Palatine, IL 60067

Revision 0 - Dated: 04/09/2010

This Page Intentionally Left Blank

Analysis Case Narrative
Ion Chromatography Analysis

Client Name:	Palatine Engineering Group	Date Received:	3/29/2010
Plant/Facility:	Wheelabrator North Broward	Date Reported:	4/7/2010
Laboratory Project No:	28557	Sample Type:	Varied
Customer Reference No:	10955	Parameters:	Fluoride
Sample Numbers:	23-32	Received From:	Scott Brown
Applicable Analytical Method		U.S. EPA Method 26A	

Summary of Analysis

This report summarizes the results of the analysis performed on samples received on: 03/29/10
The samples were analyzed following procedures found in U.S. EPA Method 26A and U.S. EPA Method 300.1.

Detection Limits

Method Detection Limits have been determined in accordance with procedures in 40 CFR 136, Appendix B. Documentation showing the determination of detection limits are included with this report.

Sample Preparation

Samples were prepared according to the procedures listed in the EPA Method above. Each sample was analyzed at full strength and a dilution was prepared if necessary to achieve a concentration that was within calibration range limits.

Standard Tracability

Each calibration standard has been prepared in accordance with US EPA Method 300.1 and US EPA Method 26 and has been designated an original lot number. This number can be used to trace back to the original dry salts used in the preparation of these standards. This number is included on the calibration page of this report.

Instrument Calibration

Instrument calibration followed regulations found in US EPA Method 300.1 and U.S. EPA Method 26A. Calibration standards were prepared from ACS grade dry salts as per section 7.3 of US EPA Method 300.1. As per section 4.2.2 of US EPA CTM-027, a series of 6 diluted standards are prepared from the original calibration standard and run through the column in duplicate from lowest concentration to highest. The average peak area for each calibration point is gathered and plotted against the expected solution concentration. In accordance with section 7.2.3 of EPA Method 9057, a least-squares regression with an r^2 value of .995 or greater must be produced from the resulting curve. In accordance with US EPA Method 26 a full post-test calibration is performed. The pre test calibration and post test calibration average peak area for any standard must agree within $\pm 5\%$ of any observed area.

Chromatograms

All chromatograms are included as an appendix of this report. Please note: Chromatograms marked as "End" are place markers meant to signify the end of a batch run and are purposely left blank as no data was acquired for that run.

Analysis QA/QC

Many elements of various EPA methods have been combined and are adhered to:

EPA Method 300.1 quality procedures:

- 1 Before the first sample was analyzed and every twenty samples thereafter (and before the post-test calibration) a laboratory blank and a Continuing Calibration Verification (CCV) were analyzed. The CCV is prepared from the same calibration standard as used to create the 7 diluted standards that make up the calibration curve. The laboratory blank must show a regression concentration of zero, and the CCV must show a regression concentration within 10 percent of the expected concentration
- 2 After the first ten samples and every twenty there after, a Quality Control (QC) sample was analyzed.

Analysis Case Narrative
Ion Chromatography Analysis

Client Name:	Palatine Engineering Group	Date Received:	3/29/2010
Plant/Facility:	Wheelabrator North Broward	Date Reported:	4/7/2010
Laboratory Project No:	28557	Sample Type:	Varied
Customer Reference No:	10955	Parameters:	Fluoride
Sample Numbers:	23-32	Received From:	Scott Brown
Applicable Analytical Method	U.S. EPA Method 26A		

The QC sample was created using ACS grade dry salts from a different manufacturer and or lot number than for the salts used to create the calibration standards.

The QC must meet the same acceptance criteria as noted for the CCV above.

- 3 A matrix spike analysis was performed on ten percent of the total number of samples. This sample was prepared with equal amounts of a sample and a calibration standard whose concentration was known to be larger than that of the sample.

The matrix spike is acceptable when the recovery is found to be 100 ± 10 percent.

- 4 As a measure of precision, all matrix spikes were prepared and analyzed in duplicate. The average area count of two identical matrix spikes may not have a relative percent difference of more than 10 percent.

EPA Method 26 quality procedure:

- 1 As per section 11.1.3, every sample was analyzed in duplicate and the mean area count used to determine the concentration. The duplicate area counts must have a relative percent difference of no greater than five percent. If this was the case, a third injection was made and the average of the three injections was used to determine the concentration.

EPA Method 7E quality procedures:

- 1 Each point on the calibration curve should be within ± 2 percent of the calibration span of the curve used.

Other CleanAir quality procedures:

- 1 The observed concentration value of each point on the calibration curve should have a relative percent difference of no more than 10 percent from its expected concentration.

Additional Comments

This report shall in no way be reproduced except in full without the prior written approval of Clean Air Analytical Laboratory management.

CleanAir Lab Services is accredited by NELAC through the state of Texas for this analysis. Our certificate number is T104704431-09-TX and expires 6/10/2010.

CERTIFICATE OF ANALYSIS

Client Name: Palatine Engineering Group
Plant/Facility: Wheelabrator North Broward
Lab Project No: 28557
Sample Numbers: 23-32

Date Received: 3/29/2010
Date Reported: 4/7/2010
Sample Type: Varied
Parameters: Fluoride

Laboratory Number	Sample Identification	Sample Volume (ml)	Fluoride Sample Conc. (mg/L)	Detection Limit (mg/L)	Reporting Limit (mg/L)
Reagent Blank					
28557-23	DI H2O Blank	303	<	0.008	0.038
Unit 1					
28557-24	U1 FF Outlet R1	920	<	0.008	0.038
28557-25	U1 FF Outlet R2	846	<	0.008	0.038
28557-26	U1 FF Outlet R3	972	<	0.008	0.038
Unit 2					
28557-27	U2 FF Outlet R1	900	<	0.008	0.038
28557-28	U2 FF Outlet R2	862	<	0.008	0.038
28557-29	U2 FF Outlet R3	884	<	0.008	0.038
Unit 3					
28557-30	U3 FF Outlet R1	897	<	0.008	0.038
28557-31	U3 FF Outlet R2	870	<	0.008	0.038
28557-32	U3 FF Outlet R3	815	<	0.008	0.038

To the best of our knowledge, the data presented in this report are accurate, complete, error free, legible and representative of the samples received by the laboratory.

Analyst: *Eric Ewing* Quality Leader, Lab Services: *Michael Tuegel*
 Eric Ewing
 email: eewing@cleanair.com
 Ph: 847-654-4519
 Michael Tuegel
 email: mtuegel@cleanair.com
 Ph: 847-654-4557



CleanAir.

CHROMATOGRAPHIC DATA REDUCTION

Client Palatine Engineering Group
 Lab Project No: 28557
 Analyte Fluoride
 Date 4/7/2010
 Stock Standard 502.62 mg/l
 Lot Number 03241002-64-00000-01
 Working Stock Conc. 5.0262 mg/l
 CCV 0.50 mg/l
 QC 139.55 mg/l
 Lot Number 03261002-64-00000-07

Analyte:

Fluoride Standards Calibration Data

Calibration Point Conc. (mg/l)	Date of Injection	1	2	3	4	5	6	7
Cal 1 Trial 1	03/29/2010	0.0000	0.0573	0.1583	0.2288	0.5777	0.7329	1.1434
Cal 1 Trial 2		0.0000	0.0600	0.1647	0.2330	0.5996	0.7458	1.1197
Cal 2 Trial 1	03/30/2010		0.0614					
Cal 2 Trial 2			0.0613					
Cal 3 Trial 1	03/31/2010		0.0572					
Cal 3 Trial 2			0.0599					
Cal 4 Trial 1	04/03/2010			0.1655	0.2207			
Cal 4 Trial 2				0.1670	0.2270			
Cal 5 Trial 1	04/05/2010		0.0558	0.1598	0.2270	0.5658	0.7039	1.1563
Cal 5 Trial 2			0.0560	0.1609	0.2207	0.5792	0.7084	1.1651

n	2	8	6	6	4	4	4
Average	0.0000	0.0586	0.1627	0.2262	0.5806	0.7228	1.1461
Standard Deviation	0.0000	0.0023	0.0035	0.0048	0.0140	0.0200	0.0197
%RSD	0.00	3.92	2.15	2.12	2.42	2.76	1.72

Quality Control Checks							
Measured Area Counts (Counts)	Actual Concentration (mg/L)	Regression Concentration (mg/L)	Difference pt-Line (% Scale)	Is Difference Less Than 2% of Scale?	Difference pt-Line (Relative %)	Is Relative Difference Less Than 10%?	
0.0000	0.000	0.009	-0.71%	Yes	0.00%	Yes	
0.0586	0.075	0.073	0.21%	Yes	3.49%	Yes	
0.1627	0.201	0.186	1.19%	Yes	7.44%	Yes	
0.2262	0.251	0.255	-0.31%	Yes	-1.56%	Yes	
0.5806	0.628	0.641	-1.02%	Yes	-2.04%	Yes	
0.7228	0.804	0.796	0.66%	Yes	1.04%	Yes	
1.1461	1.257	1.257	-0.02%	Yes	-0.02%	Yes	


Regression Constants		
Slope	m =	1.0888
Intercept	b =	0.0090
Coeff.	R ² =	0.9996

Is Coefficient of Regression > 0.995?	
Yes	

CHROMATOGRAPHIC DATA REDUCTION

Client Palatine Engineering Group
Lab Project No: 28557
Analyte Fluoride
Date 4/7/2010

Fluoride Calibration Curve



CleanAir.

CHROMATOGRAPHIC DATA REDUCTION

Client Palatine Engineering Group

Lab Project No: 28557

Analyte Fluoride

Date 4/7/2010

MDL=	0.008 mg/L	Average Flow Rate 0.81 mL/min
MRL=	0.038 mg/L	

Sample Location	Sample Identification Number	Sample Identification	Date of Injection	Area Counts Trial 1	Area Counts Trial 2	Area Count Average	DF (Analysis Dilution Factor)	V _{stdn} (Total Sample Volume, mL)	C _{Reg} (Concentration, mg/L from Reg Curve)	M _{analyte} Total Amount of Analyte (mg)
Reagent Blank	28557-23	DI H2O Blank	03/31/10	0.0000	0.0000	0.0000	1	303.0	<	<0.011
U1 FF Outlet	28557-24	U1 FF Outlet R1	03/31/10	0.0000	0.0000	0.0000	1	919.7	<	<0.035
U1 FF Outlet	28557-25	U1 FF Outlet R2	03/31/10	0.0000	0.0000	0.0000	1	846.0	<	<0.032
U1 FF Outlet	28557-26	U1 FF Outlet R3	03/31/10	0.0000	0.0000	0.0000	1	971.9	<	<0.036
U2 FF Outlet	28557-27	U2 FF Outlet R1	04/01/10	0.0000	0.0000	0.0000	1	900.0	<	<0.034
U2 FF Outlet	28557-28	U2 FF Outlet R2	04/01/10	0.0000	0.0000	0.0000	1	862.0	<	<0.032
U2 FF Outlet	28557-29	U2 FF Outlet R3	04/01/10	0.0000	0.0000	0.0000	1	884.0	<	<0.033
U3 FF Outlet	28557-30	U3 FF Outlet R1	04/01/10	0.0000	0.0000	0.0000	1	896.5	<	<0.034
U3 FF Outlet	28557-31	U3 FF Outlet R2	04/01/10	0.0000	0.0000	0.0000	1	870.0	<	<0.033
U3 FF Outlet	28557-32	U3 FF Outlet R3	04/01/10	0.0000	0.0000	0.0000	1	815.0	<	<0.031

CleanAir

CHROMATOGRAPHIC DATA REDUCTION

Client Palatine Engineering Group
Lab Project No: 28557
Analyte Fluoride
Date 4/7/2010

QUALITY CONTROL CHECKS

Sample Location	Sample Identification Number	Sample Identification	Date of Injection	Area Counts Trial 1	Area Counts Trial 2	Area Count Average	Area Count Duplicate Difference	Duplicate Relative Difference (%)
Reagent Blank	28557-23	DI H2O Blank	03/31/10	0.0000	0.0000	0.0000	na	na
U1 FF Outlet	28557-24	U1 FF Outlet R1	03/31/10	0.0000	0.0000	0.0000	na	na
U1 FF Outlet	28557-25	U1 FF Outlet R2	03/31/10	0.0000	0.0000	0.0000	na	na
U1 FF Outlet	28557-26	U1 FF Outlet R3	03/31/10	0.0000	0.0000	0.0000	na	na
U2 FF Outlet	28557-27	U2 FF Outlet R1	04/01/10	0.0000	0.0000	0.0000	na	na
U2 FF Outlet	28557-28	U2 FF Outlet R2	04/01/10	0.0000	0.0000	0.0000	na	na
U2 FF Outlet	28557-29	U2 FF Outlet R3	04/01/10	0.0000	0.0000	0.0000	na	na
U3 FF Outlet	28557-30	U3 FF Outlet R1	04/01/10	0.0000	0.0000	0.0000	na	na
U3 FF Outlet	28557-31	U3 FF Outlet R2	04/01/10	0.0000	0.0000	0.0000	na	na
U3 FF Outlet	28557-32	U3 FF Outlet R3	04/01/10	0.0000	0.0000	0.0000	na	na

CleanAir.

CHROMATOGRAPHIC DATA REDUCTION

Client Palatine Engineering Group
 Lab Project No: 28557
 Analyte Fluoride
 Date 4/7/2010

MDL=	0.008 mg/L	Average Flow Rate	QC Dilution Factor
MRL=	0.038 mg/L	0.81 mL/min	200.000

QUALITY CONTROL CHECKS (CONT)

Sample Location	Sample Identification Number	Sample Identification	Date of Injection	Area Counts Trial 1	Area Counts Trial 2	Area Count Average	Area Count Duplicate Difference	Duplicate Relative Difference (%)	C _{Reg} (Concentration, mg/L from Reg Curve)	Percent Difference from Actual Value (%)
CleanAir	28557-00	CCB	03/29/10	0.0000	0.0000	0.0000	na	na	<	
CleanAir	28557-990	CCV	03/29/10	0.4661	0.4599	0.4630	0.0062	1.3%	0.51	2.07%
CleanAir	28557-991	QC	03/30/10	0.6268	0.5984	0.6126	0.0284	4.6%	135.19	3.13%
CleanAir	28557-00	CCB	03/31/10	0.0000	0.0000	0.0000	na	na	<	
CleanAir	28557-992	CCV	03/31/10	0.4223	0.4230	0.4227	0.0007	0.2%	0.47	6.67%
CleanAir	28557-993	QC	04/01/10	0.5766	0.5868	0.5817	0.0102	1.8%	128.46	7.95%
CleanAir	28557-00	CCB	04/02/10	0.0000	0.0000	0.0000	na	na	<	
CleanAir	28557-994	CCV	04/02/10	0.4434	0.4526	0.4480	0.0092	2.1%	0.50	1.17%
CleanAir	28557-995	QC	04/02/10	0.5875	0.5956	0.5916	0.0081	1.4%	130.60	6.41%
CleanAir	28557-00	CCB	04/06/10	0.0000	0.0000	0.0000	na	na	<	
CleanAir	28557-996	CCV	04/06/10	0.4153	0.4219	0.4186	0.0066	1.6%	0.46	7.54%
Matrix Spike Recoveries										
Matrix Spike	28557-28	U2 FF Outlet R:	04/05/10	0.5606	0.5673	0.5640	0.0067	1.2%	<u>Precision</u>	<u>Spike Recovery</u>
Matrix Spike	28557-28	U2 FF Outlet R:	04/05/10	0.5384	0.5356	0.5370	0.0028	0.5%	4.9%	98.4%
										93.7%

CleanAir

CHROMATOGRAPHIC DATA REDUCTION

Client Palatine Engineering Group
 Lab Project No: 28557
 Analyte Fluoride
 Date 4/7/2010

Determination of Detection Limit

(in accordance with 40 CFR 136, Appendix B)

Analyte	Fluoride
Area Count	
Trial 1	0.0573
Trial 2	0.0600
Trial 3	0.0614
Trial 4	0.0613
Trial 5	0.0572
Trial 6	0.0599
Trial 7	0.0558
Trial 8	0.0560
Average	0.0586
Std Dev	0.0023
RMS Dev	3.92%

n	$t_{(n-1,0.99)}$
7	3.143
8	2.998
9	2.896
10	2.821
11	2.764
16	2.602
21	2.528

Average % Recovery	96.51%
Measured Concentration (mg/l)	
Trial 1	0.071
Trial 2	0.074
Trial 3	0.076
Trial 4	0.076
Trial 5	0.071
Trial 6	0.074
Trial 7	0.070
Trial 8	0.070
Average	0.073
Std Dev	0.0025
RMS Dev	3.44%
$t_{(n-1,0.99)}$	2.998
Det Lim (mg/l)	0.008
Rep Lim (mg/L)	0.038

Is the spike level higher than the MDL? Yes
 Does the spike level exceed ten times the MDL? No
 Is the Avg Recovery between 90% < Ra < 110% ? Yes

Actual Conc 0.0754
 Slope 1.09E+00
 Intercept 0.0090
 Coeff of Corr 0.9996

Sample Calculations

Customer:	Palatine Engineering Group	Lab Project No:	28557	Analyst	Eric Ewing
Plant:	Wheelabrator North Broward	Customer Ref No:	10955	Method	U.S. EPA Method 26A

Calibration Point No: 3
 Sample No: 28557-25
 Sample Location: U1 FF Outlet

1. Difference between duplicate injections for pre-test calibration (Pre Cal 1).

$$\Delta_{Injection} = |Area_{Trial\ 2} - Area_{Trial\ 1}|$$

Where:

$\Delta_{Injection}$ = Area count difference between duplicate injections

$Area_{Trial2}$ = Area count for injection Trial 2

$Area_{Trial1}$ = Area count for injection Trial 1

$$\Delta_{Injection} = 0.0064$$

$$Area_{Trial2} = 0.1647$$

$$Area_{Trial1} = 0.1583$$

2. Average area count value for duplicate injections for pre-test calibration (Pre Cal 1).

$$Avg_{PreInj} = \frac{(Area_{Trial1} + Area_{Trial2})}{2}$$

Where:

Avg_{PreInj} = Average of duplicate injection area counts

$Area_{Trial2}$ = Area count for injection Trial 2

$Area_{Trial1}$ = Area count for injection Trial 1

2 = Constant (number of values)

$$Avg_{Inj} = 0.1615$$

$$Area_{Trial2} = 0.1647$$

$$Area_{Trial1} = 0.1583$$

Sample Calculations

Customer:	Palatine Engineering Group	Lab Project No:	28557	Analyst	Eric Ewing
Plant:	Wheelabrator North Broward	Customer Ref No:	10955	Method	U.S. EPA Method 26A

Calibration Point No: 3
 Sample No: 28557-25
 Sample Location: U1 FF Outlet

3. Difference between individual injection and average area count for pre-test calibration.

$$\Delta_{PreMean\%} = \frac{|Area_{Trial2} - Avg_{PreInj}|}{Avg_{PreInj}} 100$$

Where:

- $\Delta_{PreMean\%}$ = Difference between individual injection and average area count (%).
- Avg_{PreInj} = Average of duplicate injection area counts
- $Area_{Trial2}$ = Area count for injection Trial 2
- 100 = Constant (conversion factor for percentage)

$$\begin{aligned} \Delta_{PreMean\%} &= 1.9429 \\ Avg_{PreInj} &= 0.1615 \\ Area_{Trial2} &= 0.1647 \end{aligned}$$

Note: EPA Method 26 requires $\Delta_{PreMean\%}$ to be less than 5%.

4. Average of all area count values for a given calibration point.

$$\bar{X} = \frac{\sum_{i=1}^n x_i}{n}$$

Where:

- \bar{X} = Average of all area count values for a given calibration point.
- x_i = Individual area count values for each individual injection.
- i = Iteration value.
- n = Number of injections for the calibration point under question.

$$\begin{aligned} \bar{X} &= 0.1627 \\ x_1 &= 0.1583 \\ x_2 &= 0.1647 \\ n &= 6.0000 \end{aligned}$$

Sample Calculations

Customer:	Palatine Engineering Group	Lab Project No:	28557	Analyst	Eric Ewing
Plant:	Wheelabrator North Broward	Customer Ref No:	10955	Method	U.S. EPA Method 26A

Calibration Point No: 3
 Sample No: 28557-25
 Sample Location: U1 FF Outlet

5. Average of all concentration values for used in generating calibration curve.

$$\overline{Y}_{All} = \frac{\sum_{i=1}^n y_i}{n}$$

Where:

- \overline{Y}_{All} = Average of all area concentration values.
- y_i = Individual concentration values for each individual injection.
- n = Number of injections.

- \overline{Y}_{All} = 0.4595
- y_1 = 0.0000
- y_2 = 0.0754
- n = 7.0000

6. Average of all area count values for the calibration curve.

$$\overline{X}_{All} = \frac{\sum_{i=1}^n x_i}{n}$$

Where:

- \overline{X}_{All} = Average of all area count values.
- x_i = Individual area count values.
- i = Iteration value.
- n = Number of injections.

- \overline{X}_{All} = 0.3706
- x_1 = 0.1583
- x_2 = 0.1647
- n = 34.0000

Sample Calculations

Customer:	Palatine Engineering Group	Lab Project No:	28557	Analyst	Eric Ewing
Plant:	Wheelabrator North Broward	Customer Ref No:	10955	Method	U.S. EPA Method 26A

Calibration Point No: 3
 Sample No: 28557-25
 Sample Location: U1 FF Outlet

7. Determination of slope (least-squares regression) value for calibration curve.

$$m = \frac{\sum_{i=1}^n (x_i - \bar{x})(y_i - \bar{y})}{\sum_{i=1}^n (x_i - \bar{x})^2}$$

Where:

- m = Slope of least-squares regression curve.
- x_i = Individual area count values for each individual injection.
- \bar{x} = Average of all area count values = \bar{X}_{All}
- y_i = Actual area concentration values for each individual injection.
- \bar{y} = Average of all concentration values = \bar{Y}_{All}
- i = Iteration value.
- n = Number of injections.

- m = 1.08878
- x_1 = 0.1583
- x_2 = 0.1647
- \bar{x} = 0.3706
- y_1 = 0.0000
- y_2 = 0.0754
- \bar{y} = 0.4595
- n = 34.0000

8. Determination of y-intercept (least-squares regression) value for calibration curve.

$$b = \bar{y} - m \bar{x}$$

Where:

- b = Y-axis intercept.
- \bar{x} = Average of all area count values = \bar{X}_{All}
- \bar{y} = Average of all concentration values = \bar{Y}_{All}

- b = 0.00895
- m = 1.08878
- \bar{x} = 0.3706
- \bar{y} = 0.4595

Sample Calculations

Customer: Palatine Engineering Group	Lab Project No: 28557	Analyst: Eric Ewing
Plant: Wheelabrator North Broward	Customer Ref No: 10955	Method: U.S. EPA Method 26A

Calibration Point No: 3
 Sample No: 28557-25
 Sample Location: U1 FF Outlet

9. Determination of coefficient of correlation (least-squares regression) value for calibration curve.

$$r = \frac{\sum_{i=1}^n (x_i - \bar{x})(y_i - \bar{y})}{\sqrt{\sum_{i=1}^n (x_i - \bar{x})^2 \sum_{i=1}^n (y_i - \bar{y})^2}}$$

Where:

- r^2 = Square of the Pearson product moment correlation coefficient through data points in known y's and known x's.
- r = Pearson product moment correlation coefficient through data points in known y's and known x's.
- x_i = Individual area count values for each individual injection.
- y_i = Actual area concentration values for each individual injection.
- \bar{x} = Average of all area count values = \bar{X}_{All}
- \bar{y} = Average of all concentration values = \bar{Y}_{All}
- i = Iteration value.
- n = Number of injections.

r^2	=	0.99955
r	=	0.99978
x_1	=	0.1583
x_2	=	0.1647
\bar{x}	=	0.3706
y_1	=	0.0000
y_2	=	0.0754
\bar{y}	=	0.4595
n	=	34.0000

Sample Calculations

Customer:	Palatine Engineering Group	Lab Project No:	28557	Analyst	Eric Ewing
Plant:	Wheelabrator North Broward	Customer Ref No:	10955	Method	U.S. EPA Method 26A

Calibration Point No: 3
 Sample No: 28557-25
 Sample Location: U1 FF Outlet

10. Determination of average sample area counts from duplicate injections.

$$Avg_{Sample} = \frac{(Area_{Trial1} + Area_{Trial2})}{2}$$

Where:

Avg_{Sample} = Average of duplicate injection area counts

$Area_{Trial2}$ = Area count for injection Trial 2

$Area_{Trial1}$ = Area count for injection Trial 1

2 = Constant (number of injections)

Avg_{inj} = 0.0000

$Area_{Trial2}$ = 0.0000

$Area_{Trial1}$ = 0.0000

11. Difference between duplicate injections for the sample.

$$\Delta_{Injection} = |Area_{Trial2} - Area_{Trial1}|$$

Where:

$\Delta_{Injection}$ = Area count difference between duplicate injections

$Area_{Trial2}$ = Area count for injection Trial 2

$Area_{Trial1}$ = Area count for injection Trial 1

$\Delta_{Injection}$ = 0.0000

$Area_{Trial2}$ = 0.0000

$Area_{Trial1}$ = 0.0000

Sample Calculations

Customer:	Palatine Engineering Group	Lab Project No:	28557	Analyst	Eric Ewing
Plant:	Wheelabrator North Broward	Customer Ref No:	10955	Method	U.S. EPA Method 26A

Calibration Point No: 3
 Sample No: 28557-25
 Sample Location: U1 FF Outlet

12. Difference between individual injection and average area count for the sample.

$$\Delta_{Injection} = \frac{|Area_{Trial2} - Avg_{Inj}|}{Avg_{Inj}} 100$$

Where:

- $\Delta_{Injection}$ = Difference between individual injection and average area count (%).
- Avg_{Inj} = Average of duplicate injection area counts
- $Area_{Trial2}$ = Area count for injection Trial 2
- 100 = Constant (conversion factor for percentage)

$$\begin{aligned} \Delta_{Injection} &= 0.0\% \\ Avg_{Inj} &= 0.0000 \\ Area_{Trial2} &= 0.0000 \end{aligned}$$

Note: EPA Method 26 requires $\Delta_{Injection}$ to be less than 5%.

13. Determination of sample concentration from least-squares regression curve (mg/L).

$$C_{Reg} = DF [m(Avg_{Inj}) + b]$$

Where:

- C_{Reg} = Sample concentration determined using the regression curve (mg/L)
- DF = Sample dilution factor
- Avg_{Inj} = Average of duplicate injection area counts.
- m = Slope of least-squares regression curve.
- b = Y-intercept of least-squares regression curve.

$$\begin{aligned} C_{Reg} &= < \\ DF &= 1.0000 \\ Avg_{Inj} &= 0.0000 \\ m &= 1.0888 \\ b &= 0.0090 \end{aligned}$$

Sample Calculations

Customer:	Palatine Engineering Group	Lab Project No:	28557	Analyst	Eric Ewing
Plant:	Wheelabrator North Broward	Customer Ref No:	10955	Method	U.S. EPA Method 26A

Calibration Point No: 3
 Sample No: 28557-25
 Sample Location: U1 FF Outlet

14. Determination of total amount of analyte in sample (total mg).

$$M_{Analyte} = \frac{(C_{Reg})(V_{Soln})}{1000}$$

Where:

- $M_{Analyte}$ = Amount of analyte in sample (total mg)
- C_{Reg} = Sample concentration determined using the response factor (mg/L)
- V_{Soln} = Sample volume (ml)
- 1000 = Conversion constant (ml to L)

$$\begin{aligned} M_{Analyte} &= <0.032 \\ C_{Reg} &= < \\ V_{Soln} &= 846.0000 \end{aligned}$$

15. Determination of Method Detection Limits (MDL).

15a. Determination of average spike result.

$$AvgM_{f-i} = \frac{\sum_{i=1}^n M_{f-i}}{n}$$

Where:

- $AvgM_{f-i}$ = Average of spike result (mg/L)
- M_{f-i} = Net results recorded for each iteration (mg/L)
- n = Number of iterations.
- i = Placeholder for iteration.

$$\begin{aligned} AvgM_{f-i} &= 0.073 \\ M_{f_1} &= 0.071 & M_{f_5} &= 0.071 \\ M_{f_2} &= 0.074 & M_{f_6} &= 0.074 \\ M_{f_3} &= 0.076 & M_{f_7} &= 0.070 \\ M_{f_4} &= 0.076 & M_{f_8} &= 0.070 \\ n &= 8 \end{aligned}$$

Sample Calculations

Customer:	Palatine Engineering Group	Lab Project No:	28557	Analyst	Eric Ewing
Plant:	Wheelabrator North Broward	Customer Ref No:	10955	Method	U.S. EPA Method 26A

Calibration Point No: 3
 Sample No: 28557-25
 Sample Location: U1 FF Outlet

15b. Determination of standard deviation of spike result.

$$\sigma_{f-i} = \sqrt{\frac{\sum_{i=1}^n (M_{f-i} - AvgM_{f-i})^2}{(n-1)}}$$

Where:

- σ_{f-i} = Standard deviation of spike result.
- $AvgM_{f-i}$ = Average of spike result net weights (g)
- M_{f-i} = Net weights recorded for each iteration (g)
- n = Number of iterations.
- i = Placeholder for iteration.

σ_{f-i}	=	0.0025			
$AvgM_{f-i}$	=	0.073			
M_{f-1}	=	0.071	M_{f-5}	=	0.071
M_{f-2}	=	0.074	M_{f-6}	=	0.074
M_{f-3}	=	0.076	M_{f-7}	=	0.070
M_{f-4}	=	0.076	M_{f-8}	=	0.070
n	=	8			

15c. Determination of variance of spike result.

$$V_{f-i} = (\sigma_{f-i})^2$$

Where:

- V_{f-i} = Variance of spike result.
- σ_{f-i} = Standard deviation of spike result.

V_{f-i}	=	6.27E-06
σ_{f-i}	=	0.0025

Sample Calculations

Customer:	Palatine Engineering Group	Lab Project No:	28557	Analyst	Eric Ewing
Plant:	Wheelabrator North Broward	Customer Ref No:	10955	Method	U.S. EPA Method 26A

Calibration Point No: 3
 Sample No: 28557-25
 Sample Location: U1 FF Outlet

15d. Determination of RMS deviation of spike result.

$$RMS_{f-i} = 100 \frac{\sigma_{f-i}}{AvgM_{f-i}}$$

Where:

- RMS_{f-i} = RMS deviation of spike results (%)
- σ_{f-i} = Standard deviation of spike result.
- AvgM_{f-i} = Average of spike result net weights (g)
- 100 = Conversion constant (fraction to percent)

- RMS_{f-i} = 0.0344
- σ_{f-i} = 0.0025
- AvgM_{f-i} = 0.0728

15e. Determination of average spike recovery.

$$R_f \approx 100 \frac{AvgM_{f-i}}{RA}$$

Where:

- R_f = Average spike recovery (%)
- AvgM_{f-i} = Average of spike result net weights (g)
- RA = Amount of spike residue added (g)
- 100 = Conversion constant (fraction to percent)

- R_f = 96.5%
- AvgM_{f-i} = 0.07277
- RA = 0.07539

Sample Calculations

Customer:	Palatine Engineering Group	Lab Project No:	28557	Analyst	Eric Ewing
Plant:	Wheelabrator North Broward	Customer Ref No:	10955	Method	U.S. EPA Method 26A

Calibration Point No: 3
 Sample No: 28557-25
 Sample Location: U1 FF Outlet

15f. Determination of $t_{(n-1, 0.99)}$.

Value taken from the following Table:

n	$t_{(n-1, 0.99)}$
7	3.143
8	2.998
9	2.896
10	2.821
11	2.764
16	2.602
21	2.528

Where:

$t_{(n-1, 0.99)}$ = Students' t value appropriate for a 99% confidence level and a standard deviation estimate with n-1 degrees of freedom.

n = Number of iterations.

$t_{(n-1, 0.99)}$ = 2.998

n = 8

15g. Determination of Method Detection Limit (MDL).

$$MDL = \sigma_{f_i} t_{(n-1, 0.99)}$$

Where:

MDL = Method detection limit (mg/L)

$t_{(n-1, 0.99)}$ = Students' t value appropriate for a 99% confidence level and a standard deviation estimate with n-1 degrees of freedom.

σ_{f_i} = Standard deviation of spike result.

MDL = 0.008

$t_{(n-1, 0.99)}$ = 2.998

σ_{f_i} = 0.0025

Sample Calculations

Customer:	Palatine Engineering Group	Lab Project No:	28557	Analyst	Eric Ewing
Plant:	Wheelabrator North Broward	Customer Ref No:	10955	Method	U.S. EPA Method 26A

Calibration Point No: 3
Sample No: 28557-25
Sample Location: U1 FF Outlet

15h. Determination of Method Reporting Limit (MRL).


$$MRL = 5(MDL)$$

Where:

- MRL = Method reporting limit (mg/L)
- MDL = Method detection Limit (mg/L)
- 5 = Constant


MRL = 0.038
MDL = 0.008

3 Cal 01		
CleanAir		
Sample Name:	Cal 01	Sample Vo. 1.0 mL
Vial Number:	2	Channel: ECD_1
Sample Type:	standard	ICS Condu 42.287
Control Program:	AS40Inj1	ICS Pressu 1275.96
Quantif. Method:	default	Dilution Fa 1.0X
Recording Time:	3/29/2010 16:12	Sample ID:
Run Time (min):	20.00	Replicate II




No.	Ret.Time min	Peak Name	Area μ S*min	Rel.Area %	Type	PGF
1	4.51	Fluoride	0.0573	19.79	MB*	0.91
2	6.47	Chloride	0.1046	36.13	BMB	0.99
3	9.66	Bromide	0.1276	44.08	BMB	0.93
Total:			0.289	100.00	0.00	

4 Cal 01		
CleanAir		
Sample Name:	Cal 01	Sample Vo. 1.0 mL
Vial Number:	2	Channel: ECD_1
Sample Type:	standard	ICS Condu 42.768
Control Program:	AS40Inj2	ICS Pressu 1249.43
Quantif. Method:	default	Dilution Fa 1.0X
Recording Time:	3/29/2010 16:33	Sample ID:
Run Time (min):	20.00	Replicate II




No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	1.63	n.a.	0.0259	6.98	BMB	0.80
2	4.46	Fluoride	0.0600	16.19	BMB*	0.92
3	6.35	Chloride	0.1161	31.33	BMB	0.93
4	9.38	Bromide	0.1484	40.05	BMB	0.79
5	15.53	Sulfate	0.0202	5.46	BMB	1.11
Total:			0.371	100.000	0.00	

7 Cal 02		
CleanAir		
Sample Name:	Cal 02	Sample Vo. 1.0 mL
Vial Number:	4	Channel: ECD_1
Sample Type:	standard	ICS Condu 46.136
Control Program:	AS40Inj1	ICS Pressu 1294.19
Quantif. Method:	default	Dilution Fa: 1.0X
Recording Time:	3/29/2010 17:36	Sample ID:
Run Time (min):	20.00	Replicate II




No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	4.48	Fluoride	0.1583	18.70	BMB*	0.92
2	6.42	Chloride	0.2768	32.69	BMB	0.95
3	9.58	Bromide	0.3883	45.86	BMB	0.88
4	15.55	Sulfate	0.0233	2.76	BMB	0.87
Total:			0.847	100.000	0.00	

9 Cal 03		
CleanAir		
Sample Name:	Cal 03	Sample Vol: 1.0 mL
Vial Number:	5	Channel: ECD_1
Sample Type:	standard	ICS Condu 46.549
Control Program:	AS40Inj1	ICS Pressu 1250.22
Quantif. Method:	default	Dilution Fa: 1.0X
Recording Time:	3/29/2010 18:19	Sample ID:
Run Time (min):	20.00	Replicate II




No.	Ret.Time min	Peak Name	Area μS*min	Rel.Area %	Type	PGF
1	4.47	Fluoride	0.2288	21.82	BMB*	0.92
2	6.39	Chloride	0.3687	35.16	BMB	0.91
3	9.51	Bromide	0.4511	43.02	BMB	0.94
Total:			1.049	100.000	0.00	

10 Cal 03		
CleanAir		
Sample Name:	Cal 03	Sample Vo. 1.0 mL
Vial Number:	5	Channel: ECD_1
Sample Type:	standard	ICS Condu 46.526
Control Program:	AS40Inj2	ICS Pressu 1279.74
Quantif. Method:	default	Dilution Fa 1.0X
Recording Time:	3/29/2010 18:40	Sample ID:
Run Time (min):	20.00	Replicate II




No.	Ret.Time min	Peak Name	Area μS*min	Rel.Area %	Type	PGF
1	4.51	Fluoride	0.2330	20.82	BMB*	0.91
2	6.47	Chloride	0.3780	33.77	BMB*	0.93
3	9.67	Bromide	0.5083	45.41	BMB	0.88
Total:			1.119	100.000	0.00	

11 Cal 04		
CleanAir		
Sample Name:	Cal 04	Sample Vo. 1.0 mL
Vial Number:	6	Channel: ECD_1
Sample Type:	standard	ICS Condu 48.037
Control Program:	AS40Inj1	ICS Pressu 1295.79
Quantif. Method:	default	Dilution Fa: 1.0X
Recording Time:	3/29/2010 19:01	Sample ID:
Run Time (min):	20.00	Replicate II




No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	4.54	Fluoride	0.5777	20.92	BMB*	0.91
2	6.52	Chloride	0.9481	34.34	BMB	0.94
3	9.75	Bromide	1.2355	44.74	BMB	0.93
Total:			2.761	100.000	0.00	

13 Cal 05		
CleanAir		
Sample Name:	Cal 05	Sample Vo. 1.0 mL
Vial Number:	1	Channel: ECD_1
Sample Type:	standard	ICS Condu 47.263
Control Program:	AS40Inj1	ICS Pressu. 1310.59
Quantif. Method:	default	Dilution Fa. 1.0X
Recording Time:	3/29/2010 19:43	Sample ID:
Run Time (min):	20.00	Replicate II




No.	Ret.Time min	Peak Name	Area μ S*min	Rel.Area %	Type	PGF
1	4.53	Fluoride	0.7329	20.65	BMB*	0.92
2	6.51	Chloride	1.2294	34.63	BMB	0.93
3	9.76	Bromide	1.5537	43.77	BMB	0.93
4	15.70	Sulfate	0.0337	0.95	BMB	1.01
Total:			3.550	100.000	0.00	

14 Cal 05		
CleanAir		
Sample Name:	Cal 05	Sample Vo. 1.0 mL
Vial Number:	1	Channel: ECD_1
Sample Type:	standard	ICS Condu 46.993
Control Program:	AS40Inj2	ICS Pressu 1322.37
Quantif. Method:	default	Dilution Fa: 1.0X
Recording Time:	3/29/2010 20:05	Sample ID:
Run Time (min):	20.00	Replicate II




No.	Ret.Time min	Peak Name	Area μ S*min	Rel.Area %	Type	PGF
1	4.56	Fluoride	0.7458	20.29	BMB*	0.93
2	6.56	Chloride	1.2913	35.14	BMB	0.91
3	9.86	Bromide	1.5959	43.43	BMB	0.91
4	15.79	Sulfate	0.0421	1.14	BMB	1.13
Total:			3.675	100.000	0.00	

19 CCV	
CleanAir	
Sample Name: CCV	Sample Vo. 1.0 mL
Vial Number: 4	Channel: ECD_1
Sample Type: validate	ICS Condu 46.268
Control Program: AS40Inj1	ICS Pressu 1337.78
Quantif. Method: default	Dilution Fa 1.0X
Recording Time: 3/29/2010 21:50	Sample ID:
Run Time (min): 20.00	Replicate II




No.	Ret.Time min	Peak Name	Area μ S*min	Rel.Area %	Type	PGF
1	4.62	Fluoride	0.4661	20.24	BMB*	0.91
2	6.67	Chloride	0.7783	33.80	BMB	0.93
3	10.09	Bromide	0.9936	43.15	BMB	0.92
4	15.93	Sulfate	0.0646	2.81	BMB	0.82
Total:			2.303	100.000	0.00	

20 CCV		
CleanAir		
Sample Name:	CCV	Sample Vo. 1.0 mL
Vial Number:	4	Channel: ECD_1
Sample Type:	validate	ICS Condu 46.244
Control Program:	AS40Inj2	ICS Pressu 1328.69
Quantif. Method:	default	Dilution Fa 1.0X
Recording Time:	3/29/2010 22:11	Sample ID:
Run Time (min):	20.00	Replicate II




No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	4.58	Fluoride	0.4599	19.58	BMB*	0.93
2	6.60	Chloride	0.7930	33.76	BMB	0.93
3	9.94	Bromide	0.9893	42.12	BMB	0.90
4	15.86	Sulfate	0.1066	4.54	BMB	1.00
Total:			2.349	100.000	0.00	

75 Cal 01		
CleanAir		
Sample Name:	Cal 01	Sample Vo. 1.0 mL
Vial Number:	1	Channel: ECD_1
Sample Type:	standard	ICS Condu 48.930
Control Program:	AS40Inj1	ICS Pressu 1241.00
Quantif. Method:	default	Dilution Fa 1.0X
Recording Time:	3/30/2010 17:34	Sample ID:
Run Time (min):	20.00	Replicate II




No.	Ret.Time min	Peak Name	Area μ S*min	Rel.Area %	Type	PGF
1	4.39	Fluoride	0.0614	9.39	BMB*	1.11
2	6.20	Chloride	0.1935	29.61	BMB	0.94
3	9.06	Bromide	0.1625	24.87	BMB	0.78
4	15.26	Sulfate	0.2361	36.13	BMB	1.05
Total:			0.653	100.00	0.00	

76 Cal 01		
CleanAir		
Sample Name:	Cal 01	Sample Vol. 1.0 mL
Vial Number:	1	Channel: ECD_1
Sample Type:	standard	ICS Condu 48.732
Control Program:	AS40Inj2	ICS Pressu 1241.64
Quantif. Method:	default	Dilution Fa 1.0X
Recording Time:	3/30/2010 17:55	Sample ID:
Run Time (min):	20.00	Replicate II




No.	Ret.Time min	Peak Name	Area μ S*min	Rel.Area %	Type	PGF
1	4.39	Fluoride	0.0613	18.48	BMB*	1.08
2	6.21	Chloride	0.1313	39.54	BMB	0.94
3	9.09	Bromide	0.1394	41.99	BMB	0.97
Total:			0.332	100.000	0.00	

85 Cal 01	
CleanAir	
Sample Name:	Cal 01
Vial Number:	3
Sample Type:	standard
Control Program:	AS40Inj2
Quantif. Method:	default
Recording Time:	3/31/2010 16:26
Run Time (min):	20.00
Sample Vo:	1.0 mL
Channel:	ECD_1
ICS Condu:	50.658
ICS Pressu:	1219.08
Dilution Fa:	1.0X
Sample ID:	Replicate II




No.	Ret. Time min	Peak Name	Area μS*min	Rel. Area %	Type	PGF
1	4.35	Fluoride	0.0599	18.12	BMB*	1.03
2	6.12	Chloride	0.1275	38.61	BMB	0.93
3	8.89	Bromide	0.1429	43.27	BMB	0.93
Total:			0.330	100.000	0.00	

120 QC		
CleanAir		
Sample Name:	QC	Sample Vo. 1.0 mL
Vial Number:	6	Channel: ECD_1
Sample Type:	validate	ICS Condu 50.922
Control Program:	AS40Inj1	ICS Pressu 1301.52
Quantif. Method:	default	Dilution Fa 200.0X
Recording Time:	4/1/2010 16:37	Sample ID:
Run Time (min):	20.00	Replicate II



No.	Ret.Time min	Peak Name	Area μ S*min	Rel.Area %	Type	PGF
1	4.50	Fluoride	0.5766	25.68	BMB*	0.94
2	6.42	Chloride	0.8742	38.94	BMB	0.94
3	9.51	Bromide	0.6946	30.94	BMB	0.85
4	15.59	Sulfate	0.0998	4.44	BMB	1.10
Total:			2.245	100.000	0.00	

121 QC		
CleanAir		
Sample Name:	QC	Sample Vo. 1.0 mL
Vial Number:	6	Channel: ECD_1
Sample Type:	validate	ICS Condu 51.019
Control Program:	AS40Inj2	ICS Pressu. 1300.56
Quantif. Method:	default	Dilution Fa: 200.0X
Recording Time:	4/1/2010 16:58	Sample ID:
Run Time (min):	20.00	Replicate II




No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	4.52	Fluoride	0.5868	26.20	BMB*	0.94
2	6.44	Chloride	0.8204	36.62	BMB	0.96
3	9.55	Bromide	0.7520	33.57	BMB	0.85
4	15.66	Sulfate	0.0808	3.61	BMB	0.92
Total:			2.240	100.000	0.00	

152 CCV

CleanAir

Sample Name:	CCV	Sample Vo:	1.0 mL
Vial Number:	1	Channel:	ECD_1
Sample Type:	validate	ICS Condu:	50.182
Control Program:	AS40Inj1	ICS Pressu:	1313.74
Quantif. Method:	default	Dilution Fa:	1.0X
Recording Time:	4/2/2010 14:45	Sample ID:	
Run Time (min):	20.00	Replicate II:	




No.	Ret.Time min	Peak Name	Area μ S*min	Rel.Area %	Type	PGF
1	4.50	Fluoride	0.4434	19.92	BMB*	0.91
2	6.42	Chloride	0.7809	35.07	BMB	0.92
3	9.50	Bromide	0.9623	43.22	BMB	0.93
4	15.61	Sulfate	0.0397	1.78	BMB	0.86
Total:			2.226	100.000	0.00	

153 CCV


CleanAir

Sample Name:	CCV	Sample Vo:	1.0 mL
Vial Number:	1	Channel:	ECD_1
Sample Type:	validate	ICS Condu:	50.247
Control Program:	AS40Inj2	ICS Pressu:	1300.85
Quantif. Method:	default	Dilution Fa:	1.0X
Recording Time:	4/2/2010 15:06	Sample ID:	
Run Time (min):	20.00	Replicate I:	



No.	Ret.Time min	Peak Name	Area μ S*min	Rel.Area %	Type	PGF
1	4.48	Fluoride	0.4526	19.75	BMB*	0.90
2	6.36	Chloride	0.7730	33.74	BMB	0.93
3	9.37	Bromide	0.9597	41.88	BMB	0.91
4	15.48	Sulfate	0.1059	4.62	BMB	0.87
Total:			2.291	100.000	0.00	

179 QC		
CleanAir		
Sample Name:	QC	Sample Vol: 1.0 mL
Vial Number:	2	Channel: ECD_1
Sample Type:	validate	ICS Condu 50.092
Control Program:	AS40Inj2	ICS Pressu 1321.65
Quantif. Method:	default	Dilution Fa: 200.0X
Recording Time:	4/3/2010 0:16	Sample ID:
Run Time (min):	20.00	Replicate II




No.	Ret. Time min	Peak Name	Area µS*min	Rel. Area %	Type	PGF
1	4.47	Fluoride	0.5956	24.51	BMB*	0.95
2	6.36	Chloride	0.9391	38.65	BMB	0.92
3	8.96	n.a.	0.0244	1.01	Ru	n.a.
4	9.40	Bromide	0.8708	35.84	BMB	0.79
Total:			2.430	100.000	0.00	

182 Cal 02


CleanAir

Sample Name:	Cal 02	Sample Vo. 1.0 mL
Vial Number:	4	Channel: ECD_1
Sample Type:	standard	ICS Condu 50.126
Control Program:	AS40Inj1	ICS Pressu 1314.04
Quantif. Method:	default	Dilution Fa: 1.0X
Recording Time:	4/3/2010 1:19	Sample ID:
Run Time (min):	20.00	Replicate II



No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	4.51	Fluoride	0.1655	17.75	BMB*	0.84
2	6.41	Chloride	0.2928	31.40	BMB	0.95
3	9.49	Bromide	0.4152	44.53	BMB	0.88
4	15.55	Sulfate	0.0589	6.32	BMB	0.81
Total:			0.932	100.000	0.00	

183 Cal 02		
CleanAir		
Sample Name:	Cal 02	Sample Vo.1.0 mL
Vial Number:	4	Channel: ECD_1
Sample Type:	standard	ICS Condu 50.096
Control Program:	AS40Inj2	ICS Pressu 1311.55
Quantif. Method:	default	Dilution Fa 1.0X
Recording Time:	4/3/2010 1:40	Sample ID:
Run Time (min):	20.00	Replicate II




No.	Ret.Time min	Peak Name	Area μ S*min	Rel.Area %	Type	PGF
1	4.52	Fluoride	0.1670	18.37	BMB*	0.81
2	6.43	Chloride	0.3088	33.96	BMB	0.93
3	9.51	Bromide	0.3976	43.73	BMB	0.90
4	15.54	Sulfate	0.0359	3.95	BMB	1.19
Total:			0.909	100.000	0.00	

189 Cal 03


CleanAir

Sample Name:	Cal 03	Sample Vo:	1.0 mL
Vial Number:	2	Channel:	ECD_1
Sample Type:	standard	ICS Condu:	49.213
Control Program:	AS40Inj1	ICS Pressu:	1338.96
Quantif. Method:	default	Dilution Fa:	1.0X
Recording Time:	4/3/2010 13:27	Sample ID:	
Run Time (min):	20.00	Replicate:	II



No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	4.59	Fluoride	0.2207	20.70	BM *	0.79
2	6.56	Chloride	0.3728	34.98	BMB	0.95
3	9.81	Bromide	0.4725	44.32	BMB	0.94
Total:			1.066	100.000	0.00	

190 Cal 03		
CleanAir		
Sample Name:	Cal 03	Sample Vo. 1.0 mL
Vial Number:	2	Channel: ECD_1
Sample Type:	standard	ICS Condu 49.036
Control Program:	AS40Inj2	ICS Pressu 1342.97
Quantif. Method:	default	Dilution Fac 1.0X
Recording Time:	4/3/2010 13:48	Sample ID:
Run Time (min):	20.00	Replicate II




No.	Ret. Time min	Peak Name	Area μS*min	Rel. Area %	Type	PGF
1	4.56	Fluoride	0.2270	20.18	BM *	0.81
2	6.53	Chloride	0.4034	35.85	BMB	0.89
3	9.77	Bromide	0.4947	43.97	BMB	0.90
Total:			1.125	100.000	0.00	

227 Matrix Spike


U2 FF Outlet

Sample Name:	Matrix Spike	Sample Vo:	862.0 mL
Vial Number:	6	Channel:	ECD_1
Sample Type:	spiked	ICS Condu:	49.266
Control Program:	AS40Inj1	ICS Pressu:	1314.48
Quantif. Method:	default	Dilution Fa:	1.0X
Recording Time:	4/5/2010 18:45	Sample ID:	28557-028
Run Time (min):	20.00	Replicate:	II



No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	4.50	Fluoride	0.5606	3.91	BMB*	0.92
2	6.40	Chloride	8.9771	62.65	BM	0.91
3	8.03	n.a.	0.9900	6.91	M	n.a.
4	9.44	Bromide	1.2543	8.75	M	0.90
5	10.64	n.a.	0.0501	0.35	MB	n.a.
6	13.86	n.a.	0.5805	4.05	BMB	0.98
7	15.49	Sulfate	1.9164	13.37	BMB	0.97
Total:			14.329	100.000	0.00	

228 Matrix Spike		
U2 FF Outlet		
Sample Name:	Matrix Spike	Sample Vol. 862.0 mL
Vial Number:	6	Channel: ECD_1
Sample Type:	spiked	ICS Condu 49.147
Control Program:	AS40Inj2	ICS Pressu 1317.15
Quantif. Method:	default	Dilution Fac 1.0X
Recording Time:	4/5/2010 19:06	Sample ID:
Run Time (min):	20.00	Replicate # 28557-028




No.	Ret. Time min	Peak Name	Area μ S*min	Rel. Area %	Type	PGF
1	4.51	Fluoride	0.5673	3.91	BMB*	0.91
2	6.42	Chloride	9.0521	62.45	BMB	0.92
3	9.47	Bromide	2.2282	15.37	BM	0.47
4	10.69	n.a.	0.0622	0.43	MB	n.a.
5	13.87	n.a.	0.6074	4.19	BMB	0.97
6	15.50	Sulfate	1.9505	13.46	BMB	0.95
7	19.06	n.a.	0.0282	0.19	BMB	1.32
Total:			14.496	100.000	0.00	

229 Matrix Spike


U2 FF Outlet

Sample Name:	Matrix Spike	Sample Vo. 862.0 mL
Vial Number:	1	Channel: ECD_1
Sample Type:	spiked	ICS Condu 48.992
Control Program:	AS40Inj1	ICS Pressu 1326.17
Quantif. Method:	default	Dilution Fa: 1.0X
Recording Time:	4/5/2010 19:27	Sample ID: 28557-028
Run Time (min):	20.00	Replicate II




No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	4.52	Fluoride	0.5384	3.77	BMB*	0.92
2	6.44	Chloride	8.9048	62.33	BM	0.92
3	8.17	n.a.	1.0360	7.25	M	0.94
4	9.53	Bromide	1.2485	8.74	M	0.88
5	10.72	n.a.	0.0511	0.36	MB	0.98
6	13.91	n.a.	0.5946	4.16	BMB	0.99
7	15.54	Sulfate	1.9142	13.40	BMB	0.96
Total:			14.288	100.000	0.00	

230 Matrix Spike		
U2 FF Outlet		
Sample Name:	Matrix Spike	Sample Vo. 862.0 mL
Vial Number:	1	Channel: ECD_1
Sample Type:	spiked	ICS Condu 48.869
Control Program:	AS40Inj2	ICS Pressu 1329.37
Quantif. Method:	default	Dilution Fa 1.0X
Recording Time:	4/5/2010 19:49	Sample ID:
Run Time (min):	20.00	Replicate Il 28557-028



No.	Ret. Time min	Peak Name	Area μ S*min	Rel. Area %	Type	PGF
1	4.53	Fluoride	0.5356	3.64	BMB*	0.93
2	6.46	Chloride	8.9417	60.75	BMB	0.91
3	9.56	Bromide	2.6404	17.94	BM	0.47
4	10.79	n.a.	0.0964	0.66	MB	n.a.
5	13.92	n.a.	0.6040	4.10	BMB	0.94
6	15.57	Sulfate	1.8996	12.91	BMB	0.96
Total:			14.718	100.000	0.00	

233 Cal 01		
CleanAir		
Sample Name:	Cal 01	Sample Vo.1.0 mL
Vial Number:	3	Channel: ECD_1
Sample Type:	standard	ICS Condu 48.297
Control Program:	AS40Inj1	ICS Pressu 1347.58
Quantif. Method:	default	Dilution Fa 1.0X
Recording Time:	4/5/2010 20:52	Sample ID:
Run Time (min):	20.00	Replicate II




No.	Ret.Time min	Peak Name	Area μ S*min	Rel.Area %	Type	PGF
1	4.55	Fluoride	0.0558	13.75	BM *	n.a.
2	6.49	Chloride	0.1359	33.47	BMB	0.94
3	9.67	Bromide	0.1799	44.33	BMB	0.61
4	15.56	Sulfate	0.0343	8.46	BMB	1.32
Total:			0.406	100.00	0.00	

234 Cal 01

CleanAir

Sample Name:	Cal 01	Sample Vo. 1.0 mL
Vial Number:	3	Channel: ECD_1
Sample Type:	standard	ICS Condu 48.118
Control Program:	AS40Inj2	ICS Pressu 1352.89
Quantif. Method:	default	Dilution Fa 1.0X
Recording Time:	4/5/2010 21:13	Sample ID:
Run Time (min):	20.00	Replicate II




No.	Ret. Time min	Peak Name	Area µS*min	Rel. Area %	Type	PGF
1	4.57	Fluoride	0.0560	13.53	BM *	n.a.
2	6.52	Chloride	0.1317	31.84	BMB	0.94
3	9.74	Bromide	0.2260	54.63	BMB	0.50
Total:			0.414	100.000	0.00	

235 Cal 02

CleanAir

Sample Name:	Cal 02	Sample Vo. 1.0 mL
Vial Number:	4	Channel: ECD_1
Sample Type:	standard	ICS Condu 47.990
Control Program:	AS40Inj1	ICS Pressu. 1357.98
Quantif. Method:	default	Dilution Fac 1.0X
Recording Time:	4/5/2010 21:34	Sample ID:
Run Time (min):	20.00	Replicate II




No.	Ret.Time min	Peak Name	Area μS*min	Rel.Area %	Type	PGF
1	4.56	Fluoride	0.1598	17.01	BMB*	0.86
2	6.51	Chloride	0.3162	33.66	BMB	0.93
3	9.74	Bromide	0.3907	41.59	BMB	0.86
4	15.63	Sulfate	0.0728	7.75	BMB	0.84
Total:			0.940	100.000	0.00	

236 Cal 02


CleanAir

Sample Name:	Cal 02	Sample Vo:	1.0 mL
Vial Number:	4	Channel:	ECD_1
Sample Type:	standard	ICS Condu:	47.758
Control Program:	AS40Inj2	ICS Pressu:	1355.35
Quantif. Method:	default	Dilution Fa:	1.0X
Recording Time:	4/5/2010 21:55	Sample ID:	
Run Time (min):	20.00	Replicate I:	




No.	Ret.Time min	Peak Name	Area µS*min	Rel.Area %	Type	PGF
1	4.56	Fluoride	0.1609	17.48	BMB*	0.86
2	6.52	Chloride	0.3071	33.35	BMB	0.94
3	9.75	Bromide	0.3933	42.71	BMB	0.94
4	15.65	Sulfate	0.0595	6.46	BMB	0.64
Total:			0.921	100.000	0.00	

237 Cal 03		
CleanAir		
Sample Name:	Cal 03	Sample Vo. 1.0 mL
Vial Number:	5	Channel: ECD_1
Sample Type:	standard	ICS Condu 47.688
Control Program:	AS40Inj1	ICS Pressu 1352.63
Quantif. Method:	default	Dilution Fa 1.0X
Recording Time:	4/5/2010 22:16	Sample ID:
Run Time (min):	20.00	Replicate II




No.	Ret. Time min	Peak Name	Area μ S*min	Rel. Area %	Type	PGF
1	4.56	Fluoride	0.2270	19.91	BM *	0.75
2	6.52	Chloride	0.3913	34.31	BMB	0.95
3	9.75	Bromide	0.4999	43.83	BMB	0.88
4	17.73	n.a.	0.0223	1.96	BMB	1.32
Total:			1.141	100.000	0.00	

238 Cal 03		
CleanAir		
Sample Name:	Cal 03	Sample Vo. 1.0 mL
Vial Number:	5	Channel: ECD_1
Sample Type:	standard	ICS Condu 47.616
Control Program:	AS40Inj2	ICS Pressu 1361.16
Quantif. Method:	default	Dilution Fa 1.0X
Recording Time:	4/5/2010 22:38	Sample ID:
Run Time (min):	20.00	Replicate II




No.	Ret. Time min	Peak Name	Area µS*min	Rel. Area %	Type	PGF
1	4.56	Fluoride	0.2207	20.53	BM *	0.82
2	6.53	Chloride	0.3733	34.73	BMB	0.93
3	9.78	Bromide	0.4809	44.74	BMB	0.91
Total:			1.075	100.000	0.00	

239 Cal 04		
CleanAir		
Sample Name:	Cal 04	Sample Vo. 1.0 mL
Vial Number:	6	Channel: ECD_1
Sample Type:	standard	ICS Condu 47.480
Control Program:	AS40Inj1	ICS Pressu 1367.08
Quantif. Method:	default	Dilution Fa 1.0X
Recording Time:	4/5/2010 22:58	Sample ID:
Run Time (min):	20.00	Replicate II



No.	Ret. Time min	Peak Name	Area μ S*min	Rel. Area %	Type	PGF
1	4.57	Fluoride	0.5658	19.97	BMB*	0.91
2	6.55	Chloride	0.9592	33.86	BMB	0.93
3	9.80	Bromide	1.2334	43.53	BMB	0.91
4	15.70	Sulfate	0.0748	2.64	BMB	0.89
Total:			2.833	100.000	0.00	

240 Cal 04		
CleanAir		
Sample Name:	Cal 04	Sample Vo.1.0 mL
Vial Number:	6	Channel: ECD_1
Sample Type:	standard	ICS Condu 47.334
Control Program:	AS40Inj2	ICS Pressu 1378.07
Quantif. Method:	default	Dilution Fa 1.0X
Recording Time:	4/5/2010 23:20	Sample ID:
Run Time (min):	20.00	Replicate II



No.	Ret.Time min	Peak Name	Area μ S*min	Rel.Area %	Type	PGF
1	4.58	Fluoride	0.5792	19.79	BMB*	0.90
2	5.93	n.a.	0.0302	1.03	BMB	1.37
3	6.56	Chloride	0.9554	32.65	BMB	0.93
4	9.83	Bromide	1.2950	44.26	BMB	0.88
5	15.65	Sulfate	0.0662	2.26	BMB	1.08
Total:			2.926	100.000	0.00	

Lab Project No.: 28557

Date Received: 3/29/2010

CleanAir No.: 10955
66

NOT IT

Customer : 66

Contact : Scott Brown

Phone :

Fax :

Email : sbrown@cleanair.com

Requested Analysis

Due	Analyst	Status	Sample	Type	Container	Method
4/12/2010	EE	In Queue	1-20	Imp C&R	500 mL Nalgen	EPA Method 26A
4/12/2010	EE	In Queue	21-22	Imp C&R	Glass Vials	EPA Method 26A 2 State Audit Samples
4/12/2010	EE	In Queue	23-32	Imp C&R	500 mL Nalgen	US EPA Method 13B

Printed 2010/03/29 12:28:23

WHEELABRATOR NORTH BROWARD, INC.
POMPANO BEACH, FL

CleanAir Project No: 10955-2

PERTINENT CERTIFICATIONS

J

This Page Intentionally Left Blank



AeroMet

Engineering, Inc.

Solutions for a Changing Environment

Certification of Visible Opacity Reading

Raina Vicere

qualified to conduct EPA Method 9 Tests for visible opacity in accordance with the methods established for such qualification in 40 CFR Part 60 Appendix A.

Certification Date: September 30, 2009

Expiration Date: March 30, 2010

AeroMet Instructor: *Trey Beauchamp*
Trey Beauchamp

AEROMET ENGINEERING INC. CERTIFIES THAT

Raina Vicere

has qualified as a CERTIFIED VISIBLE
EMISSIONS READER
per Title 40 Part 60 Appendix A USEPA Method 9

Issued: 9/30/09

Expires: 3/30/10

Questions? Call 573.636.6393

J-3

AeroMet Public School
GIFT CARD DRAWING

To see if you have won:

1. Go to www.aeromet.org
2. Click on Smoke School.
3. Click on Gift Card Drawing.
4. Look for your location on the list.

The winner from each public location will be announced within 7 days of the training event. You are automatically registered when you pass the certification test.

If your name is listed, you must contact AeroMet at 573.636.6393 to select your gift card. Good Luck!



FOR PUBLIC SCHOOLS ONLY

This Page Intentionally Left Blank

WHEELABRATOR NORTH BROWARD, INC.
POMPANO BEACH, FL

CleanAir Project No: 10955-2

CORRESPONDENCE AND CLARIFICATIONS

K

This Page Intentionally Left Blank



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
Office of Air Quality Planning and Standards
Research Triangle Park, North Carolina 27711

JAN 16 2002

Yves Tondeur, Ph.D.
Alta Analytical Perspectives
2714 Exchange Drive
Wilmington, NC 28405

Dear Dr. Tondeur:

We have reviewed your request dated April 26, 2001, to use an alternative gas chromatography separation column for the EPA Method 23 (40 CFR 60, Appendix A). Method 23 currently specifies the use of a DB-5 column to separate the polychlorinated dibenzodioxins (PCDD's) and polychlorinated dibenzofurans (PCDF's) that exhibit the 2, 3, 7, 8 chlorine substitution pattern from the many other PCDD and PCDF isomers. In addition, a DB-225 column must be used to separate the 2,3,7,8 tetrachloro dibenzofuran (2, 3, 7, 8 TCDF) from its nearest isomers because the DB-5 cannot make this separation. Method 23 does allow the user to substitute another column provided that it can achieve adequate separation of 2, 3, 7, 8 tetrachloro dibenzodioxin (2, 3, 7, 8 TCDD) from the other TCDD isomers and adequate separation of 2, 3, 7, 8 TCDF from the other TCDF isomers.


You are proposing to use a DB-5S column as a substitute for the combination of the DB-5 and DB-225 columns. In addition, you propose to modify the calibration and quality assurance procedures of Method 23 to demonstrate that the DB-5S column is achieving the necessary separation. Method 23 specifies an initial calibration using a series of 5 standard solutions having a range of concentrations of the various 2, 3, 7, 8 substituted PCDD and PCDF isomers. In addition to the initial calibration, Method 23 specifies a continuing calibration check with a midrange standard solution of the same isomers. If the results from the midrange standard solution meet certain performance requirements described in Method 23, the analytical system is in control and the analyst may continue to analyze samples. If the results do not meet those requirements, then the tester must repeat the initial calibration and continuing calibration until they do. As part of your alternative request, you are proposing to perform the initial calibration with the specified standard solutions. You are also proposing to perform the continuing calibration with a midrange standard solution that additionally contains the nearest eluting compounds to the 2, 3, 7, 8 TCDF isomer. The system would have to meet the usual performance requirements.

2

Method 23 contains a performance specification to demonstrate that alternative column systems can achieve adequate separation. This specification uses peak resolution as a surrogate for actual separation. You are requesting the use of the new column and the modified calibration procedures as an alternative because the DB-5S column does not meet the peak resolution specification of Method 23. We have determined that you may use the proposed new column without requesting an alternative method because the quality assurance requirements you have added will demonstrate that the column is meeting the separation requirement, and therefore, meeting the peak resolution specification (which serves as a surrogate for adequate separation) is not necessary.

If you have any questions about my decision, please feel free to contact Mr. Gary McAlister at (919)-541-1062.

Sincerely



J. David Mobley Acting Director
Emissions, Monitoring, and Analysis Division

cc: Deputy Director, Office of Ecosystem Protection, Region I
Director, Division of Environmental Planning and Protection, Region II
Director, Air Protection Division, Region III
Director, Air, Pesticides, and Toxics Management Division, Region IV
Acting Director, Air and Radiation Division, Region V
Director, Multimedia Planning and Permitting Division, Region VI
Director, Air, RCRA, and Toxics Division, Region VII
Director, Air & Radiation Program, Region VIII
Director, Air Division, Region IX
Director, Office of Air, Region X
Director, Air Enforcement Division, OECA (2242A)
Director, Compliance Assurance and Media Programs Division, OECA (2223A)



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
RESEARCH TRIANGLE PARK, NC 27711

JUN 3 2004

OFFICE OF
AIR QUALITY PLANNING
AND STANDARDS

Mr. Herbert T. Dixon, Jr.
Vice President
TESTAR, Inc.
7424-108 ACC Boulevard
Raleigh, NC 27617

Dear Mr. Dixon:

This is in response to your letter dated May 6, 2004, that requested approval for a modification to EPA Method 23 (40 CFR 60, Appendix A). Method 23 is required for determining compliance with polychlorinated dibenzo-p-dioxin and polychlorinated dibenzofuran emission limits in 40 CFR 60.30b - 60.39b (Subpart Cb), 40 CFR 60.50a - 60.59a (Subpart Ea), 40 CFR 60.50b - 60.59b (Subpart Eb), and 40 CFR 63.1340 - 63.1359 (Subpart LLL). In your letter you also cited Subpart Ca. Subpart Ca was withdrawn in 1995 when Subpart Cb became a final rule.

Method 23 specifies that the tester use acetone, methylene chloride, and toluene to recover the sample from the sampling train glassware. You have requested that we approve an alternative test procedure to omit the methylene chloride rinse. You are proposing this modification on behalf of your clients who operate municipal waste combustors subject to either Subpart Cb, Ea or Eb or operate Portland cement plants subject to Subpart LLL at the locations shown in the enclosure.


In addition, you requested approval of the same modification to EPA Method 0023A (EPA Publication # SW-846) on behalf of your clients who operate hazardous waste combustors. Method 0023A is required for determining compliance with polychlorinated dibenzo-p-dioxin and polychlorinated dibenzofuran emission limits in 40 CFR 264.340 - 264.347 (Subpart O). EPA's Office of Solid Waste is responsible for the emission limits on hazardous waste combustors in 40 CFR 264.343 as well as Method 0023A, and we do not have the delegated authority to approve alternatives to their test procedures.

Based on data that the EPA collected on the relative efficiency of rinsing with methylene chloride and toluene as opposed to rinsing with toluene alone, we agree that it is acceptable to omit the methylene chloride rinse. Therefore, we are approving your request to omit the methylene chloride rinse from Method 23, when the method is used to determine compliance with either 40 CFR 60.30b - 60.39b (Subpart Cb), 40 CFR 60.50a - 60.59a (Subpart Ea), 40 CFR

60.50b - 60.59b (Subpart Eb), or 40 CFR 63.1340 - 63.1359 (Subpart LLL) at the individual facilities specified in the enclosure (Tables I, II, and III).

If you need further assistance, please contact Gary McAlister at (919) 541-1062.

Sincerely,



Conniesue B. Oldham, Ph.D., Group Leader
Source Measurement Technology Group

Enclosure

cc: Jack Harvanek, Region I
Donald Wright, Region II
Chris Pilla, Region III
Dave McNeal, Region IV
Nabil Fayoumi, Region V
Charles Ritchey, Region VI
Don Bahnke, Region VII
Stanley Tong, Region IX
Paul Boys, Region X

**ATTACHMENT 1
MUNICIPAL WASTE COMBUSTION FACILITIES**

Facility Name	Facility Address
Wheelabrator Saugus, Inc.	Saugus, MA
Wheelabrator North Andover, Inc.	North Andover, MA
Wheelabrator Millbury, Inc.	Millbury, MA
Wheelabrator Concord, Inc.	Concord, NH
Wheelabrator Claremont, Inc.	Claremont, NH
Wheelabrator Lisbon, Inc.	Lisbon, CT
Wheelabrator Bridgeport, Inc.	Bridgeport, CT
Wheelabrator Hudson Falls, Inc.	Hudson Falls, NY
Wheelabrator Westchester, Inc.	Peekskill, NY
Wheelabrator Falls, Inc.	Morrisville PA
Wheelabrator Gloucester, Inc.	Westville, NJ
Wheelabrator Baltimore, Inc.	Baltimore, MD
Wheelabrator North Broward, Inc.	Pompano Beach, FL
Wheelabrator South Broward, Inc.	Ft. Lauderdale, FL
Wheelabrator Pinellas, Inc.	St. Petersburg, FL
Wheelabrator McKay Bay, Inc.	Tampa, FL
Wheelabrator Ridge, Inc.	Auburndale, FL
Wheelabrator Spokane, Inc.	Spokane, WA
Covanta Haverhill, Inc.	Haverhill, MA
Mid-Conn Resource Recovery Facility	Hartford, CT
Bristol Resource Recovery Facility	Bristol, CT
Wallingford Resource Recovery Facility	Wallingford, CT
Onondaga County Resource Recovery Facility	Syracuse, NY
Babylon Resource Recovery Facility	Babylon, NY
Huntington Resource Recovery Facility	Huntington, NY
Warren County Resource Recovery Facility	Oxford, NJ
Union County Resource Recovery Facility	Rahway, NJ
Lancaster County Resource Recovery Facility	Bainbridge, PA
Montgomery County Resource Recovery Facility	Dickerson, MD
Alexandria Waste to Energy Facility	Alexandria, VA
I-95 Energy / Resource Recovery Facility	Lorton, FL
Huntsville Resource Recovery Facility	Huntsville, AL
Lake County Resource Recovery Facility	Okahumpka, FL
Pasco County Resource Recovery Facility	Spring Hill, FL
Hillsborough County Resource Recovery Facility	Tampa, FL
Lee County Resource Recovery Facility	Ft. Meyers, FL
Michigan Waste Energy, Inc.	Detroit, MI
Kent County Resource Recovery Facility	Grand Rapids, MI
Indianapolis Resource Recovery Facility	Indianapolis, IN
Hennepin Resource Recovery Facility	Minneapolis, MN
Marion County Resource Recovery Facility	Salem, OR
Stanislaus Resource Recovery Facility	Crows Landing, CA
Honolulu Resource Recovery Venture	Honolulu, HI
York County Resource Recovery Facility	York, PA

ATTACHMENT 1
MUNICIPAL WASTE COMBUSTION FACILITIES
(continued)

Metro-Dade Resource Recovery Facility	Miami, FL
Panama City Resource Recovery Facility	Panama City, FL
Camden County Resource Recovery Facility	Camden, NJ
Montenay Charleston Resource Recovery, Inc.	Charleston, SC
Southeastern Connecticut Resource Recovery Facility	Preston, CT
Hempstead Resource Recovery Facility	Hempstead, NY
Mid-Maine Waste Action Corporation	Auburn, ME
Maine Energy Recovery Company	Biddeford, ME
SPSA	Portsmouth, VA