



Via electronic submittal

February 19, 2014

Yousry Attalla (Joe), P.E., CPM
Office of Permitting and Compliance
Division of Air Resource Management
Department of Environmental Protection
2600 Blair Stone Road
Tallahassee, Florida 32399

**RE: Title V Air Operation Permit - Renewal Application
City of Homestead Utilities - G.W. Ivey Power Plant
675 N. Flagler Avenue
Homestead, Florida 33030
Facility ID: 0250013
URS Job No. 38619581**

Dear Mr. Attalla:

City of Homestead Utilities (COH) respectfully submits this requested additional information for the Title V Air Operation Permit Renewal Application for the G. W. Ivey Power Plant (facility) located in Homestead, Florida. The additional information is provided in response to the Request for Additional Information (RAI) letter received from the Florida Department of Environmental Protection (FDEP) on November 25, 2013. The FDEP RAI letter was received in response to the Title V Air Operation Permit Renewal application submitted by the COH on October 4, 2013 for G.W. Ivey Power Plant. A copy of the FDEP RAI dated November 25, 2013 is included as **Attachment 1**. The comments provided by the FDEP are presented in bold, plain text and the COH responses are provided below in italic font.

- 1. The Compliance Report and Plan included with the application was a copy of the calendar year 2012 Annual Statement of Compliance, rather than a report of the current compliance status of each regulated emissions units. Please submit a full report of the current compliance status for all of the regulated units at the site (see also item 2.c.)**
 - Emission Units (Engines) 019, 020, and 021 have been retrofitted with oxidation catalysts, upgraded crankcase ventilation units, and monitoring systems. These units were successfully tested for compliance in February 2013. A copy of the compliance test report dated March 7, 2013 was submitted to the Miami-Dade County – Department of Regulatory and Economic Resources (Miami-Dade RER).*

- Energizing Your Hometown -

675 North Flagler Avenue • Homestead, Florida 33030
Phone: 305-224-4700 • Fax: 305-224-4769 • Email: hes@homesteadenergy.org

- Engines 002, 013, and 017 have been retrofitted with oxidation catalysts, upgraded crankcase ventilation units, and monitoring systems. These units were successfully tested for compliance in December 2013. A copy of the compliance test report dated January 10, 2014 was submitted to the Miami-Dade RER.
- Engines 003, 014, 015, 016 have been retrofitted with oxidation catalysts, upgraded crankcase ventilation units, and monitoring systems. These four EUs will be tested for compliance by May 2014. These engines will remain out of service until the compliance testing is complete.
- More detailed information is included in the response to item 2.c

Please note that the specifications for the oxidation catalyst, upgraded crankcase ventilation units, and monitoring systems were included with the original Title V Permit Renewal Application submitted in October 2013.

2. According to the application, the facility consists of 16 regulated dual fuel fired engine/generators (EUs 002, 003 and 008 – 021) and various unregulated fuel oil and miscellaneous storage tanks. Please confirm/clarify the following information that was reported in the application:

- a. **Retired Units:** EU 008 - EU 012 and EU 018 were listed in the application as having been taken out of service on May 3, 2013. Have these units been permanently removed from the site or are they being reserved in an inactive status with plans to upgrade them in order to comply with the federal RICE requirements at some point in the future? If they still remain at the site, what steps have been taken to ensure that these units are not capable of being operated until the necessary upgrades needed to comply with the RICE requirements are installed? If the intention is to utilize these engines in the future, please provide a compliance plan committing to a schedule for achieving compliance prior to future operation of these units.

Engines 008, 012, 018 listed as retired are permanently shut down with no plans to operate them in the future. They are not being kept in inactive reserve. The decision to retire the engines was made due their age and mechanical condition.

There are no plans to remove the engines from the site, but they are all tagged out and various tanks and lines are being removed.

- b. **Control Equipment:** EU 19, EU 20 and EU 21 have been equipped with a catalytic convertor, continuous monitoring system and an updated crankshaft ventilation system. These emission units were tested in February of 2013 and the associated test reports were received in the compliance office on March 7, 2013. The application lists the methods of operation for these engines as being able to fire on 100% oil and on a blend of oil and gas up to 95% natural gas. The introduction to the test report describes the units as being dual fueled engines fired on a blend of

95% natural gas and 5% oil. The test report shows the cubic feet of fuel fired during the tests, but does not specifically list how much oil (or what percentage of the total), if any, was fired during the actual tests.

By design, the engines utilize 5% to 7% of the total heat input from diesel fuel for ignition purposes. The natural gas supply to the engines is metered, but the fuel flow is not metered to the engine, only to the day tank. The average ratio of gas to fuel heat input can be determined over time by comparing day tank levels to gas consumption, but real time metering does not exist.

(1) Please clarify what fuel blend was fired during these referenced compliance tests.

The fuel blend used during the test was the same as referenced in the answer to question (3) below.

(2) Have any compliance tests been performed while firing 100% fuel oil?

No, there is not any intention of firing these engines on 100% diesel fuel.

(3) What is the normal fuel blend fired in these engines?

The engines run on natural gas with diesel fuel used for ignition only. By design, the heat input from the diesel fuel is 5% to 7%. The fuel oil used is ultra-low sulfur diesel (ULSD) containing 15 ppm sulfur or less.

(4) The test results indicate that the tests were performed at the “normal maximum achievable load of 57.8%, 65.9% and 86.3%, respectively for units 19, 20 and 21, as full load could not be achieved”. For permitting purposes, please provide the current design and operational capacities for each of the engines that will remain operational at this site.

*During the tests, the engines were run at the maximum achievable load that the engines were capable of on the day of the tests. Various mechanical or cooling problems prevented running the engines at name plate load. It is COH' preference to have the engines permitted at the name plate capacity, which is listed on the Engine Data Sheet, included as an **Attachment 2**.*

(5) If it is desired to be able to operate these engines (as well as the engines not yet tested) at maximum achievable load while firing 100% oil, please provide a schedule for performing representative compliance tests.

There is not any intention of firing these engines on 100% diesel fuel.

- c. **Pending Compliance Requirements:** “Installation of the catalytic convertors, continuous monitoring systems, and updated crankshaft ventilation systems for Emission Units 002, 003, 013 – 017 will be completed by December 2013.” In order to comply with the federal requirements for non-emergency reciprocating internal combustion engines (RICE), these upgrades were required to have been completed no later than May 3, 2013, and the initial compliance tests were required to be completed no later than October 30, 2013. Please be aware that any operation of these units subsequent to May 3, 2013 and prior to the completion of the upgrades is likely not in compliance with the RICE requirements. In order to determine the applicable requirements and compliance status that needs to be included in the renewed permit for each of these engines, please provide the following:

As included in the Response to the Comment No. 1, Engines 002, 003, 013, 014, 015, 016, 017 have been retrofitted with oxidation catalysts, upgraded crankcase ventilation units, and monitoring systems. Engines 002, 013, and 017 were successfully tested for compliance on December 3 and 4, 2013. Engines 003, 014, 015, 016 will be tested for compliance by May 2014 and will remain out of service until the compliance testing is complete.

(1) The operating history since May 3, 2013.

*Engines 003, 014, and 015 are not operated since May 3, 2013. Engines 002, 013, 016, and 017 were operated for backup electricity generation and their hours of operations from May 3, 2013 through November 21, 2013 were originally provided in an e-mail to Ms. Mallika Muthiah from Miami-Dade RER, on November 21, 2013. Engines 002, 013, 016, and 017 were not operated after November 21, 2013 unless the retrofitting and compliance testing activities were complete. A copy of the email is included as an **Attachment 3**.*

Please note that City of Homestead – Homestead Energy Services is a member of Florida Reliability Coordinating Council and serves as a control area within the State of Florida to have electricity generation available to respond to the disturbances to the electric grid in the State of Florida. Engines 002, 013, 016, and 017 were operated, without retrofitting from May 3, 2013 through November 21, 2013, to provide the backup electricity generation, either in the absence of the availability of the Engines 019, 020, and 021 or to meet the demand lower than the output of the Engines 019, 020, and 021.

(2) A schedule for completing the necessary upgrades.

All of the required retrofits/upgrades inclusive of the installation of the oxidation catalysts, upgraded crankcase ventilation units, and monitoring systems have been completed on the engines as of December 17, 2013.

(3) A schedule for completing the initial compliance testing.

- *Engines 019, 020, and 021 passed compliance testing on February 12, 2013.*
- *Engines 013 and 017 passed compliance testing on December 3, 2013.*
- *Engine 002 passed compliance testing on December 4, 2013.*
- *Engines 003, 014, 015, and 016 will be tested for compliance prior to May 2014 pending mechanical repairs that are required to operate the engine. These engines will remain out of service until the compliance testing is complete.*

(4) A schedule for submitting the initial test results.

- *The test results for engines 019, 020, and 021 have been submitted to the Miami-Dade RER in the compliance test report dated March 7, 2013.*
- *The test results for engines 002, 013, and 017 have been submitted to the Miami-Dade RER in the compliance test report dated January 10, 2014.*
- *Miami-Dade RER, FDEP, and the EPA will be notified of the future testing dates and the results submitted upon completion.*

(5) A compliance statement signed by the Responsible Official committing to and certifying that these schedules will be adhered to.

Noted. A compliance statement signed by the Responsible Official is included at the end of this RAI Response Letter.

- 3. As of May 3, 2013, the non-emergency compression ignition engines listed above are required to be fired on ultra-low sulfur diesel fuel oil containing no more than 0.015% sulfur. However, the existing permit describes these engines as being fired on diesel fuel containing 0.05% sulfur. Please provide documentation showing that the diesel fuel stored in the tanks that provide fuel for these engines contain a blended fuel that meets the requirements specified in 40 CFR 80.510 80.510(b) for non-road diesel fuel, and the date on which compliance with this requirement was achieved.**

COH has been purchasing and using Ultra Low Sulfur Diesel (ULSD) fuel for the engines located at the facility. Three invoices and bills of lading dated October 10, 2007, October

19, 2008, and September 9, 2010 for purchases of ULSD are included in the **Attachment 4**. COH had submitted fuel samples for sulfur content analysis to the Keystone Material Testing (KMT) in January 2011 and to Pace Analytical Services in September 2013. Copies of the laboratory reports, listing the low sulfur content in the fuel samples, dated January 21, 2011 and October 3, 2013, are also included in the **Attachment 4**.

- 4. Please identify all other internal combustion engine-driven pieces of equipment (i.e., generators, welders, air compressors, fire pumps, etc.) located at the facility that are subject to New Source Performance Standards (NSPS), Subpart IIII (Standards of performance for Stationary Compression Ignition Internal Combustion Engines), Subpart JJJJ (Standards or Performance for Spark Ignition Internal Combustion Engines) in 40 Code of Federal Regulations 60, and/or National Emission Standards for Hazardous Air Pollutants (NESHAP), Subpart ZZZZ (Stationary Reciprocating Internal Combustion Engines) in 40 CFR 63. For each such engine, please include the following information in a table:**

The facility has two other pieces of equipment utilizing internal combustion engines, an emergency backup generator (A) and an emergency air compressor (B).

- a. The engine brake-horse power, the kilowatt rating of the generator (if applicable), the number of cylinders and total displacement and the fuel type fired.**

- A. Emergency backup generator is a 158 horsepower, 100 kw, 6 cylinders, 4.5 L displacement unit operated on ULSD fuel.*
B. Emergency air compressor is a 143 horsepower, 6.1 L displacement unit operated on ULSD fuel.

- b. The date the engine was manufactured and the date the engine was ordered.**

- A. Emergency backup generator was manufactured in 2011 and purchased in 2012.*
B. Emergency air compressor was manufactured in 1989 and purchased in 1990.

- c. Is the engine certified by the manufacturer?**

- A. Emergency backup generator is certified as Tier 3/ Stage IIIA by the manufacturer.*
B. Emergency air compressor: No certification available.

- d. What is the engine used for?**

- A: Emergency Generator*
B: Emergency Air Compressor

e. Hours of operation. Does the engine meet the definition of an emergency/limited use as defined in the Code of Federal regulations?

- A. *Emergency backup generator is operated less than 100 hours per year.*
- B. *Emergency air compressor is operated less than 100 hours per year.*

f. Does the engine meet the definition of a stationary engine (i.e., is it set up in an operable configuration at one location within the facility for more than 12 consecutive months)?

Emergency backup generator and emergency air compressor remain within the facility for more than 12 consecutive months and hence meet the definition of stationary engine. The locations of these two units within the facility change depending on the usage requirements.

g. Please identify if the engine is equipped with control equipment?

Emergency backup generator and emergency air compressor are not equipped with any control equipment.

h. Please specify how the facility is complying with the applicable subparts.

Emergency backup generator and emergency air compressor are maintained and operated as per the manufacturer's recommendations.

5. Based on our review, it appears that these oil-fired diesel generators are subject to a nitrogen oxide emissions limit of 4.75 lb/MMBtu pursuant to Rule 62-296.570(4)(b)7., F.A.C., but this was not identified in the application as an applicable requirement. Please review this rule and either provide information regarding why you feel this rule is not applicable or provide information on how you will demonstrate compliance with this requirement in the future.

It is our understanding that nitrogen oxide emissions limit of 4.75 lb/MMBtu pursuant to Rule 62-296.570(4)(b)7., F.A.C. is applicable to engines which are operated on 100% fuel oil. The engines, 002, 003, 013, 014, 015, 016, 017, 019, 020, and 021, located at the facility are dual fuel engines, mainly operating on natural gas. The engines are started on 100% ULSD until the proper operating temperature is achieved, which is usually 5 to 10 minutes. The engines are then switched over to a dual fuel firing mode, which is typically 95% natural gas and 5% ULSD oil mixture. The ULSD is added to maintain operation. Therefore, above cited rule is not applicable to the Engines included the application.


Mr. Yousry Attalla (Joe), P.E. CPM
FDEP - Office of Permitting and Compliance
Response to FDEP's Request for Additional Information –
City of Homestead Utilities - G.W. Ivey Power Plant Facility ID: 0250013
February 19, 2014

Responsible Official Compliance Statement

I certify that I am a responsible official for the above listed facility and based on information and belief formed after reasonable inquiry, that the statements made in this RAI are true, accurate and complete and that, to the best of my knowledge. The air pollutant emissions units and air pollution control equipment described in this RAI will be operated and maintained so as to comply with all applicable standards for control of air pollutant emissions found in the statutes of the State of Florida and rules of the Department of Environmental Protection and revisions thereof and all other applicable requirements identified in this RAI to which the Title V source is subject. I understand that a permit, if granted by the department, cannot be transferred without authorization from the department, and I will promptly notify the department upon sale or legal transfer of the facility or any permitted emissions unit. Finally, I certify that the facility and each emissions unit are in compliance with all applicable requirements to which they are subject, except as identified in this RAI.

If you need any additional information, please contact the undersigned at (305) 224-4707.

Sincerely,
CITY OF HOMESTEAD UTILITIES



Kenneth J. Konkol
Assistant Director of Utilities

Attachments

1. Regulatory Correspondence
2. Engine Data Sheet
3. Copy of Email to Miami-Dade RER dated November 21, 2013 (Engine Hour Log)
4. Fuel Invoices and Laboratory Analytical Reports

Electronic cc:	Jonathan Holtom, Ms. Mallika Muthiah, Ms. Marta March, Ms. Ana Oquendo, Ms. Natasha Hazziez, Ms. Barbara Friday, Ms. Lynn Searce, Robert G. Cooper,	DARM/FDEP Miami Dade County, RER Miami Dade County, RER U.S. EPA Region 4 U.S. EPA Region 4 DEP OPC: DEP OPC: URS/Boca Raton	jon.holtom@dep.state.fl.us muthim@miamidade.gov marchm@miamidade.gov oquendo.ana@epa.gov hazziez.natasha@epa.gov barbara.friday@dep.state.fl.us lynn.searce@dep.state.fl.us bob.cooper@urs.com
----------------	--	---	---

ATTACHMENT 1

Regulatory Correspondence



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

BOB MARTINEZ CENTER
2600 BLAIR STONE ROAD
TALLAHASSEE, FLORIDA 32399-2400

RICK SCOTT
GOVERNOR

HERSCHEL T. VINYARD JR.
SECRETARY

November 25, 2013

Sent by Electronic mail – Received Receipt Requested

Mr. Kenneth J. Konkol, Assistant Director of Utilities
City of Homestead
675 North Flagler Avenue
Homestead, Florida 33030

Re: Request for Additional Information Regarding Title V Permit Renewal Application
Project No. 0250013-004-AV
Gordon W. Ivey Power Plant
Miami-Dade County, Florida

Dear Mr. Konkol:

The Department received your application for a Title V air operation permit renewal for the above referenced facility on October 4, 2013. The application was received in a timely manner and substantially addresses the information required to begin processing a Title V permit. However, in order to finish the processing of this application, the Department is requesting the additional information outlined below pursuant to Rules 62-213.420(1)(b)3. and 62-4.070(1), Florida Administrative Code (F.A.C.). Should your response to any of the items below require new calculations, please submit the new calculations, assumptions, reference material and appropriate revised pages of the application form.

1. The Compliance Report and Plan included with the application was a copy of the calendar year 2012 Annual Statement of Compliance, rather than a report of the current compliance status of each regulated emissions units. Please submit a full report of the current compliance status for all of the regulated units at the site (see also item 2.c.)
2. According to the application, the facility consists of 16 regulated dual fuel fired engine/generators (EUs 002, 003 and 008 – 021) and various unregulated fuel oil and miscellaneous storage tanks. Please confirm/clarify the following information that was reported in the application:
 - a. Retired Units: EU 008 - EU 012 and EU 018 were listed in the application as having been taken out of service on May 3, 2013. Have these units been permanently removed from the site or are they being reserved in an inactive status with plans to upgrade them in order to comply with the federal RICE requirements at some point in the future? If they still remain at the site, what steps have been taken to ensure that these units are not capable of being operated until the necessary upgrades needed to comply with the RICE requirements are installed? If the intention is to utilize these engines in the future, please provide a compliance plan committing to a schedule for achieving compliance prior to future operation of these units.
 - b. Control Equipment: EU 19, EU 20 and EU 21 have been equipped with a catalytic convertor, continuous monitoring system and an updated crankshaft ventilation system. These emission units were tested in February of 2013 and the associated test reports were received in the compliance office on March 7, 2013. The application lists the methods of operation for these engines as being able to fire on 100% oil and on a blend of oil and gas up to 95% natural gas. The introduction to the test report describes the units as being dual fueled engines fired on a blend of 95% natural gas and 5% oil. The test report shows the cubic feet of fuel fired during the tests, but does not specifically list how much oil (or what percentage of the total), if any, was fired during the actual tests.
 - (1) Please clarify what fuel blend was fired during these referenced compliance tests.
 - (2) Have any compliance tests been performed while firing 100% fuel oil?
 - (3) What is the normal fuel blend fired in these engines?

- (4) The test results indicate that the tests were performed at the “normal maximum achievable load of 57.8%, 65.9% and 86.3%, respectively for units 19, 20 and 21, as full load could not be achieved”. For permitting purposes, please provide the current design and operational capacities for each of the engines that will remain operational at this site.
 - (5) If it is desired to be able to operate these engines (as well as the engines not yet tested) at maximum achievable load while firing 100% oil, please provide a schedule for performing representative compliance tests.
- c. **Pending Compliance Requirements:** “Installation of the catalytic convertors, continuous monitoring systems, and updated crankshaft ventilation systems for Emission Units 002, 003, 013 – 017 will be completed by December 2013.” In order to comply with the federal requirements for non-emergency reciprocating internal combustion engines (RICE), these upgrades were required to have been completed no later than May 3, 2013, and the initial compliance tests were required to be completed no later than October 30, 2013. Please be aware that any operation of these units subsequent to May 3, 2013 and prior to the completion of the upgrades is likely not in compliance with the RICE requirements. In order to determine the applicable requirements and compliance status that needs to be included in the renewed permit for each of these engines, please provide the following:
- (1) The operating history since May 3, 2013.
 - (2) A schedule for completing the necessary upgrades.
 - (3) A schedule for completing the initial compliance testing.
 - (4) A schedule for submitting the initial test results.
 - (5) A compliance statement signed by the Responsible Official committing to and certifying that these schedules will be adhered to.
3. As of May 3, 2013, the non-emergency compression ignition engines listed above are required to be fired on ultra low sulfur diesel fuel oil containing no more than 0.015% sulfur. However, the existing permit describes these engines as being fired on diesel fuel containing 0.05% sulfur. Please provide documentation showing that the diesel fuel stored in the tanks that provide fuel for these engines contain a blended fuel that meets the requirements specified in 40 CFR 80.510(b) for non-road diesel fuel, and the date on which compliance with this requirement was achieved.
4. Please identify all other internal combustion engine-driven pieces of equipment (i.e., generators, welders, air compressors, fire pumps, etc.) located at the facility that are subject to New Source Performance Standards (NSPS), Subpart IIII (Standards of performance for Stationary Compression Ignition Internal Combustion Engines), Subpart JJJJ (Standards or Performance for Spark Ignition Internal Combustion Engines) in 40 Code of Federal Regulations 60, and/or National Emission Standards for Hazardous Air Pollutants (NESHAP), Subpart ZZZZ (Stationary Reciprocating Internal Combustion Engines) in 40 CFR 63. For each such engine, please include the following information in a table:
- a. The engine brake-horse power, the kilowatt rating of the generator (if applicable), the number of cylinders and total displacement and the fuel type fired.
 - b. The date the engine was manufactured and the date the engine was ordered.
 - c. Is the engine certified by the manufacturer?
 - d. What is the engine used for?
 - e. Hours of operation. Does the engine meet the definition of an emergency/limited use as defined in the Code of Federal regulations?
 - f. Does the engine meet the definition of a stationary engine (i.e., is it set up in an operable configuration at one location within the facility for more than 12 consecutive months)?
 - g. Please identify if the engine is equipped with control equipment?
 - h. Please specify how the facility is complying with the applicable subparts.
5. Based on our review, it appears that these oil-fired diesel generators are subject to a nitrogen oxide emissions limit of 4.75 lb/MMBtu pursuant to Rule 62-296.570(4)(b)7., F.A.C., but this was not identified in the application as an applicable requirement. Please review this rule and either provide information regarding why you feel this rule is not applicable or provide information on how you will demonstrate compliance with this requirement in the future.

Request for Additional Information

The above information is requested pursuant to the following F.A.C. regulations: Rule 62-4.050 (Procedures to Obtain Permits and Other Authorizations; Applications); 62-4.055 (Permit Processing); 62-4.070 (Standards for Issuing or Denying Permits; Issuance; Denial); 62-4.120 (Construction Permits); 62-204.800 (Federal Regulations Adopted by Reference); 62-212.300 (Permits Required); 62-210.370 (Emissions Computations and Reporting); 62-210.900 (Forms and Instructions); 62-212.300 (General Preconstruction Review); and 62-212.400 (Prevention of Significant Deterioration). All applications for a Department permit must be certified by a professional engineer registered in the State of Florida pursuant to Rule 62-4.050(3), F.A.C. This requirement also applies to responses to Department requests for additional information of an engineering nature. For any material changes to the application, please include a new certification statement by Responsible Official.

We will resume processing your application after receipt of the requested information. You are reminded that Rule 62-4.055(1), F.A.C. requires applicants to respond to requests for information within 90 days or to provide a written request for an additional period of time to submit the information. If you have any questions regarding this matter, please contact the project engineer, Yousry (Joe) Attalla, by telephone at (850) 717-9078 or by e-mail at yousry.attalla@dep.state.fl.us.

Sincerely,

Jon Holtom, P.E., CPM
Office of Permitting and Compliance
Division of Air Resource Management

JFK/sa/jh/yha

Mr. Kenneth J. Konkol, Assistant Director of Utilities: kkonkol@homesteadenergy.org

Ms. Mallika Muthia, Miami Dade County, RER: muthim@miamidade.gov

Ms. Marta March, Miami Dade County, RER: marchm@miamidade.gov

Ms. Ana Oquendo, U.S. EPA Region 4: oquendo.ana@epa.gov

Ms. Natasha Hazziez, U.S. EPA Region 4: hazziez.natasha@epa.gov

Ms. Barbara Friday, DEP OPC: barbara.friday@dep.state.fl.us

Ms. Lynn Scarce, DEP OPC: lynn.scarce@dep.state.fl.us

ATTACHMENT 2

Engine Data Sheet

ENGINE DATA

Engine Data Sheet

UNIT	ENGINE TYPE	SERIAL NUMBER	BHP	INSTALLED	NAMEPLATE		
					PF	KW	KVA
2	F/M 8 1/8 OP 12 CYL. (DF)	38D869019 TDF SM 12	2880	1970	80%	2070	2500
3	F/M 8 1/8 OP 12 CYL. (DF)	38D869024 TDF SM 12	2880	1970	80%	2070	2500
13	F/M 8 1/8 OP 12 CYL. (DF)	38D871061 TDF SM 12	2880	1972	80%	2070	2588
14	F/M 8 1/8 OP 12 CYL. (DF)	38D871062 TDF SM 12	2880	1972	80%	2070	2588
15	F/M 8 1/8 OP 12 CYL. (DF)	38D871064 TDF SM 12	2880	1972	80%	2070	2588
16	F/M 8 1/8 OP 12 CYL. (DF)	38D871068 TDF SM 12	2880	1972	80%	2070	2588
17	F/M 8 1/8 OP 12 CYL. (DF)	38D871069 TDF SM 12	2880	1972	80%	2070	2588
19	ENTER. DGSRV 20-4 (DF)	73029-2550	12,207	1975	0.8	8800	11000
20	COLT PIELSTICK PC2.3V (DF)	PO4206400A	9,000	1981	0.8	6485	8106
21	COLT PIELSTICK PC2.3V (DF)	PO4206400B	9,000	1981	0.8	6485	8106

ATTACHMENT 3

Copy of Email to Miami – Dade RER dated November 21, 2013 (Engine Hour Log)

Ken Konkol

From: Maria Medina
Sent: Thursday, November 21, 2013 1:32 PM
To: 'muthim@miamidade.gov'
Cc: Ken Konkol; William Branch
Subject: City of Homestead Engine Data

Mallika,

On behalf of Ken Konkol, as requested, listed below you will find the total hours ran during period May 3, 2013 through November 21, 2013 for engines located at the Gordon W. Ivey Power Plant for the City of Homestead.

Engine#2	163.10	
Engine#3	0.00	
Engine#8	0.00	(Retired)
Engine#9	0.00	(Retired)
Engine#10	0.00	(Retired)
Engine#11	0.00	(Retired)
Engine#12	0.00	(Retired)
Engine#13	1,250.50	
Engine#14	0.00	
Engine#15	0.00	
Engine#16	679.40	
Engine#17	1,394.90	
Engine#18	0.00	(Retired)
Totals:		3,487.90

Kind Regards,

Maria

Maria M. Medina
Administrative Assistant
Homestead Energy Services
Office: 305-224-4751
Fax: 305-224-4769
mmedina@cityofhomestead.com



ATTACHMENT 4

Fuel Invoices and Laboratory Analytical Reports



MANSFIELD

Mansfield Oil Company
of Gainesville, Inc.
1025 Airport Parkway, S.W.
Gainesville, Georgia 30501-6813
800-895-6628

PLEASE REMIT TO:

MANSFIELD OIL COMPANY
P. O. BOX 934067
ATLANTA, GA 31193-4067
FEIN 58-1091383

S H I P T O
CITY OF HOMESTEAD
POWER PLANT
675 NORTH FLAGLER AVENUE
HOMESTEAD FL 33030-D

B I L L T O
CITY OF HOMESTEAD
ATTN: DORIS JACKSON/POWER PLANT
675 NORTH FLAGLER AVE
HOMESTEAD FL 33030

ACCOUNT NUMBER 9325-01-250339

YOUR ORDER NUMBER 990219 -9/30/99

CONTRACT NO.

250339

TERMS FROM DELIVERY DATE	SHIP VIA	TERMINAL	DELIVERY NO.	DELIVERY DATE	INVOICE DATE	INVOICE N
T 30 DAYS	PENN TANK	PT EVERGLADE, FL	781-224	10/09/2007	10/10/2007	2503

B/L NO.	DESCRIPTION	GROSS	NET	UNIT PRICE	AMOUNT
545348	ULSD 15 DYED FED EXC LUST GOVT TA FL POLLUTION TAX FED ENV REC FEE	14:15 7501	7410	2.405500 .001000 020714 001200	17824. 7. 153. 8.

DEPT: Utilities DIV: PS
 REQ NO. _____ P.O. NO.: 080238
 PARTIAL: _____ FILED: DATE: 11/15/07
 FUND CFC OBJECT PROR AMOUNT
101-2300-53 31-50 E 547 252,132.53

 APPROVED AUTHORIZED DATE: 11/15/07 RM

1 of 4

ORIGINAL INVOICE

PLEASE PAY THIS AMOUNT

\$17,594.

LINE C SUPPLY OUTAGE

DUE 11/08/2007

UNLEADED DIESEL FUEL, NONTAXABLE USE ONLY, PENALTY FOR TAXABLE USE. THIS FUEL MEETS EP REQUIREMENTS FOR SULFUR (MAX .0015% SULFUR).

1601 ST 27TH ST, FT LAUDERDALE FL 33309 (510081)
 Order Number : 513349 REV: 0
 Order Entry : 10/09/2007 14:01:30 Loadorder: 4354
 Start Load : 10/09/2007 14:01:30
 End Load : 10/09/2007 14:15:51
 POLID NUMBER : 2007-10 07
 Company Registration Number : 4268

LOADING TICKET / BILL OF LADING

Subject to Section 7 of conditions of applicable bill of lading, if this shipment is to be delivered to consignee without recourse on the consignor, the consignor shall sign the following statement:
The carrier shall not make delivery of this shipment without payment of all charges.
SIGNATURE OF CONSIGNOR:
 Parathon Petroleum Company LLC

OLD TO'S : MANFIELD OIL CO OF GAINESVILLE INC
 Customer Account Number : 228002600701000
 Supplier : NPC Wholesale (Unbranded Non G)

SHIP TO: 026 MANFIELD OIL CO OF GAINESVILLE INC
 VARIOUS
 PL
 P.O. Number :
 Requisition : DEST : 701

RECEIVED BY: PENN TANK LINES
 ICAG Code : PTAL
 Trailer : 70

Carrier certifies that the cargo tank supplied for the shipment is a proper container for the transportation of this commodity.
 Received subject to tariffs and/or contracts in effect on the date of issuance thereof.
 Not a bill of lading when moved in a vehicle operated by the shipper or owner of product but merely a receipt for product on behalf of loader.
 X *[Signature]* :DRIVER

FINISHED PRODUCTS

PRODUCT NUMBER CODE	DESCRIPTION	GROSS	NET	SEE NOTES BELOW
827 827	12 MV15 DIESEL DYED	7501	7420	H, S, B

PRODUCTS BY COMPONENT

FINISHED PRODUCT COMPART & CODE	COMPONENT CODE & DESCRIPTION	GROSS	NET	TEMP	GRAV	TANK	TANK PERCENT
1 827	U04 12 MV15 DIESEL DYED DA1 RED DYE DA9 LUBRICITY	300	3260	86.7	35.9	35-1	100.0
2 827	U04 12 MV15 DIESEL DYED DA1 RED DYE DA9 LUBRICITY	1501	1482	86.1	35.9	35-1	100.0
3 827	U04 12 MV15 DIESEL DYED DA1 RED DYE DA9 LUBRICITY	2700	2668	86.0	35.9	35-1	100.0

HAZARD INFORMATION AND NOTES

Hesol Fuel
 NET Shipping Name: Combustible Liquid
 UN1993 PG III
 Total Quantity on Cargo Tank: 7501
 Gallons

24 HOUR EMERGENCY PHONE NUMBER 1-877-627-5463
 EPA Facility Registration Number: 81129
 See Note #1 on Back
 Additional Referenced Notes Located on Back

Refer to back of OSHA label information.
 Refer to Material Safety Sheet (available on request) for important health and safety information.

Receipt is acknowledged of the above merchandise in good conditions and in the quantities indicated.

X *[Signature]*

:CONSIGNEE

***** INVOICE *****

PAGE: 1

Macmillan Oil Company of Fla., Inc.
2955 East 11th Avenue
Hialeah, FL 33013
FEIN: 59-0648243

INVOICE NUMBER: 0191774-IN
INVOICE DATE: 10/19/08
ORDER NUMBER: 32454TR
ORDER DATE: 10/19/08
SALESPERSON: 0000
CUSTOMER NO: 10-CIHO

SOLD TO:
CITY OF HOMESTEAD
790 N. HOMESTEAD BOULEVARD

HOMESTEAD , FL 33030-6299

SHIP TO:
UTILITIES DEPARTMENT (C)
675 N FLAGLER AVENUE
PO # 090385
BID3143-9/18
HOMESTEAD , FL 33030-6173
BOL# 541535

CUSTOMER P.O. SHIP VIA F.O.B TERMS
090-385 Net 30 Days (from delivery)

ITEM NO.	UNIT	ORDERED	SHIPPED	BACK ORD	PRICE	AMOUNT
	OPIS	\$ 2.4282				
	FFSA	\$ 0.0220				
2300	GAL	7498.00	7406.00	0.00	2.4502	18,146.18
	RED - ULTRA LOW SULFUR DIESEL		WHSE: 377			
	Pollutant Tax				.0207	153.45
	Oil Spill Liability Fund				.0012	8.89
	FET - L.U.S.T. - Dyed				.0010	7.41
					2.4731	18,315.93

/UAP -362.92
UAP User Access Program - 2.0%
/IG 45.37
MiamiDade Audit Inspector .25%

TOTAL TOTAL TAXES AND FEES \$ 578.04

3920

NET INVOICE: 18,724.22
LESS DISCOUNT: .00
FREIGHT: .00
SALES TAX: .00

INVOICE TOTAL: 18,724.22

10/31/08

Marathon Petroleum Company LLC

501 SE 20TH ST FT LAUDERDALE FL 33405
 Order Entry : 10/19/2008 10:04:52 Load Order #5534
 Start Load : 10/19/2008 10:04:52
 End Load : 10/19/2008 10:16:54
 BLDG NUMBER : 2008-10-13
 Company Registration Number : 4268

LOADING TICKET / BILL OF LADING

Subject to Section 7 of conditions of applicable bill of lading, if this shipment is to be delivered to consignee without recourse on the consignor, the consignor shall sign the following statement:
 The carrier shall not make delivery of this shipment without payment of all charges.
SIGNATURE OF CONSIGNOR:
 Marathon Petroleum Company LLC

OLD TO: Sun Refining & Marketing Co
 Customer Account Number : 961400
 07876908910000
 Supplier : Sun Refining & Marketing Co

SHIP TO: 5310 MACMILLAN OIL CO. OF FL
 VARIOUS FL DEST
 VARIOUS FL
 P.O. Number :
 Requisition : DEST : 25314

RECEIVED BY:
 119 : MACMILLAN OIL CO OF FL
 CAC Code : MPFL
 Trailer : 1377

This is to certify that the herein named materials are properly classified, described, packaged, marked and labeled, and are in proper condition for transportation according to the applicable regulations of the Department of Transportation.
 Received subject to tariffs and/or contracts in effect on the date of issuance thereof.
 Not a bill of lading when moved in a vehicle operated by the shipper or owner of product but merely a receipt for product on behalf of loader.
X **DRIVER**

HAZARD INFORMATION

Shipping Name: 1993, Fuel oil, Combustible Liquid, PG III
 Gallons: 7498
 Total Quantity 1 Cargo Tank: 7498

24 HOUR EMERGENCY PHONE NUMBER 1-877-627-5463

FINISHED PRODUCTS

PRODUCT NUMBER	DESCRIPTION	GROSS	NET	SEE NOTES BELOW
827	#2 MV15 DIESEL DYED	7498	7406	H.S.8

PRODUCTS BY COMPONENT

FINISHED PRODUCT	COMPONENTS	GROSS	NET	TEMP	GRAY	TANK	TARGET PERCENT
1	827 U04 #2 MV15 DIESEL DYED DA1 RED DYE DA9 LUBRICITY	7498	7469	86.0	36.8	35-9	100.0
2	827 U04 #2 MV15 DIESEL DYED DA1 RED DYE DA9 LUBRICITY	999	987	86.8	36.8	35-9	100.0
4	827 U04 #2 MV15 DIESEL DYED DA1 RED DYE DA9 LUBRICITY	1800	1778	85.0	36.8	35-9	100.0
5	827 U04 #2 MV15 DIESEL DYED DA1 RED DYE DA9 LUBRICITY	2200	2172	86.3	36.8	35-9	100.0

NOTES
 A Facility Registration Number: 01128
 See Note #1 on Back
 Additional Referenced Notes Located on Back

7406

Refer to back of OSHA label information, refer to Material Safety Sheet (available on request) for important health and safety information.

Receipt is acknowledged of the above merchandise in good conditions and in the quantities indicated.

X [Signature]

CONSIGNEE

CARRIER



Macmillan Oil Company

OF FLORIDA, INC.
2955 E. 11th AVENUE
HALEAH, FLORIDA 33013

PHONE (305) 691-7814
FAX (305) 691-7817

www.macmillanoil.com

Page: 1

A Finance Charge of 1 1/2% per month (18% annum) will be charged on all invoices not paid within terms of the sale.

INVOICE NUMBER: 0246292-IN
INVOICE DATE: 9/25/2010

ORDER NUMBER: 64443YA
ORDER DATE: 9/25/2010
SALESPERSON: 0000
CUSTOMER NO: 10-CIHO

CITY OF HOMESTEAD RFP 683
790 N HOMESTEAD BOULEVARD
UAP - 01-3303-0031
HOMESTEAD, FL 33030-6299

GORDON W IVEY POWER PLANT
675 N FLAGLER AVENUE
PO 101921
HOMESTEAD, FL 33030-6173

BOL# 423694

CUSTOMER P.O.	SHIP VIA	F.O.B.	TERMS			
101921			Net 30 Days (from delivery)			
ITEM NO.	UNIT	ORDERED	SHIPPED	PRICE	AMOUNT	
PLATTS \$ 2.1515						
DIFF. \$ 0.10:0						
2300	GAL	7,500.00	7,406.00	2.25450	16,696.83	
DYED RED - ULTRA LOW SULFUR DI		Whse: 319				
POLLUTANT TAX				0.02071	153.38	
FEDERAL LUST TAX				0.00100	7.41	
OIL SPILL LIABILITY FUND				0.00191	14.15	
				2.27812	16,871.77	
/UAP					333.94	
UAP User Access Program - 2.0%						
/IG					41.74	
MiamiDade Audit Inspector .25%						
TOTAL TAXES AND FEES \$ 550.62						

DEPT: Whitbas DIV: RES. SUPPLIES
 REQ No.: 101921 P.O. No.: 101921
 PARTIAL: FINAL DATE: 10/11/10
 FUND: 401 C/C: 2300 OBJECT: 531.3150 PROJ: E547 AMOUNT: 224,488.14
 APPROVED: [Signature] AUTHORIZED: [Signature] DATE: 10/11/10

9/25, 240 gallons
Received: 9/25 - 9/30/10

Net Invoice:	17,247.45
Less Discount:	0.00
Freight:	0.00
Sales Tax:	0.00
Invoice Total:	17,247.45
Less Deposit:	0.00
	17,247.45

TransMontaigne Partners L.P.
 PORT EVERLADES NORTH #: 0012917
 2401 EISENHOWER BLVD
 FORT LAUDERDALE, FL 33316
 BILL OF LADING

Order Number:
 Order Date: 09/25/10
 Folio Number: 09/016
 Input Serial Number: 6644

BOL Number: 2423694
 Load Station: 09/25/10 09:39
 Load End: 09/25/10 06:01
 Order Type: Rack
 Loadspot Number: 02

Stockholder/Custom
 Type:
 0100001
 TRANSMONTAIGNE PRODUCT SERVICE
 TRACOR
 CONTRACT ACCOUNTS 1891

Account/Consignee
 Account #: 3983600
 MACMILLAN OIL COMPANY-ESC
 County:
 Consignee #: 0057874
 MACMILLAN OIL CO - ESC (FL)
 VARIOUS, FL

RECEIVED BY
 TN79619 HIALEAH TRANSPORT LLC
 SCAC #: HIXL
 Tractor #:
 Trailer #: 319

Retail or Petrox #
 POP
 Terminal EPA # 0000001870
 Destination EPA #

DRIVER
 Signature:
 X
 0001777 AVALOS YASSER

This is to certify that the herein named materials are properly classified, described, packaged, marked, and labeled, and are in proper condition for transportation, according to the applicable regulations of the Department of Transportation.

DELIVERY INSTRUCTIONS:

BOL COMMENTS: ABOVE SUPPLIER IS RESPONSIBLE FOR DESTINATION STATE TAX ON MOTOR FUEL
 * * * FOR EMERGENCY INFORMATION, CALL CHEMTRAC (800)484-7300 * * *

PRODUCT DESCRIPTION	GROSS	NET	TEMP	GRAV	OCT	RVP	TANK	MESSAGE NUMBER(S)
UL4343 DYED DSL (15PPM)HRLM	7500	7406	86.6	35.4	30.00			

U20 MSG: HA1793, DIESEL FUEL, 9, PG 117, 1 Cargo Tank, TOTAL 7500 7406 USE ENG GUIDE 128

1797,2201,1356,1798

MSG # MESSAGE

- 1799 DYED DIESEL FUEL, NONTAXABLE USE ONLY, PENALTY FOR TAXABLE USE. MEETS OR EXCEEDS ALL APPLICABLE LUBRICITY COMPLIANCE STANDARDS AS PER ASTM D975-04C.
- 2001 DYED 15 PPM SULFUR DIESEL FUEL. 15 PPM SULFUR (MAX) DYED ULTRA-LOW SULFUR DIESEL FUEL, FOR USE IN ALL HIGHWAY DIESEL ENGINES. NOT FOR USE IN HIGHWAY VEHICLES OR ENGINES EXCEPT FOR TAX-EXEMPT USE IN ACCORDANCE WITH SECTION 4082 OF THE INTERNAL REVENUE CODE.
- 1556 DYED DIESEL FUEL, NONTAXABLE USE ONLY, PENALTY FOR TAXABLE USE.
- 1798 DIESEL MEETS OR EXCEEDS ALL APPLICABLE LUBRICITY COMPLIANCE STANDARDS AS PER ASTM D975.

LOT	COMP	RISER	PRODUCT ID	PRODUCT NAME	GROSS	NET	TEMP	GRAV
	01	23	UL4343	DYED DSL (15PPM)HRLM	2500	2469	86.3	35.4
			UL4300	#2 DIESEL (15PPM) BASE	2500	2469	86.3	35.4
			000030	RED DYE	0.2170	0.2170	86.3	60.0
			000042	LUBRICITY ADDITIVE	0.2710	0.2710	86.3	60.0
	02	23	UL4343	DYED DSL (15PPM)HRLM	1500	1481	86.7	35.4
			UL4300	#2 DIESEL (15PPM) BASE	1500	1481	86.7	35.4
			000030	RED DYE	0.1370	0.1370	86.7	60.0
			000042	LUBRICITY ADDITIVE	0.1610	0.1610	86.7	60.0
	03	23	UL4343	DYED DSL (15PPM)HRLM	1000	987	86.9	35.4
			UL4300	#2 DIESEL (15PPM) BASE	1000	987	86.9	35.4
			000030	RED DYE	0.0870	0.0870	86.9	60.0
			000042	LUBRICITY ADDITIVE	0.1110	0.1110	86.9	60.0
	05	23	UL4343	DYED DSL (15PPM)HRLM	2500	2469	86.7	35.4
			UL4300	#2 DIESEL (15PPM) BASE	2500	2469	86.7	35.4
			000030	RED DYE	0.2170	0.2170	86.7	60.0
			000042	LUBRICITY ADDITIVE	0.2710	0.2710	86.7	60.0

SUBJECT TO CORRECTION OF CLERICAL ERRORS

CUSTOMER SIGNATURE X

CUSTOMER TANKS

NO CUSTOMER TANKS ON FILE



21-JAN-11

Project Manager: **Ken Konkol**
City of Homestead Energy Services
675 North Flagler Ave.
Homestead, FL 33030

Reference: XENCO Report No: **403757**
Diesel Fuel
Project Address:

Ken Konkol:

We are reporting to you the results of the analyses performed on the samples received under the project name referenced above and identified with the XENCO Report Number 403757. All results being reported under this Report Number apply to the samples analyzed and properly identified with a Laboratory ID number. Subcontracted analyses are identified in this report with either the NELAC certification number of the subcontract lab in the analyst ID field, or the complete subcontracted report attached to this report.

Unless otherwise noted in a Case Narrative, all data reported in this Analytical Report are in compliance with NELAC standards. Estimation of data uncertainty for this report is found in the quality control section of this report unless otherwise noted. Should insufficient sample be provided to the laboratory to meet the method and NELAC Matrix Duplicate and Matrix Spike requirements, then the data will be analyzed, evaluated and reported using all other available quality control measures.

The validity and integrity of this report will remain intact as long as it is accompanied by this letter and reproduced in full, unless written approval is granted by XENCO Laboratories. This report will be filed for at least 5 years in our archives after which time it will be destroyed without further notice, unless otherwise arranged with you. The samples received, and described as recorded in Report No. 403757 will be filed for 60 days, and after that time they will be properly disposed without further notice, unless otherwise arranged with you. We reserve the right to return to you any unused samples, extracts or solutions related to them if we consider so necessary (e.g., samples identified as hazardous waste, sample sizes exceeding analytical standard practices, controlled substances under regulated protocols, etc).

We thank you for selecting XENCO Laboratories to serve your analytical needs. If you have any questions concerning this report, please feel free to contact us at any time.

Respectfully,

Terrence Anderson
Office Manager

Recipient of the Prestigious Small Business Administration Award of Excellence in 1994.

Certified and approved by numerous States and Agencies.

A Small Business and Minority Status Company that delivers SERVICE and QUALITY

Houston - Dallas - San Antonio - Austin - Tampa - Miami - Atlanta - Corpus Christi - Latin America

CASE NARRATIVE SUMMARY

Client Name: *City of Homestead Energy Services*
Project Name: *Diesel Fuel*

Project ID:
Work Order Number: 403757

Report Date: 21-JAN-11
Date Received: 14-JAN-11

Analysis was subcontracted to KMT Laboratory, 600E 17th Street, S. Newton IA, 50208
See complete analytical report attached.

Sample designation

1. (HST-001) - Biodiesel
2. (HST-002) - Diesel



Terrence Anderson
Office Manager



ANALYTICAL REPORT

January 21, 2011

Page 1 of 1

Work Order: 91A0008

Report To

Terrence Anderson
Xenco Laboratories
3231 N.W. 7th Avenue
Boca Raton, FL 33431

Project : Fuel Testing

PO : WO # 403757

Analyte	Result	Method	Limits
ID:HST-001		Matrix:Biodiesel/B100	Collected: 01/14/11 13:30
CFPP	(4.00 C / 39.20 F)	C/F	ASTM D6371
Calorific Value	16590	BTU/lb	ASTM D240 >18000
Sulfur	1.7	ppm (wt)	ASTM D2622 <15
ID:HST-002		Matrix:Diesel Fuel	Collected: 01/14/11 13:00
CFPP	(-13.0 C / 8.60 F)	C/F	ASTM D6371
Calorific Value	19070	BTU/lb	ASTM D240 >18000
Sulfur	7.5	ppm (wt)	ASTM D2622 <15

End of Report

Keystone Materials Testing, Inc.

Josh King
Business Manager



CHAIN OF CUSTODY RECORD

Atlanta: 8017 Financial Dr. Norcross, GA 30071 770-449-9800
 Boca Raton: 3231 NW 7th Ave. Boca Raton, FL 33431 561-447-7373
 Miami: 14100 Palmetto Freeway Rd. Miami Lakes, FL 33016 305-823-8500

Company: **City of Homestead Utilities**
 Address: **14100 Palmetto Freeway Rd. Miami Lakes, FL 33016**
 PO #: **33016**
 Quote #: **33016**
 Zip: **33016**

Project Name: **Homestead**
 Project ID: **14111830**
 Sample Signature: **[Signature]**
 Collect Date: **1/14/11**
 Collect Time: **1:30**

Circle One Event: Quarterly Semi-Annual Annual Monthly
 Matrix Code: **A**
 Composite: **1**
 Filtered: **1**
 Total # of Containers: **1**

Reg. Program / Clean-up Std: **STP Standards**
 State for Certs & Regs: **FL TX GA NC SC NJ PA OK LA AL IL Other:**
 QA/QC Level & Certification: **1 2 3 4 CLP AFCEE QAPP NELAC DoD-ELAP Other:**

Reg. Program / Clean-up Std: **STP Standards**
 State for Certs & Regs: **FL TX GA NC SC NJ PA OK LA AL IL Other:**
 QA/QC Level & Certification: **1 2 3 4 CLP AFCEE QAPP NELAC DoD-ELAP Other:**

Reg. Program / Clean-up Std: **STP Standards**
 State for Certs & Regs: **FL TX GA NC SC NJ PA OK LA AL IL Other:**
 QA/QC Level & Certification: **1 2 3 4 CLP AFCEE QAPP NELAC DoD-ELAP Other:**

Reg. Program / Clean-up Std: **STP Standards**
 State for Certs & Regs: **FL TX GA NC SC NJ PA OK LA AL IL Other:**
 QA/QC Level & Certification: **1 2 3 4 CLP AFCEE QAPP NELAC DoD-ELAP Other:**

Reg. Program / Clean-up Std: **STP Standards**
 State for Certs & Regs: **FL TX GA NC SC NJ PA OK LA AL IL Other:**
 QA/QC Level & Certification: **1 2 3 4 CLP AFCEE QAPP NELAC DoD-ELAP Other:**

Reg. Program / Clean-up Std: **STP Standards**
 State for Certs & Regs: **FL TX GA NC SC NJ PA OK LA AL IL Other:**
 QA/QC Level & Certification: **1 2 3 4 CLP AFCEE QAPP NELAC DoD-ELAP Other:**

Reg. Program / Clean-up Std: **STP Standards**
 State for Certs & Regs: **FL TX GA NC SC NJ PA OK LA AL IL Other:**
 QA/QC Level & Certification: **1 2 3 4 CLP AFCEE QAPP NELAC DoD-ELAP Other:**

Reg. Program / Clean-up Std: **STP Standards**
 State for Certs & Regs: **FL TX GA NC SC NJ PA OK LA AL IL Other:**
 QA/QC Level & Certification: **1 2 3 4 CLP AFCEE QAPP NELAC DoD-ELAP Other:**

Reg. Program / Clean-up Std: **STP Standards**
 State for Certs & Regs: **FL TX GA NC SC NJ PA OK LA AL IL Other:**
 QA/QC Level & Certification: **1 2 3 4 CLP AFCEE QAPP NELAC DoD-ELAP Other:**

* Container Type Codes

VA	Vial Amber	ES	Encoke Sampler
VC	Vial Clear	TS	TimeCore Sampler
VP	Vial Pre-preserved	AC	Air Canister
VQ	Vial Clear	TB	Tedlar Bag
GA	Glass Amber	ZB	Zip Lock Bag
GC	Glass Clear	FB	Zip Lock Bag
PA	Plastic Amber	PC	Plastic Clear
Other: _____			

** Preservative Type Codes

A	None	E	HCL	I	Ice
B	HNO ₃	F	MeOH	J	MCAA
C	H ₂ SO ₄	G	Na ₂ S ₂ O ₃	K	ZnAc2/NaOH
D	NaOH	H	NaHSO ₄	L	Asbic Acid/NaOH
O	Other				

A Matrix Type Codes

GW	Ground Water	S	Soil/Sediment/Solid
WW	Waste Water	W	Wipe
DW	Drinking Water	A	Air
SW	Surface Water	O	Oil
OW	Ocean/Sea Water	T	Tissue
PL	Product-Liquid	U	Urine
PS	Product-Solid	B	Blood
SL	Sludge		
Other			

Sample #	Sample ID	Collect Date	Collect Time	Matrix Code	Composite	Filtered	Total # of Containers	Project ID	Phone	Fax	Quote #	Zip	Company	Address	PO #	TAT Work Days = D	Need results by:	Time:	Field Billable Hrs:	Lab W.O. #	Page # of #	ANALYSES REQUESTED		REMARKS	
																						Std (5-10D)	6Hrs		1D
1	Diesel	1/14/11	1:30	A	1	1	1	14111830					City of Homestead Utilities	14100 Palmetto Freeway Rd. Miami Lakes, FL 33016	33016	33016	33016				409757	1 of 1	GC GC	ASTM D6371 B-14 Content ASTM D6371	
2	Bio Diesel	1/14/11	1:30	A	1	1	1	14111830					City of Homestead Utilities	14100 Palmetto Freeway Rd. Miami Lakes, FL 33016	33016	33016	33016				409757	1 of 1	GC GC	ASTM D6371 B-14 Content ASTM D6371	
3																									
4																									
5																									
6																									
7																									
8																									
9																									
0																									

FTS: Philadelphia 610-955-5649 South Carolina 803-543-8099 B&A Laboratories: Corpus Christi 361-884-0371 Dallas 214-902-0300 Houston 281-240-4200 Odessa 432-563-1800 San Antonio 210-509-3334
 Execution of this document by client creates a legal and binding agreement between client and Xenco for analytical and testing services provided by Xenco to client under Xenco's standard terms and conditions unless previously agreed in writing. Terms of payment are Net 30 days, and all past due amounts shall accrue interest at 1.5% per month until paid in full. All laboratory analytical data and reports generated by Xenco remain the exclusive property of Xenco until invoices for such data are paid in full.
 Property of XENCO - Revision Date: Nov 12, 2009
 C.O.C. Serial # **282233**



Prelogin/Nonconformance Report- Sample Log-In

Client: City of Homestead Utilities
Date/ Time Received: 1/14/11 1740
WO ID #: 403757
Initials of Sample Receipt Person: AK
Checklist completed by, date/time: TH 1/14/11 7:00

Acceptable Temperature Range: 2-6° C
Acceptable pH Range(s):
<2 for samples preserved with HNO3, HCL, H2SO4
>10 for samples preserved with NaAsO2+NaOH, ZnAc+NaOH

Temperature Measuring device used: TDS

Sample Receipt Checklist

#	*Temperature of cooler(s)?	# of Coolers			Comments
#1		<u>1</u>	<u>1</u>	<u>13.0°c</u>	
#2	*Shipping container in good condition?	<u>YES</u>	No	None	
#3	*Samples received on ice?	<u>YES</u>	No	N/A	Blue / Water
#4	*Custody Seals intact on shipping container/ cooler?	Yes	No	<u>N/A</u>	
#5	Custody Seals intact on sample bottles/ container?	Yes	No	<u>N/A</u>	
#6	*Custody Seals Signed and dated for Containers/coolers	Yes	No	<u>N/A</u>	
#7	*Chain of Custody present?	<u>YES</u>	No		
#8	Sample instructions complete on Chain of Custody?	<u>YES</u>	No		
#9	Any missing extra samples?	Yes	<u>NO</u>		
#10	Chain of Custody signed when relinquished/ received?	<u>YES</u>	No		
#11	Chain of Custody agrees with sample label(s)?	<u>YES</u>	No		
#12	Container label(s) legible and intact?	<u>YES</u>	No		
#13	Sample matrix/ properties agree with Chain of Custody?	<u>YES</u>	No		
#14	Samples in proper container/ bottle?	<u>YES</u>	No		
#15	Samples properly preserved?	<u>YES</u>	No	N/A	See Attached Preservation Sheet if NO
#16	Sample container(s) intact?	<u>YES</u>	No		
#17	Sufficient sample amount for indicated test(s)?	<u>YES</u>	No		
#18	All samples received within hold time?	<u>YES</u>	No		
#19	Subcontract of sample(s)?	Yes	<u>NO</u>		
#20	VOC samples have zero headspace (less than 1/4 inch bubble)?	YES	No	<u>N/A</u>	

* Must be completed for after-hours delivery of samples prior to placing in the refrigerator

pH Check: Date/Time: _____ Analyst: _____ pH Device/Lot Number: _____

Nonconformance Documentation

Contact: _____ Contacted by: _____ Date/ Time: _____

Regarding: _____

Corrective Action Taken: _____

XENCO LABORATORIES
Container Receipt Verification Form

Work Order Number: **4103757**

Chain of Custody Number(s): _____

Tests	Container Type/Pres.	gal GA/	32oz NM GA/	32oz NM GA/	32oz NM GA/	32oz W/M GA/	VOA/	VOA/	VOA/	120mL P. w. Pill	4oz Plastic	4oz Plastic	250mL HDPE/	250mL HDPE/	500mL HDPE/	500mL HDPE/	500mL HDPE/	1L HDPE/	1L HDPE/	9oz GC/	9oz GC/	9oz GC/	4oz GC/	4oz GC/	2oz GC/	2oz GC/	2oz GC/	Tedlar Bag	Ampules/	Other/	Comments				

Abbreviations:
 Gal GA = One gallon amber
 32oz NM GA = 32 oz Amberglass
 VOA = 40mL vials
 32oz W/M GA = 32 oz Wide Mouth Amberglass
 1L HDPE = 1L (1000mL) Plastic Bottle
 500mL HDPE = 500mL Plastic Bottle
 250mL HDPE = 250mL Plastic Bottle
 8oz GC = 8oz Soil Jar
 4oz GC = 4oz Soil Jar
 2oz GC = 2oz soil jar
 120mL Plastic w. Pill = BacT
 Zip = Ziplock Bag
 4oz Plastic = 4oz Plastic Bottle
 HCl = Hydrochloric Acid
 H2SO4 = Sulfuric Acid
 NaOH = Sodium Hydroxide
 MeOH = Methanol
 HNO3 = Nitric Acid
 ZnAc = Zinc Acetate
 Na2S2O3 = Sodium Thiosulfate
 NH4Cl2 = Ammonium Chloride
 DI H2O = DI Water
 MCAA = Monochloroacetic Acid
 Reviewed By: _____



Pace Analytical Services, Inc.
3610 Park Central Blvd N
Pompano Beach, FL 33064
954-582-4300

October 03, 2013

Ken Knokol
City of Homestead
675 North Flagler Ave.
Homestead, FL 33030

RE: Project: Fuel Sample
Pace Project No.: 35109113

Dear Ken Knokol:

Enclosed are the analytical results for sample(s) received by the laboratory on September 19, 2013. The results relate only to the samples included in this report. Results reported herein conform to the most current TNI standards and the laboratory's Quality Assurance Manual, where applicable, unless otherwise noted in the body of the report.

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Terrence Anderson

terrence.anderson@pacelabs.com
Project Manager

Enclosures

cc: Billy Branch, City of Homestead



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc.



Pace Analytical Services, Inc.
3610 Park Central Blvd N
Pompano Beach, FL 33064
954-582-4300

CERTIFICATIONS

Project: Fuel Sample
Pace Project No.: 35109113

Asheville Certification IDs

2225 Riverside Dr., Asheville, NC 28804
Florida/NELAP Certification #: E87648
Massachusetts Certification #: M-NC030
North Carolina Drinking Water Certification #: 37712

North Carolina Wastewater Certification #: 40
South Carolina Certification #: 99030001
West Virginia Certification #: 356
Virginia/VELAP Certification #: 460222

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..



Pace Analytical Services, Inc.
3610 Park Central Blvd N
Pompano Beach, FL 33064
954-582-4300

SAMPLE SUMMARY

Project: Fuel Sample
Pace Project No.: 35109113

Lab ID	Sample ID	Matrix	Date Collected	Date Received
35109113001	Fuel Sample	Non Aqueous	09/19/13 10:00	09/19/13 17:45

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc.,



Pace Analytical Services, Inc.
3610 Park Central Blvd N
Pompano Beach, FL 33064
954-582-4300

SAMPLE ANALYTE COUNT

Project: Fuel Sample
Pace Project No.: 35109113

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
35109113001	Fuel Sample	ASTM D4239-05	ANS	1	PASI-A
		ASTM D482-95	ANS	1	PASI-A
		ASTM D5468-02	ANS	1	PASI-A

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..



ANALYTICAL RESULTS

Project: Fuel Sample

Pace Project No.: 35109113

Sample: Fuel Sample Lab ID: 35109113001 Collected: 09/19/13 10:00 Received: 09/19/13 17:45 Matrix: Non Aqueous Liquid

Results reported on a "dry-weight" basis

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
ASTM D4239-05 Sulfur	Analytical Method: ASTM D4239-05								
Sulfur	ND	% (w/w)	0.020		1		10/02/13 09:30		N2
ASTM D482-95 ASH	Analytical Method: ASTM D482-95								
Percent Ash	ND	% (w/w)	0.010		1		10/03/13 09:36		N2
ASTM D5468-02 BTU	Analytical Method: ASTM D5468-02								
British Thermal Units	20140	BTU/lb	50.0		1		10/01/13 17:15		N2

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, Inc..

QUALIFIERS

Project: Fuel Sample
Pace Project No.: 35109113

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
ND - Not Detected at or above adjusted reporting limit.
MDL - Adjusted Method Detection Limit.
PRL - Pace Reporting Limit.
RL - Reporting Limit.
S - Surrogate
1,2-Diphenylhydrazine (8270 listed analyte) decomposes to Azobenzene.
Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.
LCS(D) - Laboratory Control Sample (Duplicate)
MS(D) - Matrix Spike (Duplicate)
DUP - Sample Duplicate
RPD - Relative Percent Difference
NC - Not Calculable.
SG - Silica Gel - Clean-Up
U - Indicates the compound was analyzed for, but not detected.
N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.
Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.
TNI - The NELAC Institute.

LABORATORIES

PASI-A Pace Analytical Services - Asheville

ANALYTE QUALIFIERS

N2 The lab does not hold TNI accreditation for this parameter.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Fuel Sample
Pace Project No.: 35109113

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
35109113001	Fuel Sample	ASTM D4239-05	WET/27391		
35109113001	Fuel Sample	ASTM D482-95	WET/27407		
35109113001	Fuel Sample	ASTM D5468-02	WET/27359		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc.

WO#: 35109113
 35109113

CHAIN OF CUSTODY RECORD

LAB WO # _____

Quote: _____

Page 1 of 1

Company Name: City of Homestead PO#

Address: _____

City: _____ State: _____ Zip: _____

Attn: Ken Kontsi Fax# _____

email: _____ Phone: _____

Project Name: Fuel Sample Proj # _____

Sampler Signature: [Signature] Circle One Event: Daily Weekly Monthly Quarterly Semi-Annual Annual N/A

Parameters

Sulfur
 BTU
 Specific Gravity
 Ash

EXAMPLE
 Diss. Lead 6010

Container Type Codes

AV Amber Vial	ESB Enone Sampler
CV Clear Vial	PRV Preserved Vial
PL Plastic	PLC Plastic
PL Amber Lbr	PLJ Plastic Jar
AP Amber Plastic	TP Taper Bag
AG Amber Glass	WIP White Ink
SI Seal Jar	QJN Quin Jar
OW Other	TC Tern-one

Preserved Vial (SGL): 202, 402, 602, 1002, 2002 or "L" other _____
 Example: Asp = Asp Plastic, SGL in Asp Seal Jar

Matrix Codes

SD Solid Waste	OL Oil
GW Ground Water	SL Sludge
EP Effluent	SO Soil Sediment
FR Fly Ash	NA Non-hazardous
WW Wash Water	PE Petroleum
DW Drinking Water	O Other (Please specify)
SW Surface Water	
M Misc. Liquid	


Preservative Type Codes

A. None	E. HCl	I. Ice
B. HNO3	F. MeOH	J. MCAA
C. H2SO4	G. Na2S2O3	K. Zn Acetate
D. NaOH	H. NaHSO4	O. Other

REMARKS

55/3

Sample #	Site/Matrix	Collection Date	Collection Time	Method	Volume	Container	Matrix	Preservative	Temperature	Analysis	Remarks
1	Fuel sample	9/19/13	1:00 PM	Rotax N	1	AV	SD	A	55/3	Sulfur, BTU, Specific Gravity, Ash	
2											
3											
4											
5											
6											
7											
8											
9											
10											

	Document Name: Sample Condition Upon Receipt Form	Document Revised: September 23, 2011
	Document No.: F-FL-C-007 rev. 04	Issuing Authority: Pace Florida Quality Office

Sample Condition Upon Receipt Form (SCUR)

Table Number: _____

Client Name: C.D. Harold Project # _____

Courier: Fed Ex UPS USPS Client Commercial Pace Other _____

Tracking # _____

Custody Seal on Cooler/Box Present: yes no Seals Intact: yes no

Packing Material: Bubble Wrap Bubble Bags None Other _____

Thermometer Used T-108 Type of Ice: Wet Blue None

Date and Initials of person examining contents: TSS 9/11/18

Cooler Temperature °C 4.7 (Visual) -0.2 (Correction Factor) 4.6 (Actual) (Temp should be above freezing to 6°C. If below 0°C, then was sample frozen?)
 Yes No

Receipt of samples satisfactory: Yes No Rush TAT requested on COC: _____

If yes, then all conditions below were met: _____ If no, then mark box & describe issue (use comments area if necessary): _____

Chain of Custody Present	<input type="checkbox"/>
Chain of Custody Filled Out	<input type="checkbox"/>
Relinquished Signature & Sampler Name COC	<input type="checkbox"/>
Samples Arrived within Hold Time	<input type="checkbox"/>
Sufficient Volume	<input type="checkbox"/>
Correct Containers Used	<input type="checkbox"/>
Containers Intact	<input type="checkbox"/>
Sample Labels match COC (sample IDs & date/time of collection)	<input type="checkbox"/>
	No Labels: <input type="checkbox"/> No Time/Data on Labels: <input type="checkbox"/>
All containers needing preservation are found to be in compliance with EPA recommendation.	<input type="checkbox"/>
No Headspace in VOA Vials (>6mm):	<input type="checkbox"/>

Client Notification/ Resolution: Person Contacted: _____ Date/Time: _____

Comments/ Resolution (use back for additional comments): _____

Project Manager Review: _____ Date: _____

Finished Product Information Only	
F.P. Sample ID: _____	Size & Qty of Bottles Received
Production Code: _____	_____ x 5 Gal
Date/Time Opened: _____	_____ x 2.5 Gal
Number of Unopened Bottles Remaining: _____	_____ x 1 Gal
	_____ x 1 Liter
	_____ x 500 mL
	_____ x 250 mL
	_____ x Other: _____
Extra Sample in Shed: Yes No	