

**DEPARTMENT OF ENVIRONMENTAL PROTECTION
NOTICE OF ADMINISTRATIVE PERMIT CORRECTION**

In the Matter of an Application for Administrative Permit Correction:

Mr. Paul M. Smith
Plant Manager
11201 New Berlin Road
Jacksonville, Florida 32226

DEP File No. 0310045-014-AC, PSD-FL-010
JEA – St. Johns River Power Park


The Department has determined that a minor correction to information contained in Permit Number 0310045-014-AC is required. This correction is related to a typographical error and is minor in nature and does not alter, modify or revise any permit requirement. The correction is related to the compliance procedure for Carbon Monoxide monitoring shown on Page BD-8 of the Technical Evaluation and Final Determination for "Increased Co-Firing of Petroleum Coke" dated March 30, 2005 and revised March 30, 2006. The Compliance Procedure should read:

Five years of annual reporting by CEMS stack test proving annual emissions do not exceed 13776.5 TPY

This permit correction corrects and is a part of Permit Number 0310045-014-AC. This permit correction is issued pursuant to Chapter 403, Florida Statutes.

Any party to this order (permit correction) has the right to seek judicial review of it under section 120.68 of the Florida Statutes, by filing a notice of appeal under rule 9.110 of the Florida Rules of Appellate Procedure with the clerk of the Department of Environmental Protection in the Office of General Counsel, Mail Station #35, 3900 Commonwealth Boulevard, Tallahassee, Florida, 32399-3000, and by filing a copy of the notice of appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The notice must be filed within thirty days after this order is filed with the clerk of the Department.

Executed in Tallahassee, Florida.



Trina Vielhauer, Chief
Bureau of Air Regulation


CERTIFICATE OF SERVICE

The undersigned duly designated deputy agency clerk hereby certifies that this Notice of Administrative Permit Correction was sent by certified mail (*) and copies were mailed by U.S. Mail before the close of business on 4/28/06 to the person(s) listed:

James M. Chansler, JEA *
Jay A. Worley, JEA
Gregg Worley, EPA
John Bunyak, NPS
Chris Kirts, NED
Richard Robinson, P.E. ERMD
Mr. Hamilton S. Oven, DEP-Siting

Clerk Stamp

FILING AND ACKNOWLEDGMENT FILED, on this date, pursuant to §120.52, Florida Statutes, with the designated Department Clerk, receipt of which is hereby acknowledged.


(Clerk) 4/28/06 (Date)

TECHNICAL EVALUATION AND FINAL DETERMINATION

from the date the units resume regular operation, information demonstrating that the change did not result in a significant emissions increase. If SJRPP fails to comply with the reporting requirements of the WEPCO rule or if the submitted information indicates that emissions have increased above PSD thresholds as a consequence of the change, it will be required to obtain a PSD permit for petcoke co-firing (meaning that a BACT Review would then be applicable). Finally, even though a PSD review is not triggered due to the co-firing project, SJRPP must meet all other applicable federal, state, and local air pollution requirements.

7. ADDITIONAL COMPLIANCE PROCEDURES (AVERAGE PER EMISSION UNIT)

Pollutant	Compliance Procedures
NO _x	Five years of annual reporting by CEMS proving annual emissions do not exceed 26598.7 TPY
CO	Five years of annual reporting by <u>CEMS</u> stack test proving annual emissions do not exceed 13776.5 TPY
VOC	Five years of annual reporting by historical AOR methods, proving annual emissions do not exceed 158.5 TPY
SO ₂	Five years of annual reporting by CEMS proving annual emissions do not exceed 21758.7 TPY
SAM	Five years of annual reporting by stack test proving annual emissions do not exceed 1323.8 TPY
PM	Five years of annual reporting by stack test proving annual facility emissions do not exceed 346.7 TPY

Specific permit conditions shall further describe these limitations. The reporting procedures are to begin during the first calendar year in which petcoke is fired.

8. CONCLUSION

Based on the foregoing technical evaluation of the application, additional information submitted by the applicant and other available information, the Department has made a final determination that the proposed project will comply with all applicable state and federal air pollution regulations.

Michael P. Halpin, P.E. Review Engineer
Department of Environmental Protection, Bureau of Air Regulation
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

9. 2006 REVISION

The tables within Section 4.1 and 7 herein are revised as of March of 2006 in order to more accurately reflect historical carbon monoxide emissions, since the related permit references these tables. The data reflected within this revision is based upon historical CEMS data which the Department considers more accurate than AP-42 emission factors (see 62-210.370, F.A.C.).

SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

Mr. Paul Smith, Plant Manager
 JEA-St. Johns River Power Park
 11201 New Berlin Road
 Jacksonville, Florida 32226

COMPLETE THIS SECTION ON DELIVERY

A. Signature
 X *[Signature]* Agent Addressee

B. Received by (Printed Name) *K Toomer* C. Date of Delivery *5-4-01*

D. Is delivery address different from item 1? Yes
 If YES, enter delivery address below: No

3. Service Type
 Certified Mail Express Mail
 Registered Return Receipt for Merchandise
 Insured Mail C.O.D.

4. Restricted Delivery? (Extra Fee) Yes

2. Article Number (Transfer from service label) 7000 1670 0013 3110 0659

PS Form 3811, February 2004 Domestic Return Receipt 102595-02-M-1540

SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

Mr. James M. Chansler
 V.P. Operations and Maintenance
 JEA
 St. Johns River Power Park
 21 West Church Street
 Jacksonville, Florida 32202

COMPLETE THIS SECTION ON DELIVERY

A. Signature
 X *[Signature]* Agent Addressee

B. Received by (Printed Name) C. Date of Delivery *5-4*

D. Is delivery address different from item 1? Yes
 If YES, enter delivery address below: No

3. Service Type
 Certified Mail Express Mail
 Registered Return Receipt for Merchandise
 Insured Mail C.O.D.

4. Restricted Delivery? (Extra Fee) Yes

2. Article Number (Transfer from service label) 7000 1670 0013 3110 0666

PS Form 3811, February 2004 Domestic Return Receipt 102595-02-M-1540

**U.S. Postal Service
 CERTIFIED MAIL RECEIPT
 (Domestic Mail Only; No Insurance Coverage Provided)**

Mr. Paul Smith, Plant Manager

Postage	\$	Postmark Here
Certified Fee		
Return Receipt Fee (Endorsement Required)		
Restricted Delivery Fee (Endorsement Required)		
Total Postage & Fees	\$	

Sent To
 Mr. Paul Smith, Plant Manager
 Street, Apt. No., or PO Box No
 11201 New Berlin Road
 City, State, ZIP+4
 Jacksonville, Florida 32226

PS Form 3800, May 2000 See Reverse for Instructions

7000 1670 0013 3110 0659
 0000
 0659
 017E
 3110

**U.S. Postal Service
 CERTIFIED MAIL RECEIPT
 (Domestic Mail Only; No Insurance Coverage Provided)**

Mr. James M. Chansler, V.P.

Postage	\$	Postmark Here
Certified Fee		
Return Receipt Fee (Endorsement Required)		
Restricted Delivery Fee (Endorsement Required)		
Total Postage & Fees	\$	

Sent To
 Mr. James M. Chansler, V.P.
 Street, Apt. No., or PO Box No
 21 West Church Street
 City, State, ZIP+4
 Jacksonville, Florida 32202

PS Form 3800, May 2000 See Reverse for Instructions

7000 1670 0013 3110 0666
 0000
 0666
 017E
 3110