

Sheplak, Scott

- file -

From: Arif, Syed
Sent: Monday, December 01, 2008 2:19 PM
To: Sheplak, Scott
Subject: RE: PSD-FL-010C - JEA

You can say so.

From: Sheplak, Scott
Sent: Monday, December 01, 2008 2:18 PM
To: Arif, Syed
Subject: RE: PSD-FL-010C - JEA

so they are limits?

From: Arif, Syed
Sent: Monday, December 01, 2008 2:15 PM
To: Sheplak, Scott
Subject: RE: PSD-FL-010C - JEA

Scott,

From what I recall, if they cannot show compliance with the opacity limits, then they can do mass emission test to show compliance with the mass emission rates.

Syed

From: Sheplak, Scott
Sent: Monday, December 01, 2008 1:22 PM
To: Arif, Syed
Cc: Holtom, Jonathan
Subject: PSD-FL-010C - JEA

Syed,

Are the listed PM/PM10 (lb/hr) values in Table 6 - Part C from PSD-FL-010C (attached) emission standards/limits or are they for informational purposes only? The proposed BACT determination lists either 5 or 10% opacity as BACT yet, the table seems to list the PM values as limits.

Scott