

**Mitchell, Bruce**

---

**From:** Worley, Jay A. - Director, Environmental Programs [WorlJA@jea.com]  
**Sent:** Thursday, October 09, 2008 5:01 PM  
**To:** Mitchell, Bruce  
**Cc:** Worley, Jay A. - Director, Environmental Programs; Gianazza, N. Bert  
**Subject:** JEA - SJRPP Igniter Low Load and Flame Stabilization

Bruce, Per our earlier discussion regarding the JEA SJRPP Air Construction Application, please find below the following description of low load operation and flame stabilization. Please let me know if you have any questions or need any additional information.

Please do not hesitate to contact me at (904) 591-2595. Thanks, Jay

*Low load operation and flame stabilization is necessary using ignitors to maintain "good combustion practices" to minimize the formation of air pollutants. When combustion conditions are less than optimal for "good combustion practices" with solid fuel alone, supplemental heat is required and the ignitors provide this function. The conditions that can inhibit "good combustion practices" are typically influenced by, but not limited to, low load operation, fuel conditions, pulverizer/burner function and/or primary and secondary air function.*

-----  
Florida has a very broad Public Records Law. Virtually all written communications to or from State and Local Officials and employees are public records available to the public and media upon request. JEA does not differentiate between personal and business e-mails. E-mail sent on the JEA system will be considered public and will only be withheld from disclosure if deemed confidential pursuant to State Law. Under Florida law, e-mail addresses are public records. If you do not want your e-mail address released in response to a public-records request, do not send electronic mail to this entity. Instead, contact JEA by phone or in writing.

PSD-FL-010M

**Mitchell, Bruce**

---

**From:** Worley, Jay A. - Director, Environmental Programs [WorlJA@jea.com]  
**Sent:** Wednesday, October 22, 2008 8:48 AM  
**To:** Mitchell, Bruce  
**Cc:** Worley, Jay A. - Director, Environmental Programs  
**Subject:** JEA: SJRPP Shutdown

Bruce, Thanks for the call. Per your inquiry, I reviewed with our Production personnel in regards to fuel oil and shutdown. Per my discussion, fuel oil (and the proposed natural gas) is utilized in a shutdown condition when taking out pulverizers in order to ensure safe furnace conditions in accordance with burner logic.

Please do not hesitate to contact me if you have any questions. Thanks, Jay

---

Florida has a very broad Public Records Law. Virtually all written communications to or from State and Local Officials and employees are public records available to the public and media upon request. JEA does not differentiate between personal and business e-mails. E-mail sent on the JEA system will be considered public and will only be withheld from disclosure if deemed confidential pursuant to State Law. Under Florida law, e-mail addresses are public records. If you do not want your e-mail address released in response to a public-records request, do not send electronic mail to this entity. Instead, contact JEA by phone or in writing.

10/22/2008

## Livingston, Sylvia

---

**From:** Livingston, Sylvia  
**Sent:** Thursday, September 18, 2008 2:51 PM  
**To:** Forney.Kathleen@epamail.epa.gov; catherine\_collins@fws.gov  
**Cc:** Felton-Smith, Rita; Walker, Elizabeth (AIR); Mitchell, Bruce; robinson@coj.net  
**Subject:** JEA - Northside Generating Station/ St. Johns River Power Park (SJRPP) - 0310045-024-AC/ PSD-FL-010H

A new **Permit Application** has been received in Florida and is currently under review.

### **Link to Permit Application Documents:**

<http://arm-permit2k.dep.state.fl.us/psd/0310045/000030DC.pdf>

**ARMS PA Project ID:** 0310045-024-AC/ PSD-FL-010H

**Facility Name:** JEA - Northside Generating Station/ St. Johns River Power Park (SJRPP)

**Florida County:** Duval

**Project Description:** Minor Source Permit Application for Natural Gas Igniters

**Permit Application Processor:** Bruce Mitchell

**Processor Phone:** (850)413-9198

**Processor Email Address:** [Bruce.Mitchell@dep.state.fl.us](mailto:Bruce.Mitchell@dep.state.fl.us)

**Received in-house:** 09/15/2008

Or, Search for other Air Permit Documents on [Florida's Air Permit Documents Search](#).

Please direct any questions regarding this permit application to the permit application processor. If you have any problems accessing these documents please let me know.

Thanks,

Sylvia Livingston  
Bureau of Air Regulations  
Division of Air Resource Management (DARM)  
850/921-0771

21 West Church Street  
Jacksonville, Florida 32202-3139

RECEIVED

NOV 04 2008

BUREAU OF AIR REGULATION



November 3, 2008

ELECTRIC

WATER

SEWER

Ms. Trina Vielhauer, Chief  
Bureau of Air Regulation  
Florida Department of Environmental Protection  
2600 Blair Stone Road  
Mail Station 5505  
Tallahassee, FL 32399

RE: JEA / St. Johns River Power Park (SJRPP) Facility, Duval County  
Project No. 0310045-024-AC  
Draft Air Permit Revision No. PSD-FL-010(H)  
Public Notice – Proof of Publication

Dear Ms. Vielhauer:

The copy of the above referenced public notice was published in the City of Jacksonville's Time Union on October 31, 2008. Please find enclosed the proof of publication for this notice.

Please contact me at (904) 665-8729 if you have any questions or require any additional information regarding the proof of publication.

Sincerely,



Jay Worley  
Director Environmental Programs

Enclosure

xc: B. Mitchell, FDEP

Florida Department of Environmental Protection  
Division of Air Resource Management, Bureau of Air Regulation  
Project No. 03-10045-024-AC  
Draft Air Permit Revision No. PSD-FL-010(H)  
JEA - St. Johns River Power Park  
Duval County, Florida

THE FLORIDA TIMES-UNION  
Jacksonville, FL  
Affidavit of Publication  
  
Florida Times-Union

J.E.A./ENVIRONMENTAL  
21 W CHURCH ST  
JACKSONVILLE FL 32202

Reference: 1000250742  
Ad Number: C12580809

State of Florida  
County of Duval


Before the undersigned authority personally appeared Sharon Walker who on oath says he/she is a Legal Advertising Representative of The Florida Times-Union, a daily newspaper published in Duval County, Florida; that the attached copy of advertisement is a legal ad published in The Florida Times-Union. Affiant further says that The Florida Times-Union is a newspaper published in Duval County, Florida, and that the newspaper has heretofore been continuously published in Duval County, Florida each day, has been entered as second class mail matter at the post office in Jacksonville, in Duval County, Florida for a period of one year preceding the first publication of the attached copy of advertisement; and affiant further says that he/she has neither paid nor promised any person, firm or corporation any discount, rebate, commission, or refund for the purpose of securing this advertisement for publication in said newspaper.

PUBLISHED ON: 10/31/2008

FILED ON: 10/31/2008

Name: Sharon Walker Title: Legal Advertising  
In testimony whereof, I have hereunto set my hand and  
aforesaid.

NOTARY:




Applicant: The applicant for this project is the JEA. The applicant's authorized representative and mailing address is: Mr. Michael J. Brost, Vice President - Electric System, JEA, 21 West Church Street, Jacksonville, Florida 32202.  
Facility Location: JEA operates an electric utility in Jacksonville located at 11201 New Berlin Road in Duval County, Florida.  
Project: The applicant proposes to install and operate natural gas (NG) igniters for startup, shutdown, flame stabilization and low-load operation on the existing pulverized coal-fired Boilers Nos. 1 and 2. In addition, the applicant requests authorization to use the existing No. 2 fuel oil (FO) igniters for flame stabilization and shutdown on the same boilers if they are already permitted to use No. 2 FO igniters for startup and low-load operation. (Power Plant Siting Permit No. PA8 1-13).  
The original air construction permit, No. PSD-FL-010, required that the auxiliary boiler fire No. 2 FO while providing startup and shutdown capability for Boilers Nos. 1 and 2. The NG igniters will be used primarily in place of the No. 2 FO igniters for startup, shutdown, low load operations and flame stabilization.  
The use of NG igniters should result in lower emissions of nitrogen oxides (NOx), carbon monoxide (CO), sulfur dioxide (SO<sub>2</sub>) and particulate matter, particulate matter with an aerodynamic diameter equal to or less than 10 microns (PM<sub>10</sub>), than the current use of the No. 2 FO igniters. The emissions of volatile organic compounds (VOC) may increase (+1.85 tons per year) if the NG usage is at the same annual heat input rate when compared to No. 2 FO.  
The overall net increase of emissions will be well below the Prevention of Significant Deterioration (PSD) significant emission rates. An air quality impact analysis was not required. Emissions from the facility will not significantly contribute to or cause a violation of any state or federal ambient air quality standards.  
Permitting Authority: Applications for air construction permits are subject to review in accordance with the provisions of Chapter 403, Florida Statutes (F.S.), and Chapters 62-4, 62-210 and 62-212 of the Florida Administrative Code (F.A.C.).  
The proposed project is not exempt from air permitting requirements and an air permit is required to perform the proposed work. The Bureau of Air Regulation is the Permitting Authority responsible for making a permit determination for this project. The Permitting Authority's physical address is: 1111 South Magnolia Drive, Suite #4, Tallahassee, Florida. The Permitting Authority's mailing address is: 2600 Blair Stone Road, MS #5505, Tallahassee, Florida 32399-2400. The Permitting Authority's telephone number is 8501488-0114.  
Project File: A complete project file is available for public inspection during the normal business hours of 8:00 a.m. to 5:00 p.m., Monday through Friday, (except legal holidays), at address indicated above for the Permitting Authority. The complete project file includes the Draft Permit Revision, the Technical Evaluation and Preliminary Determination, the application, and the information submitted by the applicant, exclusive of confidential records under Section 403.111, F.S. Interested persons may contact the Permitting Authority's project review engineer for additional information at the address; phone number listed above. In addition, electronic copies of these documents are available on the following web site:  
www.dcp.state.fl.us/air/cpr/it.asv  
Notice of Intent to Issue Air Permit: The Permitting Authority gives notice of its intent to issue an air permit to the applicant for the project described above. The applicant has provided reasonable assurance that operation of proposed equipment will not adversely impact air quality and that the project will comply with all appropriate provisions of Chapters 62-4, 62-204, 62-210, 62-212, 62-296 and 62-297, F.A.C. The Permitting Authority will issue a Final Permit Revision in accordance with the conditions of the proposed Draft Permit Revision unless a timely petition for an administrative hearing is filed under Sections 120.569 and 120.57, F.S., or unless public comment received in accordance with this notice results in a different decision or a significant change of terms or conditions.  
Comments: The Permitting Authority will accept written comments concerning the proposed Draft Permit for a period of 14 days from the date of publication of the Public Notice. Written comments must be received by the Permitting Authority by close of business (5:00 p.m.) on or before the end of this 14-day period. If written comments received result in a significant change to the Draft Permit, the Permitting Authority shall revise the Draft Permit and require, if applicable, another Public Notice. All comments filed will be made available for public inspection.  
PUBLIC NOTICE OF INTENT TO ISSUE AIR PERMIT REVISION  
Petitions: A person whose substantial interests are affected by the proposed permitting decision may petition for an administrative hearing in accordance with Sections 120.569 and 120.57, F.S. The petition must contain the information set forth below and must be filed with (received by) the Department's Agency Clerk in the Office of General Counsel of the Department of Environmental Protection at 3900 Colonial Boulevard, Mail Station #35, Tallahassee, Florida 32399-3000. Petitions filed by any persons other than those entitled to written notice under Section 120.60(3), F.S., must be filed within 14 days of publication of this Public Notice or receipt of a written notice, whichever occurs first. Under Section 120.60(3), F.S., however, any person who asked the Permitting Authority for notice of agency action may file a petition within 14 days of receipt of that notice, regardless of the date of publication. A petitioner shall mail a copy of the petition to the applicant at the address indicated above, at the time of filing. The failure of any person to file a petition within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under Sections 120.569 and 120.57, F.S., or to intervene in this proceeding and participate as a party to it. Any subsequent intervention (in a proceeding initiated by another party) will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205, F.A.C. A petition that disputes the material facts on which the Permitting Authority's action is based must contain the following information: (a) The name and address of each agency affected and each agency's file or identification number, if known; (b) The name, address and telephone number of the petitioner; the name, address and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how the petitioner's substantial rights will be affected by the agency's determination; (c) A statement of when and how the petitioner received notice of the agency action or proposed decision; (d) A statement of all disputed issues of material fact. If there are none, the petition must so state; (e) A concise statement of the ultimate facts alleged, including the specific facts the petitioner contends warrant reversal or modification of the agency's proposed action; (f) A statement of the specific rules or statutes the petitioner contends require reversal or modification of the agency's proposed action including an explanation of how the alleged facts relate to the specific rules or statutes; and, (g) A statement of the relief sought by the petitioner, stating precisely the action the petitioner wishes the agency to take with respect to the agency's proposed action.  
A petition that does not dispute the material facts upon which the Permitting Authority's action is based shall state that no such facts are in dispute and otherwise shall contain the same information as set forth above, as required by Rule 28-106.301, F.A.C.  
Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Permitting Authority's final action may be different from the position taken by it in this Public Notice of Intent to Issue Air Permit Revision. Persons whose substantial interests will be affected by any such final decision of the Permitting Authority on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.  
Mediation: Mediation is not available for this proceeding.

## Memorandum

# Florida Department of Environmental Protection

---

TO: Joe Kahn, Director, Division of Air Resource Management

THROUGH: Trina Vielhauer, Chief, Bureau of Air Regulation 

THROUGH: Syed Arif, New Source Review Section SA

FROM: Bruce Mitchell, <sup>SA</sup>New Source Review Section

DATE: November 18, 2008

SUBJECT: Final Air Construction Permit Revision No. PSD-FL-010H  
Project No. 0310045-024-AC  
JEA – St. Johns River Power Park  
Pulverized Coal-Fired Boilers Nos. 1 and 2  
Addition of Natural Gas Igniters for Startup, Shutdown, Flame Stabilization and Low Load Operation; and Allow the Use of No. 2 Fuel Oil for Flame Stabilization and Shutdown (Already Allowed for Startup and Low Load Operation)

The Final Permit for this project is attached for your approval and signature, which authorizes the installation of natural gas igniters for startup, shutdown, flame stabilization and low load operation on the existing pulverized coal and petroleum coke fired Boilers Nos. 1 and 2; and it authorizes the use of the No. 2 fuel oil (FO) for flame stabilization and shutdown (already authorized to use No. 2 FO for startup and low load operation in Power Plant Siting Permit No. PA81-13). The proposed work will be conducted at the existing JEA St. Johns River Power Park facility, which is located in Duval County, Florida. The project results in a minor source air construction permit.

The Department distributed an "Intent to Issue Permit" package on October 27, 2008. The applicant published the "Public Notice of Intent to Issue" in The Florida Times-Union on October 31, 2008. No petitions for administrative hearings or extensions of time to petition for an administrative hearing were filed. Timely comments were received from the applicant and are addressed in the Final Determination; and, the comments are considered to be insignificant.

I recommend your approval of the attached Final Permit for this project.

Attachments

## FINAL DETERMINATION

---

### PERMITTEE

JEA  
21 West Church Street  
Jacksonville, Florida 32202-3139

### PERMITTING AUTHORITY

Florida Department of Environmental Protection  
Division of Air Resource Management  
Bureau of Air Regulation, Air Permitting North Section  
2600 Blair Stone Road, MS #5505  
Tallahassee, Florida 32399-2400

### PROJECT

Air Permit No. PSD-FL-010H  
Project No. 0310045-024-AC  
St. Johns River Power Park

This project authorizes the installation of natural gas igniters for startup, shutdown, flame stabilization and low load operation on the existing pulverized coal and petroleum coke fired Boilers Nos. 1 and 2; and it authorizes the use of the No. 2 fuel oil (FO) for flame stabilization and shutdown (already authorized to use No. 2 FO for startup and low load operation in Power Plant Siting Permit No. PA81-13). The proposed work will be conducted at the existing JEA St. Johns River Power Park facility, which is located in Duval County, Florida. The project results in a minor source air construction permit.

### NOTICE AND PUBLICATION

The Department distributed an Intent to Issue Permit package on October 27, 2008. The applicant published the Public Notice of Intent to Issue in the The Florida Times-Union on October 31, 2008. The Department received the proof of publication on November 5, 2008. No petitions for administrative hearings or extensions of time to petition for an administrative hearing were filed.

### COMMENTS

#### Applicant

On November 4, 2008, the Department received timely comments on the Draft Permit Revision from the applicant via an e-mail received November 4, 2008. The following summarizes the comments and the Department's response.

1. In "new" Specific Condition V.11. of the permit for Boilers Nos. 1 and 2, it was requested that an introductory phrase be added to recognize that supplemental fuel for startup, shutdown, flame stabilization and low load operation be used only if it is needed and that pulverized petroleum coke is also an authorized fuel along with pulverized coal.

*Response:* The clarification and revision better describes what was intended. The Department agrees with the request and the changes were made.

### CONCLUSION

The final action of the Department is to issue the permit with the minor revision and clarification as described above.

**STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION**

**NOTICE OF PERMIT REVISION**

In the Matter of an  
Application for Permit Revision by:

JEA  
21 West Church Street  
Jacksonville, Florida 32202

*Authorized Representative:*

Mr. Michael J. Brost, Vice President – Electric System

Air Permit No. PSD-FL-010H  
Project No. 0310045-024-AC  
St. Johns River Power Park  
Add Natural Gas Igniters on the Pulverized Coal  
and Petroleum Coke-Fired Boilers Nos. 1 and 2

JEA operates the existing St. Johns River Power Park located at 11201 New Berlin Road in Jacksonville, Duval County, Florida. The facility is an electric utility. This final air construction permit revision authorizes the installation and operation of natural gas igniters for startup, shutdown, low load operation and flame stabilization, on the pulverized coal and petroleum coke-fired Boilers Nos. 1 and 2. In addition, the applicant is also authorized to use the existing No. 2 distillate fuel oil igniters for flame stabilization and shutdown on Boilers Nos. 1 and 2 [the existing No. 2 distillate fuel oil igniters are already authorized to be used for startup and low load operation (PA81-13)]. The original air construction permit No. PSD-FL-010, required that the auxiliary boiler fire No. 2 fuel oil while providing startup and shutdown capability for Boilers Nos. 1 and 2. A copy of this Notice of Permit Revision shall be filed with the referenced permit and shall become part of the permit. This permit revision is issued pursuant to Chapter 403, Florida Statutes (F.S.).

Any party to this order has the right to seek judicial review of it under Section 120.68, F.S., by filing a notice of appeal under Rule 9.110 of the Florida Rules of Appellate Procedure with the clerk of the Department of Environmental Protection in the Office of General Counsel (Mail Station #35, 3900 Commonwealth Boulevard, Tallahassee, Florida, 32399-3000) and by filing a copy of the notice of appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The notice must be filed within 30 days after this order is filed with the clerk of the Department.

Executed in Tallahassee, Florida

  
\_\_\_\_\_  
Joseph Kahn, Director  
Division of Air Resource Management

11/21/08  
\_\_\_\_\_  
(Date)

JK/tlv/sa/bm



**FINAL PERMIT REVISION**


**CERTIFICATE OF SERVICE**

The undersigned duly designated deputy agency clerk hereby certifies that this Notice of Permit Revision (including the Final Permit Revision) was sent by electronic mail (or a link to these documents made available electronically on a publicly accessible server) with received receipt requested before the close of business on 11/24/08 to the persons listed below.

- Mr. Michael J. Brost, JEA ([brosmj@jea.com](mailto:brosmj@jea.com))
- Mr. John A. Worley, JEA ([worlja@jea.com](mailto:worlja@jea.com))
- Mr. Kennard F. Kosky, Golder Associates, Inc. ([kkosky@golder.com](mailto:kkosky@golder.com))
- Mr. Richard Robinson, Duval County Environmental Quality Division ([robinson@coj.net](mailto:robinson@coj.net))
- Ms. Kathleen Forney, U.S. EPA, Region 4 ([forney.kathleen@epamail.epa.gov](mailto:forney.kathleen@epamail.epa.gov))
- Ms. Heather Abrams, U.S. EPA Region 4 ([abrams.heather@epamail.epa.gov](mailto:abrams.heather@epamail.epa.gov))
- Ms. Catherine Collins, Fish and Wildlife Service ([catherine\\_collins@fws.gov](mailto:catherine_collins@fws.gov))
- Mr. Mike Halpin, DEP-Siting Coordination Office ([mike.halpin@dep.state.fl.us](mailto:mike.halpin@dep.state.fl.us))
- Ms. Vickie Gibson, DEP-BAR ([victoria.gibson@dep.state.fl.us](mailto:victoria.gibson@dep.state.fl.us)) (for read file)

Clerk Stamp

**FILING AND ACKNOWLEDGMENT FILED**, on this date, pursuant to Section 120.52(7), Florida Statutes, with the designated agency clerk, receipt of which is hereby acknowledged.

  
\_\_\_\_\_  
(Clerk)

11/24/08  
(Date)

## FINAL PERMIT REVISION

---

**This permit revision modifies original Permit No. PSD-FL-010.**

For pulverized coal-fired Boilers Nos. 1 and 2, the following permit revision (new specific condition) incorporates the authorization to use No. 2 fuel oil for startup and low load operation from the original Power Plant Siting Permit No. PA81-13. The new specific condition also recognizes the requirement that No. 2 fuel oil be used during startup and shutdown of the boilers, as was imposed on the auxiliary boiler in the original air construction permit No. PSD-FL-010. New text is marked with double underline.

**PSD-FL-010: New Specific Condition. V.11.**

**V.11.** If at any time the permittee determines that it is appropriate to use supplemental fuel during periods of startup, shutdown, flame stabilization and low load operation, then No. 2 fuel oil and/or natural gas shall be used for the pulverized coal and petroleum coke-fired Boiler No. 1 or Boiler No. 2.

## Livingston, Sylvia

---

**From:** Livingston, Sylvia  
**Sent:** Monday, November 24, 2008 3:38 PM  
**To:** 'brosmj@jea.com'; 'worlja@jea.com'  
**Cc:** 'kkosky@golder.com'; 'robinson@coj.net'; 'forney.kathleen@epamail.epa.gov'; 'abrams.heather@epamail.epa.gov'; 'catherine\_collins@fws.gov'; Halpin, Mike; Gibson, Victoria; Mitchell, Bruce; Walker, Elizabeth (AIR); Arif, Syed  
**Subject:** JEA - NORTHSIDE/SJRPP; 0310045-024-AC (PSD-FL-010H)

Dear Sir/ Madam:

Attached is the official **Notice of Final Permit** for the project referenced below. Click on the link displayed below to access the permit project documents and send a "reply" message verifying receipt of the document(s) provided in the link; this may be done by selecting "Reply" on the menu bar of your e-mail software, noting that you can view the documents, and then selecting "Send". **We must receive verification that you are able to access the documents.** Your immediate reply will preclude subsequent e-mail transmissions to verify accessibility of the document(s).

**Click on the following link to access the permit project documents:**

[http://ARM-PERMIT2K.dep.state.fl.us/adh/prod/pdf\\_permit\\_zip\\_files/0310045.024.AC.F\\_pdf.zip](http://ARM-PERMIT2K.dep.state.fl.us/adh/prod/pdf_permit_zip_files/0310045.024.AC.F_pdf.zip)

**Owner/Company Name:** JEA  
**Facility Name:** NORTHSIDE/SJRPP  
**Project Number:** 0310045-024-AC/ PSD-FL-010H  
**Permit Status:** FINAL  
**Permit Activity:** CONSTRUCTION/ NATURAL GAS IGNITERS  
**Facility County:** DUVAL  
**Processor:** Bruce Mitchell

The Bureau of Air Regulation is issuing electronic documents for permits, notices and other correspondence in lieu of hard copies through the United States Postal System, to provide greater service to the applicant and the engineering community. Access these documents by clicking on the link provided above, or search for other project documents using the "*Air Permit Documents Search*" website at <http://www.dep.state.fl.us/air/eproducts/apds/default.asp>.

Permit project documents addressed in this email may require immediate action within a specified time frame. Please open and review the document(s) as soon as possible, and verify that they are accessible. Please advise this office of any changes to your e-mail address or that of the Engineer-of-Record. If you have any problems opening the documents or would like further information, please contact the Florida Department of Environmental Protection, Bureau of Air Regulation at (850)488-0114.



0310045-024-AC\_N  
otice.pdf

Sylvia Livingston  
Bureau of Air Regulation  
Division of Air Resource Management (DARM)  
850/921-9506  
[sylvia.livingston@dep.state.fl.us](mailto:sylvia.livingston@dep.state.fl.us)

**Livingston, Sylvia**

---

**From:** Brost, Mike J. - VP, Electric Systems [BrosMJ@jea.com]  
**Sent:** Tuesday, November 25, 2008 9:39 AM  
**To:** Livingston, Sylvia  
**Subject:** RE: JEA - NORTHSIDE/SJRPP; 0310045-024-AC (PSD-FL-010H)

Received. Mike Brost

**From:** Livingston, Sylvia [mailto:Sylvia.Livingston@dep.state.fl.us]  
**Sent:** Monday, November 24, 2008 3:38 PM  
**To:** Brost, Mike J. - VP, Electric Systems; Worley, Jay A. - Director, Environmental Programs  
**Cc:** kkosky@golder.com; robinson@coj.net; forney.kathleen@epamail.epa.gov; abrams.heather@epamail.epa.gov; catherine\_collins@fws.gov; Halpin, Mike; Gibson, Victoria; Mitchell, Bruce; Walker, Elizabeth (AIR); Arif, Syed  
**Subject:** JEA - NORTHSIDE/SJRPP; 0310045-024-AC (PSD-FL-010H)

Dear Sir/ Madam:

Attached is the official **Notice of Final Permit** for the project referenced below. Click on the link displayed below to access the permit project documents and send a "reply" message verifying receipt of the document(s) provided in the link; this may be done by selecting "Reply" on the menu bar of your e-mail software, noting that you can view the documents, and then selecting "Send". **We must receive verification that you are able to access the documents.** Your immediate reply will preclude subsequent e-mail transmissions to verify accessibility of the document(s).

**Click on the following link to access the permit project documents:**

[http://ARM-PERMIT2K.dep.state.fl.us/adh/prod/pdf\\_permit\\_zip\\_files/0310045.024.AC.F\\_pdf.zip](http://ARM-PERMIT2K.dep.state.fl.us/adh/prod/pdf_permit_zip_files/0310045.024.AC.F_pdf.zip)

**Owner/Company Name:** JEA  
**Facility Name:** NORTHSIDE/SJRPP  
**Project Number:** 0310045-024-AC/ PSD-FL-010H  
**Permit Status:** FINAL  
**Permit Activity:** CONSTRUCTION/ NATURAL GAS IGNITERS  
**Facility County:** DUVAL  
**Processor:** Bruce Mitchell

The Bureau of Air Regulation is issuing electronic documents for permits, notices and other correspondence in lieu of hard copies through the United States Postal System, to provide greater service to the applicant and the engineering community. Access these documents by clicking on the link provided above, or search for other project documents using the "*Air Permit Documents Search*" website at <http://www.dep.state.fl.us/air/eproducts/apds/default.asp> .

Permit project documents are addressed in this email may require immediate action within a specified time frame. Please open and review the document(s) as soon as possible, and verify that they are accessible. Please advise this office of any changes to your e-mail address or that of the Engineer-of-Record. If you have any problems opening the documents or would like further information, please contact the Florida Department of Environmental Protection, Bureau of Air Regulation at (850)488-0114.

<<0310045-024-AC\_Notice.pdf>>

Sylvia Livingston  
Bureau of Air Regulation  
Division of Air Resource Management (DARM)  
850/921-9506

11/25/2008

**Livingston, Sylvia**

---

**From:** Worley, Jay A. - Director, Environmental Programs [WorJA@jea.com]  
**Sent:** Monday, November 24, 2008 3:58 PM  
**To:** Livingston, Sylvia; Brost, Mike J. - VP, Electric Systems  
**Cc:** kkosky@golder.com; robinson@coj.net; forney.kathleen@epamail.epa.gov; abrams.heather@epamail.epa.gov; catherine\_collins@fws.gov; Halpin, Mike; Gibson, Victoria; Mitchell, Bruce; Walker, Elizabeth (AIR); Arif, Syed  
**Subject:** RE: JEA - NORTHSIDE/SJRPP; 0310045-024-AC (PSD-FL-010H)

Sylvia, Please note that I have received. Thanks, Jay

---

**From:** Livingston, Sylvia [mailto:Sylvia.Livingston@dep.state.fl.us]  
**Sent:** Monday, November 24, 2008 3:38 PM  
**To:** Brost, Mike J. - VP, Electric Systems; Worley, Jay A. - Director, Environmental Programs  
**Cc:** kkosky@golder.com; robinson@coj.net; forney.kathleen@epamail.epa.gov; abrams.heather@epamail.epa.gov; catherine\_collins@fws.gov; Halpin, Mike; Gibson, Victoria; Mitchell, Bruce; Walker, Elizabeth (AIR); Arif, Syed  
**Subject:** JEA - NORTHSIDE/SJRPP; 0310045-024-AC (PSD-FL-010H)

Dear Sir/ Madam:

Attached is the official **Notice of Final Permit** for the project referenced below. Click on the link displayed below to access the permit project documents and send a "reply" message verifying receipt of the document(s) provided in the link; this may be done by selecting "Reply" on the menu bar of your e-mail software, noting that you can view the documents, and then selecting "Send". **We must receive verification that you are able to access the documents.** Your immediate reply will preclude subsequent e-mail transmissions to verify accessibility of the document(s).

**Click on the following link to access the permit project documents:**

[http://ARM-PERMIT2K.dep.state.fl.us/adh/prod/pdf\\_permit\\_zip\\_files/0310045.024.AC.F\\_pdf.zip](http://ARM-PERMIT2K.dep.state.fl.us/adh/prod/pdf_permit_zip_files/0310045.024.AC.F_pdf.zip)

**Owner/Company Name:** JEA  
**Facility Name:** NORTHSIDE/SJRPP  
**Project Number:** 0310045-024-AC/ PSD-FL-010H  
**Permit Status:** FINAL  
**Permit Activity:** CONSTRUCTION/ NATURAL GAS IGNITERS  
**Facility County:** DUVAL  
**Processor:** Bruce Mitchell

The Bureau of Air Regulation is issuing electronic documents for permits, notices and other correspondence in lieu of hard copies through the United States Postal System, to provide greater service to the applicant and the engineering community. Access these documents by clicking on the link provided above, or search for other project documents using the "*Air Permit Documents Search*" website at <http://www.dep.state.fl.us/air/eproducts/apds/default.asp>.

Permit project documents are addressed in this email may require immediate action within a specified time frame. Please open and review the document(s) as soon as possible, and verify that they are accessible. Please advise this office of any changes to your e-mail address or that of the Engineer-of-Record. If you have any problems opening the documents or would like further information, please contact the Florida Department of Environmental Protection, Bureau of Air Regulation at (850)488-0114.

<<0310045-024-AC\_Notice.pdf>>

Sylvia Livingston  
Bureau of Air Regulation  
Division of Air Resource Management (DARM)

11/24/2008

**Livingston, Sylvia**

---

**From:** Robinson, Richard [ROBINSON@coj.net]  
**Sent:** Monday, November 24, 2008 4:08 PM  
**To:** Livingston, Sylvia  
**Subject:** RE: JEA - NORTHSIDE/SJRPP; 0310045-024-AC (PSD-FL-010H)

Sylvia,

I was able to view the documents in the e-mail link below.

Thanks,

Richard

Richard L. Robinson, P.E.  
Environmental Engineering Manager  
Air Quality Branch  
Environmental Quality Division  
Environmental and Compliance Department  
City of Jacksonville, Florida  
117 West Duval Street, Suite 225  
Jacksonville, FL 32202

Phone: (904) 630-4900  
Fax: (904) 630-3638  
E-Mail: robinson@coj.net

Please note: that under Florida's very broad public records law, e-mail communications to and from City officials may be subject to public disclosure.



Please consider the environment before printing this email.

---

**From:** Livingston, Sylvia [mailto:Sylvia.Livingston@dep.state.fl.us]  
**Sent:** Monday, November 24, 2008 3:38 PM  
**To:** brosmj@jea.com; worlja@jea.com  
**Cc:** kkosky@golder.com; Robinson, Richard; forney.kathleen@epamail.epa.gov; abrams.heather@epamail.epa.gov; catherine\_collins@fws.gov; Halpin, Mike; Gibson, Victoria; Mitchell, Bruce; Walker, Elizabeth (AIR); Arif, Syed  
**Subject:** JEA - NORTHSIDE/SJRPP; 0310045-024-AC (PSD-FL-010H)

Dear Sir/ Madam:

Attached is the official **Notice of Final Permit** for the project referenced below. Click on the link displayed below to access the permit project documents and send a "reply" message verifying receipt of the document(s) provided in the link; this may be done by selecting "Reply" on the menu bar of your e-mail software, noting that you can view the documents, and then selecting "Send". **We must receive verification that you are able to access the documents.** Your immediate reply will preclude subsequent e-mail transmissions to verify accessibility of the document(s).

**Click on the following link to access the permit project documents:**

[http://ARM-PERMIT2K.dep.state.fl.us/adh/prod/pdf\\_permit\\_zip\\_files/0310045.024.AC.F\\_pdf.zip](http://ARM-PERMIT2K.dep.state.fl.us/adh/prod/pdf_permit_zip_files/0310045.024.AC.F_pdf.zip)

**Owner/Company Name:** JEA  
**Facility Name:** NORTHSIDE/SJRPP  
**Project Number:** 0310045-024-AC/ PSD-FL-010H  
**Permit Status:** FINAL

11/24/2008