

Department of Environmental Protection

Sealed

DIVISION OF AIR RESOURCES MANAGEMENT APPLICATION FOR AIR PERMIT - LONG FORM

See Instructions for Form No. 62-210.900(1)

I. APPLICATION INFORMATION

This section of the Application for Air Permit form provides general information on the scope of this application, the purpose for which this application is being submitted, and the nature of any construction or modification activities proposed as a part of this application. This section also includes information on the owner of the facility (or the responsible official in the case of a Title V source) and the necessary statements for the applicant and professional engineer, where required, to sign and date for formal submittal of the Application for Air Permit to the Department. If the application form is submitted to the Department on diskette, this section of the Application for Air Permit must also be submitted in hard-copy form.

Identification of Facility Addressed in This Application


Enter the name of the corporation, business, governmental entity, or individual that has ownership or control of the facility; the facility name, if any; and a brief reference to the facility's physical location. If known, also enter the ARMS or AIRS facility identification number. This information is intended to give a quick reference, on the first page of the application form, to the facility addressed in this application. Elsewhere in the form, numbered data fields are provided for entry of the facility data in computer-input format.

St. Johns River Power Park (SJRPP); Units 1 and 2

Application Processing Information (DEP Use)

1. Date of Receipt of Application:	
2. Permit Number:	
3. PSD Number (if applicable):	
4. Siting Number (if applicable):	

Owner/Authorized Representative or Responsible Official

1. Name and Title of Owner/Authorized Representative or Responsible Official: Richard Breitmoser, P.E., Vice Pres. Env., Health & Safety
2. Owner/Authorized Representative or Responsible Official Mailing Address: Organization/Firm: JEA/St. Johns River Power Park Street Address: 21 West Church Street City: Jacksonville State: FL Zip Code: 32202-3139
3. Owner/Authorized Representative or Responsible Official Telephone Numbers: Telephone: (904) 632-6245 Fax: (904) 632-7376
4. Owner/Authorized Representative or Responsible Official Statement: <i>I, the undersigned, am the owner or authorized representative* of the facility (non-Title V source) addressed in this Application for Air Permit or the responsible official, as defined in Chapter 62-213, F.A.C., of the Title V source addressed in this application, whichever is applicable. I hereby certify, based on information and belief formed after reasonable inquiry, that the statements made in this application are true, accurate and complete and that, to the best of my knowledge, any estimates of emissions reported in this application are based upon reasonable techniques for calculating emissions. Further, I agree to operate and maintain the air pollutant emissions units and air pollution control equipment described in this application so as to comply with all applicable standards for control of air pollutant emissions found in the statutes of the State of Florida and rules of the Department of Environmental Protection and revisions thereof. If the purpose of this application is to obtain an air operation permit or operation permit revision for one or more emissions units which have undergone construction or modification, I certify that, with the exception of any changes detailed as part of this application, each such emissions unit has been constructed or modified in substantial accordance with the information given in the corresponding application for air construction permit and with all provisions contained in such permit. I understand that a permit, if granted by the Department, cannot be transferred without authorization from the Department, and I will promptly notify the Department upon sale or legal transfer of any permitted source.</i>  Signature _____ Date <u>3/1/96</u>

* Attach letter of authorization if not currently on file.

Scope of Application

This Application for Air Permit addresses the following emissions unit(s) at the facility (or Title V source). An Emissions Unit Information Section (a Section III of the form) must be included for each emissions unit listed.

Emissions Unit ID / Description of Emissions Unit

Unit #	ARMS ID	Emissions Unit Name/Description
1		SJRPP Unit 1
2		SJRPP Unit 2

See individual Emissions Unit sections for more detailed Emissions Unit descriptions.
Multiple ARMS IDs are indicated with an asterisk (*)

Purpose of Application and Category

Check one (except as otherwise indicated):

Category I: All Air Operation Permit Applications Subject to Processing Under Chapter 62-213, F.A.C.

This Application for Air Permit is submitted to obtain:

Initial air operation permit under Chapter 62-213, F.A.C., for an existing facility which is classified as a Title V source.

Initial air operation permit under Chapter 62-213, F.A.C., for a facility which, upon start up of one or more newly constructed or modified emissions units addressed in this application, would become classified as a Title V source.

Current construction permit number: _____

Air operation permit renewal under Chapter 62-213, F.A.C., for a Title V source.

Operation permit to be renewed: _____

Air operation permit revision for a Title V source to address one or more newly constructed or modified emissions units addressed in this application.

Current construction permit number: _____

Operation permit to be renewed: _____

Air operation permit revision or administrative correction for a Title V source to address one or more proposed new or modified emissions units and to be processed concurrently with the air construction permit application. Also check Category III.

Operation permit to be revised/corrected: _____

Air operation permit revision for a Title V source for reasons other than construction or modification of an emissions unit. Give reason for the revision e.g., to comply with a new applicable requirement or to request approval of an "Early Reductions" proposal.

Operation permit to be revised: _____

Reason for revision: _____

Category II: All Air Construction Permit Applications Subject to Processing Under Rule 62-210.300(2)(b), F.A.C.

This Application for Air Permit is submitted to obtain:

- Initial air operation permit under Rule 62-210.300(2)(b), F.A.C., for an existing facility seeking classification as a synthetic non-Title V source.

Current operation/construction permit number(s): _____

- Renewal air operation permit under Rule 62-210.300(2)(b), F.A.C., for a synthetic non-Title V source.

Operation permit to be renewed: _____

- Air operation permit revision for a synthetic non-Title V source. Give reason for revision; e.g.; to address one or more newly constructed or modified emissions units.

Operation permit to be revised: _____

Reason for revision: _____

Category III: All Air Construction Permit Applications for All Facilities and Emissions Units.

This Application for Air Permit is submitted to obtain:

- Air construction permit to construct or modify one or more emissions units within a facility (including any facility classified as a Title V source).

Current operation permit number(s), if any: _____
PA 81-13(PPSA); PSD-FL-010

- Air construction permit to make federally enforceable an assumed restriction on the potential emissions of one or more existing, permitted emissions units.

Current operation permit number(s): _____

- Air construction permit for one or more existing, but unpermitted, emissions units.

Application Processing Fee

Check one:

Attached - Amount: \$ _____ Not Applicable.

Construction/Modification Information

<p>1. Description of Proposed Project or Alterations:</p> <p>See Attachment 1; Air permit fee not applicable pursuant to PPSA modification request.</p>
<p>2. Projected or Actual Date of Commencement of Construction (DD-MON-YYYY):</p>
<p>3. Projected Date of Completion of Construction (DD-MON-YYYY):</p>

Professional Engineer Certification

1. Professional Engineer Name: **Kennard F. Kosky**
Registration Number: **14996**

2. Professional Engineer Mailing Address:
Organization/Firm: **KBN Eng. and Applied Sciences, Inc.**
Street Address: **6241 NW 23rd Street, Suite 500**
City: **Gainesville** State: **FL** Zip Code: **32653-1500**

3. Professional Engineer Telephone Numbers:
Telephone: **(352) 336-5600** Fax: **(352) 336-6603**

4. Professional Engineer's Statement:

I, the undersigned, hereby certify, except as particularly noted herein, that:*

(1) To the best of my knowledge, there is reasonable assurance (a) that the air pollutant emissions unit(s) and the air pollution control equipment described in this Application for Air Permit, when properly operated and maintained, will comply with all applicable standards for control of air pollutant emissions found in the Florida Statutes and rules of the Department of Environmental Protection; or (b) for any application for a Title V source air operation permit, that each emissions unit described in this Application for Air Permit, when properly operated and maintained, will comply with the applicable requirements identified in this application to which the unit is subject, except those emissions units for which a compliance schedule is submitted with this application;

(2) To the best of my knowledge, any emission estimates reported or relied on in this application are true, accurate, and complete and are either based upon reasonable techniques available for calculating emissions or, for emission estimates of hazardous air pollutants not regulated for an emissions unit addressed in this application, based solely upon the materials, information and calculations submitted with this application; and

(3) For any application for an air construction permit for one or more proposed new or modified emissions units, the engineering features of each such emissions unit described in this application have been designed or examined by me or individuals under my direct supervision and found to be in conformity with sound engineering principles applicable to the control of emissions of the air pollutants characterized in this application.

Signature
(Seal)



Date

2/27/96

*Attach any exception to certification statement.

Application Contact

1. Name and Title of Application Contact: Richard Breitmoser, Vice Pres. Env., Safety & Health
2. Application Contact Mailing Address: Organization/Firm: JEA/St. Johns River Power Park Street Address: 21 West Church Street City: Jacksonville State: FL Zip Code: 32202-3139
3. Application Contact Telephone Numbers: Telephone: (904) 632-6248 Fax: (904) 632-7376

Application Comment

This application is for the co-firing of petroleum coke, up to 20 percent, with coal in Units 1 and 2. The proposed emission limits for sulfur dioxide will not result in a significant net increase in emissions and therefore, the requested co-firing will not be a major modification under the department's rules in 62-212. Emissions of other pollutants will also not increase significantly from actual levels.

II. FACILITY INFORMATION

A. GENERAL FACILITY INFORMATION

Facility Name, Location, and Type

1. Facility Owner or Operator: Jacksonville Electric Authority			
2. Facility Name: St. Johns River Power Park			
3. Facility Identification Number: <input checked="" type="checkbox"/> Unknown			
4. Facility Location Information: Facility Street Address: 11201 New Berlin Road City: Jacksonville County: Duval Zip Code: 32226			
5. Facility UTM Coordinates: Zone: 17 East (km): 446.9 North (km): 3366.3			
6. Facility Latitude/Longitude: Latitude (DD/MM/SS): / / Longitude: (DD/MM/SS): / /			
7. Governmental Facility Code: 4	8. Facility Status Code: A	9. Relocatable Facility? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	10. Facility Major Group SIC Code: 49
11. Facility Comment: Facility is authorized to operate under Power Plant Site Certification PA-81-13.			

Facility Contact

1. Name and Title of Facility Contact: Jay Worley, Dir. of Environmental and Safety			
2. Facility Contact Mailing Address: Organization/Firm: St. Johns River Power Park Street Address: 11201 New Berlin Road City: Jacksonville State: FL Zip Code: 32226			
3. Facility Contact Telephone Numbers: Telephone: (904) 751-7729 Fax: (904) 751-7719			

Facility Regulatory Classifications

1. Small Business Stationary Source? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Unknown
2. Title V Source? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
3. Synthetic Non-Title V Source? <input type="checkbox"/> Yes, <input checked="" type="checkbox"/> No
4. Major Source of Pollutants Other than Hazardous Air Pollutants (HAPs)? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
5. Synthetic Minor Source of Pollutants Other than HAPs? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
6. Major Source of HAPs? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Possible
7. Synthetic Minor Source of HAPs? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
8. One or More Emissions Units Subject to NSPS? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
9. One or More Emissions Units Subject to NESHAP? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
10. Title V Source by EPA Designation? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
11. Facility Regulatory Classifications Comment: HAP emissions are not expected to change as a result of co-firing petroleum coke and coal. The emission units are subject to NSPS codified under 40 CFR Part 60 Subpart Da. Facility information is not affected by co-firing petroleum coke and coal.

B. FACILITY REGULATIONS

Depending on the application category, this subsection of the Application for Air Permit form provides either a brief analysis or detailed listing of federal, state, and local regulations applicable to the facility as a whole. (Regulations applicable to individual emissions units within the facility are addressed in Subsection III-B of the form.)

Rule Applicability Analysis (Required for Category II applications and Category III applications involving non Title-V sources. See Instructions.)

Not Applicable

List of Applicable Regulations (Required for Category I applications and Category III applications involving Title-V sources. See Instructions.)

Not Applicable - Facility wide regulations not affected by co-firing petroleum coke and coal.

C. FACILITY POLLUTANT INFORMATION

This subsection of the Application for Air Permit form allows for the reporting of potential and estimated emissions of selected pollutants on a facility-wide basis. It must be completed for each pollutant for which the applicant proposes to establish a facility-wide emissions cap and for each pollutant for which emissions are not reported at the emissions-unit level.

Facility Pollutant Information: Pollutant _____ of _____

1. Pollutant Emitted:		
2. Estimated Emissions:		(tons/yr)
3. Requested Emissions Cap:	(lb/hr)	(tons/yr)
4. Basis for Emissions Cap Code:		
5. Facility Pollutant Comment:		

Facility Pollutant Information Pollutant _____ of _____

1. Pollutant Emitted:		
2. Estimated Emissions:		(tons/yr)
3. Requested Emissions Cap:	(lb/hr)	(tons/yr)
4. Basis for Emissions Cap Code:		
5. Facility Pollutant Comment:		

Facility Pollutant Information: Pollutant _____ of _____

1. Pollutant Emitted:		
2. Estimated Emissions:		(tons/yr)
3. Requested Emissions Cap:	(lb/hr)	(tons/yr)
4. Basis for Emissions Cap Code:		
5. Facility Pollutant Comment:		

Facility Pollutant Information: Pollutant _____ of _____

1. Pollutant Emitted:		
2. Estimated Emissions:		(tons/yr)
3. Requested Emissions Cap:	(lb/hr)	(tons/yr)
4. Basis for Emissions Cap Code:		
5. Facility Pollutant Comment:		

D. FACILITY SUPPLEMENTAL INFORMATION

This subsection of the Application for Air Permit form provides supplemental information related to the facility as a whole. (Supplemental information related to individual emissions units within the facility is provided in Subsection III-I of the form.) Supplemental information must be submitted as an attachment to each copy of the form, in hard-copy or computer-readable form.

Supplemental Requirements for All Applications

1. Area Map Showing Facility Location: <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
2. Facility Plot Plan: <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
3. Process Flow Diagram(s): <input type="checkbox"/> Attached, Document ID(s): _____ <input checked="" type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
4. Precautions to Prevent Emissions of Unconfined Particulate Matter: <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
5. Fugitive Emissions Identification: <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
6. Supplemental Information for Construction Permit Application: <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable

Additional Supplemental Requirements for Category I Applications Only

7. List of Insignificant Activities: <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
8. List of Equipment/Activities Regulated under Title VI: <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Equipment/Activities Onsite but Not Required to be Individually Listed <input checked="" type="checkbox"/> Not Applicable

<p>9. Alternative Methods of Operation: <input checked="" type="checkbox"/> Attached, Document ID: <u>Attachment 1</u> <input type="checkbox"/> Not Applicable</p>
<p>10. Alternative Modes of Operation (Emissions Trading): <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable</p>
<p>11. Enhanced Monitoring Plan: <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable</p>
<p>12. Risk Management Plan Verification:</p> <p><input type="checkbox"/> Plan Submitted to Implementing Agency - Verification Attached Attached, Document ID: _____</p> <p><input type="checkbox"/> Plan to be Submitted to Implementing Agency by Required Date</p> <p><input checked="" type="checkbox"/> Not Applicable</p>
<p>13. Compliance Report and Plan <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable</p>
<p>14. Compliance Statement (Hard-copy Required) <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable</p>

Emissions Unit Information Section 1 of 2

III. EMISSIONS UNIT INFORMATION

A separate Emissions Unit Information Section (including subsections A through I as required) must be completed for each emissions unit addressed in this Application for Air Permit. If submitting the application form in hard copy, indicate, in the space provided at the top of each page, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application.

A. GENERAL EMISSIONS UNIT INFORMATION

This subsection of the Application for Air Permit form provides general information on the emissions unit addressed in this Emissions Unit Information Section, including information on the type, control equipment, operating capacity, and operating schedule of the emissions unit.

Type of Emissions Unit Addressed in This Section

Check one:

- [X] This Emissions Unit information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).
- [] This Emissions Unit Information Section addresses, as a single emissions unit, an individually-regulated emission point (stack or vent) serving a single process or production unit, or activity, which also has other individually-regulated emission points.
- [] This Emissions Unit Information Section addresses, as a single emissions unit, a collectively-regulated group of process or production units and activities which has at least one definable emission point (stack or vent) but may also produce fugitive emissions.
- [] This Emissions Unit Information Section addresses, as a single emissions unit, one or more process or production units and activities which produce fugitive emissions only.

Emissions Unit Description and Status

1. Description of Emissions Unit Addressed in This Section: SJRPP Unit 1		
2. ARMS Identification Number: <input type="checkbox"/> No Corresponding ID <input type="checkbox"/> Unknown		
3. Emissions Unit Status Code: A	4. Acid Rain Unit? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5. Emissions Unit Major Group SIC Code: 49
6. Initial Startup Date (DD-MON-YYYY): 15 Dec 1986		
7. Long-term Reserve Shutdown Date (DD-MON-YYYY):		
8. Package Unit: Manufacturer: _____ Model Number: _____		
9. Generator Nameplate Rating: _____ 680 MW		
10. Incinerator Information: Dwell Temperature: _____ °F Dwell Time: _____ seconds Incinerator Afterburner Temperature: _____ °F		
11. Emissions Unit Comment: Generator Nameplate Rating: 679.6 MW. Generator nameplate rating is maximum. Initial start-up date is initial synchronization (generator) date.		

Emissions Unit Control Equipment Information

A.

<p>1. Description:</p> <p>Electrostatic precipitator</p> <p>2. Control Device or Method Code: 10</p>
--

B.

<p>1. Description:</p> <p>Flue Gas Desulfurization System. Wet Limestone Scrubbing</p> <p>2. Control Device or Method Code: 67</p>
--

C.

<p>1. Description:</p> <p>Modified Furnance and Low-NOx Burners</p> <p>2. Control Device or Method Code: 24</p>

Emissions Unit Operating Capacity

1. Maximum Heat Input Rate:	6,144 mmBtu/hr
2. Maximum Incineration Rate:	<div style="display: flex; justify-content: space-between;"> lbs/hr tons/day </div>
3. Maximum Process or Throughput Rate:	
4. Maximum Production Rate:	
5. Operating Capacity Comment: <p style="text-align: center;">The co-firing of petroleum coke and coal will not change the operating capacity of the emission unit. Maximum heat input limited by specific condition of site certification.</p>	

Emissions Unit Operating Schedule

1. Requested Maximum Operating Schedule:	
hours/day,	days/week,
weeks/yr	8,760 hours/yr

B. EMISSIONS UNIT REGULATIONS

Depending on the application category, this subsection of the Application for Air Permit form provides either a brief analysis or detailed listing of all federal, state, and local regulations applicable to the emissions unit addressed in this Emissions Unit Information Section.

Rule Applicability Analysis (Required for Category II Applications and Category III applications involving non Title-V sources. See Instructions.)

Not Applicable

List of Applicable Regulations (Required for Category I applications and Category III applications involving Title-V sources. See Instructions.)

- 40 CFR 60 Subpart Da
- 40 CFR Part 72 (as applicable)
- 40 CFR Part 73 (as applicable)
- 40 CFR Part 75 (as applicable)
- 62-210.700(1)
- 62-296.405(2)(a)
- 62-296.405(2)(b)
- 62-296.405(2)(c)
- 62-296.800(2)(a)2
- 62-296.800(3)
- 62-296.800(4)(a)
- 62-296.800(4)(b)
- 62-296.800(4)(e)
- 62-297.310
- 62-297.330
- 62-297.340
- 62-297.345(1)
- 62-297.345(3)
- 62-297.350
- 62-297.400
- 62-297.401(1)
- 62-297.401(17)
- 62-297.401(19)
- 62-297.401(2)
- 62-297.401(3)
- 62-297.401(4)
- 62-297.401(5)
- 62-297.401(6)
- 62-297.401(7)
- 62-297.401(9)

C. EMISSION POINT (STACK/VENT) INFORMATION

This subsection of the application for Air Permit form provides information about the emission point associated with the emissions unit addressed in this Emissions Unit Information Section. An emission point is typically a stack or vent but can be any identifiable location at which air pollutants, including fugitive emissions, are discharged into the atmosphere.

Emission Point Description and Type

1. Identification of Point on Plot Plan or Flow Diagram: Not Applicable
2. Emission Point Type Code: [<input checked="" type="checkbox"/>] 1 [] 2 [] 3 [] 4
3. Descriptions of Emissions Points Comprising this Emissions Unit: Unit 1 Stack
4. ID Numbers or Descriptions of Emission Units with this Emission Point in Common:
5. Discharge Type Code: [] D [] F [] H [] P [] R [<input checked="" type="checkbox"/>] V [] W

6. Stack Height:	640	ft
7. Exit Diameter:	22.3	ft
8. Exit Temperature:	160	°F
9. Actual Volumetric Flow Rate:	2,230,000	acfm
10. Percent Water Vapor:		%
11. Maximum Dry Standard Flow Rate:		dscfm
12. Nonstack Emission Point Height:		ft
13. Emission Point UTM Coordinates:		
Zone: 17	East (km): 446.9	North (km): 3366.3
14. Emission Point Comment:		

D. SEGMENT (PROCESS/FUEL) INFORMATION

For the emissions unit addressed in this Emissions Unit Information Section, a separate set of segment data (Fields 1-10) must be completed for each segment required to be reported and for each alternative operating method or mode (emissions trading scenario) under Chapter 62-213, F.A.C., for which the maximum hourly or annual segment-related rate would vary. A segment is a material handling, process, fuel burning, volatile organic liquid storage, production, or other such operation to which emissions of the unit are directly related. See instructions for further details on this subsection of the Application for Air Permit.

Segment Description and Rate Information: Segment 1 of 2

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode): Coal	
2. Source Classification Code (SCC): 1-01-001-01	
3. SCC Units: Tons	
4. Maximum Hourly Rate: 253.9	5. Maximum Annual Rate: 2,224,200
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur: 4	8. Maximum Percent Ash: 18
9. Million Btu per SCC Unit: 24	
10. Segment Comment: Maximum hourly and annual rates calculated based on typical heat content of coal (i.e., 12,100 Btu/lb) and 6,144 MMBtu/hr maximum heat input. Maximum percent sulfur based on permit limit. Million BTU per SCC Unit is 24.2.	

Segment Description and Rate Information: Segment 2 of 2

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode): Coal and Petroleum Coke (Heat Input Basis)	
2. Source Classification Code (SCC): 1-01-001-04	
3. SCC Units: Tons	
4. Maximum Hourly Rate: 244.6	5. Maximum Annual Rate: 2,142,700
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur: 4.34	8. Maximum Percent Ash: 18
9. Million Btu per SCC Unit: 25	
10. Segment Comment: Maximum hourly and annual rate based on maximum percentage of petroleum coke when co-firing (i.e., 20%). Heat content and sulfur content of petroleum coke based on typical values of 29.6 MMBtu/ton and 6% sulfur. (See Segment 1 of 2 for coal values). Maximum Percent Ash: <18. Million Btu per SCC Unit: 25.12.	

E. POLLUTANT INFORMATION

For the emissions unit addressed in this Emissions Unit Information Section, a separate set of pollutant information must be completed for each pollutant required to be reported. See instructions for further details on this subsection of the Application for Air Permit.

Pollutant Potential/Estimated Emissions: Pollutant 1 of 1

1. Pollutant Emitted: SO2	
2. Total Percent Efficiency of Control:	95 %
3. Primary Control Device Code:	067
4. Secondary Control Device Code:	
5. Potential Emissions:	491.5 lbs/hr 2,153 tons/yr
6. Synthetically Limited? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
7. Range of Estimated Fugitive/Other Emissions:	
<input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 _____ to _____ tons/yr	
8. Emission Factor:	0.4 lb/MMBtu
Reference: See Comment	
9. Emissions Method Code (check one):	
<input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input type="checkbox"/> 5	
10. Calculation of Emissions:	
6,144 MMBtu/hr x 0.20 lb petcoke/lb coal x 0.4 lb/MMBtu = 491.5 lb/hr	
11. Pollutant Potential/Estimated Emissions Comment:	
Emission Factor Reference: Proposed Emission Limit for Petroleum Coke only. Potential emissions for petroleum coke only and based on assuring no increase in 'actual emissions' based on the definition in 62-212.200 (See Attachment 1).	

Emissions Unit Information Section 1 of 2
Allowable Emissions (Pollutant identification on front page)

A.

1. Basis for Allowable Emissions Code: RULE		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.4 lb/MMBtu		
4. Equivalent Allowable Emissions:	491.5 lbs/hr	2,153 tons/yr
5. Method of Compliance: CEMS		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode): Proposed emission limit for petroleum coke only. See Attachment 1.		

B.

1. Basis for Allowable Emissions Code:		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units:		
4. Equivalent Allowable Emissions:	lbs/hr	tons/yr
5. Method of Compliance:		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode):		

F. VISIBLE EMISSIONS INFORMATION

This subsection of the Application for Air Permit form must be completed for only those emissions units which are subject to a visible emissions limitation. The intent of this subsection of the form is to identify each activity associated with the emissions unit addressed in this section for which a separate opacity limitation would be applicable. Visible emission subtype codes for each such activity are listed in the instructions for Field 1. Most emissions units will be subject to a "subtype VE" limit only.

Visible Emissions Limitations: Visible Emissions Limitation 1 of 1

1.	Visible Emissions Subtype:
2.	Basis for Allowable Opacity: <input type="checkbox"/> Rule <input type="checkbox"/> Other
3.	Requested Allowable Opacity Normal Conditions: % Exceptional Conditions: % Maximum Period of Excess Opacity Allowed: min/hour
4.	Method of Compliance:
5.	Visible Emissions Comment: Proposed co-firing will not affect visible emission limits for the unit.

Visible Emissions Limitations: Visible Emissions Limitation ____ of ____

1.	Visible Emissions Subtype:		
2.	Basis for Allowable Opacity: <input type="checkbox"/> Rule <input type="checkbox"/> Other		
3.	Requested Allowable Opacity		
	Normal Conditions: %	Exceptional Conditions:	%
	Maximum Period of Excess Opacity Allowed:		min/hour
4.	Method of Compliance:		
5.	Visible Emissions Comment:		

Visible Emissions Limitations: Visible Emissions Limitation ____ of ____

1.	Visible Emissions Subtype:		
2.	Basis for Allowable Opacity: <input type="checkbox"/> Rule <input type="checkbox"/> Other		
3.	Requested Allowable Opacity		
	Normal Conditions: %	Exceptional Conditions:	%
	Maximum Period of Excess Opacity Allowed:		min/hour
4.	Method of Compliance:		
5.	Visible Emissions Comment:		

G. CONTINUOUS MONITOR INFORMATION

This subsection of the Application for Air Permit form must be completed for only those emissions units which are required by rule or permit to install and operate one or more continuous emission, opacity, flow, or other type monitors. A separate set of continuous monitor information (fields 1-6) must be completed for each monitoring system required.

Continuous Monitoring System Continuous Monitor _____ of _____

1. Parameter Code:	
2. CMS Requirement:	<input type="checkbox"/> Rule <input type="checkbox"/> Other
3. Monitor Information:	
Monitor Manufacturer: Model Number:	Serial Number:
4. Installation Date (DD-MON-YYYY):	
5. Performance Specification Test Date (DD-MON-YYYY):	
6. Continuous Monitor Comment:	
	Proposed co-firing will not affect CEMS requirements. CEMS meet requirements of 40 CFR Part 60 Subpart Da and 40 CFR Part 75. The Part 75 monitoring has previously been submitted to the Department.

Continuous Monitoring System Continuous Monitor _____ of _____

1. Parameter Code:
2. CMS Requirement: <input type="checkbox"/> Rule <input type="checkbox"/> Other
3. Monitor Information: Monitor Manufacturer: Model Number: Serial Number:
4. Installation Date (DD-MON-YYYY):
5. Performance Specification Test Date (DD-MON-YYYY):
6. Continuous Monitor Comment:

Continuous Monitoring System Continuous Monitor _____ of _____

1. Parameter Code:
2. CMS Requirement: <input type="checkbox"/> Rule <input type="checkbox"/> Other
3. Monitor Information: Monitor Manufacturer: Model Number: Serial Number:
4. Installation Date (DD-MON-YYYY):
5. Performance Specification Test Date (DD-MON-YYYY):
6. Continuous Monitor Comment:

H. PREVENTION OF SIGNIFICANT DETERIORATION (PSD) INCREMENT TRACKING INFORMATION

This subsection of the Application for Air Permit form must be completed for all applications, not just those undergoing prevention-of-significant-deterioration (PSD) review pursuant to Rule 62-212.400, F.A.C. The intent of this subsection is to make a preliminary determination as to whether the emissions unit addressed in this Emissions Unit Information Section consumes PSD increment. PSD increment is consumed (or expanded) as a result of emission increases (decreases) occurring after pollutant-specific baseline dates. Pollutants for which baseline dates have been established are sulfur dioxide, particulate matter, and nitrogen dioxide.

PSD Increment Consumption Determination**1. Increment Consuming for Particulate Matter or Sulfur Dioxide?**

If the emissions unit addressed in this section emits particulate matter or sulfur dioxide, answer the following series of questions to make a preliminary determination as to whether or not the emissions unit consumes PSD increment for particulate matter or sulfur dioxide. Check the first statement, if any, that applies and skip remaining statements.

- [x] The emissions unit is undergoing PSD review as part of this application, or has undergone PSD review previously, for particulate matter or sulfur dioxide. If so, emissions unit consumes increment.
- [] The facility addressed in this application is classified as an EPA major source pursuant to paragraph (c) of the definition of "major source of air pollution" in Chapter 62-213, F.A.C., and the emissions unit addressed in this section commenced (or will commence) construction after January 6, 1975. If so, baseline emissions are zero, and the emissions unit consumes increment.
- [] The facility addressed in this application is classified as an EPA major source and the emissions unit began initial operation after January 6, 1975, but before December 27, 1977. If so, baseline emissions are zero, and the emissions unit consumes increment.
- [] For any facility, the emissions unit began (or will begin) initial operation after December 27, 1977. If so, baseline emissions are zero, and emissions unit consumes increment.
- [] None of the above apply. If so, the baseline emissions of the emissions unit are nonzero. In such case, additional analysis, beyond the scope of this application, is needed to determine whether changes in emissions have occurred (or will occur) after the baseline date that may consume or expand increment.

2. Increment Consuming for Nitrogen Dioxide?

If the emissions unit addressed in this section emits nitrogen oxides, answer the following series of questions to make a preliminary determination as to whether or not the emissions unit consumes PSD increment for nitrogen dioxide. Check first statement, if any, that applies and skip remaining statements.

- The emissions unit addressed in this section is undergoing PSD review as part of this application, or has undergone PSD review previously, for nitrogen dioxide. If so, emissions unit consumes increment.
- The facility addressed in this application is classified as an EPA major source pursuant to paragraph (c) of the definition of "major source of air pollution" in Chapter 62-213, F.A.C., and the emissions unit addressed in this section commenced (or will commence) construction after February 8, 1988. If so, baseline emissions are zero, and the source consumes increment.
- The facility addressed in this application is classified as an EPA major source and the emissions unit began initial operation after February 8, 1988, but before March 28, 1988. If so, baseline emissions are zero, and the source consumes increment.
- For any facility, the emissions unit began (or will begin) initial operation after March 28, 1988. If so, baseline emissions are zero, and the emissions unit consumes increment.
- None of the above apply. If so, baseline emissions of the emissions unit are nonzero. In such case, additional analysis, beyond the scope of this application, is needed to determine whether changes in emissions have occurred (or will occur) after the baseline date that may consume or expand increment.

3.	Increment Consuming/Expanding Code:			
	PM	<input checked="" type="checkbox"/> C	<input type="checkbox"/> E	<input type="checkbox"/> Unknown
	SO ₂	<input checked="" type="checkbox"/> C	<input type="checkbox"/> E	<input type="checkbox"/> Unknown
	NO ₂	<input type="checkbox"/> C	<input type="checkbox"/> E	<input type="checkbox"/> Unknown
4.	Baseline Emissions:			
	PM	lbs/hr		tons/yr
	SO ₂	lbs/hr		tons/yr
	NO ₂		16,146	tons/yr
5.	PSD Comment:			
	Proposed emission limits for SO ₂ and proposed conditions for other pollutants will not trigger PSD applicability for co-firing. See Attachment 1.			

I. EMISSIONS UNIT SUPPLEMENTAL INFORMATION

This subsection of the Application for Air Permit form provides supplemental information related to the emissions unit addressed in this Emissions Unit Information Section. Supplemental information must be submitted as an attachment to each copy of the form, in hard-copy or computer-readable form.

Supplemental Requirements for All Applications

1.	Process Flow Diagram	<input type="checkbox"/> Attached, Document ID: _____	<input type="checkbox"/> Waiver Requested
		<input checked="" type="checkbox"/> Not Applicable	
2.	Fuel Analysis or Specification	<input type="checkbox"/> Attached, Document ID: _____	<input type="checkbox"/> Waiver Requested
		<input checked="" type="checkbox"/> Not Applicable	
3.	Detailed Description of Control Equipment	<input type="checkbox"/> Attached, Document ID: _____	<input type="checkbox"/> Waiver Requested
		<input checked="" type="checkbox"/> Not Applicable	
4.	Description of Stack Sampling Facilities	<input type="checkbox"/> Attached, Document ID: _____	<input type="checkbox"/> Waiver Requested
		<input checked="" type="checkbox"/> Not Applicable	
5.	Compliance Test Report	<input type="checkbox"/> Attached, Document ID: _____	<input checked="" type="checkbox"/> Not Applicable
		<input type="checkbox"/> Previously Submitted, Date: _____	
6.	Procedures for Startup and Shutdown	<input type="checkbox"/> Attached, Document ID: _____	<input checked="" type="checkbox"/> Not Applicable
7.	Operation and Maintenance Plan	<input type="checkbox"/> Attached, Document ID: _____	<input checked="" type="checkbox"/> Not Applicable
8.	Supplemental Information for Construction Permit Application	<input checked="" type="checkbox"/> Attached, Document ID: <u>Attachment 1</u>	<input type="checkbox"/> Not Applicable
9.	Other Information Required by Rule or Statute	<input type="checkbox"/> Attached, Document ID: _____	<input checked="" type="checkbox"/> Not Applicable

Additional Supplemental Requirements for Category I Applications Only

10. Alternative Methods of Operation <input checked="" type="checkbox"/> Attached, Document ID: <u>Attachment 1</u> <input type="checkbox"/> Not Applicable
11. Alternative Modes of Operation (Emissions Trading) <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
12. Enhanced Monitoring Plan <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
13. Identification of Additional Applicable Requirements <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
14. Acid Rain Permit Application <input type="checkbox"/> Acid Rain Part - Phase II (Form No. 62-210.900(1)(a)) Attached, Document ID: _____ <input type="checkbox"/> Repowering Extension Plan (Form No. 62-210.900(1)(a)1.) Attached, Document ID: _____ <input type="checkbox"/> New Unit Exemption (Form No. 62-210.900(1)(a)2.) Attached, Document ID: _____ <input type="checkbox"/> Retired Unit Exemption (Form No. 62-210.900(1)(a)3.) Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable

Emissions Unit Information Section 2 of 2

III. EMISSIONS UNIT INFORMATION

A separate Emissions Unit Information Section (including subsections A through I as required) must be completed for each emissions unit addressed in this Application for Air Permit. If submitting the application form in hard copy, indicate, in the space provided at the top of each page, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application.

A. GENERAL EMISSIONS UNIT INFORMATION

This subsection of the Application for Air Permit form provides general information on the emissions unit addressed in this Emissions Unit Information Section, including information on the type, control equipment, operating capacity, and operating schedule of the emissions unit.

Type of Emissions Unit Addressed in This Section

Check one:

- [X] This Emissions Unit information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).
- [] This Emissions Unit Information Section addresses, as a single emissions unit, an individually-regulated emission point (stack or vent) serving a single process or production unit, or activity, which also has other individually-regulated emission points.
- [] This Emissions Unit Information Section addresses, as a single emissions unit, a collectively-regulated group of process or production units and activities which has at least one definable emission point (stack or vent) but may also produce fugitive emissions.
- [] This Emissions Unit Information Section addresses, as a single emissions unit, one or more process or production units and activities which produce fugitive emissions only.

Emissions Unit Control Equipment Information

A.

<p>1. Description:</p> <p>Electrostatic precipitator</p> <p>2. Control Device or Method Code: 10</p>
--

B.

<p>1. Description:</p> <p>Flue Gas Desulfurization System. Wet Limestone Scrubbing</p> <p>2. Control Device or Method Code: 67</p>
--

C.

<p>1. Description:</p> <p>Modified Furnance and Low-NOx Burners</p> <p>2. Control Device or Method Code: 24</p>

Emissions Unit Operating Capacity

1. Maximum Heat Input Rate:	6,144 mmBtu/hr
2. Maximum Incineration Rate:	tons/day
	lbs/hr
3. Maximum Process or Throughput Rate:	
4. Maximum Production Rate:	
5. Operating Capacity Comment:	
	The co-firing of petroleum coke and coal will not change the operating capacity of the emission unit. Maximum heat input limited by specific condition of site certification.

Emissions Unit Operating Schedule

1. Requested Maximum Operating Schedule:		
	hours/day,	days/week,
	weeks/yr	8,760 hours/yr

B. EMISSIONS UNIT REGULATIONS

Depending on the application category, this subsection of the Application for Air Permit form provides either a brief analysis or detailed listing of all federal, state, and local regulations applicable to the emissions unit addressed in this Emissions Unit Information Section.

Rule Applicability Analysis (Required for Category II Applications and Category III applications involving non Title-V sources. See Instructions.)

Not Applicable

List of Applicable Regulations (Required for Category I applications and Category III applications involving Title-V sources. See Instructions.)

40 CFR 60 Subpart Da
40 CFR Part 72 (as applicable)
40 CFR Part 73 (as applicable)
40 CFR Part 75 (as applicable)
62-210.700(1)
62-296.405(2)(a)
62-296.405(2)(b)
62-296.405(2)(c)
62-296.800(2)(a)2
62-296.800(3)
62-296.800(4)(a)
62-296.800(4)(b)
62-296.800(4)(e)
62-297.310
62-297.330
62-297.340
62-297.345(1)
62-297.345(3)
62-297.350
62-297.400
62-297.401(1)
62-297.401(17)
62-297.401(19)
62-297.401(2)
62-297.401(3)
62-297.401(4)
62-297.401(5)
62-297.401(6)
62-297.401(7)
62-297.401(9)

C. EMISSION POINT (STACK/VENT) INFORMATION

This subsection of the application for Air Permit form provides information about the emission point associated with the emissions unit addressed in this Emissions Unit Information Section. An emission point is typically a stack or vent but can be any identifiable location at which air pollutants, including fugitive emissions, are discharged into the atmosphere.

Emission Point Description and Type

<p>1. Identification of Point on Plot Plan or Flow Diagram:</p> <p>Not Applicable</p>
<p>2. Emission Point Type Code:</p> <p><input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4</p>
<p>3. Descriptions of Emissions Points Comprising this Emissions Unit:</p> <p>Unit 2 Stack</p>
<p>4. ID Numbers or Descriptions of Emission Units with this Emission Point in Common:</p>
<p>5. Discharge Type Code:</p> <p><input type="checkbox"/> D <input type="checkbox"/> F <input type="checkbox"/> H <input type="checkbox"/> P <input type="checkbox"/> R <input checked="" type="checkbox"/> V <input type="checkbox"/> W</p>

6. Stack Height:	640	ft
7. Exit Diameter:	22.3	ft
8. Exit Temperature:	160	°F
9. Actual Volumetric Flow Rate:	2,230,000	acfm
10. Percent Water Vapor:		%
11. Maximum Dry Standard Flow Rate:		dscfm
12. Nonstack Emission Point Height:		ft
13. Emission Point UTM Coordinates:		
Zone: 17	East (km): 446.9	North (km): 3366.3
14. Emission Point Comment:		

D. SEGMENT (PROCESS/FUEL) INFORMATION

For the emissions unit addressed in this Emissions Unit Information Section, a separate set of segment data (Fields 1-10) must be completed for each segment required to be reported and for each alternative operating method or mode (emissions trading scenario) under Chapter 62-213, F.A.C., for which the maximum hourly or annual segment-related rate would vary. A segment is a material handling, process, fuel burning, volatile organic liquid storage, production, or other such operation to which emissions of the unit are directly related. See instructions for further details on this subsection of the Application for Air Permit.

Segment Description and Rate Information: Segment 1 of 2

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode): Coal	
2. Source Classification Code (SCC): 1-01-001-01	
3. SCC Units: Tons	
4. Maximum Hourly Rate: 253.9	5. Maximum Annual Rate: 2,224,200
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur: 4	8. Maximum Percent Ash: 18
9. Million Btu per SCC Unit:	
10. Segment Comment: Maximum hourly and annual rates calculated based on typical heat content of coal (i.e., 12,100 Btu/lb) and 6,144 MMBtu/hr maximum heat input. Maximum percent sulfur based on permit limit. Million Btu per SCC Unit is 24.2.	

Segment Description and Rate Information: Segment 2 of 2

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode): Coal and Petroleum Coke (Heat Input Basis)	
2. Source Classification Code (SCC): 1-01-001-04	
3. SCC Units: Tons	
4. Maximum Hourly Rate: 244.6	5. Maximum Annual Rate: 2,142,700
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur: 4.34	8. Maximum Percent Ash: 18
9. Million Btu per SCC Unit: 25	
10. Segment Comment: Maximum hourly and annual rate based on maximum percentage of petroleum coke when co-firing (i.e., 20%). Heat content and sulfur content of petroleum coke based on typical values of 29.6 MMBtu/ton and 6% sulfur. (See Segment 1 of 2 for coal values). Maximum Percent Ash: <18. Million Btu per SCC Unit: 25.12.	

E. POLLUTANT INFORMATION

For the emissions unit addressed in this Emissions Unit Information Section, a separate set of pollutant information must be completed for each pollutant required to be reported. See instructions for further details on this subsection of the Application for Air Permit.

Pollutant Potential/Estimated Emissions: Pollutant 1 of 1

1. Pollutant Emitted: SO2	
2. Total Percent Efficiency of Control:	95 %
3. Primary Control Device Code:	067
4. Secondary Control Device Code:	
5. Potential Emissions:	491.5 lbs/hr 2,153 tons/yr
6. Synthetically Limited? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
7. Range of Estimated Fugitive/Other Emissions:	
<input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 _____ to _____ tons/yr	
8. Emission Factor:	0.4 lb/MMBtu
Reference: See Comment	
9. Emissions Method Code (check one):	
<input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input type="checkbox"/> 5	
10. Calculation of Emissions:	
6,144 MMBtu/hr x 0.20 lb petcoke/lb coal x 0.4 lb/MMBtu = 491.5 lb/hr	
11. Pollutant Potential/Estimated Emissions Comment:	
Emission Factor Reference: Proposed Emission Limit for Petroleum Coke only. Potential emissions for petroleum coke only and based on assuring no increase in 'actual emissions' based on the definition in 62-212.200 (See Attachment 1).	

Emissions Unit Information Section 2 of 2
Allowable Emissions (Pollutant identification on front page)

A.

1. Basis for Allowable Emissions Code: RULE		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.4 lb/MMBtu		
4. Equivalent Allowable Emissions:	491.5 lbs/hr	2,153 tons/yr
5. Method of Compliance: CEMS		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode): Proposed emission limit for petroleum coke only. See Attachment 1.		

B.

1. Basis for Allowable Emissions Code:		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units:		
4. Equivalent Allowable Emissions:	lbs/hr	tons/yr
5. Method of Compliance:		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode):		

F. VISIBLE EMISSIONS INFORMATION

This subsection of the Application for Air Permit form must be completed for only those emissions units which are subject to a visible emissions limitation. The intent of this subsection of the form is to identify each activity associated with the emissions unit addressed in this section for which a separate opacity limitation would be applicable. Visible emission subtype codes for each such activity are listed in the instructions for Field 1. Most emissions units will be subject to a "subtype VE" limit only.

Visible Emissions Limitations: Visible Emissions Limitation 1 of 1

1.	Visible Emissions Subtype:
2.	Basis for Allowable Opacity: <input type="checkbox"/> Rule <input type="checkbox"/> Other
3.	Requested Allowable Opacity Normal Conditions: % Exceptional Conditions: % Maximum Period of Excess Opacity Allowed: min/hour
4.	Method of Compliance:
5.	Visible Emissions Comment: Proposed co-firing will not affect visible emission limits for the unit.

Visible Emissions Limitations: Visible Emissions Limitation _____ of _____

1.	Visible Emissions Subtype:
2.	Basis for Allowable Opacity: <input type="checkbox"/> Rule <input type="checkbox"/> Other
3.	Requested Allowable Opacity Normal Conditions: % Exceptional Conditions: % Maximum Period of Excess Opacity Allowed: min/hour
4.	Method of Compliance:
5.	Visible Emissions Comment:

Visible Emissions Limitations: Visible Emissions Limitation _____ of _____

1.	Visible Emissions Subtype:
2.	Basis for Allowable Opacity: <input type="checkbox"/> Rule <input type="checkbox"/> Other
3.	Requested Allowable Opacity Normal Conditions: % Exceptional Conditions: % Maximum Period of Excess Opacity Allowed: min/hour
4.	Method of Compliance:
5.	Visible Emissions Comment:

G. CONTINUOUS MONITOR INFORMATION

This subsection of the Application for Air Permit form must be completed for only those emissions units which are required by rule or permit to install and operate one or more continuous emission, opacity, flow, or other type monitors. A separate set of continuous monitor information (fields 1-6) must be completed for each monitoring system required.

Continuous Monitoring System Continuous Monitor _____ of _____

1. Parameter Code:
2. CMS Requirement: <input type="checkbox"/> Rule <input type="checkbox"/> Other
3. Monitor Information: Monitor Manufacturer: _____ Model Number: _____ Serial Number: _____
4. Installation Date (DD-MON-YYYY):
5. Performance Specification Test Date (DD-MON-YYYY):
6. Continuous Monitor Comment: Proposed co-firing will not affect CEMS requirements. CEMS meet requirements of 40 CFR Part 60 Subpart Da and 40 CFR Part 75. The Part 75 monitoring plan has been previously submitted to the Department.

Continuous Monitoring System Continuous Monitor _____ of _____

1. Parameter Code:
2. CMS Requirement: <input type="checkbox"/> Rule <input type="checkbox"/> Other
3. Monitor Information: Monitor Manufacturer: Model Number: Serial Number:
4. Installation Date (DD-MON-YYYY):
5. Performance Specification Test Date (DD-MON-YYYY):
6. Continuous Monitor Comment:

Continuous Monitoring System Continuous Monitor _____ of _____

1. Parameter Code:
2. CMS Requirement: <input type="checkbox"/> Rule <input type="checkbox"/> Other
3. Monitor Information: Monitor Manufacturer: Model Number: Serial Number:
4. Installation Date (DD-MON-YYYY):
5. Performance Specification Test Date (DD-MON-YYYY):
6. Continuous Monitor Comment:

H. PREVENTION OF SIGNIFICANT DETERIORATION (PSD) INCREMENT TRACKING INFORMATION

This subsection of the Application for Air Permit form must be completed for all applications, not just those undergoing prevention-of-significant-deterioration (PSD) review pursuant to Rule 62-212.400, F.A.C. The intent of this subsection is to make a preliminary determination as to whether the emissions unit addressed in this Emissions Unit Information Section consumes PSD increment. PSD increment is consumed (or expanded) as a result of emission increases (decreases) occurring after pollutant-specific baseline dates. Pollutants for which baseline dates have been established are sulfur dioxide, particulate matter, and nitrogen dioxide.

PSD Increment Consumption Determination

1. Increment Consuming for Particulate Matter or Sulfur Dioxide?

If the emissions unit addressed in this section emits particulate matter or sulfur dioxide, answer the following series of questions to make a preliminary determination as to whether or not the emissions unit consumes PSD increment for particulate matter or sulfur dioxide. Check the first statement, if any, that applies and skip remaining statements.

- [x] The emissions unit is undergoing PSD review as part of this application, or has undergone PSD review previously, for particulate matter or sulfur dioxide. If so, emissions unit consumes increment.
- [] The facility addressed in this application is classified as an EPA major source pursuant to paragraph (c) of the definition of "major source of air pollution" in Chapter 62-213, F.A.C., and the emissions unit addressed in this section commenced (or will commence) construction after January 6, 1975. If so, baseline emissions are zero, and the emissions unit consumes increment.
- [] The facility addressed in this application is classified as an EPA major source and the emissions unit began initial operation after January 6, 1975, but before December 27, 1977. If so, baseline emissions are zero, and the emissions unit consumes increment.
- [] For any facility, the emissions unit began (or will begin) initial operation after December 27, 1977. If so, baseline emissions are zero, and emissions unit consumes increment.
- [] None of the above apply. If so, the baseline emissions of the emissions unit are nonzero. In such case, additional analysis, beyond the scope of this application, is needed to determine whether changes in emissions have occurred (or will occur) after the baseline date that may consume or expand increment.

2. Increment Consuming for Nitrogen Dioxide?

If the emissions unit addressed in this section emits nitrogen oxides, answer the following series of questions to make a preliminary determination as to whether or not the emissions unit consumes PSD increment for nitrogen dioxide. Check first statement, if any, that applies and skip remaining statements.

- The emissions unit addressed in this section is undergoing PSD review as part of this application, or has undergone PSD review previously, for nitrogen dioxide. If so, emissions unit consumes increment.
- The facility addressed in this application is classified as an EPA major source pursuant to paragraph (c) of the definition of "major source of air pollution" in Chapter 62-213, F.A.C., and the emissions unit addressed in this section commenced (or will commence) construction after February 8, 1988. If so, baseline emissions are zero, and the source consumes increment.
- The facility addressed in this application is classified as an EPA major source and the emissions unit began initial operation after February 8, 1988, but before March 28, 1988. If so, baseline emissions are zero, and the source consumes increment.
- For any facility, the emissions unit began (or will begin) initial operation after March 28, 1988. If so, baseline emissions are zero, and the emissions unit consumes increment.
- None of the above apply. If so, baseline emissions of the emissions unit are nonzero. In such case, additional analysis, beyond the scope of this application, is needed to determine whether changes in emissions have occurred (or will occur) after the baseline date that may consume or expand increment.

3.	Increment Consuming/Expanding Code:			
	PM	<input checked="" type="checkbox"/> C	<input type="checkbox"/> E	<input type="checkbox"/> Unknown
	SO ₂	<input checked="" type="checkbox"/> C	<input type="checkbox"/> E	<input type="checkbox"/> Unknown
	NO ₂	<input type="checkbox"/> C	<input type="checkbox"/> E	<input type="checkbox"/> Unknown
4.	Baseline Emissions:			
	PM	lbs/hr		tons/yr
	SO ₂	lbs/hr		tons/yr
	NO ₂		16,146	tons/yr
5.	PSD Comment:			
	Proposed emission limits for SO ₂ and proposed conditions for other pollutants will not trigger PSD applicability for co-firing. See Attachment 1.			

I. EMISSIONS UNIT SUPPLEMENTAL INFORMATION

This subsection of the Application for Air Permit form provides supplemental information related to the emissions unit addressed in this Emissions Unit Information Section. Supplemental information must be submitted as an attachment to each copy of the form, in hard-copy or computer-readable form.

Supplemental Requirements for All Applications

1.	Process Flow Diagram	<input type="checkbox"/> Attached, Document ID: _____	<input type="checkbox"/> Waiver Requested
		<input checked="" type="checkbox"/> Not Applicable	
2.	Fuel Analysis or Specification	<input type="checkbox"/> Attached, Document ID: _____	<input type="checkbox"/> Waiver Requested
		<input checked="" type="checkbox"/> Not Applicable	
3.	Detailed Description of Control Equipment	<input type="checkbox"/> Attached, Document ID: _____	<input type="checkbox"/> Waiver Requested
		<input checked="" type="checkbox"/> Not Applicable	
4.	Description of Stack Sampling Facilities	<input type="checkbox"/> Attached, Document ID: _____	<input type="checkbox"/> Waiver Requested
		<input checked="" type="checkbox"/> Not Applicable	
5.	Compliance Test Report	<input type="checkbox"/> Attached, Document ID: _____	<input checked="" type="checkbox"/> Not Applicable
		<input type="checkbox"/> Previously Submitted, Date: _____	
6.	Procedures for Startup and Shutdown	<input type="checkbox"/> Attached, Document ID: _____	<input checked="" type="checkbox"/> Not Applicable
7.	Operation and Maintenance Plan	<input type="checkbox"/> Attached, Document ID: _____	<input checked="" type="checkbox"/> Not Applicable
8.	Supplemental Information for Construction Permit Application	<input checked="" type="checkbox"/> Attached, Document ID: <u>Attachment 1</u>	<input type="checkbox"/> Not Applicable
9.	Other Information Required by Rule or Statute	<input type="checkbox"/> Attached, Document ID: _____	<input checked="" type="checkbox"/> Not Applicable

Additional Supplemental Requirements for Category I Applications Only

10. Alternative Methods of Operation <input checked="" type="checkbox"/> Attached, Document ID: <u>Attachment 1</u> <input type="checkbox"/> Not Applicable
11. Alternative Modes of Operation (Emissions Trading) <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
12. Enhanced Monitoring Plan <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
13. Identification of Additional Applicable Requirements <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
14. Acid Rain Permit Application <input type="checkbox"/> Acid Rain Part - Phase II (Form No. 62-210.900(1)(a)) Attached, Document ID: _____ <input type="checkbox"/> Repowering Extension Plan (Form No. 62-210.900(1)(a)1.) Attached, Document ID: _____ <input type="checkbox"/> New Unit Exemption (Form No. 62-210.900(1)(a)2.) Attached, Document ID: _____ <input type="checkbox"/> Retired Unit Exemption (Form No. 62-210.900(1)(a)3.) Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable

ATTACHMENT 1

ATTACHMENT 1

1.0 PROJECT DESCRIPTION

The St. Johns River Power Park (SJRPP) proposes to co-fire a mixture of up to 20 percent petroleum coke with coal in a manner that would ensure that there is not a significant net increase in actual emissions of any regulated pollutant and, therefore, the Prevention of Significant Deterioration (PSD) Rules in 62-212.400, Florida Administrative Code (F.A.C.) would not apply. This would be accomplished through a limitation on sulfur dioxide (SO₂) emissions when co-firing petroleum coke that includes both an emission limit and a percent SO₂ reduction requirement. In addition, SJRPP proposes to accept a condition for carbon monoxide (CO) that would demonstrate that a net significant emission increase would not occur.

This permit application is associated with a modification request of the site certification for the units (PA 81-13). Approval from the FDEP is being sought to use up to 20 percent (heat input basis) of petroleum coke with coal. No new facilities or equipment are required to burn petroleum coke. Minor amendments to PSD permit are required. There will be no substantial changes made in the fuel handling facilities or the emission units to accommodate co-firing of petroleum coke. A temporary hopper and conveyor will be used to load petroleum coke with coal on the reclaim conveyor prior to transporting to the crusher house. From the crusher house, the blended fuel will be conveyed to the coal storage silos. Petroleum coke can be co-fired with coal as soon as approval is obtained from FDEP and it is received in the coal yard.

2.0 TRIAL BURN TEST RESULTS

A trial test burn for co-firing petroleum coke and coal was authorized by the Florida Department of Environmental Protection (FDEP) and conducted August 8-19, 1995. A copy of the trial test burn results is attached. A summary of the trial test burn results and a statistical comparison of the baseline tests (coal only) and co-firing petroleum coke and coal are presented in Table 1. A statistical analysis was performed using Appendix C to Part 60 (of 40 CFR).

The results of the trial test burn and the statistical analysis indicate that there are no emission rate increases for particulate matter or nitrogen oxides. The emission rates of sulfur dioxide, sulfuric acid mist, and CO were lower in the baseline tests than in the tests performed while the unit was co-firing petroleum coke and coal. The remainder of this attachment discusses these pollutants.

2.1 SULFUR DIOXIDE

A federally enforceable permit condition is proposed that prevents PSD applicability by preventing actual SO₂ emissions associated with the petroleum coke fraction of the blended fuel from exceeding past actual SO₂ emissions associated with burning coal. In this manner, there will be no prospective increase in SO₂ emissions caused by the proposed change (i.e., utilization of petroleum coke). Pursuant to EPA's June 21, 1992, WEPCO regulations (57 Federal Register 32314), increases in air emissions not caused by proposed changes must be excluded from steam electric power plants' future actual emissions in assessing PSD applicability. EPA emphasized in the preamble statement that new source review "applies only where the emissions increase is cause by the change" [57 Federal Register 32325]. The approach comports with the WEPCO regulations and corresponding state rules by eliminating the possibility that the petroleum coke portion of prospective fuel blends will exceed "past actual" SO₂ emissions associated with coal burning. Consistent with the WEPCO regulations, future increases in SO₂ emissions caused solely by enhanced electricity demand or caused by permissible variations in coal sulfur content should not count toward PSD applicability.

The emission limitation has the following components:

- a. When blends of petroleum coke and coal with a sulfur content of up to or equal to 2 percent are fired in Units 1 or 2, the SO₂ emissions shall not exceed 0.56 pound per million British thermal units (lb/MMBtu) and a minimum of 75 percent reduction in the flue gas desulfurization system.
- b. When co-firing petroleum coke with coals having a sulfur content between 2 and 3.63 percent, the emission limitation shall be based on the following formula:

$$\text{SO}_2 \text{ emission limit (lb/MMBtu)} = (0.2 \times C/100) + 0.4$$

where: C = percent of coal co-fired on a heat input basis (e.g., 80 percent)

- c. When coals with a sulfur content greater than 3.63 percent are co-fired with petroleum coke, the SO₂ emissions shall not exceed the following formula:

$$\text{SO}_2 \text{ emission limit (lb/MMBtu)} = (0.1653 \times C \times S - 0.4 \times C + 40) \times 1/100$$

where: C = percent of coal co-fired on a heat input basis

where: C = percent of coal co-fired on a heat input basis

- d. The maximum SO₂ emission rate when firing petroleum coke ^{and coal} shall not exceed 0.688 lb/MMBtu.
- e. Compliance with the SO₂ emissions limit shall be based on a 30-day rolling average for those days when petroleum coke is fired. Any use of petroleum coke during a 24-hour period shall be considered 1 day of the 30-day rolling average. The 30-day rolling average shall be calculated according to the New Source Performance Standards (NSPS) codified in 40 CFR Part 60 Subpart Da, except as noted above.

The proposed emission limits for SO₂ were developed from the two fundamental requirements of the PSD approval and the specific conditions of the site certification and to assure no net increase in annual emissions. The PSD approval and site certification require that the NSPS Subpart Da be met and that emissions do not exceed 0.76 lb/MMBtu (30-day rolling average). The emission limits proposed for co-firing are supported by the following rationale:

1. The NSPS codified in 40 CFR Part 60 Subpart Da requires, in the range of coals to be fired, either 0.6 lb/MMBtu or a 70 percent reduction in the potential SO₂ combustion concentration. For coals with a sulfur content greater than 1.2 percent, the 0.6 lb/MMBtu emission limit would govern. For coals with sulfur contents of 1.2 percent or less, the 70 percent reduction requirement would govern. This is illustrated in the attached Table 2 which presents in the sixth and seventh columns the NSPS emission limit and the percent SO₂ removals as a function of the coal sulfur content (first column). In terms of practical application, under Subpart Da: (1) when the inlet air to the scrubber has SO₂ concentrations under 2.0 lb/MMBtu, 70 percent SO₂ reduction is required; (2) when the inlet SO₂ concentration is higher than 2.0 but less than 6.0 lb/MMBtu, required SO₂ scrubbing must result in emissions of 0.6 lb/MMBtu or less; (3) at higher concentrations, 90 percent removal is required. It should be noted that the facility has a 0.76 lb SO₂/MMBtu emission limit established as BACT for coal firing. The proposed emission limit for co-firing petroleum coke and coal could not exceed this limit, since this is inherent in the proposed limit.
2. The representative actual annual SO₂ emission rate for Units 1 and 2 over the last 2 years has been 0.4 lb/MMBtu. By ensuring that the emission rate when firing

petroleum coke does not exceed 0.4 lb/MMBtu, the "representative actual annual emissions" as defined in 40 CFR 52.21(b)(33) would not exceed the past actual emissions. To achieve a 0.4 lb/MMBtu emission rate with the typical sulfur content for petroleum coke (e.g., 6 percent), a 95 percent reduction is required. This is shown on the last column of the Table 2.

3. Except for coals with a sulfur content of greater than 2 percent, the proposed percent reduction requirement and the emission limit are based on co-firing 20 percent petroleum coke with coal (on a heat input basis). This is the worst-case mixture proposed and ensures that when co-firing lower percentages of petroleum coke with coal, the resulting emission rate would be lower than could be allowed by meeting only the NSPS and the "actual" emission rate. For example, if a 10 percent mixture of petroleum coke is co-fired with a 1.2 percent sulfur coal, then the resulting emissions rate to meet NSPS and 0.4 lb/MMBtu would be 0.58 lb/MMBtu. In contrast, the proposed condition would limit the SO₂ emissions to 0.56 lb/MMBtu.
4. The effect of the proposed SO₂ emission limitation is shown on Table 2 (second and third columns). As shown, for coals with sulfur content less than 1.2 percent, the 75 percent reduction requirement would produce emission rates less than 0.56 lb/MMBtu while meeting the NSPS reduction requirement of 70 percent and the "actual" emission rate of 0.4 lb/MMBtu for petroleum coke. For coals with a sulfur content of 1.2 to 2 percent, the proposed emission limit of 0.56 lb/MMBtu would meet the NSPS limit of 0.6 lb/MMBtu for coal and 0.4 lb/MMBtu for petroleum coke.
5. The equation for an SO₂ emission limit for coals above 2 percent sulfur content would allow some flexibility for petroleum coke/coal mixtures. This formula would be applicable for sulfur contents from 2.0 to 3.63 percent, since coals in this range would be required to meet the 0.6 lb/MMBtu limit in Subpart Da. The proposed equations for SO₂ emission limitations for coal above 2 percent sulfur content would allow some flexibility for petroleum coke/coal mixtures (see Table 3 for derivation of equations). The equation in Paragraph b above will achieve compliance with the governing Subpart Da limit of 0.6 lb/MMBtu and 0.4 lb/MMBtu for petroleum coke. The equation in Paragraph c above accounts for the governing Subpart Da requirement of 90 percent SO₂ reduction and 0.4 lb/MMBtu for petroleum coke. The maximum SO₂ emission rate associated with firing only coal, regardless of coal sulfur

content, cannot exceed 0.76 lb/MMBtu as required by PSD and Power Plant Siting Act (PPSA) approval. Therefore, mixtures of petroleum coke and coal can never exceed 0.688 lb/MMBtu.

6. SJRPP Units 1 and 2 feature an inlet continuous emission monitoring system to monitor inlet SO₂ levels prior to the flue gas desulfurization system as required by Subpart Da and an outlet continuous emission monitoring system which records SO₂ emissions as required by Subpart Da and 40 CFR Part 75. These SO₂ data are quality assured pursuant to Subpart Da and Part 75 requirements. The percent reduction requirements and the SO₂ emissions limitations for coals blended with petroleum coke that have a sulfur content less than 3.63 percent shall be ensured by operating in accordance with the data from the inlet and outlet continuous emissions monitoring system. The sulfur content of the coal shall be ensured by utilizing the "as received" coal analytical data or onsite sampling and analysis.

The proposed emission limitation meets the letter and intent of the WEPCO regulations. Also, this condition comports with EPA's "federal enforceability" guidance because it is enforceable both as a matter of law and as a practical matter; simply put, this condition obviates the possibility of an increase in actual emissions attributable to petroleum coke. Moreover, this proposal comports with good environmental policy. As shown in Figures 1 and 2, under the proposed permit condition, co-firing petroleum coke will be subject to lower emissions limitations than the limitations applicable when utilizing only coal. These graphs compare the emission limits and reduction percentages currently applicable to coal firing and proposed for petroleum coke co-firing. With the proposed permit condition, co-firing petroleum coke will not require PSD analysis pursuant to Rules 62-212.400 and 62.212.200(2)(d), F.A.C.

2.2 SULFURIC ACID MIST

The trial test values for sulfuric acid mist were a direct result of an associated increase in SO₂ emissions. Table 4 presents a comparison of the SO₂ and SO₃ emissions between the baseline tests and the co-firing test. The ratios of the blend to baseline test results are 1.78 and 1.70 for SO₂ and SO₃ emissions, respectively. This indicates that the SO₃ increase was in the relatively same proportion for both SO₃ and SO₂ (actually slightly greater for SO₂). In addition, the amount

of SO₂ removal for both the baseline test and blend test was almost identical at about 73 percent. The proposed SO₂ emission limit, if implemented during the test burn, would have ensured lower SO₂ emissions and concomitantly lower SO₃ emissions that would ensure no significant increase in the emission rates for both pollutants. Overall reduction in SO₂ emissions would have likely been 20 to 30 percent higher. For these reasons, no condition for sulfuric acid mist should be required.

2.3 CARBON MONOXIDE

The CO emissions during the baseline tests were lower than those observed during the blend tests. Since there was no attempt to control CO emissions during the co-firing tests, the combustion conditions were not "fine tuned" to optimize combustion of the petroleum coke and coal blend. Many factors, such as the grindability of the petroleum coke/coal blend and combustion controls (e.g., oxygen concentrations, NO_x control systems, load, etc.) can significantly influence CO concentrations. Data from other petroleum coke/coal co-firing test burns indicate no changes in CO emission rates. In addition, a review of the last several months of CO data from the SJRPP indicates CO values in the range reported for the co-firing test burn. For these reasons, SJRPP proposes to optimize combustion of co-firing petroleum coke and coal to ensure no net increase in emissions. A condition is proposed that has been issued in other Department permits approving co-firing of petroleum coke and coal:

- (a) The applicant shall maintain and submit to the Department on an annual basis for a period of 5 years from the date the unit is co-fired with petroleum coke, information demonstrating that the co-firing did not result in significant emission increases of CO. The CO emissions shall be based on test results using EPA Method 10.

Table 1. Statistical Analysis of Petroleum Coke Trial Burn, St. John's River Power Park

Test Case	Date	PM (lb/hr)	SO3 (ppm)	CO (ppm)	NOx out (lb/MMBtu)	SO2 in (lb/MMBtu)	SO2 out (lb/MMBtu)
Baseline	07/18/95	44.14	6.96	10.29	0.468	1.029	0.283
Baseline	07/19/95	21.50	5.19	45.16	0.502	1.026	0.282
Baseline	07/20/95	64.92	5.55	67.00	0.474	1.031	0.282
Baseline	08/08/95	61.85	7.04	21.15	0.549	0.973	0.270
	Average	48.1	6.19	35.9	0.498	1.015	0.279
	Std. Dev.	20.0	0.95	25.3	0.0369	0.0279	0.0062
	Sample Var	398.4	0.91	642.1	0.0014	0.0008	0.0000
	n	4	4	4	4	4	4
Blend	08/11/95		7.54	312.96	0.502	1.636	0.457
Blend	08/12/95		9.21	497.58	0.494	1.709	0.485
Blend	08/13/95		14.03	745.64	0.463	1.728	0.482
Blend	08/14/95	80.76			0.498	1.757	0.477
Blend	08/15/95	42.95			0.503	1.730	0.471
Blend	08/16/95	28.98			0.535	1.720	0.477
Blend	08/17/95	63.28			0.559	1.938	0.521
Blend	08/18/95		11.37	467.90	0.498	2.244	0.566
Blend	08/19/95	23.47			0.470	2.376	0.545
	Average	47.9	10.54	506.0	0.502	1.871	0.498
	Std. Dev.	24.0	2.81	179.1	0.030	0.264	0.037
	Sample Var	573.9	7.88	32071.4	0.001	0.070	0.001
	n	5	4	4	9	9	9
Degrees of Freedom		7	6	6	11	11	11
t prime at 95%		1.895	1.943	1.943	1.796	1.796	1.796
Sp		22.33	2.10	127.89	0.032	0.225	0.032
t calc		-0.0143188	2.937	5.198	0.220	6.322	11.406
Result		OK	Sig Diff	Sig Diff	OK	Sig Diff	Sig Diff

Table 2. Combined Emissions Limit and Scrubber Efficiency for Co-firing Petroleum Coke and Coal at St. Johns River Power Park

Coal Sulfur Content	Combined Emission Limit (lb/mmBtu)	Combined Scrubber Efficiency	Uncontrolled Emissions		Coal SO2 NSPS Limit (lb/mmBtu)	Coal SO2 Removal	Pet Coke SO2 Removal
			Coal SO2 (lb/mmBtu)	Pet Coke SO2 (lb/mmBtu)			
0.80%	0.40	75.01%	1.32	8.11	0.40	70.00%	95.07%
0.90%	0.44	75.01%	1.49	8.11	0.45	70.00%	95.07%
1.00%	0.48	75.01%	1.65	8.11	0.50	70.00%	95.07%
1.10%	0.52	75.01%	1.82	8.11	0.55	70.00%	95.07%
1.20%	0.56	75.01%	1.98	8.11	0.60	70.00%	95.07%
1.30%	0.56	76.67%	2.15	8.11	0.60	72.08%	95.07%
1.40%	0.56	78.27%	2.31	8.11	0.60	74.07%	95.07%
1.50%	0.56	79.65%	2.48	8.11	0.60	75.80%	95.07%
1.60%	0.56	80.86%	2.64	8.11	0.60	77.31%	95.07%
1.70%	0.56	81.93%	2.81	8.11	0.60	78.65%	95.07%
1.80%	0.56	82.88%	2.98	8.11	0.60	79.83%	95.07%
1.90%	0.56	83.73%	3.14	8.11	0.60	80.89%	95.07%
2.00%	0.56	84.49%	3.31	8.11	0.60	81.85%	95.07%
2.10%	0.56	85.18%	3.47	8.11	0.60	82.71%	95.07%
2.20%	0.56	85.81%	3.64	8.11	0.60	83.50%	95.07%
2.30%	0.56	86.39%	3.80	8.11	0.60	84.22%	95.07%
2.40%	0.56	86.91%	3.97	8.11	0.60	84.88%	95.07%
2.50%	0.56	87.40%	4.13	8.11	0.60	85.48%	95.07%
2.60%	0.56	87.84%	4.30	8.11	0.60	86.04%	95.07%
2.70%	0.56	88.26%	4.46	8.11	0.60	86.56%	95.07%
2.80%	0.56	88.64%	4.63	8.11	0.60	87.04%	95.07%
2.90%	0.56	89.00%	4.79	8.11	0.60	87.48%	95.07%
3.00%	0.56	89.33%	4.96	8.11	0.60	87.90%	95.07%
3.10%	0.56	89.65%	5.12	8.11	0.60	88.29%	95.07%
3.20%	0.56	89.94%	5.29	8.11	0.60	88.66%	95.07%
3.30%	0.56	90.21%	5.45	8.11	0.60	89.00%	95.07%
3.40%	0.56	90.47%	5.62	8.11	0.60	89.32%	95.07%
3.50%	0.56	90.72%	5.79	8.11	0.60	89.63%	95.07%
3.60%	0.56	90.95%	5.95	8.11	0.60	89.92%	95.07%
3.63%	0.56	91.01%	6.00	8.11	0.60	90.00%	95.07%
3.70%	0.57	91.01%	6.12	8.11	0.61	90.00%	95.07%
3.80%	0.58	91.01%	6.28	8.11	0.63	90.00%	95.07%
3.90%	0.60	91.01%	6.45	8.11	0.64	90.00%	95.07%
4.00%	0.61	91.01%	6.61	8.11	0.66	90.00%	95.07%

Assumptions: 12,100 Btu/lb for Coal
14,800 Btu/lb for Petroleum Coke
6% sulfur content of Petroleum Coke
20% Petroleum Coke firing (mmBtu/hr basis)
0.40 lb/mmBtu for Petroleum Coke

Table 3. Derivation of Formulas (Page 1 of 2)

Fundamental Requirements:

1. Coal - Meet NSPS Subpart Da and BACT Emission Limit
 - a. 0.6 lb / MMBtu or 70% SO₂ Reduction (NSPS),
 - b. 1.2 lb / MMBtu or 90% SO₂ Reduction (NSPS), and
 - c. 0.76 lb / MMBtu (30 - day rolling average).

2. Petroleum Coke - Meet 0.4 lb / MMBtu; Equivalent to 95% Reduction

$$\begin{aligned} \text{Calculation: } & \frac{0.06 \text{ lb S}}{\text{lb fuel}} \times \frac{\text{lb fuel}}{14,800 \text{ Btu}} \times \frac{2 \text{ lb SO}_2}{\text{lb S}} \times \frac{10^6}{\text{MM}} \times (1 - 0.95) \\ & = 0.4 \text{ lb / MMBtu} \end{aligned}$$

Proposed Limits:

1. Coals - ≤ 2% Sulfur; Assume 20% Petroleum Coke Co - Firing at All Times
 - a. NSPS = 0.6 lb / MMBtu

$$\begin{aligned} \text{Calculation: } & \frac{0.0121 \text{ lb S}}{\text{lb fuel}} \times \frac{\text{lb fuel}}{12,100 \text{ Btu}} \times \frac{2 \text{ lb SO}_2}{\text{lb S}} \times \frac{10^6}{\text{MM}} \times (1 - 0.7) \\ & = 0.6 \text{ lb / MMBtu} \end{aligned}$$

- b. Petroleum Coke = 0.4 lb / MMBtu

$$\begin{aligned} \text{c. Result: } & \left(\frac{80}{100} \times 0.6 \text{ lb / MMBtu} \right) + \left(\frac{20}{100} \times 0.4 \text{ lb / MMBtu} \right) \\ & = 0.56 \text{ lb / MMBtu and 75\% reduction} \end{aligned}$$

Table 3. Derivation of Formulas (Page 2 of 2)

Proposed Limits, continued:

2. Coals $>2\%$ Sulfur and $\leq 3.63\%$ Sulfur; Variable Amount of Petroleum Coke

a. NSPS = 0.6 lb / MMBtu

$$\begin{aligned} \text{Calculation: } & \frac{3.63 \text{ lb S}}{100 \text{ lb fuel}} \times \frac{\text{lb fuel}}{12,100 \text{ Btu}} \times \frac{2 \text{ lb SO}_2}{\text{lb S}} \times \left(1 - \frac{90}{100}\right) \\ & = 0.6 \text{ lb / MMBtu} \end{aligned}$$

b. Petroleum Coke = 0.4 lb / MMBtu

c. Let C = % Coal Fired

$$\begin{aligned} \text{Equation: } & \left(\frac{C}{100} \times 0.6 \text{ lb / MMBtu}\right) + \left[\left(1 - \frac{C}{100}\right) \times 0.4 \text{ lb / MMBtu}\right] \\ \text{SO}_2 \text{ Limit} & = \frac{0.6C}{100} - \frac{0.4C}{100} + 0.4 = \frac{0.2C}{100} + 0.4 \end{aligned}$$

3. Coals $> 3.63\%$ Sulfur; Variable Amount of Petroleum Coke

a. NSPS = 90% Reduction

b. Petroleum Coke = 0.4 lb / MMBtu

c. Let C = % Coal Fired and S = % Sulfur in Coal

$$\begin{aligned} \text{Equation: } & \left[\frac{C}{100} \times \frac{S}{100} \times \frac{1}{12,100} \times 2 \times \left(1 - \frac{90}{100}\right) \times 10^6\right] + \left[\left(1 - \frac{C}{100}\right) \times 0.4\right] \\ & = \left(\frac{C}{100} \times S \times 0.1653\right) + \left(0.4 - 0.4 \times \frac{C}{100}\right) \\ \text{SO}_2 \text{ Limit} & = \frac{1}{100} \times (0.1653 \times C \times S - 0.4C + 40) \end{aligned}$$

Example: 80% Coal and 3.8% Sulfur

$$(0.1653 \times 80 \times 3.8 - 0.4 \times 80 + 40) \times \frac{1}{100} = 0.58 \text{ lb / MMBtu}$$

4. Maximum limit when co - firing:

a. Coal at 0.76 .b / MMBtu, and

b. Petroleum Coke at 0.4 .b / MMBtu

Calculation:

$$\left(\frac{80}{100} \times 0.76 \text{ lb / MMBtu}\right) + \left(\frac{20}{100} \times 0.4 \text{ lb / MMBtu}\right) = 0.688 \text{ .b / MMBtu}$$

Table 4. Summary of SO₃ and SO₂ Test Cases

Test Case	SO ₃ (ppm)	SO ₂		
		Outlet (lb/MMBtu)	Inlet (lb/MMBtu)	Removal (%)
Baseline	6.19	0.279	1.015	72.7
Blend	10.54	0.498	1.87	73.4
Ratio ^a	1.70	1.784	1.843	

Note: SO₃ and SO₂ are averages of test cases.

^a Ratio = Baseline ÷ Blend.




Figure 1
Emission Limits—SO₂ Emission Rate vs. Percent Sulfur in Coal

Source: KBN, 1996.






Figure 2
Percent Removal—SO₂ Removal vs. Percent Sulfur in Coal

Source: KBN, 1996.



PETROLEUM COKE-COAL TRIAL TEST BURN RESULTS

Rec'd
ADMN

CERTIFIED MAIL

ADM 13
R 3
R 104



SJRO LC 95 483

October 2, 1995

Mr. Hamilton Oven
Adm. of Power Plant Siting
Florida Dept. of Environmental Protection
3900 Commonwealth Blvd.
Tallahassee, Florida 32399-2400

RE: St. Johns River Power Park Unit 1
Site Certification No. PA 81-13
Petroleum Coke/Coal Test Burn Final Report

Dear Mr. Oven:

The above referenced facility was authorized by the Florida Department of Environmental Protection's (FDEP) March 30, 1995 letter to test burn a blend of petroleum coke with coal. The test burn was performed August 8 - 19, 1995. Condition #1 of the FDEP authorization letter specifies that a written test report be submitted within 45 days upon completion of the last test run. Please find enclosed the test report with supporting documentation.

The results of the baseline and blend testing indicate that a blend of 80% coal and 20% petroleum coke can be burned successfully at SJRPP. Please note that SJRPP Units 1 and 2 are identical in design and are both required to comply with the limitations set forth in the Conditions of Certification. Based on the successful test of Unit 1 depicted in the enclosed test report, SJRPP requests that the Conditions of Certification be modified to burn petroleum coke in Units 1 & 2.


Condition #14 of the Certification states "Coal fired in Units 1 & 2 shall have an ash content not to exceed 18% and a sulfur content not to exceed 4% by weight." Condition #6 of the Letter of Authorization states "The maximum sulfur content of the coal shall not exceed 1.50%, by weight, during the baseline tests and the petroleum coke-coal blend tests. The maximum sulfur content of the petroleum coke shall not exceed 4%, by weight, which is the permitted value of the coal sulfur content at the facility."

SJRO IOC 95 482
September 29, 1995
PETROLEUM COKE/COAL TEST BURN FINAL REPORT
Page 2

The sulfur content of the coal and petroleum coke were below 1.5% and 4.0% respectively during the baseline and blend testing. In order to remain consistent with the Conditions of Certification as well as derive the most beneficial usage of a coal/petroleum coke fuel, SJRPP requests that the Conditions of Certification Condition #14 be modified to reflect that the sulfur content of the coal/petroleum coke blend not exceed 4%.

Please contact Jay Worley at (904)751-7729 if you have any question or require any additional information regarding this report and request for modification.

Sincerely,



Richard Breitmoser
Director Environmental, Health & Safety



RB/JAW/sj

xc: J. Worley (SJRPP)

CERTIFIED MAIL



SJRO LC 95 482

October 2, 1995

Mr. Clair Fancy
Florida Dept. of Environmental Protection
Bureau of Air Regulation
Mail Station 5505
2600 Blirstone Road
Tallahassee, Florida 32399-2400

RE: St. Johns River Power Park Unit 1
Site Certification No. PA 81-13
Petroleum Coke/Coal Test Burn Final Report

Dear Mr. Fancy:

The above referenced facility was authorized by the Florida Department of Environmental Protection's (FDEP) March 30, 1995 letter to test burn a blend of petroleum coke with coal. The test burn was performed August 8 - 19, 1995. Condition #1 of the FDEP authorization letter specifies that a written test report be submitted within 45 days upon completion of the last test run. Please find enclosed the test report with supporting documentation.

The results of the baseline and blend testing indicate that a blend of 80% coal and 20% petroleum coke can be burned successfully at SJRPP. Please note that SJRPP Units 1 and 2 are identical in design and are both required to comply with the limitations set forth in the Conditions of Certification. Based on the successful test of Unit 1 depicted in the enclosed test report, SJRPP requests that the Conditions of Certification be modified to burn petroleum coke in Units 1 & 2.


Condition #14 of the Certification states "Coal fired in Units 1 & 2 shall have an ash content not to exceed 18% and a sulfur content not to exceed 4% by weight." Condition #6 of the Letter of Authorization states "The maximum sulfur content of the coal shall not exceed 1.50%, by weight, during the baseline tests and the petroleum coke-coal blend tests. The maximum sulfur content of the petroleum coke shall not exceed 4%, by weight, which is the permitted value of the coal sulfur content at the facility."

SJRO IOC 95 482
September 29, 1995
PETROLEUM COKE/COAL TEST BURN FINAL REPORT
Page 2


The sulfur content of the coal and petroleum coke were below 1.5% and 4.0% respectively during the baseline and blend testing. In order to remain consistent with the Conditions of Certification as well as derive the most beneficial usage of a coal/petroleum coke fuel, SJRPP requests that the Conditions of Certification Condition #14 be modified to reflect that the sulfur content of the coal/petroleum coke blend not exceed 4%.

Please contact Jay Worley at (904)751-7729 if you have any question or require any additional information regarding this report and request for modification.

Sincerely,



Richard Breitmoser
Director Environmental, Health & Safety



RB/JAW/sj

xc: J. Worley (SJRPP)

CERTIFIED MAIL



SJRO LC 95 484

October 2, 1995

Mr. Steve Pace
RESO
421 West Church Street
Jacksonville, Florida 32202

RE: St. Johns River Power Park Unit 1
Site Certification No. PA 81-13
Petroleum Coke/Coal Test Burn Final Report

Dear Mr. Pace:

The above referenced facility was authorized by the Florida Department of Environmental Protection's (FDEP) March 30, 1995 letter to test burn a blend of petroleum coke with coal. The test burn was performed August 8 - 19, 1995. Condition #1 of the FDEP authorization letter specifies that a written test report be submitted within 45 days upon completion of the last test run. Please find enclosed the test report with supporting documentation.

The results of the baseline and blend testing indicate that a blend of 80% coal and 20% petroleum coke can be burned successfully at SJRPP. Please note that SJRPP Units 1 and 2 are identical in design and are both required to comply with the limitations set forth in the Conditions of Certification. Based on the successful test of Unit 1 depicted in the enclosed test report, SJRPP requests that the Conditions of Certification be modified to burn petroleum coke in Units 1 & 2.


Condition #14 of the Certification states "Coal fired in Units 1 & 2 shall have an ash content not to exceed 18% and a sulfur content not to exceed 4% by weight." Condition #6 of the Letter of Authorization states "The maximum sulfur content of the coal shall not exceed 1.50%, by weight, during the baseline tests and the petroleum coke-coal blend tests. The maximum sulfur content of the petroleum coke shall not exceed 4%, by weight, which is the permitted value of the coal sulfur content at the facility."

SJRO IOC 95 482
September 29, 1995
PETROLEUM COKE/COAL TEST BURN FINAL REPORT
Page 2

The sulfur content of the coal and petroleum coke were below 1.5% and 4.0% respectively during the baseline and blend testing. In order to remain consistent with the Conditions of Certification as well as derive the most beneficial usage of a coal/petroleum coke fuel, SJRPP requests that the Conditions of Certification Condition #14 be modified to reflect that the sulfur content of the coal/petroleum coke blend not exceed 4%.

Please contact Jay Worley at (904)751-7729 if you have any question or require any additional information regarding this report and request for modification.

Sincerely,


Richard Breitmoser
Director Environmental, Health & Safety

RB/JAW/sj

xc: J. Worley (SJRPP)

ST. JOHNS RIVER POWER PARK UNIT 1

PETROLEUM COKE/COAL TEST BURN

BACKGROUND

St. Johns River Power Park (SJRPP) investigated the feasibility of fueling the facility with a blend of bituminous coal and petroleum coke. SJRPP submitted a request to the Florida Department of Environmental Protection (FDEP) on December 20, 1994 to conduct a test burn of petroleum coke/bituminous coal. The FDEP's authorization letter dated March 30, 1995 approved the test burn in accordance with conditions as specified in the letter (Attachment A). The conditions specified notifications and coal baseline and petroleum coke/coal blend operational requirements, data collection and air emissions testing with fuel sampling and analyses. In addition, SJRPP collected in-house unit data to record and review operational performance.

DISCUSSION

The petroleum coke was received at SJRPP on July 15, 1995. FDEP baseline testing was conducted from July 18 - 20, 1995. Baseline testing was delayed due to pulverizer mechanical repairs. Upon repair, the final baseline test was conducted on August 8, 1995.

The petroleum coke/bituminous coal blend was introduced August 9, 1995 to commence the loading process to achieve the steady state operation of an 80% bituminous coal / 20% petroleum coke blend. SJRPP Unit 1 achieved a steady state 80/20 blend on August 11, 1995 in conjunction with the commencement of the FDEP blend testing.

The 80/20 blend was steady state through August 15, 1995. A new blend of approximately 87/13 and 83/17 was introduced on August 16 and 17, 1995, respectively, to assess the on-site bituminous coal supply. On August 18, 1995 an 80/20 blend was returned to the unit for the remainder of the test burn. By the morning of August 20, 1995, the supply of petroleum coke had been completely consumed.

RESULTS - Results of conditions set forth in FDEP's Letter of Authorization.

The following corresponds to the numbered Conditions 1 - 21 of the FDEP's Letter of Authorization (Attachment A).

Condition 1: 1) Please refer to Attachment B for the written notification of commencement. 2) This report submittal and attachments serve as the written test result report which has been submitted within 45 days upon completion of the final test run (8-19-95).


- Condition 2: The petroleum coke - coal blend performance tests were not conducted for more than 21 days. The blend tests commenced August 11, 1995 and were completed August 19, 1995 (9 days). An 80/20 blend steady state operation was established within 2 days of introduction of the blend. No problems were encountered that prevented steady state operation. The petroleum coke was first introduced into SJRPP's Unit 1 on August 9, 1995 and was completely consumed by the morning of August 20, 1995 (11.5 days).
- Condition 3: Please refer to Attachment C.
- Condition 4: Please refer to Attachment C.
- Condition 5: The petroleum coke and coal were fed into the reclaim hoppers located in the SJRPP coal yard (one hopper receiving petroleum coke and the other receiving coal). The belt feeders at the bottom of the hoppers each deliver fuel to the loading conveyor. The belt feeders were scale tested and adjusted prior to the test to operate at 80% and 20% of the conveyor's normal capacity of 1,600 tons/hour. A consistent 80/20 blend was accomplished by having both feeders operating simultaneously during this test.
- Condition 6: Please refer to Attachment D for the baseline coal and petroleum coke as-received analytical results.
- Condition 7: Please refer to Attachment E for the 1)Continuous Emissions Monitoring Systems (CEMS) data, 2)CEMS Quality Assurance data - most recent relative accuracy test audit and cylinder gas/linearity audit and 3)stack test results for particulate matter, carbon monoxide and sulfuric acid mist.
- Condition 8: Please refer to Attachment E for the baseline and blend pollutant emissions results.
- Condition 9: Please refer to Attachment F.
- Condition 10: The test burn was completed within the specified time frame.
- Condition 11: Please refer to Attachment G for the boiler operations and control equipment data.
- Condition 12: Please contact Duval County's R&ESD office.
- Condition 13: Complete documentation shall be kept on file for a minimum of five years.

- Condition 14: There was no release of objectional odors.
- Condition 15: Performance testing was conducted in accordance to these conditions and testing was not required to cease.
- Condition 16: Please refer to the Total Source Analysis, Inc. final baseline and blend test reports in Attachment E for the signature and stamp of the Florida Professional Engineer.
- Condition 17: Please refer to Attachment H.
- Condition 18: Please refer to Attachment I.
- Condition 19: SJRPP Unit 1 was operating at permitted capacity during the emissions testing. Please refer to Attachment G for boiler operational data.
- Condition 20: Please refer to Attachment J.
- Condition 21: Please refer to Attachment A.

CONCLUSIONS

The results of the baseline and blend testing indicate that a blend of 80% coal and 20% petroleum coke can be burned successfully at SJRPP. There was not observed adverse effects on equipment or operational activities. The pollutant emissions testing and CEMS data resulted in no increases above the permitted limitations.

ATTACHMENT A



Department of Environmental Protection

Lawton Chiles
Governor

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Virginia B. Wetherell
Secretary

March 30, 1995

CERTIFIED MAIL - RETURN RECEIPT REQUESTED

Mr. Richard Breitmoser, P.E.
Division Chief
Environmental Affairs Division
St. Johns River Power Park
11201 New Berlin Road
Jacksonville, Florida 32226

Dear Mr. Breitmoser:

Re: Request to Conduct Tests for Pollutant Emissions While Firing a Blend of Petroleum Coke and Bituminous Coal in the St. Johns River Power Park (SJRPP) Unit #1; Site Certification No. PA 81-13; and, Amendment to the Federal Permit No. PSD-FL-010(A)

The Department has reviewed the request that you provided in a letter on December 20, 1994, and supplementary material on February 7, 1995, via the FAX. We have also considered the Department's legal authority to allow SJRPP to conduct the performance tests on Unit #1. Paragraph 403.061(15), Florida Statutes (F.S.), authorizes the Department to consult with any person proposing to construct, install, or otherwise acquire a pollution control device or system concerning the efficacy of such device or system, or the pollution problem which may be related to the source, device, or system. Paragraph 403.061(16), F.S., authorizes the Department to encourage voluntary cooperation by persons in order to achieve the purposes of the state environmental control act. Paragraph 403.061(18), F.S., authorizes the Department to encourage and conduct studies, investigations, and research relating to the causes and control of pollution. Rule 62-210.700(5), Florida Administrative Code (F.A.C.), authorizes the Department to consider variations in industrial equipment and make allowances for excess emissions that provide practical regulatory controls consistent with the public interest.

In accordance with the provisions of Paragraphs 403.061(15), (16), (18), and 403.516(1), F.S., and contingent on 14 days prior public notice and on resolution of any written responses by persons whose substantial interests are negatively affected by your proposal, you are hereby authorized to conduct performance tests for pollutant emissions on SJRPP's Unit #1 while firing a blend

Letter to Authorize a Test Burn Using Petroleum Coke with Coal
St. Johns River Power Park: Unit #1
Site Certification No. PA 81-13/Federal Permit No. PSD-FL-010(A)
March 30, 1995
Page Two

of petroleum coke and bituminous coal. SJRPP's Unit #1 was permitted under Site Certification, No. PA 81-13, and Federal Permit No. PSD-FL-010, and is certified/permitted to fire only coal in accordance with the referenced Site Certification/Federal Permit.

The emissions tests are being proposed in order to gather data regarding pollutant emissions while firing a maximum of 20%, by weight, blend of petroleum coke and bituminous coal. Screening to determine whether this change results in a modification and to determine Prevention of Significant Deterioration (PSD) and/or Nonattainment Area (NAA) applicability shall be in accordance with Chapter 403, F.S.; Chapters 62-209 thru 62-297 and 62-4, F.A.C.; and, Title 40 Code of Federal Regulations (CFR; July 1, 1993 version), which will compare the actual pollutant emissions of the baseline tests (100% coal) with the actual pollutant emissions of the performance tests while firing a blend of petroleum coke and bituminous coal. The performance test results will be reviewed by the Department's Bureau of Air Regulation (BAR) and involved agencies/parties (i.e., Duval County's Regulatory and Environmental Services Department (R&ESD), U.S. EPA, National Park Service, etc.).

The performance tests shall be subject to the following conditions:

1. The permittee shall notify, in writing, the Department's BAR office, the Duval County's R&ESD office, and the Site Certification office at least 15 days prior to commencement of the baseline and the petroleum coke-coal blend performance tests. A written test result report shall be submitted to these offices within 45 days upon completion of the last test run.
2. The petroleum coke-coal blend performance tests shall be conducted for not more than 21 days. Based on the proposed testing protocol (faxed letter dated February 7, 1995, included as an attachment) to establish steady state operation and to achieve a maximum (20%) blend for which the tests shall be conducted, the Department will allow the first 4 days of petroleum coke-coal blend burning to establish these parameters. If, for any reasons, a steady state operation of 20% petroleum coke-coal blend, or less, is not achieved, the testing shall be curtailed. The Department shall be immediately notified of the problems that have prevented steady state operations and what steps will be initiated to correct this. Note that all petroleum coke-coal blend firing counts

Letter to Authorize a Test Burn Using Petroleum Coke with Coal
St. Johns River Power Park: Unit #1
Site Certification No. PA 81-13/Federal Permit No. PSD-FL-010(A)
March 30, 1995
Page Three

against the 21 days of approved time for conducting tests. All testing shall be concluded within 60 days of when petroleum coke is first introduced into SJRPP's Unit #1.

3. As-burned fuel samples shall be collected and analyzed for the sulfur, nitrogen, and metals (see condition No. 4) content throughout the petroleum coke-coal blend and the baseline coal test periods. Weekly composites from daily sampling shall be required; in addition and during the particulate matter test runs, a minimum of three (3) separate samples shall be taken and analyzed.
4. The concentration of chromium, lead, mercury, nickel, beryllium, vanadium, and zinc in the petroleum coke-coal blend shall be compared with the concentration of the same metals in the coal used during the baseline tests.
5. The trial burn of the petroleum coke-coal blends shall be limited to a maximum of 20% petroleum coke, by weight. The maximum weight of the petroleum coke burned during the petroleum coke-coal blend performance tests shall not exceed 100,000 lbs/hr.
6. The maximum sulfur content of the coal shall not exceed 1.50 percent, by weight, during the baseline tests and the petroleum coke-coal blend tests. The maximum sulfur content of the petroleum coke shall not exceed 4 percent, by weight, which is the permitted value of the coal sulfur content at the facility.
7. Sulfur dioxide, nitrogen oxides (NOx), and opacity emissions data shall be recorded using continuous emissions monitors (CEMS) during the baseline and the petroleum coke-coal blend tests. If the plant CEMS are used for these tests, these systems shall be quality assured pursuant to 40 CFR 60, Appendix F requirements. The data assessment report from 40 CFR 60, Appendix F, for the most recent relative accuracy test audit (RATA) and most recent cylinder gas audit (CGA), shall be submitted with the test report. In addition, stack tests shall be conducted for the pollutants particulate matter (PM; assume that all of PM is PM10), carbon monoxide, and sulfuric acid mist. A satisfactory performance test for each baseline test and each petroleum coke-coal blend shall consist of a minimum of three tests at three runs per test.

Letter to Authorize a Test Burn Using Petroleum Coke with Coal
St. Johns River Power Park: Unit #1
Site Certification No. PA 81-13/Federal Permit No. PSD-FL-010(A)
March 30, 1995
Page Four

8. For PSD, NAA, and modification assessment purposes, the actual pollutant emissions results from the petroleum coke-coal blend performance tests shall be compared with the actual pollutant emissions results from the baseline performance tests when firing coal only.
9. Any performance tests shall be conducted using EPA Reference Methods, as contained in 40 CFR 60 (Standards of Performance for New Stationary Sources), 40 CFR Part 61 (National Emission Standards for Hazardous Air Pollutants), and 40 CFR 266, Appendix IX (Multi-metals), or any other method approved by the Department, in writing, in accordance with Chapter 62-297, F.A.C.
10. If additional time is needed, the permittee shall request an extension of time and provide the Department with documentation of the progress accomplished to date and shall identify what is left to be done to complete the performance tests.
11. Daily records (i.e., heat input, steam production, pressure, temperature, MW, fuel input rates, etc.) of boiler operations while firing the petroleum coke-coal blend and while firing only coal (baseline) during the tests shall be required. Also, daily record keeping of the control equipment parameters (i.e., the pH of the scrubbing medium, the mix ratio of the water and medium and the injection rate to the scrubber, the pressure drop across the scrubber, etc.) shall be required and any alteration of the control equipment operational parameters between the baseline and the petroleum coke-coal blend tests shall be documented and summarized in the final report.
12. A Type I or II stack audit may be conducted by the Duval County's R&ESD office.
13. Complete documentation (recording) of any firing of the petroleum coke-coal blend shall be required (i.e., all CEMs records; testing results; materials utilized, by weight; etc.) and kept on file for a minimum of five years.
14. The authorized petroleum coke-coal blend performance tests shall not result in the release of objectionable odors pursuant to Rule 62-296.320(2), F.A.C.

Letter to Authorize a Test Burn Using Petroleum Coke with Coal
St. Johns River Power Park: Unit #1
Site Certification No. PA 81-13/Federal Permit No. PSD-FL-010(A)
March 30, 1995
Page Five

15. Performance testing shall immediately cease if SJRPP's Unit #1 operations are not in accordance with the conditions in the air section of the Site Certification, No. PA 81-13; the Federal Permit, No. PSD-FL-010; and, this authorization protocol. Performance testing shall not resume until appropriate measures to correct the problem(s) have been implemented.
16. The performance tests for pollutant emissions shall be conducted under the direct supervision and responsible charge of a professional engineer registered in Florida.
17. This Department action is only to authorize the performance tests for a petroleum coke-coal blend performance tests, where prior public notice was published in a newspaper of general circulation in the Jacksonville area. Any firing of petroleum coke after the last performance test run is completed will be deemed a violation of the Site Certification, No. PA 81-13, and the Federal Permit, No. PSD-FL-010.
18. The Duval County's R&ESD office shall be notified, in writing, on the date of the last test run completion.
19. The testing series shall include emissions tests for each of the petroleum coke-coal blends and pollutants with the source operating at permitted capacity. Permitted capacity is defined as 90-100 percent of the Site Certification (PA 81-13) and Federal Permit (PSD-FL-010) capacity allowed. If it is impracticable to test at this capacity, then the source may be tested at less than capacity for the petroleum coke-coal blend and the baseline tests, but the tests must be conducted at the same capacity; and, in this case, subsequent source operation with a petroleum coke-coal blend, if requested and approved by the Department, shall be limited to 110 percent of the tested capacity until new tests are conducted, which requires prior Department authorization.
20. Prior written approval of the pollutants to be tested for and the appropriate test methods are mandatory prior to commencement of testing. The proposal shall be submitted to the Site Certification office, the Department's BAR office, and the Duval County's R&ESD office for approval.

Letter to Authorize a Test Burn Using Petroleum Coke with Coal
St. Johns River Power Park: Unit #1
Site Certification No. PA 81-13/Federal Permit No. PSD-FL-010(A)
March 30, 1995
Page Six

21. Attachments to be incorporated:

- o SJRPP's December 20, 1994 letter with Attachment.
- o SJRPP's February 7, 1995 facsimile.

This letter amendment must be attached to the Federal Permit,
No. PSD-FL-010(A) (Site Certification No. PA 81-13), and shall
become a part of the permit.

Sincerely,



Howard L. Rhodes, Director
Division of Air Resources
Management

HLR/sa/t

Enclosure

cc: Buck Oven, DEP
Steve Pace, R&ESD
Jewell Harper, EPA/Region IV
John Bunyak, NPS
Doug Beason, Esq., DEP
Jay Worley, SJRPP

SJRO LC 94 214

December 20, 1994



Mr. Hamilton S. Oven, P.E.
Administrator, Siting Coordination Office
Florida Dept. of Environmental Protection
3900 Commonwealth Blvd.
Tallahassee, FL 32399-3000

RE: Request to Conduct a Test Burn of Petroleum Coke/Bituminous Blend in St. Johns River Power Park's (SJRPP) Unit #1, Site Certification No. PA 81-13 and PSD-FL-010.

Dear Mr. Oven:

Pursuant to your December 13, 1994 telephone conversation with Jay Worley, SJRPP Sr. Environmental Engineer, SJRPP requests to conduct a petroleum coke/bituminous coal mixture test burn commencing February 01, 1995. The test burn is anticipated to be completed by March 03, 1994 in order to inspect operational equipment during the scheduled Unit 1 outage which commences March 04, 1995.

Approximately 10,000 tons of petroleum coke will be mixed with bituminous coal to achieve mixtures up to 20% petroleum coke. Please refer to Attachment A for an example of the analytical data for the type of petroleum coke SJRPP intends to test burn.

Please contact Jay Worley at (904) 751-7729 if you have any questions or require any additional information regarding this request.

Very truly yours,

Richard Breitmoser, P.E.
Division Chief
Environmental Affairs Division

RB/JAW/pct

xc: C. Fancy, FDEP
E. Frey, FDEP
W. Tutt, RESD
J. Worley, SJRPP

American Council of Independent Laboratories
American Society for Testing and Materials
Hampton Roads Maritime Association
National Fire Protection Association
Marine Chemist Association



December 8, 1994

Sample of: TYPICAL 4" X 0 PETROLEUM COKE,
AMOCO - YORKTOWN, VIRGINIA
From: Louisiana Carbon
Date Sampled: Week of December 4, 1994

Quality "As Received"	"As Received" Guaranteed Quality
Heat Content (Btu/lb)	14000 minimum
Hardgrove Grindability	60 minimum
Proximate Analysis (% by weight)	
Volatile Matter	12 - 13.5
Fixed Carbon	75 - 79
Ash	0.75 maximum
Moisture	10 maximum
Ultimate Analysis (% by weight)	
Carbon	89.50 DCB
Hydrogen	4.00 DCB
Sulphur	4.00 As Received
Oxygen	4.25 DCB
Nitrogen	1.45 DCB
Chlorine	<0.01

Respectfully submitted,

by 
Robert F. Lanier



611 HOWMET DRIVE
HAMPTON, VIRGINIA 23661
(804) 826-5310 FAX: (804) 827-1366

Hampton Roads Testing Laboratories, Inc.

December 12, 1994

Sample of: TYPICAL 4" X 0 PETROLEUM COKE,
AMOCO - YORKTOWN, VIRGINIA

From: Louisiana Carbon

Date Sampled: Week of December 4, 1994

PETROLEUM COKE
MINERAL ANALYSIS OF ASH
DRY BASIS

Mineral	Percent
Calcium Oxide	2.4 - 3.0
Magnesium Oxide	0.5 - 1.0
Potassium Oxide	0.4 - 0.9
Iron Oxide	4.0 - 6.0
Sodium Oxide	0.7 - 1.2
Aluminium Oxide	6.5 - 10.0
Silicon Dioxide	16.0 - 22.0
Titanium Dioxide	0.3 - 0.8
Manganese Dioxide	0.04 - 0.09

METAL DETERMINATION
OF PETROLEUM COKE

Vanadium 1400 - 2000 ppm
Nickel 200 - 350 ppm

Respectfully Submitted,


by 
Robert N. Lanier



611 HOWMET DRIVE
HAMPTON, VIRGINIA 23661
(804) 826-5310 FAX: (804) 827-1366

Hampton Roads Testing Laboratories

St. Johns River Power Park PETROLEUM COKE TEST BURN SCHEDULE



LEGEND

—————▶ Represents action following operationally successful test burn

- - - - -▶ Represents action following operationally unsuccessful test burn

Note: Incremental loading of petroleum coke fuel is required to anticipate operational limitations.

ATTACHMENT B

CERTIFIED MAIL

SJRO LC 95 104

June 22, 1995



Mr. Clair Fancy
FDEP
Bureau of Air Regulation
Mail Station 5505
2600 Blirstone Road
Tallahassee, FL 32399-2400

RE: Site Certification No. PA 81-13
St. Johns River Power Park (SJRPP) Unit I
Notification of Test Burn Petroleum Coke-Coal Blend

Dear Mr. Fancy:

The above referenced facility was authorized by the Florida Department of Environmental Protection's March 30, 1995, letter to test burn a blend of petroleum coke with coal. Condition #1 requires that "the permittee shall notify, in writing, the Department's BAR office, the Duval County's RESD office and the Site Certification Office at least 15 days prior to commencement of the baseline and the petroleum coke-coal blend performance tests. In accordance with Condition #1, the tentative date to commence the baseline and petroleum coke-coal blend performance tests is July 11, 1995.

Please contact me at (904) 751-7729 if you have any questions.

Sincerely,


Jay Worley
Environmental & Safety Manager

JAW/pct

CERTIFIED MAIL



SJRO LC 95 120

July 20, 1995

Mr. Clair Fancy
Fla. Dept. of Environmental Protection
Bureau of Air Regulation
Mail Station 5505
2600 Blair Stone Rd.
Tallahassee, FL 32399-2400


RE: Site Certification No. PA 81-13
St. Johns River Power Park (SJRPP) Unit 1
Notification of Petroleum Coke/Coal Test Burn Delay

Dear Mr. Fancy:

The above referenced testing at SJRPP has been delayed due to pulverizer mechanical repairs. The unit loading of petroleum coke is now anticipated to commence August 7, 1995. Please note that the baseline testing was completed July 20, 1995, however, these repairs have become necessary to ensure that the unit will remain available throughout the pet coke testing period.

Please contact me at (904) 751-7729 if you have any questions.

Sincerely,


Jay Worley
Environmental & Safety Manager

JAW/pct

xc: R. Breitmoser

ATTACHMENT C

SJRPP UNIT 1
 TEST BURN
 PETROLEUM COKE/BITUMINOUS COAL
 ANALYTICAL RESULTS

A) BASELINE - COMPOSITE - 7/18, 7/19, 7/20, 8/8 - (Analyses in ug/g)

DATE	S	N	Cr	Pb	Hg	Ni	Be	V	Zn
BASELINE COMPOSITE	0.86	1.59	10	7	0.06	3	0.7	21	13

B) DAILY - BASELINE - (Analyses in ug/g)

DATE	S	N	Cr	Pb	Hg	Ni	Be	V	Zn
7/18	0.61	1.58	8	3	0.07	1	0.3	16	10
7/18	0.62	1.59	7	3	0.06	1	0.3	15	10
7/18	0.65	1.54	8	3	0.05	1	0.3	17	12
7/19	0.85	1.56	11	6	0.09	6	0.7	21	14
7/19	0.86	1.54	11	2	0.07	6	0.8	22	15
7/19	0.85	1.54	11	3	0.06	3	0.7	22	16
7/20	1.24	1.46	15	5	0.09	13	2.1	32	17
7/20	1.22	1.61	14	7	0.15	12	2.0	32	18
7/20	1.26	1.61	15	7	0.11	12	2.1	35	17
8/8	0.77	1.59	8	3	0.04	<1	0.3	18	12
8/8	0.72	1.58	8	5	0.03	1	0.3	17	10
8/8	0.72	1.55	8	3	0.04	1	0.3	18	11

SJRPP UNIT 1
TEST BURN
PETROLEUM COKE/BITUMINOUS COAL
ANALYTICAL RESULTS

A) BLEND A - COMPOSITE - 8/9, 8/10, 8/11, 8/12, 8/13 (Analyses in ug/g)

DATE	S	N	Cr	Pb	Hg	Ni	Be	V	Zn
COMPOSITE BLEND A	1.05	1.42	8	3	0.05	33	0.5	220	12

B) BLEND B - COMPOSITE - 8/14, 8/15, 8/16, 8/17, 8/18, 8/19 (Analyses in ug/g)

DATE	S	N	Cr	Pb	Hg	Ni	Be	V	Zn
COMPOSITE BLEND B	1.62	1.50	12	7	0.05	62	1.3	400	18

SJRPP UNIT 1
TEST BURN
PETROLEUM COKE/BITUMINOUS COAL
ANALYTICAL RESULTS

A) DAILY BLEND - (Analyses in ug/g)

DATE	S	N	Cr	Pb	Hg	Ni	Be	V	Zn
8/14	1.34	1.52	7	3	0.06	57	0.7	380	13
8/14	1.44	1.55	7	4	0.03	73	1.2	500	13
8/14	1.31	1.53	8	4	0.06	50	1.0	350	14
8/15	1.48	1.53	6	3	0.04	77	1.1	500	11
8/15	1.32	1.51	7	3	0.05	58	1.0	380	12
8/15	1.33	1.53	8	3	0.05	54	1.2	360	15
8/16	1.40	1.53	7	4	0.07	60	1.0	390	14
8/16	1.40	1.53	7	3	0.03	61	1.2	390	13
8/16	1.32	1.45	7	<2	0.05	58	0.9	380	13
8/17	1.33	1.34	7	<2	0.04	54	1.0	360	13
8/17	1.94	1.56	11	9	0.07	65	1.7	430	16
8/17	1.49	1.43	24	11	0.04	58	2.0	330	25
8/18	1.77	1.50	18	11	0.07	71	2.0	460	23
8/18	1.72	1.51	17	10	0.08	65	2.1	380	20
8/18	1.86	1.46	15	11	0.08	68	2.0	420	21
8/19	1.89	1.49	15	11	0.09	68	1.8	420	22

Best Available Copy

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • (312) 953-9300

Member of the SGS Group (Société Générale de Surveillance)

September 1, 1995

PLEASE ADDRESS ALL CORRESPONDENCE
P.O. BOX 752, HENDERSON, KY
TELEPHONE: (502) 827-
FAX: (502) 826-

ST. JOHNS RIVER POWER PARK
11201 NEW BERLIN RD
JACKSONVILLE FL 32226

Sample identification by
SJRPP

Kind of sample Coal
reported to us

60 Mesh Split
Sample #0928 Comp-A
7/18, 7/19, 7/20, 8/8
P.O. #002363

Sample taken at -----

7.31% A.D.L. Provided by Client

Sample taken by -----

BURN DATE
Date sampled July 18,19,20, 1995

August 8, 1995

Date received August 22, 1995

Analysis report no. 63-90708

<u>Parameter</u>	<u>Results</u>
Beryllium, Be	0.7
Chromium, Cr	10
Lead, Pb	7
Mercury, Hg	0.06
Nickel, Ni	3
Vanadium, V	21
Zinc, Zn	13
Sulfur, S	0.86
Nitrogen, N	1.59

Procedure: The samples were prepared according to ASTM, Part 5.05, Method D 3683. The samples were analyzed for trace elements by Inductively Coupled Plasma Emission Spectroscopy.

Mercury per ASTM, Part 5.05, Method D 3684, Double Gold Amalgamation Cold Vapor Atomic Absorption.

Sulfur per ASTM, Part 5.05, Method D 4239 (method C).
Nitrogen per ASTM, Part 5.05, Method D 5373-93.

Results: Results are reported as micrograms per gram (ug/g), except for Nitrogen and Sulfur, which are reported in weight percent (Wt.%), all on a dry basis.

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

Manager, Henderson Laboratory

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • (312) 953-9300



SINCE 1900

Member of the SGS Group (Société Générale de Surveillance)

September 1, 1995

PLEASE ADDRESS ALL CORRESPONDENCE TO:
P.O. BOX 752, HENDERSON, KY 42420
TELEPHONE: (502) 827-1187
FAX: (502) 826-0719

ST. JOHNS RIVER POWER PARK
11201 NEW BERLIN RD
JACKSONVILLE FL 32226

Sample identification by
SJRPP

60 Mesh Split
Sample #0913A
P.O. #002363

8.81% A.D.L. Provided by Client

Kind of sample Coal
reported to us

Sample taken at -----

Sample taken by -----

^{BURN DATE}
Date sampled July 18, 1995

Date received August 22, 1995

Analysis report no. 63-90696

<u>Parameter</u>	<u>Results</u>
Beryllium, Be	0.3
Chromium, Cr	8
Lead, Pb	3
Mercury, Hg	0.07
Nickel, Ni	1
Vanadium, V	16
Zinc, Zn	10
Sulfur, S	0.61
Nitrogen, N	1.58

Procedure: The samples were prepared according to ASTM, Part 5.05, Method D 3683. The samples were analyzed for trace elements by Inductively Coupled Plasma Emission Spectroscopy.

Mercury per ASTM, Part 5.05, Method D 3684, Double Gold Amalgamation Cold Vapor Atomic Absorption.

Sulfur per ASTM, Part 5.05, Method D 4239 (method C).

Nitrogen per ASTM, Part 5.05, Method D 5373-93.

Results: Results are reported as micrograms per gram (ug/g), except for Nitrogen and Sulfur, which are reported in weight percent (Wt.%), all on a dry basis.

Respectfully submitted,
[Signature]
COMMERCIAL TESTING & ENGINEERING CO.

Manager, Henderson Laboratory

OVER 40 BRANCH LABORATORIES STRATEGICALLY LOCATED IN COAL MINING AREAS,
TIDEWATER AND GREAT LAKES PORTS & FACILITIES

Original Copy Watermarked

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • (312) 953-9300

Member of the SGS Group (Société Générale de Surveillance)

PLEASE ADDRESS ALL CORRESPONDENCE TO:
P.O. BOX 752, HENDERSON, KY 42420
TELEPHONE: (502) 827-1187
FAX: (502) 826-0719

September 1, 1995

ST. JOHNS RIVER POWER PARK
11201 NEW BERLIN RD
JACKSONVILLE FL 32226Sample identification by
SJRPP60 Mesh Split
Sample #0914B
P.O. #002363

8.81% A.D.L. Provided by Client.

Kind of sample Coal
reported to us

Sample taken at -----

Sample taken by -----

Date ^{BURN DATE} sampled July 18, 1995

Date received August 22, 1995

Analysis report no. 63-90697

<u>Parameter</u>	<u>Results</u>
Beryllium, Be	0.3
Chromium, Cr	7
Lead, Pb	3
Mercury, Hg	0.06
Nickel, Ni	1
Vanadium, V	15
Zinc, Zn	10
Sulfur, S	0.62
Nitrogen, N	1.59

Procedure: The samples were prepared according to ASTM, Part 5.05, Method D 3683. The samples were analyzed for trace elements by Inductively Coupled Plasma Emission Spectroscopy.

Mercury per ASTM, Part 5.05, Method D 3684, Double Gold Amalgamation Cold Vapor Atomic Absorption.

Sulfur per ASTM, Part 5.05, Method D 4239 (method C).
Nitrogen per ASTM, Part 5.05, Method D 5373-93.

Results: Results are reported as micrograms per gram (ug/g), except for Nitrogen and Sulfur, which are reported in weight percent (Wt.%), all on a dry basis.

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • (312) 953-9300



SMCC 1908

Member of the SGS Group (Société Générale de Surveillance)

PLEASE ADDRESS ALL CORRESPONDENCE TO:
P.O. BOX 752, HENDERSON, KY 42420
TELEPHONE: (502) 827-1187
FAX: (502) 828-0719

September 1, 1995

ST. JOHNS RIVER POWER PARK
11201 NEW BERLIN RD
JACKSONVILLE FL 32226

Sample identification by
SJRPP

60 Mesh Split
Sample #0915C
P.O. #002363

8.81% A.D.L. Provided by Client

Kind of sample reported to us Coal

Sample taken at -----

Sample taken by -----

^{BURN DATE}
Date sampled July 18, 1995

Date received August 22, 1995

Analysis report no. 63-90698

<u>Parameter</u>	<u>Results</u>
Beryllium, Be	0.3
Chromium, Cr	8
Lead, Pb	3
Mercury, Hg	0.05
Nickel, Ni	1
Vanadium, V	17
Zinc, Zn	12
Sulfur, S	0.65
Nitrogen, N	1.54

Procedure: The samples were prepared according to ASTM, Part 5.05, Method D 3683. The samples were analyzed for trace elements by Inductively Coupled Plasma Emission Spectroscopy.

Mercury per ASTM, Part 5.05, Method D 3684, Double Gold Amalgamation Cold Vapor Atomic Absorption.

Sulfur per ASTM, Part 5.05, Method D 4239 (method C).

Nitrogen per ASTM, Part 5.05, Method D 5373-93.

Results: Results are reported as micrograms per gram (ug/g), except for Nitrogen and Sulfur, which are reported in weight percent (Wt.%), all on a dry basis.

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

Manager, Henderson, KY

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • (312) 853-8300

SINCE 1908

Member of the SGS Group (Société Générale de Surveillance)

September 1, 1995

PLEASE ADDRESS ALL CORRESPONDENCE TO:
P.O. BOX 752, HENDERSON, KY 42420
TELEPHONE: (502) 827-1187
FAX: (502) 826-0719

ST. JOHNS RIVER POWER PARK
11201 NEW BERLIN RD
JACKSONVILLE FL 32226

Sample identification by
SJRPP

60 Mesh Split
Sample #0918D
P.O. #002363

8.70% A.D.L. Provided by Client

Kind of sample Coal
reported to us

Sample taken at -----

Sample taken by -----

Date sampled July 19, 1995

Date received August 22, 1995

Analysis report no. 63-90699

<u>Parameter</u>	<u>Results</u>
Beryllium, Be	0.7
Chromium, Cr	11
Lead, Pb	6
Mercury, Hg	0.09
Nickel, Ni	6
Vanadium, V	21
Zinc, Zn	14
Sulfur, S	0.85
Nitrogen, N	1.56

Procedure: The samples were prepared according to ASTM, Part 5.05, Method D 3683. The samples were analyzed for trace elements by Inductively Coupled Plasma Emission Spectroscopy.

Mercury per ASTM, Part 5.05, Method D 3684, Double Gold Amalgamation Cold Vapor Atomic Absorption.

Sulfur per ASTM, Part 5.05, Method D 4239 (method C).
Nitrogen per ASTM, Part 5.05, Method D 5373-93.

Results: Results are reported as micrograms per gram (ug/g), except for Nitrogen and Sulfur, which are reported in weight percent (Wt.%), all on a dry basis.

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

Manager, Henderson Laboratory

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • (312) 953-9300

Member of the SGS Group (Société Générale de Surveillance)

PLEASE ADDRESS ALL CORRESPONDENCE TO:
P.O. BOX 752, HENDERSON, KY 42420
TELEPHONE: (502) 827-1187
FAX: (502) 826-0719

September 1, 1995

ST. JOHNS RIVER POWER PARK
11201 NEW BERLIN RD
JACKSONVILLE FL 32226

Sample identification by
SJRPP

60 Mesh Split
Sample #0919E
P.O. #002363

8.70% A.D.L. Provided by Client

Kind of sample Coal
reported to us

Sample taken at -----

Sample taken by -----

Date ~~sampled~~ July 19, 1995

Date received August 22, 1995

Analysis report no. 63-90700

<u>Parameter</u>	<u>Results</u>
Beryllium, Be	0.8
Chromium, Cr	11
Lead, Pb	2
Mercury, Hg	0.07
Nickel, Ni	6
Vanadium, V	22
Zinc, Zn	15
Sulfur, S	0.86
Nitrogen, N	1.54

Procedure: The samples were prepared according to ASTM, Part 5.05, Method D 3683. The samples were analyzed for trace elements by Inductively Coupled Plasma Emission Spectroscopy.

Mercury per ASTM, Part 5.05, Method D 3684, Double Gold Amalgamation Cold Vapor Atomic Absorption.

Sulfur per ASTM, Part 5.05, Method D 4239 (method C).
Nitrogen per ASTM, Part 5.05, Method D 5373-93.

Results: Results are reported as micrograms per gram (ug/g), except for Nitrogen and Sulfur, which are reported in weight percent (Wt.%), all on a dry basis.

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

Richard D. Howard
Manager, Henderson Laboratory

OVER 40 BRANCH LABORATORIES STRATEGICALLY LOCATED IN PRINCIPAL COAL MINING AREAS,
TIDEWATER AND GREAT LAKES PORTS, AND RIVER LOADING FACILITIES

Original Copy Watermarked For Your Protection

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • (312) 953-9300

SWCF 1900

Member of the SGS Group (Société Générale de Surveillance)

September 1, 1995

PLEASE ADDRESS ALL CORRESPONDENCE TO:
P.O. BOX 752, HENDERSON, KY 42420
TELEPHONE: (502) 827-1187
FAX: (502) 826-0719

ST. JOHNS RIVER POWER PARK
11201 NEW BERLIN RD
JACKSONVILLE FL 32226

Sample identification by
SJRPP

60 Mesh Split
Sample #0920F
P.O. #002363

8.70% A.D.L. Provided by Client

Kind of sample Coal
reported to us

Sample taken at -----

Sample taken by -----

DATE Date ~~sampled~~ July 19, 1995

Date received August 22, 1995

Analysis report no. 63-90701

<u>Parameter</u>	<u>Results</u>
Beryllium, Be	0.7
Chromium, Cr	11
Lead, Pb	3
Mercury, Hg	0.06
Nickel, Ni	3
Vanadium, V	22
Zinc, Zn	16
Sulfur, S	0.35
Nitrogen, N	1.54


Procedure: The samples were prepared according to ASTM, Part 5.05, Method D 3683. The samples were analyzed for trace elements by Inductively Coupled Plasma Emission Spectroscopy.

Mercury per ASTM, Part 5.05, Method D 3684, Double Gold Amalgamation Cold Vapor Atomic Absorption.

Sulfur per ASTM, Part 5.05, Method D 4239 (method C).
Nitrogen per ASTM, Part 5.05, Method D 5373-93.

Results: Results are reported as micrograms per gram (ug/g), except for Nitrogen and Sulfur, which are reported in weight percent (Wt.%), all on a dry basis.

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.



Manager, Henderson Laboratory

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • (312) 853-9300

Member of the SGS Group (Société Générale de Surveillance)

September 1, 1995

PLEASE ADDRESS ALL CORRESPONDENCE TO:
P.O. BOX 752, HENDERSON, KY 42420
TELEPHONE: (502) 827-1187
FAX: (502) 828-0719

ST. JOHNS RIVER POWER PARK
11201 NEW BERLIN RD
JACKSONVILLE FL 32226

Sample identification by
SJRPP

60 Mesh Split
Sample #0923G
P.O. #002363

Kind of sample Coal
reported to us

4.00% A.D.L. Provided by Client

Sample taken at -----

Sample taken by -----

Date ~~sampled~~ July 20, 1995

Date received August 22, 1995

Analysis report no. 63-90702

<u>Parameter</u>	<u>Results</u>
Beryllium, Be	2.1
Chromium, Cr	15
Lead, Pb	5
Mercury, Hg	0.09
Nickel, Ni	13
Vanadium, V	32
Zinc, Zn	17
Sulfur, S	1.24
Nitrogen, N	1.46


Procedure: The samples were prepared according to ASTM, Part 5.05, Method D 3683. The samples were analyzed for trace elements by Inductively Coupled Plasma Emission Spectroscopy.

Mercury per ASTM, Part 5.05, Method D 3684, Double Gold Amalgamation Cold Vapor Atomic Absorption.

Sulfur per ASTM, Part 5.05, Method D 4239 (method C).
Nitrogen per ASTM, Part 5.05, Method D 5373-93.

Results: Results are reported as micrograms per gram (ug/g), except for Nitrogen and Sulfur, which are reported in weight percent (Wt.%), all on a dry basis.

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.



Manager, Henderson Laboratory

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • (312) 953-9300

Member of the SGS Group (Société Générale de Surveillance)

September 1, 1995

PLEASE ADDRESS ALL CORRESPONDENCE TO:
P.O. BOX 752, HENDERSON, KY 42420
TELEPHONE: (502) 827-1187
FAX: (502) 826-0719

ST. JOHNS RIVER POWER PARK
11201 NEW BERLIN RD
JACKSONVILLE FL 32226

Sample identification by
SJRPP

60 Mesh Split
Sample #0924H
P.O. #002363

4.00% A.D.L. Provided by Client

Kind of sample Coal
reported to us

Sample taken at -----

Sample taken by -----

Date ~~sampled~~ July 20, 1995

Date received August 22, 1995

Analysis report no. 63-90703

<u>Parameter</u>	<u>Results</u>
Beryllium, Be	2.0
Chromium, Cr	14
Lead, Pb	7
Mercury, Hg	0.15
Nickel, Ni	12
Vanadium, V	32
Zinc, Zn	18
Sulfur, S	1.22
Nitrogen, N	1.61

Procedure: The samples were prepared according to ASTM, Part 5.05, Method D 3683. The samples were analyzed for trace elements by Inductively Coupled Plasma Emission Spectroscopy.

Mercury per ASTM, Part 5.05, Method D 3684, Double Gold Amalgamation Cold Vapor Atomic Absorption.

Sulfur per ASTM, Part 5.05, Method D 4239 (method C).

Nitrogen per ASTM, Part 5.05, Method D 5373-93.

Results: Results are reported as micrograms per gram (ug/g), except for Nitrogen and Sulfur, which are reported in weight percent (Wt.%), all on a dry basis.

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

Rafael A. Hernandez
Manager, Henderson Laboratory



Laboratory Report No. 312917 Date of Report July 14, 1995

CERTIFICATE OF ANALYSIS

Sample of: PETROLEUM COKE - LOT 2
Mark: Representing a 48 car sample of PET COKE,
 car top sampled at the Yorktown Refinery
From: Louisiana Carbon/Amoco
Date Sampled: July 12, 1995
Sampled By: Hampton Roads Testing Labs., Inc.

**PROXIMATE ANALYSIS
 As Received Dry Basis**

Moisture	5.45	
Volatile Matter	14.31	15.13
Fixed Carbon	79.89	84.50
Ash	0.35	0.37
Total (100%)	100.00	100.00
Sulphur	3.04	3.22
B.T.U./Lb.	14811	15665
Calories/Gram	8228	8703

MOISTURE/ASH FREE B.T.U. 15723

Hampton Roads Testing Laboratories, Inc.

By

[Signature]
 Chemist

JUL-14-1995 15:05 FROM HAMPTON ROADS TESTING TO LACARBON-LARSON P.03

OXDOW-SURVEY SITE OFFICE # 4/4
 7-14-95 2:44PM
 SEVI BT

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • (312) 953-9300

Member of the SGS Group (Société Générale de Surveillance)

September 7, 1995

PLEASE ADDRESS ALL CORRESPONDENCE
P.O. BOX 752, HENDERSON, KY 42420
TELEPHONE: (502) 827-1111
FAX: (502) 826-0111

ST. JOHNS RIVER POWER PARK
11201 NEW BERLIN RD
JACKSONVILLE FL 32226

Sample identification by
SJRPP

60 Mesh Split
Sample #09251
P.O. #002363

Kind of sample Coal
reported to us

4.00% A.D.L. Provided by Client

Sample taken at -----

Corrected analysis

Sample taken by -----

Date sampled July 20, 1995

Date received August 22, 1995

Analysis report no. 63-90704

Parameter	Results
Beryllium, Be	2.1
Chromium, Cr	15
Lead, Pb	7
Mercury, Hg	0.11
Nickel, Ni	12
Vanadium, V	35
Zinc, Zn	17
Sulfur, S	1.26
Nitrogen, N	1.61

Procedure: The samples were prepared according to ASTM, Part 5.05, Method D 3683. The samples were analyzed for trace elements by Inductively Coupled Plasma Emission Spectroscopy.

Mercury per ASTM, Part 5.05, Method D 3684, Double Gold Amalgamation Cold Vapor Atomic Absorption.

Sulfur per ASTM, Part 5.05, Method D 4239 (method C).
Nitrogen per ASTM, Part 5.05, Method D 5373-93.

Results: Results are reported as micrograms per gram (ug/g), except for Nitrogen and Sulfur, which are reported in weight percent (Wt.%), all on a dry basis.

Richard A. Henderson
COMMERCIAL TESTING & ENGINEERING CO. RR

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • (312) 953-9300

SINCE 1908

Member of the SGS Group (Société Générale de Surveillance)

September 1, 1995

PLEASE ADDRESS ALL CORRESPONDENCE
P.O. BOX 752, HENDERSON, KY 4
TELEPHONE: (502) 827
FAX: (502) 826ST. JOHNS RIVER POWER PARK
11201 NEW BERLIN RD
JACKSONVILLE FL 32226Sample identification by
SJRPP60 Mesh Split
Sample #0929J
P.O. #002363Kind of sample Coal
reported to us

7.74% A.D.L. Provided by Client

Sample taken at -----

Sample taken by -----

Date ~~August 8, 1995~~ August 8, 1995

Date received August 22, 1995

Analysis report no. 63-90705

<u>Parameter</u>	<u>Results</u>
Beryllium, Be	0.3
Chromium, Cr	8
Lead, Pb	3
Mercury, Hg	0.04
Nickel, Ni	<1
Vanadium, V	18
Zinc, Zn	12
Sulfur, S	0.77
Nitrogen, N	1.59

Procedure: The samples were prepared according to ASTM, Part 5.05, Method D 3683. The samples were analyzed for trace elements by Inductively Coupled Plasma Emission Spectroscopy.

Mercury per ASTM, Part 5.05, Method D 3684, Double Gold Amalgamation Cold Vapor Atomic Absorption.

Sulfur per ASTM, Part 5.05, Method D 4239 (method C).
Nitrogen per ASTM, Part 5.05, Method D 5373-93.

Results: Results are reported as micrograms per gram (ug/g), except for Nitrogen and Sulfur, which are reported in weight percent (Wt.%), all on a dry basis.

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

 Manager, Henderson Laboratory



COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • (312) 953-9300

Member of the SGS Group (Société Générale de Surveillance)

September 1, 1995

PLEASE ADDRESS ALL CORRESPONDENCE
P.O. BOX 752, HENDERSON, KY 42420
TELEPHONE: (502) 827-1111
FAX: (502) 826-0000

ST. JOHNS RIVER POWER PARK
11201 NEW BERLIN RD
JACKSONVILLE FL 32226

Sample identification by
SJRPP

60 Mesh Split
Sample #0930K
P.O. #002363

Kind of sample Coal
reported to us

7.74% A.D.L. Provided by Client

Sample taken at -----

Sample taken by -----

BURN Date ~~sampled~~ August 8, 1995

Date received August 22, 1995

Analysis report no. 63-90706

<u>Parameter</u>	<u>Results</u>
Beryllium, Be	0.3
Chromium, Cr	8
Lead, Pb	5
Mercury, Hg	0.03
Nickel, Ni	1
Vanadium, V	17
Zinc, Zn	10
Sulfur, S	0.72
Nitrogen, N	1.58

Procedure: The samples were prepared according to ASTM, Part 5.05, Method D 3683. The samples were analyzed for trace elements by Inductively Coupled Plasma Emission Spectroscopy.

Mercury per ASTM, Part 5.05, Method D 3684, Double Gold Amalgamation Cold Vapor Atomic Absorption.

Sulfur per ASTM, Part 5.05, Method D 4239 (method C).

Nitrogen per ASTM, Part 5.05, Method D 5373-93.

Results: Results are reported as micrograms per gram (ug/g), except for Nitrogen and Sulfur, which are reported in weight percent (Wt.%), all on a dry basis.

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

Manager, Henderson Laboratory



COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • (312) 953-9300

Member of the SGS Group (Société Générale de Surveillance)

September 1, 1995

PLEASE ADDRESS ALL CORRESPONDENCE
P.O. BOX 752, HENDERSON, KY 4
TELEPHONE: (502) 827-
FAX: (502) 828-

ST. JOHNS RIVER POWER PARK
11201 NEW BERLIN RD
JACKSONVILLE FL 32226

Sample identification by
SJRPP

60 Mesh Split
Sample #0931L
P.O. #002363

7.74% A.D.L. Provided by Client

Kind of sample Coal
reported to us

Sample taken at -----

Sample taken by -----

BURN Date ~~sampled~~ August 8, 1995

Date received August 22, 1995

Analysis report no. 63-90707

Parameter	Results
Beryllium, Be	0.3
Chromium, Cr	8
Lead, Pb	3
Mercury, Hg	0.04
Nickel, Ni	1
Vanadium, V	18
Zinc, Zn	11
Sulfur, S	0.72
Nitrogen, N	1.55

Procedure: The samples were prepared according to ASTM, Part 5.05, Method D 3683. The samples were analyzed for trace elements by Inductively Coupled Plasma Emission Spectroscopy.

Mercury per ASTM, Part 5.05, Method D 3684, Double Gold Amalgamation Cold Vapor Atomic Absorption.

Sulfur per ASTM, Part 5.05, Method D 4239 (method C).
Nitrogen per ASTM, Part 5.05, Method D 5373-93.

Results: Results are reported as micrograms per gram (ug/g), except for Nitrogen and Sulfur, which are reported in weight percent (Wt.%), all on a dry basis.

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.
[Signature]

Manager, Henderson Laboratory

BEST AVAILABLE COPY

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1819 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • (312) 953-9300

SINCE 1908

Member of the SGS Group (Société Générale de Surveillance)

September 11, 1995

PLEASE ADDRESS ALL CORRESPONDENCE
P.O. BOX 752, HENDERSON, KY 42420
TELEPHONE: (502) 827-1111
FAX: (502) 826-0000ST. JOHNS RIVER POWER PARK
11201 NEW BERLIN RD
JACKSONVILLE FL 32226Sample identification by
SJRPPSample #0939M
P.O. #008306

Kind of sample reported to us Coal

6.92% A.D.L. Provided by Client

Sample taken at -----

Sample taken by -----

Date sampled August 14, 1995

Date received August 25, 1995

Analysis report no. 63-90988


<u>Parameter</u>	<u>Results</u>
Beryllium, Be	0.7
Chromium, Cr	7
Lead, Pb	3
Mercury, Hg	0.06
Nickel, Ni	57
Vanadium, V	380
Zinc, Zn	13
Sulfur, S	1.34
Nitrogen, N	1.52

Procedure: The samples were prepared according to ASTM, Part 5.05, Method D 3683. The samples were analyzed for trace elements by Inductively Coupled Plasma Emission Spectroscopy.

Mercury per ASTM, Part 5.05, Method D 3684, Double Gold Amalgamation Cold Vapor Atomic Absorption.

Sulfur per ASTM, Part 5.05, Method D 4239 (method C).
Nitrogen per ASTM, Part 5.05, Method D 5373-93.

Results: Results are reported as micrograms per gram (ug/g), except for Nitrogen and Sulfur, which are reported in weight percent (Wt.%), all on a dry basis.

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.


Manager, Henderson Laboratory

BEST AVAILABLE COPY

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1010 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • (312) 953-9300

Member of the SGS Group (Société Générale de Surveillance)

September 11, 1995

PLEASE ADDRESS ALL CORRESPONDENCE TO
P.O. BOX 752, HENDERSON, KY 424
TELEPHONE: (502) 827-11
FAX: (502) 826-07ST. JOHNS RIVER POWER PARK
11201 NEW BERLIN RD
JACKSONVILLE FL 32226Sample identification by
SJRPPSample #0940N
P.O. #008306Kind of sample Coal
reported to us

4.74% A.D.L. Provided by Client

Sample taken at -----

Sample taken by -----

Date sampled August 14, 1995

Date received August 25, 1995

Analysis report no. 63-90989

<u>Parameter</u>	<u>Results</u>
Beryllium, Be	1.2
Chromium, Cr	7
Lead, Pb	4
Mercury, Hg	0.03
Nickel, Ni	73
Vanadium, V	500
Zinc, Zn	13
Sulfur, S	1.44
Nitrogen, N	1.55

Procedure: The samples were prepared according to ASTM, Part 5.05, Method D 3683. The samples were analyzed for trace elements by Inductively Coupled Plasma Emission Spectroscopy.

Mercury per ASTM, Part 5.05, Method D 3684, Double Gold Amalgamation Cold Vapor Atomic Absorption.

Sulfur per ASTM, Part 5.05, Method D 4239 (method C).

Nitrogen per ASTM, Part 5.05, Method D 5373-93.

Results: Results are reported as micrograms per gram (ug/g), except for Nitrogen and Sulfur, which are reported in weight percent (Wt.%), all on a dry basis.

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO


Manager, Henderson Laboratory

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1818 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • (312) 953-9300

Member of the SGS Group (Société Générale de Surveillance)

September 11, 1995

PLEASE ADDRESS ALL CORRESPONDENCE TO
P.O. BOX 752, HENDERSON, KY 424
TELEPHONE: (502) 827-1111
FAX: (502) 826-0707

ST. JOHNS RIVER POWER PARK
11201 NEW BERLIN RD
JACKSONVILLE FL 32226

Sample identification by
SJRPP

Sample #09410
P.O. #008306

Kind of sample Coal
reported to us

7.51% A.D.L. Provided by Client

Sample taken at -----

Sample taken by -----

Date sampled August 14, 1995

Date received August 25, 1995

Analysis report no. 63-90990

Parameter	Results
Beryllium, Be	1.0
Chromium, Cr	8
Lead, Pb	4
Mercury, Hg	0.06
Nickel, Ni	50
Vanadium, V	350
Zinc, Zn	14
Sulfur, S	1.31
Nitrogen, N	1.53

Procedure: The samples were prepared according to ASTM, Part 5.05, Method D 3683. The samples were analyzed for trace elements by Inductively Coupled Plasma Emission Spectroscopy.

Mercury per ASTM, Part 5.05, Method D 3684, Double Gold Amalgamation Cold Vapor Atomic Absorption.

Sulfur per ASTM, Part 5.05, Method D 4239 (method C).
Nitrogen per ASTM, Part 5.05, Method D 5373-93.

Results: Results are reported as micrograms per gram (ug/g), except for Nitrogen and Sulfur, which are reported in weight percent (Wt.%), all on a dry basis.

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

Manager, Henderson Laboratory


COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • (312) 953-9300

Member of the SGS Group (Société Générale de Surveillance)

September 11, 1995

PLEASE ADDRESS ALL CORRESPONDENCE TO
P.O. BOX 752, HENDERSON, KY 424
TELEPHONE: (502) 827-11
FAX: (502) 826-07

ST. JOHNS RIVER POWER PARK
11201 NEW BERLIN RD
JACKSONVILLE FL 32226

Sample identification by
SJRPP

Sample #0943P
P.O. #008306

Kind of sample Coal
reported to us

4.71% A.D.L. Provided by Client

Sample taken at -----

Sample taken by -----

Date sampled August 15, 1995

Date received August 25, 1995

Analysis report no. 63-90991

<u>Parameter</u>	<u>Results</u>
Beryllium, Be	1.1
Chromium, Cr	6
Lead, Pb	3
Mercury, Hg	0.04
Nickel, Ni	77
Vanadium, V	500
Zinc, Zn	11
Sulfur, S	1.48
Nitrogen, N	1.53

Procedure: The samples were prepared according to ASTM, Part 5.05, Method D 3683. The samples were analyzed for trace elements by Inductively Coupled Plasma Emission Spectroscopy.

Mercury per ASTM, Part 5.05, Method D 3684, Double Gold Amalgamation Cold Vapor Atomic Absorption.

Sulfur per ASTM, Part 5.05, Method D 4239 (method C).
Nitrogen per ASTM, Part 5.05, Method D 5373-93.

Results: Results are reported as micrograms per gram (ug/g), except for Nitrogen and Sulfur, which are reported in weight percent (Wt.%), all on a dry basis.

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO

Richard L. Henderson
Manager, Henderson Laboratory

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1918 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • (312) 953-9300

Member of the SGS Group (Société Générale de Surveillance)

September 11, 1995

PLEASE ADDRESS ALL CORRESPONDENCE TO
P.O. BOX 752, HENDERSON, KY 424
TELEPHONE: (502) 827-11
FAX: (502) 826-07

ST. JOHNS RIVER POWER PARK
11201 NEW BERLIN RD
JACKSONVILLE FL 32226

Sample identification by
SJRPP

Sample #0944Q
P.O. #008306

Kind of sample Coal
reported to us

6.91% A.D.L. Provided by Client

Sample taken at -----

Sample taken by -----

Date sampled August 15, 1995

Date received August 25, 1995

Analysis report no. 63-90992

Parameter	Results
Beryllium, Be	1.0
Chromium, Cr	7
Lead, Pb	3
Mercury, Hg	0.05
Nickel, Ni	58
Vanadium, V	380
Zinc, Zn	12
Sulfur, S	1.32
Nitrogen, N	1.51

Procedure: The samples were prepared according to ASTM, Part 5.05, Method D 3683. The samples were analyzed for trace elements by Inductively Coupled Plasma Emission Spectroscopy.

Mercury per ASTM, Part 5.05, Method D 3684, Double Gold Amalgamation Cold Vapor Atomic Absorption.

Sulfur per ASTM, Part 5.05, Method D 4239 (method C).
Nitrogen per ASTM, Part 5.05, Method D 5373-93.

Results: Results are reported as micrograms per gram (ug/g), except for Nitrogen and Sulfur, which are reported in weight percent (Wt.%), all on a dry basis.

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

Manager, Henderson Laboratory

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1819 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • (312) 953-9300

Member of the SGS Group (Société Générale de Surveillance)

September 11, 1995

PLEASE ADDRESS ALL CORRESPONDENCE TO
P.O. BOX 752, HENDERSON, KY 424
TELEPHONE: (502) 827-11
FAX: (502) 826-07ST. JOHNS RIVER POWER PARK
11201 NEW BERLIN RD
JACKSONVILLE FL 32226Sample identification by
SJRPPSample #0945R
P.O. #008306Kind of sample Coal
reported to us

7.56% A.D.L. Provided by Client

Sample taken at -----

Sample taken by -----

Date sampled August 15, 1995

Date received August 25, 1995

Analysis report no. 63-90993

<u>Parameter</u>	<u>Results</u>
Beryllium, Be	1.2
Chromium, Cr	8
Lead, Pb	3
Mercury, Hg	0.05
Nickel, Ni	54
Vanadium, V	360
Zinc, Zn	15
Sulfur, S	1.33
Nitrogen, N	1.53

Procedure: The samples were prepared according to ASTM, Part 5.05, Method D 3683. The samples were analyzed for trace elements by Inductively Coupled Plasma Emission Spectroscopy.

Mercury per ASTM, Part 5.05, Method D 3684, Double Gold Amalgamation Cold Vapor Atomic Absorption.

Sulfur per ASTM, Part 5.05, Method D 4239 (method C).
Nitrogen per ASTM, Part 5.05, Method D 5373-93.

Results: Results are reported as micrograms per gram (ug/g), except for Nitrogen and Sulfur, which are reported in weight percent (Wt.%), all on a dry basis.

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

Robert D. Henderson
Manager, Henderson Laboratory

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • (312) 953-9300

Member of the SGS Group (Société Générale de Surveillance)

September 11, 1995

PLEASE ADDRESS ALL CORRESPONDENCE
P.O. BOX 752, HENDERSON, KY 42404
TELEPHONE: (502) 827-1100
FAX: (502) 826-0100

ST. JOHNS RIVER POWER PARK
11201 NEW BERLIN RD
JACKSONVILLE FL 32226

Sample identification by
SJRPP

Sample #09475
P.O. #008306

Kind of sample reported to us Coal

7.15% A.D.L. Provided by Client

Sample taken at -----

Sample taken by -----

Date sampled August 16, 1995

Date received August 25, 1995

Analysis report no. 63-90994

Parameter	Results
Beryllium, Be	1.0
Chromium, Cr	7
Lead, Pb	4
Mercury, Hg	0.07
Nickel, Ni	60
Vanadium, V	390
Zinc, Zn	14
Sulfur, S	1.40
Nitrogen, N	1.53

Procedure: The samples were prepared according to ASTM, Part 5.05, Method D 3683. The samples were analyzed for trace elements by Inductively Coupled Plasma Emission Spectroscopy.

Mercury per ASTM, Part 5.05, Method D 3684, Double Gold Amalgamation Cold Vapor Atomic Absorption.

Sulfur per ASTM, Part 5.05, Method D 4239 (method C).

Nitrogen per ASTM, Part 5.05, Method D 5373-93.

Results: Results are reported as micrograms per gram (ug/g), except for Nitrogen and Sulfur, which are reported in weight percent (Wt.%), all on a dry basis.

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

Manager, Henderson Laboratory

OVER 40 BRANCH LABORATORIES STRATEGICALLY LOCATED IN PRINCIPAL COAL MINING AREAS, TIDEWATER AND GREAT LAKES PORTS, AND RIVER LOADING FACILITIES

Original Copy Watermarked For Your Protection

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • (312) 953-9300

Member of the SGS Group (Société Générale de Surveillance)

September 11, 1995

PLEASE ADDRESS ALL CORRESPONDENCE TO
P.O. BOX 752, HENDERSON, KY 4242
TELEPHONE: (502) 827-1111
FAX: (502) 826-0711

ST. JOHNS RIVER POWER PARK
11201 NEW BERLIN RD
JACKSONVILLE FL 32226

Sample identification by
SJRPP

Sample #0948T
P.O. #008306

Kind of sample Coal
reported to us

7.15% A.D.L. Provided by Client

Sample taken at -----

Sample taken by -----

Date sampled August 16, 1995

Date received August 25, 1995

Analysis report no. 63-90995

Parameter	Results
Beryllium, Be	1.2
Chromium, Cr	7
Lead, Pb	3
Mercury, Hg	0.03
Nickel, Ni	61
Vanadium, V	390
Zinc, Zn	13
Sulfur, S	1.40
Nitrogen, N	1.53

Procedure: The samples were prepared according to ASTM, Part 5.05, Method D 3683. The samples were analyzed for trace elements by Inductively Coupled Plasma Emission Spectroscopy.

Mercury per ASTM, Part 5.05, Method D 3684, Double Gold Amalgamation Cold Vapor Atomic Absorption.

Sulfur per ASTM, Part 5.05, Method D 4239 (method C).
Nitrogen per ASTM, Part 5.05, Method D 5373-93.

Results: Results are reported as micrograms per gram (ug/g), except for Nitrogen and Sulfur, which are reported in weight percent (Wt.%), all on a dry basis.

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

Manager, Henderson Laboratory

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • (312) 953-9300

Member of the SGS Group (Société Générale de Surveillance)

September 11, 1995

PLEASE ADDRESS ALL CORRESPONDENCE TO
P.O. BOX 732, HENDERSON, KY 424
TELEPHONE: (502) 827-1111
FAX: (502) 826-0707

ST. JOHNS RIVER POWER PARK
11201 NEW BERLIN RD
JACKSONVILLE FL 32226

Sample identification by
SJRPP

Sample #0949U
P.O. #008306

Kind of sample Coal
reported to us

7.15% A.D.L. Provided by Client

Sample taken at -----

Sample taken by -----

Date sampled August 16, 1995

Date received August 25, 1995

Analysis report no. 63-90996

<u>Parameter</u>	<u>Results</u>
Beryllium, Be	0.9
Chromium, Cr	7
Lead, Pb	<2
Mercury, Hg	0.05
Nickel, Ni	58
Vanadium, V	380
Zinc, Zn	13
Sulfur, S	1.32
Nitrogen, N	1.45


Procedure: The samples were prepared according to ASTM, Part 5.05, Method D 3683. The samples were analyzed for trace elements by Inductively Coupled Plasma Emission Spectroscopy.

Mercury per ASTM, Part 5.05, Method D 3684, Double Gold Amalgamation Cold Vapor Atomic Absorption.

Sulfur per ASTM, Part 5.05, Method D 4239 (method C).
Nitrogen per ASTM, Part 5.05, Method D 5373-93.

Results: Results are reported as micrograms per gram (ug/g), except for Nitrogen and Sulfur, which are reported in weight percent (Wt.%), all on a dry basis.

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.



Manager, Henderson Laboratory

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • (312) 953-9300

Member of the SGS Group (Société Générale de Surveillance)

September 11, 1995

PLEASE ADDRESS ALL CORRESPONDENCE TO
P.O. BOX 752, HENDERSON, KY 42424
TELEPHONE: (502) 827-1155
FAX: (502) 826-0711

ST. JOHNS RIVER POWER PARK
11201 NEW BERLIN RD
JACKSONVILLE FL 32226

Sample identification by
SJRPP

Sample #0952V
P.O. #008306

Kind of sample Coal
reported to us

7.23% A.D.L. Provided by Client

Sample taken at -----

Sample taken by -----

Date sampled August 17, 1995

Date received August 25, 1995

Analysis report no. 63-90997

Parameter	Results
Beryllium, Be	1.0
Chromium, Cr	7
Lead, Pb	<2
Mercury, Hg	0.04
Nickel, Ni	54
Vanadium, V	360
Zinc, Zn	13
Sulfur, S	1.33
Nitrogen, N	1.34

Procedure: The samples were prepared according to ASTM, Part 5.05, Method D 3683. The samples were analyzed for trace elements by Inductively Coupled Plasma Emission Spectroscopy.

Mercury per ASTM, Part 5.05, Method D 3684, Double Gold Amalgamation Cold Vapor Atomic Absorption.

Sulfur per ASTM, Part 5.05, Method D 4239 (method C).
Nitrogen per ASTM, Part 5.05, Method D 5373-93.

Results: Results are reported as micrograms per gram (ug/g), except for Nitrogen and Sulfur, which are reported in weight percent (Wt.%), all on a dry basis.

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO
[Signature]

Manager, Henderson Laboratory

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • (312) 953-8300

Member of the SGS Group (Société Générale de Surveillance)

September 11, 1995

PLEASE ADDRESS ALL CORRESPONDENCE TO
P.O. BOX 752, HENDERSON, KY 424
TELEPHONE: (502) 827-11
FAX: (502) 826-07

ST. JOHNS RIVER POWER PARK
11201 NEW BERLIN RD
JACKSONVILLE FL 32226

Sample identification by
SJRPP

Sample #0953W
P.O. #008306

Kind of sample Coal
reported to us

3.44% A.D.L. Provided by Client

Sample taken at -----

Sample taken by -----

Date sampled August 17, 1995

Date received August 25, 1995

Analysis report no. 63-90998

Parameter	Results
Beryllium, Be	1.7
Chromium, Cr	11
Lead, Pb	9
Mercury, Hg	0.07
Nickel, Ni	65
Vanadium, V	430
Zinc, Zn	16
Sulfur, S	1.94
Nitrogen, N	1.56

Procedure: The samples were prepared according to ASTM, Part 5.05, Method D 3683. The samples were analyzed for trace elements by Inductively Coupled Plasma Emission Spectroscopy.

Mercury per ASTM, Part 5.05, Method D 3684, Double Gold Amalgamation Cold Vapor Atomic Absorption.

Sulfur per ASTM, Part 5.05, Method D 4239 (method C).
Nitrogen per ASTM, Part 5.05, Method D 5373-93.

Results: Results are reported as micrograms per gram (ug/g), except for Nitrogen and Sulfur, which are reported in weight percent (Wt.%), all on a dry basis.

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

Manager, Henderson Laboratory

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • (312) 953-9300

Member of the SGS Group (Société Générale de Surveillance)

September 11, 1995

PLEASE ADDRESS ALL CORRESPONDENCE TO:
P.O. BOX 752, HENDERSON, KY 424
TELEPHONE: (502) 827-1111
FAX: (502) 828-0777

ST. JOHNS RIVER POWER PARK
11201 NEW BERLIN RD
JACKSONVILLE FL 32226

Sample identification by
SJRPP

Sample #0954X
P.O. #008306

Kind of sample Coal
reported to us

4.19% A.D.L. Provided by Client

Sample taken at -----

Sample taken by -----

Date sampled August 17, 1995

Date received August 25, 1995

Analysis report no. 63-90999

<u>Parameter</u>	<u>Results</u>
Beryllium, Be	2.0
Chromium, Cr	24
Lead, Pb	11
Mercury, Hg	0.04
Nickel, Ni	58
Vanadium, V	330
Zinc, Zn	25
Sulfur, S	1.49
Nitrogen, N	1.43

Procedure: The samples were prepared according to ASTM, Part 5.05, Method D 3683. The samples were analyzed for trace elements by Inductively Coupled Plasma Emission Spectroscopy.

Mercury per ASTM, Part 5.05, Method D 3684, Double Gold Amalgamation Cold Vapor Atomic Absorption.

Sulfur per ASTM, Part 5.05, Method D 4239 (method C).

Nitrogen per ASTM, Part 5.05, Method D 5373-93.

Results: Results are reported as micrograms per gram (ug/g), except for Nitrogen and Sulfur, which are reported in weight percent (Wt.%), all on a dry basis.

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

Kevin D. Henderson
Manager, Henderson Laboratory



COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1819 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • (312) 953-9300

Member of the SGS Group (Societe' Generale de Surveillance)

September 11, 1995

PLEASE ADDRESS ALL CORRESPONDENCE TO
P.O. BOX 752, HENDERSON, KY 424
TELEPHONE: (502) 827-1111
FAX: (502) 828-0700

ST. JOHNS RIVER POWER PARK
11201 NEW BERLIN RD
JACKSONVILLE FL 32226

Sample identification by
SJRPP

Sample #0956Y
P.O. #008306

Kind of sample Coal
reported to us

5.24% A.D.L. Provided by Client

Sample taken at -----

Sample taken by -----

Date sampled August 18, 1995

Date received August 25, 1995

Analysis report no. 63-91000

Parameter	Results
Beryllium, Be	2.0
Chromium, Cr	18
Lead, Pb	11
Mercury, Hg	0.07
Nickel, Ni	71
Vanadium, V	460
Zinc, Zn	23
Sulfur, S	1.77
Nitrogen, N	1.50

Procedure: The samples were prepared according to ASTM, Part 5.05, Method D 3683. The samples were analyzed for trace elements by Inductively Coupled Plasma Emission Spectroscopy.

Mercury per ASTM, Part 5.05, Method D 3684, Double Gold Amalgamation Cold Vapor Atomic Absorption.

Sulfur per ASTM, Part 5.05, Method D 4239 (method C).
Nitrogen per ASTM, Part 5.05, Method D 5373-93.

Results: Results are reported as micrograms per gram (ug/g), except for Nitrogen and Sulfur, which are reported in weight percent (Wt.%), all on a dry basis.

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

Rafael A. Hernandez
Manager, Henderson Laboratory



COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-G, LOMBARD, ILLINOIS 60148 • (312) 853-9300

Member of the SGS Group (Societe Generale de Surveillance)

September 11, 1995

PLEASE ADDRESS ALL CORRESPONDENCE TO
P.O. BOX 752, HENDERSON, KY 424
TELEPHONE: (502) 827-11
FAX: (502) 826-07

ST. JOHNS RIVER POWER PARK
11201 NEW BERLIN RD
JACKSONVILLE FL 32226

Sample identification by
SJRPP

Sample #09572
P.O. #008306

Kind of sample Coal
reported to us

4.17% A.D.L. Provided by Client

Sample taken at -----

Sample taken by -----

Date sampled August 18, 1995

Date received August 25, 1995

Analysis report no. 63-91001

<u>Parameter</u>	<u>Results</u>
Beryllium, Be	2.1
Chromium, Cr	17
Lead, Pb	10
Mercury, Hg	0.08
Nickel, Ni	65
Vanadium, V	380
Zinc, Zn	20
Sulfur, S	1.72
Nitrogen, N	1.51

Procedure: The samples were prepared according to ASTM, Part 5.05, Method D 3683. The samples were analyzed for trace elements by Inductively Coupled Plasma Emission Spectroscopy.

Mercury per ASTM, Part 5.05, Method D 3684, Double Gold Amalgamation Cold Vapor Atomic Absorption.

Sulfur per ASTM, Part 5.05, Method D 4239 (method C).

Nitrogen per ASTM, Part 5.05, Method D 5373-93.

Results: Results are reported as micrograms per gram (ug/g), except for Nitrogen and Sulfur, which are reported in weight percent (Wt.%), all on a dry basis.

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

Delvin D. Henderson
Manager, Henderson Laboratory

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • (312) 953-9300

SINCE 1908

Member of the SGS Group (Société Générale de Surveillance)

September 11, 1995

PLEASE ADDRESS ALL CORRESPONDENCE
P.O. BOX 752, HENDERSON, KY 40425
TELEPHONE: (502) 827-
FAX: (502) 826-4

ST. JOHNS RIVER POWER PARK
11201 NEW BERLIN RD
JACKSONVILLE FL 32226

Sample identification by
SJRPP

Sample #0958Z1
P.O. #008306

Kind of sample reported to us Coal

4.72% A.D.L. Provided by Client

Sample taken at -----

Sample taken by -----

Date sampled August 18, 1995

Date received August 25, 1995

Analysis report no. 63-91002

<u>Parameter</u>	<u>Results</u>
Beryllium, Be	2.0
Chromium, Cr	15
Lead, Pb	11
Mercury, Hg	0.08
Nickel, Ni	68
Vanadium, V	420
Zinc, Zn	21
Sulfur, S	1.86
Nitrogen, N	1.46

Procedure: The samples were prepared according to ASTM, Part 5.05, Method D 3683. The samples were analyzed for trace elements by Inductively Coupled Plasma Emission Spectroscopy.

Mercury per ASTM, Part 5.05, Method D 3684, Double Gold Amalgamation Cold Vapor Atomic Absorption.

Sulfur per ASTM, Part 5.05, Method D 4239 (method C).
Nitrogen per ASTM, Part 5.05, Method D 5373-93.

Results: Results are reported as micrograms per gram (ug/g), except for Nitrogen and Sulfur, which are reported in weight percent (Wt.%), all on a dry basis.

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

Manager, Henderson Laboratory

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • (312) 953-9300

Member of the SGS Group (Société Générale de Surveillance)

September 11, 1995

PLEASE ADDRESS ALL CORRESPONDENCE TO
P.O. BOX 752, HENDERSON, KY 424
TELEPHONE: (502) 827-1111
FAX: (502) 826-0707

ST. JOHNS RIVER POWER PARK
11201 NEW BERLIN RD
JACKSONVILLE FL 32226

Sample identification by
SJRPP

Sample #0960
P.O. #008306

Kind of sample Coal
reported to us

5.50% A.D.L. Provided by Client

Sample taken at -----

Sample taken by -----

Date sampled August 19, 1995

Date received August 25, 1995

Analysis report no. 63-91003

<u>Parameter</u>	<u>Results</u>
Beryllium, Be	1.8
Chromium, Cr	15
Lead, Pb	11
Mercury, Hg	0.09
Nickel, Ni	68
Vanadium, V	420
Zinc, Zn	22
Sulfur, S	1.89
Nitrogen, N	1.49

Procedure: The samples were prepared according to ASTM, Part 5.05, Method D 3683. The samples were analyzed for trace elements by Inductively Coupled Plasma Emission Spectroscopy.


Mercury per ASTM, Part 5.05, Method D 3684, Double Gold Amalgamation Cold Vapor Atomic Absorption.

Sulfur per ASTM, Part 5.05, Method D 4239 (method C).

Nitrogen per ASTM, Part 5.05, Method D 5373-93.

Results: Results are reported as micrograms per gram (ug/g), except for Nitrogen and Sulfur, which are reported in weight percent (Wt.%), all on a dry basis.

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.



Manager, Henderson Laboratory

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • (312) 953-9300

Member of the SGS Group (Société Générale de Surveillance)

September 11, 1995

PLEASE ADDRESS ALL CORRESPONDENCE TO:
P.O. BOX 752, HENDERSON, KY 424
TELEPHONE: (502) 827-1111
FAX: (502) 826-0707

ST. JOHNS RIVER POWER PARK
11201 NEW BERLIN RD
JACKSONVILLE FL 32226

Sample identification by
SJRPP

Sample #0951
Composite C
P.O. #008306

5.27% A.D.L. Provided by Client

Kind of sample Coal
reported to us

Sample taken at -----

Sample taken by -----

Date sampled August 14,15,16,17,18,19, 1995

Date received August 25, 1995

Analysis report no. 63-91005

<u>Parameter</u>	<u>Results</u>
Beryllium, Be	1.3
Chromium, Cr	12
Lead, Pb	7
Mercury, Hg	0.05
Nickel, Ni	62
Vanadium, V	400
Zinc, Zn	18
Sulfur, S	1.62
Nitrogen, N	1.50

Procedure: The samples were prepared according to ASTM, Part 5.05, Method D 3683. The samples were analyzed for trace elements by Inductively Coupled Plasma Emission Spectroscopy.

Mercury per ASTM, Part 5.05, Method D 3684, Double Gold Amalgamation Cold Vapor Atomic Absorption.

Sulfur per ASTM, Part 5.05, Method D 4239 (method C).
Nitrogen per ASTM, Part 5.05, Method D 5373-93.

Results: Results are reported as micrograms per gram (ug/g), except for Nitrogen and Sulfur, which are reported in weight percent (Wt.%), all on a dry basis.

Respectfully submitted,
COMMERCIAL-TESTING & ENGINEERING CO.

Manager, Henderson Laboratory



COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • (312) 953-9300

Member of the SGS Group (Societe Generale de Surveillance)

September 11, 1995

PLEASE ADDRESS ALL CORRESPONDENCE TO
P.O. BOX 752, HENDERSON, KY 424
TELEPHONE: (502) 827-1111
FAX: (502) 828-0707

ST. JOHNS RIVER POWER PARK
11201 NEW BERLIN RD
JACKSONVILLE FL 32226

Sample identification by
SJRPP

Sample #0938
Composite B
P.O. #008306

Kind of sample reported to us Coal

7.65% A.D.L. Provided by Client

Sample taken at -----

Sample taken by -----

Date sampled August 9,10,11,12,13, 1995

Date received August 25, 1995

Analysis report no. 63-91004

Parameter	Results
Beryllium, Be	0.5
Chromium, Cr	8
Lead, Pb	3
Mercury, Hg	0.05
Nickel, Ni	33
Vanadium, V	220
Zinc, Zn	12
Sulfur, S	1.05
Nitrogen, N	1.42

Procedure: The samples were prepared according to ASTM, Part 5.05, Method D 3683. The samples were analyzed for trace elements by Inductively Coupled Plasma Emission Spectroscopy.

Mercury per ASTM, Part 5.05, Method D 3684, Double Gold Amalgamation Cold Vapor Atomic Absorption.

Sulfur per ASTM, Part 5.05, Method D 4239 (method C).

Nitrogen per ASTM, Part 5.05, Method D 5373-93.

Results: Results are reported as micrograms per gram (ug/g), except for Nitrogen and Sulfur, which are reported in weight percent (Wt.%), all on a dry basis.

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

Manager, Henderson Laboratory

ATTACHMENT D

COAL ANALYSIS REPORT

BEST AVAILABLE COPY

SUPPLIER: EXXON SAMPLE TAKEN AT EXXON BY EXXON
ANALYZED BY EXXON

DATE SMP	TONS	AS RECEIVED				#SO2/MBTU	DRY			-A&M FREE- BTU
		%MOIST	%ASH	%SULFUR	BTU		%ASH	%SULFUR	BTU	
CONTRACTUAL		9.20	9.60	0.70	11810					
07/01/95 V513	45540.00	10.60	7.66	0.69	11831	1.16	8.57	0.77	13234	14474
07/16/95 V514	60025.00	10.78	7.38	0.62	11843	1.05	8.27	0.69	13274	14471
07/29/95 V515	59789.00	11.05	7.18	0.63	11823	1.06	8.07	0.71	13292	14459
WEIGHTED AVG	165354.00	10.83	7.38	0.64	11832	1.08	8.28	0.72	13269	14467

09/14/95
14:59:46

ST. JOHNS RIVER POWER PARK

COAL ANALYSIS REPORT

SUPPLIER: ASHLAND SAMPLE TAKEN AT ASHLAND BY ASHLAND
ANALYZED BY ASHLAND

DATE SMP	AS RECEIVED					#SO2/MBTU	DRY			-AGM FREE- BTU
	TONS	%MOIST	%ASH	%SULFUR	BTU		%ASH	%SULFUR	BTU	
CONTRACTUAL		6.00	11.00	0.85	12000					
08/01/95 7173	9522.00	5.69	13.33	0.88	12074	1.46	14.13	0.93	12802	14910
08/07/95 7174	9526.10	6.53	13.33	0.95	11947	1.59	14.26	1.02	12782	14908
08/11/95 7175	9720.80	5.80	13.63	1.00	12084	1.65	14.47	1.06	12828	14998
08/16/95 7176	9518.65	5.86	13.06	0.81	12129	1.33	13.87	0.86	12884	14959
08/22/95 7177	9376.50	5.83	13.93	0.81	11986	1.35	14.79	0.86	12728	14938
08/25/95 7178	9347.65	5.25	13.34	0.89	12161	1.46	14.08	0.94	12835	14938
WEIGHTED AVG	57011.70	5.83	13.44	0.89	12063	1.47	14.27	0.95	12810	14942

BEST AVAILABLE COPY



Hampton Roads Testing Laboral, Inc.
611 Howmet Drive, Hampton, Virginia 23061-1300
Tel (804) 826-8310 Fax (804) 827-1306

Laboratory Report No. 312916 Date of Report July 14, 1995

CERTIFICATE OF ANALYSIS

Sample of: PETROLEUM COKE - LOT 1

Mark: Representing a 71 car sample of PET COKE,
car top sampled at the Yorktown Refinery
and at Lee Hall, Virginia

From: Louisiana Carbon/Amoco

Date Sampled: July 13, 1995

Sampled By: Hampton Roads Testing Labs., Inc.

PROXIMATE ANALYSIS
As Received Dry Basis

Moisture	5.40	
Volatile Matter	14.28	15.09
Fixed Carbon	79.94	84.91
Ash	0.38	0.40
Total (100%)	100.00	100.00
Sulphur	3.15	3.33
B.T.U./Lb.	14777	15621
Calories/Gran	8209	8678

MOISTURE/ASH FREE B.T.U. 15684

Hampton Roads Testing Laboratories, Inc.

By

Tom Turner
Thomas

JUL-14-1995 15:05 FROM HAMPTON ROADS TESTING TO LACARBON-LARSON P.02

SENT BY: 7-14-95 : 2:43PM : Oxbow-SJKFF SITE OFFICE :# 3/ 4



Laboratory Report No. 312917 Date of Report July 14, 1995

CERTIFICATE OF ANALYSIS

Sample of: **PETROLEUM COKE - LOT 2**

Mark: **Representing a 48 car sample of PET COKE,
 car top sampled at the Yorktown Refinery**

From: **Louisiana Carbon/Amoco**

Date Sampled: **July 12, 1995**

Sampled By: **Hampton Roads Testing Labs., Inc.**

**PROXIMATE ANALYSIS
 As Received Dry Basis**

Moisture	5.45	
Volatile Matter	14.31	15.13
Fixed Carbon	79.89	84.50
Ash	0.35	0.37
Total (100%)	100.00	100.00
Sulphur	3.04	3.22
B.T.U./Lb.	14811	15665
Calories/Gran	8228	8703

MOISTURE/ASH FREE B.T.U. 15723

Hampton Roads Testing Laboratories, Inc.

By

[Signature]
 Chemist

JUL-14-1995 15:05 FROM HAMPTON ROADS TESTING TO LACARBON-LARSON P.03

OXDOW-SUNNY SITE OFFICE # 4 / 4
 7-14-95 2:44PM
 10 INCH

Oxbow-SJRPP SITE OFFICE :# 2/ 4

7-14-95 : 2:42PM :

SENT BY:



Hampton Roads Testing Laboratories, Inc.
611 Howland Drive, Hampton, Virginia 23661-1380
Tel (804) 826-5310 Fax (804) 827-1388

Laboratory Report No. 312918 Date of Report July 14, 1995

CERTIFICATE OF ANALYSIS

Sample of: **PETROLEUM COKE - DOMESTIC SHIPMENT**

Mark: **Calculated composite representing 119 cars of PET COKE for shipment to Jacksonville Electric, car top sampled at the Yorktown Refinery and at Lee Hall, Virginia**

From: **Louisiana Carbon/Amoco**

Date Sampled: **July 12 and 13, 1995**

Sampled By: **Hampton Roads Testing Labs., Inc.**

PROXIMATE ANALYSIS As Received Dry Basis

Moisture	5.42	
Volatile Matter	14.29	15.11
Fixed Carbon	79.92	84.50
Ash	0.37	0.39
Total (100%)	100.00	100.00
Sulphur	3.11	3.29
B.T.U./Lb.	14791	15639
Calories/Gran	8217	8688
MOISTURE/ASH FREE B.T.U.		15700

TOTAL P.04

Hampton Roads Testing Laboratories, Inc.

By Tom Janner
Chemist

JUL-14-1995 15:05 FROM HAMPTON ROADS TESTING TO LACARBON-LARSON P.04

ATTACHMENT E

ATTACHMENT E-1

Daily Summary

FROM 07/18/95 00:00 TO 07/19/95 00:00

Date/ Time	1inCO2_C %	1outCO2_C %	1outNOX_MM #/M	1inSO2_MM #/M	1outSO2_MM #/M
-18-95 00:00	13.45	12.68	0.451	1.024	0.294
07-18-95 01:00	13.07	12.41	0.438	1.020	0.292
07-18-95 02:00	12.70	11.88	0.444	1.021	0.289
07-18-95 03:00	12.64	11.87	0.451	1.013	0.284
07-18-95 04:00	12.68	11.90	0.454	1.015	0.284
07-18-95 05:00	12.67	11.94	0.454	1.014	0.283
07-18-95 06:00	13.08	12.27	0.504	1.020	0.270
07-18-95 07:00	13.23	12.47	0.529	1.005	0.271
07-18-95 08:00	13.27	12.45	0.523	0.996	0.269
07-18-95 09:00	13.23	12.43	0.519	0.992	0.270
07-18-95 10:00	13.31	12.44	0.520	0.991	0.270
07-18-95 11:00	13.27	12.45	0.524	1.000	0.273
07-18-95 12:00	13.33	12.45	0.525	1.007	0.274
07-18-95 13:00	13.31	12.47	0.522	1.016	0.277
07-18-95 14:00	13.33	12.45	0.514	1.021	0.279
07-18-95 15:00	13.03	12.26	0.465	1.030	0.282
07-18-95 16:00	13.17	12.31	0.500	1.057	0.289
07-18-95 17:00	13.26	12.40	0.490	1.072	0.296
07-18-95 18:00	13.37	12.49	0.480	1.072	0.293
07-18-95 19:00	13.28	12.49	0.472	1.063	0.290
07-18-95 20:00	13.33	12.49	0.477	1.059	0.289
07-18-95 21:00	13.24	12.50	0.457	1.061	0.293
07-18-95 22:00	13.25	12.43	0.459	1.059	0.294
07-18-95 23:00	13.13	12.40	0.482	1.055	0.291

*FINAL AVERAGE (s) 13.15 12.35 0.486 1.029 0.283
 *FINAL AVERAGE -- Summation of AVERAGING PERIODS excluding INVALID PERIODS

BEST AVAILABLE COPY

St. Johns Unit 1

Daily Summary

FROM 07/19/95 00:00 TO 07/20/95 00:00

Date/ Time	linCO2_C %	loutCO2_C %	loutNOX_MM #/M	linSO2_MM #/M	loutSO2_MM #/M
-19-95 00:00	13.16	12.28	0.488	1.048	0.297
07-19-95 01:00	13.18	12.39	0.490	1.043	0.290
07-19-95 02:00	13.30	12.46	0.490	1.039	0.286
07-19-95 03:00	13.30	12.54	0.486	1.040	0.286
07-19-95 04:00	13.29	12.49	0.505	1.041	0.285
07-19-95 05:00	13.25	12.51	0.507	1.043	0.286
07-19-95 06:00	13.31	12.54	0.506	1.042	0.284
07-19-95 07:00	13.22	12.54	0.500	1.040	0.285
07-19-95 08:00	13.31	12.52	0.502	1.040	0.287
07-19-95 09:00	13.28	12.52	0.505	1.050	0.290
07-19-95 10:00	13.31	12.54	0.507	1.047	0.289
07-19-95 11:00	13.23	12.45	0.516	1.034	0.284
07-19-95 12:00	13.30	12.47	0.512	1.025	0.281
07-19-95 13:00	13.24	12.44	0.515	1.014	0.278
07-19-95 14:00	13.30	12.41	0.517	1.011	0.277
07-19-95 15:00	13.27	12.48	0.510	1.011	0.275
07-19-95 16:00	13.29	12.45	0.515	1.007	0.272
07-19-95 17:00	13.28	12.50	0.501	1.010	0.275
07-19-95 18:00	13.36	12.50	0.501	1.009	0.276
07-19-95 19:00	13.31	12.54	0.507	1.005	0.272
07-19-95 20:00	13.37	12.54	0.498	1.006	0.273
07-19-95 21:00	13.32	12.53	0.495	1.008	0.276
07-19-95 22:00	13.41	12.55	0.489	1.009	0.277
07-19-95 23:00	13.31	12.53	0.486	1.005	0.277

FINAL AVERAGE (s) 13.29 12.49 0.502 1.026 0.282
 FINAL AVERAGE -- Summation of AVERAGING PERIODS excluding INVALID PERIODS

St. Johns Unit 1

Daily Summary

FROM 07/20/95 00:00 TO 07/21/95 00:00

Date/ Time	linCO2_C %	loutCO2_C %	loutNOX_MM #/M	linSO2_MM #/M	loutSO2_MM #/M
-20-95 00:00	13.39	12.44	0.485	1.002	0.286
07-20-95 01:00	13.29	12.54	0.478	1.007	0.282
07-20-95 02:00	13.39	12.55	0.460	1.004	0.277
07-20-95 03:00	13.29	12.52	0.459	1.002	0.274
07-20-95 04:00	13.34	12.51	0.443	0.994	0.272
07-20-95 05:00	13.33	12.49	0.399	1.003	0.275
07-20-95 06:00	13.36	12.43	0.444	0.999	0.273
07-20-95 07:00	13.30	12.50	0.447	1.008	0.272
07-20-95 08:00	13.37	12.53	0.446	1.021	0.275
07-20-95 09:00	13.33	12.49	0.448	1.029	0.280
07-20-95 10:00	13.42	12.50	0.458	1.037	0.284
07-20-95 11:00	13.38	12.54	0.466	1.043	0.281
07-20-95 12:00	13.37	**	**	1.045	**
07-20-95 13:00	13.31	12.29	0.488	1.049	0.280
07-20-95 14:00	13.38	12.40	0.505	1.050	0.288
07-20-95 15:00	13.33	12.44	0.504	1.050	0.284
07-20-95 16:00	13.35	12.49	0.502	1.051	0.285
07-20-95 17:00	13.29	12.44	0.498	1.051	0.287
07-20-95 18:00	13.39	12.42	0.496	1.050	0.289
07-20-95 19:00	13.35	12.48	0.494	1.048	0.289
07-20-95 20:00	13.34	12.42	0.489	1.048	0.289
07-20-95 21:00	13.31	12.44	0.496	1.047	0.289
07-20-95 22:00	13.37	12.47	0.501	1.049	0.288
07-20-95 23:00	13.26	12.44	0.496	1.046	0.286

*FINAL AVERAGE (s) 13.34 12.47 0.474 1.031 0.282
 *FINAL AVERAGE -- Summation of AVERAGING PERIODS excluding INVALID PERIODS

BEST AVAILABLE COPY

St. Johns Unit 1

Daily Summary

FROM 08/08/95 00:00 TO 08/09/95 00:00

Date/ Time	1inCO2_C %	1outCO2_C %	1outNOX_MM #/M	1inSO2_MM #/M	1outSO2_MM #/M
-08-95 00:00	13.38	12.27	**	1.041	0.306
08-08-95 01:00	13.30	12.38	**	1.023	0.296
08-08-95 02:00	13.41	12.39	**	1.020	0.291
08-08-95 03:00	13.31	**	**	1.017	**
08-08-95 04:00	13.31	12.10	0.546	1.011	0.415
08-08-95 05:00	13.25	12.29	0.537	1.003	0.278
08-08-95 06:00	13.32	12.32	0.533	1.000	0.274
08-08-95 07:00	13.28	12.34	0.538	0.997	0.274
08-08-95 08:00	13.36	12.40	0.552	0.986	0.272
08-08-95 09:00	13.32	12.38	0.562	0.975	0.268
08-08-95 10:00	13.39	12.37	0.574	0.975	0.266
08-08-95 11:00	13.37	12.37	0.568	0.969	0.264
08-08-95 12:00	13.38	12.36	0.567	0.953	0.258
08-08-95 13:00	13.33	12.21	0.566	0.948	0.254
08-08-95 14:00	13.35	12.38	0.535	0.938	0.250
08-08-95 15:00	13.29	12.38	0.553	0.938	0.248
08-08-95 16:00	13.38	12.39	0.562	0.942	0.249
08-08-95 17:00	13.35	12.41	0.562	0.951	0.251
08-08-95 18:00	13.47	12.44	0.557	0.954	0.248
08-08-95 19:00	13.33	12.39	0.550	0.950	0.249
08-08-95 20:00	13.39	12.39	0.536	0.941	0.247
08-08-95 21:00	13.30	12.39	0.531	0.942	0.249
08-08-95 22:00	13.43	12.46	0.546	0.944	0.250
08-08-95 23:00	13.26	12.37	0.514	0.943	0.249

FINAL AVERAGE (s) 13.34 12.36 0.549 0.973 0.270
 FINAL AVERAGE -- Summation of AVERAGING PERIODS excluding INVALID PERIODS

BEST AVAILABLE COPY

St. Johns Unit 1

Daily Summary

FROM 08/09/95 00:00 TO 08/10/95 00:00

Date/ Time	linCO2_C %	loutCO2_C %	loutNOX_MM #/M	linSO2_MM #/M	loutSO2_MM #/M
-09-95 00:00	13.34	12.28	**	0.938	0.258
08-09-95 01:00	13.27	13.43	**	0.939	0.298
08-09-95 02:00	13.37	12.31	**	0.953	0.253
08-09-95 03:00	13.26	12.36	**	0.956	0.255
08-09-95 04:00	13.29	12.31	0.541	0.962	0.261
08-09-95 05:00	13.25	12.33	0.545	0.960	0.255
08-09-95 06:00	13.34	12.34	0.555	0.965	0.255
08-09-95 07:00	13.31	12.37	0.589	0.979	0.258
08-09-95 08:00	13.36	12.38	0.579	0.994	0.263
08-09-95 09:00	13.25	12.34	0.583	1.020	0.270
08-09-95 10:00	13.32	12.34	0.578	1.032	0.274
08-09-95 11:00	13.30	12.41	0.563	1.047	0.279
08-09-95 12:00	13.12	12.42	0.575	1.072	0.280
08-09-95 13:00	13.00	12.42	0.569	1.085	0.296
08-09-95 14:00	13.09	12.34	0.611	1.078	0.298
08-09-95 15:00	13.17	12.46	0.595	1.083	0.306
08-09-95 16:00	13.26	12.56	0.568	1.124	0.310
08-09-95 17:00	13.39	12.67	0.482	1.152	0.316
08-09-95 18:00	13.42	12.65	0.484	1.136	0.313
08-09-95 19:00	13.31	12.65	0.491	1.135	0.311
08-09-95 20:00	13.30	12.62	0.491	1.140	0.311
08-09-95 21:00	13.24	12.58	0.493	1.139	0.312
08-09-95 22:00	13.29	12.58	0.482	1.157	0.318
08-09-95 23:00	13.25	12.56	0.474	1.171	0.323

FINAL AVERAGE (s) 13.27 12.49 0.542 1.051 0.286
 FINAL AVERAGE -- Summation of AVERAGING PERIODS excluding INVALID PERIODS

BEST AVAILABLE COPY

St. Johns Unit 1

Daily Summary

FROM 08/10/95 00:00 TO 08/11/95 00:00

Date/ Time	linCO2_C %	loutCO2_C %	loutNOX_MM #/M	linSO2_MM #/M	loutSO2_MM #/M
-10-95 00:00	13.30	12.48	0.490	1.188	0.337
08-10-95 01:00	13.22	12.55	0.478	1.263	0.348
08-10-95 02:00	13.32	12.55	0.470	1.235	0.349
08-10-95 03:00	13.18	12.49	0.489	1.230	0.350
08-10-95 04:00	13.11	12.37	0.497	1.275	0.359
08-10-95 05:00	13.15	12.49	0.516	1.287	0.355
08-10-95 06:00	13.21	12.53	0.502	1.284	0.352
08-10-95 07:00	13.23	12.54	0.489	1.291	0.356
08-10-95 08:00	13.33	12.62	0.498	1.313	0.362
08-10-95 09:00	13.23	12.59	0.497	1.328	0.367
08-10-95 10:00	13.16	12.52	0.512	1.333	0.368
08-10-95 11:00	13.01	12.40	0.564	1.294	0.354
08-10-95 12:00	13.08	12.41	0.582	1.300	0.355
08-10-95 13:00	13.02	12.30	0.505	1.359	0.379
08-10-95 14:00	13.07	12.35	0.501	1.375	0.391
08-10-95 15:00	13.05	12.44	0.491	1.361	0.385
08-10-95 16:00	13.21	12.49	0.546	1.371	0.378
08-10-95 17:00	13.27	12.49	0.535	1.398	0.394
08-10-95 18:00	13.29	**	**	1.394	**
08-10-95 19:00	13.22	12.54	0.508	1.405	0.387
08-10-95 20:00	13.34	12.57	0.490	1.407	0.379
08-10-95 21:00	13.29	12.60	0.461	1.406	0.378
08-10-95 22:00	13.38	12.66	0.464	1.419	0.380
08-10-95 23:00	13.13	12.55	0.458	1.468	0.393
FINAL AVERAGE (s)	13.20	12.50	0.502	1.333	0.368
FINAL AVERAGE	-- Summation of AVERAGING PERIODS excluding INVALID PERIODS				

BEST AVAILABLE COPY

St. Johns Unit 1

Daily Summary

FROM 08/11/95 00:00 TO 08/12/95 00:00

Date/ Time	linCO2_C %	loutCO2_C %	loutNOX_MM #/M	linSO2_MM #/M	loutSO2_MM #/M
-11-95 00:00	13.29	12.24	0.468	1.480	0.504
08-11-95 01:00	13.20	12.59	0.484	1.497	0.406
08-11-95 02:00	13.29	12.59	0.501	1.488	0.407
08-11-95 03:00	13.29	12.65	0.509	1.516	0.414
08-11-95 04:00	13.38	12.66	0.517	1.558	0.429
08-11-95 05:00	13.31	12.67	0.527	1.597	0.441
08-11-95 06:00	13.36	12.65	0.523	1.621	0.450
08-11-95 07:00	13.31	12.64	0.508	1.646	0.462
08-11-95 08:00	13.37	12.66	0.499	1.670	0.466
08-11-95 09:00	13.34	12.67	0.500	1.684	0.466
08-11-95 10:00	13.44	12.71	0.493	1.710	0.474
08-11-95 11:00	13.34	12.67	0.484	1.705	0.473
08-11-95 12:00	13.27	12.56	0.491	1.672	0.467
08-11-95 13:00	13.03	12.40	0.562	1.582	0.441
08-11-95 14:00	13.14	12.46	0.549	1.579	0.437
08-11-95 15:00	13.20	12.55	0.508	1.682	0.465
08-11-95 16:00	13.35	12.62	0.497	1.699	0.475
08-11-95 17:00	13.33	12.64	0.496	1.705	0.480
08-11-95 18:00	13.46	12.72	0.494	1.704	0.480
08-11-95 19:00	13.39	12.73	0.496	1.694	0.473
08-11-95 20:00	13.45	12.76	0.495	1.689	0.464
08-11-95 21:00	13.36	12.75	0.490	1.692	0.464
08-11-95 22:00	13.36	12.70	0.476	1.697	0.464
08-11-95 23:00	13.30	12.67	0.478	1.693	0.464

*FINAL AVERAGE (s) 13.32 12.62 0.502 1.636 0.457
 *FINAL AVERAGE -- Summation of AVERAGING PERIODS excluding INVALID PERIODS

BEST AVAILABLE COPY

St. Johns Unit 1

Daily Summary

FROM 08/12/95 00:00 TO 08/13/95 00:00

Date/ Time	linCO2_C %	loutCO2_C %	loutNOX_MM #/M	linSO2_MM #/M	loutSO2_MM #/M
-12-95 00:00	13.40	12.63	0.482	1.700	0.478
08-12-95 01:00	13.20	12.64	0.480	1.699	0.477
08-12-95 02:00	13.26	12.57	0.485	1.707	0.479
08-12-95 03:00	13.21	12.56	0.484	1.713	0.485
08-12-95 04:00	13.23	12.53	0.484	1.722	0.492
08-12-95 05:00	13.14	12.50	0.485	1.722	0.494
08-12-95 06:00	13.25	12.57	0.495	1.723	0.494
08-12-95 07:00	13.23	12.64	0.498	1.711	0.495
08-12-95 08:00	13.35	12.72	0.509	1.712	0.482
08-12-95 09:00	13.31	12.71	0.507	1.715	0.482
08-12-95 10:00	13.39	12.68	0.498	1.722	0.485
08-12-95 11:00	13.35	12.68	0.498	1.727	0.489
08-12-95 12:00	13.43	12.68	0.501	1.721	0.489
08-12-95 13:00	13.31	12.67	0.503	1.717	0.488
08-12-95 14:00	13.39	12.67	0.509	1.710	0.485
08-12-95 15:00	13.27	12.60	0.508	1.716	0.486
08-12-95 16:00	13.28	12.56	0.507	1.712	0.484
08-12-95 17:00	13.22	12.54	0.514	1.708	0.483
08-12-95 18:00	13.34	12.59	0.492	1.703	0.482
08-12-95 19:00	13.26	12.64	0.486	1.703	0.478
08-12-95 20:00	13.33	12.63	0.488	1.691	0.473
08-12-95 21:00	13.24	12.63	0.479	1.686	0.479
08-12-95 22:00	13.28	12.59	0.472	1.687	0.487
08-12-95 23:00	13.25	12.64	0.483	1.694	0.492

*FINAL AVERAGE (s) 13.29 12.62 0.494 1.709 0.485
 *FINAL AVERAGE -- Summation of AVERAGING PERIODS excluding INVALID PERIODS

BEST AVAILABLE COPY

St. Johns Unit 1

Daily Summary

FROM 08/13/95 00:00 TO 08/14/95 00:00

Date/ Time	1inCO2_C %	1outCO2_C %	1outNOX_MM #/M	1inSO2_MM #/M	1outSO2_MM #/M
-13-95 00:00	13.33	12.49	0.483	1.702	0.502
08-13-95 01:00	13.22	12.63	0.488	1.714	0.497
08-13-95 02:00	13.35	12.64	0.493	1.715	0.479
08-13-95 03:00	13.33	12.72	0.495	1.714	0.475
08-13-95 04:00	13.37	12.68	0.489	1.706	0.473
08-13-95 05:00	13.25	12.62	0.492	1.693	0.473
08-13-95 06:00	13.30	12.61	0.483	1.686	0.478
08-13-95 07:00	13.25	12.63	0.480	1.687	0.480
08-13-95 08:00	13.42	12.72	0.475	1.686	0.482
08-13-95 09:00	13.38	12.73	0.462	1.696	0.486
08-13-95 10:00	13.51	12.74	0.448	1.715	0.493
08-13-95 11:00	13.49	12.78	0.451	1.733	0.496
08-13-95 12:00	13.54	12.76	0.478	1.743	0.496
08-13-95 13:00	13.47	12.80	0.471	1.751	0.492
08-13-95 14:00	13.50	12.70	0.461	1.752	0.489
08-13-95 15:00	13.41	12.68	0.447	1.752	0.495
08-13-95 16:00	13.49	12.66	0.439	1.759	0.499
08-13-95 17:00	13.45	12.71	0.446	1.765	0.502
08-13-95 18:00	13.51	12.72	0.447	1.759	0.491
08-13-95 19:00	13.46	12.77	0.443	1.755	0.467
08-13-95 20:00	13.54	12.77	0.444	1.752	0.459
08-13-95 21:00	13.46	12.81	0.432	1.750	0.458
08-13-95 22:00	13.50	12.75	0.434	1.741	0.455
08-13-95 23:00	13.43	12.80	0.430	1.743	0.456

*FINAL AVERAGE (s) 13.41 12.70 0.463 1.728 0.482
 *FINAL AVERAGE -- Summation of AVERAGING PERIODS excluding INVALID PERIODS

BEST AVAILABLE COPY

St. Johns Unit 1

Daily Summary

FROM 08/14/95 00:00 TO 08/15/95 00:00

Date/ Time	linCO2_C %	loutCO2_C %	loutNOX_MM #/M	linSO2_MM #/M	loutSO2_MM #/M
-14-95 00:00	13.50	12.72	**	1.749	0.466
08-14-95 01:00	13.29	14.22	**	1.751	0.458
08-14-95 02:00	13.42	12.58	0.499	1.743	0.481
08-14-95 03:00	13.37	12.69	0.487	1.742	0.475
08-14-95 04:00	13.44	12.67	0.498	1.740	0.476
08-14-95 05:00	13.40	12.73	0.496	1.744	0.478
08-14-95 06:00	13.46	12.74	0.500	1.755	0.484
08-14-95 07:00	13.36	12.72	0.496	1.762	0.489
08-14-95 08:00	13.47	12.73	0.502	1.767	0.492
08-14-95 09:00	13.41	12.75	0.477	1.778	0.498
08-14-95 10:00	13.49	12.74	0.479	1.787	0.504
08-14-95 11:00	13.44	12.75	0.471	1.784	0.506
08-14-95 12:00	13.55	12.76	0.469	1.775	0.502
08-14-95 13:00	13.50	12.78	0.467	1.764	0.493
08-14-95 14:00	13.57	12.77	0.467	1.762	0.479
08-14-95 15:00	13.40	12.66	0.490	1.764	0.467
08-14-95 16:00	13.43	12.60	0.499	1.761	0.458
08-14-95 17:00	13.40	12.62	0.517	1.758	0.461
08-14-95 18:00	13.54	12.68	0.525	1.757	0.463
08-14-95 19:00	13.44	12.72	0.525	1.753	0.456
08-14-95 20:00	13.47	12.67	0.517	1.744	0.462
08-14-95 21:00	13.37	12.66	0.509	1.736	0.464
08-14-95 22:00	13.46	12.66	0.550	1.741	0.466
08-14-95 23:00	13.32	12.61	0.516	1.747	0.467

*FINAL AVERAGE (s) 13.44 12.76 0.498 1.757 0.477
 *FINAL AVERAGE -- Summation of AVERAGING PERIODS excluding INVALID PERIODS

BEST AVAILABLE COPY

St. Johns Unit 1

Daily Summary

FROM 08/15/95 00:00 TO 08/16/95 00:00

Date/ Time	linCO2_C %	loutCO2_C %	loutNOX_MM #/M	linSO2_MM #/M	loutSO2_MM #/M
-15-95 00:00	13.33	12.26	**	1.740	0.572
08-15-95 01:00	13.29	14.15	**	1.722	0.454
08-15-95 02:00	13.43	12.55	0.491	1.720	0.463
08-15-95 03:00	13.41	12.67	0.482	1.731	0.457
08-15-95 04:00	13.44	12.65	0.503	1.743	0.458
08-15-95 05:00	13.36	12.67	0.505	1.741	0.457
08-15-95 06:00	13.42	12.65	0.495	1.739	0.455
08-15-95 07:00	13.30	12.61	0.510	1.728	0.458
08-15-95 08:00	13.39	12.65	0.512	1.726	0.482
08-15-95 09:00	13.34	12.70	0.497	1.729	0.485
08-15-95 10:00	13.29	12.57	0.491	1.732	0.489
08-15-95 11:00	13.27	12.56	0.528	1.726	0.481
08-15-95 12:00	13.36	12.58	0.530	1.728	0.472
08-15-95 13:00	13.31	12.51	0.343	1.725	0.466
08-15-95 14:00	13.40	12.35	0.535	1.723	0.463
08-15-95 15:00	13.38	12.49	0.519	1.727	0.471
08-15-95 16:00	13.44	12.64	0.536	1.730	0.468
08-15-95 17:00	13.34	12.67	0.516	1.733	0.466
08-15-95 18:00	13.43	12.63	0.509	1.730	0.466
08-15-95 19:00	13.34	12.70	0.518	1.727	0.468
08-15-95 20:00	13.42	12.67	0.515	1.730	0.464
08-15-95 21:00	13.34	12.68	0.512	1.730	0.463
08-15-95 22:00	13.40	12.61	0.520	1.734	0.464
08-15-95 23:00	13.32	12.66	0.493	1.728	0.462

*FINAL AVERAGE (s) 13.36 12.66 0.503 1.730 0.471
 *FINAL AVERAGE -- Summation of AVERAGING PERIODS excluding INVALID PERIODS

BEST AVAILABLE COPY

St. Johns Unit 1

Daily Summary

FROM 08/16/95 00:00 TO 08/17/95 00:00

Date/ Time	1inCO2_C %	1outCO2_C %	1outNOX_MM #/M	1inSO2_MM #/M	1outSO2_MM #/M
-16-95 00:00	13.43	12.60	0.501	1.728	0.469
08-16-95 01:00	13.31	12.71	0.510	1.716	0.463
08-16-95 02:00	13.41	12.69	0.524	1.715	0.459
08-16-95 03:00	13.27	12.65	0.519	1.719	0.461
08-16-95 04:00	13.37	12.63	0.525	1.715	0.461
08-16-95 05:00	13.31	12.67	0.528	1.723	0.467
08-16-95 06:00	13.39	12.68	0.526	1.722	0.463
08-16-95 07:00	13.33	12.58	0.524	1.720	0.484
08-16-95 08:00	13.37	12.62	0.535	1.717	0.484
08-16-95 09:00	13.38	11.63	0.518	1.718	0.502
08-16-95 10:00	13.46	12.32	0.529	1.717	0.503
08-16-95 11:00	13.39	12.71	0.561	1.722	0.479
08-16-95 12:00	13.46	12.74	0.543	1.732	0.483
08-16-95 13:00	13.40	12.68	0.575	1.726	0.482
08-16-95 14:00	13.38	12.62	0.579	1.718	0.479
08-16-95 15:00	13.25	12.47	0.598	1.710	0.477
08-16-95 16:00	13.33	12.57	0.595	1.715	0.479
08-16-95 17:00	13.31	12.62	0.555	1.720	0.480
08-16-95 18:00	13.40	12.61	0.555	1.730	0.481
08-16-95 19:00	13.35	12.69	0.538	1.732	0.476
08-16-95 20:00	13.45	12.70	0.517	1.725	0.478
08-16-95 21:00	13.36	12.69	0.499	1.714	0.476
08-16-95 22:00	13.48	12.71	0.499	1.714	0.476
08-16-95 23:00	13.33	12.67	0.497	1.711	0.476

FINAL AVERAGE (s) 13.37 12.59 0.535 1.720 0.477
 FINAL AVERAGE -- Summation of AVERAGING PERIODS excluding INVALID PERIODS

BEST AVAILABLE COPY

St. Johns Unit 1

Daily Summary

FROM 08/17/95 00:00 TO 08/18/95 00:00

Date/ Time	1inCO2_C %	1outCO2_C %	1outNOX_MM #/M	1inSO2_MM #/M	1outSO2_MM #/M
-17-95 00:00	13.43	12.63	**	1.717	0.485
08-17-95 01:00	13.24	13.92	**	1.718	0.464
08-17-95 02:00	13.35	12.54	0.575	1.702	0.479
08-17-95 03:00	13.27	12.62	0.560	1.707	0.479
08-17-95 04:00	13.28	12.55	0.517	1.716	0.476
08-17-95 05:00	13.20	12.56	0.547	1.733	0.474
08-17-95 06:00	13.41	12.70	0.544	1.727	0.485
08-17-95 07:00	13.30	12.68	0.534	1.732	0.483
08-17-95 08:00	13.22	12.55	0.537	1.759	0.489
08-17-95 09:00	13.18	12.53	0.525	1.790	0.500
08-17-95 10:00	13.19	12.47	0.560	1.859	0.525
08-17-95 11:00	13.27	12.57	0.572	1.969	0.538
08-17-95 12:00	13.42	12.62	0.573	2.086	0.560
08-17-95 13:00	13.37	12.66	0.558	2.140	0.552
08-17-95 14:00	13.45	12.56	0.538	2.156	0.560
08-17-95 15:00	13.39	12.63	0.547	2.167	0.561
08-17-95 16:00	13.51	12.56	0.559	2.187	0.576
08-17-95 17:00	13.38	12.61	0.588	2.196	0.574
08-17-95 18:00	13.44	12.60	0.598	2.166	0.565
08-17-95 19:00	13.33	12.61	0.601	2.112	0.547
08-17-95 20:00	13.42	12.51	0.602	2.067	0.543
08-17-95 21:00	13.30	12.59	0.597	2.039	0.533
08-17-95 22:00	13.24	12.49	0.551	2.029	0.524
08-17-95 23:00	13.26	12.58	0.520	2.029	0.526

*FINAL AVERAGE (s) 13.33 12.64 0.559 1.938 0.521
 *FINAL AVERAGE -- Summation of AVERAGING PERIODS excluding INVALID PERIODS

BEST AVAILABLE COPY

St. Johns Unit 1

Daily Summary

FROM 08/18/95 00:00 TO 08/19/95 00:00

Date/ Time	1inCO2_C %	1outCO2_C %	1outNOX_MM #/M	1inSO2_MM #/M	1outSO2_MM #/M
-18-95 00:00	13.32	12.46	0.516	2.039	0.536
08-18-95 01:00	13.22	12.57	0.519	2.061	0.538
08-18-95 02:00	13.44	12.63	0.522	2.101	0.561
08-18-95 03:00	13.27	12.63	0.547	2.128	0.549
08-18-95 04:00	13.41	12.67	0.531	2.165	0.564
08-18-95 05:00	13.34	12.69	0.527	2.190	0.575
08-18-95 06:00	13.38	12.67	0.518	2.209	0.584
08-18-95 07:00	13.29	12.59	0.513	2.220	0.585
08-18-95 08:00	13.35	12.63	**	2.235	0.587
08-18-95 09:00	13.29	**	**	2.248	**
08-18-95 10:00	13.35	12.46	0.459	2.259	0.577
08-18-95 11:00	13.32	12.47	0.463	2.269	0.589
08-18-95 12:00	13.41	12.52	0.468	2.272	0.596
08-18-95 13:00	13.36	12.46	0.487	2.272	0.562
08-18-95 14:00	13.43	12.56	0.494	2.277	0.550
08-18-95 15:00	13.35	12.60	0.489	2.276	0.555
08-18-95 16:00	13.45	12.59	0.488	2.267	0.546
08-18-95 17:00	13.38	12.63	0.489	2.268	0.544
08-18-95 18:00	13.47	12.64	0.490	2.282	0.560
08-18-95 19:00	13.36	12.63	0.491	2.305	0.561
08-18-95 20:00	13.44	12.62	0.489	2.332	0.565
08-18-95 21:00	13.19	12.51	0.495	2.368	0.579
08-18-95 22:00	13.35	12.56	0.475	2.405	0.579
08-18-95 23:00	13.20	12.51	0.485	2.418	0.575

*FINAL AVERAGE (s) 13.35 12.58 0.498 2.244 0.566
 *FINAL AVERAGE -- Summation of AVERAGING PERIODS excluding INVALID PERIODS

BEST AVAILABLE COPY

St. Johns Unit 1

Daily Summary

FROM 08/19/95 00:00 TO 08/20/95 00:00

Date/ Time	linCO2_C %	loutCO2_C %	loutNOX_MM #/M	linSO2_MM #/M	loutSO2_MM #/M
-19-95 00:00	13.00	12.31	0.501	2.428	0.581
08-19-95 01:00	13.00	12.33	0.512	2.443	0.582
08-19-95 02:00	13.18	12.39	0.505	2.453	0.572
08-19-95 03:00	13.08	12.35	0.493	2.455	0.563
08-19-95 04:00	13.20	12.41	0.483	2.462	0.563
08-19-95 05:00	13.10	12.41	0.481	2.472	0.563
08-19-95 06:00	13.16	12.38	0.490	2.481	0.560
08-19-95 07:00	13.12	12.45	0.496	2.494	0.560
08-19-95 08:00	13.11	12.41	0.490	2.504	0.566
08-19-95 09:00	13.03	12.37	0.467	2.504	0.559
08-19-95 10:00	13.09	12.32	0.505	2.499	0.560
08-19-95 11:00	13.01	12.31	0.489	2.507	0.557
08-19-95 12:00	13.38	12.61	0.435	2.519	0.560
08-19-95 13:00	13.47	12.77	0.431	2.518	0.580
08-19-95 14:00	13.57	12.78	0.436	2.489	0.564
08-19-95 15:00	13.52	12.80	0.435	2.457	0.558
08-19-95 16:00	13.59	12.80	0.437	2.406	0.531
08-19-95 17:00	13.49	12.86	0.451	2.332	0.504
08-19-95 18:00	13.49	12.81	0.458	2.253	0.489
08-19-95 19:00	13.45	12.85	0.454	2.180	0.498
08-19-95 20:00	13.48	12.74	0.464	2.115	0.520
08-19-95 21:00	13.38	12.75	0.456	2.052	0.509
08-19-95 22:00	13.47	12.74	0.455	2.010	0.493
08-19-95 23:00	13.38	12.81	0.452	1.986	0.494

*FINAL AVERAGE (s) 13.28 12.57 0.470 2.376 0.545
 *FINAL AVERAGE -- Summation of AVERAGING PERIODS excluding INVALID PERIODS

Company: St. Johns Unit 1
Source: Unit 1 7-18-95

Location:
Channel: 10capacity Units: %

00:00	5.5	5.5	5.9	5.3	6.6	5.7	5.5	6.0	5.5	11.7ZC	Avg:	5.7	9
01:00	15.9SC	5.8	6.1	5.8	6.1	5.2	5.8	6.5	5.2	5.3	Avg:	5.8	9
02:00	5.6	5.3	5.7	5.8	5.4	6.2	6.1	6.1	5.3	5.0	Avg:	5.6	10
03:00	5.5	5.2	5.2	4.9	5.3	5.3	5.0	5.1	5.4	5.0	Avg:	5.2	10
04:00	5.3	4.9	5.2	5.8	5.6	5.7	5.3	5.4	5.8	4.8	Avg:	5.3	10
05:00	5.8	5.6	5.0	5.3	5.3	5.6	5.4	5.0	5.2	5.3	Avg:	5.4	10
06:00	5.3	5.5	5.3	5.9	5.5	5.7	7.3	5.7	6.2	5.8	Avg:	5.8	10
07:00	5.6	6.0	5.1	5.1	5.3	5.8	5.8	5.6	5.5	5.9	Avg:	5.6	10
08:00	5.5	5.7	5.5	5.8	5.8	5.2	5.6	5.4	5.5	5.6	Avg:	5.6	10
09:00	5.4	5.5	5.4	5.1	5.4	5.3	5.2	5.6	5.3	5.5	Avg:	5.4	10
10:00	5.7	5.9	5.3	5.6	5.6	5.4	5.4	5.4	5.5	5.4	Avg:	5.5	10
11:00	5.2	5.2	5.8	5.4	5.6	5.4	5.5	5.5	5.4	5.4	Avg:	5.4	10
12:00	5.4	5.7	5.7	5.5	6.3	5.9	5.8	5.6	5.7	5.9	Avg:	5.8	10
13:00	5.7	5.3	5.5	5.9	5.7	6.0	6.2	6.1	5.6	5.7	Avg:	5.8	10
14:00	5.9	5.7	5.7	6.2	5.9	5.9	6.1	5.6	5.8	6.4	Avg:	5.9	10
15:00	6.3	5.7	6.0	5.8	6.2	6.1	6.2	6.1	6.3	6.6	Avg:	6.1	10
16:00	6.4	6.7	6.4	6.4	6.7	6.3	6.1	6.7	6.3	6.2	Avg:	6.4	10
17:00	6.3	6.1	6.1	6.7	6.4	6.6	6.2	6.3	6.0	6.1	Avg:	6.3	10
18:00	5.7	6.2	6.1	5.9	6.0	6.1	6.1	6.3	6.0	5.9	Avg:	6.0	10
19:00	6.0	6.1	6.1	5.9	6.6	6.1	6.0	6.0	5.9	5.9	Avg:	6.1	10
20:00	5.8	5.7	6.1	5.9	6.2	6.1	5.6	5.7	5.5	5.8	Avg:	5.8	10
21:00	5.9	6.0	5.6	5.8	5.9	5.6	5.5	6.0	5.2	5.5	Avg:	5.7	10
22:00	5.7	5.5	6.4	6.4	5.9	5.7	5.7	5.8	5.7	5.7	Avg:	5.8	10
23:00	6.0	5.4	5.4	5.5	5.5	5.9	6.0	5.7	5.9	5.9	Avg:	5.7	10
Daily Average:		5.7	Count: 238										

Company: St. Johns Unit 1
Source : Unit 1

Location:
Channel : 10capacity Units: %

~~2/19-95~~

00:00	6.1	5.7	5.7	5.8	6.0	6.2	5.7	6.6	6.0	10.72C	Avg:	6.0	9
01:00	16.7SC	5.8	5.8	6.8	5.7	5.5	5.8	5.6	5.7	5.5	Avg:	5.8	9
02:00	5.7	5.8	5.7	5.9	5.7	5.7	5.6	5.5	5.6	5.9	Avg:	5.7	10
03:00	5.4	5.5	5.6	6.3	5.8	5.4	6.1	5.7	5.6	5.7	Avg:	5.7	10
04:00	5.7	6.4	5.7	5.8	5.7	6.0	6.1	5.7	5.7	5.7	Avg:	5.8	10
05:00	6.2	5.5	5.7	5.9	5.5	5.5	5.8	5.8	5.5	5.8	Avg:	5.7	10
06:00	5.3	5.5	5.4	5.8	5.5	5.5	5.5	5.7	5.5	5.3	Avg:	5.5	10
07:00	5.4	5.8	5.8	6.2	6.0	5.4	5.9	5.9	5.6	5.5	Avg:	5.7	10
08:00	5.7	5.6	5.7	5.7	5.8	5.5	5.7	5.7	5.3	5.6	Avg:	5.6	10
09:00	5.4	6.2	5.4	5.0	5.5	5.9	6.3	5.3	5.0	5.3	Avg:	5.5	10
10:00	5.2	5.0	5.1	5.2	5.4	5.0	4.9	5.6	5.5	5.7	Avg:	5.3	10
11:00	5.8	5.8	6.1	5.7	5.5	5.7	5.6	5.6	5.5	5.9	Avg:	5.7	10
12:00	5.5	5.6	5.6	5.6	5.5	5.4	5.3	5.2	5.3	5.2	Avg:	5.4	10
13:00	5.3	5.7	5.6	5.3	5.5	5.4	5.5	5.4	5.4	5.5	Avg:	5.4	10
14:00	5.8	5.5	5.3	5.4	5.7	5.8	5.7	5.5	5.6	5.5	Avg:	5.6	10
15:00	5.5	5.6	5.5	5.6	5.4	5.4	5.6	5.7	5.6	5.5	Avg:	5.5	10
16:00	5.5	5.9	5.7	6.0	5.7	5.8	5.8	5.7	5.8	6.1	Avg:	5.8	10
17:00	6.3	6.3	6.0	6.1	6.2	6.3	6.0	6.1	6.1	6.1	Avg:	6.1	10
18:00	6.2	6.3	6.0	6.0	6.1	6.1	6.0	6.0	6.0	6.1	Avg:	6.1	10
19:00	6.1	5.8	6.0	6.1	5.9	5.9	6.0	6.2	5.9	5.8	Avg:	6.0	10
20:00	6.0	5.8	5.9	6.0	5.8	6.4	6.0	5.8	5.9	5.9	Avg:	5.9	10
21:00	5.9	5.8	5.6	5.7	5.8	5.6	5.6	5.8	6.3	6.0	Avg:	5.8	10
22:00	5.8	5.8	5.7	6.0	5.7	5.9	7.1	5.8	5.6	5.8	Avg:	5.9	10
23:00	5.8	5.8	5.7	5.6	5.9	5.7	5.6	5.4	5.7	5.7	Avg:	5.7	10

Daily Average: 5.7 Count: 238

Company: St. Johns Unit 1
Source : Unit 1

7-20-95

Location:
Channel : 10Capacity Units: %

00:00	5.5	5.3	5.7	5.7	6.1	5.6	5.4	5.5	5.5	10.12C	Avg:	5.6	9
01:00	10.9SC	5.3	5.6	5.2	5.3	5.7	5.6	5.5	5.3	5.5	Avg:	5.4	9
02:00	5.6	5.6	5.5	5.5	5.6	5.6	5.3	5.6	5.7	5.5	Avg:	5.5	10
03:00	5.7	5.5	5.7	5.8	5.7	5.6	5.5	5.5	6.2	5.7	Avg:	5.7	10
04:00	5.9	6.1	5.7	6.5	5.7	6.3	5.9	6.2	6.3	6.1	Avg:	6.1	10
05:00	5.7	6.3	6.3	6.8	6.3	5.8	6.4	5.8	5.9	5.9	Avg:	6.1	10
06:00	5.6	6.4	5.3	5.5	5.8	6.0	6.9	6.3	6.4	7.1	Avg:	6.1	10
07:00	6.1	6.5	6.5	6.8	7.5	6.4	7.1	7.5	6.7	6.9	Avg:	6.8	10
08:00	6.1	7.1	6.4	6.4	7.2	17.0	7.0	7.0	7.3	10.8	Avg:	8.2	10
09:00	7.0	6.5	6.2	6.7	6.4	6.5	6.6	6.0	6.2	6.3	Avg:	6.4	10
10:00	5.7	6.8	6.6	6.7	6.6	6.9	6.9	6.6	7.0	6.4	Avg:	6.6	10
11:00	6.0	6.6	6.8	6.2	6.2	6.1	6.5	6.0	6.3	6.4	Avg:	6.3	10
12:00	5.9	6.3	6.5	6.5	6.3	6.1	6.6	6.6	6.2	6.4	Avg:	6.3	10
13:00	7.2	6.6	6.6	6.4	6.8	6.5	6.4	6.8	6.6	6.5	Avg:	6.6	10
14:00	6.4	6.4	6.3	6.3	6.6	6.6	6.6	6.7	7.0	6.8	Avg:	6.6	10
15:00	7.1	7.0	6.9	7.3	7.1	7.5	7.4	7.0	7.0	7.0	Avg:	7.1	10
16:00	7.1	6.8	7.3	7.5	7.4	7.2	7.3	7.1	6.8	6.9	Avg:	7.1	10
17:00	7.0	7.1	7.2	7.4	7.2	7.1	7.2	7.1	7.8	7.0	Avg:	7.2	10
18:00	7.0	7.3	6.8	7.1	7.0	6.9	7.2	7.3	7.0	6.8	Avg:	7.1	10
19:00	7.0	7.0	6.6	7.4	7.3	6.7	7.1	6.7	7.0	6.8	Avg:	7.0	10
20:00	6.7	6.4	6.3	6.7	6.6	6.3	6.5	6.7	6.6	6.1	Avg:	6.5	10
21:00	6.5	6.5	6.6	6.2	6.4	6.0	6.6	6.5	5.9	6.3	Avg:	6.4	10
22:00	6.4	6.4	6.4	6.2	6.4	6.5	6.4	6.6	6.4	6.7	Avg:	6.5	10
23:00	6.6	6.8	6.7	6.8	6.3	6.7	6.8	7.0	6.4	6.2	Avg:	6.6	10

Daily Average: 6.5 Count: 238 Max: 17.0

SO₂, CO₂, NO_x 1215-1300 CAL. DRAWING. m R.

Company: St. Johns Unit 1
 Source : Unit 1 8-8-95

Location:
 Channel : 10acity Units: %

00:00	6.5	6.9	6.7	5.6	6.8	6.7	5.0	6.9	6.8	5.2	Avg:	6.3 10
01:00	9.8ZC	17.7SC	6.8	5.7	7.1	6.6	4.6	6.5	6.5	4.7	Avg:	6.1 8
02:00	6.2	7.3	5.8	5.9	6.4	7.1	4.8	7.1	6.9	4.8	Avg:	6.2 10
03:00	6.6	6.9	6.1	5.8	7.1	6.8	5.1	7.5	6.9	5.0	Avg:	6.4 10
04:00	6.2	7.1	5.9	5.6	6.5	7.2	4.7	6.9	6.7	5.1	Avg:	6.2 10
05:00	6.5	6.9	5.6	6.2	6.8	6.7	4.6	7.0	6.7	4.8	Avg:	6.2 10
06:00	6.4	6.9	5.9	5.6	7.0	6.8	5.3	6.8	6.5	4.8	Avg:	6.2 10
07:00	6.7	6.8	5.3	6.3	6.9	6.7	5.2	6.7	6.8	4.9	Avg:	6.2 10
08:00	7.0	7.3	5.3	6.9	7.1	6.5	5.2	7.1	7.2	5.0	Avg:	6.5 10
09:00	6.7	7.1	5.1	6.6	7.0	6.4	5.1	7.2	6.8	4.9	Avg:	6.3 10
10:00	6.7	6.9	5.5	6.5	6.8	6.4	5.2	7.2	6.9	5.0	Avg:	6.3 10
11:00	7.0	7.1	5.4	6.7	7.3	7.1	5.4	7.3	6.9	4.9	Avg:	6.5 10
12:00	7.6	7.1	5.2	6.8	7.6	6.4	6.1	6.8	6.9	4.9	Avg:	6.5 10
13:00	7.6	7.5	5.2	6.6	8.0	6.2	6.1	7.0	7.4	5.1	Avg:	6.7 10
14:00	7.6	7.1	5.4	6.7	7.1	5.9	6.0	7.1	7.0	4.8	Avg:	6.5 10
15:00	7.2	7.0	5.1	6.4	6.8	6.1	5.7	7.2	7.3	5.1	Avg:	6.4 10
16:00	6.9	7.1	5.9	7.4	7.9	6.4	6.0	7.5	7.7	5.4	Avg:	6.8 10
17:00	7.6	7.5	5.7	7.2	7.9	6.8	6.4	6.1	6.4	6.7	Avg:	6.8 10
18:00	6.2	6.8	6.2	6.5	6.5	6.4	5.9	6.0	6.3	6.5	Avg:	6.3 10
19:00	6.0	5.7	5.9	6.0	5.9	6.1	5.7	5.6	6.0	6.1	Avg:	5.9 10
20:00	6.0	6.0	6.0	6.1	5.6	6.0	5.9	5.8	5.8	5.6	Avg:	5.9 10
21:00	5.5	5.8	6.0	5.6	5.2	5.1	5.2	5.5	5.5	5.5	Avg:	5.5 10
22:00	5.2	5.4	5.3	5.6	5.8	5.5	5.3	5.0	5.4	5.9	Avg:	5.5 10
23:00	5.4	5.2	5.4	5.5	5.3	5.4	5.8	5.6	5.7	5.2	Avg:	5.5 10

Daily Average: 6.2 Count: 238 Max: 8.0

NOx > 5 < 10 0007 - 0430 APP. B PART 75
 SO2, CO2 ~~NOx~~ 0300 - 0345 OTHER

Company: St. Johns Unit 1
 Source : Unit 1 5-9-95

Location:
 Channel : 10capacity Units: %

00:00	5.2	5.7	5.2	5.2	5.7	6.0	5.5	5.4	5.4	5.8	Avg:	5.5	10
01:00	9.92C	16.4SC	5.5	5.7	6.1	5.6	5.7	5.8	5.5	5.5	Avg:	5.7	8
02:00	5.1	6.3	5.6	5.6	5.8	5.7	5.6	5.3	5.7	5.5	Avg:	5.6	10
03:00	5.8	5.4	5.4	5.8	5.4	5.4	5.6	5.7	5.7	6.0	Avg:	5.6	10
04:00	6.1	6.0	5.5	5.7	5.8	5.6	5.9	5.8	5.8	5.8	Avg:	5.8	10
05:00	6.0	5.4	5.9	5.7	5.8	6.5	6.1	5.5	6.1	6.1	Avg:	5.9	10
06:00	6.1	6.3	5.6	5.8	5.5	5.5	5.6	5.6	6.5	6.1	Avg:	5.9	10
07:00	5.8	5.6	5.8	5.4	5.9	5.5	5.6	5.7	5.8	6.2	Avg:	5.7	10
08:00	5.8	5.5	5.9	6.0	6.2	5.8	5.7	6.3	5.7	6.2	Avg:	5.9	10
09:00	5.8	5.8	5.9	5.5	5.9	6.5	6.2	6.3	6.0	6.3	Avg:	6.0	10
10:00	5.8	5.8	6.0	5.6	5.5	6.0	5.8	6.8	6.0	6.2	Avg:	6.0	10
11:00	6.0	6.0	6.4	5.8	5.6	6.0	6.0	5.9	6.2	6.2	Avg:	6.0	10
12:00	6.2	5.9	5.9	6.1	5.8	6.1	6.1	6.0	6.1	5.9	Avg:	6.0	10
13:00	6.0	5.9	6.1	6.3	6.3	6.3	6.5	6.3	6.4	6.4	Avg:	6.2	10
14:00	6.2	7.1	6.0	6.1	5.8	6.0	6.2	7.4	6.1	6.1	Avg:	6.3	10
15:00	6.2	6.1	5.9	7.0	6.0	6.1	6.3	5.8	6.0	6.2	Avg:	6.2	10
16:00	5.9	6.2	6.1	6.3	6.7	5.9	6.3	6.2	6.5	5.9	Avg:	6.2	10
17:00	6.5	6.0	6.7	6.3	6.2	6.6	6.9	6.3	5.9	6.2	Avg:	6.4	10
18:00	6.0	6.6	6.3	6.4	6.2	5.8	5.8	6.0	6.3	6.2	Avg:	6.2	10
19:00	6.1	6.1	5.9	5.9	5.8	6.0	6.0	6.3	5.7	6.0	Avg:	6.0	10
20:00	5.9	5.8	5.9	5.7	6.2	5.9	6.0	6.0	6.1	5.7	Avg:	5.9	10
21:00	5.9	5.6	6.1	6.3	6.0	5.7	6.0	6.2	6.0	5.9	Avg:	6.0	10
22:00	6.0	5.5	6.1	6.1	5.9	6.3	6.2	6.2	6.0	5.8	Avg:	6.0	10
23:00	6.1	6.0	5.8	6.1	5.9	6.1	5.9	5.9	6.3	6.5	Avg:	6.1	10

Daily Average: 6.0 Count: 238 Max: 7.4

0415
 N10x 0007-~~0000~~ APP. B - PART 75

Company: St. Johns Unit 1

Location:

Source : Unit 1

Channel : 1Opacity

Units: %

00:00	6.3	5.8	5.7	5.8	5.8	6.2	6.1	6.1	5.8	6.0	Avg:	6.0 10
01:00	14.5IC	11.6SC	6.3	5.8	5.6	5.9	5.4	6.0	5.8	5.9	Avg:	5.9 8
02:00	6.9	6.1	6.0	5.6	6.0	5.8	5.8	5.5	6.1	5.3	Avg:	5.9 10
03:00	6.8	5.7	5.7	5.7	5.4	5.7	5.6	5.5	5.9	5.4	Avg:	5.7 10
04:00	5.7	5.6	5.6	5.6	5.9	5.7	5.7	5.6	5.7	5.7	Avg:	5.7 10
05:00	5.6	6.2	5.6	5.9	6.0	5.9	6.0	5.4	5.3	6.2	Avg:	5.8 10
06:00	5.5	5.5	5.5	5.9	6.1	5.9	5.7	6.1	5.9	5.9	Avg:	5.8 10
07:00	5.8	6.1	6.0	5.8	5.9	5.6	5.7	5.8	5.7	5.8	Avg:	5.8 10
08:00	5.7	5.7	6.3	5.8	6.2	5.8	5.8	5.7	5.8	6.4	Avg:	5.9 10
09:00	5.7	5.7	5.8	5.9	5.5	5.9	5.8	5.8	5.5	5.9	Avg:	5.7 10
10:00	5.7	5.5	6.0	5.8	5.8	6.1	5.9	6.0	6.3	6.7	Avg:	6.0 10
11:00	6.4	6.2	6.3	5.8	6.0	6.1	6.0	6.1	6.3	6.3	Avg:	6.1 10
12:00	6.3	6.7	6.3	5.9	6.2	6.1	5.8	6.1	5.6	6.3	Avg:	6.1 10
13:00	5.9	5.7	6.1	6.2	6.2	6.1	6.0	6.2	6.0	6.8	Avg:	6.1 10
14:00	6.4	6.2	5.9	6.0	5.9	5.9	5.8	5.9	5.8	6.0	Avg:	6.0 10
15:00	5.8	5.8	6.2	6.0	6.5	6.2	6.3	6.4	6.4	6.2	Avg:	6.2 10
16:00	6.2	6.5	6.8	6.7	7.3	6.9	6.5	6.6	6.4	6.4	Avg:	6.6 10
17:00	6.8	6.7	6.5	6.9	6.5	6.7	6.9	6.8	6.7	6.6	Avg:	6.7 10
18:00	6.4	6.5	6.5	6.5	6.4	6.6	6.7	7.0	6.6	6.2	Avg:	6.5 10
19:00	6.5	6.8	6.3	6.5	6.7	6.2	6.3	6.2	7.1	6.4	Avg:	6.5 10
20:00	6.7	6.7	6.6	6.7	6.8	6.7	6.5	6.8	6.5	6.5	Avg:	6.6 10
21:00	7.1	6.7	6.7	6.8	6.2	6.3	6.6	6.7	6.2	6.2	Avg:	6.5 10
22:00	6.6	6.2	6.3	6.6	6.5	6.6	6.1	6.6	5.9	6.2	Avg:	6.4 10
23:00	6.4	5.8	6.1	6.4	6.4	7.7	6.6	6.6	6.6	6.1	Avg:	6.5 10

Daily Average: 6.1 Count: 238 Max: 7.7

SO2 1315-1330 u.E.

NOx 1615-1645 u.E.

SO2, NOx 1800-1815 u.E.

Company: St. Johns Unit 1

Location:

Source : Unit 1

Channel : 1Opacity

Units: %

00:00	6.4	6.2	6.0	6.7	6.2	6.3	6.5	6.3	6.6	5.9IC	Avg:	6.3	9
01:00	13.2IC	11.1SC	5.8	6.0	6.1	6.1	6.0	5.5	5.4	6.4	Avg:	5.9	8
02:00	5.9	6.8	5.8	6.1	5.8	5.8	6.1	5.3	5.6	5.5	Avg:	5.9	10
03:00	5.6	5.8	6.1	6.0	6.1	5.7	5.7	5.5	5.6	6.1	Avg:	5.8	10
04:00	5.5	5.8	5.8	6.2	6.4	5.7	5.8	5.8	5.9	6.1	Avg:	5.9	10
05:00	5.8	5.9	5.9	5.9	6.2	6.2	5.7	6.3	5.7	5.6	Avg:	5.9	10
06:00	6.4	5.8	6.3	5.8	5.8	5.8	5.9	5.8	6.1	6.1	Avg:	6.0	10
07:00	5.9	5.9	5.9	6.0	5.7	5.8	5.4	5.8	5.6	5.6	Avg:	5.8	10
08:00	6.2	5.8	5.6	6.2	5.5	5.9	5.3	5.4	5.8	5.7	Avg:	5.7	10
09:00	6.2	5.5	5.9	6.2	5.6	5.8	5.9	5.6	5.9	5.7	Avg:	5.8	10
10:00	5.9	5.7	5.3	5.6	5.2	5.6	5.6	5.3	5.7	6.3	Avg:	5.6	10
11:00	6.2	6.5	5.9	6.0	5.8	5.7	6.2	5.9	5.8	6.2	Avg:	6.0	10
12:00	6.1	6.3	5.5	5.8	5.9	6.0	5.8	5.8	5.8	6.2	Avg:	5.9	10
13:00	6.4	6.3	6.6	6.5	6.8	6.3	6.6	6.5	6.0	6.3	Avg:	6.4	10
14:00	6.4	6.0	6.3	6.0	6.3	5.9	6.2	6.5	6.0	6.3	Avg:	6.2	10
15:00	5.9	5.9	6.3	6.0	6.0	6.1	6.1	6.1	6.1	6.2	Avg:	6.1	10
16:00	5.9	6.2	6.0	6.1	6.0	6.4	6.1	6.3	6.2	6.2	Avg:	6.1	10
17:00	5.9	6.4	6.3	6.5	6.6	6.3	6.7	6.6	6.4	6.2	Avg:	6.4	10
18:00	6.2	6.2	6.3	6.5	6.5	6.5	6.5	6.4	6.1	6.4	Avg:	6.4	10
19:00	6.2	6.2	6.2	6.0	6.3	6.0	6.0	6.6	6.5	6.3	Avg:	6.2	10
20:00	6.4	6.1	6.3	5.9	6.1	6.2	6.1	6.2	6.0	6.1	Avg:	6.1	10
21:00	6.1	6.3	6.1	5.9	5.9	6.2	5.9	6.5	5.7	6.4	Avg:	6.1	10
22:00	5.8	5.7	6.3	5.8	5.7	6.0	5.7	5.6	5.7	5.5	Avg:	5.8	10
23:00	6.1	5.8	5.9	6.0	5.8	5.9	6.0	5.8	5.9	6.0	Avg:	5.9	10

Daily Average: 6.0 Count: 237 Max: 6.8

Company: St. Johns Unit 1

Location:

Source : Unit 1

Channel : 1Opacity

Units: %

00:00	5.6	5.8	6.1	5.9	6.0	6.2	5.8	5.9	6.1	11.6IC	Avg:	5.9	9
01:00	13.2IC	12.2SC	6.6	7.0	6.2	6.1	6.2	5.9	6.2	6.3	Avg:	6.3	8
02:00	6.0	6.3	5.9	6.1	6.1	5.9	6.5	5.8	6.2	6.3	Avg:	6.1	10
03:00	5.8	6.6	5.7	6.4	6.3	5.7	6.0	5.7	5.3	5.9	Avg:	5.9	10
04:00	5.6	6.1	6.3	5.8	5.9	5.8	5.8	5.1	5.4	5.8	Avg:	5.8	10
05:00	5.5	6.0	5.8	5.6	6.0	5.3	5.8	5.4	5.4	5.9	Avg:	5.7	10
06:00	5.7	5.8	6.1	5.7	6.2	5.7	6.0	5.6	5.5	5.8	Avg:	5.8	10
07:00	5.7	5.5	5.6	6.1	5.9	5.4	5.8	6.0	5.6	5.8	Avg:	5.7	10
08:00	6.1	5.6	6.1	5.4	5.5	5.9	5.2	6.1	5.5	5.6	Avg:	5.7	10
09:00	5.9	5.6	6.9	6.1	5.5	6.0	5.5	5.6	5.8	5.3	Avg:	5.8	10
10:00	5.4	5.4	5.6	5.5	5.2	5.9	5.5	5.8	5.8	5.5	Avg:	5.6	10
11:00	7.7	5.5	5.7	5.7	5.8	5.9	5.7	5.8	5.9	5.6	Avg:	5.9	10
12:00	6.5	5.8	5.5	6.1	5.4	5.6	5.7	5.8	5.6	5.8	Avg:	5.8	10
13:00	5.8	6.0	5.5	5.7	5.6	5.9	6.4	5.9	6.8	6.9	Avg:	6.1	10
14:00	5.8	6.1	6.0	6.0	6.1	6.1	6.9	6.4	6.1	6.4	Avg:	6.2	10
15:00	6.4	6.2	6.1	6.3	6.5	6.4	6.4	6.5	6.1	6.3	Avg:	6.3	10
16:00	6.4	6.5	6.4	6.3	6.4	6.3	6.4	6.4	6.0	6.4	Avg:	6.3	10
17:00	6.1	6.1	6.6	6.1	6.3	6.4	6.7	7.1	6.3	6.4	Avg:	6.4	10
18:00	6.3	6.2	6.1	6.0	6.0	6.3	6.1	6.3	6.0	5.7	Avg:	6.1	10
19:00	6.2	5.8	6.1	6.0	6.1	6.4	6.5	6.0	6.4	6.3	Avg:	6.2	10
20:00	6.3	6.1	5.7	6.1	5.8	6.1	6.1	5.5	5.7	6.0	Avg:	6.0	10
21:00	6.3	6.2	6.0	6.2	6.1	6.0	6.7	6.4	6.1	6.6	Avg:	6.3	10
22:00	6.2	6.0	5.9	6.6	6.4	6.1	5.8	5.4	5.6	5.9	Avg:	6.0	10
23:00	5.8	5.8	5.7	5.8	6.3	5.7	6.1	6.0	5.9	6.0	Avg:	5.9	10

Daily Average: 6.0 Count: 237 Max:

7.7

Company: St. Johns Unit 1

Location:

Source : Unit 1

Channel : 1Opacity

Units: %

00:00	5.7	6.0	5.9	5.5	5.9	6.0	5.5	6.3	5.3	11.1IC	Avg:	5.8	9
01:00	11.8IC	10.9SC	6.1	5.9	6.3	6.8	5.8	6.6	6.6	6.1	Avg:	6.3	8
02:00	5.5	6.0	6.5	5.8	5.7	6.1	5.6	5.8	5.5	5.8	Avg:	5.8	10
03:00	6.0	5.7	5.7	6.5	6.0	6.1	5.9	6.3	6.1	6.0	Avg:	6.0	10
04:00	5.8	5.7	5.7	5.7	5.8	5.9	5.6	5.7	5.6	5.3	Avg:	5.7	10
05:00	5.7	5.5	5.3	5.8	5.5	5.6	6.3	5.9	6.1	6.0	Avg:	5.8	10
06:00	5.9	5.6	5.3	5.7	6.2	5.6	5.5	5.4	5.3	5.7	Avg:	5.6	10
07:00	6.0	5.7	6.0	6.8	6.4	6.4	6.3	6.2	6.4	6.2	Avg:	6.2	10
08:00	6.0	6.1	6.2	6.8	6.4	5.9	5.8	6.3	6.1	6.0	Avg:	6.2	10
09:00	5.9	6.0	5.9	6.1	6.3	6.0	6.2	6.0	6.3	6.0	Avg:	6.1	10
10:00	6.2	5.9	5.9	6.0	5.8	5.7	6.2	5.7	5.7	6.0	Avg:	5.9	10
11:00	5.9	6.4	5.9	5.6	5.7	6.1	6.3	5.7	6.0	6.3	Avg:	6.0	10
12:00	5.9	6.2	6.0	5.9	6.2	6.1	5.8	5.8	5.8	6.1	Avg:	6.0	10
13:00	5.9	6.7	6.0	6.1	6.6	6.0	6.3	7.1	6.4	7.7	Avg:	6.5	10
14:00	7.0	6.6	6.7	6.4	6.4	7.0	6.6	6.6	6.8	6.6	Avg:	6.7	10
15:00	7.0	6.6	7.1	6.8	6.8	6.7	6.6	6.9	6.6	6.7	Avg:	6.8	10
16:00	7.5	7.1	7.1	7.3	6.8	6.7	7.5	7.0	6.8	6.9	Avg:	7.1	10
17:00	6.9	6.8	6.8	7.1	6.5	7.0	7.3	6.5	7.0	6.6	Avg:	6.9	10
18:00	6.9	6.7	6.7	6.8	6.6	6.9	6.9	6.7	6.8	7.0	Avg:	6.8	10
19:00	7.0	6.8	6.5	6.6	6.9	6.3	6.7	6.9	6.9	6.8	Avg:	6.7	10
20:00	6.5	6.7	6.5	6.5	6.4	6.6	6.3	6.8	6.4	6.5	Avg:	6.5	10
21:00	6.7	6.3	6.6	6.0	6.5	6.3	6.3	6.5	6.3	6.5	Avg:	6.4	10
22:00	6.4	6.2	6.6	6.3	6.3	6.2	6.3	5.9	6.1	6.5	Avg:	6.3	10
23:00	6.2	5.7	5.9	5.8	6.2	6.7	6.2	5.7	6.8	6.3	Avg:	6.1	10

Daily Average: 6.3 Count: 237 Max: 7.7

NOx 0007-24cc ~~Cap.F.-P.i~~
>1090

Company: St. Johns Unit 1

Location:

Source : Unit 1

Channel : 10Capacity

Units: %

00:00	6.7	6.5	5.5	5.6	5.8	5.5	6.4	6.3	6.1	11.6IC	Avg:	6.1	9
01:00	11.7IC	11.5SC	5.8	6.7	5.9	6.2	6.4	6.2	6.1	7.6	Avg:	6.4	8
02:00	6.3	7.2	5.9	5.9	6.5	5.8	6.3	6.0	6.1	6.6	Avg:	6.2	10
03:00	5.7	6.2	6.6	5.9	6.6	6.2	7.0	6.8	6.2	6.5	Avg:	6.4	10
04:00	6.1	5.8	6.2	6.3	6.6	5.8	5.5	6.1	5.9	6.0	Avg:	6.0	10
05:00	6.2	5.4	5.9	5.7	5.8	5.8	5.8	6.3	6.5	5.9	Avg:	5.9	10
06:00	5.9	5.8	6.1	5.3	5.8	6.2	6.0	5.9	6.2	6.4	Avg:	6.0	10
07:00	6.5	5.8	6.3	6.1	6.0	6.7	6.0	6.6	6.4	6.2	Avg:	6.3	10
08:00	5.6	6.1	5.8	6.0	5.8	6.4	6.2	5.7	5.9	5.5	Avg:	5.9	10
09:00	6.6	5.8	5.7	6.2	5.6	6.3	6.3	5.9	6.2	6.0	Avg:	6.1	10
10:00	5.7	6.0	6.0	6.2	5.9	5.9	6.3	6.0	6.2	6.0	Avg:	6.0	10
11:00	5.7	6.2	5.7	5.9	6.6	6.2	6.4	6.3	6.7	6.1	Avg:	6.2	10
12:00	6.1	5.9	6.2	6.0	6.3	6.2	6.4	6.0	5.9	6.0	Avg:	6.1	10
13:00	5.9	6.2	6.3	6.3	6.7	6.2	6.7	6.3	6.0	6.7	Avg:	6.3	10
14:00	6.3	6.3	6.2	6.0	6.0	7.5	7.1	6.3	6.3	6.6	Avg:	6.4	10
15:00	6.3	6.5	6.3	6.5	6.7	6.7	6.7	6.3	6.3	6.5	Avg:	6.5	10
16:00	5.8	8.5	7.4	7.4	8.2	7.4	7.9	7.5	7.6	8.5	Avg:	7.6	10
17:00	7.6	7.5	7.9	7.8	8.2	8.3	8.5	8.1	7.4	8.0	Avg:	7.9	10
18:00	7.7	7.8	7.6	8.4	7.8	7.0	7.5	7.5	6.7	7.7	Avg:	7.6	10
19:00	7.2	7.5	7.5	7.5	7.7	7.2	7.8	7.5	7.0	7.6	Avg:	7.4	10
20:00	6.7	7.6	7.2	7.0	7.7	7.1	7.5	7.4	6.7	7.8	Avg:	7.3	10
21:00	6.9	6.8	7.9	6.8	7.2	6.7	7.1	7.5	6.6	7.6	Avg:	7.1	10
22:00	6.2	6.3	7.3	6.3	6.4	6.3	6.3	7.2	6.3	6.9	Avg:	6.6	10
23:00	6.1	5.8	6.9	5.7	6.3	6.0	6.0	6.9	5.8	7.2	Avg:	6.3	10

Daily Average: 6.5 Count: 237 Max: 8.5

NOx 9907-0215 AP.B - AP.F.

Company: St. Johns Unit 1

Location:

Source : ~~Unit 1~~

Channel : 1Opacity

Units: %

00:00	6.5	6.3	7.2	6.2	7.0	6.6	6.5	6.8	6.3	11.8IC	Avg:	6.6	9
01:00	11.6IC	6.6	7.7	6.1	6.8	6.8	6.8	7.1	7.0	6.5	Avg:	6.8	9
02:00	6.8	6.3	7.0	6.5	6.7	6.6	6.9	6.6	6.0	6.2	Avg:	6.5	10
03:00	7.1	6.4	7.0	6.3	7.0	7.7	6.5	7.1	6.6	7.2	Avg:	6.9	10
04:00	7.4	6.8	7.1	6.4	6.6	7.1	6.1	6.9	6.4	6.1	Avg:	6.7	10
05:00	7.6	7.1	6.9	6.7	6.2	7.1	6.6	7.5	6.4	6.6	Avg:	6.9	10
06:00	7.6	6.7	7.1	6.8	6.5	7.5	6.5	6.7	6.6	6.5	Avg:	6.9	10
07:00	7.2	6.3	6.9	7.2	6.5	7.8	6.1	7.2	6.6	7.1	Avg:	6.9	10
08:00	7.2	6.0	7.2	7.6	6.4	7.3	6.4	7.7	6.6	6.1	Avg:	6.8	10
09:00	6.0	5.8	5.7	5.8	4.8	7.2	6.6	5.9	5.9	6.3	Avg:	6.0	10
10:00	6.0	5.7	5.6	6.2	5.8	5.8	5.6	6.0	5.6	5.7	Avg:	5.8	10
11:00	5.5	5.9	5.7	5.7	5.6	5.7	5.5	5.4	5.2	5.3	Avg:	5.5	10
12:00	5.2	5.4	5.2	5.6	6.1	5.6	5.0	5.6	5.6	5.1	Avg:	5.4	10
13:00	5.5	5.2	5.1	5.6	5.2	5.4	5.8	5.2	5.4	5.3	Avg:	5.4	10
14:00	5.1	5.4	5.5	5.9	6.0	6.1	5.9	5.7	6.3	6.2	Avg:	5.8	10
15:00	5.8	5.9	6.0	6.1	5.5	5.3	6.1	5.6	5.5	5.4	Avg:	5.7	10
16:00	5.6	6.1	5.7	5.5	5.6	5.4	5.4	5.5	5.2	5.5	Avg:	5.5	10
17:00	5.5	5.3	5.7	5.5	5.5	5.3	5.3	5.9	5.6	5.9	Avg:	5.5	10
18:00	5.8	5.6	5.8	5.5	5.4	5.9	5.3	5.6	5.7	6.0	Avg:	5.6	10
19:00	7.2	5.5	5.8	6.3	5.3	5.5	5.7	5.4	5.8	5.4	Avg:	5.8	10
20:00	5.9	7.3	6.2	7.0	5.2	5.7	5.5	5.1	5.5	5.2	Avg:	5.9	10
21:00	5.5	5.5	5.5	5.2	5.0	5.1	5.0	5.1	5.0	5.1	Avg:	5.2	10
22:00	5.0	5.3	5.5	5.2	5.5	5.4	4.8	4.9	4.8	5.0	Avg:	5.1	10
23:00	5.2	4.7	4.9	4.4	4.4	5.3	5.1	5.1	5.1	4.7	Avg:	4.9	10

Daily Average: 6.0 Count: 238 Max:

7.8

NOx 25 LIC - APP. B (PART 75) 0007-0215

11 0945-1000 A.E.

502-002 NOx 1330-1430 A.E.

Company: St. Johns Unit 1

Location:

Source : Unit 1

Channel : 1Opacity

Units: %

00:00	6.2	5.3	4.7	4.8	4.4	4.8	4.8	4.8	5.1	10.1IC	Avg:	5.0	9
01:00	14.3IC	4.9	4.7	4.7	4.7	5.0	4.8	4.6	4.8	4.8	Avg:	4.8	9
02:00	5.2	5.3	4.5	4.9	4.8	4.7	4.7	4.8	4.8	4.8	Avg:	4.9	10
03:00	5.5	5.3	5.9	4.8	5.0	4.8	5.2	5.4	5.0	4.8	Avg:	5.2	10
04:00	5.2	4.7	4.9	4.5	5.4	4.7	4.4	4.9	4.5	4.6	Avg:	4.8	10
05:00	5.3	4.5	5.0	4.5	4.5	4.8	5.0	5.1	4.7	4.7	Avg:	4.8	10
06:00	5.2	4.5	4.8	4.4	4.6	4.9	4.3	4.8	4.8	4.8	Avg:	4.7	10
07:00	5.2	4.3	4.6	5.1	4.6	5.3	5.7	5.7	5.7	6.1	Avg:	5.2	10
08:00	5.7	5.5	5.1	5.4	4.8	5.5	5.4	5.5	5.6	5.8	Avg:	5.4	10
09:00	5.5	5.1	5.1	6.2	5.5	5.6	5.6	5.4	5.8	5.9	Avg:	5.6	10
10:00	5.3	5.8	5.4	5.5	5.3	5.3	5.5	5.4	5.4	5.9	Avg:	5.5	10
11:00	5.3	5.9	5.1	5.5	5.2	5.2	5.5	5.3	6.0	6.1	Avg:	5.5	10
12:00	5.4	5.5	5.3	5.4	5.4	5.0	5.5	5.2	5.5	5.7	Avg:	5.4	10
13:00	5.2	5.5	5.3	5.2	5.5	5.5	5.7	5.3	5.8	6.2	Avg:	5.5	10
14:00	6.0	5.6	5.8	5.8	6.1	5.9	5.5	5.6	5.5	6.2	Avg:	5.8	10
15:00	5.8	6.0	6.3	5.6	5.9	5.8	6.2	6.2	6.2	6.2	Avg:	6.0	10
16:00	6.2	6.1	6.3	6.4	6.4	6.2	6.2	6.3	6.1	6.3	Avg:	6.3	10
17:00	6.4	6.4	6.2	6.4	6.2	6.6	6.8	6.5	6.6	6.2	Avg:	6.4	10
18:00	6.8	6.6	6.1	6.6	5.9	6.0	6.2	6.1	6.3	6.2	Avg:	6.3	10
19:00	6.3	6.2	6.1	6.2	6.1	6.4	6.3	6.1	6.5	6.3	Avg:	6.3	10
20:00	6.0	6.1	5.7	5.8	5.7	5.8	6.3	6.1	6.3	6.0	Avg:	6.0	10
21:00	6.8	5.9	5.9	6.2	6.1	6.3	6.1	6.0	6.6	6.7	Avg:	6.3	10
22:00	6.2	6.3	5.8	6.0	6.3	5.9	5.9	5.8	6.0	6.0	Avg:	6.0	10
23:00	6.4	6.3	5.8	6.1	5.5	6.2	6.0	6.0	6.2	6.5	Avg:	6.1	10

Daily Average: 5.6 Count: 238 Max: 6.8

SO2, CO2, NOx 1245-1360 u2.
1445-1515 u2.

Company: St. Johns Unit 1

Location:

Source : Unit 1

Channel : 1Opacity

Units: %

00:00	5.8	6.0	5.7	5.6	5.8	6.0	6.0	5.6	6.1	11.9IC	Avg:	5.8	9
01:00	8.9IC	6.8	6.0	5.7	6.0	6.4	7.1	6.1	8.3	7.2	Avg:	6.6	9
02:00	6.1	6.3	6.1	6.0	5.7	5.8	5.5	6.1	5.9	6.4	Avg:	6.0	10
03:00	5.6	5.7	5.6	5.4	6.0	5.6	5.4	6.2	5.4	6.1	Avg:	5.7	10
04:00	5.3	5.4	5.2	5.0	5.0	5.2	5.1	4.9	6.1	5.3	Avg:	5.2	10
05:00	5.0	5.5	5.8	6.2	6.0	6.3	5.6	6.2	6.5	5.6	Avg:	5.9	10
06:00	5.9	5.8	5.7	5.8	5.3	5.9	5.5	5.5	6.1	5.3	Avg:	5.7	10
07:00	5.4	5.3	5.7	5.4	4.6	10.2	5.5	9.5	9.2	6.8	Avg:	6.8	10
08:00	7.6	8.4	8.2	5.3	8.8	8.1	5.2	8.0	8.7	6.2	Avg:	7.4	10
09:00	6.6	7.9	8.2	5.1	7.9	8.1	5.4	8.4	8.6	6.1	Avg:	7.2	10
10:00	6.2	7.6	7.3	5.0	6.9	7.3	5.0	7.0	7.0	5.5	Avg:	6.5	10
11:00	5.8	6.9	6.2	5.3	6.8	7.1	4.8	6.8	6.8	5.2	Avg:	6.2	10
12:00	6.8	5.7	5.7	5.5	5.5	5.7	6.1	5.9	5.6	5.5	Avg:	5.8	10
13:00	5.4	6.0	5.5	5.6	5.7	5.5	5.4	5.7	5.5	6.0	Avg:	5.6	10
14:00	5.8	5.5	5.9	5.6	5.7	6.0	6.0	6.4	5.8	5.8	Avg:	5.8	10
15:00	6.0	6.0	6.4	5.7	6.0	6.6	6.1	6.5	6.1	6.0	Avg:	6.1	10
16:00	6.3	6.2	6.6	6.7	6.2	6.5	6.4	6.5	6.4	6.1	Avg:	6.4	10
17:00	6.6	6.5	6.3	6.6	6.6	7.0	7.1	6.6	6.8	6.5	Avg:	6.7	10
18:00	6.7	6.9	6.5	6.9	6.6	6.7	7.1	6.7	7.2	6.9	Avg:	6.8	10
19:00	6.9	7.3	6.7	6.7	6.8	6.8	7.5	6.5	6.9	7.0	Avg:	6.9	10
20:00	6.6	6.9	6.6	6.6	7.0	6.6	7.1	6.5	6.6	6.4	Avg:	6.7	10
21:00	6.3	6.4	6.7	6.8	6.4	6.4	6.9	6.8	6.8	6.6	Avg:	6.6	10
22:00	6.3	6.2	6.8	5.9	6.6	6.3	6.8	6.9	6.3	6.1	Avg:	6.4	10
23:00	6.0	6.0	6.9	5.7	6.1	6.6	6.9	5.9	6.6	6.6	Avg:	6.3	10

Daily Average: 6.3 Count: 238 Max: 10.2

NOx 0007-0215 APP. B - PART 75 > 5
1545-1600 U.E.

Company: St. Johns Unit 1
Source : Unit 1

Location:
Channel : 10pacity Units: %

5-15-75

Time	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
00:00	5.9	6.0	6.1	5.7	5.6	6.1	5.6	5.7	6.0	15.4IC	Avg:	5.9	9											
01:00	13.3IC	5.5	5.5	5.9	5.9	5.7	5.3	5.3	5.8	5.2	Avg:	5.6	9											
02:00	5.4	6.3	5.8	6.1	5.5	6.0	5.6	5.4	5.3	5.5	Avg:	5.7	10											
03:00	5.3	5.3	5.3	6.1	5.7	6.5	5.8	5.8	6.5	5.6	Avg:	5.8	10											
04:00	5.9	5.8	5.4	5.4	5.7	6.1	5.8	5.8	5.4	5.5	Avg:	5.7	10											
05:00	5.6	6.0	5.3	5.8	6.3	6.2	5.9	5.5	6.2	6.2	Avg:	5.9	10											
06:00	5.7	5.6	5.5	5.6	5.9	6.0	6.3	5.6	5.9	5.5	Avg:	5.8	10											
07:00	5.8	6.2	5.9	5.5	6.3	7.0	6.3	5.8	6.1	5.6	Avg:	6.0	10											
08:00	5.0	5.5	6.0	5.7	6.3	5.8	5.7	5.4	5.5	5.2	Avg:	5.6	10											
09:00	5.3	5.4	5.3	5.3	5.6	5.5	5.5	5.6	5.2	5.9	Avg:	5.5	10											
10:00	5.9	5.5	5.4	5.5	5.7	5.4	5.7	5.7	5.3	5.5	Avg:	5.5	10											
11:00	5.4	5.5	5.7	5.6	5.5	5.7	6.1	5.8	5.6	5.6	Avg:	5.7	10											
12:00	5.7	5.3	5.5	5.8	5.4	5.6	5.7	5.7	5.7	5.4	Avg:	5.6	10											
13:00	5.2	5.6	5.7	5.5	5.6	5.7	6.3	6.4	5.6	6.0	Avg:	5.7	10											
14:00	6.1	5.7	5.8	5.7	6.1	5.8	5.7	6.2	5.9	6.1	Avg:	5.9	10											
15:00	6.1	5.9	6.1	6.0	5.9	6.0	6.1	6.8	6.1	5.9	Avg:	6.1	10											
16:00	6.4	6.0	6.3	6.2	6.3	6.5	6.5	6.3	6.4	6.2	Avg:	6.3	10											
17:00	6.5	6.2	6.8	6.9	6.6	6.9	6.7	6.6	6.7	6.3	Avg:	6.6	10											
18:00	6.7	6.5	6.4	6.4	6.4	6.9	6.8	6.6	6.4	6.1	Avg:	6.5	10											
19:00	6.7	6.3	6.1	6.4	6.3	6.5	6.6	6.5	6.6	6.5	Avg:	6.5	10											
20:00	6.2	6.2	6.4	6.6	6.2	6.4	6.1	6.0	6.5	6.2	Avg:	6.3	10											
21:00	6.5	6.3	6.2	6.7	6.3	6.6	6.2	5.8	6.3	5.9	Avg:	6.3	10											
22:00	5.8	5.7	5.8	6.3	5.5	5.8	5.5	5.8	5.7	5.8	Avg:	5.8	10											
23:00	5.5	5.9	5.3	5.7	6.5	5.9	6.6	5.6	6.1	6.8	Avg:	6.0	10											

Daily Average: 5.9 Count: 238 Max: 7.0

NGx 0800-0900 u.e.
SO2, CO2 max 0915-1000 u.e.

Company: St. Johns Unit 1
Source : Unit 1 5-4-15

Location:
Channel : 10pacity Units: %

00:00	6.2	6.2	5.7	6.3	6.1	5.9	6.1	5.7	5.7	13.0IC	Avg:	6.0	9
01:00	8.9IC	5.9	5.9	6.7	6.0	6.9	6.2	6.0	6.7	6.8	Avg:	6.3	9
02:00	6.0	5.6	6.1	5.8	6.6	5.9	6.2	6.6	6.0	6.3	Avg:	6.1	10
03:00	6.2	5.8	6.6	6.3	6.5	6.5	6.3	6.5	7.3	5.9	Avg:	6.4	10
04:00	6.3	6.0	6.1	6.8	7.6	6.9	6.2	6.0	6.5	5.9	Avg:	6.4	10
05:00	6.4	6.3	5.7	6.9	6.7	6.4	7.3	5.8	6.6	6.4	Avg:	6.5	10
06:00	5.8	6.8	5.7	7.0	6.8	6.3	6.4	7.1	6.6	6.7	Avg:	6.5	10
07:00	5.8	6.4	6.3	6.8	6.8	6.1	6.5	7.1	6.5	6.8	Avg:	6.5	10
08:00	7.3	6.8	7.0	6.4	6.5	6.5	6.3	6.5	6.7	6.5	Avg:	6.7	10
09:00	7.1	7.7	7.4	6.6	6.8	6.5	6.5	6.5	6.6	6.1	Avg:	6.8	10
10:00	6.1	6.3	6.8	6.3	6.3	6.1	6.0	6.0	5.8	5.9	Avg:	6.2	10
11:00	6.3	7.1	6.1	6.2	5.6	6.5	6.3	6.5	6.2	6.1	Avg:	6.3	10
12:00	6.0	6.0	6.0	5.8	5.6	5.6	5.8	5.9	6.3	5.9	Avg:	5.9	10
13:00	5.9	5.7	6.1	5.9	5.6	5.9	6.3	5.9	6.2	6.2	Avg:	6.0	10
14:00	6.3	7.1	6.3	5.8	5.8	5.9	5.8	5.6	5.7	5.9	Avg:	6.0	10
15:00	6.3	6.7	6.2	5.8	6.3	6.1	5.9	6.2	6.5	6.3	Avg:	6.2	10
16:00	6.0	6.3	6.1	6.2	6.1	6.3	5.6	5.7	5.8	5.6	Avg:	6.0	10
17:00	5.7	6.3	5.9	5.8	5.6	5.9	6.2	7.6	7.4	6.3	Avg:	6.3	10
18:00	6.1	6.0	5.6	5.4	5.6	5.6	5.0	6.0	5.9	5.7	Avg:	5.7	10
19:00	6.4	9.0	5.8	6.1	5.5	6.3	5.6	5.9	5.8	5.4	Avg:	6.2	10
20:00	7.2	5.4	5.1	5.1	4.8	5.3	4.7	5.1	4.9	4.7	Avg:	5.2	10
21:00	6.0	5.0	5.1	5.2	4.9	5.0	5.2	4.9	5.3	5.1	Avg:	5.2	10
22:00	5.8	5.0	4.6	5.1	5.2	4.9	5.1	4.8	4.9	5.1	Avg:	5.1	10
23:00	5.5	5.1	4.9	5.3	5.4	5.5	6.3	5.7	5.6	5.5	Avg:	5.5	10

Daily Average: 6.1 Count: 238 Max: 9.0

ATTACHMENT E-2

RELATIVE ACCURACY
TEST REPORT
FOR
KVB
AT
S.J.R.P.P.
UNIT 1

November 17-19 & 21, 1994

94-489-FL



TOTAL SOURCE ANALYSIS, INC.

St. John's River Power Park

Unit 1 Outlet

RELATIVE ACCURACY - NOx lb/mmBtu

RATA TABLE 1

ANALYZER TYPE	NOx
MODEL NUMBER	42
MANUFACTURER	TECO
SERIAL NUMBER	42-49353-282
MEASUREMENT SPAN	1000 PPM
Fc FACTOR	1800
BOILER LOAD	650 MW

RUN USED	RUN NUMBER	RM NOx ppm	RM CO2 %	RM NOx lb/mmBtu	DATE	TIME	CEMS NOx ppm	CEMS CO2 %	CEMS NOx lb/mmBtu	DIFFERENCE lb/mmBtu
N	1	279.9	12.2	0.49	17-Nov-94	08:30-09:00	290.3	12.62	0.49	0.00
Y	2	277.9	11.9	0.50	17-Nov-94	09:20-09:50	282.9	12.27	0.50	0.00
Y	3	281.5	12.0	0.50	17-Nov-94	10:10-10:40	293.6	12.72	0.50	0.00
Y	4	289.3	12.1	0.51	17-Nov-94	11:10-11:40	298.4	12.76	0.50	0.01
Y	5	289.7	12.4	0.50	17-Nov-94	12:05-12:35	297.2	12.77	0.50	0.00
Y	6	286.2	11.9	0.52	17-Nov-94	13:25-13:55	298.3	12.74	0.50	0.02
Y	7	287.8	12.1	0.51	17-Nov-94	14:10-14:40	296.2	12.72	0.50	0.01
Y	8	283.8	12.2	0.50	17-Nov-94	15:05-15:35	302.6	12.71	0.51	-0.01
Y	9	300.7	12.4	0.52	17-Nov-94	16:05-16:35	304.9	12.72	0.52	0.00
Y	10	296.1	12.3	0.52	17-Nov-94	16:55-17:25	303.2	12.76	0.51	0.01
N	11	302.1	12.4	0.52	17-Nov-94	17:40-18:10	301.3	12.73	0.51	0.01
N	12	293.5	12.2	0.52	17-Nov-94	18:30-19:00	299.3	12.73	0.51	0.01

AVERAGE CEM VALUE	0.504
AVERAGE RM VALUE	0.509
MEAN DIFFERENCE	0.004
NUMBER OF RUNS	9
STANDARD DEVIATION	0.009
T - VALUE	2.306
CONFIDENCE COEFFICIENT	0.007
RELATIVE ACCURACY, %	2.16

Conversion Factor = 1.194 E-07

BIAS TEST	PASS
BIAS ADJUSTMENT FACTOR	1.000
NEXT TEST	ANNUAL

St. John's River Power Park

Unit 1 Outlet

RELATIVE ACCURACY CO2 ANALYZER

ANALYZER TYPE
 MODEL NUMBER
 MANUFACTURER
 SERIAL NUMBER
 MEASUREMENT SPAN
 BOILER LOAD

CO2	
41H	
TECO	
41H-49357-282	
20	%
650	MW

RATA TABLE 2

RUN USED	RUN NUMBER	RM DATA %	DATE	TIME	CEMS DATA %	DIFFERENCE % CO2
Y	1	12.2	17-Nov-94	08:30-09:00	12.6	-0.4
Y	2	11.9	17-Nov-94	09:20-09:50	12.3	-0.4
Y	3	12.0	17-Nov-94	10:10-10:40	12.7	-0.7
N	4	12.1	17-Nov-94	11:10-11:40	12.8	-0.7
Y	5	12.4	17-Nov-94	12:05-12:35	12.8	-0.4
N	6	11.9	17-Nov-94	13:25-13:55	12.7	-0.8
N	7	12.1	17-Nov-94	14:10-14:40	12.7	-0.6
Y	8	12.2	17-Nov-94	15:05-15:35	12.7	-0.5
Y	9	12.4	17-Nov-94	16:05-16:35	12.7	-0.3
Y	10	12.3	17-Nov-94	16:55-17:25	12.8	-0.5
Y	11	12.4	17-Nov-94	17:40-18:10	12.7	-0.3
Y	12	12.2	17-Nov-94	18:30-19:00	12.7	-0.5

AVERAGE CEM VALUE	12.67
AVERAGE RM VALUE	12.22
MEAN DIFFERENCE	-0.44
NUMBER OF RUNS	9
STANDARD DEVIATION	0.12
T - VALUE	2.306
CONFIDENCE COEFFICIENT	0.09
RELATIVE ACCURACY, %	4.34

St. John's River Power Park

Unit 1 Outlet

RELATIVE ACCURACY SO2 ANALYZER

RATA TABLE 3

ANALYZER TYPE	SO2
MODEL NUMBER	43H
MANUFACTURER	TECO
SERIAL NUMBER	43B-49122-282
MEASUREMENT SPAN	3500 PPM
BOILER LOAD	650 MW

RUN USED	RUN NUMBER	RM DATA ppm	DATE	TIME	CEMS DATA ppm	DIFFERENCE ppm
Y	1	141.5	17-Nov-94	08:30-09:00	142.0	-0.5
Y	2	136.7	17-Nov-94	09:20-09:50	139.0	-2.3
Y	3	140.0	17-Nov-94	10:10-10:40	144.0	-4.0
N	4	163.3	17-Nov-94	11:10-11:40	142.0	21.3
Y	5	140.7	17-Nov-94	12:05-12:35	150.0	-9.3
Y	6	130.7	17-Nov-94	13:25-13:55	140.0	-9.3
Y	7	142.9	17-Nov-94	14:10-14:40	142.0	0.9
Y	8	92.0	17-Nov-94	15:05-15:35	94.0	-2.0
N	9	169.2	17-Nov-94	16:05-16:35	147.0	22.2
Y	10	166.4	17-Nov-94	16:55-17:25	150.0	16.4
N	11	166.9	17-Nov-94	17:40-18:10	149.0	17.9
Y	12	163.8	17-Nov-94	18:30-19:00	150.0	13.8

AVERAGE CEM VALUE	139.00		
AVERAGE RM VALUE	139.41		
MEAN DIFFERENCE	0.41		
NUMBER OF RUNS	9		
STANDARD DEVIATION	9.06	BIAS TEST	PASS
T - VALUE	2.306	BIAS ADJUSTMENT FACTOR	1.000
CONFIDENCE COEFFICIENT	6.96		
RELATIVE ACCURACY, %	5.29	NEXT TEST	ANNUAL

St. John's River Power Park

Unit 1 Outlet

RELATIVE ACCURACY FLOW LOW LOAD

ANALYZER TYPE	FLOW
MODEL NUMBER	Ultraflow100
MANUFACTURER	USI
SERIAL NUMBER	R-08771U-0194
MEASUREMENT SPAN	144000000 scfh
BOILER LOAD	307 MW

RATA TABLE 4

RUN USED	RUN NUMBER	RM DATA scfh	DATE	TIME	CEMS DATA scfh	DIFFERENCE scfh
Y	1	56594400	18-Nov-94	22:00-22:25	60270000	-3675600
Y	2	56820800	18-Nov-94	22:30-22:55	59766000	-2945200
N	3	56538200	18-Nov-94	23:00-23:25	60846000	-4307800
Y	4	57604000	18-Nov-94	23:30-23:55	60474000	-2870000
N	5	56676900	19-Nov-94	00:00-00:25	61140000	-4463100
Y	6	56896200	19-Nov-94	00:30-00:55	60114000	-3217800
Y	7	56930300	19-Nov-94	01:00-01:25	60264000	-3333700
Y	8	56423000	19-Nov-94	01:30-01:55	60492000	-4069000
Y	9	56467800	19-Nov-94	02:00-02:25	60576000	-4108200
Y	10	56633000	19-Nov-94	02:30-02:55	60156000	-3523000
Y	11	56740100	19-Nov-94	03:00-03:25	60090000	-3349900
N						

AVERAGE CEM VALUE	60255750
AVERAGE RM VALUE	56809575
MEAN DIFFERENCE	-3446175
NUMBER OF RUNS	9
STANDARD DEVIATION	468409
T - VALUE	2.306
CONFIDENCE COEFFICIENT	360050
RELATIVE ACCURACY, %	6.70
BIAS TEST	PASS
BIAS ADJUSTMENT FACTOR	1.000
NEXT TEST	ANNUAL

St. John's River Power Park

Unit 1 Outlet

RELATIVE ACCURACY MID FLOW

ANALYZER TYPE
 MODEL NUMBER
 MANUFACTURER
 SERIAL NUMBER
 MEASUREMENT SPAN
 BOILER LOAD

FLOW	
Ultraflow100	
USI	
R-08771U-0194	
144000000	scfh
450	MW

RATA TABLE 5

RUN USED	RUN NUMBER	RM DATA scfh	DATE	TIME	CEMS DATA scfh	DIFFERENCE scfh
Y	1	72549000	19-Nov-94	05:00-05:25	76992000	-4443000
Y	2	72741000	19-Nov-94	05:30-05:55	77328000	-4587000
Y	3	72860100	19-Nov-94	06:00-06:25	77592000	-4731900
Y	4	72718600	19-Nov-94	06:30-06:55	77370000	-4651400
N	5	72188600	19-Nov-94	07:00-07:25	77436000	-5247400
Y	6	73290900	19-Nov-94	07:30-07:55	77922000	-4631100
Y	7	72769300	19-Nov-94	08:00-08:25	77202000	-4432700
Y	8	72696600	19-Nov-94	08:30-08:55	77634000	-4937400
Y	9	72631700	19-Nov-94	09:00-09:25	77226000	-4594300
Y	10	72646800	19-Nov-94	09:30-10:00	77016000	-4369200
N						
N						

AVERAGE CEM VALUE
 AVERAGE RM VALUE
 MEAN DIFFERENCE
 NUMBER OF RUNS
 STANDARD DEVIATION
 T - VALUE
 CONFIDENCE COEFFICIENT
 RELATIVE ACCURACY, %
 BIAS TEST
 BIAS ADJUSTMENT FACTOR
 NEXT TEST

77364667
72767111
-4597556
9
173530
2.306
133387
6.50
PASS
1.000
ANNUAL

St. John's River Power Park

Unit 1 Outlet

RELATIVE ACCURACY HIGH LOAD FLOW

ANALYZER TYPE
 MODEL NUMBER
 MANUFACTURER
 SERIAL NUMBER
 MEASUREMENT SPAN
 BOILER LOAD

FLOW	
Ultraflow100	
USI	
R-08771U-0194	
144000000	scfh
650	MW

RATA TABLE 6

RUN USED	RUN NUMBER	RM DATA scfh	DATE	TIME	CEMS DATA scfh	DIFFERENCE scfh
Y	1	90767400	17-Nov-94	08:30-09:00	95928000	-5160600
Y	2	90740100	17-Nov-94	09:20-09:50	96048000	-5307900
Y	3	91426700	17-Nov-94	10:10-10:40	95712000	-4285300
N	4	90410800	17-Nov-94	11:10-11:40	96402000	-5991200
Y	5	91297900	17-Nov-94	12:05-12:35	96144000	-4846100
N	6	106028300	17-Nov-94	13:25-13:55	96144000	9884300
Y	7	92663000	17-Nov-94	14:10-14:40	96486000	-3823000
Y	8	93143000	17-Nov-94	15:05-15:35	97848000	-4705000
Y	9	92152700	17-Nov-94	16:05-16:35	97482000	-5329300
Y	10	92531600	17-Nov-94	16:55-17:25	97920000	-5388400
Y	11	92229000	17-Nov-94	17:40-18:10	97452000	-5223000
N	12	92414600	17-Nov-94	18:30-19:00	98460000	-6045400

AVERAGE CEM VALUE	96780000
AVERAGE RM VALUE	91883489
MEAN DIFFERENCE	-4896511
NUMBER OF RUNS	9
STANDARD DEVIATION	540840
T - VALUE	2.306
CONFIDENCE COEFFICIENT	415726
RELATIVE ACCURACY, %	5.78
BIAS TEST	PASS
BIAS ADJUSTMENT FACTOR	1.000
NEXT TEST	ANNUAL

CGA Results

CGA/Linearity Set Name: CO2sk06/95

	Low	Mid	High
Avg Ref Val:	4.900	11.120	17.040
Avg Mon Val:	4.990	11.340	17.247
Results:	1.837	1.978	1.213
APS Flag:	0	0	0
#OOC Hrs:	0		

Exit

CGA / Linearity Test Data Entry

Calibrations on: loutCO2_C

120 - 123 Monitor/Component ID

Analyzer Range: 20.000

CGA Set Members

06/07/95 06:18

06/07/95 09:17

06/07/95 12:17

CGA Set Name: CO2sk06/95

Legend:

CAL In Net
 CGA Type Cal
 Non CGA Cal

Date/Time	Low	Mid	High
06/07/95 06:18	4.99	11.35	17.27
06/07/95 09:17	4.99	11.33	17.25
06/07/95 12:17	4.99	11.34	17.22
06/08/95 00:07	0.01	-99.99	17.16
06/09/95 00:07	0.01	-99.99	17.15
06/10/95 00:07	0.01	-99.99	17.17
06/11/95 00:07	0.01	-99.99	17.17
06/12/95 00:07	0.01	-99.99	17.19

Exit

Delete

Tester

View
Results

Save

CGA Results

CGA/Linearity Set Name: NOXsk06/95

	Low	Mid	High
Avg Ref Val:	252.000	554.000	858.000
Avg Mon Val:	258.500	555.100	849.567
Results:	2.579	0.199	0.983
APS Flag:	0	0	0
#OOC Hrs:	0		

Exit

CGA / Linearity Test Data Entry

Calibrations on: loutNOX_C

130-133 Monitor/Component ID

Analyzer Range: 1000.000

CGA Set Members

06/07/95 06:18

06/07/95 09:17

06/07/95 12:17

CGA Set Name: NOXsk06/95

Legend:

Cal III Set
CGA Type Cal
Non CGA Cal

Date/Time Low Mid High

06/07/95 06:18	289.60	556.20	850.20
06/07/95 09:17	288.80	555.90	851.40
06/07/95 12:17	287.60	553.20	847.10
06/08/95 00:07	0.20	-999.90	849.90
06/09/95 00:07	0.20	-999.90	858.00
06/10/95 00:07	0.20	-999.90	864.40
06/11/95 00:07	0.20	-999.90	859.50
06/12/95 00:07	0.20	-999.90	691.20

Exit

Delete

Tester

View
Results

Save

CGA Results

CGA/Linearity Set Name: SO2lo06/95

	Low	Mid	High
Avg Ref Val:	75.000	164.200	257.000
Avg Mon Val:	77.167	168.367	262.433
Results:	2.889	2.538	2.114
APS Flag:	0	0	0
#OOC Hrs:	0		

Exit

CGA / Linearity Test Data Entry

Calibrations on: loutSO2L_C 140-143 Monitor/Component ID

Analyzer Range: 300.000

CGA Set Members

06/07/95 06:18
06/07/95 09:17
06/07/95 12:17

CGA Set Name: SO2lo06/95

Legend:

Cal In Set
 CGA Type Cal
 Non CGA Cal

Date/Time	Low	Mid	High
06/07/95 06:18	75.40	167.50	261.40
06/07/95 09:17	77.30	168.30	262.90
06/07/95 12:17	77.80	169.30	263.00
06/08/95 00:07	1.20	-999.90	251.50
06/09/95 00:07	0.00	-999.90	249.30
06/10/95 00:07	0.00	-999.90	250.00
06/11/95 00:07	0.00	-999.90	249.40
06/12/95 00:07	-0.10	-999.90	248.00

Exit

Delete

Tester

View
Results

Save

CGA Results

CGA/Linearity Set Name: SO2h106/95

	Low	Mid	High
Avg Ref Val:	862.000	1939.000	2964.000
Avg Mon Val:	868.000	1913.000	2873.667
Results:	0.696	1.341	3.048
APS Flag:	0	0	0
#OOC Hrs:	0		

Exit

CGA / Linearity Test Data Entry

Calibrations on: loutSO2H_C 140 -143 Monitor/Component ID

Analyzer Range: 3500.000

CGA Set Name: SO2hi06/95

CGA Set Members

06/07/95 06:18

06/07/95 09:17

06/07/95 12:17

Legend:

Cal In Rel

CGA Type Cal

Non CGA Cal

Date/Time	Low	Mid	High
06/07/95 06:18	867.00	1915.00	2874.00
06/07/95 09:17	869.00	1910.00	2873.00
06/07/95 12:17	868.00	1914.00	2874.00
06/08/95 00:07	0.00	-9999.00	2982.00
06/09/95 00:07	0.00	-9999.00	2981.00
06/10/95 00:07	0.00	-9999.00	2990.00
06/11/95 00:07	0.00	-9999.00	2978.00
06/12/95 00:07	0.00	-9999.00	2972.00

Exit

Delete

Tester

View
Results

Save

ATTACHMENT E-3

SJRPP UNIT 1
 TEST BURN
 PETROLEUM COKE/BITUMINOUS COAL
 AIR EMISSIONS TEST

A) STACK TEST - BASELINE RESULTS

DATE	(3 RUN AVE.) PARTICULATE (lbs/MBN)	(3 RUN AVG.) SO ₃ (ppm)	(3 RUN AVG.) CO (ppm)
7/18/95	0.007	6.96	10.29
7/19/95	0.003	5.19	45.16
7/20/95	0.0096	5.55	67.00
8/8/95	0.009	7.04	21.15

B) STACK TEST - BLEND RESULTS

DATE	(3 RUN AVG.) PARTICULATE (lbs/MBN)	(3 RUN AVG.) SO ₃ (ppm)	(3 RUN AVG.) CO (ppm)
8/11/95	----	7.54	312.96
8/12/95	----	9.21	497.58
8/13/95	----	14.03	745.64
8/14/95	0.011	----	----
8/15/95	0.006	----	----
8/16/95	0.004	----	----
8/17/95	0.009	----	----
8/18/95	----	11.37	467.90
8/19/95	0.003	----	----

ATTACHMENT F

CERTIFIED MAIL



SJRO LC 95 094

June 14, 1995

Mr. Steve Pace
RESO
421 W. Church St.
Jacksonville, FL 32202

RE: Site Certification No. PA 81-13
St. Johns River Power Park (SJRPP) Unit I
Authorization of Test Burn Using Petroleum Coke with Coal
Request for Approval - Pollutants & Testing Methodology

Dear Mr. Pace:

The above referenced facility was authorized by your agency's March 30, 1995, letter to test burn a blend of petroleum coke with coal (Attachment A). Condition #20 requires "Prior written approval of the pollutants to be tested for and the appropriate test methods are mandatory prior to commencement of testing. The proposal shall be submitted to the Site Certification Office, the Department's BAR office and the Duval County's RESO office for approval."

Pursuant to Condition #7, stack tests shall be conducted for the pollutants particulate matter, carbon monoxide and sulfuric acid mist. The following are the EPA Reference methodologies which are contained in 40 CFR 60 that shall be conducted:

- | | | | |
|----|--------------------|---|---------------|
| 1) | Particulate matter | - | EPA Method 5B |
| 2) | Carbon Monoxide | - | EPA Method 10 |
| 3) | Sulfuric Acid Mist | - | EPA Method 8 |

Conditions #3 and #4 specifies that as-burned fuel samples shall be collected and analyzed for sulfur, nitrogen and metals. The baseline coal and pet coke/coal blend shall be sampled from the sampling building loading belt transfer to the Unit 1 to analyze the parameters in accordance with the following methods:


SJRO LC 95 092
Page 2

1)	Sulfur	ASTM D 4239 Method "C"
2)	Nitrogen	ASTM D 5373
3)	Chromium	ASTM D 3683
4)	Lead	ASTM D 3683
5)	Mercury	ASTM D 3684
6)	Nickel	ASTM D 3683
7)	Beryllium	ASTM D 3683
8)	Vanadium	ASTM D 3683
9)	Zinc	ASTM D 3683

The testing is scheduled to commence July 11, 1995 for the baseline. Your expeditious review and response are appreciated.

Please contact me at (904) 751-7729 if you have any questions.

Sincerely,



Jay Worley
Environmental & Safety Manager

JAW/pct

cc: R. Breitmoser

**REGULATORY & ENVIRONMENTAL
SERVICES DEPARTMENT**

Air Quality Division

June 22, 1995



Mr. Jay Worley
Environmental & Safety Manager
St. Johns River Power Park (SJRPP)
11201 New Berlin Road
Jacksonville, Florida 32226

**RE: Request for Approval - Pollutants & Testing Methodology
Unit #1 Test Burn Using Petroleum Coke with Coal
Site Certification No. PA 81-13
SJRPP Correspondence of June 14, 1995**

Dear Mr. Worley:

This is to acknowledge receipt and review of the above captioned SJRPP correspondence, submitted June 15, 1995.

Regulatory & Environmental Services Department (RESD) agrees that the use of EPA Reference Test Methods 5B, 10, and 8 for the testing of particulate matter, carbon monoxide, and sulfuric acid mist, respectively, during the above referenced test burn, satisfies Condition No. 20 of the Site Certification.

If there are any questions concerning this matter, please contact me at (904) 630-3484.

Very truly yours,

A handwritten signature in black ink that reads "Robert S. Pace".

Robert S. Pace, P.E.
Division Chief

RSP/WLW/be

c: AQD File 1710 B
Wayne Walker, AQD



421 West Church Street - Suite 412
Jacksonville, Florida 32202-4111

Area Code 904/630-3484

ATTACHMENT G

ST. JOHN'S RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - POWER BLOCK

DATE: 7-18-95

UNIT #: 1

TIME	INITIALS	2494 HEAT INPUT (MMBTU/HR)	STEAM 64 PRODUCTION (MMLBS/HR)	GROSS MW/HR	FUEL INPUT RATE (TONS/HR)							
					344 A	434 B	464 C	524 D	584 E	644 F	704 G	
0000												
0100												
0200												
0300												
0400												
0500												
0600	E.A.	4132	3.52	511	36.5	34	35.5	9/5	36.5	34	36	88.
0700	E.A.	4952	4.40	640	47	44	44	9/5	46	43.5	45	86.4
0800	E.A.	5131	4.57	657	46.5	44.5	44	9/5	45.5	40	44.5	88.
0900	E.A.	5152	4.56	658	46	44.5	44	9/5	44.5	40	45.5	88.1
1000	E.A.	5161	4.58	658	46	44	44	9/5	45.5	40	45	88.
1100	E.A.	5152	4.56	658	45.5	42	43	9/5	45	40	44	88.
1200	E.A.	5146	4.57	659	46	43	44	9/5	45.5	40	45	88.
1300	E.A.	5119	4.58	659	46.5	45	43.5	9/5	44	38.5	44	88.
1400	E.A.	5176	4.57	658	46	44	43.5	9/5	44.5	38.5	45	88.1
1500	E.A.	5078	4.36	632	43.5	41.5	41.5	9/5	41	30	40.5	88.
1600	E.A.	5042	4.37	636	40.5	39	38.5	38.5	39.5	9/5	39.5	88.
1700	E.A.	5172	4.59	660	43	42.5	42	42.5	42.5	9/5	42.5	88.
1800	M.T.	5155	4.58	656	43	42.5	43	43.5	43.5	9/5	43	88.
1900	M.T.	5165	4.56	659	44	42.5	42.5	43.5	43.5	9/5	43	88.
2000	M.T.	5125	4.52	657	44	42.5	42.5	43.5	43.5	9/5	43	88.
2100	M.T.	5161	4.56	658	44	42	42.5	43	43	9/5	42.5	88.
2200	M.T.	4999	4.32	629	42.5	40	41	41.5	42.5	9/5	42.5	88.
2300	M.T.	4989	4.35	630	45.5	43	43	43	44	9/5	44	88.

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - POWER BLOCK

DATE: 7/19/95

UNIT #: 1

TIME	INITIALS	2494 HEAT INPUT (MMBTU/HR)	STEAM 64 PRODUCTION (MMLBS/HR)	Gross MW/HR	344	404	464	524	584	644	704	
					A	B	FUEL INPUT RATE (TONS/HR)					
0000	mtt	4961	4.34	629	42	39.5	41	41.5	43	%s	42.5	37
0100	mtt	5227	4.53	658	47.5	45	45	45.5	45.5	%s	45	33
0200	mtt	5121	4.53	654	44	41.5	42.5	43	44	%s	44	59
0300	mtt	5176	4.51	654	46	43	43.5	37.5	44	%s	43.5	58
0400	mtt	5106	4.50	653	45	42.5	43.5	40.5	45	%s	45.5	55
0500	mtt	5162	4.55	657	44.5	41	41.5	41	42.5	%s	42	88
0600	✓	5147	4.56	659	45	42	42.5	43	44	%s	43.5	88
0700	✓	5142	4.55	657	44.5	42	42.5	43	44	%s	43	88
0800	✓	5188	4.55	658	44	41	42	43	43.5	%s	44	88
0900	✓	5181	4.53	657	46	43	43.5	44	44	%s	45	88.1
1000	✓	5146	4.59	659	44.5	41.5	43	44	44.5	%s	43.5	86
1100	✓	5206	4.57	659	45	41.5	42.5	42.5	44.5	%s	43	88
1200	✓	5325	4.71	675	46	42.5	43.5	43.5	45	%s	44	88.5
1300	✓	5394	4.71	676	46	43	44	44	45	%s	44.5	86
1400	✓	5317	4.68	673	44.5	41.5	42.5	42.5	44	%s	43	86
1500	✓	5293	4.74	674	42.5	40	41	41	41.5	%s	42	88.1
1600	✓	5267	4.67	667	44.5	42.5	43.5	43.5	44.5	%s	44	88
1700	✓	5248	4.70	677	45	42.5	43.5	44	44.5	%s	44	86
1800	Escp	5275	4.70	673	45	42.5	43.5	43.5	44	%s	44.5	86
1900	Escp	5267	4.70	674	45	42	43	43	44	%s	43.5	86
2000	Escp	5285	4.70	674	45.5	43	43.5	43.5	45	%s	44.5	86
2100	Escp	5308	4.68	675	45	42.5	43.5	44	44.5	%s	44	83
2200	Escp	5287	4.70	673	45.5	42.5	43	43.5	44.5	%s	44	82
2300	Escp	5279	4.71	675	45	43	43.5	43.5	44.5	%s	44.5	82

ST. JOHNS RIVER POWER PARK

PETROLEUM COKE/COAL TRIAL BURN

BASELINE & BLEND OPERATION: L DATA - POWER BLOCK

DATE: 8-8-95 UNIT #: 1

TIME	INITIALS	HEAT INPUT (MMBTU/HR)	BOILER EFFICIENCY (%)	MAIN STEAM TEMPERATURE (DEG. F)	MAIN STEAM PRESSURE (psig)	STEAM PRODUCTION (MMLS/HR)	GROSS MW	FUEL INPUT RATE (TONS/HR) (K#/hr)						
								A	B	C	D	E	G	
0000														
0100														
0200														
0300														
0400														
0500														
0600														
0700	JB	5841	88.6	1002	2390	4.58	660	85	86	80	85	82	77	95
0800	JB	5830	88.5	1002	2398	4.57	660	84	79	80	85	82	78	-
0900	JB	5849	88.5	1002	2395	4.58	660	80	73	75	85	76	72	-
1000	JB	5983	88.6	1005	2402	4.68	677	86	80	81	85	85	80	-
1100	JB	5956	88.6	1002	2394	4.69	674	87	81	82	85	85	81	-
1200	JB	5971	88.6	997	2395	4.70	670	86	79	82	85	85	80	-
1300	By	5947	88.6	998	2394	4.70	669	84	78	79	85	82	78	-
1400	JB	5984	88.5	999	2394	4.69	667	84	78	80	85	82	78	-
1500	JB	5958	88.5	1002	2397	4.70	670	84	77	79	85	80	77	-
1600	By	5993	88.4	1001	2396	4.71	669	85	79	80	86	84	78	-
1700	JB	5950	88.5	1000	2394	4.70	669	85	79	81	85	83	78	-
1800	Q	5955	88.5	1001	2403	4.72	671	86	80	81	85	84	79	-
1900	Q	5892	88.5	1000	2400	4.60	658	86	81	82	85	84	81	-
2000	Q	5867	88.5	1002	2405	4.57	656	87	81	83	86	85	80	-
2100	Q	5849	88.6	1003	2399	4.61	659	84	78	80	84	79	77	-
2200	Q	5863	88.5	1006	2414	4.59	660	83	76	79	86	81	76	-
2300	Q	5757	88.6	998	2398	4.52	644	79	74	76	85	79	75	-

DEB vukz

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN

DATE: 8-9-95 UNIT #: 1

BASELINE & BLEND OPERATIONAL DATA - POWER BLOCK

TIME	INITIALS	HEAT INPUT (MMBTU/Hr)	BOILER EFFICIENCY (%)	MAIN STEAM TEMPERATURE (DEG. F)	MAIN STEAM PRESSURE (psig)	STEAM PRODUCTION (MM. BB/Hr)	GROSS MW	FUEL INPUT RATE (TONS/Hr) (K#/hr)						
								A	B	C	D	E	F	G
0600	OK	5733	88.6	1002	2421	4.41	634	76	69	72	86	77	74	—
0700	OK	5880	88.6	1002	2398	4.61	660	85	78	80	79	81	77	—
0800	OK	5780	88.8	1003	2422	4.56	660	84	78	79	79	81	77	—
0900	OK	5843	88.8	1002	2406	4.60	658	83	77	79	80	82	79	—
0400	OK	5859	88.7	1008	2407	4.59	659	86	79	82	82	83	80	—
0500	OK	5885	88.8	1006	2399	4.59	660	85	80	81	81	83	78	—
0600	WMD	5828	88.8	1003	2394	4.49	650	84	77	81	80	83	78	—
0700	WMD	5979	88.8	999	2405	4.72	675	86	81	84	84	87	82	—
0800	WMD	5958	88.7	999	2405	4.72	672	87	80	82	82	85	80	—
0900	WMD	5958	88.7	1001	2401	4.71	672	86	80	84	83	86	81	—
1000	WMD	5976	88.6	1003	2403	4.71	672	87	81	84	84	87	82	—
1100	WMD	5949	88.7	999	2402	4.72	672	87	82	85	84	87	82	—
1200	WMD	5992	88.6	1003	2412	4.71	673	87	82	85	84	88	82	—
1300	WMD	5968	88.4	1003	2415	4.73	674	86	80	89	88	87	80	—
1400	WMD	5983	88.5	1005	2410	4.72	674	77	73	76	75	79	74	55
1500	WMD	5951	88.6	1009	2394	4.69	670	79	74	76	75	80	55	77
1600	WMD	5949	88.6	994	2417	4.76	674	75	70	74	73	76	70	74
1700	WMD	6020	88.5	996	2405	4.74	670	—	83	86	85	89	83	87
1800	EA	5989	88.6	1008	2402	4.70	669	—	83	85	84	88	83	87
1900	EA	5849	88.9	1004	2392	4.60	659	—	82	85	84	86	83	86
2000	EA	5851	88.7	985	2400	4.65	657	—	82	83	83	85	81	84
2100	EA	5878	88.7	1006	2420	4.60	658	—	82	82	82	86	80	84
2200	EA	5920	88.8	1005	2405	4.50	659	—	80	82	83	84	80	84
2300	EA	5837	88.8	1002	2390	4.60	657	—	84	85	85	86	84	87

VWD →

G Pwr I/

A Pwr O/S

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - POWER BLOCK

DATE: 8-10-95 UNIT #: 1

TIME	INITIALS	HEAT INPUT (MMBTU/HR)	BOILER EFFICIENCY (%)	MAIN STEAM TEMPERATURE (DEG. F)	MAIN STEAM PRESSURE (psig)	STEAM PRODUCTION (MMLBS/HR)	GROSS MW	FUEL INPUT RATE (TONS/HR) (K#/hr)						
								A	B	C	D	E	F	
0000	EA	5827	88.8	996	2410	4.60	653	—	78	80	81	83	79	83
0100	EA	5790	88.8	1002	2400	4.60	658	—	82	83	84	85	80	85
0200	EA	5792	88.8	997	2408	4.60	658	—	81	82	83	85	80	85
0300	EA	5790	88.8	1000	2405	4.60	656	—	80	81	83	83	79	82
0400	EA	5087	88.5	996	2391	3.69	550	—	65	68	68	69	67	69
0500	EA	5364	88.7	1001	2402	4.18	613	—	76	77	77	79	75	80
0600	JB	5850	88.6	1010	2412	4.57	655	—	77	80	80	80	77	82
0700	Ry	5849	88.7	1001	2383	4.58	658	—	79	81	82	83	78	83
0800	Ry	5831	88.9	1001	2398	4.59	659	—	81	82	82	84	80	84
0900	JB	5882	88.9	1005	2412	4.55	660	—	80	82	82	83	79	83
1000	JB	5622	88.8	996	2399	4.40	639	—	81	82	84	84	81	81
1100	Ry	5809	88.6	992	2409	4.63	659	74	67	70	70	73	68	72
1200	JB	5813	88.7	1006	2401	4.61	659	77	71	73	73	76	50	76
1300	Ry	5848	88.7	1004	2404	4.59	658	75	69	71	71	73	68	72
1400	Ry	5871	88.8	1007	2400	4.62	658	84	79	—	81	83	78	82
1500	JB	5839	88.8	999	2414	4.59	658	84	78	—	79	81	76	80
1600		Busy - Problems with unit & Pulv swaps.												
1700	JB	6063	88.6	1004	2406	4.71	672	—	83	84	84	86	85	85
1800	DB	6001	88.7	1005	2401	4.70	670	—	81	84	83	86	82	85
1900	DB	6003	88.8	994	2385	4.69	668	—	78	82	80	85	79	84
2000	DB	5979	88.9	993	2382	4.68	665	—	77	82	81	85	78	83
2100	DB	6029	88.8	1001	2425	4.74	679	—	79	82	81	85	79	84
2200	DB	5852	88.9	1011	2368	4.64	664	—	85	89	89	95	86	92
2300	DB	5898	88.7	1005	2397	4.61	658	—	79	83	83	86	80	85

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - POWER BLOCK

DATE: 8-11-95 UNIT #: 1

VW0

TIME	INITIALS	HEAT INPUT (MMBTU/HR)	BOILER EFFICIENCY (%)	MAIN STEAM TEMPERATURE (DEG. F)	MAIN STEAM PRESSURE (PSIG)	STEAM PRODUCTION (MMLBS/HR)	GROSS MW	FUEL INPUT RATE (TONS/HR)						
								A	B	C	D	E	F	G
0000	DB	5756	89	1000	2401	4.60	659	0/s	74	76	77	81	76	80
0100	DB	5865	88.9	1001	2409	4.58	653	0/s	78	83	81	85	80	85
0200	DB	5705	88.9	997	2397	4.50	642	0/s	75	77	76	80	74	77
0300	DB	5745	88.9	1008	2402	4.52	655	0/s	77	82	81	85	79	84
0400	DB	5784	88.8	1007	2413	4.53	652	0/s	78	83	82	86	81	85
0500	DB	5813	88.9	1004	2407	4.58	658	0/s	79	83	81	85	80	84
0600	mTT	5794	89	1007	2387	4.57	659	0/s	80	83	83	85	80	84
0700	mTT	5801	89	1004	2388	4.58	659	0/s	80	81	82	84	80	84
0800	mTT	5821	88.9	996	2385	4.61	658	0/s	79	80	83	83	79	83
0900	mTT	5787	89	1000	2384	4.59	659	0/s	79	80	81	82	78	83
1000	mTT	5803	89	1003	2381	4.59	659	0/s	80	80	81	83	79	83
1100	mTT	5955	88.8	1010	2384	4.65	669	0/s	81	83	84	86	81	86
1200	mTT	5934	88.8	1008	2383	4.68	673	0/s	81	83	82	86	81	85
1300	mTT	6019	88.7	987	2391	4.76	670	7/s	50	73	73	74	70	74
1400	mTT	5919	88.7	998	2384	4.71	669	77	71	73	50	75	71	74
1500	mTT	5993	88.8	997	2372	4.69	665	0/s	74	76	76	78	74	77
1600	mTT	5928	89	1000	2380	4.70	670	0/s	80	81	81	83	79	84
1700	mTT	5931	88.9	1003	2389	4.70	672	0/s	80	81	82	84	80	84
1800	DS	5925	89.0	1002	2383	4.70	670	0/s	80	82	81	84	79	83
1900	DS	5897	89.0	1002	2386	4.69	668	0/s	80	82	82	84	79	84
2000	DS	5893	89.0	1002	2391	4.68	669	0/s	81	82	82	84	80	84
2100	DS	5937	88.9	1003	2390	4.71	669	0/s	80	83	82	84	81	84
2200	DS	5934	89.1	1011	2382	4.68	669	0/s	81	82	82	84	80	85
2300	DS	5916	93.9	1001	2385	4.68	667	0/s	80	83	83	84	79	83

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN

DATE: 8.12.95 UNIT #: ONE

BASELINE & BLEND OPERATIONAL DATA - POWER BLOCK

TIME	INITIALS	HEAT INPUT (MMBtu/HR)	BOILER EFFICIENCY (%)	MAIN STEAM TEMPERATURE (DEG. F)	MAIN STEAM PRESSURE (psig)	STEAM PRODUCTION (MMBtu/HR)	GROSS MW	FUEL INPUT RATE (TONS/HR)						
								A	B	C	D	E	F	G
0000	DS	5914	88.9	1005	2381	4.68	670	0/5	81	82	82	83	79	84
0100	DS	5942	89.2	1001	2392	4.72	668	0/5	81	82	83	84	79	84
0200	DS	5889	88.8	1005	2381	4.65	657	0/5	79	81	82	83	78	82
0300	DS	5789	88.9	1001	2389	4.55	650	0/5	79	81	81	83	78	82
0400	DS	5633	89.0	999	2401	4.43	635	0/5	75	77	78	80	75	79
0500	DS	5264	94.0	995	2381	4.09	595	0/5	75	77	77	79	74	78
0600	EAP	5445	89.1 EAP	999	2394	4.18	612	0/5	72	75	75	76	72	76
0700	EAP	5611	89.0	992	2378	4.35	632	0/5	73	76	76	78	73	77
0800	EAP	5699	89.0	1005	2376	4.51	650	0/5	78	81	80	82	78	80
0900	EAP	5166	89.1	997	2376	4.61	659	0/5	80	81	82	84	79	83
1000	EAP	5794	89.1	1007	2391	4.56	657	0/5	75	78	80	80	76	79
1100	EAP	5777	89.1	1000	2381	4.61	657	0/5	79	82	82	84	79	83
1200	EAP	5771	89.0	1001	2373	4.57	654	0/5	76	80	79	81	76	80
1300	EAP	5857	89.0	1002	2378	4.59	660	0/5	80	82	80	84	77	83
1400	EAP	5810	88.9	1001	2385	4.63	658	0/5	74	77	77	79	79	81
1500	EAP	5877	88.9	1003	2380	4.61	656	0/5	79	82	82	83	79	83
1600	EAP	5922	88.7	1002	2392	4.61	658	0/5	79	81	81	83	79	83
1700	EAP	5809	89.0	999	2387	4.60	657	0/5	79	81	81	84	78	83
1800	DB	5806	89	1000	2393	4.55	659	0/5	77	81	80	84	77	82
1900	DB	5777	89.1	1004	2402	4.60	657	0/5	78	82	81	85	80	84
2000	DB	5804	89.1	1002	2398	4.59	657	0/5	77	81	81	84	77	83
2100	DB	5832	89.0	993	2401	4.62	657	0/5	77	81	79	82	77	80
2200	DB	5780	89.0	997	2395	4.51	654	0/5	78	81	80	84	78	81
2300	DB	5790	88.9	998	2391	4.46	648	0/5	81	85	84	88	82	85

ST. JOHNS RIVER POWER PARK
 PETROLEUM COKE/COAL TRIAL BURN

DATE: 8-13-95 UNIT #: 1

BASELINE & BLEND OPERATIONAL DATA - POWER BLOCK

TIME	INITIALS	HEAT INPUT (MMBtu/hr)	BOILER EFFICIENCY (%)	MAIN STEAM TEMPERATURE (DEG. F)	MAIN STEAM PRESSURE (psig)	STEAM PRODUCTION (MMBtu/hr)	GROSS MW	FUEL INPUT RATE (TONS/HR)						
								A	B	C	D	E	F	G
0000	DB	5746	89.1	999	2381	4.55	654	0/s	85	85	85	87	83	85
0100	DB	5699	89.0	993	2396	4.50	654	0/s	81	81	85	88	77	80
0200	DB	5591	88.9	1002	2396	4.45	632	0/s	81	80	85	85	80	85
0300	DB	5791	89.0	1004	2403	4.50	650	0/s	83	82	86	88	80	85
0400	DB	5730	88.9	998	2411	4.47	643	0/s	79	82	81	85	80	84
0500	DB	5601	88.8	1009	2417	4.35	630	0/s	75	78	76	80	75	78
0600	mtt	5571	88.9	999	2386	4.35	635	0/s	75	76	77	78	72	77
0700	mtt	5441	89.0	1000	2385	4.20	619	0/s	74	75	76	77	73	77
0800	mtt	5774	88.8	997	2400	4.60	659	0/s	81	82	82	84	80	84
0900	mtt	5786	88.9	999	2383	4.58	657	0/s	77	80	79	81	76	81
1000	mtt	5835	88.9	1001	2387	4.60	661	0/s	79	81	83	83	79	83
1100	mtt	5802	89.0	999	2386	4.60	661	0/s	80	82	83	83	80	83
1200	mtt	5854	88.9	1004	2391	4.61	661	0/s	79	81	82	83	79	84
1300	mtt	5902	88.9	1005	2397	4.65	676	0/s	81	82	83	85	81	84
1400	mtt	5722	88.8	1003	2383	4.70	674	0/s	80	82	82	84	80	84
1500	mtt	5944	88.8	1001	2378	4.69	671	0/s	80	82	82	84	80	84
1600	mtt	5930	88.9	1003	2389	4.71	672	0/s	80	82	82	84	80	85
1700	mtt	5943	89.1	1003	2387	4.71	669	0/s	80	82	82	83	80	85
1800	DS	5912	89.1	1001	2389	4.69	672	0/s	79	81	81	83	79	83
1900	DS	5934	89.1	997	2393	4.70	671	0/s	79	82	82	84	79	83
2000	DS	5910	88.9	1000	2393	4.68	671	0/s	81	82	83	85	81	85
2100	DS	5930	89.0	998	2390	4.69	674	0/s	82	83	83	84	80	84
2200	DS	5908	88.9	985	2397	4.71	670	0/s	79	80	81	83	79	82
2300	DS	5915	88.9	1003	2387	4.67	671	0/s	79	81	80	83	79	84

1W0
 VW0
 VW0
 VW0

Best Available Copy

ST. JOHNS RIVER POWER PARK
 PETROLEUM COKE/COAL TRIAL BURN
 BASELINE & BLEND OPERATIONAL DATA - POWER BLOCK

DATE: 8-14-95 UNIT #: ONE

TIME	INITIALS	HEAT INPUT (MMBtu/hr)	BOILER EFFICIENCY (%)	MAIN STEAM TEMPERATURE (DEG. F)	MAIN STEAM PRESSURE (psi)	STEAM PRODUCTION (MMI.BS/HR)	GROSS MW	FUEL INPUT RATE (TONS/HR)						
								A	B	C	D	E	F	G
0000	DS	5829	88.9	997	2403	4.59	658	0/s	80	82	82	81	80	84
0100	DS	5879	88.9	994	2391	4.64	658	0/s	80	82	81	83	79	83
0200	DS	5885	88.8	1002	2391	4.63	659	0/s	79	82	82	84	80	83
0300	DS	5844	88.9	997	2404	4.61	639	0/s	73	76	77	77	75	79
0400	DS	5906	88.8	1001	2389	4.67	658	0/s	79	81	81	79	78	82
0500	DS	5838	88.7	1001	2385	4.59	658	0/s	79	82	82	82	79	84
0600	✓	5828	88.9	1000	2400	4.59	657	0/s	79	82	82	81	73	81
0700	✓	5801	88.4	987	2400	4.63	655	0/s	77	80	81	80	74	79
0800	✓	5831	88.9	997	2405	4.62	657	0/s	78	80	81	81	73	84
0900	✓	5814	89.0	1007	2401	4.60	658	0/s	80	81	82	81	79	83
1000	✓	5901	88.7	1000	2390	4.63	667	0/s	83	84	85	81	83	86
1100	✓	5951	89.1	1001	2399	4.70	669	0/s	80	83	83	82	79	85
1200	✓	5923	89.1	1000	2393	4.70	667	0/s	81	83	83	81	80	85
1300	✓	5915	89.1	1005	2411	4.72	671	0/s	80	82	83	83	81	84
1400	✓	5955	89.1	1000	2398	4.71	665	0/s	81	82	82	82	80	83
1500	✓	5953	89.0	1001	2404	4.72	668	0/s	80	82	82	84	82	84
1600	✓	5957	89.0	996	2396	4.72	665	0/s	80	81	81	81	80	83
1700	✓	5959	89.0	998	2401	4.71	667	0/s	80	81	82	81	80	83
1800	EAP	5962	89.9	1000	2386	4.72	671	0/s	80	82	82	82	79	84
1900	EAP	5934	89.0	997	2387	4.71	670	0/s	80	82	82	82	79	83
2000	EAP	5950	89.0	997	2393	4.72	670	0/s	81	81	81	81	79	83
2100	EAP	5970	89.0	1007	2372	4.66	667	0/s	82	84	84	84	81	86
2200	EAP	5974	89.0	1004	2390	4.71	672	0/s	78	80	80	80	76	82
2300	EAP	5877	88.9	1001	2392	4.66	668	0/s	79	81	81	81	78	82

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - POWER BLOCK

DATE: 8-15-95 UNIT #: ONE

TIME	INITIALS	HEAT INPUT (MMBTU/HR)	BOILER EFFICIENCY (%)	MAIN STEAM TEMPERATURE (DEG. F)	MAIN STEAM PRESSURE (PSIG)	STEAM PRODUCTION (MMBLS/HR)	GROSS MW	FUEL INPUT RATE (TONS/HR)						
								A	B	C	D	E	F	G
0000	ECAP	5680	89.1	1012	2381	4.39	640	9/5	77	79	80	80	77	83
0100	ECAP	5818	88.9	1002	2393	4.63	659	9/5	80	81	82	82	79	84
0200	ECAP	5864	89.0	1003	2391	4.60	657	9/5	78	80	80	79	77	81
0300	ECAP	5818	89.1	997	2389	4.61	657	9/5	78	80	80	80	78	82
0400	ECAP	5791	88.9	987	2399	4.57	648	9/5	77	79	78	78	75	79
0500	ECAP	5833	89.0	1013	2374	4.52	658	9/5	80	81	81	81	78	82
0600	EA	5841	88.8	1006	2408	4.57	658	9/5	78	79	80	80	78	81
0700	EA	5815	88.9	988	2401	4.60	659	9/5	79	81	80	81	77	83
0800	EA	5676	88.7	1000	2426	4.38	635	9/5	69	72	72	72	70	75
0900	EA	5904	88.6	988	2392	4.69	667	9/5	78	80	80	80	78	82
1000	EA	6025	88.7	985	2404	4.74	672	9/5	83	82	83	82	80	83
1100	EA	5983	88.7	1002	2399	4.70	667	9/5	80	82	83	81	81	82
1200	EA	5975	88.7	994	2401	4.72	667	9/5	79	83	82	82	80	84
1300	EA	5947	88.5	1008	2406	4.70	670	9/5	81	82	83	82	81	85
1400	EA	5990	88.3	998	2411	4.73	669	9/5	81	82	82	83	80	84
1500	EA	5970	88.3	999	2400	4.70	667	9/5	79	81	82	81	79	83
1600	EA	5938	88.8	1000	2412	4.73	670	9/5	79	83	84	82	81	84
1700	EA	5935	88.5	1002	2393	4.68	667	9/5	81	82	83	82	80	84
1800	MTT	6006	88.5	992	2401	4.75	672	9/5	77	79	79	79	77	82
1900	MTT	6005	88.4	998	2399	4.75	677	9/5	82	84	84	83	82	85
2000	MTT	5991	88.4	997	2391	4.71	671	9/5	81	82	84	82	80	83
2100	MTT	6012	88.6	1000	2389	4.71	673	9/5	81	83	83	81	80	84
2200	MTT	5975	88.8	1000	2393	4.73	675	9/5	80	81	81	81	79	83
2300	MTT	5898	89.0	1002	2405	4.60	660	9/5	78	79	80	79	78	81

Best Available Copy

**ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - POWER BLOCK**

DATE: 8/16/95 UNIT #: ONE

TIME	INITIALS	HEAT INPUT (MMBTU/HR)	BOILER EFFICIENCY (%)	MAIN STEAM TEMPERATURE (DEG. F)	MAIN STEAM PRESSURE (PSIG)	STEAM PRODUCTION (MM. LB/HR)	GROSS MW	FUEL INPUT RATE (TON/MIN)						
								A	B	C	D	E	F	G
0000	mjt	5814	88.9	1003	2382	4.58	658	%s	78	80	80	80	77	83
0100	mjt	5815	88.9	1001	2385	4.57	661	%s	78	80	80	81	78	81
0200	mjt	5848	88.8	1001	2393	4.57	651	%s	74	76	77	77	75	79
0300	mjt	5825	88.8	986	2393	4.62	660	%s	79	81	81	83	79	83
0400	mjt	5867	88.7	995	2388	4.62	661	%s	79	81	81	83	79	83
0500	mjt	5812	88.8	999	2388	4.57	654	%s	75	78	78	80	76	80
0600	✓	5721	88.8	1000	2399	4.52	650	%s	78	79	80	82	78	82
0700	✓	5800	88.9	1008	2400	4.58	660	%s	77	78	78	81	76	81
0800	✓	BD	BD	1007	2399	4.29	621	%s	75	77	78	81	76	81
0900	✓	5924	88.7	1004	2389	4.68	668	%s	79	82	80	83	78	83
1000	✓	5959	88.7	1002	2395	4.70	671	%s	80	82	82	84	79	84
1100	✓	5990	88.7	1005	2411	4.72	673	%s	80	83	82	84	80	84
1200	✓	5956	88.6	1000	2407	4.73	671	%s	82	82	83	85	80	85
1300	✓	5970	88.6	1008	2392	4.67	669	%s	82	85	84	87	83	86
1400	✓	6037	88.7	987	2399	4.74	665	%s	79	80	80	83	78	81
1500	✓	6007	88.6	1006	2381	4.66	660	%s	82	84	85	87	82	87
1600	mjt	5174	83.5	990	2371	4.75	668	%s	77	81	81	83	77	83
1700	mjt	6040	88.6	980	2373	4.75	663	%s	77	82	80	82	77	81
1800	Scp	5999	88.9	1001	2413	4.75	677	%s	70	83	83	85	80	85
1900	Scp	5950	89.1	992	2380	4.72	664	%s	77	80	82	81	78	82
2000	Scp	5971	89.1	995	2389	4.72	671	%s	80	81	81	83	79	83
2100	Scp	5922	89.1	999	2386	4.70	672	%s	81	83	83	84	79	85
2200	Scp	5929	89.1	999	2391	4.72	673	%s	81	82	82	83	79	81
2300	Scp	5829	89.3	1005	2393	4.59	658	%s	79	80	80	82	77	83

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
B. BASELINE & BLEND OPERATIONAL DATA - POWER BLOCK

DATE: 8-17-95 UNIT #: 1

TIME	INITIALS	HEAT INPUT (MMBTU/HR)	BOILER EFFICIENCY (%)	MAIN STEAM TEMPERATURE (DEG. F)	MAIN STEAM PRESSURE (psig)	STEAM PRODUCTION (MM. LB/HR)	GROSS MW	FUEL INPUT RATE (TONS/HR)						
								A	B	C	D	E	F	G
0000	ECAD	5827	89.3	1003	2399	4.62	658	4/5	81	82	82	84	80	84
0100	ECAD	5813	89.2	1004	2389	4.62	658	0/5	80	81	80	84	79	82
0200	ECAD	5897	89.1	996	2391	4.63	658	0/5	81	82	82	85	80	84
0300	ECAD	5839	89.2	998	2383	4.61	657	0/5	80	81	82	83	79	83
0400	ECAD	5669	88.8	1002	2383	4.46	637	0/5	77	80	79	81	75	78
0500	ECAD	5123	89.0	1011	2374	3.97	560	0/5	72	75	74	76	71	75
0600	EA	5866	88.6	992	2411	4.62	658	0/5	76	78	79	80	76	80
0700	EA	5882	88.6	999	2398	4.60	658	0/5	78	79	78	82	78	82
0800	EA	5919	88.4	996	2393	4.61	655	0/5	80	82	82	84	79	83
0900	EA	5859	88.4	1003	2407	4.60	658	0/5	79	80	80	84	78	82
1000	EA	5913	88.4	1004	2401	4.60	658	0/5	79	81	81	83	79	82
1100	EA	5962	88.6	1001	2407	4.72	673	0/5	80	81	81	83	80	83
1200	EA	6000	88.6	996	2397	4.71	669	0/5	77	79	80	81	76	81
1300	EA	5968	88.7	997	2405	4.72	672	0/5	77	79	80	81	77	81
1400	EA	6013	88.6	1001	2404	4.71	670	0/5	77	79	79	81	77	81
1500	EA	5960	88.5	997	2403	4.73	670	0/5	77	79	79	80	76	81
1600	EA	6012	88.4	1001	2401	4.71	670	0/5	77	79	79	81	76	81
1700	EA	5962	88.4	1001	2409	4.73	673	0/5	77	79	77	81	76	81
1800	UMD	5993	88.3	1006	2402	4.69	669	0/5	76	78	78	79	76	81
1900	UMD	5997	88.3	1001	2401	4.69	672	0/5	76	76	78	78	77	80
2000	UMD	5999	88.3	1002	2407	4.72	672	0/5	76	80	79	84	77	82
2100	UMD	5959	88.3	1000	2406	4.72	672	0/5	77	81	80	84	78	83
2200	Pyg.	5794	88.4	993	2313	4.55	657	0/5	71	72	73	76	73	76
2300	UMD	5734	88.4	993	2393	4.47	638	0/5	74	78	76	81	75	78

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - POWER BLOCK

DATE: 8/18/95 UNIT #: 1

TIME	INITIALS	HEAT INPUT (MMBTU/HR)	BOILER EFFICIENCY (%)	MAIN STEAM TEMPERATURE (DEG. F)	MAIN STEAM PRESSURE (PSIG)	STEAM PRODUCTION (MMBLS/HR)	GROSS MW	FUEL INPUT RATE (CONSTANT) KLBS/HR						
								A	B	C	D	E	G	
0000	WD	5712	88.4	1000	2401	4.39	636	0/S	78	78	76	81	75	78
0100	WD	5703	88.4	1001	2398	4.39	633	0/S	74	78	76	81	75	78
0200	WD	5755	88.6	1009	2398	4.52	651	0/S	75	77	77	81	75	81
0300	WD	5754	88.8	1001	2397	4.62	657	0/S	74	78	77	81	75	81
0400	WD	5798	88.8	1000	2399	4.61	658	0/S	74	78	77	81	75	81
0500	WD	5865	88.7	1005	2400	4.61	661	0/S	74	76	77	81	74	81
0600	n.d.	5824	88.6	1003	2398	4.57	655	0/S	75	76	78	80	73	80
0700	WD	5834	88.6	1000	2401	4.57	652	0/S	74	76	77	79	74	80
0800	WD	5860	88.7	1010	2397	4.57	654	0/S	75	76	78	79	73	80
0900	WD	5984	88.6	999	2401	4.67	663	0/S	77	78	79	80	75	74
1000	WD	5993	88.6	1006	2392	4.70	670	0/S	75	76	77	81	75	79
1100	WD	5954	88.7	999	2397	4.71	672	0/S	76	78	76	80	76	80
1200	WD	5964	88.6	998	2401	4.71	672	0/S	76	78	78	81	76	81
1300	WD	5924	88.7	1003	2401	4.71	670	0/S	76	78	78	80	75	80
1400	WD	5750	88.6	1062	2404	4.72	670	0/S	75	77	77	80	74	80
1500	WD	5944	88.7	999	2400	4.71	670	0/S	76	78	78	81	75	80
1600	WD	5965	88.6	986	2410	4.71	670	0/S	75	76	78	80	74	80
1700	WD	5965	88.5	1001	2402	4.71	670	0/S	75	78	78	79	75	79
1800	JB	5990	88.3	1000	2404	4.71	671	-	76	77	78	80	76	80
1900	JB	5968	88.2	1001	2405	4.71	672	-	76	77	76	80	75	79
2000	JB	5999	88.3	999	2400	4.71	672	-	76	78	78	80	75	80
2100	JB	5978	88.4	1000	2404	4.71	671	-	76	78	78	79	74	79
2200	JB	6004	88.4	1000	2397	4.70	671	-	75	77	77	78	75	79
2300	JB	5824	88.5	1006	2405	4.58	660	-	76	78	78	78	77	78

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - POWER BLOCK

DATE: 8-17-95 UNIT #: 1

TIME	INITIALS	HEAT INPUT (MMBTU/HR)	BOILER EFFICIENCY (%)	MAIN STEAM TEMPERATURE (DEG. F)	MAIN STEAM PRESSURE (psig)	STEAM PRODUCTION (MM. BS/HR)	GROSS MW	FUEL INPUT RATE (TONS/HR) K LBS/HR						
								A	D	C	D	E	V	G
0000	AB	5969	88.2	998	2403	4.62	658	0/3	74	76	76	78	74	78
0100	AB	5868	88.5	979	2408	4.61	660	0/3	76	75	77	76	75	76
0200	AB	5900	88.5	1003	2400	4.61	659	-	76	75	77	76	75	75
0300	AB	5918	88.5	1006	2402	4.68	672	-	76	74	77	76	75	76
0400	AB	5883	88.6	1005	2401	4.67	670	0/3	76	75	77	76	74	76
0500	AB	5885	88.6	1004	2402	4.64	664	-	77	75	77	77	74	76
0600	A.S.	5942	88.5	1002	2383	4.65	665	0/3	76	75	77	76	74	76
0700	A.S.	5991	88.5	1002	2397	4.67	667	0/3	76	75	77	76	75	76
0800	A.S.	5923	88.5	997	2401	4.63	662	0/3	76	76	77	76	75	76
0900	A.S.	5906	88.6	1001	2402	4.67	664	0/3	74	74	77	75	75	76
1000	A.S.	5924	88.5	1000	2387	4.64	658	0/3	76	74	77	77	74	75
1100	A.S.	5831	88.8	1003	2402	4.59	664	0/3	77	75	77	76	75	76
1200	A.S.	5890	88.9	994	2400	4.66	665	0/3	76	75	77	76	75	76
1300	AS	5930	89.2	1002	2386	4.70	672	0/3	77	79	79	77	77	80
1400	DE	5957	89.2	999	2393	4.74	672	0/3	76	78	79	77	76	80
1500	T.L.	5941	89.2	996	2403	4.72	671	0/3	76	78	78	77	76	80
1600	T.L.	5943	89.2	1002	2405	4.72	673	0/3	76	78	79	75	76	80
1700	T.L.	5904	89.2	1004	2404	4.70	672	0/3	77	79	79	76	78	81
1800	WD	BD	BD	990	2405	4.74	675	0/3	76	80	79	78	77	82
1900	WD	BD	BD	1000	2398	4.68	673	0/3	77	81	80	78	79	83
2000	WD	BD	BD	1006	2401	4.70	674	0/3	77	82	80	79	79	83
2100	WD	BD	BD	1003	2407	4.55	660	0/3	78	82	79	83	76	79
2200	WD	BD	BD	1005	2398	4.59	660	0/3	75	80	79	83	76	81
2300	WD	BD	BD	1004	2395	4.58	660	0/3	75	80	77	81	77	80

twir off WWD
 back to ABS

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - AQCS

DATE: 7-18-95

TOWER: 1A

TIME	INITIALS	ABSORBER pB	QUENCHER pB	INJECTION RATE (% flow of reagent feed valve)	MIX RATIO (Density)	PRESSURE DROP ACROSS TOWER
0000						
0100						
0200						
0300						
0400						
0500						
0600						
0700	CS	6.07 5.96	3.09 2.89	4	1.33	1.25
0800	CS	6.08 5.97	3.06 2.83	3	1.335	1.25
0900	CS	6.08 5.95	2.98 2.77	3	1.335	1.25
1000	CS	6.07 5.95	2.92 2.69	3	1.34	1.25
1100	CS	6.06 5.94	2.90 2.67	3	1.335	1.25
1200	CS	6.06 5.93	2.96 2.74	3	1.33	1.25
1300	CS	6.04 5.92	2.92 2.70	3	1.34	1.25
1400	CS	6.03 5.92	2.91 2.67	3	1.34	1.25
1500	CS	6.03 5.93	2.88 2.66	4	1.34	1.25
1600	CS	6.04 5.93	2.90 2.68	4	1.34	1.20
1700	CS	6.02 5.92	2.92 2.69	5	1.345	1.25
1800	van	6.04 5.93	2.87 2.65	5	1.34	1.25
1900	van	6.05 5.96	3.65 3.44	3	1.34	1.20
2000	van	6.03 5.94	3.32 3.10	3	1.335	1.20
2100	van	6.03 5.93	3.27 3.06	4	1.335	1.25
2200	van	6.04 5.94	3.21 2.99	4	1.33	1.20
2300	van	6.03 5.94	3.20 2.98	4	1.33	1.25

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - AQCS

DATE: 7-19-95

TOWER: 1A

TIME	INITIALS	ABSORBER pH	QUENCHER pH	INJECTION RATE (% flow of reagent feed valve)	MIX RATIO (Density)	PRESSURE DROP ACROSS TOWER
0000	van	6.07 5.98	3.72 3.52	4	1.34	1.20
0100	van	6.05 5.97	3.38 3.16	4	1.33	1.25
0200	van	6.05 5.97	3.33 3.12	4	1.32	1.20
0300	van	6.05 5.97	3.26 3.05	4	1.33	1.20
0400	van	6.06 5.97	3.29 3.07	4	1.33	1.25
0500	van	6.04 5.95	3.24 3.01	3	1.33	1.25
0600	es	6.03 5.95	3.30 3.08	3	1.32	1.25
0700	es	6.07 5.98	3.77 3.57	3	1.33	1.10
0800	es	6.05 5.96	3.46 3.24	3	1.335	1.20
0900	es	6.05 5.96	3.33 3.12	3	1.33	1.20
1000	es	6.04 5.94	3.33 3.11	3	1.33	1.20
1100	es	6.03 5.93	3.28 3.08	3	1.33	1.25
1200	es	6.02 5.93	3.33 3.13	3	1.33	1.25
1300	es	6.02 5.93	3.27 3.06	4	1.34	1.25
1400	es	6.03 5.94	3.22 3.00	4	1.325	1.20
1500	es	6.03 5.94	3.16 2.94	5	1.33	1.25
1600	es	6.06 5.97	3.48 3.27	5	1.33	1.25
1700	es	6.04 5.95	3.36 3.14	4	1.33	1.25
1800	van	6.03 5.94	3.27 3.04	3	1.33	1.25
1900	van	6.04 5.92	3.62 3.41	3	1.33	1.25
2000	van	6.05 5.95	3.81 3.59	3	1.33	1.25
2100	van	6.02 5.93	3.51 3.27	3	1.33	1.25
2200	van	6.01 5.91	3.40 3.17	4	1.33	1.25
2300	van	6.00 5.90	3.32 3.07	4	1.33	1.25

**ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - AQCS**

DATE: 7-20-95

TOWER: 1A

TIME	INITIALS	ABSORBER pH	QUENCHER pH	INJECTION RATE (% Close of Request Feed valves)	MIX RATIO (Density)	PRESSURE DROP ACROSS TOWER
0000	van	6.00 5.90	3.24 2.99	4	1.33	1.25
0100	van	6.01 5.91	3.21 2.98	5	1.33	1.25
0200	van	6.01 5.91	3.23 2.99	5	1.33	1.20
0300	van	6.04 5.94	3.58 3.36	5	1.33	1.20
0400	van	6.06 5.96	3.41 3.19	5	1.33	1.20
0500	MN	6.05 5.95	3.30 3.08	4	1.33	1.30
0600	CS	6.04 5.94	3.23 3.01	4	1.33	1.20
0700	CS	6.03 5.93	3.18 2.94	4	1.32	1.25
0800	CS	6.05 5.96	3.43 3.21	4	1.315	1.20
0900	CS	6.07 5.97	3.45 3.23	4	1.32	1.20
1000	CS	6.05 5.94	3.26 3.04	4	1.31	1.20
1100	CS	6.04 5.93	3.11 2.88	5	1.31	1.25
1200	CS	6.07 5.96	3.48 3.26	5	1.32	1.25
1300	CS	6.07 5.97	3.56 3.35	4	1.37	1.25
1400	CS	6.06 5.96	3.35 3.13	4	1.365	1.30
1500	CS	6.08 5.98	3.53 3.33	4	1.375	1.25
1600	CS	6.09 5.99	3.55 3.35	4	1.37	1.25
1700						
1800						
1900						
2000						1.027
2100						
2200						
2300						

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - AQCS

DATE: 8-8-95

TOWER: 1A

TIME	INITIALS	ABSORBER pH	QUENCHER pH	INJECTION RATE (% flow of reagent feed valve)	MIX RATIO (Density)	PRESSURE DROP ACROSS TOWER
0000						
0100						
0200						
0300						
0400						
0500						
0600						
0700	T.D.	5.94 / 5.75	3.71 / 3.48	3	1.33	1.30
0800	T.D.	5.86 / 5.70	3.75 / 3.51	3	1.33	1.25
0900	T.D.	5.84 / 5.71	3.79 / 3.55	5	1.33	1.20
1000	T.D.	5.79 / 5.71	3.74 / 3.56	5	1.33	1.30
1100	T.D.	5.78 / 5.73	3.75 / 3.55	5	1.33	1.30
1200	T.D.	5.89 / 5.73	3.79 / 3.58	5	1.33	1.25
1300	T.D.	6.14 / 5.77	4.14 / 3.95	5	1.33	1.30
1400	TD	5.91 / 5.76	4.29 / 4.10	5	1.33	1.20
1500	T.D.	5.92 / 5.77	4.24 / 4.07	5	1.33	1.20
1600	TD	5.92 / 5.78	4.25 / 4.05	5	1.33	1.25
1700	TD	5.93 / 5.79	3.92 / 3.70	5	1.33	1.25
1800	CS	5.90 / 5.77	3.85 / 3.63	5	1.33	1.25
1900	CS	5.90 / 5.77	3.87 / 3.64	5	1.325	1.25
2000	CS	6.42 / 5.77	3.88 / 3.65	5	1.33	1.25
2100	CS	6.41 / 5.76	3.88 / 3.66	5	1.33	1.25
2200	CS	6.37 / 5.77	3.86 / 3.65	5	1.33	1.30
2300	CS	6.33 / 5.78	3.85 / 3.63	5	1.34	1.25

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - AQCS

DATE: 8-9-95

TOWER: A

TIME	INITIALS	ABSORBER pH	QUENCHER pH	INJECTION RATE (% flow of reagent feed valve)	MIX RATIO (Density)	PRESSURE DROP ACROSS TOWER
0000	CS	5.93 5.80	3.86 3.63	4	1.34	1.25
0100	CS	5.91 5.77	3.86 3.63	4	1.34	1.25
0200	CS	5.90 5.77	3.84 3.60	4	1.34	1.25
0300	CS	5.88 5.76	3.84 3.59	4	1.34	1.25
0400	CS	5.95 5.74	3.87 3.62	5	1.34	1.25
0500	CS	5.93 5.77	3.86 3.61	5	1.34	1.25
0600	T.D.	6.19 5.77	3.87 3.61	5	1.34	1.30
0700	T.D.	5.63 5.67	2.98 2.50	5	1.335	1.25
0800	T.D.	5.77 5.67	2.73 2.51	5	1.34	1.20
0900	T.D.	5.35 5.64	5.30 2.53	6	1.34	1.40
1000	T.D.	5.37 5.67	2.53 2.57	4	1.335	1.30
1100	T.D.	5.0 5.68	2.61 2.62	6	1.33	1.30
1200	T.D.	5.0 5.70	2.64 2.67	4	1.33	1.30
1300	T.D.	5.71 5.76	2.65 2.65	4	1.335	1.30
1400	T.D.	5.73 5.71	2.92 2.92	7	1.33	1.30
1500	T.D.	5.78 5.74	3.17 3.17	6	1.335	1.25
1600	T.D.	5.79 5.74	3.30 3.31	5	1.33	1.25
1700	T.D.	5.76 5.74	3.22 3.24	6	1.33	1.25
1800	CS	5.79 5.77	3.27 3.27	6	1.33	1.25
1900	CS	5.81 5.78	3.22 3.23	6	1.345	1.25
2000	CS	5.81 5.80	3.44 3.46	6	1.34	1.25
2100	CS	5.84 5.82	3.40 3.42	5	1.34	1.25
2200	CS	5.84 5.82	3.27 3.27	4	1.33	1.25
2300	CS	5.83 5.81	3.18 3.19	4	1.34	1.25

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - AQCS

DATE: 8-10-95

TOWER: A

TIME	INITIALS	ABSORBER pH	QUENCHER pH	INJECTION RATE (% Open of ramped feed valve)	MIX RATIO (Density)	PRESSURE DROP ACROSS TOWER
0000	CS	5.83 / 5.81	3.11 / 3.11	4	1.33	1.25
0100	CS	5.83 / 5.81	2.70 / 2.69	4	1.345	1.25
0200	CS	5.81 / 5.78	2.61 / 2.60	4	1.83	1.25
0300	CS	5.79 / 5.78	2.63 / 2.61	4	1.335	1.25
0400	CS	5.81 / 5.79	2.65 / 2.64	3	1.33	1.0
0500	CS	5.78 / 5.77	2.62 / 2.61	3	1.34	1.20
0600	T.D.	5.77 / 5.74	2.64 / 2.64	5	1.34	1.25
0700	T.D.	5.75 / 5.75	2.62 / 2.63	6	1.34	1.15
0800	TD	5.75 / 5.75	2.63 / 2.64	4	1.34	1.25
0900	TD	5.74 / 5.76	2.65 / 2.64	7	1.34	1.15
1000	T.D.	5.77 / 5.77	2.72 / 2.74	7	1.34	1.05
1100	TD	5.79 / 5.70	2.72 / 2.75	7	1.34	1.25
1200	T.D.	5.81 / 5.80	2.80 / 2.82	7	1.34	1.25
1300	T.D.	5.81 / 5.81	2.76 / 2.78	7	1.33.5	1.30
1400	T.D.	5.81 / 5.81	2.75 / 2.76	7	1.34	1.40
1500	T.D.	5.82 / 5.82	2.73 / 2.74	7	1.33	1.35
1600	T.D.	5.81 / 5.81	2.72 / 2.73	7	1.335	1.25
1700	T.D.	5.80 / 5.81	2.74 / 2.78	7	1.34	1.30
1800	YJA	5.82 / 5.83	2.31 / 2.35	7	1.33	1.40
1900	YJA	5.82 / 5.84	3.44 / 3.47	7	1.36	1.30
2000	YJA	5.85 / 5.86	3.51 / 3.52	6	1.34	1.25
2100	YJA	5.84 / 5.85	3.50 / 3.51	5	1.335	1.25
2200	MM	5.82 / 5.83	3.43 / 3.45	5	1.335	1.28
2300	MM	5.82 / 5.83	3.46 / 3.49	5	1.33	1.25

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - AQCS

DATE: 8/11/95

TOWER: A

TIME	INITIALS	ABSORBER pH	QUENCHER pH	INJECTION RATE (% base of request feed valve)	MIX RATIO (Density)	PRESSURE DROP ACROSS TOWER
0000	MM	5.80 / 5.82	3.39 / 3.41	5	1.335	1.25
0100	MM	5.80 / 5.83	3.35 / 3.38	5	1.33	1.20
0200	MA	5.80 / 5.83	3.32 / 3.34	5	1.325	1.20
0300	MM	5.80 / 5.82	3.26 / 3.28	6	1.325	1.10
0400	MM	5.81 / 5.83	3.34 / 3.37	6	1.34	1.20
0500	MM	5.81 / 5.84	3.07 / 3.08	5	1.34	1.20
0600	Van	5.78 / 5.82	3.06 / 3.09	6	1.34	1.25
0700	Van	5.77 / 5.81	2.87 / 2.88	6	1.355	1.25
0800	Van	5.79 / 5.83	3.10 / 3.13	6	1.345	1.25
0900	Van	5.80 / 5.84	3.19 / 3.23	6	1.355	1.25
1000	Van	5.80 / 5.84	3.09 / 3.13	6	1.355	1.25
1100	Van	5.80 / 5.84	3.15 / 3.18	6	1.36	1.25
1200	Van	5.80 / 5.84	3.17 / 3.20	5	1.37	1.30
1300	Van	5.83 / 5.84	3.05 / 3.05	5	1.365	1.25
1400	Van	5.81 / 5.85	3.08 / 3.12	6	1.38	1.35
1500	Van	5.81 / 5.86	3.15 / 3.18	5	1.38	1.35
1600	Van	5.82 / 5.87	3.12 / 3.15	5	1.38	1.30
1700	Van	5.80 / 5.85	3.08 / 3.10	6	1.38	1.30
1800	R. Reed	5.79 / 5.86	2.96 / 2.97	6	1.38	1.30
1900	R. Reed	5.81 / 5.87	2.96 / 2.98	6	1.37	1.31
2000	R. Reed	5.81 / 5.87	3.11 / 3.12	7	1.35	1.27
2100	R. Reed	5.82 / 5.89	3.13 / 3.14	7	1.032	1.27
2200	R. Reed	5.81 / 5.87	3.04 / 3.05	6	1.021	1.25
2300	R. Reed	5.83 / 5.89	3.03 / 3.05	6	1.033	1.24

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - AQCS

DATE: 8-12-95

TOWER: A

TIME	INITIALS	ABSORBER pH	QUENCHER pH	INJECTION RATE (% time of request feed valve)	MIX RATIO (Density)	PRESSURE DROP ACROSS TOWER
0000	R. Rudy	5.81 / 5.87	3.05 / 3.06	6	1.034	1.27
0100	R. Rudy	5.82 / 5.89	3.03 / 3.05	6	1.037	1.26
0200	R. Rudy	5.81 / 5.88	3.04 / 3.05	6	1.026	1.25
0300	R. Rudy	5.81 / 5.88	3.10 / 3.12	6	1.034	1.25
0400	R. Rudy	5.81 / 5.89	3.08 / 3.10	6	1.036	1.20
0500	R. Rudy	5.83 / 5.91	3.13 / 3.15	6	1.041	1.22
0600	Van	5.83 / 5.91	3.09 / 3.10	6	1.37	1.10
0700	Van	5.80 / 5.88	2.69 / 2.70	6	1.37	1.15
0800	Van	5.81 / 5.90	3.13 / 3.16	6	1.37	1.25
0900	Van	5.83 / 5.89	3.11 / 3.12	6	1.355	1.25
1000	Van	5.82 / 5.88	3.12 / 3.16	6	1.34	1.25
1100	Van	5.82 / 5.88	3.12 / 3.14	6	1.37	1.25
1200	Van	5.82 / 5.89	3.16 / 3.17	6	1.36	1.25
1300	Van	5.80 / 5.87	3.06 / 3.07	6	1.37	1.25
1400	Van	5.82 / 5.88	3.11 / 3.12	6	1.36	1.25
1500	Van	5.81 / 5.87	3.07 / 3.09	6	1.37	1.30
1600	Van	5.84 / 5.90	3.06 / 3.05	6	1.365	1.25
1700	Van	5.86 / 5.89	2.73 / 2.77	6	1.35	1.20
1800	T.D.	5.83 / 5.89	3.11 / 3.11	6	1.35	1.30
1900	T.D.	5.84 / 5.90	3.06 / 3.07	6	1.35	1.20
2000	T.D.	5.83 / 5.89	3.22 / 3.25	6	1.35	1.25
2100	T.D.	5.81 / 5.87	3.09 / 3.12	6	1.35	1.30
2200	T.D.	5.80 / 5.85	2.77 / 2.77	5	1.35	1.30
2300	T.D.	5.77 / 5.82	2.67 / 2.68	6	1.35	1.25

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - AQCS

DATE: 3.13.95

TOWER: A

TIME	INITIALS	ABSORBER pH	QUENCHER pH	INJECTION RATE (% flow of reagent feed valve)	MIX RATIO (Density)	PRESSURE DROP ACROSS TOWER
0000	TD	5.30 / 5.31	2.62 / 2.63	7	1.34	1.20
0100	TD	5.77 / 5.42	2.63 / 2.63	7	1.345	1.20
0200	T.D.	5.76 / 5.80	2.65 / 2.64	7	1.34	1.20
0300	T.D.	5.30 / 5.84	2.64 / 2.65	8	1.345	1.25
0400	T.D.	5.77 / 5.71	2.62 / 2.65	8	1.345	1.15
0500	T.D.	5.79 / 5.85	2.60 / 2.61	8	1.34	1.20
0600	Wam	5.79 / 5.83	2.58 / 2.60	8	1.34	1.25
0700	Wam	5.79 / 5.84	2.58 / 2.59	8	1.34	1.25
0800	Wam	5.80 / 5.84	2.56 / 2.58	8	1.34	1.30
0900	Wam	5.80 / 5.83	2.57 / 2.58	8	1.32	1.25
1000	Wam	5.80 / 5.83	2.56 / 2.58	8	1.34	1.25
1100	Wam	5.81 / 5.83	2.55 / 2.57	8	1.34	1.02
1200	Wam	5.81 / 5.83	2.56 / 2.58	8	1.34	1.25
1300	Wam	5.81 / 5.84	2.54 / 2.55	8	1.34	1.30
1400	Wam	5.83 / 5.86	3.00 / 3.10	8	1.35	1.30
1500	Wam	5.80 / 5.83	2.65 / 2.65	8	1.35	1.30
1600	Wam	5.80 / 5.85	2.59 / 2.59	8	1.36	1.30
1700	Wam	5.82 / 5.85	2.55 / 2.55	8	1.355	1.30
1800	T.D.	5.78 / 5.91	2.59 / 2.58	7	1.36	1.20
1900	T.D.	5.80 / 5.84	2.89 / 2.88	9	1.35	1.20
2000	T.D.	5.82 / 5.86	3.21 / 3.22	9	1.35	1.30
2100	T.D.	5.85 / 5.89	3.17 / 3.17	9	1.35	1.20
2200	TD	5.84 / 5.87	3.12 / 3.13	7	1.35	1.25
2300	T.D.	5.84 / 5.87	3.11 / 3.10	8	1.34	1.30

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - AQCS

DATE: 8.14.95

TOWER: A

TIME	INITIALS	ABSORBER pH	QUENCHER pH	INJECTION RATE (% flow of reagent feed valve)	MIX RATIO (Density)	PRESSURE DROP ACROSS TOWER
0000	T.D.	5.74 / 5.87	3.15 / 3.14	7	1.34	1.20
0100	T.D.	5.73 / 5.86	3.11 / 3.12	8	1.34	1.25
0200	T.D.	5.81 / 5.84	3.17 / 3.17	8	1.34	1.15
0300	T.D.	5.72 / 5.86	3.12 / 3.12	8	1.33	1.25
0400	T.D.	5.82 / 5.84	3.10 / 3.10	7	1.34	1.25
0500	TD	5.79 / 5.82	3.13 / 3.13	7	1.34	1.25
0600	CS	5.82 / 5.85	3.08 / 3.09	8	1.33	1.25
0700	CS	5.80 / 5.84	3.09 / 3.09	8	1.33	1.25
0800	CS	5.80 / 5.83	3.16 / 3.14	8	1.33	1.25
0900	CS	5.81 / 5.84	3.09 / 3.08	8	1.33	1.25
1000	CS	5.79 / 5.82	3.14 / 3.14	8	1.33	1.25
1100	CS	5.79 / 5.80	3.12 / 3.13	8	1.33	1.25
1200	CS	5.79 / 5.81	3.16 / 3.16	8	1.34	1.25
1300	CS	5.81 / 5.83	3.42 / 3.43	8	1.34	1.25
1400	CS	5.78 / 5.81	3.17 / 3.17	8	1.35	1.25
1500	CS	5.80 / 5.82	3.13 / 3.13	8	1.35	1.30
1600	CS	5.78 / 5.81	3.52 / 3.55	8	1.34	1.30
1700	CS	5.81 / 5.83	3.45 / 3.46	8	1.35	1.30
1800	Wom	5.77 / 5.80	3.14 / 3.13	8	1.35	1.40
1900	Wom	5.80 / 5.82	3.45 / 3.44	8	1.36	1.30
2000	Wom	5.79 / 5.82	3.47 / 3.47	8	1.36	1.30
2100	Wom	5.80 / 5.82	3.48 / 3.42	8	1.355	1.30
2200	Wom	5.78 / 5.80	3.16 / 3.13	8	1.35	1.30
2300	Wom	5.79 / 5.81		8	1.36	1.30

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - AQCS

DATE: 8-15-95

TOWER: A

TIME	INITIALS	ABSORBER pH	QUENCHER pH	INJECTION RATE (% time of reagent feed valve)	MIX RATIO (Density)	PRESSURE DROP ACROSS TOWER
0000	van	5.79 / 5.81	3.29 / 3.27	7	1.35	1.20
0100	van	5.79 / 5.82	3.19 / 3.19	8	1.35	1.20
0200	van	5.90 / 5.83	3.20 / 3.19	8	1.345	1.25
0300	van	5.79 / 5.82	3.27 / 3.26	8	1.345	1.30
0400	van	5.83 / 5.86	3.30 / 3.30	8	1.34	1.30
0500	van	5.83 / 5.85	3.25 / 3.24	8	1.34	1.25
0600	CS	5.83 / 5.85	3.26 / 3.26	8	1.35	1.20
0700	CS	5.80 / 5.83	3.33 / 3.33	8	1.34	1.20
0800	CS	5.83 / 5.86	3.36 / 3.36	6	1.34	1.20
0900	CS	5.82 / 5.84	3.35 / 3.34	8	1.34	1.25
1000	CS	5.82 / 5.84	3.35 / 3.34	8	1.34	1.25
1100	CS	5.85 / 5.87	3.32 / 3.32	8	1.35	1.25
1200	CS	5.86 / 5.88	3.90 / 3.92	9	1.34	1.25
1300	CS	5.87 / 5.89	4.33 / 4.37	9	1.34	1.25
1400	CS	5.89 / 5.90	4.61 / 4.65	9	1.34	1.25
1500	CS	5.92 / 5.93	4.64 / 4.69	9	1.35	1.25
1600	CS	5.92 / 5.93	4.76 / 4.83	9	1.33	1.25
1700	CS	5.93 / 5.94	4.70 / 4.76	9	1.33	1.25
1800	van	5.93 / 5.94	4.65 / 4.71	9	1.34	1.30
1900	van	5.93 / 5.94	4.55 / 4.61	9	1.34	1.30
2000	van	5.92 / 5.93	4.61 / 4.66	9	1.34	1.30
2100	van	5.94 / 5.95	4.57 / 4.64	8	1.34	1.25
2200	van	5.93 / 5.94	4.51 / 4.57	8	1.34	1.30
2300	van	5.92 / 5.94	4.51 / 4.56	8	1.33	1.25

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - AQCS

DATE: 8-16-95

TOWER: A

TIME	INITIALS	ABSORBER pH	QUENCHER pH	INJECTION RATE (% flow of reagent feed valve)	MIX RATIO (Density)	PRESSURE DROP ACROSS TOWER
0000	Vam	5.93 / 5.95	4.75 / 4.92	8	1.325	1.25
0100	Vam	5.93 / 5.94	4.69 / 4.78	8	1.34	1.25
0200	Vam	5.94 / 5.96	4.64 / 4.71	7	1.32	1.25
0300	Vam	5.93 / 5.95	4.61 / 4.70	7	1.325	1.25
0400	Vam	5.93 / 5.95	4.56 / 4.63	7	1.32	1.25
0500	Vam	5.93 / 5.95	4.43 / 4.49	7	1.32	1.20
0600	CS	5.93 / 5.95	4.43 / 4.50	7	1.32	1.25
0700	CS	5.94 / 5.95	4.40 / 4.47	6	1.32	1.20
0800	CS	5.94 / 5.95	4.46 / 4.53	6	1.32	1.25
0900	CS	5.95 / 5.96	4.53 / 4.59	7	1.33	1.20
1000	CS	5.95 / 5.96	4.52 / 4.58	6	1.33	1.25
1100	CS	5.95 / 5.96	4.59 / 4.67	5	1.35	1.25
1200	CS	5.95 / 5.96	4.74 / 4.81	5	1.36	1.25
1300	CS	5.95 / 5.96	4.49 / 4.56	5	1.33	1.25
1400	CS	5.94 / 5.94	4.31 / 4.37	5	1.33	1.25
1500	CS	5.94 / 5.95	4.22 / 4.27	5	1.33	1.25
1600	CS	5.94 / 5.94	4.18 / 4.22	5	1.34	1.25
1700	CS	5.93 / 5.94	4.51 / 4.56	7	1.34	1.25
1800	Vam	5.95 / 5.96	4.63 / 4.68	6	1.34	1.25
1900	Vam	5.96 / 5.96	4.80 / 4.86	6	1.33	1.25
2000	Vam	5.95 / 5.96	4.87 / 4.94	5	1.33	1.25
2100	Vam	5.94 / 5.95	4.86 / 4.93	5	1.32	1.25
2200	Vam	5.95 / 5.96	4.85 / 4.93	7	1.32	1.25
2300	Vam	5.95 / 5.96	4.84 / 4.87	7	1.3	1.25

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - AQCS

DATE: 8-17-95

TOWER: A

TIME	INITIALS	ABSORBER pH	QUENCHER pH	INJECTION RATE (% size of reagent feed valve)	MIX RATIO (Density)	PRESSURE DROP ACROSS TOWER
0000	van	5.96 5.98	4.78 4.86	7	1.31	1.25
0100	van	5.97 5.98	4.67 4.74	6	1.31	1.20
0200	van	5.98 5.98	4.58 4.65	8	1.31	1.25
0300	van	5.99 5.99	4.49 4.54	8	1.31	1.25
0400	van	5.99 6.00	4.34 4.40	9	1.31	1.20
0500	van	6.00 6.01	4.09 4.15	6	1.305	1.10
0600	cs	5.98 5.99	4.48 4.53	8	1.30	1.25
0700	cs	5.99 6.00	4.14 4.21	8	1.34	1.25
0800	cs	6.01 6.01	4.71 4.78	8	1.31	1.25
0900	cs	6.01 6.01	4.64 4.70	8	1.31	1.25
1000	cs	6.01 6.01	4.06 4.11	8	1.31	1.25
1100	cs	6.02 6.01	4.59 4.58	8	1.31	1.25
1200	cs	5.99 5.98	4.21 4.20	11	1.31	1.25
1300	cs	5.98 5.98	3.96 3.92	11	1.32	1.25
1400	cs	5.99 5.98	3.95 3.93	12	1.34	1.25
1500	cs	5.99 5.98	4.26 4.24	12	1.335	1.25
1600	cs	6.00 5.99	4.17 4.15	12	1.34	1.40
1700	cs	5.97 5.97	3.93 3.89	12	1.34	1.25
1800	T.D.	5.99 5.99	3.91 3.87	12	1.32	1.25
1900	T.D.	5.97 5.97	3.82 3.77	13	1.32	1.25
2000	T.D.	5.99 5.98	4.01 3.97	13	1.32	1.30
2100	T.D.	5.97 5.98	3.95 3.90	13	1.31	1.30
2200	T.D.	6.01 6.02	4.20 4.15	13	1.30	1.30
2300	T.D.	6.0 6.01	4.03 3.98	10	1.31	1.25

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - AQCS

DATE: 2.17.95

TOWER: A

TIME	INITIALS	ABSORBER pH	QUENCHER pH	INJECTION RATE (% time of reagent feed valve)	MIX RATIO (Density)	PRESSURE DROP ACROSS TOWER
0000	T.D.	6.0 5.99	4.14 4.11	10	1.31	1.25
0100	T.D.	6.0 6.0	4.04 4.0	10	1.305	1.25
0200	T.D.	5.94 5.98	3.92 3.75	10	1.31	1.25
0300	T.D.	5.97 5.97	3.27 3.42	10	1.305	1.25
0400	T.D.	5.97 5.98	4.53 4.52	11	1.30	1.30
0500	T.D.	5.94 5.94	4.0 3.74	11	1.30	1.35
0600	LJA	5.97 5.96	3.95 3.89	12	1.29	1.30
0700	LJA	5.96 5.96	4.12 4.08	12	1.29	1.25
0800	LJA	5.97 5.97	4.20 4.15	13	1.29	1.28
0900	LJA	5.96 5.96	3.97 3.90	13	1.28	1.25
1000	LJA	5.98 5.97	4.24 4.26	14	1.28	1.30
1100	LJA	5.99 5.99	4.35 4.32	14	1.28	1.28
1200	LJA	5.98 5.97	4.18 4.16	14	1.295	1.35
1300	LJA	5.95 5.94	4.05 3.97	15	1.28	1.30
1400	LJA	6.00 5.99	4.32 4.28	16	1.29	1.40
1500	LJA	5.98 5.97	4.37 4.33	16	1.29	1.40
1600	LJA	5.96 5.94	3.73 3.64	17	1.29	1.35
1700	LJA	5.98 5.97	4.32 4.28	17	1.30	1.50
1800	T.D.	5.99 5.98	3.65 3.78	17	1.30	1.45
1900	T.D.	5.94 5.94	3.58 3.49	17	1.28	1.45
2000	T.D.	5.97 5.94	3.88 3.79	17	1.28	1.40
2100	T.D.	5.94 5.97	3.98 3.90	17	1.27	1.40
2200	T.D.	5.97 5.94	3.54 2.88	17	1.27	1.40
2300	T.D.	5.99 5.98	3.91 3.75	17	1.27	1.45

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - AQCS

DATE: 3.19.95

TOWER: A

TIME	INITIALS	ABSORBER pH	QUENCHER pH	INJECTION RATE (% flow of ramped feed value)	MIX RATIO (Density)	PRESSURE DROP ACROSS TOWER
0000	T.D.	5.97 / 5.97	3.94 / 3.72	17	1.27	1.40
0100	T.D.	5.99 / 5.98	3.92 / 3.86	18	1.27	1.45
0200	T.D.	5.97 / 5.96	3.74 / 3.81	18	1.26	1.45
0300	T.D.	5.94 / 5.95	3.76 / 3.61	19	1.265	1.40
0400	TD	5.97 / 5.95	3.91 / 3.85	20	1.265	1.4
0500	T.D.	5.94 / 5.94	3.95 / 3.90	20	1.27	1.4
0600	PJA	5.98 / 5.97	3.92 / 3.86	22	1.265	1.45
0700	PJA	6.00 / 5.98	4.59 / 4.55	22	1.26	1.45
0800	PJA	6.00 / 5.99	4.69 / 4.67	22	1.27	1.45
0900	PJA	6.01 / 6.00	3.65 / 3.58	22	1.265	1.50
1000	PJA	6.02 / 6.01	4.73 / 4.69	21	1.27	1.50
1100	PJA	6.00 / 5.99	3.59 / 3.51	21	1.27	1.45
1200	PJA	6.00 / 5.98	4.63 / 4.59	21	1.27	1.50
1300	PJA	6.01 / 5.99	3.91 / 3.85	21	1.27	1.47
1400	PJA	5.96 / 5.94	3.52 / 3.44	21	1.27	1.45
1500	PJA	5.99 / 5.97	4.61 / 4.56	21	1.29	1.40
1600	PJA	5.98 / 5.96	3.50 / 3.42	21	1.325	1.45
1700	PJA	6.05 / 6.03	4.80 / 4.76	19	1.30	1.45
1800	T.D.	6.07 / 6.06	4.76 / 4.68	12	1.29	1.35
1900	T.D.	6.07 / 6.07	3.77 / 3.71	12	1.29	1.35
2000	T.D.	6.12 / 6.10	4.25 / 4.20	9	1.29	1.25
2100	T.D.	6.11 / 6.09	3.61 / 3.55	6	1.29	1.30
2200	TD.	6.10 / 6.08	4.62 / 3.79	6	1.29	1.25
2300		6.09 / 6.07	3.99 / 3.96	6	1.29	1.25

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - AQCS

DATE: 7-18-95

TOWER: 1B

TIME	INITIALS	ABSORBER pH	QUENCHER pH	INJECTION RATE (% flow of reagent feed valve)	MIX RATIO (Density)	PRESSURE DROP ACROSS TOWER
0000						
0100						
0200						
0300						
0400						
0500						
0600						
0700	cs	5.86 5.96	3.41 3.30	5	1.33	1.15
0800	cs	5.86 5.95	3.45 3.33	5	1.335	1.20
0900	cs	5.88 5.96	3.44 3.33	4	1.32	1.20
1000	cs	5.84 5.92	3.44 3.33	4	1.34	1.20
1100	cs	5.87 5.94	3.40 3.31	4	1.33	1.20
1200	cs	5.86 5.94	3.40 3.30	4	1.33	1.20
1300	cs	5.84 5.92	3.37 3.27	4	1.33	1.20
1400	cs	5.83 5.91	3.40 3.27	4	1.34	1.20
1500	cs	5.82 5.90	3.44 3.33	5	1.33	1.15
1600	cs	5.85 5.93	3.40 3.30	4	1.33	1.20
1700	cs	5.84 5.91	3.39 3.30	4	1.33	1.25
1800	van	5.83 5.91	3.42 3.31	4	1.34	1.25
1900	van	5.79 5.87	3.37 3.27	4	1.33	1.20
2000	van	5.78 5.85	3.42 3.30	4	1.33	1.20
2100	van	5.78 5.87	3.41 3.30	4	1.33	1.25
2200	van	5.78 5.87	3.36 3.27	4	1.33	1.20
2300	van	5.78 5.86	3.44 3.33	4	1.33	1.10

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - AQCS

DATE: 7-19-95

TOWER: 1B

TIME	INITIALS	ABSORBER pH	QUENCHER pH	INJECTION RATE (% flow of reagent feed valve)	MIX RATIO (Density)	PRESSURE DROP ACROSS TOWER
0000	van	5.79 5.88	3.43 3.31	4	1.34	1.10
0100	van	5.77 5.84	3.41 3.31	4	1.33	1.25
0200	van	5.77 5.85	3.38 3.29	4	1.32	1.20
0300	van	5.77 5.84	3.41 3.30	4	1.32	1.20
0400	van	5.76 5.84	3.44 3.31	4	1.33	1.20
0500	van	5.76 5.85	3.41 3.31	4	1.32	1.20
0600	cs	5.76 5.84	3.44 3.31	4	1.32	1.15
0700	cs	5.76 5.84	3.44 3.32	5	1.32	1.10
0800	cs	5.75 5.84	3.41 3.31	4	1.32	1.10
0900	cs	5.75 5.82	3.49 3.36	4	1.32	1.15
1000	cs	5.75 5.82	3.41 3.31	4	1.32	1.20
1100	cs	5.77 5.83	3.37 3.27	4	1.32	1.20
1200	cs	5.77 5.84	3.34 3.26	4	1.32	1.25
1300	cs	5.76 5.83	3.35 3.25	4	1.32	1.25
1400	cs	5.74 5.80	3.41 3.29	4	1.335	1.25
1500	cs	5.75 5.83	3.38 3.27	4	1.32	1.20
1600	cs	5.74 5.81	3.60 3.45	5	1.32	1.25
1700	cs	5.77 5.84	3.47 3.37	4	1.32	1.25
1800	van	5.76 5.84	3.49 3.36	4	1.33	1.25
1900	van	5.72 5.83	3.37 3.26	4	1.33	1.25
2000	van	5.67 5.82	3.61 3.46	4	1.33	1.25
2100	van	5.72 5.81	3.59 3.46	4	1.33	1.20
2200	van	5.72 5.82	3.30 3.23	4	1.33	1.25
2300	van	5.73 5.82	3.16 3.10	4	1.33	1.25

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - AQCS

DATE: 7-20-95

TOWER: 1B

TIME	INITIALS	ABSORBER pH	QUENCHER pH	INJECTION RATE (% flow of reagent feed valve)	MIX RATIO (Density)	PRESSURE DROP ACROSS TOWER
0000	van	5.73 5.82	3.08 3.02	5	1.33	1.20
0100	van	5.72 5.81	3.10 3.03	5	1.33	1.20
0200	van	5.74 5.82	3.05 3.00	5	1.33	1.25
0300	van	5.75 5.82	3.04 2.99	5	1.33	1.20
0400	van	5.77 5.85	3.05 3.00	5	1.33	1.20
0500	MN	5.77 5.84	3.06 3.01	5	1.33	1.25
0600	es	5.75 5.84	3.03 2.97	5	1.33	1.20
0700	es	5.77 5.85	3.02 2.96	5	1.32	1.25
0800	es	5.76 5.84	3.02 2.97	5	1.315	1.25
0900	es	5.76 5.84	3.01 2.96	4	1.32	1.10
1000	es	5.75 5.82	2.95 2.91	4	1.30	1.25
1100	es	5.74 5.81	2.91 2.88	4	1.31	1.20
1200	es	5.75 5.82	3.37 3.25	4	1.32	1.25
1300	es	5.76 5.83	3.21 3.12	4	1.37	1.25
1400	es	5.78 5.86	3.41 3.31	4	1.365	1.25
1500	es	5.75 5.83	3.13 3.07	4	1.375	1.25
1600	es	5.74 5.82	3.04 2.98	4	1.37	1.25
1700						
1800						
1900						
2000						
2100						
2200						
2300						

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - AQCS

DATE: 8-8-95

TOWER: 1B

TIME	INITIALS	ABSORBER pH	QUENCHER pH	INJECTION RATE (% flow of reagent feed valve)	MIX RATIO (Density)	PRESSURE DROP ACROSS TOWER
0000						
0100						
0200						
0300						
0400						
0500						
0600						
0700	T.D.	5.71 / 5.96	4.54 / 3.04	3	1.33	1.20
0800	T.D.	5.63 / 5.93	4.49 / 3.04	3	1.33	1.20
0900	T.D.	5.70 / 5.92	4.48 / 3.01	5	1.33	1.20
1000	T.D.	5.63 / 5.93	4.49 / 3.03	5	1.33	1.15
1100	T.D.	5.74 / 5.95	4.59 / 3.07	5	1.33	1.25
1200	T.D.	5.74 / 5.95	4.55 / 3.07	5	1.33	1.20
1300	T.D.	5.75 / 5.94	4.62 / 3.13	5	1.33	1.20
1400	TD	5.74 / 5.95	4.60 / 3.11	5	1.33	1.20
1500	T.D.	5.77 / 5.95	4.63 / 3.13	5	1.33	1.20
1600	TD	5.74 / 5.95	4.62 / 3.14	5	1.33	1.25
1700	T.D.	5.75 / 5.94	4.69 / 3.12	5	1.33	1.20
1800	cs	5.73 / 5.94	4.64 / 3.15	5	1.33	1.25
1900	cs	5.74 / 5.95	4.64 / 3.15	5	1.325	1.20
2000	cs	5.74 / 5.95	4.61 / 3.13	5	1.33	1.20
2100	cs	5.78 / 5.95	4.65 / 3.17	5	1.33	1.20
2200	cs	5.73 / 5.99	4.63 / 3.15	5	1.33	1.20
2300	cs	5.79 / 5.97	4.75 / 3.26	5	1.34	1.20

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - AQCS

DATE: 8-9-95

TOWER: B

TIME	INITIALS	ABSORBER pH	QUENCHER pH	INJECTION RATE (% time of response feed valve)	MIX RATIO (Density)	PRESSURE DROP ACROSS TOWER
0000	CS	5.81 / 5.98	4.78 / 3.28	4	1.34	1.10
0100	CS	5.82 / 5.99	4.78 / 3.29	4	1.34	1.10
0200	CS	5.80 / 5.98	4.71 / 3.22	4	1.34	1.10
0300	CS	5.79 / 5.98	4.64 / 3.15	4	1.34	1.20
0400	CS	5.78 / 5.98	4.64 / 3.16	4	1.34	1.20
0500	CS	5.83 / 6.01	5.21 / 3.66	4	1.34	1.20
0600	T.D.	5.21 / 5.99	5.06 / 3.51	3	1.335	1.20
0700	T.D.	5.21 / 5.78	3.36 / 3.42	3	1.34	1.20
0800	T.D.	5.26 / 5.77	3.27 / 3.33	3	1.34	1.10
0900	T.D.	5.92 / 5.77	3.14 / 3.24	3	1.34	1.20
1000	T.D.	5.92 / 5.77	3.10 / 3.20	4	1.33	1.25
1100	T.D.	5.97 / 5.77	3.02 / 3.13	4	1.33	1.25
1200	T.D.	5.92 / 5.77	2.98 / 3.09	4	1.33	1.20
1300	T.D.	5.77 / 5.77	2.53 / 3.04	4	1.33	1.25
1400	T.D.	5.21 / 5.75	2.94 / 3.07	6	1.33	1.15
1500	T.D.	5.21 / 5.78	3.0 / 3.12	5	1.335	1.15
1600	T.D.	5.80 / 5.78	2.98 / 3.09	5	1.33	1.10
1700	T.D.	5.21 / 5.79	2.95 / 3.06	5	1.33	1.10
1800	CS	5.82 / 5.76	2.95 / 3.05	5	1.33	1.10
1900	CS	5.77 / 5.78	2.89 / 3.02	5	1.34	1.10
2000	CS	5.84 / 5.84	3.27 / 3.28	6	1.34	1.10
2100	CS	5.90 / 5.85	3.37 / 3.42	5	1.33	1.10
2200	CS	5.82 / 5.84	3.07 / 3.16	5	1.33	1.10
2300	CS	5.88 / 5.84	3.12 / 3.21	4	1.33	1.10

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - AQCS

DATE: 8-10-95

TOWER: B

TIME	INITIALS	ABSORBER pH	QUENCHER pH	INJECTION RATE (% flow of reagent feed valve)	MIX RATIO (Density)	PRESSURE DROP ACROSS TOWER
0000	CS	5.83 5.82	2.97 3.08	4	1.33	1.10
0100	CS	5.84 5.83	2.95 3.05	4	1.34	1.10
0200	CS	5.80 5.80	2.93 3.04	4	1.34	1.10
0300	CS	5.82 5.82	2.89 3.02	4	1.335	1.15
0400	CS	5.81 5.82	2.87 3.00	3	1.33	1.10
0500	CS	5.80 5.81	2.80 2.95	3	1.33	1.05
0600	T.D.	5.79 5.81	2.77 2.91	5	1.33	1.10
0700	TD	5.77 5.80	2.75 2.82	5	1.33	1.10
0800	T.D.	5.77 5.79	2.82 2.86	4	1.33	1.10
0900	T.D.	5.77 5.81	2.86 2.90	7	1.335	1.10
1000	T.D.	5.77 5.81	2.82 2.93	7	1.32	1.05
1100	TD	5.80 5.81	2.91 2.97	5	1.33	1.10
1200	T.D.	5.80 5.81	2.95 3.01	5	1.33	1.10
1300	T.D.	5.77 5.79	2.91 2.95	4	1.35	1.15
1400	T.D.	5.76 5.79	2.90 2.93	4	1.34	1.10
1500	T.D.	5.80 5.80	2.93 2.95	6	1.34	1.20
1600	TD	5.77 5.79	2.92 2.95	6	1.33	1.10
1700	T.D.	5.75 5.80	2.96 2.97	6	1.34	1.05
1800	LJA	5.86 5.82	3.14 3.14	7	1.33	1.20
1900	LJA	5.79 5.81	3.13 3.11	8	1.33	1.20
2000	LJA	5.82 5.84	3.20 3.17	8	1.32	1.20
2100	LJA	5.81 5.84	3.20 3.19	7	1.335	1.20
2200	MM	5.81 5.84	3.18 3.15	7	1.325	1.18
2300	MM	5.80 5.84	3.27 3.23	7	1.325	1.15

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - AQCS

DATE: 8/11/95

TOWER: B

TIME	INITIALS	ABSORBER pH	QUENCHER pH	INJECTION RATE (% flow of ringmist feed valve)	MIX RATIO (Density)	PRESSURE DROP ACROSS TOWER
0000	MM	5.80/5.85	3.20/3.23	6	1.325	1.09
0100	MM	5.81/5.84	3.20/3.18	6	1.325	1.10
0200	MM	5.81/5.85	3.12/3.15	6	1.325	1.11
0300	MM	5.75/5.84	3.15/3.13	7	1.325	1.02
0400	MM	5.83/5.82	3.19/3.14	7	1.33	1.05
0500	MM	5.83/5.85	3.11/3.10	6	1.335	1.01
0600	van	5.83/5.84	3.10/3.09	6	1.345	1.10
0700	van	5.80/5.83	3.04/3.04	6	1.34	1.10
0800	van	5.79/5.84	3.03/3.03	6	1.34	1.08
0900	van	5.80/5.83	3.04/3.04	6	1.35	1.10
1000	van	5.84/5.86	3.08/3.07	6	1.35	1.05
1100	van	5.81/5.84	3.04/3.04	6	1.36	1.15
1200	van	5.83/5.84	3.07/3.05	5	1.37	1.15
1300	van	5.85/5.86	3.19/3.17	6	1.37	1.20
1400	van	5.83/5.87	3.24/3.21	6	1.37	1.20
1500	van	5.85/5.86	3.28/3.24	5	1.37	1.25
1600	van	5.83/5.84	3.21/3.18	5	1.375	1.25
1700	van	5.81/5.84	3.00/3.00	6	1.375	1.15
1800	R. Roach	5.81/5.84	2.98/2.96	6	1.023	1.25
1900	R. Roach	5.80/5.84	2.99/2.99	6	1.022	1.20
2000	R. Roach	5.81/5.86	3.85/3.75	6	1.022	1.20
2100	R. Roach	5.88/5.91	4.15/4.01	6	1.026	1.15
2200	R. Roach	5.91/5.94	4.43/4.24	5	1.024	1.15
2300	R. Roach	5.92/5.97	4.54/4.35	5	1.025	1.15

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - AQCS

DATE: 8.12.95

TOWER: 8

TIME	INITIALS	ABSORBER pH	QUENCHER pH	INJECTION RATE (% flow of reagent feed valve)	MIX RATIO (Density)	PRESSURE DROP ACROSS TOWER
0000	R. Rudy	5.95 5.98	4.51 4.30	5	1.023	1.20
0100	R. Rudy	5.93 5.97	3.65 3.56	5	1.023	1.20
0200	R. Rudy	5.97 5.98	3.40 3.35	5	1.020	1.20
0300	R. Rudy	5.92 5.96	3.13 3.12	5	1.020	1.10
0400	R. Rudy	5.88 5.95	2.91 2.92	5	1.018	1.10
0500	R. Rudy	5.87 5.95	2.78 2.81	5	1.016	1.0
0600	Wam	5.90 5.97	2.73 2.77	5	1.36	1.15
0700	Wam	5.89 5.94	2.69 2.73	6	1.36	1.10
0800	Wam	5.89 5.94	2.70 2.74	6	1.36	1.10
0900	Wam	5.89 5.94	2.69 2.73	6	1.35	1.20
1000	Wam	5.90 5.93	2.75 2.77	6	1.35	1.15
1100	Wam	5.89 5.92	2.71 2.75	6	1.35	1.10
1200	Wam	5.87 5.91	2.74 2.77	6	1.36	1.15
1300	Wam	5.82 5.90	2.69 2.69	6	1.36	1.20
1400	Wam	5.87 5.90	2.74 2.77	6	1.36	1.15
1500	Wam	5.87 5.89	2.75 2.78	6	1.37	1.20
1600	Wam	5.89 5.90	2.73 2.77	6	1.36	1.20
1700	Wam	5.84 5.90	3.05 3.05	6	1.36	1.20
1800	T.D.	5.82 5.87	2.71 2.73	6	1.34	1.15
1900	T.D.	5.81 5.87	2.67 2.71	6	1.345	1.15
2000	T.D.	5.85 5.89	2.70 2.73	7	1.35	1.20
2100	T.D.	5.83 5.87	2.72 2.76	7	1.35	1.15
2200	T.D.	5.82 5.85	2.73 2.77	7	1.34	1.10
2300	T.D.	5.83 5.86	2.75 2.78	7	1.34	1.10

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - AQCS

DATE: 8-12-95

TOWER: 18

TIME	INITIALS	ABSORBER pH		QUENCHER pH		INJECTION RATE (% time of reagent feed rates)	MIX RATIO (Density)	PRESSURE DROP ACROSS TOWER
0000	TD	5.82	5.87	2.71	2.74	7	1.34	1.10
0100	TD	5.77	5.84	2.68	2.73	7	1.33	1.05
0200	TD	5.82	5.89	2.45	3.40	8	1.33	1.25
0300	TD	5.84	5.92	3.67	3.59	8	1.33	1.10
0400	T.D.	5.83	5.93	3.83	3.72	8	1.33	1.05
0500	T.D.	5.91	5.96	3.64	3.57	6	1.33	1
0600	van	5.90	5.93	3.12	3.10	6	1.33	1.05
0700	van	5.94	5.93	2.75	2.80	6	1.33	1.05
0800	van	5.86	5.91	2.68	2.73	6	1.32	1.15
0900	van	5.82	5.89	2.64	2.70	7	1.32	1.10
1000	van	5.85	5.90	2.65	2.70	7	1.32	1.15
1100	van	5.84	5.89	2.63	2.69	8	1.33	1.15
1200	van	5.86	5.91	2.59	2.64	8	1.34	1.15
1300	van	5.85	5.88	2.60	2.66	8	1.335	1.15
1400	van	5.89	5.88	2.62	2.68	8	1.34	1.25
1500	van	5.84	5.86	2.64	2.68	8	1.35	1.25
1600	van	5.85	5.89	2.63	2.68	8	1.34	1.15
1700	van	5.80	5.85	2.62	2.67	8	1.35	1.20
1800	T.D.	5.78	5.84	2.60	2.64	8	1.34	1.10
1900	T.D.	5.79	5.87	3.12	3.11	9	1.345	1.15
2000	T.D.	5.76	5.92	3.73	3.67	9	1.35	1.15
2100	T.D.	5.90	5.9	3.82	3.71	9	1.35	1.20
2200	T.D.	5.91	5.96	3.76	3.74	8	1.345	1.15
2300	T.D.	6.29	5.97	3.87	3.74	8	1.34	1.15

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - AQCS

DATE: 2.14.95

TOWER: B

TIME	INITIALS	ABSORBER pH	QUENCHER pH	INJECTION RATE (% flow of reagent feed valve)	MIX RATIO (Density)	PRESSURE DROP ACROSS TOWER
0000	T.D.	6.21 / 6.0	3.73 / 3.73	7	1.34	1.10
0100	T.D.	5.97 / 5.99	3.77 / 3.64	7	1.345	1.10
0200	T.D.	6.01 / 5.99	3.15 / 3.13	7	1.34	1.10
0300	T.D.	5.93 / 5.97	2.72 / 2.71	7	1.33	1.15
0400	T.D.	5.78 / 5.94	2.62 / 2.67	7	1.335	1.15
0500	T.D.	5.75 / 5.93	2.55 / 2.60	7	1.33	1.10
0600	CS	5.76 / 5.91	2.47 / 2.53	7	1.33	1.15
0700	CS	5.75 / 5.90	2.45 / 2.52	7	1.33	1.15
0800	CS	5.77 / 5.92	2.40 / 2.48	7	1.33	1.15
0900	CS	5.72 / 5.87	2.31 / 2.42	8	1.32	1.20
1000	CS	5.78 / 5.88	2.30 / 2.40	8	1.33	1.20
1100	CS	5.77 / 5.88	2.31 / 2.40	8	1.34	1.20
1200	CS	5.79 / 5.88	2.30 / 2.40	8	1.34	1.20
1300	CS	5.74 / 5.86	2.27 / 2.38	8	1.33	1.20
1400	CS	5.80 / 5.90	3.31 / 3.28	8	1.34	1.20
1500	CS	5.81 / 5.89	3.23 / 3.20	8	1.35	1.15
1600	CS	5.91 / 5.92	3.73 / 3.65	8	1.34	1.25
1700	CS	5.83 / 5.90	3.70 / 3.63	8	1.35	1.20
1800	van	5.81 / 5.90	3.66 / 3.57	8	1.345	1.25
1900	van	5.82 / 5.90	3.55 / 3.47	8	1.35	1.25
2000	van	5.80 / 5.89	3.51 / 3.45	8	1.35	1.25
2100	van	5.80 / 5.87	3.48 / 3.42	8	1.35	1.30
2200	van	5.80 / 5.88	3.45 / 3.39	8	1.35	1.25
2300	van	5.82 / 5.87	3.44 / 3.40	8	1.35	1.20

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - AQCS

DATE: 8-15-95

TOWER: B

TIME	INITIALS	ABSORBER pH	QUENCHER pH	INJECTION RATE (% Gas of reagent feed valve)	MIX RATIO (Density)	PRESSURE DROP ACROSS TOWER
0000	Vam	5.91 5.88	3.40 3.42	7	1.35	1.00
0100	Vam	5.80 5.86	3.44 3.39	8	1.35	1.25
0200	Vam	5.84 5.89	3.45 3.49	8	1.35	1.20
0300	Vam	5.86 5.93	3.45 3.40	8	1.35	1.20
0400	Vam	5.89 5.92	3.48 3.43	8	1.34	1.15
0500	Vam	5.85 5.88	3.49 3.43	8	1.34	1.10
0600	CS	5.85 5.88	3.50 3.44	8	1.33	1.10
0700	CS	5.89 5.90	3.50 3.45	8	1.33	1.10
0800	CS	5.86 5.88	3.52 3.46	6	1.34	1.10
0900	CS	5.87 5.89	3.05 3.06	8	1.34	1.20
1000	CS	5.92 5.87	3.02 3.01	8	1.34	1.15
1100	CS	5.97 5.86	2.96 2.99	8	1.34	1.15
1200	CS	5.88 5.87	2.94 3.00	9	1.34	1.15
1300	CS	5.85 5.86	3.01 3.06	8	1.33	1.15
1400	CS	5.85 5.86	3.02 3.08	8	1.33	1.20
1500	CS	5.82 5.82	3.02 3.07	8	1.34	1.15
1600	CS	5.86 5.84	3.04 3.08	9	1.33	1.20
1700	CS	5.85 5.84	3.00 3.12	9	1.34	1.20
1800	Vam	5.81 5.87	3.24 3.25	9	1.325	1.20
1900	Vam	5.77 5.84	2.69 2.76	9	1.33	1.20
2000	Vam	5.88 5.94	3.05 3.09	9	1.33	1.20
2100	Vam	5.89 5.86	3.32 3.31	9	1.325	1.15
2200	Vam	5.96 5.85	3.32 3.32	9	1.33	1.15
2300	Vam	5.88 5.86	3.37 3.36	9	1.33	1.15

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - AQCS

DATE: 8-16-95

TOWER: B

TIME	INITIALS	ABSORBER pH	QUENCHER pH	INJECTION RATE (% Open of reagent feed valve)	MIX RATIO (Density)	PRESSURE DROP ACROSS TOWER
0000	van	5.86 5.87	3.30 3.30	9	1.33	1.20
0100	van	5.83 5.84	3.29 3.29	8	1.325	1.15
0200	van	5.82 5.84	3.41 3.39	9	1.31	1.20
0300	van	5.84 5.84	3.33 3.34	10	1.32	1.15
0400	van	5.90 5.88	3.49 3.46	10	1.32	1.15
0500	van	5.77 5.86	2.84 2.90	10	1.32	1.10
0600	cl	5.82 5.87	3.37 3.35	10	1.32	1.15
0700	cl	5.82 5.86	3.51 3.47	9	1.32	1.10
0800	cl	5.84 5.87	3.50 3.46	9	1.32	1.15
0900	cl	5.83 5.86	3.50 3.47	8	1.33	1.15
1000	cl	5.84 5.85	3.50 3.46	6	1.33	1.15
1100	cl	5.77 5.83	3.48 3.45	6	1.34	1.15
1200	cl	5.78 5.83	3.49 3.46	6	1.34	1.15
1300	cl	5.78 5.81	3.37 3.36	6	1.33	1.15
1400	cl	5.78 5.80	3.41 3.39	6	1.33	1.15
1500	cl	5.85 5.83	3.48 3.46	6	1.33	1.15
1600	cl	5.79 5.79	3.36 3.34	5	1.34	1.15
1700	cl	5.80 5.81	3.39 3.37	6	1.34	1.15
1800	van	5.73 5.78	3.34 3.34	7	1.34	1.20
1900	van	5.80 5.81	3.73 3.66	8	1.34	1.10
2000	van	5.82 5.83	3.69 3.65	8	1.33	1.15
2100	van	5.84 5.83	3.46 3.43	8	1.32	1.15
2200	van	5.86 5.84	3.52 3.49	9	1.32	1.20
2300	van	5.84 5.84	3.47 3.43	10	1.31	1.15

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - AQCS

DATE: 8-17-95

TOWER: K

TIME	INITIALS	ABSORBER pH	QUENCHER pH	INJECTION RATE (% time of request feed valve)	MIX RATIO (Density)	PRESSURE DROP ACROSS TOWER
0000	van	5.85 5.84	3.48 3.44	14	1.31	1.15
0100	van	5.91 5.89	3.64 3.58	14	1.31	1.15
0200	van	5.93 5.87	3.57 3.53	10	1.31	1.10
0300	van	5.86 5.89	3.62 3.58	14	1.31	1.10
0400	van	5.94 5.91	3.65 3.59	11	1.31	1.00
0500	van	5.90 5.92	3.73 3.67	7	1.305	1.00
0600	cd	5.88 5.90	3.59 3.55	9	1.30	1.15
0700	cd	5.89 5.89	3.70 3.63	9	1.33	1.10
0800	cd	5.96 5.90	3.73 3.67	8	1.31	1.10
0900	cd	5.92 5.89	3.68 3.63	7	1.31	1.10
1000	cd	5.93 5.89	3.65 3.59	7	1.31	1.10
1100	cd	5.84 5.87	3.47 3.45	7	1.31	1.10
1200	cd	5.84 5.86	3.46 3.44	10	1.31	1.15
1300	cd	5.82 5.87	3.40 3.38	14	1.32	1.20
1400	cd	5.88 5.88	3.96 3.88	14	1.34	1.15
1500	cd	5.89 5.90	4.05 3.96	14	1.33	1.15
1600	cd	5.89 5.89	4.12 4.00	14	1.34	1.15
1700	cd	5.91 5.91	4.15 4.03	14	1.34	1.20
1800	T.D.	5.90 5.93	4.19 4.02	14	1.33	1.15
1900	T.D.	5.89 5.92	4.24 4.13	14	1.31	1.20
2000	T.D.	5.92 5.94	4.12 4.01	14	1.32	1.20
2100	T.D.	5.92 5.94	3.74 3.77	13	1.31	1.20
2200	T.D.	5.90 5.93	3.91 3.83	13	1.31	1.20
2300	T.D.	5.93 5.90	3.90 3.81	11	1.31	1.10

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - AQCS

DATE: 8.18.95

TOWER: B

TIME	INITIALS	ABSORBER pH	QUENCHER pH	INJECTION RATE (% Rate of Request Feed Water)	MIX RATIO (Density)	PRESSURE DROP ACROSS TOWER
0000	T.D.	5.95 / 5.95	3.96 / 3.85	12	1.31	1.10
0100	T.D.	5.94 / 5.94	3.87 / 3.79	13	1.305	1.10
0200	T.D.	5.93 / 5.97	3.79 / 3.71	13	1.31	1.15
0300	T.D.	5.91 / 5.97	3.92 / 3.84	12	1.30	1.10
0400	T.D.	5.94 / 5.97	3.77 / 3.71	12	1.30	1.10
0500	T.D.	5.94 / 5.94	3.87 / 3.86	12	1.30	1.10
0600	RJA	5.94 / 5.95	3.78 / 3.71	12	1.29	1.10
0700	LJA	5.93 / 5.94	3.33 / 3.32	12	1.295	1.20
0800	RJA	5.97 / 5.96	3.80 / 3.72	12	1.29	1.20
0900	RJA	5.96 / 5.97	3.76 / 3.79	12	1.28	1.26
1000	LJA	5.91 / 5.94	3.78 / 3.72	14	1.28	1.20
1100	RJA	5.94 / 5.95	3.79 / 3.72	14	1.028	1.20
1200	RJA	5.94 / 5.96	3.84 / 3.76	14	1.295	1.20
1300	LJA	5.90 / 5.93	3.90 / 3.81	16	1.295	1.25
1400	LJA	5.95 / 5.94	3.92 / 3.84	16	1.29	1.25
1500	RJA	5.95 / 5.95	3.96 / 3.87	16	1.29	1.25
1600	RJA	5.96 / 5.96	4.04 / 3.94	17	1.29	1.25
1700	LJA	5.98 / 5.98	4.13 / 4.02	17	1.30	1.25
1800	T.D.	5.94 / 5.96	4.07 / 3.95	17	1.30	1.20
1900	T.D.	6.0 / 5.97	4.12 / 4.02	17	1.28	1.25
2000	T.D.	6.01 / 5.97	4.03 / 4.02	17	1.28	1.25
2100	T.D.	5.97 / 5.97	4.26 / 4.13	17	1.27	1.20
2200	T.D.	5.92 / 5.9	3.14 / 3.14	17	1.27	1.25
2300	T.D.	5.97 / 5.95	3.96 / 3.86	17	1.27	1.25

ST. JOHNS RIVER POWER PARK
PETROLEUM COKE/COAL TRIAL BURN
BASELINE & BLEND OPERATIONAL DATA - AQCS

DATE: 2.19.95

TOWER: B

TIME	INITIALS	ABSORBER pH	QUENCHER pH	INJECTION RATE <small>(% Open of reagent feed valve)</small>	MIX RATIO <small>(Density)</small>	PRESSURE DROP ACROSS TOWER
0000	T.D.	5.97 / 5.96	4.02 / 3.94	17	1.27	1.20
0100	T.D.	6.05 / 5.99	4.16 / 4.03	18	1.27	1.25
0200	T.D.	6.0 / 5.98	3.99 / 3.88	17	1.26	1.25
0300	T.D.	5.98 / 5.99	4.05 / 3.94	19	1.265	1.20
0400	T.D.	5.98 / 5.97	4.12 / 4.0	19	1.27	1.25
0500	T.D.	5.99 / 5.99	4.22 / 4.08	19	1.27	1.25
0600	LJA	5.97 / 5.96	4.26 / 4.12	21	1.27	1.25
0700	LJA	5.96 / 5.96	3.33 / 3.31	21	1.26	1.25
0800	LJA	5.98 / 5.95	4.10 / 3.99	21	1.27	1.28
0900	LJA	6.02 / 5.97	4.26 / 4.14	21	1.27	1.25
1000	LJA	6.01 / 5.98	4.33 / 4.20	20	1.27	1.25
1100	LJA	5.98 / 5.99	4.35 / 4.22	20	1.275	1.25
1200	LJA	5.98 / 5.98	4.42 / 4.28	20	1.27	1.25
1300	LJA	5.96 / 5.96	4.34 / 4.21	20	1.27	1.25
1400	LJA	5.97 / 5.95	4.39 / 4.25	20	1.27	1.25
1500	LJA	5.96 / 5.94	4.33 / 4.19	20	1.29	1.20
1600	LJA	5.96 / 5.94	4.38 / 4.24	20	1.32	1.25
1700	LJA	5.97 / 5.96	4.45 / 4.31	21	1.30	1.25
1800	T.D.	6.06 / 6.00	4.45 / 4.39	21	1.29	1.20
1900	T.D.	6.00 / 6.02	4.69 / 4.50	21	1.29	1.20
2000	T.D.	6.07 / 6.06	3.11 / 3.49	9	1.29	1.10
2100	T.D.	6.05 / 6.06	3.10 / 3.13	7	1.29	1.10
2200	T.D.	6.03 / 6.07	4.13 / 4.04	7	1.29	1.10
2300	T.D.	6.07 / 6.08	4.27 / 4.16	7	1.29	1.10

ATTACHMENT H

SJRO LC 95 053

March 17, 1995



Mr. C.H. Fancy, P.E.
Chief, Bureau of Air Regulation
Florida Dept. of Environmental Protection
2600 Blair Stone Road
Tallahassee, FL 32399-2400


RE: St. Johns River Power Park Unit #1
Request to Fire a Blend of Petroleum Coke and Bituminous Coal
Public Notice of Intent to Issue an Amendment

Dear Mr. Fancy:

A request to conduct tests for pollutant emissions while firing a blend of petroleum coke and bituminous coal at the above referenced facility was submitted to your agency on 12-20-94 with supplemental material submitted on 02-07-95. Your agency prepared a draft letter authorization and the "Public Notice Intent to Issue" which was received in our office 02-16-95.

A copy of the "Notice of Intent to Issue an Amendment" which was published in the Florida Times Union Friday, February 24, 1995 to commence the 14 day public comment period was submitted to your attention February 27, 1995. Pursuant to your request please find enclosed the "Affidavit of Publication" from the newspaper that published the notice, Florida Times Union.

Sincerely,


Jay Worley

Environmental & Safety Manager

JAW/pct

xc: H. Oven, FDEP
E. Frey, FDEP
S. Pace, RESD
R. Breitmoser, JEA

FLORIDA PUBLISHING COMPANY
Publisher
JACKSONVILLE, DUVAL COUNTY, FLORIDA

STATE OF FLORIDA
COUNTY OF DUVAL

Before the undersigned authority personally appeared

Cappy MacPherson who on oath says that he is

Classified Adv Inside Sales REP of The Florida Times-Union,

a daily newspaper published at Jacksonville in Duval County, Florida; that the

attached copy of advertisement, being a Legal Notice

in the matter of Notice of Intent to Issue an Amendment

in the Court,

was published in THE FLORIDA TIMES-UNION in the issues of

February 24, 1995

Affiant further says that the said The Florida Times-Union is a newspaper published at Jacksonville, in said Duval County, Florida, and that the said newspaper has heretofore been continuously published in said Duval County, Florida, The Florida Times-Union each day, has been entered as second class mail matter at the postoffice in Jacksonville, in said Duval County, Florida, for a period of one year next preceding the first publication of the attached copy of advertisement; and affiant further says that he has neither paid nor promised any person, firm or corporation any discount, rebate, commission or refund for purpose of securing this advertisement for publication in said newspaper.

Sworn to and subscribed before me

this 28 day of

February A.D. 19 95

Notary Public, State of Florida at Large.

VERA JANE LIKENS

My Commission Expires June 1, 1996

DA 444

BONDED THROUGH FAIR INSURANCE, INC.

Cappy MacPherson (Signature)

The applicant, St. Johns River Water Park, 1 New Berlin Road, Jacksonville, Florida 32224, submitted a request on December 28, 1994, and submitted material on February 7, 1995, to the Department's Site Certification Section for authorization to conduct petroleum emissions tests on SJRPP's Unit #1 boiler while firing a blend of petroleum coke and coal. The performance test protocol emissions will be conducted at base conditions (firing 100% coal only) and while firing a blend of petroleum coke and coal. Petroleum coke will be blended at a maximum of 25 percent weight, with coal during the trial performance tests. SJRPP's Unit #1 was certified under Certification No. PA 81-13, and Federal consent plan permit No. PSD-F-1-016, and is not currently permitted to fire petroleum coke in accordance with the referenced Site Certification and permit.

Requested for a modification and a determination of Prevention of Significant and/or Hazardous Air (NSA) requirements shall be in accordance with Chapter 62, Florida Statutes (F.S.); Florida Administrative Code (F.A.C.) Chapters 62-30 through 62-37 and 62-4; and Title 6 of the Code of Federal Regulations (CFR); Parts 62, 61 and 63 (July 1, 1993 version).

Under the performance test results are evaluated by the Department's Site Certification Section in affected parties (i.e., Duval County's Register and Environmental Services Department, U.S. EPA, National Park Service, Department's Bureau of Air Regulation, and etc.) and it is determined that actual pollutant emissions (baseline of 100% coal vs. a blend of petroleum coke and coal) did not increase, the Department may issue a modification to the Site Certification, No. PA 81-13, and a permit amendment to the Federal Permit, No. PSD-F-1-016(A), authorizing continuous utilization/firing of blend of petroleum coke and coal in the SJRPP Unit #1. However, if there is an actual emission increase in pollutant emissions, SJRPP will not be permitted to fire a blend of petroleum coke and coal in the emissions unit without further PSD and/or NSA evaluation by the Department's Site Certification Section and involved agencies/parties. The proposed project will occur at the applicant's facility located in Jacksonville, Duval County, Florida.

The Department has jurisdiction under Paragraph 603.014(1), F.S. The project is not exempt from Site Certification procedures. The Department has determined that a Site Certification modification and at least an amendment to the Federal Permit is required to modify the proposed activity. SJRPP wishes to modify the Conditions of Certification and amend/modify the Federal Permit to a permit allowing a blend of petroleum coke and coal in SJRPP's Unit #1 on a permanent basis. Subsequent proceedings will be announced providing an opportunity for any affected person to object in the following manner:

A person whose substantial interests are affected by the Department's proposed permitting decision may petition for an administrative procedure hearing in accordance with section 120.57, F.S. The petition must contain the information set forth below and must be filed (received) in the Office of General Counsel of the Department of 3400 State Street, Tallahassee, Florida 32309-0001, within fourteen (14) days of publication of this notice. The petitioner shall mail a copy of the petition to the applicant at the address indicated above at the time of filing. Petitioners to file a petition within this time period shall constitute a waiver of any right such person may have to request an administrative determination hearing under section 120.57 F.S.

The Petition shall contain the following information:

- (a) The name, address, and telephone number of each petitioner, the applicant's name and address; the Department's Site Certification File Number and the county in which the project is proposed;
(b) A statement of how and when each petitioner received notice of the Department's action or proposed action;
(c) A statement of how each petitioner's substantial interests are affected by the Department's action or proposed action;
(d) A statement of the material facts supporting petitioner's view;
(e) A statement of facts which petitioner desires reversed or modification of the Department's action or proposed action;
(f) A statement of which rules or statutes petitioner wishes revised or modified;
(g) A statement of the relief sought by petitioner, stating precisely the action petitioner wants the Department to take with respect to the applicant's action or proposed action.

A petitioner filing the administrative petition shall be notified by the administrative unit of the Department's final action. Any petition filed with the petitioner's name and address, from which substantial interests will be affected by the action of the Department will be referred to the Department's Office of General Counsel. The petitioner's petition to the Department's Office of General Counsel (received) within 14 days of publication of this notice in the Office of General Counsel of the Department. Failure to petition within the allowed time frame constitutes a waiver of any right such person may have to participate in the administrative procedure. Any subsequent intervention will only be at the approval of the presiding officer and shall comply with Part 28-1.003, F.A.C.

Department of Environmental Protection, Bureau of Air Regulation, 111 South Magnolia Drive, Tallahassee, Florida 32304

Duval County Register and Environmental Services Department, 67 West Church Street, Subj 408

ATTACHMENT I

CERTIFIED MAIL



SJRO LC 95 137

August 21, 1995

Mr. Steve Pace
RESO
421 West Church Street
Jacksonville, Florida 32202

RE: Site Certification No. PA 81-13
St. Johns River Power Park (SJRPP) Unit 1
Notification of Petroleum Coke/Coal Test Run Completion


Dear Mr. Pace:

The above referenced facility was authorized by the Florida Department of Environmental Protection's March 30, 1995 letter to test burn a blend of petroleum coke with coal. Condition #18 requires that "The Duval County's R&ESD office shall be notified, in writing on the date of the last test run completion".

The petroleum coke/coal blend test burn was completed on August 19, 1995. Stack testing was conducted throughout the test burn and completed on this date.

Please contact me at (904) 751-7729 if you have any questions.

Sincerely,



Jay Worley
Environmental & Safety Manager

JW/sj

xc: C. Fancy, FDEP
H. Oven, FDEP
R. Breitmoser, JEA
S. Serrian

ATTACHMENT J

**REGULATORY & ENVIRONMENTAL
SERVICES DEPARTMENT**
Air Quality Division

June 22, 1995



Mr. Jay Worley
Environmental & Safety Manager
St. Johns River Power Park (SJRPP)
11201 New Berlin Road
Jacksonville, Florida 32226

**RE: Request for Approval - Pollutants & Testing Methodology
Unit #1 Test Burn Using Petroleum Coke with Coal
Site Certification No. PA 81-13
SJRPP Correspondence of June 14, 1995**

Dear Mr. Worley:

This is to acknowledge receipt and review of the above captioned SJRPP correspondence, submitted June 15, 1995.

Regulatory & Environmental Services Department (RESD) agrees that the use of EPA Reference Test Methods 5B, 10, and 8 for the testing of particulate matter, carbon monoxide, and sulfuric acid mist, respectively, during the above referenced test burn, satisfies Condition No. 20 of the Site Certification.

If there are any questions concerning this matter, please contact me at (904) 630-3484.

Very truly yours,

Robert S. Pace, P.E.
Division Chief

RSP/WLW/be

c: AQD File 1710 B
Wayne Walker, AQD



CERTIFIED MAIL



SJRO LC 95 094

June 14, 1995

Mr. Steve Pace
RESO
421 W. Church St.
Jacksonville, FL 32202

RE: Site Certification No. PA 81-13
St. Johns River Power Park (SJRPP) Unit I
Authorization of Test Burn Using Petroleum Coke with Coal
Request for Approval - Pollutants & Testing Methodology

Dear Mr. Pace:

The above referenced facility was authorized by your agency's March 30, 1995, letter to test burn a blend of petroleum coke with coal (Attachment A). Condition #20 requires "Prior written approval of the pollutants to be tested for and the appropriate test methods are mandatory prior to commencement of testing. The proposal shall be submitted to the Site Certification Office, the Department's BAR office and the Duval County's RESD office for approval."

Pursuant to Condition #7, stack tests shall be conducted for the pollutants particulate matter, carbon monoxide and sulfuric acid mist. The following are the EPA Reference methodologies which are contained in 40 CFR 60 that shall be conducted:

- | | | | |
|----|--------------------|---|---------------|
| 1) | Particulate matter | - | EPA Method 5B |
| 2) | Carbon Monoxide | - | EPA Method 10 |
| 3) | Sulfuric Acid Mist | - | EPA Method 8 |

Conditions #3 and #4 specifies that as-burned fuel samples shall be collected and analyzed for sulfur, nitrogen and metals. The baseline coal and pet coke/coal blend shall be sampled from the sampling building loading belt transfer to the Unit 1 to analyze the parameters in accordance with the following methods:

SJRO LC 95 092


Page 2

- | | | |
|----|-----------|------------------------|
| 1) | Sulfur | ASTM D 4239 Method "C" |
| 2) | Nitrogen | ASTM D 5373 |
| 3) | Chromium | ASTM D 3683 |
| 4) | Lead | ASTM D 3683 |
| 5) | Mercury | ASTM D 3684 |
| 6) | Nickel | ASTM D 3683 |
| 7) | Beryllium | ASTM D 3683 |
| 8) | Vanadium | ASTM D 3683 |
| 9) | Zinc | ASTM D 3683 |

The testing is scheduled to commence July 11, 1995 for the baseline. Your expeditious review and response are appreciated.

Please contact me at (904) 751-7729 if you have any questions.

Sincerely,



Jay Worley
Environmental & Safety Manager

JAW/pct

cc: R. Breitmoser

KBN ENGINEERING AND APPLIED SCIENCES, INC.

Gainesville, Florida • Boca Raton, Florida • Jacksonville, Florida • Tampa, Florida • Washington, DC

1-800-333-4KBN