

PART 60 CO
RELATIVE ACCURACY
TEST REPORT
FOR
ST. JOHNS RIVER POWER PARK
UNITS 1 & 2 STACK & INLET
JACKSONVILLE, FL
December 12 & 13, 2001

Job # 01-315

Test Report Date: 1-25-02



GRACE CONSULTING, INC.
EMISSIONS TESTING SERVICES

RECEIVED

JAN 31 2002

BUREAU OF AIR REGULATION

January 25, 2002

I, Hal Stiles, hereby certify that the data obtained for St. Johns River Power Park, Units 1 & 2 Stack & Inlet in Jacksonville, FL are in accordance with procedures set forth by the USEPA. This report accurately represents the data obtained from the testing procedures and analysis of this data.

Hal Stiles
Crew Chief

I, Carl Vineyard, hereby certify that I have reviewed this report and to the best of my knowledge, the data presented herein is complete and accurate.

Carl Vineyard, P.E.
Test Engineer

Grace Consulting, Inc.
P.O. Box 58
Wellington, Ohio 44090

Phone: 440-647-6672
Fax: 440-647-6673

| | |
|---|----|
| INTRODUCTION | 1 |
| SUMMARY OF TEST RESULTS | 2 |
| INTERMEDIATE CALCULATIONS | 3 |
| SAMPLING AND ANALYTICAL PROCEDURES | 4 |
| APPENDIX | |
| Sample Calculations | 5 |
| Test Data Sheets | 6 |
| GCI Calibration Data | 7 |
| Calibration Sheets/Gas Certification Sheets | 8 |
| Laboratory Reports | 9 |
| Plant Data Sheets | 10 |

INTRODUCTION

This report presents the results of the Relative Accuracy tests performed for St. Johns River Power Park, Units 1 & 2 Stack & Inlet in Jacksonville, FL.

The purpose of the tests was to determine the emissions of the units. The results can be found in the Summary of Test Results section of this report.

The testing was performed by Grace Consulting, Inc., located at 510 Dickson Street – Wellington, OH 44090. Present during the testing were Hal Stiles, Tim Moody, Josh Nichols, and Ernie Givens from Grace Consulting, Inc. Mark Loechelt was present from St. Johns River Power Park.

The tests were performed on December 12 & 13, 2001. The testing was completed in accordance with USEPA test methods as published in the July 1, 2001 Federal Register, - "Standards of Performance for New Stationary Sources" and subsequent revisions.

The sampling and analytical procedures can be found in the Sampling and Analytical Procedures section of this report. The raw field data and the equations used to determine the final results are presented in the Appendix section.

2

SUMMARY OF TEST RESULTS

The following presents the results of the Relative Accuracy tests performed for St. Johns River Power Park, Units 1 & 2 Stack and Inlet in Jacksonville, FL.

**PART 60 RELATIVE ACCURACY
Unit 1**

| Date | Monitor | Location | Units | RA | Allowable | Results | MW |
|----------|-----------------|----------|----------|-------|-----------|---------|-------|
| 12-13-01 | CO | Stack | ppm | 3.81% | 20% | Pass | 662.2 |
| 12-13-01 | CO | Stack | lb/mmBtu | 3.81% | 20% | Pass | 662.2 |
| 12-13-01 | CO ₂ | Stack | Percent | 2.21% | 20% | Pass | 662.2 |

Unit 2

| Date | Monitor | Location | Units | RA | Allowable | Results | MW |
|----------|-----------------|----------|----------|-------|-----------|---------|-------|
| 12-12-01 | CO | Stack | ppm | 3.37% | 20% | Pass | 650.9 |
| 12-12-01 | CO | Stack | lb/mmBtu | 5.02% | 20% | Pass | 650.9 |
| 12-12-01 | CO ₂ | Stack | Percent | 1.95% | 20% | Pass | 650.9 |

The complete results can be found on the computer printouts following.

Grace Consulting, Inc.

St. Johns River Power Park: Jacksonville, FL Unit 1

Relative Accuracy Test Audit

Relative Accuracy Calculations and Results

CO ppm

12/13/01

| Use | Run | CO ppm | | Difference |
|----------|-----|---------|---------|------------|
| | | RM | CEMS | |
| Y | 1 | 88.134 | 96.600 | -8.466 |
| Y | 2 | 135.911 | 141.700 | -5.789 |
| Y | 3 | 148.535 | 149.100 | -0.565 |
| Y | 4 | 160.258 | 162.600 | -2.342 |
| Y | 5 | 153.520 | 157.900 | -4.380 |
| Y | 6 | 107.125 | 116.200 | -9.075 |
| Y | 7 | 250.105 | 244.500 | 5.605 |
| N | 8 | 195.678 | 213.800 | -18.122 |
| Y | 9 | 196.260 | 194.200 | 2.060 |
| Y | 10 | 221.068 | 215.800 | 5.268 |
| N | 11 | 0.000 | 0.000 | 0.000 |
| N | 12 | 0.000 | 0.000 | 0.000 |
| Averages | | 162.324 | 164.289 | -1.965 |

Standard Deviation 5.491

Confidence Coefficient 4.221

Relative Accuracy 3.81

Grace Consulting, Inc.

St. Johns River Power Park: Jacksonville, FL Unit 1

Relative Accuracy Test Audit

Relative Accuracy Calculations and Results

CO lb/mmBtu

12/13/01

| Use | Run | CO lb/mmBtu | | |
|----------|-----|-------------|-------|------------|
| | | RM | CEMS | Difference |
| Y | 1 | 0.097 | 0.108 | -0.011 |
| Y | 2 | 0.153 | 0.157 | -0.004 |
| Y | 3 | 0.168 | 0.166 | 0.002 |
| Y | 4 | 0.181 | 0.180 | 0.001 |
| Y | 5 | 0.173 | 0.176 | -0.003 |
| Y | 6 | 0.121 | 0.129 | -0.008 |
| Y | 7 | 0.282 | 0.272 | 0.010 |
| N | 8 | 0.220 | 0.237 | -0.017 |
| Y | 9 | 0.223 | 0.216 | 0.007 |
| Y | 10 | 0.252 | 0.239 | 0.013 |
| N | 11 | 0.000 | 0.000 | 0.000 |
| N | 12 | 0.000 | 0.000 | 0.000 |
| Averages | | 0.183 | 0.183 | 0.001 |

Standard Deviation 0.008

Confidence Coefficient 0.006

Relative Accuracy 3.81

Grace Consulting, Inc.

St. Johns River Power Park: Jacksonville, FL Unit 1

Relative Accuracy Test Audit

Relative Accuracy Calculations and Results

- CO2 Percent

12/13/01

| Use | Run | CO2 Percent | | |
|----------|-----|-------------|--------|------------|
| | | RM | CEMS | Difference |
| N | 1 | 11.893 | 11.740 | 0.153 |
| Y | 2 | 11.644 | 11.790 | -0.146 |
| Y | 3 | 11.541 | 11.760 | -0.219 |
| Y | 4 | 11.575 | 11.760 | -0.185 |
| Y | 5 | 11.607 | 11.750 | -0.143 |
| Y | 6 | 11.599 | 11.830 | -0.231 |
| Y | 7 | 11.575 | 11.800 | -0.225 |
| Y | 8 | 11.608 | 11.800 | -0.192 |
| Y | 9 | 11.510 | 11.780 | -0.270 |
| Y | 10 | 11.478 | 11.790 | -0.312 |
| N | 11 | 0.000 | 0.000 | 0.000 |
| N | 12 | 0.000 | 0.000 | 0.000 |
| Averages | | 11.571 | 11.784 | -0.214 |

Standard Deviation 0.055

Confidence Coefficient 0.042

Relative Accuracy 2.21

Grace Consulting, Inc.

SJRPP: Jacksonville, FL Unit 2
 Relative Accuracy Test Audit
 Relative Accuracy Calculations and Results
 CO ppm
 12/12/01

| Use | Run | RM | CO ppm | |
|----------|-----|---------|---------|------------|
| | | | CEMS | Difference |
| Y | 1 | 400.442 | 393.100 | 7.342 |
| Y | 2 | 408.633 | 426.900 | -18.267 |
| Y | 3 | 412.402 | 426.400 | -13.998 |
| Y | 4 | 388.974 | 403.600 | -14.626 |
| Y | 5 | 435.131 | 446.700 | -11.569 |
| Y | 6 | 501.230 | 494.800 | 6.430 |
| Y | 7 | 368.115 | 379.300 | -11.185 |
| Y | 8 | 413.159 | 409.400 | 3.759 |
| N | 9 | 309.647 | 331.900 | -22.253 |
| Y | 10 | 393.740 | 399.200 | -5.460 |
| N | 11 | 0.000 | 0.000 | 0.000 |
| N | 12 | 0.000 | 0.000 | 0.000 |
| Averages | | 413.536 | 419.933 | -6.397 |

Standard Deviation 9.832
 Confidence Coefficient 7.558
 Relative Accuracy 3.37

Grace Consulting, Inc.

SJRPP: Jacksonville, FL Unit 2
 Relative Accuracy Test Audit
 Relative Accuracy Calculations and Results
 CO lb/mmBtu
 12/12/01

| Use | Run | CO lb/mmBtu | | |
|----------|-----|-------------|-------|------------|
| | | RM | CEMS | Difference |
| Y | 1 | 0.444 | 0.443 | 0.001 |
| Y | 2 | 0.452 | 0.477 | -0.025 |
| Y | 3 | 0.459 | 0.480 | -0.021 |
| Y | 4 | 0.431 | 0.452 | -0.021 |
| Y | 5 | 0.483 | 0.503 | -0.020 |
| Y | 6 | 0.554 | 0.570 | -0.016 |
| Y | 7 | 0.407 | 0.433 | -0.026 |
| Y | 8 | 0.456 | 0.460 | -0.004 |
| N | 9 | 0.344 | 0.374 | -0.030 |
| Y | 10 | 0.437 | 0.448 | -0.011 |
| N | 11 | 0.000 | 0.000 | 0.000 |
| N | 12 | 0.000 | 0.000 | 0.000 |
| Averages | | 0.458 | 0.474 | -0.016 |

Standard Deviation 0.009
 Confidence Coefficient 0.007
 Relative Accuracy 5.02

Grace Consulting, Inc.

SJRPP: Jacksonville, FL Unit 2
 Relative Accuracy Test Audit
 Relative Accuracy Calculations and Results
 CO2 Percent
 12/12/01

| Use | Run | CO2 Percent | | |
|----------|-----|-------------|--------|------------|
| | | RM | CEMS | Difference |
| Y | 1 | 11.781 | 11.610 | 0.171 |
| Y | 2 | 11.807 | 11.700 | 0.107 |
| Y | 3 | 11.729 | 11.640 | 0.089 |
| Y | 4 | 11.785 | 11.650 | 0.135 |
| Y | 5 | 11.782 | 11.620 | 0.162 |
| N | 6 | 11.827 | 11.340 | 0.487 |
| Y | 7 | 11.819 | 11.460 | 0.359 |
| Y | 8 | 11.834 | 11.610 | 0.224 |
| Y | 9 | 11.774 | 11.630 | 0.144 |
| Y | 10 | 11.772 | 11.680 | 0.092 |
| N | 11 | 0.000 | 0.000 | 0.000 |
| N | 12 | 0.000 | 0.000 | 0.000 |
| Averages | | 11.787 | 11.622 | 0.165 |

Standard Deviation 0.085
 Confidence Coefficient 0.065
 Relative Accuracy 1.95

Grace Consulting, Inc.

Sampling System Bias Check and Measured Value Correction

St. Johns River Power Park
Jacksonville, FL - Unit 1 Outlet

Date: 12/13/2001
Pollutant: CO
Monitor Span: 1000

| Run Number | Average Measured Value | Initial Zero Gas Bias | Final Zero Gas Bias | Zero Gas Drift | Initial Upscale Gas Bias | Final Upscale Gas Bias | Upscale Gas Drift | Calibration Gas | Percent Moisture | Corrected Value, Dry Basis | Corrected Value, Wet Basis |
|------------|------------------------|-----------------------|---------------------|----------------|--------------------------|------------------------|-------------------|-----------------|------------------|----------------------------|----------------------------|
| 1 | 101.20 | 0.20 | 0.30 | 0.01 | 308.00 | 307.00 | -0.10 | 304.00 | 11.76 | 99.88 | 88.13 |
| 2 | 155.40 | 0.30 | 0.50 | 0.02 | 307.00 | 306.00 | -0.10 | 304.00 | 11.71 | 153.94 | 135.91 |
| 3 | 168.80 | 0.50 | 0.40 | -0.01 | 306.00 | 304.00 | -0.20 | 304.00 | 11.61 | 168.05 | 148.54 |
| 4 | 183.00 | 0.40 | 0.50 | 0.01 | 304.00 | 308.00 | 0.40 | 304.00 | 11.76 | 181.62 | 160.26 |
| 5 | 175.90 | 0.50 | 0.80 | 0.03 | 308.00 | 306.50 | -0.15 | 304.00 | 11.65 | 173.76 | 153.52 |
| 6 | 122.30 | 0.80 | 0.60 | -0.02 | 306.50 | 305.00 | -0.15 | 304.00 | 11.60 | 121.18 | 107.13 |
| 7 | 284.90 | 0.60 | 0.60 | 0.00 | 305.00 | 307.50 | 0.25 | 304.00 | 11.55 | 282.77 | 250.10 |
| 8 | 224.20 | 0.60 | 0.00 | -0.06 | 307.50 | 309.00 | 0.15 | 304.00 | 11.47 | 221.03 | 195.68 |
| 9 | 223.20 | 0.00 | 0.00 | 0.00 | 309.00 | 302.00 | -0.70 | 304.00 | 11.64 | 222.10 | 196.26 |
| 10 | 250.30 | 0.00 | -0.20 | -0.02 | 302.00 | 306.00 | 0.40 | 304.00 | 11.68 | 250.32 | 221.07 |

$$C_{gas} = (C_{avg} - C_o) * C_{ma} / (C_m - C_o) \quad \text{Eq. 6C-1}$$

where:

C_{gas} = Effluent gas concentration, dry basis, ppm

C_{avg} = Average gas concentration indicated by gas analyzer, dry basis, ppm

C_o = Average of initial and final system calibration bias check responses for the zero gas, ppm

C_m = Average of initial and final system calibration bias check responses for the upscale calibration gas, ppm

C_{ma} = Actual concentration of the upscale calibration gas, ppm

Grace Consulting, Inc.

Sampling System Bias Check and Measured Value Correction

St. Johns River Power Park
Jacksonville, FL - Unit 1 Outlet

Date: 12/13/2001
Pollutant: CO2
Monitor Span: 20

| Run Number | Average Measured Percent | Initial Gas Bias | Zero Gas Bias | Final Zero Gas Bias | Zero Gas Drift | Initial Upscale Gas Bias | Final Upscale Gas Bias | Upscale Gas Drift | Calibration Gas | Percent Moisture | Corrected Percent, Dry Basis | Corrected Percent, Wet Basis |
|------------|--------------------------|------------------|---------------|---------------------|----------------|--------------------------|------------------------|-------------------|-----------------|------------------|------------------------------|------------------------------|
| 1 | 13.43 | 0.23 | | 0.45 | 1.10 | 11.04 | 11.20 | 0.80 | 11.10 | 11.76 | 13.48 | 11.89 |
| 2 | 13.27 | 0.45 | | 0.51 | 0.30 | 11.20 | 11.29 | 0.45 | 11.10 | 11.71 | 13.19 | 11.64 |
| 3 | 13.19 | 0.51 | | 0.52 | 0.05 | 11.29 | 11.29 | 0.00 | 11.10 | 11.61 | 13.06 | 11.54 |
| 4 | 13.20 | 0.52 | | 0.59 | 0.35 | 11.29 | 11.22 | -0.35 | 11.10 | 11.76 | 13.12 | 11.57 |
| 5 | 13.17 | 0.59 | | 0.54 | -0.25 | 11.22 | 11.21 | -0.05 | 11.10 | 11.65 | 13.14 | 11.61 |
| 6 | 13.17 | 0.54 | | 0.48 | -0.30 | 11.21 | 11.23 | 0.10 | 11.10 | 11.60 | 13.12 | 11.60 |
| 7 | 13.16 | 0.48 | | 0.54 | 0.30 | 11.23 | 11.25 | 0.10 | 11.10 | 11.55 | 13.09 | 11.57 |
| 8 | 13.17 | 0.54 | | 0.51 | -0.15 | 11.25 | 11.21 | -0.20 | 11.10 | 11.47 | 13.11 | 11.61 |
| 9 | 13.08 | 0.51 | | 0.49 | -0.10 | 11.21 | 11.23 | 0.10 | 11.10 | 11.64 | 13.03 | 11.51 |
| 10 | 13.11 | 0.49 | | 0.45 | -0.20 | 11.23 | 11.30 | 0.35 | 11.10 | 11.68 | 13.00 | 11.48 |

$$C_{gas} = (C_{avg} - C_o) * C_{ma} / (C_m - C_o) \quad \text{Eq. 6C-1}$$

where:

- C_{gas} = Effluent gas concentration, dry basis, percent
- C_{avg} = Average gas concentration indicated by gas analyzer, dry basis, percent
- C_o = Average of initial and final system calibration bias check responses for the zero gas, percent
- C_m = Average of initial and final system calibration bias check responses for the upscale calibration gas, percent
- C_{ma} = Actual concentration of the upscale calibration gas, percent

Grace Consulting, Inc.
Moisture Calculations (Runs 1 - 6)

Client: St. Johns River Power Park
 Site: Jacksonville, FL - Unit 1 Outlet
 Date: 12/13/01
 Unit Number: 1 Outlet

| Run: | 1 | 2 | 3 |
|--------------------------|--------|--------|--------|
| Volume of Condensate: | 48.60 | 48.10 | 47.70 |
| Weight of Silica Gel: | 14.10 | 14.30 | 14.10 |
| Volume Metered: | 22.483 | 22.489 | 22.488 |
| Meter Temperature: | 94.00 | 94.00 | 94.00 |
| Delta H: | 1.80 | 1.80 | 1.80 |
| Barometric Pressure: | 30.29 | 30.29 | 30.29 |
| Meter Correction Factor: | 1.017 | 1.017 | 1.017 |
| Volume Measured (DSCF): | 22.15 | 22.15 | 22.15 |
| Water Volume (SCF): | 2.95 | 2.94 | 2.91 |
| % Moisture in Flue Gas: | 11.76 | 11.71 | 11.61 |

| Run: | 4 | 5 | 6 |
|--------------------------|--------|--------|--------|
| Volume of Condensate: | 48.90 | 47.60 | 47.50 |
| Weight of Silica Gel: | 13.80 | 14.30 | 14.10 |
| Volume Metered: | 22.479 | 22.478 | 22.480 |
| Meter Temperature: | 94.00 | 95.00 | 95.00 |
| Delta H: | 1.80 | 1.80 | 1.80 |
| Barometric Pressure: | 30.29 | 30.29 | 30.29 |
| Meter Correction Factor: | 1.017 | 1.017 | 1.017 |
| Volume Measured (DSCF): | 22.15 | 22.10 | 22.11 |
| Water Volume (SCF): | 2.95 | 2.91 | 2.90 |
| % Moisture in Flue Gas: | 11.76 | 11.65 | 11.60 |

Grace Consulting, Inc.
Moisture Calculations (Runs 7 - 10)

Client: St. Johns River Power Park
Site: Jacksonville, FL - Unit 1 Outlet
Date: 12/13/01
Unit Number: 1 Outlet

| Run: | 7 | 8 | 9 |
|--------------------------|--------|--------|--------|
| Volume of Condensate: | 47.10 | 46.90 | 47.60 |
| Weight of Silica Gel: | 14.20 | 13.80 | 14.10 |
| Volume Metered: | 22.478 | 22.476 | 22.477 |
| Meter Temperature: | 95.00 | 96.00 | 96.00 |
| Delta H: | 1.80 | 1.80 | 1.80 |
| Barometric Pressure: | 30.29 | 30.29 | 30.29 |
| Meter Correction Factor: | 1.017 | 1.017 | 1.017 |
| Volume Measured (DSCF): | 22.10 | 22.06 | 22.06 |
| Water Volume (SCF): | 2.89 | 2.86 | 2.91 |
| % Moisture in Flue Gas: | 11.55 | 11.47 | 11.64 |

| Run: | 10 |
|--------------------------|--------|
| Volume of Condensate: | 48.30 |
| Weight of Silica Gel: | 13.70 |
| Volume Metered: | 22.479 |
| Meter Temperature: | 96.00 |
| Delta H: | 1.80 |
| Barometric Pressure: | 30.29 |
| Meter Correction Factor: | 1.017 |
| Volume Measured (DSCF): | 22.07 |
| Water Volume (SCF): | 2.92 |
| % Moisture in Flue Gas: | 11.68 |

Grace Consulting, Inc.

Sampling System Bias Check and Measured Value Correction

St. Johns River Power Park
Jacksonville, FL - Unit 2

Date: 12/12/01
Pollutant: CO
Monitor Span: 1000

| Run Number | Average Measured Value | Initial Zero Gas Bias | Final Zero Gas Bias | Zero Gas Drift | Initial Upscale Gas Bias | Final Upscale Gas Bias | Upscale Gas Drift | Calibration Gas | Percent Moisture | Corrected Value, Dry Basis | Corrected Value, Wet Basis |
|------------|------------------------|-----------------------|---------------------|----------------|--------------------------|------------------------|-------------------|-----------------|------------------|----------------------------|----------------------------|
| 1 | 454.50 | 0.70 | 1.20 | 0.05 | 308.00 | 302.00 | -0.60 | 304.00 | 11.69 | 453.48 | 400.44 |
| 2 | 461.80 | 1.20 | 0.70 | -0.05 | 302.00 | 307.00 | 0.50 | 304.00 | 11.46 | 461.53 | 408.63 |
| 3 | 468.80 | 0.70 | 1.00 | 0.03 | 307.00 | 305.00 | -0.20 | 304.00 | 11.54 | 466.19 | 412.40 |
| 4 | 442.30 | 1.00 | 2.60 | 0.16 | 305.00 | 308.00 | 0.30 | 304.00 | 11.49 | 439.49 | 388.97 |
| 5 | 492.90 | 2.60 | 0.60 | -0.20 | 308.00 | 303.00 | -0.50 | 304.00 | 11.46 | 491.46 | 435.13 |
| 6 | 564.50 | 0.60 | 1.30 | 0.07 | 303.00 | 304.90 | 0.19 | 304.00 | 11.35 | 565.41 | 501.23 |
| 7 | 415.70 | 1.30 | 2.30 | 0.10 | 304.90 | 304.80 | -0.01 | 304.00 | 11.34 | 415.20 | 368.12 |
| 8 | 470.50 | 2.30 | 0.30 | -0.20 | 304.80 | 308.00 | 0.32 | 304.00 | 11.63 | 467.51 | 413.16 |
| 9 | 352.00 | 0.30 | 0.00 | -0.03 | 308.00 | 303.00 | -0.50 | 304.00 | 11.60 | 350.29 | 309.65 |
| 10 | 444.65 | 0.00 | 0.00 | 0.00 | 303.00 | 304.00 | 0.10 | 304.00 | 11.60 | 445.38 | 393.74 |

$$C_{gas} = (C_{avg} - C_o) * C_{ma} / (C_m - C_o) \quad \text{Eq. 6C-1}$$

where: C_{gas} = Effluent gas concentration, dry basis, ppm

for the zero gas, ppm

for the upscale calibration gas, ppm

C_{ma} = Actual concentration of the upscale calibration gas, ppm

Grace Consulting, Inc.

Sampling System Bias Check and Measured Value Correction

St. Johns River Power Park
Jacksonville, FL - Unit 2

Date: 12/12/01
Pollutant: CO2
Monitor Span: 20

| Run Number | Average Measured Percent | Initial Gas Bias | Zero Gas Bias | Final Zero Gas Bias | Zero Gas Drift | Initial Upscale Gas Bias | Final Upscale Gas Bias | Upscale Gas Drift | Calibration Gas | Percent Moisture | Corrected Percent, Dry Basis | Corrected Percent, Wet Basis |
|------------|--------------------------|------------------|---------------|---------------------|----------------|--------------------------|------------------------|-------------------|-----------------|------------------|------------------------------|------------------------------|
| 1 | 13.53 | 0.35 | 0.40 | 0.40 | 0.25 | 11.24 | 11.40 | 0.80 | 11.10 | 11.69 | 13.34 | 11.78 |
| 2 | 13.62 | 0.40 | 0.35 | 0.35 | -0.25 | 11.40 | 11.40 | 0.00 | 11.10 | 11.46 | 13.34 | 11.81 |
| 3 | 13.54 | 0.35 | 0.44 | 0.44 | 0.45 | 11.40 | 11.40 | 0.00 | 11.10 | 11.54 | 13.26 | 11.73 |
| 4 | 13.59 | 0.44 | 0.42 | 0.42 | -0.10 | 11.40 | 11.40 | 0.00 | 11.10 | 11.49 | 13.32 | 11.79 |
| 5 | 13.60 | 0.42 | 0.37 | 0.37 | -0.25 | 11.40 | 11.42 | 0.10 | 11.10 | 11.46 | 13.31 | 11.78 |
| 6 | 13.62 | 0.37 | 0.38 | 0.38 | 0.05 | 11.42 | 11.37 | -0.25 | 11.10 | 11.35 | 13.34 | 11.83 |
| 7 | 13.57 | 0.38 | 0.47 | 0.47 | 0.45 | 11.37 | 11.37 | 0.00 | 11.10 | 11.34 | 13.33 | 11.82 |
| 8 | 13.61 | 0.47 | 0.44 | 0.44 | -0.15 | 11.37 | 11.35 | -0.10 | 11.10 | 11.63 | 13.39 | 11.83 |
| 9 | 13.55 | 0.44 | 0.44 | 0.44 | 0.00 | 11.35 | 11.38 | 0.15 | 11.10 | 11.60 | 13.32 | 11.77 |
| 10 | 13.56 | 0.44 | 0.36 | 0.36 | -0.40 | 11.38 | 11.36 | -0.10 | 11.10 | 11.60 | 13.32 | 11.77 |

$$C_{gas} = (C_{avg} - C_o) * C_{ma} / (C_m - C_o) \quad \text{Eq. 6C-1}$$

where: C_{gas} = Effluent gas concentration, dry basis, percent
 C_{avg} = Average gas concentration indicated by gas analyzer, dry basis, percent

for the zero gas, percent

for the upscale calibration gas, percent

C_{ma} = Actual concentration of the upscale calibration gas, percent

Grace Consulting, Inc.
Moisture Calculations (Runs 1 - 6)

Client: St. Johns River Power Park
 Site: Jacksonville, FL - Unit 2
 Date: 12/12/01
 Unit Number: 2
 Load: High

| Run: | 1 | 2 | 3 |
|--------------------------|--------|--------|--------|
| Volume of Condensate: | 47.80 | 47.10 | 46.30 |
| Weight of Silica Gel: | 14.90 | 13.80 | 14.20 |
| Volume Metered: | 22.483 | 22.482 | 22.210 |
| Meter Temperature: | 91.50 | 95.00 | 96.00 |
| Delta H: | 1.80 | 1.80 | 1.80 |
| Barometric Pressure: | 30.35 | 30.35 | 30.35 |
| Meter Correction Factor: | 1.017 | 1.017 | 1.017 |
| Volume Measured (DSCF): | 22.29 | 22.15 | 21.84 |
| Water Volume (SCF): | 2.95 | 2.87 | 2.85 |
| % Moisture in Flue Gas: | 11.69 | 11.46 | 11.54 |

| Run: | 4 | 5 | 6 |
|--------------------------|--------|--------|--------|
| Volume of Condensate: | 47.20 | 47.30 | 46.80 |
| Weight of Silica Gel: | 13.90 | 13.50 | 14.10 |
| Volume Metered: | 22.485 | 22.485 | 22.484 |
| Meter Temperature: | 95.00 | 96.00 | 89.00 |
| Delta H: | 1.80 | 1.80 | 1.80 |
| Barometric Pressure: | 30.35 | 30.35 | 30.35 |
| Meter Correction Factor: | 1.017 | 1.017 | 1.017 |
| Volume Measured (DSCF): | 22.15 | 22.11 | 22.40 |
| Water Volume (SCF): | 2.88 | 2.86 | 2.87 |
| % Moisture in Flue Gas: | 11.49 | 11.46 | 11.35 |

Grace Consulting, Inc.
Moisture Calculations (Runs 7 - 12)

Client: St. Johns River Power Park
 Site: Jacksonville, FL - Unit 2
 Date: 12/12/01
 Unit Number: 2
 Load: High

| Run: | 7 | 8 | 9 |
|--------------------------|--------|--------|--------|
| Volume of Condensate: | 46.30 | 47.30 | 48.20 |
| Weight of Silica Gel: | 14.20 | 14.60 | 13.40 |
| Volume Metered: | 22.484 | 22.448 | 22.466 |
| Meter Temperature: | 92.00 | 94.00 | 96.00 |
| Delta H: | 1.80 | 1.80 | 1.80 |
| Barometric Pressure: | 30.35 | 30.35 | 30.35 |
| Meter Correction Factor: | 1.017 | 1.017 | 1.017 |
| Volume Measured (DSCF): | 22.27 | 22.16 | 22.10 |
| Water Volume (SCF): | 2.85 | 2.91 | 2.90 |
| % Moisture in Flue Gas: | 11.34 | 11.63 | 11.60 |

| Run: | 10 |
|--------------------------|--------|
| Volume of Condensate: | 47.20 |
| Weight of Silica Gel: | 14.30 |
| Volume Metered: | 22.449 |
| Meter Temperature: | 96.00 |
| Delta H: | 1.80 |
| Barometric Pressure: | 30.35 |
| Meter Correction Factor: | 1.017 |
| Volume Measured (DSCF): | 22.08 |
| Water Volume (SCF): | 2.90 |
| % Moisture in Flue Gas: | 11.60 |

Test Methods used at St. Johns River Power Park, Units 1 & 2**Method 3A**

CO₂ and O₂ concentrations were determined with 10 Method 3A test runs on Units 1 & 2. The sampling was performed at 3-points. GCI used a monitor range of 0-20% for CO₂ and a range of 0-25% for O₂.

Method 10

CO emissions were determined with 10 test runs on Units 1 & 2. The sampling was performed at 3-points. GCI used a monitor span of 1000 ppm for CO testing on both Unit 1 and Unit 2.

APPENDIX

CO CALCULATION
(CO₂ Based)

$$\text{lb/dscf} = .726 \times 10^{-7} \times \text{PPM}$$

$$\text{lb/mmBtu} = \text{lb/dscf} \times \text{f-factor} \times \frac{100}{\%CO_2}$$

$$\text{lb/hour} = \text{lb/dscf} \times \text{dscfm} \times 60 \text{ min./hr}$$

The following is used to convert ppm dry to ppm wet.

$$\text{ppm dry} \times \left(1 - \frac{\% \text{ moisture}}{100}\right) = \text{ppm wet}$$

Calculate the arithmetic mean of the differences, d , of a data set as follows:

$$\bar{d} = \frac{1}{n} \sum_{i=1}^n d_i$$

Where:

n = Number of data points

$\sum_{i=1}^n d_i$ = Algebraic sum of the individual differences d_i

d_i = The difference between a reference method value and the corresponding continuous emissions monitoring system value ($RM_i - CEM_i$) at a given point in time i .

When calculating the arithmetic mean of the difference of a flow monitor data set, be sure to correct the monitor measurements for moisture if applicable.

Calculate the confidence coefficient (one-tailed), CC, of a data set as follows:

$$CC = t_{0.025} \frac{S_d}{\sqrt{n}}$$

Where:

$t_{0.025}$ = t value (see Table 7-1).

TABLE 7-1 T-VALUES

| n-1 | $t_{0.025}$ | n-1 | $t_{0.025}$ | n-1 | $t_{0.025}$ |
|-----|-------------|-----|-------------|-----|-------------|
| 1 | 12.076 | 12 | 2.179 | 23 | 2.069 |
| 2 | 4.303 | 13 | 2.160 | 24 | 2.064 |
| 3 | 3.182 | 14 | 2.145 | 25 | 2.060 |
| 4 | 2.775 | 15 | 2.131 | 26 | 2.056 |
| 5 | 2.571 | 16 | 2.120 | 27 | 2.052 |
| 6 | 2.447 | 17 | 2.110 | 28 | 2.048 |
| 7 | 2.365 | 18 | 2.101 | 29 | 2.045 |
| 8 | 2.306 | 19 | 2.093 | 30 | 2.042 |
| 9 | 2.262 | 20 | 2.086 | 40 | 2.021 |
| 10 | 2.228 | 21 | 2.080 | 60 | 2.000 |
| 11 | 2.201 | 22 | 2.074 | >60 | 1.960 |

Calculate the standard deviation, S_d , of a data set as follows:

$$S_d = \sqrt{\frac{\sum_{i=1}^n d_i^2 - \frac{\left(\sum_{i=1}^n d_i\right)^2}{n}}{n-1}}$$

The following equation is used to calculate the relative accuracy of a data set:

$$RA = \frac{|\bar{d}| + |cc|}{RM} \times 100$$

Where:

RM = Arithmetic mean of the reference method values.

$|\bar{d}|$ = The absolute value of the mean difference between the reference method values and the corresponding continuous emissions monitoring system values.

$|cc|$ = The absolute value of the confidence coefficient.

SAMPLING SYSTEM BIAS CORRECTION

EMISSION CALCULATION (CFR 40, Part 60, Appendix A)

Eq. 6C-1

$$C_{gas} = (\bar{C} - C_o) \frac{C_{ma}}{C_m - C_o}$$

Where:

- C_{gas} = Effluent gas concentration, dry basis, ppm.
- \bar{C} = Average gas concentration indicated by gas analyzer, dry basis, ppm.
- C_o = Average of initial and final system calibration bias check responses for the zero gas, ppm.
- C_m = Average of initial and final system calibration bias check responses for the upscale calibration gas, ppm.
- C_{ma} = Actual concentration of the upscale calibration gas, ppm.

MOISTURE FIELD DATA SHEETS

6

| | |
|---------------------------|---------------------------|
| CLIENT: SJAPP | DATE: 12-13-01 |
| PROJECT NO.: C-315 | OPERATOR: Nichols |
| SAMPLING LOCATION: Unit 1 | METER-ORFCE 3:2978 |
| BAROMETRIC PRESSURE 30.29 | METER CORR. FACTOR: 1.017 |
| SAMPLE PT. TIME 5min | UNIT LOAD: high PROBE NO: |

LEAK CHECK: BEFORE .00@15in AFTER .00@5in

| RUN NO. | SAMPLE POINT | DELTA H | PROBE TEMP. | IMP. OUT | METER IN | METER OUT | VAC. PR. (In. Hg) | DRY GAS VOLUME (Cu. Ft.) | |
|------------|--------------|---------|-------------|----------|----------|-----------|-------------------|--------------------------|---------------|
| | | | | | | | | INITIAL READING | FINAL READING |
| | | | | | | | | | 253.520 |
| START TIME | 10:56 | 1 | 1.798 | 250 | 55 | 89 | 3 | | 257.266 |
| STOP TIME | 11:26 | 2 | | | 56 | 93 | | | 261.013 |
| SILICA GEL | 14.1 | 3 | | | 57 | 98 | | | 264.761 |
| CONDENSATE | 48.6 | 4 | | | 58 | 100 | | | 268.509 |
| | | 5 | | | 59 | 102 | | | 272.275 |
| | | 6 | ↓ | ↓ | 60 | 103 | | ↓ | 276.003 |
| AVG. | | | | | | 94 | | | 22.483 |

LEAK CHECK: BEFORE .00@15in AFTER .00@5in

| RUN NO. | SAMPLE POINT | DELTA H | PROBE TEMP. | IMP. OUT | METER IN | METER OUT | VAC. PR. (In. Hg) | DRY GAS VOLUME (Cu. Ft.) | |
|------------|--------------|---------|-------------|----------|----------|-----------|-------------------|--------------------------|---------------|
| | | | | | | | | INITIAL READING | FINAL READING |
| | | | | | | | | | 276.200 |
| START TIME | 11:35 | 1 | 1.798 | 250 | 55 | 91 | 3 | | 279.745 |
| STOP TIME | 12:05 | 2 | | | 56 | 93 | | | 283.697 |
| SILICA GEL | 14.3 | 3 | | | 58 | 97 | | | 287.444 |
| CONDENSATE | 48.1 | 4 | | | 59 | 101 | | | 291.193 |
| | | 5 | | | 60 | 103 | | | 294.941 |
| | | 6 | | | 61 | 103 | | ↓ | 298.689 |
| AVG. | | | | | | 94 | | | 22.489 |

LEAK CHECK: BEFORE .00@15in AFTER .00@5in

| RUN NO. | SAMPLE POINT | DELTA H | PROBE TEMP. | IMP. OUT | METER IN | METER OUT | VAC. PR. (In. Hg) | DRY GAS VOLUME (Cu. Ft.) | |
|------------|--------------|---------|-------------|----------|----------|-----------|-------------------|--------------------------|------------------------|
| | | | | | | | | INITIAL READING | FINAL READING |
| | | | | | | | | | 298.800 |
| START TIME | 12:11 | 1 | 1.798 | 250 | 54 | 90 | 3 | | 297 302.54 |
| STOP TIME | 12:41 | 2 | | | 55 | 93 | | | 306.2 306.2 |
| SILICA GEL | 14.1 | 3 | | | 56 | 96 | | | 310.045 |
| CONDENSATE | 47.7 | 4 | | | 57 | 100 | | | 313.793 |
| | | 5 | | | 58 | 103 | | | 317.541 |
| | | 6 | ↓ | ↓ | 59 | 103 | | ↓ | 321.288 |
| AVG. | | | | | | 94 | | | 20.488 |

MOISTURE FIELD DATA SHEETS

| | |
|----------------------------|---------------------------|
| CLIENT: SJRPP | DATE: 12-13-01 |
| PROJECT NO.: 01-315 | OPERATOR: Nichols |
| SAMPLING LOCATION: Unit 1 | METER-ORFCE: 3.2978 |
| BAROMETRIC PRESSURE: 30.29 | METER CORR. FACTOR: 1.017 |
| SAMPLE PT. TIME: 5min | UNIT LOAD: high PROBE NO: |

LEAK CHECK: BEFORE .001@ 15 AFTER .001@ 4in

| RUN NO. | SAMPLE POINT | DELTA H | PROBE TEMP. | IMP. OUT | TEMPERATURE DEGREE FAHRENHEIT | | VAC. PR. (In. Hg) | DRY GAS VOLUME (Cu. Ft.) | |
|------------|--------------|---------|-------------|----------|-------------------------------|-----------|-------------------|--------------------------|---------|
| | | | | | METER IN | METER OUT | | INITIAL READING | |
| | 4 | | | | | | | 321.400 | |
| START TIME | 12:49 | 1 | 1.798 | 250 | 54 | 91 | 90 | 3 | 325.148 |
| STOP TIME | 1:19 | 2 | | | 55 | 94 | 90 | | 328.894 |
| SILICA GEL | 13.8 | 3 | | | 56 | 98 | 90 | | 332.640 |
| CONDENSATE | 48.9 | 4 | | | 57 | 101 | 91 | | 336.385 |
| | | 5 | | | 59 | 102 | 91 | | 340.132 |
| | | 6 | | | 60 | 104 | 91 | | 343.879 |
| AVG. | | | | | | | 94 | | 22.479 |

LEAK CHECK: BEFORE AFTER

| RUN NO. | SAMPLE POINT | DELTA H | PROBE TEMP. | IMP. OUT | TEMPERATURE DEGREE FAHRENHEIT | | VAC. PR. (In. Hg) | DRY GAS VOLUME (Cu. Ft.) | |
|------------|--------------|---------|-------------|----------|-------------------------------|-----------|-------------------|--------------------------|---------|
| | | | | | METER IN | METER OUT | | INITIAL READING | |
| | 5 | | | | | | | 344.000 | |
| START TIME | 13:26 | 1 | 1.798 | 250 | 55 | 91 | 90 | 3 | 347.746 |
| STOP TIME | 13:56 | 2 | | | 56 | 94 | 90 | | 351.493 |
| SILICA GEL | 42.3 | 3 | | | 57 | 98 | 90 | | 355.239 |
| CONDENSATE | 47.6 | 4 | | | 58 | 101 | 91 | | 358.985 |
| | | 5 | | | 59 | 103 | 92 | | 362.732 |
| | | 6 | | | 61 | 104 | 92 | | 366.478 |
| AVG. | | | | | | | 95 | | 22.478 |

LEAK CHECK: BEFORE AFTER

| RUN NO. | SAMPLE POINT | DELTA H | PROBE TEMP. | IMP. OUT | TEMPERATURE DEGREE FAHRENHEIT | | VAC. PR. (In. Hg) | DRY GAS VOLUME (Cu. Ft.) | |
|------------|--------------|---------|-------------|----------|-------------------------------|-----------|-------------------|--------------------------|---------|
| | | | | | METER IN | METER OUT | | INITIAL READING | |
| | 6 | | | | | | | 366.600 | |
| START TIME | 14:13 | 1 | 1.798 | 250 | 55 | 91 | 90 | 3 | 370.347 |
| STOP TIME | 14:43 | 2 | | | 56 | 95 | 90 | | 374.095 |
| SILICA GEL | 14.1 | 3 | | | 57 | 99 | 91 | | 377.841 |
| CONDENSATE | 47.5 | 4 | | | 58 | 101 | 91 | | 381.587 |
| | | 5 | | | 59 | 103 | 91 | | 385.334 |
| | | 6 | | | 60 | 105 | 91 | | 389.080 |
| AVG. | | | | | | | 95 | | 22.480 |

MOISTURE FIELD DATA SHEETS

| | |
|----------------------------|---------------------------|
| CLIENT: STAPP | DATE: 12-13-01 |
| PROJECT NO.: 01-315 | OPERATOR: Nicklas |
| SAMPLING LOCATION: Onitl | METER ORifice: 3.2978 |
| BAROMETRIC PRESSURE: 30.29 | METER CORR. FACTOR: 1.017 |
| SAMPLE PT. TIME: 5min | UNIT LOAD: high PROBE NO: |

LEAK CHECK: BEFORE .001@15in AFTER .001@5in

| RUN NO. | SAMPLE POINT | DELTA H | PROBE TEMP. | IMP. OUT | METER IN | METER OUT | VAC. PR. (In. Hg) | DRY GAS VOLUME |
|------------|--------------|---------|-------------|----------|----------|-----------|-------------------|----------------|
| | | | | | | | | (CU. FT.) |
| 7 | 1 | 1.798 | 250 | 55 | 91 | 90 | 3 | 389.200 |
| START TIME | 14:54 | | | | | | | 392.946 |
| STOP TIME | 15:24 | 2 | | 56 | 95 | 91 | | 396.692 |
| SILICA GEL | 14.2 | 3 | | 57 | 98 | 91 | | 400.438 |
| CONDENSATE | 47.1 | 4 | | 58 | 102 | 91 | | 404.184 |
| | | 5 | | 59 | 104 | 91 | | 407.931 |
| | | 6 | | 61 | 105 | 92 | | 411.678 |
| AVG. | | | | | | 95 | | 22.478 |

LEAK CHECK: BEFORE .001@15in AFTER .001@5in

| RUN NO. | SAMPLE POINT | DELTA H | PROBE TEMP. | IMP. OUT | METER IN | METER OUT | VAC. PR. (In. Hg) | DRY GAS VOLUME |
|------------|--------------|---------|-------------|----------|----------|-----------|-------------------|----------------|
| | | | | | | | | (CU. FT.) |
| 8 | 1 | 1.788 | 250 | 55 | 93 | 92 | 3 | 411.800 |
| START TIME | 15:33 | | | | | | | 415.546 |
| STOP TIME | 16:03 | 2 | | 57 | 97 | 92 | | 419.292 |
| SILICA GEL | 13.8 | 3 | | 58 | 100 | 92 | | 423.039 |
| CONDENSATE | 46.9 | 4 | | 60 | 101 | 93 | | 426.784 |
| | | 5 | | 61 | 104 | 93 | | 430.530 |
| | | 6 | | 62 | 105 | 93 | | 434.276 |
| AVG. | | | | | | 96 | | 22.476 |

LEAK CHECK: BEFORE .001@15in AFTER .001@5in

| RUN NO. | SAMPLE POINT | DELTA H | PROBE TEMP. | IMP. OUT | METER IN | METER OUT | VAC. PR. (In. Hg) | DRY GAS VOLUME |
|------------|--------------|---------|-------------|----------|----------|-----------|-------------------|----------------|
| | | | | | | | | (CU. FT.) |
| 9 | 1 | 1.798 | 250 | 55 | 93 | 92 | 3 | 434.400 |
| START TIME | 16:18 | | | | | | | 438.147 |
| STOP TIME | 16:48 | 2 | | 56 | 98 | 92 | | 441.893 |
| SILICA GEL | 14.1 | 3 | | 57 | 100 | 92 | | 445.638 |
| CONDENSATE | 47.6 | 4 | | 58 | 101 | 93 | | 449.383 |
| | | 5 | | 59 | 104 | 93 | | 453.128 |
| | | 6 | | 60 | 106 | 94 | | 456.877 |
| AVG. | | | | | | 96 | | 22.477 |

MOISTURE FIELD DATA SHEETS

| | |
|----------------------------|---------------------------|
| CLIENT: SJRPP | DATE: 12-13-01 |
| PROJECT NO.: 01-315 | OPERATOR: Nichols |
| SAMPLING LOCATION: Unit 1 | METER-ORICE: 3.2978 |
| BAROMETRIC PRESSURE: 30.29 | METER CORR. FACTOR: 1.017 |
| SAMPLE PT. TIME: 5min | UNIT LOAD: High PROBE NO: |

LEAK CHECK: BEFORE .001@15in AFTER .001@5in

| RUN NO. | SAMPLE POINT | DELTA H | PROBE TEMP. | IMP. OUT | TEMPERATURE DEGREE FAHRENHEIT | | METER OUT | VAC. PR. (In. Hg) | DRY GAS VOLUME (Cu. Ft.) | |
|------------|--------------|---------|-------------|----------|-------------------------------|-----------|-----------|-------------------|--------------------------|---------------|
| | | | | | METER IN | METER OUT | | | INITIAL READING | FINAL READING |
| 10 | 1 | 1.798 | 250 | 55 | 93 | 92 | 3 | | 457.000 | 460.746 |
| START TIME | 16:56 | | | | | | | | | 460.746 |
| STOP TIME | 17:26 | 2 | | 56 | 97 | 92 | | | | 464.494 |
| SILICA GEL | 13.7 | 3 | | 57 | 101 | 93 | | | | 468.241 |
| CONDENSATE | 48.3 | 4 | | 58 | 103 | 93 | | | | 471.989 |
| | | 5 | | 59 | 104 | 94 | | | | 475.733 |
| | | 6 | | 61 | 106 | 94 | | | | 479.479 |
| AVG. | | | | | | 96 | | | | 22.479 |

LEAK CHECK: BEFORE AFTER

| RUN NO. | SAMPLE POINT | DELTA H | PROBE TEMP. | IMP. OUT | TEMPERATURE DEGREE FAHRENHEIT | | METER OUT | VAC. PR. (In. Hg) | DRY GAS VOLUME (Cu. Ft.) | |
|------------|--------------|---------|-------------|----------|-------------------------------|-----------|-----------|-------------------|--------------------------|---------------|
| | | | | | METER IN | METER OUT | | | INITIAL READING | FINAL READING |
| START TIME | | | | | | | | | | |
| STOP TIME | | | | | | | | | | |
| SILICA GEL | | | | | | | | | | |
| CONDENSATE | | | | | | | | | | |
| AVG. | | | | | | | | | | |

LEAK CHECK: BEFORE AFTER

| RUN NO. | SAMPLE POINT | DELTA H | PROBE TEMP. | IMP. OUT | TEMPERATURE DEGREE FAHRENHEIT | | METER OUT | VAC. PR. (In. Hg) | DRY GAS VOLUME (Cu. Ft.) | |
|------------|--------------|---------|-------------|----------|-------------------------------|-----------|-----------|-------------------|--------------------------|---------------|
| | | | | | METER IN | METER OUT | | | INITIAL READING | FINAL READING |
| START TIME | | | | | | | | | | |
| STOP TIME | | | | | | | | | | |
| SILICA GEL | | | | | | | | | | |
| CONDENSATE | | | | | | | | | | |
| AVG. | | | | | | | | | | |

Test Run 1 Begin. STRATA Version 2.0

Operator: hal stiles

Plant Name: St.Johns River Power Park

Location: Unit 1 high load

| | | CO2 | CO |
|-----------------|-------------|-------|--------|
| | | % | ppm |
| Start Averaging | | | |
| 12/13/01 | 10:57:11 | 13.59 | 95.10 |
| 12/13/01 | 10:58:10 | 13.37 | 104.60 |
| 12/13/01 | 10:59:10 | 13.39 | 121.10 |
| 12/13/01 | 11:00:11 | 13.44 | 125.70 |
| 12/13/01 | 11:01:11 | 13.37 | 115.00 |
| 12/13/01 | 11:02:10 | 13.38 | 64.70 |
| 12/13/01 | 11:03:10 | 13.43 | 90.70 |
| 12/13/01 | 11:04:11 | 13.45 | 75.30 |
| 12/13/01 | 11:05:11 | 13.47 | 81.40 |
| 12/13/01 | 11:06:10 | 13.55 | 151.30 |
| 12/13/01 | 11:07:10 | 13.47 | 127.10 |
| 12/13/01 | 11:08:11 | 13.30 | 46.80 |
| 12/13/01 | 11:09:11 | 13.46 | 54.40 |
| 12/13/01 | 11:10:10 | 13.48 | 218.60 |
| 12/13/01 | 11:11:09 | 13.33 | 103.40 |
| 12/13/01 | 11:12:11 | 13.39 | 89.80 |
| 12/13/01 | 11:13:11 | 13.56 | 92.00 |
| 12/13/01 | 11:14:10 | 13.35 | 112.50 |
| 12/13/01 | 11:15:09 | 13.37 | 104.80 |
| 12/13/01 | 11:16:11 | 13.42 | 85.30 |
| 12/13/01 | 11:17:10 | 13.44 | 67.00 |
| Test Run 1 End | | | |
| Average | 572 samples | 13.43 | 101.20 |

Test Run 2 Begin. STRATA Version 2.0

Operator: hal stiles

Plant Name: St.Johns River Power Park

Location: Unit 1 high load

| | | CO2 | CO |
|-----------------|-------------|-------|--------|
| | | % | ppm |
| Start Averaging | | | |
| 12/13/01 | 11:36:05 | 13.13 | 123.20 |
| 12/13/01 | 11:37:07 | 13.14 | 139.20 |
| 12/13/01 | 11:38:06 | 13.22 | 108.60 |
| 12/13/01 | 11:39:06 | 13.24 | 271.30 |
| 12/13/01 | 11:40:05 | 13.08 | 141.30 |
| 12/13/01 | 11:41:07 | 13.20 | 216.40 |
| 12/13/01 | 11:42:06 | 13.28 | 169.70 |
| 12/13/01 | 11:43:06 | 13.18 | 108.70 |
| 12/13/01 | 11:44:05 | 13.23 | 133.40 |
| 12/13/01 | 11:45:07 | 13.31 | 177.10 |
| 12/13/01 | 11:46:06 | 13.33 | 120.90 |
| 12/13/01 | 11:47:06 | 13.32 | 203.20 |
| 12/13/01 | 11:48:05 | 13.36 | 167.70 |
| 12/13/01 | 11:49:07 | 13.33 | 283.70 |
| 12/13/01 | 11:50:06 | 13.29 | 294.10 |
| 12/13/01 | 11:51:06 | 13.30 | 103.90 |
| 12/13/01 | 11:52:05 | 13.40 | 116.00 |
| 12/13/01 | 11:53:07 | 13.39 | 145.60 |
| 12/13/01 | 11:54:06 | 13.26 | 92.00 |
| 12/13/01 | 11:55:06 | 13.23 | 54.40 |
| 12/13/01 | 11:56:07 | 13.36 | 91.80 |
| Test Run 2 End | | | |
| Average | 572 samples | 13.27 | 155.40 |

Test Run 3 Begin. STRATA Version 2.0

Operator: hal stiles

Plant Name: St.Johns River Power Park

Location: Unit 1 high load

| | | CO2 | CO |
|-----------------|-----------|-------|--------|
| | | % | ppm |
| Start Averaging | | | |
| 12/13/01 | 12:12:36 | 12.96 | 71.00 |
| 12/13/01 | 12:13:35 | 13.07 | 81.30 |
| 12/13/01 | 12:14:36 | 13.03 | 204.80 |
| 12/13/01 | 12:15:35 | 13.09 | 178.80 |
| 12/13/01 | 12:16:37 | 13.14 | 239.70 |
| 12/13/01 | 12:17:36 | 13.21 | 183.50 |
| 12/13/01 | 12:18:35 | 13.34 | 151.70 |
| 12/13/01 | 12:19:36 | 13.18 | 128.00 |
| 12/13/01 | 12:20:35 | 13.05 | 126.20 |
| 12/13/01 | 12:21:36 | 13.15 | 83.90 |
| 12/13/01 | 12:22:35 | 13.22 | 205.10 |
| 12/13/01 | 12:23:36 | 13.32 | 141.50 |
| 12/13/01 | 12:24:35 | 13.28 | 88.40 |
| 12/13/01 | 12:25:36 | 13.27 | 194.20 |
| 12/13/01 | 12:26:35 | 13.24 | 251.70 |
| 12/13/01 | 12:27:36 | 13.37 | 241.70 |
| 12/13/01 | 12:28:35 | 13.15 | 165.80 |
| 12/13/01 | 12:29:36 | 13.31 | 266.00 |
| 12/13/01 | 12:30:35 | 13.21 | 233.40 |
| 12/13/01 | 12:31:36 | 13.19 | 135.50 |
| 12/13/01 | 12:32:35 | 13.22 | 167.80 |
| Test Run 3 End | | | |
| Average | 576 sampl | 13.19 | 168.80 |

Test Run 4 Begin. STRATA Version 2.0

Operator: hal stiles

Plant Name: St.Johns River Power Park

Location: Unit 1 high load

| | | CO2 | CO |
|-----------------|-------------|-------|--------|
| | | % | ppm |
| Start Averaging | | | |
| 12/13/01 | 12:50:16 | 12.91 | 155.40 |
| 12/13/01 | 12:51:15 | 13.05 | 215.50 |
| 12/13/01 | 12:52:14 | 12.99 | 127.10 |
| 12/13/01 | 12:53:16 | 13.14 | 143.20 |
| 12/13/01 | 12:54:15 | 13.10 | 176.80 |
| 12/13/01 | 12:55:15 | 13.35 | 166.10 |
| 12/13/01 | 12:56:14 | 13.25 | 294.80 |
| 12/13/01 | 12:57:16 | 13.21 | 248.10 |
| 12/13/01 | 12:58:15 | 13.20 | 68.60 |
| 12/13/01 | 12:59:15 | 13.25 | 85.30 |
| 12/13/01 | 13:00:14 | 13.11 | 174.50 |
| 12/13/01 | 13:01:16 | 13.16 | 72.60 |
| 12/13/01 | 13:02:15 | 13.30 | 65.00 |
| 12/13/01 | 13:03:15 | 13.17 | 174.60 |
| 12/13/01 | 13:04:14 | 13.25 | 161.00 |
| 12/13/01 | 13:05:16 | 13.35 | 390.20 |
| 12/13/01 | 13:06:15 | 13.33 | 364.60 |
| 12/13/01 | 13:07:15 | 13.37 | 240.60 |
| 12/13/01 | 13:08:14 | 13.27 | 273.10 |
| 12/13/01 | 13:09:16 | 13.30 | 119.70 |
| 12/13/01 | 13:10:15 | 13.21 | 125.60 |
| Test Run 4 End | | | |
| Average | 573 samples | 13.20 | 183.00 |

Test Run 5 Begin. STRATA Version 2.0
Operator: hal stiles
Plant Name: St.Johns River Power Park
Location: Unit 1 high load

| | | CO2 | CO |
|-----------------|-------------|-------|--------|
| | | % | ppm |
| Start Averaging | | | |
| 12/13/01 | 13:27:14 | 13.04 | 185.70 |
| 12/13/01 | 13:28:14 | 12.98 | 211.00 |
| 12/13/01 | 13:29:15 | 12.97 | 166.30 |
| 12/13/01 | 13:30:15 | 13.02 | 115.00 |
| 12/13/01 | 13:31:14 | 13.15 | 225.40 |
| 12/13/01 | 13:32:13 | 13.29 | 162.20 |
| 12/13/01 | 13:33:15 | 13.15 | 387.50 |
| 12/13/01 | 13:34:15 | 13.09 | 231.20 |
| 12/13/01 | 13:35:14 | 13.18 | 72.10 |
| 12/13/01 | 13:36:13 | 13.13 | 79.70 |
| 12/13/01 | 13:37:15 | 13.15 | 77.90 |
| 12/13/01 | 13:38:14 | 13.31 | 127.80 |
| 12/13/01 | 13:39:14 | 13.16 | 277.50 |
| 12/13/01 | 13:40:13 | 13.15 | 188.50 |
| 12/13/01 | 13:41:15 | 13.23 | 258.00 |
| 12/13/01 | 13:42:14 | 13.15 | 167.10 |
| 12/13/01 | 13:43:14 | 13.20 | 173.70 |
| 12/13/01 | 13:44:13 | 13.23 | 177.30 |
| 12/13/01 | 13:45:15 | 13.32 | 118.10 |
| 12/13/01 | 13:46:14 | 13.26 | 131.80 |
| 12/13/01 | 13:47:14 | 13.32 | 156.00 |
| Test Run 5 End | | | |
| Average | 572 samples | 13.17 | 175.90 |

Test Run 6 Begin. STRATA Version 2.0

Operator: hal stiles

Plant Name: St.Johns River Power Park

Location: Unit 1 high load

| | | CO2 | CO |
|-----------------|-------------|-------|--------|
| | | % | ppm |
| Start Averaging | | | |
| 12/13/01 | 14:14:12 | 13.05 | 173.80 |
| 12/13/01 | 14:15:13 | 13.06 | 211.70 |
| 12/13/01 | 14:16:13 | 13.05 | 151.00 |
| 12/13/01 | 14:17:12 | 13.05 | 88.80 |
| 12/13/01 | 14:18:12 | 13.07 | 51.20 |
| 12/13/01 | 14:19:13 | 13.18 | 50.50 |
| 12/13/01 | 14:20:13 | 13.15 | 173.50 |
| 12/13/01 | 14:21:12 | 13.07 | 149.50 |
| 12/13/01 | 14:22:12 | 13.15 | 78.40 |
| 12/13/01 | 14:23:13 | 13.14 | 75.50 |
| 12/13/01 | 14:24:13 | 13.23 | 94.90 |
| 12/13/01 | 14:25:12 | 13.30 | 136.60 |
| 12/13/01 | 14:26:12 | 13.21 | 109.10 |
| 12/13/01 | 14:27:13 | 13.31 | 138.10 |
| 12/13/01 | 14:28:13 | 13.12 | 115.00 |
| 12/13/01 | 14:29:12 | 13.15 | 63.50 |
| 12/13/01 | 14:30:12 | 13.32 | 114.20 |
| 12/13/01 | 14:31:13 | 13.31 | 155.00 |
| 12/13/01 | 14:32:13 | 13.19 | 134.80 |
| 12/13/01 | 14:33:12 | 13.15 | 147.50 |
| 12/13/01 | 14:34:14 | 13.25 | 152.90 |
| Test Run 6 End | | | |
| Average | 573 samples | 13.17 | 122.30 |

Test Run 7 Begin. . STRATA Version 2.0

Operator: hal stiles

Plant Name: St.Johns River Power Park

Location: Unit 1 high load

| | | CO2 % | CO ppm |
|-----------------|-------------|----------|-----------|
| Start Averaging | | | |
| 12/13/01 | 14:55:40 | 13.19 | 126.20 |
| 12/13/01 | 14:56:41 | 13.16 | 144.20 |
| 12/13/01 | 14:57:41 | 13.06 | 76.60 |
| 12/13/01 | 14:58:40 | 13.25 | 69.30 |
| 12/13/01 | 14:59:40 | 13.27 | 75.90 |
| 12/13/01 | 15:00:41 | 13.07 | 118.30 |
| 12/13/01 | 15:01:41 | 12.98 | 422.80 |
| 12/13/01 | 15:02:40 | 13.07 | 662.50 |
| 12/13/01 | 15:03:42 | 13.05 | 209.70 |
| 12/13/01 | 15:04:41 | 13.01 | 60.90 |
| 12/13/01 | 15:05:41 | 13.12 | 200.90 |
| 12/13/01 | 15:06:40 | 12.93 | 724.40 |
| 12/13/01 | 15:07:40 | 13.30 | 778.80 |
| 12/13/01 | 15:08:41 | 13.36 | 478.60 |
| 12/13/01 | 15:09:41 | 13.12 | 234.90 |
| 12/13/01 | 15:10:40 | 13.02 | 211.00 |
| 12/13/01 | 15:11:42 | 13.31 | 411.30 |
| 12/13/01 | 15:12:41 | 13.40 | 241.50 |
| 12/13/01 | 15:13:41 | 13.25 | 377.50 |
| 12/13/01 | 15:14:40 | 13.18 | 256.60 |
| 12/13/01 | 15:15:42 | 13.28 | 108.20 |
| Test Run 7 End | | | |
| Average | 573 samples | 13.16 | 284.90 |

Test Run 8 Begin. STRATA Version 2.0

Operator: hal stiles

Plant Name: St.Johns River Power Park

Location: Unit 1 high load

| | | CO2 | CO |
|-----------------|-------------|-------|--------|
| | | % | ppm |
| Start Averaging | | | |
| 12/13/01 | 15:34:28 | 13.02 | 335.30 |
| 12/13/01 | 15:35:30 | 13.00 | 360.30 |
| 12/13/01 | 15:36:29 | 13.14 | 197.20 |
| 12/13/01 | 15:37:29 | 13.13 | 265.50 |
| 12/13/01 | 15:38:28 | 13.14 | 262.80 |
| 12/13/01 | 15:39:30 | 13.24 | 307.90 |
| 12/13/01 | 15:40:29 | 13.22 | 229.60 |
| 12/13/01 | 15:41:28 | 13.16 | 226.10 |
| 12/13/01 | 15:42:28 | 13.14 | 190.60 |
| 12/13/01 | 15:43:30 | 13.21 | 244.70 |
| 12/13/01 | 15:44:29 | 13.12 | 219.70 |
| 12/13/01 | 15:45:28 | 13.28 | 142.50 |
| 12/13/01 | 15:46:28 | 13.17 | 302.90 |
| 12/13/01 | 15:47:29 | 13.11 | 153.80 |
| 12/13/01 | 15:48:29 | 13.22 | 76.50 |
| 12/13/01 | 15:49:28 | 13.24 | 142.40 |
| 12/13/01 | 15:50:30 | 13.17 | 191.70 |
| 12/13/01 | 15:51:29 | 13.17 | 199.80 |
| 12/13/01 | 15:52:29 | 13.32 | 330.20 |
| 12/13/01 | 15:53:28 | 13.23 | 233.90 |
| 12/13/01 | 15:54:30 | 13.10 | 96.60 |
| Test Run 8 End | | | |
| Average | 573 samples | 13.17 | 224.20 |

Test Run 9 Begin. STRATA Version 2.0
Operator: hal stiles
Plant Name: St.Johns River Power Park
Location: Unit 1 high load

| | | CO2 | CO |
|-----------------|-----------|-------|--------|
| | | % | ppm |
| Start Averaging | | | |
| 12/13/01 | 16:19:15 | 12.97 | 136.40 |
| 12/13/01 | 16:20:14 | 12.93 | 172.80 |
| 12/13/01 | 16:21:16 | 13.12 | 398.40 |
| 12/13/01 | 16:22:15 | 13.14 | 465.40 |
| 12/13/01 | 16:23:14 | 12.95 | 505.30 |
| 12/13/01 | 16:24:15 | 13.05 | 326.00 |
| 12/13/01 | 16:25:14 | 12.96 | 282.10 |
| 12/13/01 | 16:26:15 | 13.01 | 73.70 |
| 12/13/01 | 16:27:14 | 13.03 | 204.50 |
| 12/13/01 | 16:28:14 | 12.95 | 195.00 |
| 12/13/01 | 16:29:15 | 13.03 | 194.70 |
| 12/13/01 | 16:30:14 | 13.09 | 206.00 |
| 12/13/01 | 16:31:15 | 13.12 | 125.10 |
| 12/13/01 | 16:32:14 | 13.07 | 88.20 |
| 12/13/01 | 16:33:15 | 13.15 | 124.90 |
| 12/13/01 | 16:34:14 | 13.17 | 186.80 |
| 12/13/01 | 16:35:15 | 13.19 | 127.90 |
| 12/13/01 | 16:36:14 | 13.10 | 144.10 |
| 12/13/01 | 16:37:15 | 13.15 | 125.70 |
| 12/13/01 | 16:38:14 | 13.27 | 265.10 |
| 12/13/01 | 16:39:15 | 13.30 | 349.10 |
| Test Run 9 End | | | |
| Average | 577 sampl | 13.08 | 223.20 |

Test Run 10 Begin. STRATA Version 2.0

Operator: hal stiles

Plant Name: St.Johns River Power Park

Location: Unit 1 high load

| | | CO2 | CO |
|-----------------|-----------|-------|--------|
| | | % | ppm |
| Start Averaging | | | |
| 12/13/01 | 16:57:09 | 13.01 | 240.10 |
| 12/13/01 | 16:58:08 | 13.01 | 214.00 |
| 12/13/01 | 16:59:07 | 13.01 | 136.40 |
| 12/13/01 | 17:00:08 | 13.02 | 213.10 |
| 12/13/01 | 17:01:07 | 12.98 | 180.80 |
| 12/13/01 | 17:02:09 | 12.94 | 130.10 |
| 12/13/01 | 17:03:08 | 12.97 | 120.20 |
| 12/13/01 | 17:04:09 | 13.19 | 214.50 |
| 12/13/01 | 17:05:08 | 13.21 | 343.00 |
| 12/13/01 | 17:06:09 | 13.20 | 445.30 |
| 12/13/01 | 17:07:08 | 13.20 | 396.60 |
| 12/13/01 | 17:08:07 | 13.24 | 386.00 |
| 12/13/01 | 17:09:08 | 13.15 | 311.10 |
| 12/13/01 | 17:10:07 | 13.15 | 265.70 |
| 12/13/01 | 17:11:08 | 13.12 | 272.50 |
| 12/13/01 | 17:12:09 | 13.15 | 194.00 |
| 12/13/01 | 17:13:08 | 13.09 | 174.80 |
| 12/13/01 | 17:14:09 | 13.02 | 212.90 |
| 12/13/01 | 17:15:08 | 13.22 | 192.90 |
| 12/13/01 | 17:16:09 | 13.31 | 282.10 |
| 12/13/01 | 17:17:08 | 13.17 | 328.50 |
| Test Run 10 | End | | |
| Average | 577 sampl | 13.11 | 250.30 |

GRACE CONSULTING, INC.

MOISTURE DATA SHEET

| | |
|----------------------------|-----------------------|
| Client: SRP | Date: 12-12-01 |
| Project No.: 01-815 | Operator: Nichols |
| Sampling Location: Unit 2 | Run No.: 1 high |
| Barometric Pressure: 30.35 | Probe Number: |
| Condensate: 47.8 | Silica Gel: 14.9 |
| Meter Corr. Factor: 1.017 | Meter Orifice: 3.2978 |
| Sample Pt. Time: 5 min | Meter # 4A |
| | Leak Test @ (in. HG): |
| | After @ (in. HG): |

| Sample Point | Start Time | Delta H | Probe | Imp. Out | Meter In | Meter Out | Vac. Pr (in. HG) | Dry Gas Meter Reading in Cu. Ft. |
|--------------|------------|---------|-------|----------|----------|-----------|------------------|----------------------------------|
| | | | | | | | | 4.000 |
| 5 | 8:52 | 1.798 | 250 | 59 | 86 | 86 | 3 | 7.747 |
| 10 | | | | 59 | 94 | 87 | | 11.495 |
| 15 | | | | 60 | 95 | 87 | | 15.241 |
| 20 | | | | 61 | 98 | 87 | | 18.988 |
| 25 | | | | 62 | 100 | 88 | | 22.736 |
| 30 | | | | 64 | 101 | 89 | | 26.483 |
| | | ↓ | ↓ | | | | ↓ | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| AVG. | 9:22 | | | | | 91.5 | | 22.483 |

MOISTURE FIELD DATA SHEETS

| | |
|----------------------------|----------------------------|
| CLIENT: SJRPP | DATE: 12-12-09 |
| PROJECT NO.: 01-315 | OPERATOR: Nichols |
| SAMPLING LOCATION: Unit 2 | METER ORifice: 3.2978 |
| BAROMETRIC PRESSURE: 30.35 | METER CORR. FACTOR: 1.017 |
| SAMPLE PT. TIME: 5min | UNIT LOAD: high PROBE NO.: |

LEAK CHECK: BEFORE .00 @ 15in AFTER .00 @ 5in

| RUN NO. | SAMPLE POINT | DELTA H | PROBE TEMP. | TEMPERATURE DEGREE FAHRENHEIT | | | | VAC. PR. (In. Hg) | DRY GAS VOLUME (CL FL) |
|------------|--------------|---------|-------------|-------------------------------|----------|-----------|-----------------|-------------------|------------------------|
| | | | | IMP. OUT | METER IN | METER OUT | INITIAL READING | | |
| 2 | 1 | 1.798 | 250 | 56 | 91 | 89 | 3 | 26.505 | |
| START TIME | 9:30 | | | | | | | 30.252 | |
| STOP TIME | 10:00 | 2 | | | 57 | 100 | 89 | 33.990 | |
| SILICA GEL | 13.8 | 3 | | | 57 | 102 | 89 | 37.745 | |
| CONDENSATE | 47.1 | 4 | | | 58 | 103 | 90 | 41.492 | |
| | | 5 | | | 59 | 104 | 90 | 45.239 | |
| | | 6 | ↓ | ↓ | 61 | 105 | 91 | 48.987 | |
| AVG. | | | | | | 95 | | 22.482 | |

LEAK CHECK: BEFORE .00 @ 15in AFTER .00 @ 4in

| RUN NO. | SAMPLE POINT | DELTA H | PROBE TEMP. | TEMPERATURE DEGREE FAHRENHEIT | | | | VAC. PR. (In. Hg) | DRY GAS VOLUME (CL FL) |
|------------|--------------|---------|-------------|-------------------------------|----------|-----------|-----------------|-------------------|------------------------|
| | | | | IMP. OUT | METER IN | METER OUT | INITIAL READING | | |
| 3 | 1 | 1.798 | 250 | 54 | 94 | 90 | 3 | 49.093 | |
| START TIME | 10:08 | | | | | | | 52.840 | |
| STOP TIME | 10:38 | 2 | | | 55 | 98 | 90 | 56.588 | |
| SILICA GEL | 14.2 | 3 | | | 56 | 101 | 90 | 60.334 | |
| CONDENSATE | 46.3 | 4 | | | 57 | 104 | 91 | 64.082 | |
| | | 5 | | | 58 | 105 | 91 | 67.829 | |
| | | 6 | ↓ | ↓ | 60 | 105 | 91 | 71.303 | |
| AVG. | | | | | | 96 | | 22.210 | |

LEAK CHECK: BEFORE .00 @ 14in AFTER .00 @ 5in

| RUN NO. | SAMPLE POINT | DELTA H | PROBE TEMP. | TEMPERATURE DEGREE FAHRENHEIT | | | | VAC. PR. (In. Hg) | DRY GAS VOLUME (CL FL) |
|------------|--------------|---------|-------------|-------------------------------|----------|-----------|-----------------|-------------------|------------------------|
| | | | | IMP. OUT | METER IN | METER OUT | INITIAL READING | | |
| 4 | 1 | 1.798 | 250 | 55 | 93 | 90 | 3 | 71.500 | |
| START TIME | 10:47 | | | | | | | 75.247 | |
| STOP TIME | 11:17 | 2 | | | 56 | 98 | 90 | 78.995 | |
| SILICA GEL | 13.9 | 3 | | | 57 | 102 | 90 | 82.743 | |
| CONDENSATE | 47.2 | 4 | | | 58 | 103 | 90 | 86.490 | |
| | | 5 | | | 59 | 103 | 91 | 90.238 | |
| | | 6 | ↓ | ↓ | 61 | 104 | 91 | 93.985 | |
| AVG. | | | | | | 95 | | 22.485 | |

MOISTURE FIELD DATA SHEETS

CLIENT: STRPP DATE: 12-12-01
 PROJECT NO.: 01-315 OPERATOR: Nichols
 SAMPLING LOCATION: Unit 2 METER-ORFCE: 3.2978
 BAROMETRIC PRESSURE: 30.35 METER CORR. FACTOR: 1.017
 SAMPLE FT. TIME: 5min UNIT LOAD: high PROBE NO:

LEAK CHECK: BEFORE .00 @ 15in AFTER .00 @ 15in

| RUN NO. | SAMPLE POINT | DELTA H | PROBE TEMP. | TEMPERATURE DEGREE FAHRENHEIT | | | VAC. PR. (In. Hg) | DRY GAS VOLUME (CU. FT.) | |
|---------|--------------|---------|-------------|-------------------------------|----------|-----------|-------------------|--------------------------|---------------|
| | | | | IMP. OUT | METER IN | METER OUT | | INITIAL READING | FINAL READING |
| 5 | 1 | 1.798 | 250 | 55 | 93 | 90 | 3 | 94.120 | 97.867 |
| | 2 | | | 56 | 100 | 90 | | | 101.615 |
| | 3 | | | 58 | 103 | 90 | | | 105.363 |
| | 4 | | | 58 | 103 | 90 | | | 109.111 |
| | 5 | | | 59 | 104 | 90 | | | 112.858 |
| | 6 | | | 60 | 104 | 91 | | | 116.605 |
| AVG. | | | | | | 96 | | | 22.485 |

LEAK CHECK: BEFORE .00 @ 15in AFTER .00 @ 15in

| RUN NO. | SAMPLE POINT | DELTA H | PROBE TEMP. | TEMPERATURE DEGREE FAHRENHEIT | | | VAC. PR. (In. Hg) | DRY GAS VOLUME (CU. FT.) | |
|---------|--------------|---------|-------------|-------------------------------|----------|-----------|-------------------|--------------------------|---------------|
| | | | | IMP. OUT | METER IN | METER OUT | | INITIAL READING | FINAL READING |
| 6 | 1 | 1.798 | 250 | 54 | 84 | 84 | 3 | 116.800 | 120.547 |
| | 2 | | | 55 | 89 | 84 | | | 124.295 |
| | 3 | | | 57 | 93 | 84 | | | 128.042 |
| | 4 | | | 57 | 95 | 84 | | | 131.789 |
| | 5 | | | 58 | 98 | 85 | | | 135.537 |
| | 6 | | | 60 | 97 | 85 | | | 139.284 |
| AVG. | | | | | | 89 | | | 22.484 |

LEAK CHECK: BEFORE .00 @ 15in AFTER .00 @ 15in

| RUN NO. | SAMPLE POINT | DELTA H | PROBE TEMP. | TEMPERATURE DEGREE FAHRENHEIT | | | VAC. PR. (In. Hg) | DRY GAS VOLUME (CU. FT.) | |
|---------|--------------|---------|-------------|-------------------------------|----------|-----------|-------------------|--------------------------|----------------------------|
| | | | | IMP. OUT | METER IN | METER OUT | | INITIAL READING | FINAL READING |
| 7 | 1 | 1.798 | 250 | 54 | 91 | 85 | 3 | 139.600 | 143.347 143.347 |
| | 2 | | | 56 | 97 | 86 | | | 147.095 147.095 |
| | 3 | | | 56 | 98 | 86 | | | 150.842 150.842 |
| | 4 | | | 57 | 100 | 86 | | | 154.590 154.590 |
| | 5 | | | 58 | 101 | 87 | | | 158.337 158.337 |
| | 6 | | | 59 | 102 | 87 | | | 162.084 162.084 |
| AVG. | | | | | | 92 | | | 22.484 |

MOISTURE FIELD DATA SHEETS

| | |
|-----------------------------------|-----------------------------------|
| CLIENT: STRPP | DATE: 12-12-01 |
| PROJECT NO.: 01-315 | OPERATOR: Nichols |
| SAMPLING LOCATION: Unit 2 | METER ORifice: 3.2978 |
| BAROMETRIC PRESSURE: 30.35 | METER CORR. FACTOR: 1.017 |
| SAMPLE FT. TIME: 5min | UNIT LOAD: High PROBE NO.: |

LEAK CHECK: BEFORE .001 @ 15 in AFTER .001 @ 5 in

| RUN NO. | SAMPLE POINT | DELTA H | PROBE TEMP. | IMP. OUT | TEMPERATURE DEGREE FAHRENHEIT | | VAC. PR. (In. Hg) | DRY GAS VOLUME (Cu. Ft.) |
|------------|--------------|---------|-------------|----------|-------------------------------|-----------|-------------------|--------------------------|
| | | | | | METER IN | METER OUT | | INITIAL READING |
| 8 | 1 | 1.798 | 250 | 54 | 89 | 88 | 3 | 162.200 |
| START TIME | 13:56 | | | | | | | 165.948 |
| STOP TIME | 14:26 | | | 55 | 98 | 88 | | 169.695 |
| SILICA GEL | 42.6 | | | 56 | 102 | 88 | | 173.442 |
| CONDENSATE | 47.3 | | | 57 | 102 | 89 | | 177.189 |
| | | | | 58 | 103 | 90 | | 180.936 |
| | | | | 59 | 104 | 90 | | 184.648 |
| AVG. | | | | | | 94 | | 22.488 |

LEAK CHECK: BEFORE .001 @ 15 in AFTER .001 @ 5 in

| RUN NO. | SAMPLE POINT | DELTA H | PROBE TEMP. | IMP. OUT | TEMPERATURE DEGREE FAHRENHEIT | | VAC. PR. (In. Hg) | DRY GAS VOLUME (Cu. Ft.) |
|------------|--------------|---------|-------------|----------|-------------------------------|-----------|-------------------|--------------------------|
| | | | | | METER IN | METER OUT | | INITIAL READING |
| 9 | 1 | 1.798 | 250 | 55 | 92 | 89 | 3 | 184.800 |
| START TIME | 14:31 | | | | | | | 188.548 |
| STOP TIME | 15:01 | | | 56 | 101 | 90 | | 192.295 |
| SILICA GEL | 13.4 | | | 57 | 103 | 90 | | 196.043 |
| CONDENSATE | 48.2 | | | 58 | 104 | 90 | | 199.790 |
| | | | | 59 | 104 | 90 | | 203.537 |
| | | | | 61 | 105 | 91 | | 207.286 |
| AVG. | | | | | | 96 | | 22.486 |

LEAK CHECK: BEFORE .001 @ 15 in AFTER .000 @ 5 in

| RUN NO. | SAMPLE POINT | DELTA H | PROBE TEMP. | IMP. OUT | TEMPERATURE DEGREE FAHRENHEIT | | VAC. PR. (In. Hg) | DRY GAS VOLUME (Cu. Ft.) |
|------------|--------------|---------|-------------|----------|-------------------------------|-----------|-------------------|--------------------------|
| | | | | | METER IN | METER OUT | | INITIAL READING |
| 10 | 1 | 1.788 | 250 | 54 | 91 | 90 | 3 | 207.400 |
| START TIME | 15:09 | | | | | | | 211.147 |
| STOP TIME | 15:39 | | | 55 | 100 | 90 | | 214.895 |
| SILICA GEL | 14.3 | | | 56 | 102 | 90 | | 218.642 |
| CONDENSATE | 47.2 | | | 57 | 105 | 91 | | 222.390 |
| | | | | 58 | 105 | 91 | | 226.137 |
| | | | | 59 | 106 | 92 | | 229.849 |
| AVG. | | | | | | 96 | | 22.449 |

Test Run 1 Begin. STRATA Version 2.0

Operator: hal stiles

Plant Name: St.Johns River Power Park

Location: Unit 2 high load

| | | CO2 | CO |
|-----------------|-------------|-------|--------|
| | | % | ppm |
| Start Averaging | | | |
| 12/12/01 | 8:53:12 | 13.32 | 378.80 |
| 12/12/01 | 8:54:11 | 13.42 | 393.10 |
| 12/12/01 | 8:55:11 | 13.38 | 368.50 |
| 12/12/01 | 8:56:12 | 13.35 | 463.10 |
| 12/12/01 | 8:57:12 | 13.52 | 547.20 |
| 12/12/01 | 8:58:11 | 13.61 | 674.70 |
| 12/12/01 | 8:59:11 | 13.52 | 826.80 |
| 12/12/01 | 9:00:12 | 13.29 | 474.50 |
| 12/12/01 | 9:01:12 | 13.38 | 273.40 |
| 12/12/01 | 9:02:11 | 13.58 | 335.30 |
| 12/12/01 | 9:03:11 | 13.56 | 515.10 |
| 12/12/01 | 9:04:12 | 13.50 | 404.60 |
| 12/12/01 | 9:05:12 | 13.53 | 400.80 |
| 12/12/01 | 9:06:11 | 13.59 | 417.40 |
| 12/12/01 | 9:07:10 | 13.66 | 363.20 |
| 12/12/01 | 9:08:12 | 13.56 | 531.60 |
| 12/12/01 | 9:09:11 | 13.67 | 405.70 |
| 12/12/01 | 9:10:11 | 13.63 | 410.80 |
| 12/12/01 | 9:11:13 | 13.57 | 396.80 |
| 12/12/01 | 9:12:12 | 13.63 | 406.80 |
| 12/12/01 | 9:13:11 | 13.69 | 487.70 |
| Test Run 1 End | | | |
| Average | 549 samples | 13.53 | 454.50 |

Test Run 2 Begin. STRATA Version 2.0

Operator: hal stiles

Plant Name: St.Johns River Power Park

Location: Unit 2 high load

| | | CO2 | CO |
|-----------------|-------------|-------|--------|
| | | % | ppm |
| Start Averaging | | | |
| 12/12/01 | 9:31:18 | 13.57 | 529.60 |
| 12/12/01 | 9:32:17 | 13.47 | 551.40 |
| 12/12/01 | 9:33:19 | 13.52 | 537.50 |
| 12/12/01 | 9:34:18 | 13.58 | 467.20 |
| 12/12/01 | 9:35:18 | 13.59 | 464.60 |
| 12/12/01 | 9:36:17 | 13.54 | 389.30 |
| 12/12/01 | 9:37:19 | 13.64 | 439.80 |
| 12/12/01 | 9:38:18 | 13.59 | 573.10 |
| 12/12/01 | 9:39:17 | 13.59 | 390.30 |
| 12/12/01 | 9:40:17 | 13.70 | 501.10 |
| 12/12/01 | 9:41:18 | 13.66 | 596.50 |
| 12/12/01 | 9:42:18 | 13.67 | 445.50 |
| 12/12/01 | 9:43:17 | 13.52 | 335.00 |
| 12/12/01 | 9:44:17 | 13.47 | 270.50 |
| 12/12/01 | 9:45:18 | 13.67 | 341.10 |
| 12/12/01 | 9:46:18 | 13.74 | 553.10 |
| 12/12/01 | 9:47:17 | 13.65 | 432.10 |
| 12/12/01 | 9:48:19 | 13.67 | 597.20 |
| 12/12/01 | 9:49:18 | 13.74 | 524.50 |
| 12/12/01 | 9:50:18 | 13.76 | 450.10 |
| 12/12/01 | 9:51:17 | 13.63 | 303.30 |
| Test Run 2 End | | | |
| Average | 572 samples | 13.62 | 461.80 |

Test Run 3 Begin. STRATA Version 2.0

Operator: hal stiles

Plant Name: St.Johns River Power Park

Location: Unit 2 high load

| | | CO2 | CO |
|-----------------|-------------|-------|--------|
| | | % | ppm |
| Start Averaging | | | |
| 12/12/01 | 10:09:22 | 13.48 | 500.90 |
| 12/12/01 | 10:10:23 | 13.51 | 522.20 |
| 12/12/01 | 10:11:23 | 13.58 | 683.50 |
| 12/12/01 | 10:12:22 | 13.45 | 564.00 |
| 12/12/01 | 10:13:22 | 13.53 | 424.60 |
| 12/12/01 | 10:14:23 | 13.64 | 698.20 |
| 12/12/01 | 10:15:23 | 13.43 | 524.60 |
| 12/12/01 | 10:16:22 | 13.37 | 293.30 |
| 12/12/01 | 10:17:24 | 13.47 | 393.20 |
| 12/12/01 | 10:18:23 | 13.45 | 419.80 |
| 12/12/01 | 10:19:23 | 13.58 | 447.30 |
| 12/12/01 | 10:20:22 | 13.69 | 389.40 |
| 12/12/01 | 10:21:24 | 13.55 | 410.00 |
| 12/12/01 | 10:22:23 | 13.42 | 319.90 |
| 12/12/01 | 10:23:23 | 13.53 | 357.10 |
| 12/12/01 | 10:24:22 | 13.55 | 449.20 |
| 12/12/01 | 10:25:24 | 13.62 | 418.10 |
| 12/12/01 | 10:26:23 | 13.60 | 467.30 |
| 12/12/01 | 10:27:23 | 13.53 | 564.10 |
| 12/12/01 | 10:28:22 | 13.51 | 401.70 |
| 12/12/01 | 10:29:24 | 13.73 | 590.80 |
| Test Run 3 End | | | |
| Average | 573 samples | 13.54 | 468.80 |

Test Run 4 Begin. STRATA Version 2.0

Operator: hal stiles

Plant Name: St.Johns River Power Park

Location: Unit 2 high load

| | | CO2 | CO |
|-----------------|-------------|-------|--------|
| | | % | ppm |
| Start Averaging | | | |
| 12/12/01 | 10:48:17 | 13.39 | 416.20 |
| 12/12/01 | 10:49:19 | 13.53 | 474.70 |
| 12/12/01 | 10:50:18 | 13.46 | 367.40 |
| 12/12/01 | 10:51:18 | 13.54 | 392.10 |
| 12/12/01 | 10:52:19 | 13.61 | 549.10 |
| 12/12/01 | 10:53:19 | 13.67 | 471.30 |
| 12/12/01 | 10:54:18 | 13.58 | 475.00 |
| 12/12/01 | 10:55:18 | 13.52 | 323.10 |
| 12/12/01 | 10:56:19 | 13.68 | 295.00 |
| 12/12/01 | 10:57:19 | 13.40 | 238.90 |
| 12/12/01 | 10:58:18 | 13.52 | 232.20 |
| 12/12/01 | 10:59:18 | 13.54 | 450.10 |
| 12/12/01 | 11:00:19 | 13.59 | 423.40 |
| 12/12/01 | 11:01:19 | 13.65 | 435.10 |
| 12/12/01 | 11:02:18 | 13.74 | 574.00 |
| 12/12/01 | 11:03:18 | 13.74 | 749.20 |
| 12/12/01 | 11:04:19 | 13.64 | 547.60 |
| 12/12/01 | 11:05:19 | 13.66 | 540.90 |
| 12/12/01 | 11:06:18 | 13.64 | 428.80 |
| 12/12/01 | 11:07:17 | 13.66 | 397.20 |
| 12/12/01 | 11:08:19 | 13.56 | 503.80 |
| Test Run 4 End | | | |
| Average | 573 samples | 13.59 | 442.30 |

Test Run 5 Begin. STRATA Version 2.0

Operator: hal stiles

Plant Name: St.Johns River Power Park

Location: Unit 2 high load

| | | CO2 % | CO ppm |
|-----------------|-------------|----------|-----------|
| Start Averaging | | | |
| 12/12/01 | 11:26:05 | 13.55 | 584.90 |
| 12/12/01 | 11:27:06 | 13.67 | 582.20 |
| 12/12/01 | 11:28:06 | 13.63 | 609.50 |
| 12/12/01 | 11:29:05 | 13.45 | 334.00 |
| 12/12/01 | 11:30:05 | 13.52 | 310.30 |
| 12/12/01 | 11:31:06 | 13.65 | 361.50 |
| 12/12/01 | 11:32:06 | 13.64 | 354.40 |
| 12/12/01 | 11:33:05 | 13.55 | 481.20 |
| 12/12/01 | 11:34:05 | 13.51 | 411.00 |
| 12/12/01 | 11:35:06 | 13.57 | 366.20 |
| 12/12/01 | 11:36:06 | 13.49 | 645.40 |
| 12/12/01 | 11:37:05 | 13.44 | 540.30 |
| 12/12/01 | 11:38:07 | 13.57 | 620.70 |
| 12/12/01 | 11:39:06 | 13.61 | 566.80 |
| 12/12/01 | 11:40:06 | 13.62 | 500.50 |
| 12/12/01 | 11:41:05 | 13.51 | 442.30 |
| 12/12/01 | 11:42:07 | 13.61 | 373.40 |
| 12/12/01 | 11:43:06 | 13.85 | 536.70 |
| 12/12/01 | 11:44:06 | 13.80 | 665.80 |
| 12/12/01 | 11:45:05 | 13.64 | 524.50 |
| 12/12/01 | 11:46:07 | 13.68 | 545.10 |
| Test Run 5 End | | | |
| Average | 573 samples | 13.60 | 492.90 |

Test Run 6 Begin. STRATA Version 2.0

Operator: hal stiles

Plant Name: St.Johns River Power Park

Location: Unit 2 high load

| | | CO2 | CO |
|-----------------|-------------|-------|--------|
| | | % | ppm |
| Start Averaging | | | |
| 12/12/01 | 12:49:15 | 13.60 | 408.20 |
| 12/12/01 | 12:50:17 | 13.61 | 312.40 |
| 12/12/01 | 12:51:16 | 13.52 | 273.10 |
| 12/12/01 | 12:52:16 | 13.59 | 432.00 |
| 12/12/01 | 12:53:15 | 13.56 | 519.40 |
| 12/12/01 | 12:54:17 | 13.65 | 592.50 |
| 12/12/01 | 12:55:16 | 13.51 | 430.70 |
| 12/12/01 | 12:56:16 | 13.63 | 525.20 |
| 12/12/01 | 12:57:15 | 13.73 | 915.80 |
| 12/12/01 | 12:58:17 | 13.59 | 761.70 |
| 12/12/01 | 12:59:16 | 13.58 | 520.20 |
| 12/12/01 | 13:00:15 | 13.47 | 414.60 |
| 12/12/01 | 13:01:15 | 13.61 | 542.10 |
| 12/12/01 | 13:02:16 | 13.82 | 902.50 |
| 12/12/01 | 13:03:16 | 13.73 | 992.40 |
| 12/12/01 | 13:04:15 | 13.57 | 647.70 |
| 12/12/01 | 13:05:17 | 13.64 | 465.50 |
| 12/12/01 | 13:06:16 | 13.66 | 661.10 |
| 12/12/01 | 13:07:16 | 13.57 | 480.10 |
| 12/12/01 | 13:08:15 | 13.63 | 447.20 |
| 12/12/01 | 13:09:17 | 13.69 | 606.20 |
| Test Run 6 End | | | |
| Average | 573 samples | 13.62 | 564.50 |

Test Run 7 Begin. STRATA Version 2.0
Operator: hal stiles
Plant Name: St.Johns River Power Park
Location: Unit 2 high load

| | | CO2 % | CO ppm |
|-----------------|-------------|----------|-----------|
| Start Averaging | | | |
| 12/12/01 | 13:23:15 | 13.50 | 618.70 |
| 12/12/01 | 13:24:17 | 13.54 | 765.90 |
| 12/12/01 | 13:25:16 | 13.39 | 549.20 |
| 12/12/01 | 13:26:15 | 13.47 | 418.50 |
| 12/12/01 | 13:27:15 | 13.49 | 293.90 |
| 12/12/01 | 13:28:17 | 13.56 | 393.60 |
| 12/12/01 | 13:29:16 | 13.56 | 430.90 |
| 12/12/01 | 13:30:15 | 13.51 | 444.00 |
| 12/12/01 | 13:31:17 | 13.71 | 377.60 |
| 12/12/01 | 13:32:16 | 13.74 | 438.50 |
| 12/12/01 | 13:33:16 | 13.70 | 627.80 |
| 12/12/01 | 13:34:15 | 13.52 | 409.50 |
| 12/12/01 | 13:35:17 | 13.58 | 334.80 |
| 12/12/01 | 13:36:16 | 13.74 | 322.70 |
| 12/12/01 | 13:37:16 | 13.66 | 389.60 |
| 12/12/01 | 13:38:15 | 13.56 | 375.70 |
| 12/12/01 | 13:39:17 | 13.51 | 248.80 |
| 12/12/01 | 13:40:16 | 13.67 | 340.70 |
| 12/12/01 | 13:41:16 | 13.45 | 279.90 |
| 12/12/01 | 13:42:15 | 13.48 | 305.10 |
| 12/12/01 | 13:43:17 | 13.67 | 361.80 |
| Test Run 7 End | | | |
| Average | 573 samples | 13.57 | 415.70 |

Test Run 8 Begin. STRATA Version 2.0

Operator: hal stiles

Plant Name: St.Johns River Power Park

Location: Unit 2 high load

| | | CO2 | CO |
|-----------------|-------------|-------|--------|
| | | % | ppm |
| Start Averaging | | | |
| 12/12/01 | 13:57:20 | 13.54 | 430.00 |
| 12/12/01 | 13:58:22 | 13.50 | 553.10 |
| 12/12/01 | 13:59:21 | 13.47 | 447.90 |
| 12/12/01 | 14:00:20 | 13.52 | 445.50 |
| 12/12/01 | 14:01:20 | 13.60 | 484.10 |
| 12/12/01 | 14:02:22 | 13.67 | 566.00 |
| 12/12/01 | 14:03:21 | 13.69 | 715.80 |
| 12/12/01 | 14:04:20 | 13.61 | 678.20 |
| 12/12/01 | 14:05:20 | 13.52 | 354.30 |
| 12/12/01 | 14:06:21 | 13.62 | 341.80 |
| 12/12/01 | 14:07:21 | 13.75 | 526.10 |
| 12/12/01 | 14:08:20 | 13.81 | 650.30 |
| 12/12/01 | 14:09:20 | 13.55 | 451.80 |
| 12/12/01 | 14:10:21 | 13.44 | 276.60 |
| 12/12/01 | 14:11:21 | 13.54 | 259.80 |
| 12/12/01 | 14:12:20 | 13.74 | 317.10 |
| 12/12/01 | 14:13:20 | 13.74 | 526.90 |
| 12/12/01 | 14:14:21 | 13.49 | 397.70 |
| 12/12/01 | 14:15:21 | 13.77 | 304.70 |
| 12/12/01 | 14:16:20 | 13.81 | 586.90 |
| 12/12/01 | 14:17:20 | 13.51 | 573.40 |
| Test Run 8 End | | | |
| Average | 573 samples | 13.61 | 470.50 |

Test Run 9 Begin. STRATA Version 2.0

Operator: hal stiles

Plant Name: St.Johns River Power Park

Location: Unit 2 high load

| | | CO2 | CO |
|-----------------|-------------|-------|--------|
| | | % | ppm |
| Start Averaging | | | |
| 12/12/01 | 14:32:19 | 13.52 | 529.00 |
| 12/12/01 | 14:33:21 | 13.41 | 446.80 |
| 12/12/01 | 14:34:21 | 13.45 | 357.20 |
| 12/12/01 | 14:35:20 | 13.42 | 269.10 |
| 12/12/01 | 14:36:19 | 13.47 | 285.40 |
| 12/12/01 | 14:37:21 | 13.54 | 410.00 |
| 12/12/01 | 14:38:21 | 13.53 | 369.10 |
| 12/12/01 | 14:39:20 | 13.56 | 389.90 |
| 12/12/01 | 14:40:19 | 13.46 | 355.70 |
| 12/12/01 | 14:41:21 | 13.46 | 253.90 |
| 12/12/01 | 14:42:20 | 13.67 | 307.20 |
| 12/12/01 | 14:43:20 | 13.65 | 501.90 |
| 12/12/01 | 14:44:19 | 13.47 | 258.00 |
| 12/12/01 | 14:45:21 | 13.41 | 177.10 |
| 12/12/01 | 14:46:20 | 13.59 | 282.50 |
| 12/12/01 | 14:47:20 | 13.63 | 388.90 |
| 12/12/01 | 14:48:19 | 13.71 | 357.50 |
| 12/12/01 | 14:49:21 | 13.60 | 287.00 |
| 12/12/01 | 14:50:20 | 13.54 | 225.40 |
| 12/12/01 | 14:51:20 | 13.81 | 403.60 |
| 12/12/01 | 14:52:21 | 13.65 | 536.70 |
| Test Run 9 End | | | |
| Average | 573 samples | 13.55 | 352.00 |

Test Run 10 Begin. STRATA Version 2.0

Operator: hal stiles

Plant Name: St.Johns River Power Park

Location: Unit 2 high load

| | | CO2 | CO |
|-----------------|----------|-------|--------|
| | | % | ppm |
| 12/12/01 | 15:10:04 | 13.36 | 424.00 |
| 12/12/01 | 15:11:06 | 13.46 | 514.50 |
| 12/12/01 | 15:12:05 | 13.51 | 627.10 |
| 12/12/01 | 15:13:05 | 13.59 | 670.30 |
| 12/12/01 | 15:14:04 | 13.50 | 552.00 |
| 12/12/01 | 15:15:06 | 13.48 | 326.60 |
| 12/12/01 | 15:16:05 | 13.60 | 456.90 |
| 12/12/01 | 15:17:05 | 13.55 | 426.30 |
| 12/12/01 | 15:18:06 | 13.61 | 440.70 |
| 12/12/01 | 15:19:05 | 13.57 | 552.30 |
| 12/12/01 | 15:20:05 | 13.59 | 385.20 |
| 12/12/01 | 15:21:04 | 13.58 | 302.60 |
| 12/12/01 | 15:22:06 | 13.63 | 404.30 |
| 12/12/01 | 15:23:05 | 13.69 | 535.80 |
| 12/12/01 | 15:24:05 | 13.73 | 669.30 |
| 12/12/01 | 15:25:04 | 13.68 | 411.50 |
| 12/12/01 | 15:26:06 | 13.48 | 280.00 |
| 12/12/01 | 15:27:05 | 13.57 | 221.40 |
| 12/12/01 | 15:28:04 | 13.59 | 343.90 |
| 12/12/01 | 15:29:06 | 13.59 | 396.30 |
| 12/12/01 | 15:30:05 | 13.49 | 396.70 |
| Test Run 10 End | | | |
| | averages | 13.56 | 444.65 |

ANALYZER CALIBRATION DATA

Client **SJRPP** Project # **01-315** Test Date **12/13/01**
Source Identification **Jacksonville, FL** 1 Operator **stiles**

| Calibration Data For Sampling Runs: 1-12 Gas Type: CO Span: 1000 | Cylinder Number | Cylinder Value % or PPM | Analyzer Response | Absolute Difference % or PPM | Difference % of Span |
|--|--------------------|-------------------------------|----------------------|------------------------------------|-------------------------|
| Zero Gas | | .0 | .8 | .80 | .08 |
| Low-Range Gas | | N/A | | | |
| Mid-Range Gas | 351 | 304.0 | 307.5 | 3.50 | .35 |
| High-Range Gas | 065 | 608.0 | 612.0 | 4.00 | .40 |

| Calibration Data For Sampling Runs: 1-12 Gas Type: CO2 Span: 20 | Cylinder Number | Cylinder Value % or PPM | Analyzer Response | Absolute Difference % or PPM | Difference % of Span |
|---|--------------------|-------------------------------|----------------------|------------------------------------|-------------------------|
| Zero Gas | | .00 | .04 | .04 | .20 |
| Low-Range Gas | | N/A | | | |
| Mid-Range Gas | CC99263 | 11.10 | 11.34 | .24 | 1.20 |
| High-Range Gas | DP010791 | 17.30 | 17.35 | .05 | .25 |

ANALYZER CALIBRATION BIAS AND DRIFT DATA

Client **SJRPP** Project # **01-315** Test Date **12/13/2001**
 Source Identification **Jacksonville, FL 1** Operator **stiles**

| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
|----------------------|------|-------------------|-----------------|----------------------------|-----------------|----------------------------|-----------------|
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO | | | | | | |
| Span: | 1000 | | | | | | |
| Zero Gas | | 0.80 | 0.20 | 0.06 | 0.30 | 0.05 | 0.01 |
| Upscale Gas | | 307.50 | 308.00 | 0.05 | 307.00 | 0.05 | 0.10 |
| | | | | | | | |
| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO | | | | | | |
| Span: | 1000 | | | | | | |
| Zero Gas | | 0.80 | 0.30 | 0.05 | 0.50 | 0.03 | 0.02 |
| Upscale Gas | | 307.50 | 307.00 | 0.05 | 306.00 | 0.15 | 0.10 |
| | | | | | | | |
| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO | | | | | | |
| Span: | 1000 | | | | | | |
| Zero Gas | | 0.80 | 0.50 | 0.03 | 0.40 | 0.04 | 0.01 |
| Upscale Gas | | 307.50 | 306.00 | 0.15 | 304.00 | 0.35 | 0.20 |
| | | | | | | | |
| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO | | | | | | |
| Span: | 1000 | | | | | | |
| Zero Gas | | 0.80 | 0.40 | 0.04 | 0.50 | 0.03 | 0.01 |
| Upscale Gas | | 307.50 | 304.00 | 0.35 | 308.00 | 0.05 | 0.40 |

DRIFT = (FINAL SYSTEM CAL. RESPONSE - INITIAL CAL. RESPONSE / SPAN) X 100

ANALYZER CALIBRATION BIAS AND DRIFT DATA

Client **SJRPP** Project # **01-315** Test Date **12/13/2001**
 Source Identification Jacksonville, FL 1 Operator **stiles**

| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
|----------------------|------|-------------------|-----------------|----------------------------|-----------------|----------------------------|-----------------|
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO | | | | | | |
| Span: | 1000 | | | | | | |
| Zero Gas | | 0.80 | 0.50 | 0.03 | 0.80 | 0.00 | 0.03 |
| Upscale Gas | | 307.50 | 308.00 | 0.05 | 306.50 | 0.10 | 0.15 |
| | | | | | | | |
| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO | | | | | | |
| Span: | 1000 | | | | | | |
| Zero Gas | | 0.80 | 0.80 | 0.00 | 0.60 | 0.02 | 0.02 |
| Upscale Gas | | 307.50 | 306.50 | 0.10 | 305.00 | 0.25 | 0.15 |
| | | | | | | | |
| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO | | | | | | |
| Span: | 1000 | | | | | | |
| Zero Gas | | 0.80 | 0.60 | 0.02 | 0.60 | 0.02 | 0.00 |
| Upscale Gas | | 307.50 | 305.00 | 0.25 | 307.50 | 0.00 | 0.25 |
| | | | | | | | |
| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO | | | | | | |
| Span: | 1000 | | | | | | |
| Zero Gas | | 0.80 | 0.60 | 0.02 | 0.00 | 0.08 | 0.06 |
| Upscale Gas | | 307.50 | 307.50 | 0.00 | 309.00 | 0.15 | 0.15 |

DRIFT = (FINAL SYSTEM CAL. RESPONSE - INITIAL CAL. RESPONSE / SPAN) X 100

ANALYZER CALIBRATION BIAS AND DRIFT DATA

Client **SJRPP** Project # **01-315** Test Date **12/13/2001**
 Source Identification Jacksonville, FL **1** Operator **stiles**

| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
|----------------------|------|-------------------|-----------------|----------------------------|-----------------|----------------------------|-----------------|
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO | | | | | | |
| Span: | 1000 | | | | | | |
| Zero Gas | | 0.80 | 0.00 | 0.08 | 0.00 | 0.08 | 0.00 |
| Upscale Gas | | 307.50 | 309.00 | 0.15 | 302.00 | 0.55 | 0.70 |
| | | | | | | | |
| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO | | | | | | |
| Span: | 1000 | | | | | | |
| Zero Gas | | 0.80 | 0.00 | 0.08 | -0.20 | 0.10 | 0.02 |
| Upscale Gas | | 307.50 | 302.00 | 0.55 | 306.00 | 0.15 | 0.40 |
| | | | | | | | |
| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO | | | | | | |
| Span: | 1000 | | | | | | |
| Zero Gas | | 0.80 | -0.20 | 0.10 | 0.00 | 0.08 | 0.02 |
| Upscale Gas | | 307.50 | 304.50 | 0.30 | 0.00 | 30.75 | 30.45 |
| | | | | | | | |
| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO | | | | | | |
| Span: | 1000 | | | | | | |
| Zero Gas | | 0.80 | 0.00 | 0.08 | 0.00 | 0.08 | 0.00 |
| Upscale Gas | | 307.50 | 0.00 | 30.75 | 0.00 | 30.75 | 0.00 |

DRIFT = (FINAL SYSTEM CAL. RESPONSE - INITIAL CAL. RESPONSE / SPAN) X 100

ANALYZER CALIBRATION BIAS AND DRIFT DATA

Client **SJRPP** Project # **01-315** Test Date **12/13/2001**
 Source Identification **Jacksonville, FL 1** Operator **stiles**

| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
|----------------------|-----|-------------------|-----------------|----------------------------|-----------------|----------------------------|-----------------|
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO2 | | | | | | |
| Span: | 20 | | | | | | |
| Zero Gas | | 0.04 | 0.23 | 0.95 | 0.45 | 2.05 | 1.10 |
| Upscale Gas | | 11.34 | 11.04 | 1.50 | 11.20 | 0.70 | 0.80 |
| | | | | | | | |
| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO2 | | | | | | |
| Span: | 20 | | | | | | |
| Zero Gas | | 0.04 | 0.45 | 2.05 | 0.51 | 2.35 | 0.30 |
| Upscale Gas | | 11.34 | 11.20 | 0.70 | 11.29 | 0.25 | 0.45 |
| | | | | | | | |
| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO2 | | | | | | |
| Span: | 20 | | | | | | |
| Zero Gas | | 0.04 | 0.51 | 2.35 | 0.52 | 2.40 | 0.05 |
| Upscale Gas | | 11.34 | 11.29 | 0.25 | 11.29 | 0.25 | 0.00 |
| | | | | | | | |
| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO2 | | | | | | |
| Span: | 20 | | | | | | |
| Zero Gas | | 0.04 | 0.52 | 2.40 | 0.59 | 2.75 | 0.35 |
| Upscale Gas | | 11.34 | 11.29 | 0.25 | 11.22 | 0.60 | 0.35 |

DRIFT = (FINAL SYSTEM CAL. RESPONSE - INITIAL CAL. RESPONSE / SPAN) X 100

ANALYZER CALIBRATION BIAS AND DRIFT DATA

Client **SJRPP** Project # **01-315** Test Date **12/13/2001**
 Source Identification Jacksonville, FL 1 Operator **stiles**

| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
|----------------------|-----|-------------------|-----------------|----------------------------|-----------------|----------------------------|-----------------|
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO2 | | | | | | |
| Span: | 20 | | | | | | |
| Zero Gas | | 0.04 | 0.59 | 2.75 | 0.54 | 2.50 | 0.25 |
| Upscale Gas | | 11.34 | 11.22 | 0.60 | 11.21 | 0.65 | 0.05 |
| | | | | | | | |
| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO2 | | | | | | |
| Span: | 20 | | | | | | |
| Zero Gas | | 0.04 | 0.54 | 2.50 | 0.48 | 2.20 | 0.30 |
| Upscale Gas | | 11.34 | 11.21 | 0.65 | 11.23 | 0.55 | 0.10 |
| | | | | | | | |
| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO2 | | | | | | |
| Span: | 20 | | | | | | |
| Zero Gas | | 0.04 | 0.48 | 2.20 | 0.54 | 2.50 | 0.30 |
| Upscale Gas | | 11.34 | 11.23 | 0.55 | 11.25 | 0.45 | 0.10 |
| | | | | | | | |
| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO2 | | | | | | |
| Span: | 20 | | | | | | |
| Zero Gas | | 0.04 | 0.54 | 2.50 | 0.51 | 2.35 | 0.15 |
| Upscale Gas | | 11.34 | 11.25 | 0.45 | 11.21 | 0.65 | 0.20 |

DRIFT = (FINAL SYSTEM CAL. RESPONSE - INITIAL CAL. RESPONSE / SPAN) X 100

ANALYZER CALIBRATION BIAS AND DRIFT DATA

Client **SJRPP** Project # **01-315** Test Date **12/13/2001**
 Source Identification Jacksonville, FL 1 Operator **stiles**

| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
|----------------------|-----|-------------------|-----------------|----------------------------|-----------------|----------------------------|-----------------|
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO2 | | | | | | |
| Span: | 20 | | | | | | |
| Zero Gas | | 0.04 | 0.51 | 2.35 | 0.49 | 2.25 | 0.10 |
| Upscale Gas | | 11.34 | 11.21 | 0.65 | 11.23 | 0.55 | 0.10 |
| | | | | | | | |
| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO2 | | | | | | |
| Span: | 20 | | | | | | |
| Zero Gas | | 0.04 | 0.49 | 2.25 | 0.45 | 2.05 | 0.20 |
| Upscale Gas | | 11.34 | 11.23 | 0.55 | 11.30 | 0.20 | 0.35 |
| | | | | | | | |
| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO2 | | | | | | |
| Span: | 20 | | | | | | |
| Zero Gas | | 0.04 | 0.45 | 2.05 | 0.00 | 0.20 | 2.25 |
| Upscale Gas | | 11.34 | 11.30 | 0.20 | 0.00 | 56.70 | 56.50 |
| | | | | | | | |
| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO2 | | | | | | |
| Span: | 20 | | | | | | |
| Zero Gas | | 0.04 | 0.00 | 0.20 | 0.00 | 0.20 | 0.00 |
| Upscale Gas | | 11.34 | 0.00 | 56.70 | 0.00 | 56.70 | 0.00 |

DRIFT = (FINAL SYSTEM CAL. RESPONSE - INITIAL CAL. RESPONSE / SPAN) X 100

ANALYZER CALIBRATION DATA

Client **SJRPP** Project # **01-315** Test Date **12/12/01**
 Source Identification **Jacksonville, FL** **2** Operator **stiles**

| Calibration Data For Sampling Runs: 1-12 Gas Type: CO Span: 1000 | Cylinder Number | Cylinder Value % or PPM | Analyzer Response | Absolute Difference % or PPM | Difference % of Span |
|--|--------------------|-------------------------------|----------------------|------------------------------------|-------------------------|
| Zero Gas | | .0 | 1.1 | 1.10 | .11 |
| Low-Range Gas | | N/A | | | |
| Mid-Range Gas | 351 | 304.0 | 311.0 | 7.00 | .70 |
| High-Range Gas | 065 | 608.0 | 618.0 | 10.00 | 1.00 |

| Calibration Data For Sampling Runs: 1-12 Gas Type: CO2 Span: 20 | Cylinder Number | Cylinder Value % or PPM | Analyzer Response | Absolute Difference % or PPM | Difference % of Span |
|---|--------------------|-------------------------------|----------------------|------------------------------------|-------------------------|
| Zero Gas | | .00 | .08 | .08 | .40 |
| Low-Range Gas | | N/A | | | |
| Mid-Range Gas | CC99263 | 11.10 | 11.14 | .04 | .20 |
| High-Range Gas | DP010791 | 17.30 | 17.25 | .05 | .25 |

ANALYZER CALIBRATION BIAS AND DRIFT DATA

Client **SJRPP** Project # **01-315** Test Date **12/12/2001**
 Source Identification Jacksonville, FL 2 Operator **stiles**

| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
|----------------------|----|-------------------|-----------------|----------------------------|-----------------|----------------------------|-----------------|
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| 1 | CO | 1.10 | 0.70 | 0.04 | 1.20 | 0.01 | 0.05 |
| Span: 1000 | | | 311.00 | 308.00 | 0.30 | 302.00 | 0.90 |
| Zero Gas | | | | | | | |
| Upscale Gas | | | | | | | |
| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| 2 | CO | 1.10 | 1.20 | 0.01 | 0.70 | 0.04 | 0.05 |
| Span: 1000 | | | 311.00 | 302.00 | 0.90 | 307.00 | 0.40 |
| Zero Gas | | | | | | | |
| Upscale Gas | | | | | | | |
| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| 3 | CO | 1.10 | 0.70 | 0.04 | 1.00 | 0.01 | 0.03 |
| Span: 1000 | | | 311.00 | 307.00 | 0.40 | 305.00 | 0.60 |
| Zero Gas | | | | | | | |
| Upscale Gas | | | | | | | |
| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| 4 | CO | 1.10 | 1.00 | 0.01 | 2.60 | 0.15 | 0.16 |
| Span: 1000 | | | 311.00 | 305.00 | 0.60 | 308.00 | 0.30 |
| Zero Gas | | | | | | | |
| Upscale Gas | | | | | | | |

DRIFT = (FINAL SYSTEM CAL. RESPONSE - INITIAL CAL. RESPONSE / SPAN) X 100

ANALYZER CALIBRATION BIAS AND DRIFT DATA

Client **SJRPP** Project # **01-315** Test Date **12/12/2001**
 Source Identification Jacksonville, FL **2** Operator **stiles**

| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
|----------------------|------|-------------------|-----------------|----------------------------|-----------------|----------------------------|-----------------|
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO | | | | | | |
| Span: | 1000 | | | | | | |
| Zero Gas | | 1.10 | 2.60 | 0.15 | 0.60 | 0.05 | 0.20 |
| Upscale Gas | | 311.00 | 308.00 | 0.30 | 303.00 | 0.80 | 0.50 |
| | | | | | | | |
| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO | | | | | | |
| Span: | 1000 | | | | | | |
| Zero Gas | | 1.10 | 0.60 | 0.05 | 1.30 | 0.02 | 0.07 |
| Upscale Gas | | 311.00 | 303.00 | 0.80 | 304.90 | 0.61 | 0.19 |
| | | | | | | | |
| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO | | | | | | |
| Span: | 1000 | | | | | | |
| Zero Gas | | 1.10 | 1.30 | 0.02 | 2.30 | 0.12 | 0.10 |
| Upscale Gas | | 311.00 | 304.90 | 0.61 | 304.80 | 0.62 | 0.01 |
| | | | | | | | |
| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO | | | | | | |
| Span: | 1000 | | | | | | |
| Zero Gas | | 1.10 | 2.30 | 0.12 | 0.30 | 0.08 | 0.20 |
| Upscale Gas | | 311.00 | 304.80 | 0.62 | 308.00 | 0.30 | 0.32 |

DRIFT = (FINAL SYSTEM CAL. RESPONSE - INITIAL CAL. RESPONSE / SPAN) X 100

ANALYZER CALIBRATION BIAS AND DRIFT DATA

Client **SJRPP** Project # **01-315** Test Date **12/12/2001**
 Source Identification **Jacksonville, FL** 2 Operator **stiles**

| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
|----------------------|------|-------------------|-----------------|----------------------------|-----------------|----------------------------|-----------------|
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO | 1.10 | 0.30 | 0.08 | 0.00 | 0.11 | 0.03 |
| Span: | 1000 | | | | | | |
| Zero Gas | | 1.10 | 0.30 | 0.08 | 0.00 | 0.11 | 0.03 |
| Upscale Gas | | 311.00 | 308.00 | 0.30 | 303.00 | 0.80 | 0.50 |
| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO | 1.10 | 0.00 | 0.11 | 0.00 | 0.11 | 0.00 |
| Span: | 1000 | | | | | | |
| Zero Gas | | 1.10 | 0.00 | 0.11 | 0.00 | 0.11 | 0.00 |
| Upscale Gas | | 311.00 | 303.00 | 0.80 | 304.00 | 0.70 | 0.10 |
| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO | 1.10 | 0.00 | 0.11 | 0.00 | 0.11 | 0.00 |
| Span: | 1000 | | | | | | |
| Zero Gas | | 1.10 | 0.00 | 0.11 | 0.00 | 0.11 | 0.00 |
| Upscale Gas | | 311.00 | 304.00 | 0.70 | 0.00 | 31.10 | 30.40 |
| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO | 1.10 | 0.00 | 0.11 | 0.00 | 0.11 | 0.00 |
| Span: | 1000 | | | | | | |
| Zero Gas | | 1.10 | 0.00 | 0.11 | 0.00 | 0.11 | 0.00 |
| Upscale Gas | | 311.00 | 0.00 | 31.10 | 0.00 | 31.10 | 0.00 |

DRIFT = (FINAL SYSTEM CAL. RESPONSE - INITIAL CAL. RESPONSE / SPAN) X 100

ANALYZER CALIBRATION BIAS AND DRIFT DATA

Client **SJRPP** Project # **01-315** Test Date **12/12/01**
 Source Identification Jacksonville, FL **2** Operator **stiles**

| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
|----------------------|-----|-------------------|-----------------|----------------------------|-----------------|----------------------------|-----------------|
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO2 | | | | | | |
| Span: | 20 | | | | | | |
| Zero Gas | | 0.08 | 0.35 | 1.35 | 0.40 | 1.60 | 0.25 |
| Upscale Gas | | 11.14 | 11.24 | 0.50 | 11.40 | 1.30 | 0.80 |
| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO2 | | | | | | |
| Span: | 20 | | | | | | |
| Zero Gas | | 0.08 | 0.40 | 1.60 | 0.35 | 1.35 | 0.25 |
| Upscale Gas | | 11.14 | 11.40 | 1.30 | 11.40 | 1.30 | 0.00 |
| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO2 | | | | | | |
| Span: | 20 | | | | | | |
| Zero Gas | | 0.08 | 0.35 | 1.35 | 0.44 | 1.80 | 0.45 |
| Upscale Gas | | 11.14 | 11.40 | 1.30 | 11.40 | 1.30 | 0.00 |
| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO2 | | | | | | |
| Span: | 20 | | | | | | |
| Zero Gas | | 0.08 | 0.44 | 1.80 | 0.42 | 1.70 | 0.10 |
| Upscale Gas | | 11.14 | 11.40 | 1.30 | 11.40 | 1.30 | 0.00 |

DRIFT = (FINAL SYSTEM CAL. RESPONSE - INITIAL CAL. RESPONSE / SPAN) X 100

ANALYZER CALIBRATION BIAS AND DRIFT DATA

Client **SJRPP** Project # **01-315** Test Date **12/12/01**
 Source Identification **Jacksonville, FL 2** Operator **stiles**

| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
|----------------------|-----|-------------------|-----------------|----------------------------|-----------------|----------------------------|-----------------|
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| 5 | CO2 | | | | | | |
| Span: | 20 | | | | | | |
| Zero Gas | | 0.08 | 0.42 | 1.70 | 0.37 | 1.45 | 0.25 |
| Upscale Gas | | 11.14 | 11.40 | 1.30 | 11.42 | 1.40 | 0.10 |
| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| 6 | CO2 | | | | | | |
| Span: | 20 | | | | | | |
| Zero Gas | | 0.08 | 0.37 | 1.45 | 0.38 | 1.50 | 0.05 |
| Upscale Gas | | 11.14 | 11.42 | 1.40 | 11.37 | 1.15 | 0.25 |
| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| 7 | CO2 | | | | | | |
| Span: | 20 | | | | | | |
| Zero Gas | | 0.08 | 0.38 | 1.50 | 0.47 | 1.95 | 0.45 |
| Upscale Gas | | 11.14 | 11.37 | 1.15 | 11.37 | 1.15 | 0.00 |
| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| 8 | CO2 | | | | | | |
| Span: | 20 | | | | | | |
| Zero Gas | | 0.08 | 0.47 | 1.95 | 0.44 | 1.80 | 0.15 |
| Upscale Gas | | 11.14 | 11.37 | 1.15 | 11.35 | 1.05 | 0.10 |

$$\text{DRIFT} = (\text{FINAL SYSTEM CAL. RESPONSE} - \text{INITIAL CAL. RESPONSE} / \text{SPAN}) \times 100$$

ANALYZER CALIBRATION BIAS AND DRIFT DATA

Client **SJRPP** Project # **01-315** Test Date **12/12/01**
 Source Identification Jacksonville, FL **2** Operator **stiles**

| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
|----------------------|-----|-------------------|-----------------|----------------------------|-----------------|----------------------------|-----------------|
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO2 | | | | | | |
| Span: | 20 | | | | | | |
| Zero Gas | | 0.08 | 0.44 | 1.80 | 0.44 | 1.80 | 0.00 |
| Upscale Gas | | 11.14 | 11.35 | 1.05 | 11.38 | 1.20 | 0.15 |
| | | | | | | | |
| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO2 | | | | | | |
| Span: | 20 | | | | | | |
| Zero Gas | | 0.08 | 0.44 | 1.80 | 0.36 | 1.40 | 0.40 |
| Upscale Gas | | 11.14 | 11.38 | 1.20 | 11.36 | 1.10 | 0.10 |
| | | | | | | | |
| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO2 | | | | | | |
| Span: | 20 | | | | | | |
| Zero Gas | | 0.08 | 0.36 | 1.40 | 0.00 | 0.40 | 1.80 |
| Upscale Gas | | 11.14 | 11.36 | 1.10 | 0.00 | 55.70 | 56.80 |
| | | | | | | | |
| Calibration Data For | | Analyzer Response | Initial Values | | Final Values | | Drift % of Span |
| Sampling Runs: | | | System Response | System Cal. Bias % of Span | System Response | System Cal. Bias % of Span | |
| Gas Type: | CO2 | | | | | | |
| Span: | 20 | | | | | | |
| Zero Gas | | 0.08 | 0.32 | 1.20 | 0.00 | 0.40 | 1.60 |
| Upscale Gas | | 11.14 | 11.37 | 1.15 | 0.00 | 55.70 | 56.85 |

DRIFT = (FINAL SYSTEM CAL. RESPONSE - INITIAL CAL. RESPONSE / SPAN) X 100

Grace Consulting, Inc.
EPA Method 5
522 Series Meter Box Calibration
Calibration Orifice Method
English Meter Box Units, English K' Factor

8

| | |
|---------|---------|
| Date: | 10/2/01 |
| Model: | Apex |
| Serial: | 4A |

| | | |
|------------------------------|-------|---------|
| Barometric Pressure: | 29.29 | (in Hg) |
| Theoretical Critical Vacuum: | 13.82 | (in Hg) |

IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.
IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)³*(deg R)^{0.5}/((in.Hg)*(min)).

| DRY GAS METER READINGS | | | | | | | Critical Orifice Readings | | | AMBIENT TEMPERATURE | | |
|------------------------|---------------|------------------------------|----------------------------|----------------------------|----------------------------|--------------------------|---------------------------|--|-----------------------------|---------------------|------------------|--------------------|
| dH (in H2O) | Time (min) | Volume Initial (cu ft) | Volume Final (cu ft) | Volume Total (cu ft) | Temp Initial (deg F) | Temp Final (deg F) | Orifice Serial # | K' Orifice Coefficient (see above) | Actual Vacuum (in Hg) | Initial (deg F) | Final (deg F) | Average (deg F) |
| 0.61 | 11.45 | 800.50 | 805.50 | 5 | 64 | 66 | 48 | 0.3449 | 14 | 65 | 66 | 65.5 |
| 1.1 | 9.37 | 806.50 | 812.00 | 5.5 | 66 | 67 | 55 | 0.4595 | 14 | 66 | 66 | 66 |
| 1.9 | 12.98 | 812.50 | 822.50 | 10 | 69 | 72 | 63 | 0.5958 | 14 | 66 | 66 | 66 |
| 3.5 | 19.42 | 823.00 | 843.50 | 20.5 | 71 | 77 | 73 | 0.8215 | 14 | 65 | 66 | 65.5 |
| 5.4 | 15.22 | 844.00 | 864.00 | 20 | 77 | 77 | 81 | 1.0185 | 14 | 66 | 66 | 66 |

| CORRECTED VOLUME | |
|--|--------------------------------|
| DRY GAS METER Vm(std) (cu ft) | ORIFICE Vcr(std) (cu ft) |
| 4.928 | 5.046 |
| 5.412 | 5.499 |
| 9.786 | 9.876 |
| 20.009 | 20.384 |
| 19.504 | 19.797 |

| DRY GAS METER CALIBRATION FACTOR Y | |
|--|-----------|
| Value | Variation |
| 1.024 | 0.007 |
| 1.016 | -0.0006 |
| 1.009 | -0.0073 |
| 1.019 | 0.0022 |
| 1.015 | -0.0015 |

| ORIFICE CALIBRATION FACTOR dH@ | |
|--------------------------------------|-----------------------|
| Value (in H2O) | Variation (in H2O) |
| 1.767 | -0.032 |
| 1.797 | -0.002 |
| 1.846 | 0.048 |
| 1.787 | -0.011 |
| 1.795 | -0.003 |

Orifice for Calc.
3.2978

Average 1.017

Average 1.798

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/-0.02.

For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/-0.2.

SIGNED: _____

Date: _____

$$V_{m(std)} = 17.64 (V_m) \frac{P_b + \frac{\Delta H}{13.6}}{t_m + 460}$$

$$V_{cr(std)} = K' \frac{P_b \theta}{\sqrt{t_{amb} + 460}}$$

$$Y = \frac{V_{cr(std)}}{V_{m(std)}}$$

$$\Delta H_{@} = \Delta H \left(\frac{.75\theta}{V_{cr(std)}} \right)^2$$

Grace Consulting, Inc.
 EPA Method 5
 Post Test Calibration
 Calibration Orifice Method
 English Meter Box Units, English K' Factor

| | |
|---------|----------|
| Date: | 12/20/01 |
| Model: | Apex |
| Serial: | 4-a |

| | | |
|------------------------------|-------|---------|
| Barometric Pressure: | 29.25 | (in Hg) |
| Theoretical Critical Vacuum: | 13.80 | (in Hg) |

IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.
 IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)³*(deg R)^{0.5}/((in.Hg)*(min)).

| DRY GAS METER READINGS | | | | | | | Critical Orifice Readings | | | AMBIENT TEMPERATURE | | |
|-----------------------------|---------------|------------------------------|----------------------------|----------------------------|----------------------------|--------------------------|---------------------------|--|-----------------------------|---------------------|------------------|--------------------|
| dH (in H ₂ O) | Time (min) | Volume Initial (cu ft) | Volume Final (cu ft) | Volume Total (cu ft) | Temp Initial (deg F) | Temp Final (deg F) | Orifice Serial # | K' Orifice Coefficient (see above) | Actual Vacuum (in Hg) | Initial (deg F) | Final (deg F) | Average (deg F) |
| 1.8 | 13.08 | 975.1 | 985.1 | 10 | 61 | 65 | 63 | 0.5958 | 14 | 58 | 59 | 58.5 |
| 1.8 | 13.13 | 985.1 | 995.1 | 10 | 65 | 66 | 63 | 0.5958 | 14 | 59 | 59 | 59 |
| 1.8 | 13.05 | 1005.1 | 1015.1 | 10 | 67 | 67 | 63 | 0.5958 | 14 | 59 | 58 | 58.5 |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |

| CORRECTED VOLUME | |
|-------------------------------------|--------------------------------|
| DRY GAS METER Vm(std) (cu ft) | ORIFICE Vcr(std) (cu ft) |
| 9.910 | 10.011 |
| 9.863 | 10.044 |
| 9.835 | 9.988 |
| | |
| | |

| DRY GAS METER CALIBRATION FACTOR Y | |
|--|-----------|
| Value | Variation |
| 1.010 | -0.005 |
| 1.018 | 0.00368 |
| 1.016 | 0.00085 |
| | |
| | |

| ORIFICE CALIBRATION FACTOR dH@ | |
|--------------------------------------|------------------------------------|
| Value (in H ₂ O) | Variation (in H ₂ O) |
| 1.729 | -0.001 |
| 1.730 | 0.001 |
| 1.729 | -0.001 |
| | |
| | |

Average 1.015

Average 1.729

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/-0.02.

For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H₂O that equates to 0.75 cfm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/-0.2.

SIGNED: *Adrylak*

Date: 12/20/01

$$V_{m(std)} = 17.64 (V_m) \frac{P_b + \frac{\Delta H}{13.6}}{t_m + 460}$$

$$V_{\sigma(std)} = K' \frac{P_b \theta}{\sqrt{t_{amb} + 460}}$$

$$Y = \frac{V_{\sigma(std)}}{V_{m(std)}}$$

$$\Delta H_{@} = \Delta H \left(\frac{.75\theta}{V_{\sigma(std)}} \right)^2$$

For Technical Information Call
1-800-752-1597

AI
PRODUCTS

Air Products and Chemicals, Inc. * 12722 S. Wentworth Avenue, Chicago, IL 60628

ISO CERTIFICATION: 9002

CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS STANDARD

PERFORMED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS (PROCEDURE #G1)

Customer: 231 -1
APCI
5420 WARNER RD.
VALLEY VIEW
CLEVELAND

OH 44125-

Order No: 861032862-06
Batch No: 86144684
PO:
Release:

Cylinder No: SG9139334BAL
Bar Code No: DEL893
Cylinder Pressure*: 1400 psig
Certification Date: 06/17/2001
Expiration Date: 06/17/2004

| CERTIFIED CONCENTRATION | | REFERENCE STANDARDS | | | ANALYTICAL INSTRUMENTATION | | | |
|-------------------------|-------------------------|---------------------|---------------|------------------------|----------------------------|---------------|------------------|-------------------------|
| Component | Certified Concentration | Cylinder Number | Standard Type | Standard Concentration | Instrument Make/Model | Serial Number | Last Calibration | Measurement Principal |
| CARBON MONOXIDE | 304±2.5 PPM | SG9168784BAL | NTRM | 491.0 PPM | Horiba VIA-510 | 405079 | 06/01/01 | NON DISPERSIVE INFRARED |

NITROGEN Balance Gas

* STANDARD SHOULD NOT BE USED BELOW 150 PSIG

Notes: CHRONOLOGICAL DATA
CERT:2/4/98 EXP: 2/4/01
PREVIOUS: CO 305PPM


EPA PROTOCOL GAS MIXTURE : CARBON MONOXIDE IN NITROGEN
To reorder this mixture please use Mix ID: 27580

Analyst:



Abbasi Husain

Approved By:



James Laas

(16921)

351

Pub. No. 320-9702

For Technical Information Call
1-800-752-1597



Air Products and Chemicals, Inc. * 12722 S. Wentworth Avenue, Chicago, IL 60628

ISO CERTIFICATION: 9002

CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS STANDARD

PERFORMED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS (PROCEDURE #G1)

Customer:

APCI
5420 WARNER RD.
VALLEY VIEW
CLEVELAND OH 44125

Order No: SRP-226455-04
Batch No: 861-60506
PO:
Release:

Cylinder No: SG860029
Bar Code No: DXC089
Cylinder Pressure*: 2000 psig
Certification Date: 08/02/1999
Expiration Date: 08/02/2002

| CERTIFIED CONCENTRATION | | REFERENCE STANDARDS | | | ANALYTICAL INSTRUMENTATION | | | |
|-------------------------|-------------------------|---------------------|---------------|------------------------|----------------------------|---------------|------------------|-------------------------|
| Component | Certified Concentration | Cylinder Number | Standard Type | Standard Concentration | Instrument Make/Model | Serial Number | Last Calibration | Measurement Principal |
| CARBON MONOXIDE | 608 ±7.5 PPM | SG9165511BAL | GMIS | 990.2 PPM | HORIBA VIA-510 | 405079 | 07/13/99 | NON DISPERSIVE INFRARED |

NITROGEN Balance Gas

* STANDARD SHOULD NOT BE USED BELOW 150 PSIG

Analyst:

J Segbaw
JULIAN K. SEGBAW

Approved By:

J Laas
James Laas

065

(16921)

Pub. No. 320-9702

AGA**AGA Gas, Inc.****CERTIFICATE OF ANALYSIS****EPA PROTOCOL**

PERFORMED ACCORDING TO EPA-600/R-97/121, PROCEDURE G1

NOTICE: THIS CYLINDER IS NOT TO BE USED WHEN PRESSURE IS UNDER 150 psig**MANUFACTURED AND CERTIFIED AT:**

AGA Gas inc.
 Specialty & Medical Gas Division
 6421 Monclova Road
 Maumee, Ohio 43537
 419-893-7226

ANALYTICAL AND CYLINDER DATA:

| Certified Component | Concentration and Uncertainty | Date of Certification |
|---------------------|-------------------------------|-----------------------|
| Nitric Oxide | 552 ± 6 ppm | 3/13/2001 |
| Sulfur Dioxide | 161 ± 2 ppm | 3/13/2001 |
| Carbon Monoxide | 1090 ± 10 ppm | 3/13/2001 |
| Carbon Dioxide | 11.1 ± 0.1% | 3/13/2001 |

| Analyzed for Reference Use Only | Concentration | Date of Analysis |
|---------------------------------|---------------|------------------|
| NOX | 552 ppm | 3/13/2001 |

Production Number: 100032368
 Cylinder Number: CC99263
 Expiration Date: 3/13/2003

Cylinder Pressure (psi): 2000
 Balance Gas: Nitrogen
 CGA: 660

REFERENCE STANDARDS DATA (TRACEABLE TO NIST AND NMI STANDARDS):

| Reference Standard Number | Cylinder Number | Concentration and Component | Expiration Date |
|---------------------------|-----------------|-----------------------------|-----------------|
| GMIS | CC84214 | 2522 ppm Carbon Monoxide | 3/21/2002 |
| GMIS | DP009338 | 490.5 ppm Carbon Monoxide | 3/21/2002 |
| GMIS | CC59278 | 2075 ppm Nitric Oxide | 3/21/2002 |
| GMIS | CC13748 | 496.1 ppm Nitric Oxide | 3/21/2002 |
| GMIS | CC314 | 494.0 ppm Sulfur Dioxide | 3/21/2002 |
| GMIS | CC59244 | 100.7 ppm Sulfur Dioxide | 3/21/2002 |
| NTRM | CC59213 | 19.91% Carbon Dioxide | 8/1/2005 |
| NTRM | CC59178 | 6.90% Carbon Dioxide | 10/2002 |

INSTRUMENTATION DATA:

| Instrument Model | Serial Number | Date of Last Calibration | Analytical Principle |
|------------------|---------------|--------------------------|-------------------------|
| Horiba CLA-510SS | 569466055 | 3/13/2001 | Chemiluminescence |
| Horiba VIA-510 | 568279012 | 3/13/2001 | Non-Dispersive Infrared |
| Horiba VIA-510 | 568849043 | 3/13/2001 | Non-Dispersive Infrared |

Analytical Report Approved By: *Kathy Anderson*

AGA Gas, Inc.
 6421 Monclova Road
 Maumee, Ohio 43537

Telephone:
 (419) 893-7226

Fax:
 (419) 893-6411



AGA Gas, Inc.

CERTIFICATE OF ANALYSIS

EPA PROTOCOL

PERFORMED ACCORDING TO EPA-600/R-97/121, PROCEDURE G1

NOTICE: THIS CYLINDER IS NOT TO BE USED WHEN PRESSURE IS UNDER 150 psig

MANUFACTURED AND CERTIFIED AT:

AGA Gas inc.
Specialty & Medical Gas Division
6421 Monclova Road
Maumee, Ohio 43537
419-893-7226

ANALYTICAL AND CYLINDER DATA:

| Certified Component | Concentration and Uncertainty | Date of Certification |
|---------------------|-------------------------------|-----------------------|
| Nitric Oxide | 866 ± 8 ppm | 3/13/2001 |
| Sulfur Dioxide | 251 ± 3 ppm | 3/13/2001 |
| Carbon Monoxide | 1610 ± 16 ppm | 3/13/2001 |
| Carbon Dioxide | 17.3 ± 0.2% | 3/13/2001 |

| Analyzed for Reference Use Only | Concentration | Date of Analysis |
|---------------------------------|---------------|------------------|
| NOX | 869 ppm | 3/13/2001 |

Production Number: 100032367
Cylinder Number: DP010791
Expiration Date: 3/13/2003

Cylinder Pressure (psi): 2000
Balance Gas: Nitrogen
CGA: 660

REFERENCE STANDARDS DATA (TRACEABLE TO NIST AND NMI STANDARDS):

| Reference Standard Number | Cylinder Number | Concentration and Component | Expiration Date |
|---------------------------|-----------------|-----------------------------|-----------------|
| GMIS | CC84214 | 2522 ppm Carbon Monoxide | 3/21/2002 |
| GMIS | DP009338 | 490.5 ppm Carbon Monoxide | 3/21/2002 |
| GMIS | CC59278 | 2075 ppm Nitric Oxide | 3/21/2002 |
| GMIS | CC13748 | 496.1 ppm Nitric Oxide | 3/21/2002 |
| GMIS | CC314 | 494.0 ppm Sulfur Dioxide | 3/21/2002 |
| GMIS | CC59244 | 100.7 ppm Sulfur Dioxide | 3/21/2002 |
| NTRM | CC59213 | 19.91% Carbon Dioxide | 8/1/2005 |
| NTRM | CC59178 | 6.90% Carbon Dioxide | 10/2002 |

INSTRUMENTATION DATA:

| Instrument Model | Serial Number | Date of Last Calibration | Analytical Principle |
|------------------|---------------|--------------------------|-------------------------|
| Horiba CLA-510SS | 569466055 | 3/13/2001 | Chemiluminescence |
| Horiba VIA-510 | 568279012 | 3/13/2001 | Non-Dispersive Infrared |
| Horiba VIA-510 | 568849043 | 3/13/2001 | Non-Dispersive Infrared |

Analytical Report Approved By:

AGA Gas, Inc.
6421 Monclova Road
Maumee, Ohio 43537

Telephone:
(419) 893-7226

Fax:
(419) 893-6411

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • TEL: 630-953-8300 FAX: 630-953-9308

9

SINCE 1908



Member of the SGS Group (Société Générale de Surveillance)

1908-1998 90 Years Committed To Excellence

ADDRESS ALL CORRESPONDENCE TO:
P.O. BOX 752
HENDERSON, KY 42419
TEL: (502) 827-1187
FAX: (502) 826-0719

December 27, 2001

ST. JOHNS RIVER POWER PARK
11201 NEW BERLIN RD
JACKSONVILLE FL 32226Sample identification by
SJRPPUnit #: ONE
Date Collected: 12/10/01
SJRPP Lab ID #: UNIT1-121001
P.O. #2312Kind of sample Coal
reported to us

Sample taken at -----

Sample taken by -----

Date sampled December 10, 2001

Date received December 21, 2001

Analysis Report No. 63-53281

SHORT PROXIMATE ANALYSIS

| | <u>As Received</u> | <u>Dry Basis</u> | | |
|------------|--------------------|------------------|-----|-------|
| % Moisture | 10.40 | XXXXXX | | |
| % Ash | 7.54 | 8.41 | | |
| Btu/lb | 12137 | 13546 | MAF | 14790 |
| % Sulfur | 1.63 | 1.82 | | |

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING
Henderson LaboratoryMEMBER
ACIL



COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • TEL: 630-953-9300 FAX: 630-853-9306



Member of the SGS Group (Société Générale de Surveillance)

1908-1998 90 Years Committed To Excellence

ADDRESS ALL CORRESPONDENCE TO:
P.O. BOX 752
HENDERSON, KY 42419
TEL: (502) 827-1187
FAX: (502) 826-0719

December 27, 2001

ST. JOENS RIVER POWER PARK
11201 NEW BERLIN RD
JACKSONVILLE FL 32226

Sample identification by
SJRPP

Unit #: ONE
Date Collected: 12/11/01
SJRPP Lab ID #: UNIT1-121101
P.O. #2312

Kind of sample Coal
reported to us

Sample taken at -----

Sample taken by ---

Date sampled December 11, 2001

Date received December 21, 2001

Analysis Report No. 63-53282

SHORT PROXIMATE ANALYSIS

| | <u>As Received</u> | <u>Dry Basis</u> | | |
|------------|--------------------|------------------|-----|-------|
| % Moisture | 11.51 | XXXXXX | | |
| % Ash | 5.98 | 6.76 | | |
| Btu/lb | 12104 | 13678 | MAF | 14670 |
| % Sulfur | 1.50 | 1.69 | | |

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

Rafael D. Henderson
Henderson Laboratory



COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • TEL: 630-853-9300 FAX: 630-853-8306

SINCE 1908®



Member of the SGS Group (Société Générale de Surveillance)

1908-1998 90 Years Committed To Excellence

ADDRESS ALL CORRESPONDENCE TO:

P.O. BOX 752

HENDERSON, KY 42419

TEL: (502) 827-1167

FAX: (502) 826-0719

December 27, 2001

ST. JOHNS RIVER POWER PARK
11201 NEW BERLIN RD
JACKSONVILLE FL 32226Sample identification by
SJRPPUnit #: ONE
Date Collected: 12/12/01
SJRPP Lab ID #: UNIT1-121201
P.O. #2312Kind of sample Coal
reported to us

Sample taken at -----

Sample taken by -----

Date sampled December 12, 2001

Date received December 21, 2001

Analysis Report No. 63-53283

SHORT PROXIMATE ANALYSIS

| | <u>As Received</u> | <u>Dry Basis</u> | | |
|------------|--------------------|------------------|-----|-------|
| % Moisture | 10.91 | xxxxxx | | |
| % Ash | 7.11 | 7.98 | | |
| Btu/lb | 12048 | 13523 | MAF | 14696 |
| % Sulfur | 1.15 | 1.29 | | |

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.
Henderson Laboratory

MEMBER

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1918 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • TEL: 830-963-9300 FAX: 830-853-8306



SINCE 1908®



Member of the SGS Group (Société Générale de Surveillance)

1908-1998 90 Years Committed To Excellence

ADDRESS ALL CORRESPONDENCE TO:

P.O. BOX 762
HENDERSON, KY 42419
TEL: (502) 827-1187
FAX: (502) 826-0719

December 27, 2001

ST. JOHNS RIVER POWER PARK
11201 NEW BERLIN RD
JACKSONVILLE FL 32226Sample identification by
SJRPPUnit #: ONE
Date Collected: 12/13/01
SJRPP Lab ID #: UNIT1-121301
P.O. #2312Kind of sample Coal
reported to us

Sample taken at -----

Sample taken by -----

Date sampled December 13, 2001

Date received December 21, 2001

Analysis Report No. 63-53284

SHORT PROXIMATE ANALYSIS

| | <u>As Received</u> | <u>Dry Basis</u> | | |
|------------|--------------------|------------------|-----|-------|
| % Moisture | 9.89 | XXXXXX | | |
| % Ash | 5.12 | 5.68 | | |
| Btu/lb | 12514 | 13888 | MAF | 14724 |
| % Sulfur | 1.59 | 1.76 | | |

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.
Henderson LaboratoryMEMBER
ACIL

BEST AVAILABLE COPY

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • TEL: 630-953-8300 FAX: 630-953-8306

SINCE 1908®



Member of the SGS Group (Société Générale de Surveillance)

1908-1998 90 Years Committed To Excellence

ADDRESS ALL CORRESPONDENCE TO:

P.O. BOX 752
HENDERSON, KY 42419
TEL: (502) 827-1187
FAX: (502) 826-0719

December 27, 2001

ST. JOHNS RIVER POWER PARK
11201 NEW BERLIN RD
JACKSONVILLE FL 32226Sample identification by
SJRPPUnit #: TWO
Date Collected: 12/10/01
SJRPP Lab ID #: UNIT2-121001
P.O. #2312Kind of sample Coal
reported to us

Sample taken at -----

Sample taken by -----

Date sampled December 10, 2001

Date received December 21, 2001

Analysis Report No. 63-53285

SHORT PROXIMATE ANALYSIS

| | <u>As Received</u> | <u>Dry Basis</u> | | |
|------------|--------------------|------------------|-----|-------|
| % Moisture | 7.38 | xxxxx | | |
| % Ash | 13.15 | 14.20 | | |
| Btu/lb | 11902 | 12850 | MAF | 14977 |
| % Sulfur | 2.12 | 2.29 | | |

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.
Richard Henderson
Henderson LaboratoryMEMBER
ACIL


COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1818 SOUTH HIGHLAND AVE., SUITE 210-E, LOMBARD, ILLINOIS 60148 • TEL: 630-853-8300 FAX: 630-853-8305

SINCE 1888[®]

Member of the SGS Group (Société Générale de Surveillance)

1908-1998 90 Years Committed To Excellence

 ADDRESS ALL CORRESPONDENCE TO:
 P.O. BOX 752
 HENDERSON, KY 42419
 TEL: (502) 827-1187
 FAX: (502) 826-0719

December 27, 2001

 ST. JOHNS RIVER POWER PARK
 11201 NEW BERLIN RD
 JACKSONVILLE FL 32226

 Sample identification by
 SJRPP

 Unit #: TWO
 Date Collected: 12/11/01
 SJRPP Lab ID #: UNIT2-121101
 P.O. #2312

 Kind of sample Coal
 reported to us

Sample taken at -----

Sample taken by -----

Date sampled December 11, 2001


Date received December 21, 2001

Analysis Report No. 63-53286

SHORT PROXIMATE ANALYSIS

| | <u>As Received</u> | <u>Dry Basis</u> | | |
|------------|--------------------|------------------|-----|-------|
| % Moisture | 7.23 | XXXXX | | |
| % Ash | 9.32 | 10.05 | | |
| Btu/lb | 12434 | 13403 | MAF | 14901 |
| % Sulfur | 2.27 | 2.45 | | |

 Respectfully submitted,
 COMMERCIAL TESTING & ENGINEERING CO.


 Henderson Laboratory

 MEMBER
 ACIL

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • TEL: 630-853-8300 FAX: 630-853-8306



SINCE 1908



Member of the SGS Group (Société Générale de Surveillance)

1908-1998 80 Years Committed To Excellence

ADDRESS ALL CORRESPONDENCE TO:

P.O. BOX 752
HENDERSON, KY 42419
TEL: (502) 827-1187
FAX: (502) 826-0719

December 27, 2001

ST. JOHNS RIVER POWER PARK
11201 NEW BERLIN RD
JACKSONVILLE FL 32226

Sample identification by
SJRPP

Unit #: TWO
Date Collected: 12/12/01
SJRPP Lab ID #: UNIT2-121201
P.O. #2312

Kind of sample Coal
reported to us

Sample taken at -----

Sample taken by

Date sampled December 12, 2001

Data received December 21, 2001

Analysis Report No. 63-53287

SHORT PROXIMATE ANALYSIS

| | <u>As Received</u> | <u>Dry Basis</u> | | |
|------------|--------------------|------------------|-----|-------|
| % Moisture | 8.05 | XXXXX | | |
| % Ash | 7.36 | 8.00 | | |
| Btu/lb | 12605 | 13708 | MAF | 14900 |
| % Sulfur | 2.29 | 2.49 | | |

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

Henderson Laboratory



COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1918 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • TEL: 630-988-0300 FAX: 630-953-8309

SINCE 1906



Member of the SGS Group (Société Générale de Surveillance)

1806-1996 90 Years Committed To Excellence

ADDRESS ALL CORRESPONDENCE TO:
P.O. BOX 752
HENDERSON, KY 42419
TEL: (502) 827-1187
FAX: (502) 826-0719

December 27, 2001

ST. JOHNS RIVER POWER PARK
11201 NEW BERTIN RD
JACKSONVILLE FL 32226Sample identification by
SJRPPUnit #: TWO
Date Collected: 12/13/01
SJRPP Lab ID #: UNIT2-121301
P.O. #2312Kind of sample Coal
reported to us

Sample taken at -----

Sample taken by ---

Date sampled December 13, 2001

Date received December 21, 2001

Analysis Report No. 63-53288

SHORT PROXIMATE ANALYSIS

| | <u>As Received</u> | <u>Dry Basis</u> | | |
|------------|--------------------|------------------|-----|-------|
| % Moisture | 7.24 | XXXXX | | |
| % Ash | 8.87 | 9.56 | | |
| Btu/lb | 12426 | 13396 | MAF | 14812 |
| % Sulfur | 1.93 | 2.08 | | |

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.
Henderson LaboratoryMEMBER
ACIL

Run # 00102
 Enertec NTDAS®
 Average Values Report
 Generated : 12/13/01 12:01

10

Company: St. Johns River Power Park U#1
 Plant: 11201 New Berlin Road
 City/St: Jacksonville, FL 32226
 Source: Unit 1

Period Start: 12/13/01 10:56
 Period End: 12/13/01 11:17
 Validation Type: 1/1 min
 Averaging Period: 1/1 min
 Type: Rolling Avg

| Period Start | Average loutCO_C ppm | Average loutCO_MM #/M | Average loutCO2_C % | Average loutNOX_MM #/M | Average loutSO2_C ppm | Average loutSO2_MM #/M | Average 1Stk_kscfh | Average 1Unit_Load MW |
|----------------|----------------------------|-----------------------------|---------------------------|------------------------------|-----------------------------|------------------------------|-----------------------|-----------------------------|
| 12/13/01 10:56 | 97.2 | 0.108 | 11.77 | 0.421 | 165.8 | 0.421 | 101670.0 | 663.7 |
| 12/13/01 10:57 | 99.7 | 0.110 | 11.85 | 0.411 | 169.2 | 0.427 | 101694.0 | 663.1 |
| 12/13/01 10:58 | 98.5 | 0.110 | 11.74 | 0.419 | 168.8 | 0.430 | 101748.0 | 662.2 |
| 12/13/01 10:59 | 106.5 | 0.119 | 11.74 | 0.423 | 168.7 | 0.430 | 101922.0 | 661.7 |
| 12/13/01 11:00 | 125.9 | 0.140 | 11.75 | 0.424 | 168.5 | 0.429 | 101934.0 | 663.3 |
| 12/13/01 11:01 | 99.1 | 0.117 | 11.69 | 0.426 | 165.6 | 0.423 | 101934.0 | 663.4 |
| 12/13/01 11:02 | 71.3 | 0.079 | 11.69 | 0.426 | 164.4 | 0.421 | 101880.0 | 663.5 |
| 12/13/01 11:03 | 86.0 | 0.096 | 11.71 | 0.424 | 166.3 | 0.424 | 101724.0 | 665.4 |
| 12/13/01 11:04 | 76.1 | 0.084 | 11.76 | 0.416 | 164.9 | 0.418 | 101712.0 | 663.5 |
| 12/13/01 11:05 | 81.5 | 0.091 | 11.75 | 0.420 | 164.3 | 0.418 | 101700.0 | 657.4 |
| 12/13/01 11:06 | 142.2 | 0.158 | 11.80 | 0.417 | 165.3 | 0.420 | 101562.0 | 662.7 |
| 12/13/01 11:07 | 107.6 | 0.119 | 11.79 | 0.415 | 165.5 | 0.419 | 101580.0 | 665.8 |
| 12/13/01 11:08 | 51.0 | 0.057 | 11.69 | 0.428 | 164.3 | 0.420 | 101592.0 | 660.2 |
| 12/13/01 11:09 | 77.6 | 0.087 | 11.69 | 0.428 | 166.7 | 0.426 | 101580.0 | 660.8 |
| 12/13/01 11:10 | 170.9 | 0.190 | 11.78 | 0.415 | 167.9 | 0.426 | 101262.0 | 664.7 |
| 12/13/01 11:11 | 101.7 | 0.113 | 11.72 | 0.419 | 166.7 | 0.425 | 101274.0 | 660.7 |
| 12/13/01 11:12 | 84.0 | 0.094 | 11.65 | 0.426 | 165.9 | 0.426 | 101274.0 | 658.4 |
| 12/13/01 11:13 | 90.2 | 0.099 | 11.80 | 0.417 | 169.4 | 0.428 | 101376.0 | 659.6 |
| 12/13/01 11:14 | 104.0 | 0.116 | 11.75 | 0.416 | 167.6 | 0.426 | 101508.0 | 660.1 |
| 12/13/01 11:15 | 99.1 | 0.111 | 11.69 | 0.421 | 166.4 | 0.425 | 101484.0 | 662.1 |
| 12/13/01 11:16 | 80.7 | 0.090 | 11.73 | 0.425 | 166.9 | 0.424 | 101496.0 | 664.2 |
| 12/13/01 11:17 | 73.8 | 0.082 | 11.74 | 0.427 | 167.0 | 0.425 | 101580.0 | 666.5 |
| Final Average* | 96.6 | 0.108 | 11.74 | 0.421 | 166.6 | 0.424 | 101613.0 | 662.4 |
| Maximum* | 170.9 | 0.190 | 11.85 | 0.428 | 169.4 | 0.430 | 101934.0 | 666.5 |
| Minimum* | 51.0 | 0.057 | 11.65 | 0.411 | 164.3 | 0.418 | 101262.0 | 657.4 |

*Does not include Invalid Averaging Periods ("N/A")

PUN # 2 OUTLET

Enertec NTDAS®
 Average Values Report
 Generated : 12/13/01 12:01

Company: St. Johns River Power Park U#1
 Plant: 11201 New Berlin Road
 City/St: Jacksonville, FL 32226
 Source: Unit 1

Period Start: 12/13/01 11:35
 Period End: 12/13/01 11:56
 Validation Type: 1/1 min
 Averaging Period: 1/1 min
 Type: Rolling Avg

| Period Start | Average 1outCO_C ppm | Average 1outCO_MM #/M | Average 1outCO2_C % | Average 1outNOX_MM #/M | Average 1outSO2_C ppm | Average 1outSO2_MM #/M | Average 1Stk_kscfh | Average 1Unit_Load MW |
|-----------------------|----------------------------|-----------------------------|---------------------------|------------------------------|-----------------------------|------------------------------|-----------------------|-----------------------------|
| 12/13/01 11:35 | 152.6 | 0.170 | 11.73 | 0.430 | 167.2 | 0.426 | 101832.0 | 662.7 |
| 12/13/01 11:36 | 116.2 | 0.130 | 11.76 | 0.428 | 167.8 | 0.428 | 101814.0 | 664.0 |
| 12/13/01 11:37 | 124.9 | 0.139 | 11.78 | 0.423 | 168.1 | 0.426 | 101652.0 | 659.5 |
| 12/13/01 11:38 | 125.4 | 0.139 | 11.78 | 0.425 | 169.2 | 0.429 | 101646.0 | 662.4 |
| 12/13/01 11:39 | 215.0 | 0.238 | 11.81 | 0.420 | 170.6 | 0.432 | 101658.0 | 664.2 |
| 12/13/01 11:40 | 124.5 | 0.139 | 11.75 | 0.426 | 166.8 | 0.424 | 101724.0 | 660.4 |
| 12/13/01 11:41 | 204.3 | 0.227 | 11.76 | 0.427 | 166.4 | 0.423 | 101988.0 | 662.0 |
| 12/13/01 11:42 | 140.5 | 0.156 | 11.77 | 0.426 | 166.1 | 0.422 | 102000.0 | 662.8 |
| 12/13/01 11:43 | 105.5 | 0.117 | 11.75 | 0.428 | 166.9 | 0.423 | 101976.0 | 664.1 |
| 12/13/01 11:44 | 131.7 | 0.147 | 11.76 | 0.427 | 167.1 | 0.423 | 101892.0 | 664.2 |
| 12/13/01 11:45 | 145.7 | 0.161 | 11.81 | 0.422 | 168.1 | 0.425 | 101880.0 | 664.8 |
| 12/13/01 11:46 | 117.6 | 0.130 | 11.81 | 0.423 | 169.7 | 0.429 | 101880.0 | 663.0 |
| 12/13/01 11:47 | 185.0 | 0.199 | 11.85 | 0.424 | 170.1 | 0.428 | 101880.0 | 661.5 |
| 12/13/01 11:48 | 151.6 | 0.175 | 11.80 | 0.427 | 170.6 | 0.432 | 101880.0 | 663.4 |
| 12/13/01 11:49 | 250.9 | 0.278 | 11.81 | 0.421 | 168.6 | 0.427 | 101880.0 | 665.1 |
| 12/13/01 11:50 | 236.4 | 0.263 | 11.80 | 0.422 | 168.4 | 0.427 | 101904.0 | 665.7 |
| 12/13/01 11:51 | 107.5 | 0.120 | 11.77 | 0.428 | 168.5 | 0.428 | 101934.0 | 659.6 |
| 12/13/01 11:52 | 114.9 | 0.127 | 11.84 | 0.423 | 169.9 | 0.429 | 101934.0 | 658.6 |
| 12/13/01 11:53 | 125.2 | 0.138 | 11.86 | 0.421 | 170.9 | 0.431 | 101934.0 | 664.1 |
| 12/13/01 11:54 | 83.2 | 0.093 | 11.78 | 0.428 | 171.2 | 0.434 | 101592.0 | 665.5 |
| 12/13/01 11:55 | 64.2 | 0.072 | 11.73 | 0.432 | 171.0 | 0.436 | 101496.0 | 658.4 |
| 12/13/01 11:56 | 94.3 | 0.105 | 11.77 | 0.427 | 171.9 | 0.436 | 101508.0 | 659.1 |
| Final Average* | 141.7 | 0.157 | 11.79 | 0.425 | 168.9 | 0.428 | 101812.9 | 662.5 |
| Maximum* | 250.9 | 0.278 | 11.86 | 0.432 | 171.9 | 0.436 | 102000.0 | 665.7 |
| Minimum* | 64.2 | 0.072 | 11.73 | 0.420 | 166.1 | 0.422 | 101496.0 | 658.4 |

*Does not include Invalid Averaging Periods ("N/A")

PUN #3 OUTLET
 Enertec NTDHS®
 Average Values Report
 Generated : 12/13/01 12:44

Company: St. Johns River Power Park U#1
 Plant: 11201 New Berlin Road
 City/St: Jacksonville, FL 32226
 Source: Unit 1

Period Start: 12/13/01 12:11
 Period End: 12/13/01 12:32
 Validation Type: 1/1 min
 Averaging Period: 1/1 min
 Type: Rolling Avg

| Period Start | Average loutCO_C ppm | Average loutCO_MM #/M | Average loutCO2_C % | Average loutNOX_MM #/M | Average loutSO2_C ppm | Average loutSO2_MM #/M | Average lStk_kscfh | Average lUnit_Load MW |
|-----------------------|----------------------------|-----------------------------|---------------------------|------------------------------|-----------------------------|------------------------------|-----------------------|-----------------------------|
| 12/13/01 12:11 | 117.6 | 0.131 | 11.73 | 0.428 | 168.5 | 0.429 | 102036.0 | 658.1 |
| 12/13/01 12:12 | 80.4 | 0.090 | 11.71 | 0.429 | 167.2 | 0.427 | 102024.0 | 659.6 |
| 12/13/01 12:13 | 71.2 | 0.079 | 11.74 | 0.424 | 168.6 | 0.429 | 102054.0 | 661.9 |
| 12/13/01 12:14 | 149.9 | 0.165 | 11.75 | 0.423 | 167.3 | 0.426 | 101988.0 | 662.2 |
| 12/13/01 12:15 | 170.7 | 0.191 | 11.73 | 0.427 | 165.1 | 0.421 | 101988.0 | 665.3 |
| 12/13/01 12:16 | 193.3 | 0.215 | 11.74 | 0.421 | 163.8 | 0.417 | 101988.0 | 666.1 |
| 12/13/01 12:17 | 182.0 | 0.207 | 11.77 | 0.415 | 163.9 | 0.416 | 101826.0 | 660.6 |
| 12/13/01 12:18 | 135.4 | 0.149 | 11.86 | 0.413 | 166.1 | 0.419 | 101772.0 | 660.8 |
| 12/13/01 12:19 | 130.6 | 0.145 | 11.84 | 0.417 | 165.1 | 0.417 | 101760.0 | 662.2 |
| 12/13/01 12:20 | 123.2 | 0.137 | 11.74 | 0.424 | 162.4 | 0.414 | 101760.0 | 665.1 |
| 12/13/01 12:21 | 81.8 | 0.092 | 11.70 | 0.430 | 161.6 | 0.413 | 101736.0 | 664.6 |
| 12/13/01 12:22 | 149.3 | 0.167 | 11.74 | 0.427 | 162.3 | 0.413 | 101748.0 | 664.6 |
| 12/13/01 12:23 | 157.3 | 0.175 | 11.79 | 0.418 | 164.1 | 0.416 | 101724.0 | 663.4 |
| 12/13/01 12:24 | 89.9 | 0.100 | 11.81 | 0.419 | 165.5 | 0.419 | 101388.0 | 665.2 |
| 12/13/01 12:25 | 142.8 | 0.159 | 11.76 | 0.420 | 165.4 | 0.420 | 101184.0 | 660.7 |
| 12/13/01 12:26 | 209.0 | 0.232 | 11.79 | 0.415 | 166.0 | 0.421 | 101220.0 | 662.5 |
| 12/13/01 12:27 | 224.7 | 0.250 | 11.78 | 0.414 | 166.6 | 0.423 | N/A | 663.7 |
| 12/13/01 12:28 | 151.9 | 0.169 | 11.79 | 0.417 | 166.6 | 0.422 | N/A | 659.0 |
| 12/13/01 12:29 | 215.5 | 0.240 | 11.74 | 0.422 | 165.1 | 0.420 | N/A | 660.4 |
| 12/13/01 12:30 | 217.3 | 0.241 | 11.79 | 0.413 | 164.2 | 0.416 | N/A | 659.4 |
| 12/13/01 12:31 | 142.0 | 0.158 | 11.73 | 0.420 | 163.6 | 0.416 | N/A | 659.6 |
| 12/13/01 12:32 | 144.3 | 0.161 | 11.74 | 0.422 | 162.9 | 0.414 | N/A | 657.3 |
| Final Average* | 149.1 | 0.166 | 11.76 | 0.421 | 165.1 | 0.419 | 101762.3 | 661.9 |
| Maximum* | 224.7 | 0.250 | 11.86 | 0.430 | 168.6 | 0.429 | 102054.0 | 666.1 |
| Minimum* | 71.2 | 0.079 | 11.70 | 0.413 | 161.6 | 0.413 | 101184.0 | 657.3 |

*Does not include Invalid Averaging Periods ("N/A")

RUN #4 OUTLET

Enertec NTDAS®

Average Values Report

Generated : 12/13/01 13:38

Company: St. Johns River Power Park U#1
 Plant: 11201 New Berlin Road
 City/St: Jacksonville, FL 32226
 Source: Unit 1

Period Start: 12/13/01 12:49
 Period End: 12/13/01 13:10
 Validation Type: 1/1 min
 Averaging Period: 1/1 min
 Type: Rolling Avg

| Period Start | Average loutCO_C ppm | Average loutCO_MM #/M | Average loutCO2_C % | Average loutNOX_MM #/M | Average loutSO2_C ppm | Average loutSO2_MM #/M | Average 1Stk_kscfh | Average 1Unit_Load MW |
|-----------------------|----------------------------|-----------------------------|---------------------------|------------------------------|-----------------------------|------------------------------|-----------------------|-----------------------------|
| 12/13/01 12:49 | 132.6 | 0.149 | 11.70 | 0.424 | 164.2 | 0.420 | 101232.0 | 660.3 |
| 12/13/01 12:50 | 147.9 | 0.166 | 11.65 | 0.427 | 161.4 | 0.414 | 101220.0 | 660.9 |
| 12/13/01 12:51 | 179.7 | 0.200 | 11.76 | 0.417 | 162.6 | 0.413 | 101220.0 | 660.9 |
| 12/13/01 12:52 | 117.2 | 0.131 | 11.70 | 0.420 | 162.2 | 0.414 | 101760.0 | 665.2 |
| 12/13/01 12:53 | 136.9 | 0.148 | 11.76 | 0.418 | 163.9 | 0.416 | 101760.0 | 667.7 |
| 12/13/01 12:54 | 155.1 | 0.173 | 11.76 | 0.418 | 165.6 | 0.421 | 101772.0 | 664.6 |
| 12/13/01 12:55 | 158.4 | 0.167 | 11.81 | 0.412 | 168.7 | 0.427 | 101916.0 | 661.5 |
| 12/13/01 12:56 | 252.7 | 0.279 | 11.84 | 0.409 | 169.0 | 0.427 | 102090.0 | 663.8 |
| 12/13/01 12:57 | 211.4 | 0.235 | 11.79 | 0.413 | 170.0 | 0.431 | 102066.0 | 659.3 |
| 12/13/01 12:58 | 77.1 | 0.086 | 11.76 | 0.422 | 169.3 | 0.431 | 102222.0 | 658.6 |
| 12/13/01 12:59 | 90.2 | 0.100 | 11.77 | 0.418 | 168.6 | 0.428 | 102624.0 | 661.2 |
| 12/13/01 13:00 | 152.8 | 0.171 | 11.72 | 0.421 | 165.5 | 0.422 | 102636.0 | 657.6 |
| 12/13/01 13:01 | 76.1 | 0.085 | 11.67 | 0.428 | 163.2 | 0.418 | 102618.0 | 659.9 |
| 12/13/01 13:02 | 72.9 | 0.081 | 11.78 | 0.419 | 165.4 | 0.420 | 102288.0 | 662.1 |
| 12/13/01 13:03 | 155.5 | 0.169 | 11.75 | 0.414 | 163.3 | 0.416 | 102174.0 | 663.7 |
| 12/13/01 13:04 | 147.2 | 0.164 | 11.70 | 0.419 | 161.8 | 0.412 | 102132.0 | 663.5 |
| 12/13/01 13:05 | 316.8 | 0.351 | 11.83 | 0.407 | 163.6 | 0.413 | 102054.0 | 663.5 |
| 12/13/01 13:06 | 306.4 | 0.341 | 11.79 | 0.410 | 164.1 | 0.416 | 101826.0 | 665.5 |
| 12/13/01 13:07 | 215.4 | 0.244 | 11.85 | 0.405 | 164.4 | 0.414 | 101802.0 | 665.9 |
| 12/13/01 13:08 | 231.4 | 0.254 | 11.79 | 0.405 | 163.9 | 0.415 | 101790.0 | 663.3 |
| 12/13/01 13:09 | 121.2 | 0.137 | 11.75 | 0.413 | 165.0 | 0.420 | 101790.0 | 664.0 |
| 12/13/01 13:10 | 121.6 | 0.136 | 11.74 | 0.415 | 164.3 | 0.419 | 101760.0 | 668.3 |
| Final Average* | 162.6 | 0.180 | 11.76 | 0.416 | 165.0 | 0.419 | 101943.3 | 662.8 |
| Maximum* | 316.8 | 0.351 | 11.85 | 0.428 | 170.0 | 0.431 | 102636.0 | 668.3 |
| Minimum* | 72.9 | 0.081 | 11.65 | 0.405 | 161.4 | 0.412 | 101220.0 | 657.6 |

*Does not include Invalid Averaging Periods ("N/A")

PUN # 5 ATLET

Enertec NTDAS®
Average Values Report
Generated : 12/13/01 14:47

Company: St. Johns River Power Park U#1
Plant: 11201 New Berlin Road
City/St: Jacksonville, FL 32226
Source: Unit 1

Period Start: 12/13/01 13:26
Period End: 12/13/01 13:47
Validation Type: 1/1 min
Averaging Period: 1/1 min
Type: Rolling Avg

| Period Start | Average loutCO_C ppm | Average loutCO_MM #/M | Average loutCO2_C % | Average loutNOX_MM #/M | Average loutSO2_C ppm | Average loutSO2_MM #/M | Average lStk_kscfh kscfh | Average lUnit_Load MW |
|----------------|----------------------------|-----------------------------|---------------------------|------------------------------|-----------------------------|------------------------------|--------------------------------|-----------------------------|
| 12/13/01 13:26 | 153.0 | 0.170 | 11.77 | 0.414 | 163.9 | 0.416 | 101364.0 | 658.5 |
| 12/13/01 13:27 | 161.9 | 0.181 | 11.74 | 0.417 | 163.9 | 0.417 | 101352.0 | 658.1 |
| 12/13/01 13:28 | 192.6 | 0.215 | 11.71 | 0.424 | 164.0 | 0.419 | 101364.0 | 661.7 |
| 12/13/01 13:29 | 144.8 | 0.162 | 11.67 | 0.426 | 163.3 | 0.419 | 101388.0 | 667.2 |
| 12/13/01 13:30 | 112.9 | 0.127 | 11.66 | 0.427 | 160.4 | 0.411 | 101364.0 | 662.8 |
| 12/13/01 13:31 | 198.9 | 0.222 | 11.74 | 0.420 | 160.6 | 0.409 | 101394.0 | 658.3 |
| 12/13/01 13:32 | 151.3 | 0.168 | 11.81 | 0.411 | 162.0 | 0.410 | 101388.0 | 662.1 |
| 12/13/01 13:33 | 340.3 | 0.377 | 11.80 | 0.407 | 160.7 | 0.407 | 101352.0 | 662.5 |
| 12/13/01 13:34 | 190.3 | 0.213 | 11.70 | 0.419 | 160.1 | 0.409 | 101298.0 | 662.1 |
| 12/13/01 13:35 | 83.4 | 0.092 | 11.72 | 0.424 | 160.4 | 0.409 | 101256.0 | 664.9 |
| 12/13/01 13:36 | 83.1 | 0.093 | 11.73 | 0.423 | 159.9 | 0.408 | 101262.0 | 663.7 |
| 12/13/01 13:37 | 77.5 | 0.088 | 11.72 | 0.427 | 159.3 | 0.406 | 101274.0 | 659.7 |
| 12/13/01 13:38 | 125.3 | 0.137 | 11.80 | 0.418 | 160.5 | 0.406 | 101652.0 | 662.1 |
| 12/13/01 13:39 | 224.6 | 0.250 | 11.78 | 0.416 | 160.8 | 0.408 | 101772.0 | 660.4 |
| 12/13/01 13:40 | 178.6 | 0.200 | 11.70 | 0.421 | 158.0 | 0.404 | 101748.0 | 659.5 |
| 12/13/01 13:41 | 213.3 | 0.237 | 11.77 | 0.417 | 158.2 | 0.402 | 101862.0 | 661.3 |
| 12/13/01 13:42 | 153.5 | 0.171 | 11.73 | 0.420 | 156.7 | 0.399 | 101880.0 | 665.9 |
| 12/13/01 13:43 | 151.5 | 0.169 | 11.73 | 0.416 | 156.2 | 0.398 | 101880.0 | 666.4 |
| 12/13/01 13:44 | 160.1 | 0.175 | 11.76 | 0.417 | 156.4 | 0.397 | 101880.0 | 666.9 |
| 12/13/01 13:45 | 107.8 | 0.120 | 11.77 | 0.416 | 156.6 | 0.398 | 101892.0 | 667.5 |
| 12/13/01 13:46 | 123.8 | 0.138 | 11.80 | 0.414 | 155.9 | 0.396 | 101880.0 | 666.5 |
| 12/13/01 13:47 | 144.7 | 0.161 | 11.80 | 0.415 | 156.4 | 0.396 | 101880.0 | 659.5 |
| Final Average* | 157.9 | 0.176 | 11.75 | 0.419 | 159.7 | 0.407 | 101562.8 | 662.6 |
| Maximum* | 340.3 | 0.377 | 11.81 | 0.427 | 164.0 | 0.419 | 101892.0 | 667.5 |
| Minimum* | 77.5 | 0.088 | 11.66 | 0.407 | 155.9 | 0.396 | 101256.0 | 658.1 |

*Does not include Invalid Averaging Periods ("N/A")

PUN# 6 OUTLET

Enertec NTDHS®
 Average Values Report
 Generated : 12/13/01 14:47

Company: St. Johns River Power Park U#1
 Plant: 11201 New Berlin Road
 City/St: Jacksonville, FL 32226
 Source: Unit 1

Period Start: 12/13/01 14:13
 Period End: 12/13/01 14:34
 Validation Type: 1/1 min
 Averaging Period: 1/1 min
 Type: Rolling Avg

| Period Start | Average loutCO_C ppm | Average loutCO_MM #/M | Average loutCO2_C % | Average loutNOX_MM #/M | Average loutSO2_C ppm | Average loutSO2_MM #/M | Average lStk_kscfh | Average lUnit_Load MW |
|-----------------------|----------------------------|-----------------------------|---------------------------|------------------------------|-----------------------------|------------------------------|-----------------------|-----------------------------|
| 12/13/01 14:13 | 164.7 | 0.183 | 11.77 | 0.414 | 158.5 | 0.403 | 102264.0 | 662.2 |
| 12/13/01 14:14 | 164.1 | 0.182 | 11.80 | 0.408 | 159.0 | 0.403 | 102264.0 | 661.5 |
| 12/13/01 14:15 | 171.6 | 0.197 | 11.85 | 0.407 | 157.7 | 0.398 | 103506.0 | 660.2 |
| 12/13/01 14:16 | 137.9 | 0.153 | 11.84 | 0.407 | 157.4 | 0.397 | 103914.0 | 663.7 |
| 12/13/01 14:17 | 86.0 | 0.095 | 11.80 | 0.413 | 156.4 | 0.396 | 103926.0 | 661.5 |
| 12/13/01 14:18 | 59.2 | 0.066 | 11.83 | 0.414 | 156.9 | 0.396 | 105846.0 | 657.8 |
| 12/13/01 14:19 | 61.6 | 0.068 | 11.83 | 0.412 | 157.5 | 0.398 | 106506.0 | 658.7 |
| 12/13/01 14:20 | 164.1 | 0.181 | 11.85 | 0.409 | 157.1 | 0.396 | 106386.0 | 660.9 |
| 12/13/01 14:21 | 122.3 | 0.136 | 11.80 | 0.410 | 156.9 | 0.398 | 106428.0 | 664.5 |
| 12/13/01 14:22 | 79.0 | 0.088 | 11.76 | 0.416 | 157.4 | 0.400 | 106440.0 | 664.2 |
| 12/13/01 14:23 | 79.6 | 0.088 | 11.83 | 0.415 | 159.3 | 0.402 | 106416.0 | 662.5 |
| 12/13/01 14:24 | 99.4 | 0.110 | 11.81 | 0.417 | 160.0 | 0.405 | N/A | 662.8 |
| 12/13/01 14:25 | 119.1 | 0.131 | 11.88 | 0.410 | 162.9 | 0.410 | N/A | 658.3 |
| 12/13/01 14:26 | 103.8 | 0.115 | 11.86 | 0.413 | 162.4 | 0.409 | 106200.0 | 659.7 |
| 12/13/01 14:27 | 129.5 | 0.140 | 11.88 | 0.409 | 163.1 | 0.410 | 106242.0 | 662.5 |
| 12/13/01 14:28 | 97.4 | 0.108 | 11.82 | 0.412 | 162.4 | 0.411 | 106200.0 | 663.5 |
| 12/13/01 14:29 | 71.6 | 0.080 | 11.77 | 0.424 | 161.0 | 0.409 | 106200.0 | 658.2 |
| 12/13/01 14:30 | 114.4 | 0.126 | 11.85 | 0.415 | 161.1 | 0.407 | 106200.0 | 657.8 |
| 12/13/01 14:31 | 135.0 | 0.148 | 11.91 | 0.405 | 161.4 | 0.405 | 106200.0 | 659.1 |
| 12/13/01 14:32 | 126.8 | 0.140 | 11.84 | 0.412 | 160.6 | 0.405 | 106224.0 | 660.8 |
| 12/13/01 14:33 | 131.6 | 0.147 | 11.77 | 0.421 | 159.1 | 0.404 | 105630.0 | 663.0 |
| 12/13/01 14:34 | 137.8 | 0.153 | 11.81 | 0.415 | 158.7 | 0.401 | 103878.0 | 664.7 |
| Final Average* | 116.2 | 0.129 | 11.83 | 0.413 | 159.4 | 0.403 | 105343.5 | 661.3 |
| Maximum* | 171.6 | 0.197 | 11.91 | 0.424 | 163.1 | 0.411 | 106506.0 | 664.7 |
| Minimum* | 59.2 | 0.066 | 11.76 | 0.405 | 156.4 | 0.396 | 102264.0 | 657.8 |

*Does not include Invalid Averaging Periods ("N/A")

Run # 7 OUTLET

Enertec NTDANS®
Average Values Report
Generated : 12/13/01 16:19

Company: St. Johns River Power Park U#1
Plant: 11201 New Berlin Road
City/St: Jacksonville, FL 32226
Source: Unit 1

Period Start: 12/13/01 14:54
Period End: 12/13/01 15:15
Validation Type: 1/1 min
Averaging Period: 1/1 min
Type: Rolling Avg

| Period Start | Average 1outCO_C ppm | Average 1outCO_MM #/M | Average 1outCO2_C % | Average 1outNOX_MM #/M | Average 1outSO2_C ppm | Average 1outSO2_MM #/M | Average 1Stk_kscfh kscfh | Average 1Unit_Load MW |
|-----------------------|----------------------------|-----------------------------|---------------------------|------------------------------|-----------------------------|------------------------------|--------------------------------|-----------------------------|
| 12/13/01 14:54 | 89.3 | 0.098 | 11.88 | 0.386 | 162.5 | 0.409 | 101658.0 | 666.5 |
| 12/13/01 14:55 | 93.0 | 0.103 | 11.87 | 0.384 | 163.1 | 0.411 | 101568.0 | 660.9 |
| 12/13/01 14:56 | 148.3 | 0.163 | 11.91 | 0.377 | 165.5 | 0.415 | 101580.0 | 661.7 |
| 12/13/01 14:57 | 98.1 | 0.108 | 11.83 | 0.387 | 165.4 | 0.418 | 101592.0 | 663.9 |
| 12/13/01 14:58 | 70.7 | 0.079 | 11.82 | 0.392 | 165.9 | 0.419 | 101646.0 | 659.5 |
| 12/13/01 14:59 | 72.7 | 0.080 | 11.91 | 0.390 | 168.9 | 0.424 | 101700.0 | 659.6 |
| 12/13/01 15:00 | 87.1 | 0.090 | 11.91 | 0.400 | 169.1 | 0.425 | 101688.0 | 666.6 |
| 12/13/01 15:01 | 255.9 | 0.285 | 11.75 | 0.410 | 164.0 | 0.417 | 101826.0 | 660.8 |
| 12/13/01 15:02 | 544.1 | 0.610 | 11.67 | 0.395 | 163.4 | 0.418 | 101856.0 | 657.5 |
| 12/13/01 15:03 | 321.8 | 0.359 | 11.75 | 0.391 | 164.7 | 0.419 | 101868.0 | 648.9 |
| 12/13/01 15:04 | 97.0 | 0.108 | 11.71 | 0.397 | 163.8 | 0.418 | 102000.0 | 650.1 |
| 12/13/01 15:05 | 122.8 | 0.137 | 11.70 | 0.404 | 164.2 | 0.419 | 102180.0 | 662.8 |
| 12/13/01 15:06 | 439.7 | 0.492 | 11.71 | 0.398 | 164.1 | 0.419 | 102156.0 | 666.4 |
| 12/13/01 15:07 | 699.9 | 0.785 | 11.67 | 0.386 | 164.4 | 0.421 | 102168.0 | 656.2 |
| 12/13/01 15:08 | 468.7 | 0.517 | 11.87 | 0.386 | 168.7 | 0.425 | 101814.0 | 658.0 |
| 12/13/01 15:09 | 292.4 | 0.322 | 11.88 | 0.397 | 167.6 | 0.422 | 101814.0 | 664.8 |
| 12/13/01 15:10 | 182.0 | 0.204 | 11.71 | 0.414 | 161.9 | 0.413 | 101790.0 | 669.3 |
| 12/13/01 15:11 | 306.8 | 0.343 | 11.69 | 0.416 | 161.1 | 0.412 | 102000.0 | 663.4 |
| 12/13/01 15:12 | 287.9 | 0.318 | 11.86 | 0.400 | 165.0 | 0.416 | N/A | 660.9 |
| 12/13/01 15:13 | 283.7 | 0.312 | 11.90 | 0.401 | 166.5 | 0.418 | N/A | 665.5 |
| 12/13/01 15:14 | 275.8 | 0.307 | 11.78 | 0.408 | 163.8 | 0.416 | N/A | 665.0 |
| 12/13/01 15:15 | 142.2 | 0.158 | 11.78 | 0.410 | 161.9 | 0.411 | N/A | 659.5 |
| Final Average* | 244.5 | 0.272 | 11.80 | 0.397 | 164.8 | 0.418 | 101828.0 | 661.3 |
| Maximum* | 699.9 | 0.785 | 11.91 | 0.416 | 169.1 | 0.425 | 102180.0 | 669.3 |
| Minimum* | 70.7 | 0.079 | 11.67 | 0.377 | 161.1 | 0.409 | 101568.0 | 648.9 |

*Does not include Invalid Averaging Periods ("N/A")

RUN# 8 OUTLET

Enertec NTDHNS®
Average Values Report
Generated : 12/13/01 16:19

Company: St. Johns River Power Park U#1
Plant: 11201 New Berlin Road
City/St: Jacksonville, FL 32226
Source: Unit 1

Period Start: 12/13/01 15:33
Period End: 12/13/01 15:54
Validation Type: 1/1 min
Averaging Period: 1/1 min
Type: Rolling Avg

| Period Start | Average loutCO_C ppm | Average loutCO_MM #/M | Average loutCO2_C % | Average loutNOX_MM #/M | Average loutSO2_C ppm | Average loutSO2_MM #/M | Average lStk_kscfh | Average lUnit_Load MW |
|-----------------------|----------------------------|-----------------------------|---------------------------|------------------------------|-----------------------------|------------------------------|-----------------------|-----------------------------|
| 12/13/01 15:33 | 413.0 | 0.457 | 11.83 | 0.401 | 160.8 | 0.406 | 101844.0 | 660.2 |
| 12/13/01 15:34 | 307.8 | 0.342 | 11.81 | 0.408 | 160.2 | 0.405 | N/A | 662.0 |
| 12/13/01 15:35 | 326.9 | 0.364 | 11.75 | 0.412 | 159.7 | 0.406 | N/A | 662.3 |
| 12/13/01 15:36 | 196.1 | 0.218 | 11.76 | 0.417 | 160.1 | 0.407 | N/A | 666.1 |
| 12/13/01 15:37 | 238.4 | 0.264 | 11.81 | 0.412 | 160.8 | 0.407 | N/A | 666.5 |
| 12/13/01 15:38 | 230.1 | 0.256 | 11.78 | 0.413 | 161.8 | 0.411 | N/A | 663.9 |
| 12/13/01 15:39 | 264.7 | 0.293 | 11.83 | 0.410 | 162.4 | 0.410 | N/A | 662.0 |
| 12/13/01 15:40 | 223.4 | 0.246 | 11.88 | 0.405 | 161.9 | 0.407 | N/A | 664.2 |
| 12/13/01 15:41 | 201.3 | 0.223 | 11.82 | 0.405 | 160.4 | 0.405 | N/A | 658.9 |
| 12/13/01 15:42 | 180.7 | 0.201 | 11.77 | 0.407 | 159.6 | 0.405 | N/A | 661.8 |
| 12/13/01 15:43 | 201.6 | 0.224 | 11.80 | 0.409 | 160.1 | 0.405 | N/A | 661.0 |
| 12/13/01 15:44 | 219.7 | 0.244 | 11.75 | 0.411 | 159.7 | 0.406 | N/A | 658.7 |
| 12/13/01 15:45 | 136.0 | 0.151 | 11.80 | 0.412 | 159.4 | 0.404 | N/A | 661.7 |
| 12/13/01 15:46 | 234.3 | 0.259 | 11.83 | 0.408 | 160.5 | 0.406 | N/A | 663.5 |
| 12/13/01 15:47 | 175.4 | 0.195 | 11.76 | 0.415 | 159.8 | 0.406 | N/A | 660.9 |
| 12/13/01 15:48 | 87.3 | 0.097 | 11.75 | 0.419 | 158.9 | 0.405 | N/A | 660.2 |
| 12/13/01 15:49 | 123.4 | 0.137 | 11.81 | 0.413 | 159.3 | 0.403 | N/A | 664.0 |
| 12/13/01 15:50 | 164.9 | 0.183 | 11.81 | 0.412 | 157.0 | 0.397 | N/A | 665.6 |
| 12/13/01 15:51 | 177.6 | 0.201 | 11.76 | 0.414 | 156.1 | 0.397 | N/A | 660.3 |
| 12/13/01 15:52 | 261.3 | 0.291 | 11.77 | 0.412 | 158.8 | 0.403 | N/A | 658.0 |
| 12/13/01 15:53 | 231.6 | 0.255 | 11.86 | 0.408 | 160.4 | 0.404 | N/A | 662.0 |
| 12/13/01 15:54 | 107.4 | 0.120 | 11.75 | 0.417 | 161.3 | 0.410 | N/A | 665.5 |
| Final Average* | 213.8 | 0.237 | 11.80 | 0.411 | 160.0 | 0.405 | 101844.0 | 662.2 |
| Maximum* | 413.0 | 0.457 | 11.88 | 0.419 | 162.4 | 0.411 | 101844.0 | 666.5 |
| Minimum* | 87.3 | 0.097 | 11.75 | 0.401 | 156.1 | 0.397 | 101844.0 | 658.0 |

*Does not include Invalid Averaging Periods ("N/A")

RUN #9 Outlet

Enertec NTDAHS®
Average Values Report
Generated : 12/13/01 17:04

Company: St. Johns River Power Park U#1
Plant: 11201 New Berlin Road
City/St: Jacksonville, FL 32226
Source: Unit 1

Period Start: 12/13/01 16:18
Period End: 12/13/01 16:39
Validation Type: 1/1 min
Averaging Period: 1/1 min
Type: Rolling Avg

| Period Start | Average loutCO_C ppm | Average loutCO_MM #/M | Average loutCO2_C % | Average loutNOX_MM #/M | Average loutSO2_C ppm | Average loutSO2_MM #/M | Average lStk_kscfh kscfh | Average lUnit_Load MW |
|----------------|----------------------------|-----------------------------|---------------------------|------------------------------|-----------------------------|------------------------------|--------------------------------|-----------------------------|
| 12/13/01 16:18 | 126.1 | 0.140 | 11.81 | 0.414 | 161.7 | 0.409 | 102132.0 | 667.9 |
| 12/13/01 16:19 | 128.3 | 0.142 | 11.86 | 0.412 | 162.2 | 0.409 | 102144.0 | 669.1 |
| 12/13/01 16:20 | 169.4 | 0.188 | 11.78 | 0.418 | 160.0 | 0.406 | 102024.0 | 664.5 |
| 12/13/01 16:21 | 357.1 | 0.394 | 11.85 | 0.408 | 161.9 | 0.409 | 101604.0 | 663.0 |
| 12/13/01 16:22 | 387.2 | 0.426 | 11.89 | 0.408 | 165.1 | 0.415 | 101616.0 | 662.1 |
| 12/13/01 16:23 | 402.3 | 0.447 | 11.79 | 0.414 | 164.3 | 0.417 | 101640.0 | 661.3 |
| 12/13/01 16:24 | 294.3 | 0.327 | 11.77 | 0.420 | 166.5 | 0.423 | 101574.0 | 660.3 |
| 12/13/01 16:25 | 216.9 | 0.241 | 11.75 | 0.421 | 168.0 | 0.428 | 101472.0 | 657.9 |
| 12/13/01 16:26 | 87.4 | 0.098 | 11.73 | 0.429 | 168.9 | 0.430 | 101496.0 | 658.0 |
| 12/13/01 16:27 | 187.3 | 0.208 | 11.76 | 0.418 | 169.6 | 0.431 | 101328.0 | 660.7 |
| 12/13/01 16:28 | 173.8 | 0.194 | 11.69 | 0.425 | 168.6 | 0.431 | 101250.0 | 661.8 |
| 12/13/01 16:29 | 171.1 | 0.191 | 11.71 | 0.426 | 168.0 | 0.429 | 101274.0 | 660.4 |
| 12/13/01 16:30 | 177.4 | 0.198 | 11.74 | 0.416 | 165.9 | 0.422 | 101262.0 | 660.7 |
| 12/13/01 16:31 | 114.8 | 0.128 | 11.77 | 0.417 | 165.9 | 0.421 | 101256.0 | 661.9 |
| 12/13/01 16:32 | 95.0 | 0.106 | 11.75 | 0.425 | 166.0 | 0.422 | 101262.0 | 662.8 |
| 12/13/01 16:33 | 121.7 | 0.136 | 11.75 | 0.422 | 165.3 | 0.421 | 101262.0 | 659.5 |
| 12/13/01 16:34 | 157.1 | 0.174 | 11.79 | 0.420 | 165.4 | 0.420 | 101142.0 | 659.3 |
| 12/13/01 16:35 | 129.7 | 0.144 | 11.78 | 0.419 | 166.2 | 0.422 | 101154.0 | 661.9 |
| 12/13/01 16:36 | 123.8 | 0.138 | 11.75 | 0.425 | 165.3 | 0.420 | 101118.0 | 667.9 |
| 12/13/01 16:37 | 122.1 | 0.136 | 11.76 | 0.426 | 165.3 | 0.420 | 101184.0 | 667.8 |
| 12/13/01 16:38 | 244.3 | 0.271 | 11.80 | 0.417 | 165.8 | 0.420 | 101220.0 | 662.4 |
| 12/13/01 16:39 | 284.3 | 0.314 | 11.84 | 0.414 | 166.8 | 0.421 | 101220.0 | 658.4 |
| Final Average* | 194.2 | 0.216 | 11.78 | 0.419 | 165.6 | 0.420 | 101437.9 | 662.3 |
| Maximum* | 402.3 | 0.447 | 11.89 | 0.429 | 169.6 | 0.431 | 102144.0 | 669.1 |
| Minimum* | 87.4 | 0.098 | 11.69 | 0.408 | 160.0 | 0.406 | 101118.0 | 657.9 |

*Does not include Invalid Averaging Periods ("N/A")

REN #16 OUTLET

Enertec NTDHS®
Average Values Report
Generated : 12/13/01 17:39

Company: St. Johns River Power Park U#1
Plant: 11201 New Berlin Road
City/St: Jacksonville, FL 32226
Source: Unit 1

Period Start: 12/13/01 16:56
Period End: 12/13/01 17:17
Validation Type: 1/1 min
Averaging Period: 1/1 min
Type: Rolling Avg

| Period Start | Average loutCO_C ppm | Average loutCO_MM #/M | Average loutCO2_C % | Average loutNOX_MM #/M | Average loutSO2_C ppm | Average loutSO2_MM #/M | Average 1Stk kscfh | Average 1Unit Load MW |
|-----------------------|----------------------------|-----------------------------|---------------------------|------------------------------|-----------------------------|------------------------------|-----------------------|-----------------------------|
| 12/13/01 16:56 | 144.5 | 0.156 | 11.82 | 0.423 | 164.1 | 0.415 | 101580.0 | 662.2 |
| 12/13/01 16:57 | 217.9 | 0.243 | 11.76 | 0.425 | 163.5 | 0.416 | 101580.0 | 661.1 |
| 12/13/01 16:58 | 156.3 | 0.174 | 11.77 | 0.424 | 163.5 | 0.415 | 101976.0 | 658.5 |
| 12/13/01 16:59 | 144.9 | 0.161 | 11.75 | 0.427 | 162.3 | 0.413 | 102432.0 | 656.5 |
| 12/13/01 17:00 | 178.0 | 0.200 | 11.75 | 0.425 | 160.2 | 0.408 | 102444.0 | 657.3 |
| 12/13/01 17:01 | 158.8 | 0.177 | 11.74 | 0.426 | 157.8 | 0.402 | 102318.0 | 662.6 |
| 12/13/01 17:02 | 114.7 | 0.129 | 11.69 | 0.428 | 156.9 | 0.401 | 102036.0 | 663.8 |
| 12/13/01 17:03 | 115.7 | 0.129 | 11.70 | 0.429 | 156.9 | 0.401 | 102048.0 | 664.4 |
| 12/13/01 17:04 | 217.8 | 0.242 | 11.79 | 0.419 | 159.6 | 0.405 | 101922.0 | 664.2 |
| 12/13/01 17:05 | 297.6 | 0.323 | 11.88 | 0.413 | 161.2 | 0.406 | 101580.0 | 667.8 |
| 12/13/01 17:06 | 393.3 | 0.435 | 11.85 | 0.416 | 160.8 | 0.405 | 101580.0 | 667.0 |
| 12/13/01 17:07 | 339.2 | 0.375 | 11.84 | 0.418 | 161.5 | 0.408 | 101580.0 | 665.0 |
| 12/13/01 17:08 | 329.5 | 0.364 | 11.84 | 0.415 | 162.1 | 0.409 | 101568.0 | 663.0 |
| 12/13/01 17:09 | 241.3 | 0.267 | 11.83 | 0.412 | 162.3 | 0.410 | 101112.0 | 662.4 |
| 12/13/01 17:10 | 243.0 | 0.270 | 11.79 | 0.418 | 161.7 | 0.410 | 101088.0 | 658.7 |
| 12/13/01 17:11 | 237.0 | 0.263 | 11.78 | 0.419 | 160.3 | 0.407 | 101100.0 | 657.4 |
| 12/13/01 17:12 | 156.5 | 0.174 | 11.80 | 0.425 | 161.5 | 0.409 | 101262.0 | 664.0 |
| 12/13/01 17:13 | 173.6 | 0.193 | 11.77 | 0.426 | 159.9 | 0.406 | 101418.0 | 668.5 |
| 12/13/01 17:14 | 183.2 | 0.205 | 11.70 | 0.431 | 157.8 | 0.403 | 101406.0 | 663.2 |
| 12/13/01 17:15 | 172.2 | 0.192 | 11.77 | 0.425 | 157.6 | 0.400 | 101418.0 | 661.9 |
| 12/13/01 17:16 | 273.1 | 0.301 | 11.88 | 0.413 | 159.8 | 0.402 | 101448.0 | 664.3 |
| 12/13/01 17:17 | 258.5 | 0.286 | 11.81 | 0.417 | 158.4 | 0.400 | 101460.0 | 664.3 |
| Final Average* | 215.8 | 0.239 | 11.79 | 0.422 | 160.4 | 0.407 | 101652.5 | 662.6 |
| Maximum* | 393.3 | 0.435 | 11.88 | 0.431 | 164.1 | 0.416 | 102444.0 | 668.5 |
| Minimum* | 114.7 | 0.129 | 11.69 | 0.412 | 156.9 | 0.400 | 101088.0 | 656.5 |

*Does not include Invalid Averaging Periods ("N/A")

Run # 1 OUTLET
 Enertec NTDAHS®
 Average Values Report
 Generated : 12/12/01 11:00

Company: St. Johns Unit 2
 Plant: _____
 City/St: _____
 Source: Unit 2

Period Start: 12/12/01 08:52
 Period End: 12/12/01 09:13
 Validation Type: 1/1 min
 Averaging Period: 1 min
 Type: Block Avg

| Period Start | Average 2outCO_C ppm | Average 2outCO_MM #/M | Average ✓ 2outCO2_C % | Average ✓ 2outNOX_MM #/M | Average 2outSO2_C ppm | Average ✓ 2outSO2_MM #/M | Average 2Stk_kscfh | Average 2Unit_Load MW |
|-----------------------|----------------------------|-----------------------------|-----------------------------|--------------------------------|-----------------------------|--------------------------------|-----------------------|-----------------------------|
| 12/12/01 08:52 | 281.5 | 0.321 | 11.48 | 0.479 | 150.3 | 0.391 | 97506.0 | 652.4 |
| 12/12/01 08:53 | 258.4 | 0.295 | 11.49 | 0.485 | 150.2 | 0.392 | 97524.0 | 655.7 |
| 12/12/01 08:54 | 352.2 | 0.404 | 11.42 | 0.484 | 153.2 | 0.401 | 97536.0 | 651.2 |
| 12/12/01 08:55 | 361.8 | 0.411 | 11.53 | 0.479 | 154.0 | 0.399 | 97524.0 | 645.7 |
| 12/12/01 08:56 | 320.0 | 0.362 | 11.57 | 0.481 | 154.1 | 0.398 | 97704.0 | 648.8 |
| 12/12/01 08:57 | 438.4 | 0.495 | 11.57 | 0.479 | 152.5 | 0.394 | 97746.0 | 654.8 |
| 12/12/01 08:58 | 508.1 | 0.574 | 11.59 | 0.476 | 153.2 | 0.395 | 97758.0 | 656.6 |
| 12/12/01 08:59 | 628.1 | 0.704 | 11.69 | 0.470 | 155.6 | 0.398 | 97746.0 | 649.1 |
| 12/12/01 09:00 | 646.5 | 0.724 | 11.68 | 0.474 | 154.2 | 0.395 | 98376.0 | 645.8 |
| 12/12/01 09:01 | 370.4 | 0.428 | 11.57 | 0.489 | 150.3 | 0.388 | 98376.0 | 647.1 |
| 12/12/01 09:02 | 266.5 | 0.302 | 11.53 | 0.491 | 149.8 | 0.388 | 98400.0 | 653.7 |
| 12/12/01 09:03 | 357.1 | 0.400 | 11.69 | 0.474 | 151.7 | 0.388 | 98202.0 | 655.9 |
| 12/12/01 09:04 | 442.6 | 0.497 | 11.66 | 0.476 | 151.8 | 0.389 | 98034.0 | 656.2 |
| 12/12/01 09:05 | 362.5 | 0.409 | 11.60 | 0.485 | 152.3 | 0.392 | 98022.0 | 653.0 |
| 12/12/01 09:06 | 363.8 | 0.409 | 11.63 | 0.484 | 150.1 | 0.386 | 98034.0 | 650.1 |
| 12/12/01 09:07 | 377.4 | 0.425 | 11.62 | 0.482 | 150.1 | 0.386 | 98100.0 | 650.5 |
| 12/12/01 09:08 | 365.1 | 0.407 | 11.75 | 0.477 | 150.5 | 0.383 | 98124.0 | 654.5 |
| 12/12/01 09:09 | 452.3 | 0.509 | 11.65 | 0.481 | 150.5 | 0.387 | 98112.0 | 656.3 |
| 12/12/01 09:10 | 375.5 | 0.421 | 11.69 | 0.478 | 152.0 | 0.389 | 97938.0 | 654.1 |
| 12/12/01 09:11 | 365.6 | 0.410 | 11.66 | 0.481 | 154.1 | 0.395 | 97482.0 | 652.0 |
| 12/12/01 09:12 | 370.5 | 0.414 | 11.70 | 0.478 | 153.6 | 0.392 | 97494.0 | 652.1 |
| 12/12/01 09:13 | 383.1 | 0.427 | 11.64 | 0.480 | 154.1 | 0.396 | 97494.0 | 653.3 |
| Final Average* | 393.1 | 0.443 | 11.61 | 0.480 | 152.2 | 0.392 | 97874.2 | 652.2 |
| Maximum* | 646.5 | 0.724 | 11.75 | 0.491 | 155.6 | 0.401 | 98400.0 | 656.6 |
| Minimum* | 258.4 | 0.295 | 11.42 | 0.470 | 149.8 | 0.383 | 97482.0 | 645.7 |

*Does not include Invalid Averaging Periods ("N/A")

DUN #2 OUTLET
 Enertec NTDAMS®
 Average Values Report
 Generated : 12/12/01 11:01

Company: St. Johns Unit 2
 Plant:
 City/St:
 Source: Unit 2

Period Start: 12/12/01 09:30
 Period End: 12/12/01 09:51
 Validation Type: 1/1 min
 Averaging Period: 1 min
 Type: Block Avg

| Period Start | Average 2outCO_C ppm | Average 2outCO_MM #/M | Average 2outCO2_C % | Average 2outNOX_MM #/M | Average 2outSO2_C ppm | Average 2outSO2_MM #/M | Average 2Stk_kscfh kscfh | Average 2Unit_Load MW |
|-----------------------|----------------------------|-----------------------------|---------------------------|------------------------------|-----------------------------|------------------------------|--------------------------------|-----------------------------|
| 12/12/01 09:30 | 398.0 | 0.450 | 11.58 | 0.485 | 153.0 | 0.395 | 98562.0 | 657.3 |
| 12/12/01 09:31 | 490.4 | 0.549 | 11.75 | 0.476 | 155.4 | 0.396 | 98562.0 | 654.5 |
| 12/12/01 09:32 | 468.7 | 0.520 | 11.80 | 0.478 | 154.8 | 0.392 | 98592.0 | 648.5 |
| 12/12/01 09:33 | 487.9 | 0.548 | 11.69 | 0.484 | 153.4 | 0.392 | 98406.0 | 649.0 |
| 12/12/01 09:34 | 476.7 | 0.536 | 11.63 | 0.484 | 153.4 | 0.394 | 98430.0 | 650.6 |
| 12/12/01 09:35 | 433.4 | 0.487 | 11.66 | 0.486 | 154.7 | 0.397 | 98430.0 | 654.8 |
| 12/12/01 09:36 | 407.0 | 0.456 | 11.68 | 0.487 | 153.8 | 0.393 | 98406.0 | 654.1 |
| 12/12/01 09:37 | 369.4 | 0.413 | 11.70 | 0.485 | 152.3 | 0.389 | 98376.0 | 652.5 |
| 12/12/01 09:38 | 409.3 | 0.457 | 11.73 | 0.484 | 151.4 | 0.386 | 98376.0 | 650.6 |
| 12/12/01 09:39 | 495.0 | 0.553 | 11.71 | 0.482 | 151.9 | 0.388 | 98376.0 | 650.5 |
| 12/12/01 09:40 | 369.6 | 0.414 | 11.68 | 0.485 | 153.5 | 0.393 | 98298.0 | 651.6 |
| 12/12/01 09:41 | 480.6 | 0.526 | 11.72 | 0.482 | 154.5 | 0.394 | 98274.0 | 651.0 |
| 12/12/01 09:42 | 534.4 | 0.591 | 11.70 | 0.481 | 154.6 | 0.395 | 98274.0 | 648.4 |
| 12/12/01 09:43 | 397.0 | 0.446 | 11.66 | 0.485 | 153.1 | 0.392 | 98286.0 | 647.3 |
| 12/12/01 09:44 | 296.9 | 0.332 | 11.69 | 0.486 | 152.8 | 0.391 | 98076.0 | 650.4 |
| 12/12/01 09:45 | 273.0 | 0.309 | 11.58 | 0.486 | 151.7 | 0.391 | 98100.0 | 654.2 |
| 12/12/01 09:46 | 335.9 | 0.377 | 11.64 | 0.484 | 152.8 | 0.393 | 98100.0 | 652.6 |
| 12/12/01 09:47 | 487.5 | 0.542 | 11.77 | 0.484 | 154.4 | 0.392 | 98118.0 | 653.4 |
| 12/12/01 09:48 | 406.4 | 0.452 | 11.77 | 0.479 | 152.9 | 0.388 | 98268.0 | 654.5 |
| 12/12/01 09:49 | 526.7 | 0.590 | 11.69 | 0.482 | 153.4 | 0.392 | 98262.0 | 655.8 |
| 12/12/01 09:50 | 465.0 | 0.519 | 11.73 | 0.480 | 153.2 | 0.390 | 98274.0 | 654.0 |
| 12/12/01 09:51 | 383.5 | 0.427 | 11.74 | 0.479 | 152.8 | 0.389 | 98064.0 | 653.1 |
| Final Average* | 426.9 | 0.477 | 11.70 | 0.483 | 153.4 | 0.392 | 98314.1 | 652.2 |
| Maximum* | 534.4 | 0.591 | 11.80 | 0.487 | 155.4 | 0.397 | 98592.0 | 657.3 |
| Minimum* | 273.0 | 0.309 | 11.58 | 0.476 | 151.4 | 0.386 | 98064.0 | 647.3 |

*Does not include Invalid Averaging Periods ("N/A")

DUN #3 OUTLET
 Enertec NTAHS®
 Average Values Report
 Generated : 12/12/01 11:02

Company: St. Johns Unit 2
 Plant:
 City/St:
 Source: Unit 2

Period Start: 12/12/01 10:08
 Period End: 12/12/01 10:29
 Validation Type: 1/1 min
 Averaging Period: 1 min
 Type: Block Avg

| Period Start | Average 2outCO_C ppm | Average 2outCO_MM #/M | Average 2outCO2_C % | Average 2outNOX_MM #/M | Average 2outSO2_C ppm | Average 2outSO2_MM #/M | Average 2Stk_kscfh kscfh | Average 2Unit_Load MW |
|-----------------------|----------------------------|-----------------------------|---------------------------|------------------------------|-----------------------------|------------------------------|--------------------------------|-----------------------------|
| 12/12/01 10:08 | 448.3 | 0.498 | 11.66 | 0.487 | 146.7 | 0.376 | 98364.0 | 656.4 |
| 12/12/01 10:09 | 566.0 | 0.635 | 11.66 | 0.489 | 149.0 | 0.382 | 98118.0 | 655.3 |
| 12/12/01 10:10 | 450.3 | 0.504 | 11.70 | 0.489 | 150.3 | 0.384 | 98046.0 | 654.5 |
| 12/12/01 10:11 | 477.4 | 0.533 | 11.73 | 0.483 | 152.0 | 0.387 | 98022.0 | 652.1 |
| 12/12/01 10:12 | 601.8 | 0.673 | 11.71 | 0.479 | 151.4 | 0.386 | 98010.0 | 654.1 |
| 12/12/01 10:13 | 478.6 | 0.541 | 11.70 | 0.486 | 150.4 | 0.385 | 98004.0 | 653.4 |
| 12/12/01 10:14 | 412.1 | 0.465 | 11.60 | 0.490 | 150.8 | 0.389 | 98472.0 | 646.6 |
| 12/12/01 10:15 | 606.6 | 0.677 | 11.74 | 0.475 | 152.5 | 0.389 | 98514.0 | 643.8 |
| 12/12/01 10:16 | 451.8 | 0.520 | 11.61 | 0.487 | 150.9 | 0.388 | 98496.0 | 643.0 |
| 12/12/01 10:17 | 296.7 | 0.337 | 11.52 | 0.498 | 150.1 | 0.389 | 98508.0 | 646.4 |
| 12/12/01 10:18 | 360.8 | 0.406 | 11.63 | 0.493 | 150.6 | 0.387 | 98496.0 | 652.8 |
| 12/12/01 10:19 | 388.7 | 0.439 | 11.60 | 0.491 | 150.8 | 0.389 | 98508.0 | 653.8 |
| 12/12/01 10:20 | 402.9 | 0.458 | 11.61 | 0.489 | 152.5 | 0.393 | 98460.0 | 645.5 |
| 12/12/01 10:21 | 361.6 | 0.403 | 11.75 | 0.485 | 152.8 | 0.389 | 98496.0 | 642.1 |
| 12/12/01 10:22 | 359.0 | 0.408 | 11.68 | 0.482 | 152.5 | 0.390 | 98496.0 | 645.8 |
| 12/12/01 10:23 | 299.6 | 0.338 | 11.60 | 0.493 | 149.3 | 0.385 | 98460.0 | 651.5 |
| 12/12/01 10:24 | 336.0 | 0.380 | 11.55 | 0.496 | 149.3 | 0.386 | 98448.0 | 650.8 |
| 12/12/01 10:25 | 396.6 | 0.446 | 11.63 | 0.488 | 152.4 | 0.392 | 98448.0 | 648.8 |
| 12/12/01 10:26 | 383.9 | 0.431 | 11.64 | 0.488 | 153.8 | 0.395 | 98418.0 | 646.5 |
| 12/12/01 10:27 | 438.5 | 0.493 | 11.64 | 0.485 | 152.6 | 0.392 | 98418.0 | 649.0 |
| 12/12/01 10:28 | 484.5 | 0.548 | 11.57 | 0.489 | 151.3 | 0.390 | 98406.0 | 652.5 |
| 12/12/01 10:29 | 379.1 | 0.430 | 11.55 | 0.491 | 150.9 | 0.390 | 98406.0 | 651.9 |
| Final Average* | 426.4 | 0.480 | 11.64 | 0.488 | 151.0 | 0.388 | 98364.3 | 649.8 |
| Maximum* | 606.6 | 0.677 | 11.75 | 0.498 | 153.8 | 0.395 | 98514.0 | 656.4 |
| Minimum* | 296.7 | 0.337 | 11.52 | 0.475 | 146.7 | 0.376 | 98004.0 | 642.1 |

*Does not include Invalid Averaging Periods ("N/A")

PUN #4 OUTLET

Enertec NTAHS®

Average Values Report

Generated : 12/12/01 11:21

Company: St. Johns Unit 2

Period Start: 12/12/01 10:47

Plant:

Period End: 12/12/01 11:08

City/St:

Validation Type: 1/1 min

Source: Unit 2

Averaging Period: 1 min

Type: Block Avg

| Period Start | Average 2outCO_C ppm | Average 2outCO_MM #/M | Average 2outCO2_C % | Average 2outNOX_MM #/M | Average 2outSO2_C ppm | Average 2outSO2_MM #/M | Average 2Stk_kscfh kscfh | Average 2Unit_Load MW |
|-----------------------|----------------------------|-----------------------------|---------------------------|------------------------------|-----------------------------|------------------------------|--------------------------------|-----------------------------|
| 12/12/01 10:47 | 437.8 | 0.493 | 11.61 | 0.491 | 149.6 | 0.385 | 98976.0 | 651.8 |
| 12/12/01 10:48 | 465.1 | 0.524 | 11.63 | 0.488 | 149.4 | 0.384 | 98856.0 | 651.8 |
| 12/12/01 10:49 | 391.1 | 0.437 | 11.58 | 0.488 | 149.9 | 0.387 | 98814.0 | 652.3 |
| 12/12/01 10:50 | 420.3 | 0.473 | 11.64 | 0.480 | 150.7 | 0.387 | 98814.0 | 651.3 |
| 12/12/01 10:51 | 324.4 | 0.365 | 11.68 | 0.481 | 149.5 | 0.384 | 98814.0 | 653.4 |
| 12/12/01 10:52 | 385.7 | 0.423 | 11.62 | 0.483 | 149.1 | 0.383 | 98706.0 | 655.0 |
| 12/12/01 10:53 | 489.5 | 0.546 | 11.69 | 0.480 | 149.4 | 0.382 | 98376.0 | 655.6 |
| 12/12/01 10:54 | 443.1 | 0.495 | 11.75 | 0.480 | 149.9 | 0.382 | 98376.0 | 655.4 |
| 12/12/01 10:55 | 392.8 | 0.440 | 11.67 | 0.484 | 151.0 | 0.387 | 98376.0 | 652.6 |
| 12/12/01 10:56 | 308.4 | 0.342 | 11.63 | 0.485 | 151.4 | 0.389 | 98520.0 | 647.5 |
| 12/12/01 10:57 | 274.5 | 0.308 | 11.67 | 0.487 | 152.0 | 0.389 | 98496.0 | 645.0 |
| 12/12/01 10:58 | 223.3 | 0.251 | 11.63 | 0.493 | 148.9 | 0.382 | 98484.0 | 646.0 |
| 12/12/01 10:59 | 245.5 | 0.278 | 11.56 | 0.495 | 149.7 | 0.387 | 98508.0 | 647.7 |
| 12/12/01 11:00 | 405.8 | 0.458 | 11.61 | 0.482 | 149.6 | 0.385 | 98496.0 | 650.8 |
| 12/12/01 11:01 | 374.2 | 0.421 | 11.62 | 0.484 | 149.2 | 0.384 | 98508.0 | 651.4 |
| 12/12/01 11:02 | 415.0 | 0.458 | 11.65 | 0.485 | 149.6 | 0.384 | 98508.0 | 650.1 |
| 12/12/01 11:03 | 522.8 | 0.584 | 11.71 | 0.477 | 149.8 | 0.382 | 98640.0 | 649.0 |
| 12/12/01 11:04 | 638.3 | 0.715 | 11.70 | 0.475 | 151.4 | 0.387 | 98694.0 | 650.0 |
| 12/12/01 11:05 | 478.0 | 0.527 | 11.68 | 0.479 | 150.3 | 0.385 | 98682.0 | 651.3 |
| 12/12/01 11:06 | 471.0 | 0.530 | 11.64 | 0.481 | 148.2 | 0.380 | 98550.0 | 648.6 |
| 12/12/01 11:07 | 381.8 | 0.428 | 11.65 | 0.484 | 146.4 | 0.376 | 98166.0 | 644.6 |
| 12/12/01 11:08 | 390.3 | 0.439 | 11.64 | 0.482 | 147.1 | 0.378 | 98154.0 | 649.4 |
| Final Average* | 403.6 | 0.452 | 11.65 | 0.484 | 149.6 | 0.384 | 98568.8 | 650.5 |
| Maximum* | 638.3 | 0.715 | 11.75 | 0.495 | 152.0 | 0.389 | 98976.0 | 655.6 |
| Minimum* | 223.3 | 0.251 | 11.56 | 0.475 | 146.4 | 0.376 | 98154.0 | 644.6 |

*Does not include Invalid Averaging Periods ("N/A")

Run # 5 Outlet

Enertec NTDAS®
 Average Values Report
 Generated : 12/12/01 12:06

Company: St. Johns Unit 2
 Plant: _____
 City/St:
 Source: Unit 2

Period Start: 12/12/01 11:25
 Period End: 12/12/01 11:46
 Validation Type: 1/1 min
 Averaging Period: 1 min
 Type: Block Avg

| Period Start | Average 2outCO_C ppm | Average 2outCO_MM #/M | Average 2outCO2_C % | Average 2outNOX_MM #/M | Average 2outSO2_C ppm | Average 2outSO2_MM #/M | Average 2Stk_kscfh | Average 2Unit_Load MW |
|-----------------------|----------------------------|-----------------------------|---------------------------|------------------------------|-----------------------------|------------------------------|-----------------------|-----------------------------|
| 12/12/01 11:25 | 495.2 | 0.555 | 11.68 | 0.474 | 147.3 | 0.377 | 98652.0 | 655.6 |
| 12/12/01 11:26 | 561.7 | 0.632 | 11.63 | 0.474 | 148.8 | 0.382 | 98628.0 | 656.8 |
| 12/12/01 11:27 | 502.9 | 0.566 | 11.63 | 0.476 | 149.4 | 0.384 | 98550.0 | 654.6 |
| 12/12/01 11:28 | 544.9 | 0.608 | 11.73 | 0.470 | 149.5 | 0.381 | 98244.0 | 651.5 |
| 12/12/01 11:29 | 439.5 | 0.490 | 11.72 | 0.473 | 148.8 | 0.379 | 98244.0 | 650.7 |
| 12/12/01 11:30 | 303.2 | 0.341 | 11.64 | 0.487 | 146.2 | 0.375 | 98220.0 | 651.6 |
| 12/12/01 11:31 | 307.0 | 0.347 | 11.57 | 0.489 | 146.9 | 0.379 | 98046.0 | 650.9 |
| 12/12/01 11:32 | 326.4 | 0.365 | 11.70 | 0.478 | 148.3 | 0.379 | 97890.0 | 647.4 |
| 12/12/01 11:33 | 369.8 | 0.416 | 11.66 | 0.476 | 149.5 | 0.383 | 97878.0 | 646.9 |
| 12/12/01 11:34 | 404.8 | 0.457 | 11.59 | 0.481 | 149.7 | 0.386 | 97890.0 | 646.3 |
| 12/12/01 11:35 | 349.6 | 0.396 | 11.51 | 0.488 | 149.0 | 0.387 | 98124.0 | 645.3 |
| 12/12/01 11:36 | 418.4 | 0.471 | 11.60 | 0.487 | 148.1 | 0.382 | 98100.0 | 649.0 |
| 12/12/01 11:37 | 559.2 | 0.632 | 11.57 | 0.486 | 144.4 | 0.373 | 98112.0 | 649.4 |
| 12/12/01 11:38 | 457.9 | 0.520 | 11.50 | 0.488 | 143.2 | 0.372 | 98100.0 | 652.9 |
| 12/12/01 11:39 | 570.6 | 0.645 | 11.58 | 0.481 | 145.1 | 0.375 | 97758.0 | 651.2 |
| 12/12/01 11:40 | 493.0 | 0.557 | 11.59 | 0.481 | 146.9 | 0.379 | 97758.0 | 648.2 |
| 12/12/01 11:41 | 433.6 | 0.488 | 11.62 | 0.480 | 148.7 | 0.382 | 97758.0 | 652.5 |
| 12/12/01 11:42 | 376.7 | 0.428 | 11.54 | 0.483 | 147.6 | 0.382 | 97758.0 | 658.7 |
| 12/12/01 11:43 | 369.6 | 0.419 | 11.56 | 0.477 | 149.1 | 0.386 | 97758.0 | 658.3 |
| 12/12/01 11:44 | 507.6 | 0.566 | 11.75 | 0.467 | 154.2 | 0.392 | 97746.0 | 657.0 |
| 12/12/01 11:45 | 569.5 | 0.636 | 11.72 | 0.471 | 155.6 | 0.397 | 97740.0 | 655.6 |
| 12/12/01 11:46 | 466.8 | 0.525 | 11.64 | 0.477 | 153.0 | 0.393 | 97626.0 | 653.1 |
| Final Average* | 446.7 | 0.503 | 11.62 | 0.479 | 148.6 | 0.382 | 98026.4 | 652.0 |
| Maximum* | 570.6 | 0.645 | 11.75 | 0.489 | 155.6 | 0.397 | 98652.0 | 658.7 |
| Minimum* | 303.2 | 0.341 | 11.50 | 0.467 | 143.2 | 0.372 | 97626.0 | 645.3 |

*Does not include Invalid Averaging Periods ("N/A")

RUN #6 OUTLET
 Enertec NTDHSS®
 Average Values Report
 Generated : 12/12/01 14:26

Company: St. Johns Unit 2
 Plant:
 City/St:
 Source: Unit 2

Period Start: 12/12/01 12:48
 Period End: 12/12/01 13:09
 Validation Type: 1/1 min
 Averaging Period: 1 min
 Type: Block Avg

| Period Start | Average 2outCO_C ppm | Average 2outCO_MM #/M | Average 2outCO2_C % | Average 2outNOX_MM #/M | Average 2outSO2_C ppm | Average 2outSO2_MM #/M | Average 2Stk_kscfh kscfh | Average 2Unit_Load MW |
|-----------------------|----------------------------|-----------------------------|---------------------------|------------------------------|-----------------------------|------------------------------|--------------------------------|-----------------------------|
| 12/12/01 12:48 | 451.9 | 0.528 | 11.20 | 0.481 | 140.6 | 0.375 | 97848.0 | 652.3 |
| 12/12/01 12:49 | 507.3 | 0.589 | 11.28 | 0.478 | 141.3 | 0.375 | 97848.0 | 646.8 |
| 12/12/01 12:50 | 330.7 | 0.385 | 11.25 | 0.490 | 140.8 | 0.374 | 97836.0 | 642.5 |
| 12/12/01 12:51 | 260.7 | 0.303 | 11.29 | 0.494 | 139.6 | 0.370 | 97938.0 | 646.8 |
| 12/12/01 12:52 | 267.0 | 0.312 | 11.21 | 0.495 | 137.8 | 0.367 | 97932.0 | 653.0 |
| 12/12/01 12:53 | 418.4 | 0.487 | 11.24 | 0.490 | 137.3 | 0.365 | 97956.0 | 650.3 |
| 12/12/01 12:54 | 451.3 | 0.522 | 11.32 | 0.485 | 139.5 | 0.368 | 98052.0 | 647.3 |
| 12/12/01 12:55 | 487.3 | 0.561 | 11.38 | 0.475 | 145.3 | 0.382 | 98142.0 | 647.4 |
| 12/12/01 12:56 | 381.3 | 0.442 | 11.30 | 0.487 | 146.0 | 0.387 | 98136.0 | 649.2 |
| 12/12/01 12:57 | 515.4 | 0.594 | 11.36 | 0.481 | 145.4 | 0.383 | 98136.0 | 648.8 |
| 12/12/01 12:58 | 753.1 | 0.871 | 11.42 | 0.471 | 145.9 | 0.382 | 97758.0 | 646.6 |
| 12/12/01 12:59 | 578.0 | 0.668 | 11.33 | 0.474 | 145.4 | 0.383 | 97770.0 | 644.2 |
| 12/12/01 13:00 | 460.6 | 0.532 | 11.33 | 0.477 | 145.6 | 0.384 | 97746.0 | 651.5 |
| 12/12/01 13:01 | 356.4 | 0.414 | 11.25 | 0.481 | 143.4 | 0.381 | 97692.0 | 656.2 |
| 12/12/01 13:02 | 559.2 | 0.644 | 11.37 | 0.470 | 146.9 | 0.386 | 97494.0 | 656.2 |
| 12/12/01 13:03 | 873.4 | 0.994 | 11.49 | 0.465 | 150.2 | 0.391 | 97494.0 | 651.7 |
| 12/12/01 13:04 | 869.5 | 0.992 | 11.47 | 0.465 | 151.3 | 0.394 | 97482.0 | 646.5 |
| 12/12/01 13:05 | 504.3 | 0.579 | 11.39 | 0.478 | 148.7 | 0.391 | 97404.0 | 647.6 |
| 12/12/01 13:06 | 450.5 | 0.518 | 11.39 | 0.475 | 146.9 | 0.386 | 97392.0 | 647.7 |
| 12/12/01 13:07 | 550.4 | 0.629 | 11.46 | 0.467 | 146.9 | 0.383 | 97404.0 | 652.1 |
| 12/12/01 13:08 | 405.4 | 0.464 | 11.43 | 0.475 | 145.9 | 0.381 | 97518.0 | 649.6 |
| 12/12/01 13:09 | 453.2 | 0.521 | 11.38 | 0.478 | 145.9 | 0.384 | 97848.0 | 644.6 |
| Final Average* | 494.8 | 0.570 | 11.34 | 0.479 | 144.4 | 0.381 | 97764.8 | 649.0 |
| Maximum* | 873.4 | 0.994 | 11.49 | 0.495 | 151.3 | 0.394 | 98142.0 | 656.2 |
| Minimum* | 260.7 | 0.303 | 11.20 | 0.465 | 137.3 | 0.365 | 97392.0 | 642.5 |

*Does not include Invalid Averaging Periods ("N/A")

PUN #7 OUTLET

Enertec NTDH5®
 Average Values Report
 Generated : 12/12/01 14:27

Company: St. Johns Unit 2
 Plant:
 City/St:
 Source: Unit 2

Period Start: 12/12/01 13:22
 Period End: 12/12/01 13:43
 Validation Type: 1/1 min
 Averaging Period: 1 min
 Type: Block Avg

| Period Start | Average 2outCO_C ppm | Average 2outCO_MM #/M | Average 2outCO2_C % | Average 2outNOX_MM #/M | Average 2outSO2_C ppm | Average 2outSO2_MM #/M | Average 2Stk_kscfh kscfh | Average 2Unit_Load MW |
|----------------|----------------------------|-----------------------------|---------------------------|------------------------------|-----------------------------|------------------------------|--------------------------------|-----------------------------|
| 12/12/01 13:22 | 440.4 | 0.507 | 11.36 | 0.475 | 145.1 | 0.382 | 98340.0 | 650.9 |
| 12/12/01 13:23 | 441.6 | 0.505 | 11.43 | 0.473 | 145.7 | 0.381 | 98298.0 | 649.6 |
| 12/12/01 13:24 | 607.7 | 0.695 | 11.44 | 0.470 | 146.1 | 0.382 | 98298.0 | 647.2 |
| 12/12/01 13:25 | 612.4 | 0.695 | 11.52 | 0.466 | 148.2 | 0.384 | 98298.0 | 644.4 |
| 12/12/01 13:26 | 474.8 | 0.545 | 11.40 | 0.475 | 147.8 | 0.387 | 98076.0 | 646.7 |
| 12/12/01 13:27 | 334.7 | 0.385 | 11.39 | 0.478 | 146.3 | 0.384 | 97992.0 | 650.7 |
| 12/12/01 13:28 | 294.1 | 0.338 | 11.40 | 0.476 | 146.4 | 0.384 | 97992.0 | 653.0 |
| 12/12/01 13:29 | 364.6 | 0.417 | 11.46 | 0.471 | 147.2 | 0.384 | 97980.0 | 652.1 |
| 12/12/01 13:30 | 401.1 | 0.458 | 11.48 | 0.467 | 147.4 | 0.384 | 97536.0 | 654.2 |
| 12/12/01 13:31 | 359.3 | 0.412 | 11.41 | 0.473 | 146.4 | 0.383 | 97536.0 | 656.3 |
| 12/12/01 13:32 | 377.0 | 0.428 | 11.54 | 0.465 | 148.9 | 0.385 | 97524.0 | 654.5 |
| 12/12/01 13:33 | 386.7 | 0.437 | 11.58 | 0.462 | 149.8 | 0.387 | 97524.0 | 652.1 |
| 12/12/01 13:34 | 531.3 | 0.603 | 11.53 | 0.461 | 150.8 | 0.390 | 97716.0 | 651.2 |
| 12/12/01 13:35 | 354.0 | 0.406 | 11.40 | 0.471 | 149.0 | 0.391 | 97716.0 | 651.9 |
| 12/12/01 13:36 | 299.1 | 0.343 | 11.42 | 0.475 | 147.6 | 0.386 | 97728.0 | 652.2 |
| 12/12/01 13:37 | 305.2 | 0.345 | 11.55 | 0.467 | 148.4 | 0.384 | 97494.0 | 648.1 |
| 12/12/01 13:38 | 353.7 | 0.399 | 11.55 | 0.469 | 147.4 | 0.382 | 97494.0 | 643.8 |
| 12/12/01 13:39 | 309.9 | 0.354 | 11.47 | 0.475 | 145.1 | 0.378 | 97494.0 | 643.8 |
| 12/12/01 13:40 | 263.0 | 0.302 | 11.41 | 0.479 | 146.1 | 0.382 | 97506.0 | 640.4 |
| 12/12/01 13:41 | 292.2 | 0.331 | 11.54 | 0.471 | 149.1 | 0.386 | 98208.0 | 641.9 |
| 12/12/01 13:42 | 263.5 | 0.301 | 11.45 | 0.476 | 147.0 | 0.384 | 98184.0 | 648.0 |
| 12/12/01 13:43 | 279.3 | 0.321 | 11.40 | 0.479 | 145.5 | 0.381 | 98196.0 | 657.4 |
| Final Average* | 379.3 | 0.433 | 11.46 | 0.472 | 147.3 | 0.384 | 97869.6 | 649.6 |
| Maximum* | 612.4 | 0.695 | 11.58 | 0.479 | 150.8 | 0.391 | 98340.0 | 657.4 |
| Minimum* | 263.0 | 0.301 | 11.36 | 0.461 | 145.1 | 0.378 | 97494.0 | 640.4 |

*Does not include Invalid Averaging Periods ("N/A")

Run #8 OUTLET

Enertec NTDAHS®
 Average Values Report
 Generated : 12/12/01 14:29

Company: St. Johns Unit 2
 Plant: _____
 City/St:
 Source: Unit 2

Period Start: 12/12/01 13:56
 Period End: 12/12/01 14:17
 Validation Type: 1/1 min
 Averaging Period: 1 min
 Type: Block Avg

| Period Start | Average 2outCO_C ppm | Average 2outCO_MM #/M | Average 2outCO2_C % | Average 2outNOX_MM #/M | Average 2outSO2_C ppm | Average 2outSO2_MM #/M | Average 2Stk_kscfh kscfh | Average 2Unit_Load MW |
|-----------------------|----------------------------|-----------------------------|---------------------------|------------------------------|-----------------------------|------------------------------|--------------------------------|-----------------------------|
| 12/12/01 13:56 | 338.8 | 0.385 | 11.51 | 0.478 | 149.4 | 0.388 | 98178.0 | 648.4 |
| 12/12/01 13:57 | 264.0 | 0.301 | 11.49 | 0.481 | 147.9 | 0.385 | 98112.0 | 649.6 |
| 12/12/01 13:58 | 421.3 | 0.476 | 11.57 | 0.471 | 148.3 | 0.383 | 98124.0 | 649.9 |
| 12/12/01 13:59 | 479.0 | 0.542 | 11.60 | 0.470 | 149.3 | 0.385 | 98376.0 | 649.4 |
| 12/12/01 14:00 | 399.2 | 0.454 | 11.52 | 0.472 | 148.2 | 0.384 | 98484.0 | 652.3 |
| 12/12/01 14:01 | 396.6 | 0.448 | 11.59 | 0.470 | 149.8 | 0.386 | 98460.0 | 654.4 |
| 12/12/01 14:02 | 452.8 | 0.510 | 11.63 | 0.468 | 150.6 | 0.388 | 98472.0 | 655.5 |
| 12/12/01 14:03 | 505.3 | 0.568 | 11.64 | 0.466 | 150.9 | 0.387 | 98076.0 | 652.4 |
| 12/12/01 14:04 | 632.1 | 0.710 | 11.66 | 0.461 | 151.9 | 0.389 | 97656.0 | 648.3 |
| 12/12/01 14:05 | 542.4 | 0.607 | 11.70 | 0.461 | 152.2 | 0.389 | 97668.0 | 649.5 |
| 12/12/01 14:06 | 318.5 | 0.362 | 11.51 | 0.476 | 150.2 | 0.390 | 97662.0 | 656.2 |
| 12/12/01 14:07 | 331.0 | 0.375 | 11.57 | 0.472 | 148.9 | 0.385 | 97638.0 | 657.3 |
| 12/12/01 14:08 | 492.5 | 0.552 | 11.63 | 0.469 | 148.9 | 0.382 | 97638.0 | 654.5 |
| 12/12/01 14:09 | 567.4 | 0.628 | 11.81 | 0.465 | 150.3 | 0.381 | 97638.0 | 646.9 |
| 12/12/01 14:10 | 364.0 | 0.410 | 11.61 | 0.482 | 149.9 | 0.386 | 97626.0 | 648.5 |
| 12/12/01 14:11 | 263.4 | 0.299 | 11.51 | 0.484 | 149.9 | 0.389 | 97362.0 | 654.6 |
| 12/12/01 14:12 | 251.8 | 0.287 | 11.49 | 0.480 | 149.9 | 0.390 | 97284.0 | 651.9 |
| 12/12/01 14:13 | 315.4 | 0.354 | 11.66 | 0.474 | 152.8 | 0.391 | 97284.0 | 648.8 |
| 12/12/01 14:14 | 468.0 | 0.523 | 11.73 | 0.467 | 154.3 | 0.393 | 97812.0 | 650.9 |
| 12/12/01 14:15 | 330.5 | 0.375 | 11.53 | 0.478 | 151.8 | 0.394 | N/A | 653.5 |
| 12/12/01 14:16 | 302.8 | 0.342 | 11.59 | 0.476 | 152.9 | 0.394 | N/A | 650.5 |
| 12/12/01 14:17 | 570.9 | 0.618 | 11.78 | 0.464 | 155.1 | 0.393 | N/A | 645.1 |
| Final Average* | 409.4 | 0.460 | 11.61 | 0.472 | 150.6 | 0.388 | 97871.1 | 651.3 |
| Maximum* | 632.1 | 0.710 | 11.81 | 0.484 | 155.1 | 0.394 | 98484.0 | 657.3 |
| Minimum* | 251.8 | 0.287 | 11.49 | 0.461 | 147.9 | 0.381 | 97284.0 | 645.1 |

*Does not include Invalid Averaging Periods ("N/A")

RUN # 9 OUTLET
 Enertec NTDAHS®
 Average Values Report
 Generated : 12/12/01 14:54

Company: St. Johns Unit 2
 Plant: _____
 City/St:
 Source: Unit 2

Period Start: 12/12/01 14:31
 Period End: 12/12/01 14:52
 Validation Type: 1/1 min
 Averaging Period: 1 min
 Type: Block Avg

| Period Start | Average 2outCO_C ppm | Average 2outCO_MM #/M | Average 2outCO2_C % | Average 2outNOX_MM #/M | Average 2outSO2_C ppm | Average 2outSO2_MM #/M | Average 2Stk_kscfh kscfh | Average 2Unit_Load MW |
|-----------------------|----------------------------|-----------------------------|---------------------------|------------------------------|-----------------------------|------------------------------|--------------------------------|-----------------------------|
| 12/12/01 14:31 | 538.1 | 0.602 | 11.70 | 0.465 | 153.3 | 0.392 | 98598.0 | 657.3 |
| 12/12/01 14:32 | 478.6 | 0.537 | 11.66 | 0.470 | 153.3 | 0.393 | 98574.0 | 657.0 |
| 12/12/01 14:33 | 466.3 | 0.522 | 11.69 | 0.471 | 154.2 | 0.394 | 98514.0 | 655.8 |
| 12/12/01 14:34 | 377.5 | 0.425 | 11.63 | 0.474 | 153.9 | 0.396 | 98448.0 | 652.2 |
| 12/12/01 14:35 | 326.3 | 0.368 | 11.62 | 0.476 | 154.1 | 0.396 | 98460.0 | 646.1 |
| 12/12/01 14:36 | 251.2 | 0.283 | 11.61 | 0.481 | 152.7 | 0.393 | 98460.0 | 648.5 |
| 12/12/01 14:37 | 290.2 | 0.329 | 11.55 | 0.480 | 151.4 | 0.392 | 97956.0 | 652.2 |
| 12/12/01 14:38 | 366.0 | 0.412 | 11.62 | 0.476 | 150.4 | 0.387 | 97800.0 | 651.9 |
| 12/12/01 14:39 | 330.4 | 0.372 | 11.63 | 0.477 | 150.6 | 0.387 | 97800.0 | 644.3 |
| 12/12/01 14:40 | 360.7 | 0.406 | 11.64 | 0.476 | 152.1 | 0.390 | 97878.0 | 645.0 |
| 12/12/01 14:41 | 300.9 | 0.346 | 11.61 | 0.480 | 152.1 | 0.392 | 97932.0 | 652.1 |
| 12/12/01 14:42 | 242.4 | 0.274 | 11.57 | 0.480 | 151.9 | 0.393 | 97920.0 | 652.7 |
| 12/12/01 14:43 | 311.1 | 0.350 | 11.62 | 0.480 | 153.1 | 0.394 | 97920.0 | 646.6 |
| 12/12/01 14:44 | 424.5 | 0.473 | 11.75 | 0.470 | 154.7 | 0.393 | 97770.0 | 641.7 |
| 12/12/01 14:45 | 226.0 | 0.255 | 11.59 | 0.481 | 153.9 | 0.397 | 97638.0 | 643.2 |
| 12/12/01 14:46 | 185.9 | 0.212 | 11.48 | 0.491 | 152.3 | 0.397 | 97644.0 | 650.4 |
| 12/12/01 14:47 | 274.9 | 0.310 | 11.62 | 0.483 | 154.0 | 0.396 | 97650.0 | 655.1 |
| 12/12/01 14:48 | 359.6 | 0.405 | 11.64 | 0.475 | 154.7 | 0.397 | 98244.0 | 650.2 |
| 12/12/01 14:49 | 307.9 | 0.345 | 11.69 | 0.474 | 155.4 | 0.398 | 98460.0 | 649.1 |
| 12/12/01 14:50 | 251.8 | 0.286 | 11.67 | 0.478 | 155.6 | 0.399 | 98460.0 | 653.4 |
| 12/12/01 14:51 | 224.6 | 0.254 | 11.58 | 0.483 | 153.9 | 0.398 | 98460.0 | 655.9 |
| 12/12/01 14:52 | 407.5 | 0.455 | 11.72 | 0.473 | 155.8 | 0.397 | 97890.0 | 654.4 |
| Final Average* | 331.9 | 0.374 | 11.63 | 0.477 | 153.3 | 0.394 | 98112.6 | 650.7 |
| Maximum* | 538.1 | 0.602 | 11.75 | 0.491 | 155.8 | 0.399 | 98598.0 | 657.3 |
| Minimum* | 185.9 | 0.212 | 11.48 | 0.465 | 150.4 | 0.387 | 97638.0 | 641.7 |

*Does not include Invalid Averaging Periods ("N/A")

PON #10 OUTLET

Enertec NTDAS®
Average Values Report
Generated : 12/12/01 15:56

Company: St. Johns Unit 2
Plant:
City/St:
Source: Unit 2

Period Start: 12/12/01 15:09
Period End: 12/12/01 15:30
Validation Type: 1/1 min
Averaging Period: 1 min
Type: Block Avg

| Period Start | Average 2outCO_C ppm | Average 2outCO_MM #/M | Average 2outCO2_C % | Average 2outNOX_MM #/M | Average 2outsO2_C ppm | Average 2outSO2_MM #/M | Average 2Stk_kscfh kscfh | Average 2Unit_Load MW |
|-----------------------|----------------------------|-----------------------------|---------------------------|------------------------------|-----------------------------|------------------------------|--------------------------------|-----------------------------|
| 12/12/01 15:09 | 297.9 | 0.336 | 11.61 | 0.490 | 150.1 | 0.386 | 99006.0 | 650.7 |
| 12/12/01 15:10 | 406.1 | 0.458 | 11.60 | 0.486 | 151.1 | 0.389 | 98772.0 | 653.3 |
| 12/12/01 15:11 | 404.1 | 0.456 | 11.60 | 0.483 | 151.4 | 0.390 | 98772.0 | 654.2 |
| 12/12/01 15:12 | 493.4 | 0.556 | 11.61 | 0.476 | 153.1 | 0.394 | 98784.0 | 653.8 |
| 12/12/01 15:13 | 558.3 | 0.628 | 11.63 | 0.478 | 153.3 | 0.394 | 98484.0 | 650.9 |
| 12/12/01 15:14 | 598.8 | 0.668 | 11.73 | 0.475 | 153.7 | 0.392 | 98184.0 | 651.0 |
| 12/12/01 15:15 | 384.9 | 0.432 | 11.66 | 0.480 | 151.2 | 0.387 | 98196.0 | 649.5 |
| 12/12/01 15:16 | 341.7 | 0.385 | 11.62 | 0.483 | 150.6 | 0.387 | 98196.0 | 650.7 |
| 12/12/01 15:17 | 419.2 | 0.469 | 11.71 | 0.483 | 150.4 | 0.384 | 98196.0 | 650.9 |
| 12/12/01 15:18 | 401.7 | 0.450 | 11.68 | 0.482 | 150.1 | 0.384 | 98184.0 | 650.4 |
| 12/12/01 15:19 | 430.5 | 0.480 | 11.74 | 0.475 | 152.1 | 0.387 | 98196.0 | 651.5 |
| 12/12/01 15:20 | 454.0 | 0.510 | 11.66 | 0.475 | 152.3 | 0.391 | 98184.0 | 654.3 |
| 12/12/01 15:21 | 319.1 | 0.361 | 11.67 | 0.483 | 151.2 | 0.387 | 98178.0 | 654.2 |
| 12/12/01 15:22 | 294.1 | 0.330 | 11.69 | 0.488 | 152.3 | 0.389 | 98232.0 | 656.6 |
| 12/12/01 15:23 | 414.0 | 0.461 | 11.76 | 0.486 | 153.8 | 0.391 | 98298.0 | 656.3 |
| 12/12/01 15:24 | 574.7 | 0.641 | 11.73 | 0.477 | 156.8 | 0.399 | 98316.0 | 654.5 |
| 12/12/01 15:25 | 464.3 | 0.516 | 11.78 | 0.469 | 156.6 | 0.398 | 98286.0 | 649.2 |
| 12/12/01 15:26 | 335.1 | 0.373 | 11.77 | 0.478 | 155.8 | 0.397 | 98316.0 | 647.7 |
| 12/12/01 15:27 | 224.4 | 0.253 | 11.63 | 0.489 | 153.4 | 0.394 | 98298.0 | 647.5 |
| 12/12/01 15:28 | 245.9 | 0.276 | 11.64 | 0.492 | 154.1 | 0.396 | 98304.0 | 647.6 |
| 12/12/01 15:29 | 358.6 | 0.402 | 11.69 | 0.486 | 155.1 | 0.397 | 98376.0 | 647.9 |
| 12/12/01 15:30 | 362.0 | 0.405 | 11.70 | 0.484 | 155.0 | 0.396 | 98388.0 | 646.0 |
| Final Average* | 399.2 | 0.448 | 11.68 | 0.482 | 152.9 | 0.391 | 98370.3 | 651.3 |
| Maximum* | 598.8 | 0.668 | 11.78 | 0.492 | 156.8 | 0.399 | 99006.0 | 656.6 |
| Minimum* | 224.4 | 0.253 | 11.60 | 0.469 | 150.1 | 0.384 | 98178.0 | 646.0 |

*Does not include Invalid Averaging Periods ("N/A")

**ST. JOHNS RIVER POWER PARK
BOILER CONTROL ROOM DATA**

UNIT # 1

DATE: 12-13-01

| PARAMETER | UNITS | Readings (30 minute intervals) | | | | | |
|------------------------|-------------------------|--------------------------------|-------|-------|-------|-------|-------|
| | | | | | | | |
| Person Recording Data | | DB | DB | DB | DB | DB | DB |
| Time | | 08:00 | 08:30 | 09:00 | 09:30 | 10:00 | 10:30 |
| Steam Flow | Lb/Hr x 10 ⁶ | 4.55 | 4.51 | 4.52 | 4.53 | 4.54 | 4.54 |
| Air Flow | % | 65 | 67 | 67 | 68 | 69 | 69 |
| Generator Load (Gross) | Megawatts | 668 | 662 | 664 | 669 | 660 | 669 |
| Boiler Thermal Demand | Megawatts | 674 | 674 | 674 | 674 | 674 | 674 |
| O2 Flue gas | % | 2.4 | 3.0 | 3.1 | 3.3 | 3.4 | 3.3 |
| Fuel Flow | % | 96.2 | 96.2 | 96.2 | 96.4 | 95.4 | 95.7 |
| Coal Totalizer | Tons | | | | | | |
| A | — | 78850 | 78868 | 78886 | 78912 | 78930 | 78950 |
| B | — | 78178 | 78196 | 78203 | 78240 | 78258 | 78276 |
| C | — | 79486 | 79504 | 79522 | 79548 | 79566 | 79586 |
| D | — | 12065 | 12065 | 12065 | 12065 | 12065 | 12065 |
| E | — | 92742 | 92760 | 92778 | 92804 | 92822 | 92842 |
| F | — | 78354 | 78370 | 78386 | 78414 | 78432 | 78452 |
| G | — | 93024 | 93042 | 93058 | 93086 | 93104 | 93122 |

**ST. JOHNS RIVER POWER PARK
BOILER CONTROL ROOM DATA**

UNIT # /

DATE: 12-13-01

| PARAMETER | UNITS | Readings (30 minute intervals) | | | | | |
|------------------------|-------------------------|--------------------------------|-------|-------|-------|-------|-------|
| | | DB | DB | DB | DB | DB | DB |
| Person Recording Data | | DB | DB | DB | DB | DB | DB |
| Time | | 11:00 | 11:30 | 12:00 | 12:30 | 13:00 | 13:30 |
| Steam Flow | Lb/Hr x 10 ⁶ | 4.56 | 4.55 | 4.53 | 4.52 | 4.54 | 4.54 |
| Air Flow | % | 69 | 69 | 70 | 69 | 69 | 69 |
| Generator Load (Gross) | Megawatts | 663 | 664 | 663 | 658 | 663 | 668 |
| Boiler Thermal Demand | Megawatts | 674 | 674 | 674 | 674 | 674 | 674 |
| O2 Flue gas | % | 3.5 | 3.6 | 3.7 | 3.7 | 3.5 | 3.6 |
| Fuel Flow | % | 95.5 | 95 | 95.8 | 96.8 | 96.2 | 96.8 |
| Coal Totalizer | Tons | | | | | | |
| A | — | 78970 | 78988 | 79012 | 79030 | 79050 | 79068 |
| B | — | 78296 | 78316 | 78340 | 78356 | 78376 | 78396 |
| C | — | 79606 | 79626 | 79648 | 79666 | 79686 | 79704 |
| D | — | 12065 | 12065 | 12065 | 12065 | 12065 | 12065 |
| E | — | 92862 | 92880 | 92904 | 92922 | 92942 | 92962 |
| F | — | 78472 | 78492 | 78514 | 78532 | 78552 | 78570 |
| G | — | 93142 | 93162 | 93186 | 93204 | 93224 | 93242 |

**ST. JOHNS RIVER POWER PARK
BOILER CONTROL ROOM DATA**

UNIT # 1

DATE: 12-13-01

| PARAMETER | UNITS | Readings (30 minute intervals) | | | | | |
|------------------------|-------------------------|--------------------------------|-------|-------|-------|-------|-------|
| | | | | | | | |
| Person Recording Data | | DB | DB | DB | DB | DB | DB |
| Time | | 14:00 | 14:30 | 15:00 | 15:30 | 16:00 | 16:30 |
| Steam Flow | Lb/Hr x 10 ³ | 4.55 | 4.54 | 4.59 | 4.58 | 4.54 | 4.54 |
| Air Flow | % | 69 | 69 | 69 | 69 | 69 | 68 |
| Generator Load (Gross) | Megawatts | 664 | 665 | 661 | 664 | 664 | 664 |
| Boiler Thermal Demand | Megawatts | 674 | 674 | 674 | 674 | 674 | 674 |
| O2 Flue gas | % | 3.7 | 3.5 | 3.5 | 3.7 | 3.6 | 3.6 |
| Fuel Flow | % | 95.0 | 95.9 | 94.4 | 94.3 | 94.3 | 96.1 |
| Coal Totalizer | Tons | | | | | | |
| A | — | 79090 | 79110 | 79136 | 79154 | 79172 | 79190 |
| B | — | 78416 | 78436 | 78462 | 78480 | 78498 | 78516 |
| C | — | 79726 | 79746 | 79772 | 79790 | 79808 | 79826 |
| D | — | 12065 | 12065 | 12065 | 12065 | 12065 | 12065 |
| E | — | 92982 | 93002 | 93028 | 93046 | 93066 | 93082 |
| F | — | 78592 | 78612 | 78638 | 78654 | 78672 | 78688 |
| G | — | 93262 | 93284 | 93310 | 93328 | 93346 | 93364 |

**ST. JOHNS RIVER POWER PARK
BOILER CONTROL ROOM DATA**

UNIT # 1

DATE: 12-13-01

| PARAMETER | UNITS | Readings (30 minute intervals) | | | | | |
|------------------------|-------------------------|--------------------------------|-------|--|--|--|--|
| | | | | | | | |
| Person Recording Data | | DB | DB | | | | |
| Time | | 17:00 | 17:30 | | | | |
| Steam Flow | Lb/Hr x 10 ³ | 4.54 | 4.54 | | | | |
| Air Flow | % | 69 | 69 | | | | |
| Generator Load (Gross) | Megawatts | 665 | 662 | | | | |
| Boiler Thermal Demand | Megawatts | 674 | 674 | | | | |
| O2 Flue gas | % | 3.7 | 3.7 | | | | |
| Fuel Flow | % | 97.5 | 94.8 | | | | |
| Coal Totalizer | Tons | | | | | | |
| A | — | 79210 | 79226 | | | | |
| B | — | 78576 | 78552 | | | | |
| C | — | 79846 | 79862 | | | | |
| D | — | 12065 | 12065 | | | | |
| E | — | 93102 | 93120 | | | | |
| F | — | 78708 | 78724 | | | | |
| G | — | 93384 | 93400 | | | | |

**ST. JOHNS RIVER POWER PARK
FLUE GAS DESULFURIZATION
OPERATIONAL PARAMETERS
UNIT # ONE**

Date: 12/13/01
Initials: _____

| HOUR | PACKING DIFFERENTIAL PRESSURE (inches H2O column) | | |
|------|---|-----|-----|
| | A | B | C |
| 0000 | | | 0/5 |
| 0100 | | | |
| 0200 | | | |
| 0300 | | | |
| 0400 | | | |
| 0500 | | | |
| 0600 | | | |
| 0700 | | | |
| 0800 | 5.0 | 5.4 | |
| 0900 | 5.1 | 5.5 | |
| 1000 | 5.2 | 5.7 | |
| 1100 | 5.2 | 5.7 | |
| 1200 | 5.2 | 5.7 | |
| 1300 | 5.2 | 5.7 | |
| 1400 | 5.2 | 5.7 | |
| 1500 | 5.2 | 5.7 | |
| 1600 | 5.2 | 5.6 | |
| 1700 | 5.2 | 5.6 | |
| 1800 | 5.2 | 5.7 | |
| 1900 | 5.2 | 5.6 | |
| 2000 | 5.1 | 5.5 | |
| 2100 | 5.1 | 5.6 | |
| 2200 | 5.1 | 5.6 | |
| 2300 | 4.9 | 5.3 | |

START 1173 75
1248
Daily Water System Use: _____ (Total Gallons) / 1440 (min/day) = _____ GPM

COMMENTS:

ST. JOHNS RIVER POWER PARK
BOILER CONTROL ROOM DATA

UNIT # Two

DATE: 12-12-01

| PARAMETER | UNITS | Readings (30 minute intervals) | | | | | |
|------------------------|-------------------------|--------------------------------|-------------------------|-------------------------|-------------------------|--------|--------|
| | | Person | Person | Person | Person | Person | Person |
| Person Recording Data | | Person | Person | Person | Person | Person | Person |
| Time | | 0800 | 0830 | 0900 | 0930 | 1000 | 1030 |
| Steam Flow | Lb/Hr x 10 ³ | 4.62 | 4.62 | 4.66 | 4.63 | 4.62 | 4.71 |
| Air Flow | % | 72 | 73 | 73 | 72 | 72 | 72 |
| Generator Load (Gross) | Megawatts | 657 | 651 | 657 | 654 | 649 | 657 |
| Boiler Thermal Demand | Megawatts | 604 | 604 | 604 | 604 | 604 | 604 |
| O2 Flue gas | % | 3.21 3.55 | 3.43 3.92 | 3.57 3.87 | 3.83 4.03 | 3.90 | 3.90 |
| Fuel Flow | % | 100.2 | 100 | 100.5 | 100.2 | 100.6 | 100.2 |
| Coal Totalizer | Tons | | | | | | |
| A | | 543.8 | 560 | 584.7 | 606.3 | 628.4 | 651.5 |
| B | | 9173.1 | 9185.6 | 9188.0 | 9190.2 | 9192.6 | 9194.8 |
| C | | 9499.2 | 9501.2 | 9503.0 | 9505.4 | 9507.7 | 9510.2 |
| D | | 934.7 | 934.7 | 934.7 | 934.7 | 934.7 | 934.7 |
| E | | 7090.4 | 7090.7 | 7093.4 | 7095.0 | 7096.6 | 7098.0 |
| F | | 9285.4 | 9288.2 | 9290.6 | 9292.8 | 9294.7 | 9296.2 |
| G | | 9477.8 | 9476.6 | 9479.0 | 9481.0 | 9483.2 | 9485.4 |

ST. JOHNS RIVER POWER PARK
BOILER CONTROL ROOM DATA

UNIT # Two

DATE: 12-12-81

| PARAMETER | UNITS | Readings (30 minute intervals) | | | | | |
|------------------------|-------------------------|--------------------------------|--------|--------|--------|--------|--------|
| Person Recording Data | | Person | Person | Person | Person | Person | Person |
| Time | | 1200 | 1230 | 1260 | 1290 | 1320 | 1350 |
| Steam Flow | Lb/Hr x 10 ⁶ | 4.64 | 4.63 | 4.64 | 4.64 | 4.66 | 4.66 |
| Air Flow | % | 73 | 73 | 73 | 73 | 73 | 72 |
| Generator Load (Gross) | Megawatts | 658 | 650 | 650 | 655 | 650 | 655 |
| Boiler Thermal Demand | Megawatts | 600 | 604 | 604 | 607 | 600 | 604 |
| O2 Flue gas | % | 3.45 | 3.45 | 3.45 | 3.45 | 3.45 | 3.45 |
| Fuel Flow | % | 10 | 99.7 | 10 | 10.14 | 10 | 10.13 |
| Coal Totalizer | Tons | | | | | | |
| A | | 275 | 492.3 | 719.4 | 743.9 | 763.5 | 779.4 |
| B | | 2910 | 9262 | 9211 | 92037 | 92058 | 92082 |
| C | | 93124 | 93100 | 93170 | 93100 | 93012 | 93236 |
| D | | 9387 | 9307 | 9397 | 9347 | 9347 | 9307 |
| E | | 77030 | 77010 | 77000 | 77042 | 77062 | 77080 |
| F | | 93010 | 93036 | 93058 | 93042 | 93002 | 93024 |
| G | | 94576 | 94490 | 94400 | 94400 | 94462 | 94484 |

**ST. JOHNS RIVER POWER PARK
BOILER CONTROL ROOM DATA**

UNIT # Two

DATE: 12-12-01

| PARAMETER | UNITS | Readings (30 minute intervals) | | | | | |
|------------------------|-------------------------|--------------------------------|-------------------------|-------------------------|-------------------------|-------------------------|----------|
| | | Person 1 | Person 2 | Person 3 | Person 4 | Person 5 | Person 6 |
| Person Recording Data | | Person 1 | Person 2 | Person 3 | Person 4 | Person 5 | Person 6 |
| Time | | 1430 | 1430 | 1500 | 1530 | 1600 | 1630 |
| Steam Flow | Lb/Hr x 10 ⁶ | 4.68 | 4.69 | 4.59 | 4.48 | 3.89 | |
| Air Flow | % | 72 | 73 | 74 | 69 | 62 | |
| Generator Load (Gross) | Megawatts | 657 | 650 | 654 | 630 | 500 | |
| Boiler Thermal Demand | Megawatts | 664 | 664 | 604 | 619 | 572 | |
| O2 Flue gas | % | 3.40 3.40 | 3.51 3.83 | 3.19 3.22 | 3.55 3.44 | 3.55 3.58 | |
| Fuel Flow | % | 2.7 | 0.1 | 2.7 | 2.2 | 2.15 | |
| Coal Totalizer | Tons | | | | | | |
| A | | 828.5 | 830 | 853 | 872.5 | 897.4 | |
| B | | 9210 | 92122 | 9210 | 92172 | 9210 | |
| C | | 93270 | 93270 | 93312 | 93326 | 93342 | |
| D | | 9348 | 9348 | 9301 | 9348 | 9308 | |
| E | | 77020 | 77114 | 77126 | 77144 | 77166 | |
| F | | 93144 | 93170 | 93177 | 93212 | 93226 | |
| G | | 95004 | 95028 | 95044 | 95070 | 95086 | |

**ST. JOHNS RIVER POWER PARK
FLUE GAS DESULFURIZATION
OPERATIONAL PARAMETERS**

Date: 12/21/01

UNIT # _____

Initials: _____

| HOUR | PACKING DIFFERENTIAL PRESSURE (inches H2O column) | | |
|------|---|-----|-----|
| | A | B | C |
| 0000 | | | |
| 0100 | | | |
| 0200 | | | |
| 0300 | | | |
| 0400 | | | |
| 0500 | | | |
| 0600 | | | |
| 0700 | NOT WORKING | 0/S | |
| 0800 | 7.0 | | 6.3 |
| 0900 | | | 6.1 |
| 1000 | | | 6.4 |
| 1100 | | | 6.4 |
| 1200 | | | 6.2 |
| 1300 | | | 6.1 |
| 1400 | | | 6.0 |
| 1500 | | | 6.4 |
| 1600 | | | 6.5 |
| 1700 | | | |
| 1800 | | | |
| 1900 | | | |
| 2000 | | | |
| 2100 | | | |
| 2200 | | | |
| 2300 | | | |

1100

START

Daily Water System Use: _____ (Total Gallons) / 1440 (min/day) = _____ GPM

COMMENTS: _____



GCI