

TOTAL SOURCE ANALYSIS, INC.
ENVIRONMENTAL TESTING CONSULTANTS

FINAL
BLEND EMISSIONS
TEST REPORT
FOR
JACKSONVILLE ELECTRIC
ST. JOHNS RIVER
POWER PARK
UNIT 1

August 11/19, 1995

95-058-FL

Report Date 9-11-95




TOTAL SOURCE ANALYSIS, INC.
ENVIRONMENTAL TESTING CONSULTANTS

September 11, 1995

I, James Tayfel, hereby certify that the emissions tests conducted at Jacksonville Electric Authority's St. Johns River Power Park, Unit 1 are in accordance with procedures established by the USEPA. This report accurately and faithfully presents the data obtained from the tests and the results determined from analysis of this data.


James Tayfel
Crew Chief

I, Carl Vineyard, P.E., hereby attest that all work on this project was completed under my supervision and this report accurately presents the emissions from the units.



Carl Vineyard, P.E.
Chief Test Engineer

I, Angel Aguiar, P.E., have reviewed the reports for completeness and accuracy.



Angel Aguiar, P.E.
Florida Professional Engineer

TABLE OF CONTENTS

INTRODUCTION.....A1
SUMMARY OF TEST RESULTS.....B1-B20
SAMPLING AND ANALYTICAL PROCEDURES.....C1-C17
APPENDIX
 Sample Calculations.....D1-D6
 TSA Field Data Sheets.....E1-E27
 TSA CEMS Log.....F1-F24
 TSA Calibration Data.....G1-G16
 Gas Certification Sheets.....H1-H9
 Calibration of Test Equipment.....I1-I5
 Laboratory Reports.....J1-J9

INTRODUCTION

INTRODUCTION

This report presents the results of the emissions tests performed for Jacksonville Electric St. Johns River Power Park, Unit 1.

The purpose of the tests was to determine the emissions of the unit. The results of the tests can be found in Section II of this report.

The emissions testing was performed by Total Source Analysis, Inc., whose Florida Branch Office is located at 810 N. Central Avenue, Umatilla, Florida 32784.

The tests were performed on August 11/19, 1995. The testing was performed in accordance with EPA reference methods as published in the July 1, 1994 Federal Register, - "Standards of Performance for New Stationary Sources" and subsequent revisions.

The testing equipment and sampling procedures are described in Section III of this report. The raw field data and equations used in determining final results are presented in the Appendix as well as the calibration data sheets for the applicable testing equipment.

SUMMARY OF TEST RESULTS

SUMMARY OF TEST RESULTS

The following table presents the final results of the emissions tests performed on Unit 1 at Jacksonville Electric's St. Johns River Power Park.

PARTICULATE

<u>Run No.</u>	<u>Location</u>	<u>Date</u>	<u>lbs/dscf</u>	<u>lbs/hr</u>	<u>lbs/MBtu</u>
1	Stack	8-14-95	5.06E-07	46.19	.006
2	Stack	8-14-95	1.07E-06	100.39	.014
3	Stack	8-14-95	1.03E-06	95.71	.013
Avg.			8.72E-07	80.76	.011
1	Stack	8-15-95	3.97E-07	36.25	.005
2	Stack	8-15-95	4.70E-07	44.01	.006
3	Stack	8-15-95	5.22E-07	48.60	.007
Avg.			4.63E-07	42.95	.006
1	Stack	8-16-95	2.29E-07	20.98	.003
2	Stack	8-16-95	4.08E-07	37.85	.005
3	Stack	8-16-95	3.04E-07	28.11	.004
Avg.			3.14E-07	28.98	.004
1	Stack	8-17-95	7.84E-07	71.31	.010
2	Stack	8-17-95	7.66E-07	71.73	.010
3	Stack	8-17-95	5.10E-07	46.82	.006
Avg.			6.87E-07	63.28	.009
1	Stack	8-19-95	2.75E-07	26.06	.004
2	Stack	8-19-95	2.65E-07	25.01	.003
3	Stack	8-19-95	2.05E-07	19.34	.003
Avg.			2.48E-07	23.47	.003

SO₃

Run No.	Location	Date	lbs/dscf	ppm	02%
1	Stack	8-11-95	1.541E-06	7.41	4.9
2	Stack	8-11-95	1.602E-06	7.70	4.9
3	Stack	8-11-95	1.559E-06	7.50	5.0
Avg.			1.567E-06	7.54	4.9
1	Stack	8-12-95	2.013E-06	9.68	5.0
2	Stack	8-12-95	1.879E-06	9.03	5.0
3	Stack	8-12-95	1.857E-06	8.93	4.9
Avg.			1.916E-06	9.21	5.0
1	Stack	8-13-95	1.154E-06	5.55	4.9
2	Stack	8-13-95	2.359E-06	11.34	4.8
3	Stack	8-13-95	5.243E-06	25.21	4.7
Avg.			2.9186E-06	14.03	4.8
1	Stack	8-18-95	1.712E-06	8.23	5.0
2	Stack	8-18-95	2.469E-06	11.87	5.1
3	Stack	8-18-95	2.913E-06	14.01	5.0
Avg.			2.364E-06	11.37	5.0

CO

<u>Run No.</u>	<u>Location</u>	<u>Test Date</u>	<u>ppm</u>	<u>%O2</u>
1	Stack	8-11-95	399.07	4.92
2	Stack	8-11-95	420.65	4.86
3	Stack	8-11-95	119.16	5.01
Avg.			312.96	4.93
1	Stack	8-12-95	460.81	5.04
2	Stack	8-12-95	481.31	4.98
3	Stack	8-12-95	550.61	4.93
Avg.			497.58	4.98
1	Stack	8-13-95	630.22	4.95
2	Stack	8-13-95	773.39	4.77
3	Stack	8-13-95	833.32	4.75
Avg.			745.64	4.82
1	Stack	8-18-95	444.22	5.00
2	Stack	8-18-95	471.25	5.05
3	Stack	8-18-95	488.23	5.04
Avg.			467.90	5.03

The complete results can be found on the computer printouts following.

Total Source Analysis, Inc.
Particulate Test Analysis

JEA
SJRPP
UNIT 1
95-058

Run Number	1	2	3
Data set	(01)	(02)	(03)
Date	8-14-95	8-14-95	8-14-95
Location	STACK BLEND	STACK BLEND	STACK BLEND
Start time	07:45	10:50	13:15
End time	10:05	13:00	15:25
Barometric Pressure	In. Hg 30.23	30.23	30.23
Static Pressure	In. H2O -0.55	-0.55	-0.55
Volume of Condensate	Mls 262	257	261
Volume Sampled	DCF 86.588	83.536	82.954
Meter Correction Factor	1.00	1.00	1.00
Square Root of Delta P	1.149	1.172	1.174
Orifice Pressure	In. H2O 1.40	1.42	1.40
Meter Temperature	Deg. F 116	118	118
Flue Temperature	Deg. F 166	164	166
Percent CO2	% 14.40	14.20	14.45
Percent O2	% 4.80	4.90	4.46
Diameter of Nozzle	In 0.187	0.187	0.187
Area of Flue	Sq Ft 471.43	471.43	471.43
Sample Time	Min 120	120	120
Weight Gain	Grams 0.0184	0.0377	0.0358
F Factor	DSCF/MBtu 9780	9780	9780
Absolute Flue Pressure	In. Hg 30.19	30.19	30.19
Corrected Sample Volume	DSCF 80.11	77.03	76.49
Moisture in Flue Gas	% 13.3	13.6	13.9
Molecular Weight	Lb/LbMole 28.83	28.78	28.76
Velocity of Flue Gas	FpS 72.89	74.30	74.57
Volume of Flue Gas	ACFM 2,061,809	2,101,643	2,109,254
Volume of Flue Gas	DSCFM 1,520,149	1,550,385	1,545,685
Dust Concentration	Lb/DSCF 5.06E-07	1.07E-06	1.03E-06
Dust Concentration	Lbs/Hour 46.19	100.39	95.71
Dust Concentration	Grs/ACF 2.63E-03	5.62E-03	5.34E-03
Dust Concentration	Grs/DSCF 3.54E-03	7.55E-03	7.22E-03
Isokinetic Rate	% 108.4	102.2	101.8
Particulate Emissions	Lb/MBtu 0.006	0.014	0.013

Averages:

Stack Temperature	:	165.3	Percent O2	:	4.7
Vol Flue Gas	ACFM	2,090,902	DSCFM	:	1,538,740
Part Emis	Lb/DSCF	8.72E-07	Lb/Hour	:	80.76
	Grs/ACF	4.53E-03	Grs/DSCF	:	6.11E-03
	Lbs/MBtu	1.1E-02			

Total Source Analysis, Inc.
Particulate Test Analysis

JEA
SJRPP
UNIT 1
95-058

Run Number	1	2	3
Data set	(04)	(05)	(06)
Date	8-15-95	8-15-95	8-15-95
Location	STACK BLEND	STACK BLEND	STACK BLEND
Start time	08:00	10:35	13:15
End time	10:07	12:40	15:25
Barometric Pressure	In. Hg 30.16	30.16	30.16
Static Pressure	In. H2O -0.54	-0.54	-0.54
Volume of Condensate	Mls 261	284	276
Volume Sampled	DCF 83.217	85.552	84.692
Meter Correction Factor	1.00	1.00	1.00
Square Root of Delta P	1.158	1.192	1.186
Orifice Pressure	In. H2O 1.43	1.51	1.49
Meter Temperature	Deg. F 118	118	123
Flue Temperature	Deg. F 168	166	167
Percent CO2	% 14.40	14.00	14.30
Percent O2	% 5.10	5.20	4.80
Diameter of Nozzle	In 0.187	0.187	0.187
Area of Flue	Sq Ft 471.43	471.43	471.43
Sample Time	Min 120	120	120
Weight Gain	Grams 0.0138	0.0168	0.0183
F Factor	DSCF/MBtu 9780	9780	9780
Absolute Flue Pressure	In. Hg 30.12	30.12	30.12
Corrected Sample Volume	DSCF 76.56	78.72	77.26
Moisture in Flue Gas	% 13.8	14.5	14.4
Molecular Weight	Lb/LbMole 28.78	28.64	28.68
Velocity of Flue Gas	FpS 73.73	75.96	75.58
Volume of Flue Gas	ACFM 2,085,624	2,148,508	2,137,733
Volume of Flue Gas	DSCFM 1,520,200	1,558,742	1,550,968
Dust Concentration	Lb/DSCF 3.97E-07	4.70E-07	5.22E-07
Dust Concentration	Lbs/Hour 36.25	44.01	48.60
Dust Concentration	Grs/ACF 2.04E-03	2.41E-03	2.67E-03
Dust Concentration	Grs/DSCF 2.78E-03	3.29E-03	3.65E-03
Isokinetic Rate	% 103.6	103.9	102.5
Particulate Emissions	Lb/MBtu 0.005	0.006	0.007

Averages:

Stack Temperature	:	167.0	Percent O2	:	5.0
Vol Flue Gas	ACFM :	2,123,955	DSCFM	:	1,543,303
Part Emis	Lb/DSCF :	4.63E-07	Lb/Hour	:	42.95
	Grs/ACF :	2.38E-03	Grs/DSCF	:	3.24E-03
	Lbs/MBtu :	6E-03			

Total Source Analysis, Inc.
Particulate Test Analysis

JEA SJRPP POWERPARK
JACKSONVILLE FLA

95-058

Run Number	1	2	3
Data set	(10)	(11)	(12)
Date	8-16-95	8-16-95	8-16-95
Location	UNIT 1	UNIT 1	UNIT 1
	BLEND	BLEND	BLEND
Start time	08:00	10:45	13:25
End time	10:25	12:50	15:37
Barometric Pressure	In. Hg 30.15	30.15	30.15
Static Pressure	In. H2O -0.88	-0.88	-0.88
Volume of Condensate	Mls 247	256	264
Volume Sampled	DCF 79.551	82.145	82.095
Meter Correction Factor	1.00	1.00	1.00
Square Root of Delta P	1.160	1.174	1.175
Orifice Pressure	In. H2O 1.25	1.40	1.41
Meter Temperature	Deg. F 118	118	119
Flue Temperature	Deg. F 167	167	167
Percent CO2	% 14.30	14.20	14.10
Percent O2	% 5.00	4.80	4.90
Diameter of Nozzle	In 0.187	0.187	0.187
Area of Flue	Sq Ft 471.43	471.43	471.43
Sample Time	Min 120	120	120
Weight Gain	Grams 0.0076	0.0140	0.0104
F Factor	DSCF/MBtu 9780	9780	9780
Absolute Flue Pressure	In. Hg 30.09	30.09	30.09
Corrected Sample Volume	DSCF 73.12	75.50	75.33
Moisture in Flue Gas	% 13.7	13.8	14.2
Molecular Weight	Lb/LbMole 28.78	28.75	28.69
Velocity of Flue Gas	FpS 73.84	74.79	74.92
Volume of Flue Gas	ACFM 2,088,592	2,115,444	2,119,114
Volume of Flue Gas	DSCFM 1,525,857	1,543,258	1,539,304
Dust Concentration	Lb/DSCF 2.29E-07	4.08E-07	3.04E-07
Dust Concentration	Lbs/Hour 20.98	37.85	28.11
Dust Concentration	Grs/ACF 1.17E-03	2.11E-03	1.56E-03
Dust Concentration	Grs/DSCF 1.60E-03	2.86E-03	2.13E-03
Isokinetic Rate	% 98.6	100.6	100.7
Particulate Emissions	Lb/MBtu 0.003	0.005	0.004

Averages:

Stack Temperature	:	167.0	Percent O2	:	4.9
Vol Flue Gas	ACFM	2,107,717	DSCFM	:	1,536,140
Part Emis	Lb/DSCF	3.14E-07	Lb/Hour	:	28.98
	Grs/ACF	1.62E-03	Grs/DSCF	:	2.2E-03
	Lbs/MBtu	4E-03			

Total Source Analysis, Inc.
Particulate Test Analysis

JEA SJRPP POWERPARK
JACKSONVILLE FLA
B. Cond.
95-058
Unit #1

Run Number	1	2	3
Data set	(13)	(14)	(15)
Date	8-17-95	8-17-95	8-17-95
Location	UNIT 1	UNIT 1	UNIT 1
	BLEND	BLEND	BLEND
Start time	08:00	10:35	13:15
End time	10:10	12:45	15:25
Barometric Pressure	In. Hg 30.19	30.19	30.19
Static Pressure	In. H2O -0.83	-0.83	-0.83
Volume of Condensate	Mls 271	256	262
Volume Sampled	DCF 81.273	82.783	82.149
Water Correction Factor	1.00	1.00	1.00
Square Root of Delta P	1.161	1.184	1.166
Orifice Pressure	In. H2O 1.37	1.43	1.37
Water Temperature	Deg. F 118	120	119
Flue Temperature	Deg. F 167	166	169
Percent CO2	% 14.20	14.30	14.30
Percent O2	% 5.10	4.80	4.70
Diameter of Nozzle	In 0.187	0.187	0.187
Area of Flue	Sq Ft 471.43	471.43	471.43
Sample Time	Min 120	120	120
Weight Gain	Grams 0.0266	0.0264	0.0175
F Factor	DSCF/MBtu 9780	9780	9780
Absolute Flue Pressure	In. Hg 30.13	30.13	30.13
Corrected Sample Volume	DSCF 74.79	75.96	75.54
Moisture in Flue Gas	% 14.6	13.7	14.0
Molecular Weight	Lb/LbMole 28.66	28.77	28.73
Velocity of Flue Gas	FpS 74.03	75.26	74.37
Volume of Flue Gas	ACFM 2,094,037	2,128,696	2,103,624
Volume of Flue Gas	DSCFM 1,515,493	1,559,947	1,527,697
Dust Concentration	Lb/DSCF 7.84E-07	7.66E-07	5.10E-07
Dust Concentration	Lbs/Hour 71.31	71.73	46.82
Dust Concentration	Grs/ACF 4.01E-03	3.98E-03	2.62E-03
Dust Concentration	Grs/DSCF 5.48E-03	5.36E-03	3.57E-03
Stoichiometric Rate	% 101.5	100.2	101.7
Particulate Emissions	Lb/MBtu 0.010	0.010	0.006

Averages:

Stack Temperature	: 167.5	Percent O2	: 4.9
Vol Flue Gas	ACFM : 2,108,786	DSCFM	: 1,534,379
Part Emis	Lb/DSCF : 6.87E-07	Lb/Hour	: 63.28
	Grs/ACF : 3.54E-03	Grs/DSCF	: 4.81E-03
	Lbs/MBtu : 8.67E-03		

Total Source Analysis, Inc.
Particulate Test Analysis

JEA SJRPP POWERPARK
JACKSONVILLE FLA

95-058

Run Number	1	2	3
Data set	(17)	(18)	(19)
Date	8-19-95	8-19-95	8-19-95
Location	UNIT 1 BLEND	UNIT 1 BLEND	UNIT 1 BLEND
Start time	08:00	10:38	13:16
End time	10:15	12:56	15:32
Barometric Pressure	In. Hg 30.28	30.28	30.28
Static Pressure	In. H2O -0.71	-0.74	-0.74
Volume of Condensate	Mls 205	217	231
Volume Sampled	DCF 81.337	83.156	87.737
Meter Correction Factor	1.00	1.00	1.00
Square Root of Delta P	1.157	1.160	1.160
Orifice Pressure	In. H2O 1.38	1.44	1.46
Meter Temperature	Deg. F 111	120	121
Flue Temperature	Deg. F 154	154	154
Percent CO2	% 14.20	14.30	14.40
Percent O2	% 5.00	5.20	4.60
Diameter of Nozzle	In 0.187	0.187	0.187
Area of Flue	Sq Ft 471.43	471.43	471.43
Sample Time	Min 120	120	120
Weight Gain	Grams 0.0095	0.0092	0.0075
F Factor	DSCF/MBtu 9780	9780	9780
Absolute Flue Pressure	In. Hg 30.23	30.23	30.23
Corrected Sample Volume	DSCF 76.04	76.54	80.62
Moisture in Flue Gas	% 11.3	11.8	11.9
Molecular Weight	Lb/LbMole 29.07	29.02	29.00
Velocity of Flue Gas	FpS 72.35	72.60	72.62
Volume of Flue Gas	ACFM 2,046,505	2,053,438	2,054,070
Volume of Flue Gas	DSCFM 1,577,001	1,572,924	1,571,863
Dust Concentration	Lb/DSCF 2.75E-07	2.65E-07	2.05E-07
Dust Concentration	Lbs/Hour 26.06	25.01	19.34
Dust Concentration	Grs/ACF 1.49E-03	1.43E-03	1.10E-03
Dust Concentration	Grs/DSCF 1.92E-03	1.85E-03	1.43E-03
Isokinetic Rate	% 99.2	100.1	105.5
Particulate Emissions	Lb/MBtu 0.004	0.003	0.003

Averages:

Stack Temperature	:	154.0	Percent O2	:	4.9
Vol Flue Gas	ACFM	: 2,051,338	DSCFM	:	1,573,929
Part Emis	Lb/DSCF	: 2.48E-07	Lb/Hour	:	23.47
	Grs/ACF	: 1.35E-03	Grs/DSCF	:	1.74E-03
	Lbs/MBtu	: 3.33E-03			

Total Source Analysis, Inc.
SO3 - Sulfur Analysis

JEA
SJRPP
UNIT 1
95-058

Run Number	1	2	3
Data set	(19)	(20)	(21)
Date	8-11-95	8-11-95	8-11-95
Location	UNIT 1 STACK	UNIT 1 STACK	UNIT 1 STACK
Start time	08:15	10:14	12:13
End time	09:30	11:30	13:27
Barometric Pressure	In/Hg 30.22	30.22	30.22
Volume of Sample	Cu. Ft. 39.309	40.344	46.718
Meter Correction Factor	0.996	0.996	0.996
Meter Temperature	Deg. F 88	94	108
Percent O2	% 4.9	4.9	5.0
Volume of Solution	ML 160	211	224
Volume of Aliquot	ML 25	25	25
Normality of Barium	N 0.0099	0.0099	0.0099
Volume to Titrate Blank	ML 0.00	0.00	0.00
Volume to Titrate Sample	ML 10.50	8.40	8.70
Volume of Metered Gas	DSCF 38.086	38.665	43.671
Concentration of SO3	LBS/DSCF 1.541E-06	1.602E-06	1.559E-06
Parts Per Million SO3	PPM 7.41	7.70	7.50

Total Source Analysis, Inc.
SO3 - Sulfur Analysis

JEA
SJRPP
UNIT 1
95-058

Run Number	1	2	3
Data set	(22)	(23)	(24)
Date	8-12-95	8-12-95	8-12-95
Location	UNIT 1 STACK	UNIT 1 STACK	UNIT 1 STACK
Start time	08:06	10:00	11:50
End time	09:18	11:10	13:00
Barometric Pressure	In/Hg 30.23	30.23	30.29
Volume of Sample	Cu. Ft. 40.322	39.944	42.347
Meter Correction Factor	0.996	0.996	0.996
Meter Temperature	Deg. F 89	106	113
Percent O2	% 5.0	5.0	4.9
Volume of Solution	ML 250	175	171
Volume of Aliquot	ML 25	25	25
Normality of Barium	N 0.0100	0.0100	0.0100
Volume to Titrate Blank	ML 0.00	0.00	0.00
Volume to Titrate Sample	ML 8.90	11.40	12.10
Volume of Metered Gas	DSCF 39.009	37.483	39.330
Concentration of SO3	LBS/DSCF 2.013E-06	1.879E-06	1.857E-06
Parts Per Million SO3	PPM 9.68	9.03	8.93

Total Source Analysis, Inc.
SO3 - Sulfur Analysis

JEA
SJRPP
UNIT 1
95-058

Run Number	1	2	3
Data set	(25)	(26)	(27)
Date	8-13-95	8-13-95	8-13-95
Location	UNIT 1 STACK	UNIT 1 STACK	UNIT 1 STACK
Start time	08:00	09:47	11:43
End time	09:10	11:00	12:55
Barometric Pressure	In/Hg 30.29	30.29	30.29
Volume of Sample	Cu. Ft. 41.740	41.816	40.900
Meter Correction Factor	0.996	0.996	0.996
Meter Temperature	Deg. F 110	113	112
Percent O2	% 4.9	4.8	4.7
Volume of Solution	ML 196	193	199
Volume of Aliquot	ML 25	25	25
Normality of Barium	N 0.0100	0.0100	0.0100
Volume to Titrate Blank	ML 0.00	0.00	0.00
Volume to Titrate Sample	ML 6.50	13.45	28.40
Volume of Metered Gas	DSCF 38.970	38.837	38.053
Concentration of SO3	LBS/DSCF 1.154E-06	2.359E-06	5.243E-06
Parts Per Million SO3	PPM 5.55	11.34	25.21

Total Source Analysis, Inc.
SO3 - Sulfur Analysis

JEA
SJRPP
UNIT 1
95-058

Run Number	1	2	3
Data set	(28)	(29)	(30)
Date	8-18-95	8-18-95	8-18-95
Location	UNIT 1 STACK	UNIT 1 STACK	UNIT 1 STACK
Start time	08:00	09:50	11:35
End time	09:10	11:00	12:40
Barometric Pressure	In/Hg 30.19	30.19	30.19
Volume of Sample	Cu. Ft. 37.253	38.505	38.477
Meter Correction Factor	0.996	0.996	0.996
Meter Temperature	Deg. F 98	111	115
Percent O2	% 5.0	5.1	5.0
Volume of Solution	ML 193	197	165
Volume of Aliquot	ML 25	25	10
Normality of Barium	N 0.0100	0.0100	0.0100
Volume to Titrate Blank	ML 0.00	0.00	0.00
Volume to Titrate Sample	ML 8.90	12.70	7.10
Volume of Metered Gas	DSCF 35.412	35.769	35.494
Concentration of SO3	LBS/DSCF 1.712E-06	2.469E-06	2.913E-06
Parts Per Million SO3	PPM 8.23	11.87	14.01

SAMPLING SYSTEM BIAS CHECK AND MEASURED VALUE CORRECTION

POLLUTANT: CO
MONITOR SPAN 1000

UNIT NO.:

RUN NUMBER	AVERAGE MEASURED PPM	INITIAL ZERO GAS BIAS	FINAL ZERO GAS BIAS	ZERO GAS DRIFT	INITIAL UPSCALE GAS BIAS	FINAL UPSCALE GAS BIAS	UPSCALE GAS DRIFT	GAS CALIBRATION GAS PPM	CORRECTED PPM, DRY BASIS
1	392.31	0.00	0.00	0.00	59.90	62.00	0.21	62.00	399.07
2	422.81	0.00	0.00	0.00	302.70	304.40	0.17	302.00	420.65
3	119.69	0.00	0.00	0.00	304.40	302.30	-0.21	302.00	119.16

B13

$$C_{gas} = (C_{avg} - C_o) * C_{ma} / (C_m - C_o) \quad \text{Eq. 6C-1}$$

where:

C_{gas} = Effluent gas concentration, dry basis, ppm

C_{avg} = Average gas concentration indicated by gas analyzer, dry basis, ppm

C_o = Average of initial and final system calibration bias check responses for the zero gas, ppm

C_m = Average of initial and final system calibration bias check responses for the upscale calibration gas, ppm

C_{ma} = Actual concentration of the upscale calibration gas, ppm

8-11-95

SAMPLING SYSTEM BIAS CHECK AND MEASURED VALUE CORRECTION

POLLUTANT: O2
MONITOR SPAN 25

UNIT NO.: 1

RUN NUMBER	AVERAGE MEASURED PERCENT	INITIAL ZERO GAS BIAS	FINAL ZERO GAS BIAS	ZERO GAS DRIFT	INITIAL UPSCALE GAS BIAS	FINAL UPSCALE GAS BIAS	UPSCALE GAS DRIFT	GAS CALIBRATION GAS PERCENT	CORRECTED PERCENT, DRY BASIS
1	4.87%	0.10%	0.10%	0.00%	11.40%	11.30%	-0.40%	11.60%	4.92%
2	4.77%	0.10%	0.10%	0.00%	11.30%	11.20%	-0.40%	11.60%	4.86%
3	4.89%	0.10%	0.10%	0.00%	11.20%	11.20%	0.00%	11.60%	5.01%

B14

8-12-93

SAMPLING SYSTEM BIAS CHECK AND MEASURED VALUE CORRECTION

POLLUTANT: CO
MONITOR SPAN 1000

UNIT NO.: J

RUN NUMBER	AVERAGE MEASURED PPM	INITIAL ZERO GAS BIAS	FINAL ZERO GAS BIAS	ZERO GAS DRIFT	INITIAL UPSCALE GAS BIAS	FINAL UPSCALE GAS BIAS	UPSCALE GAS DRIFT	GAS CALIBRATION GAS PPM	CORRECTED PPM, DRY BASIS
1	464.24	0.00	0.00	0.00	304.20	304.30	0.01	302.00	460.81
2	484.47	0.00	0.10	0.01	304.30	303.70	-0.06	302.00	481.31
3	552.57	0.10	0.00	-0.01	303.70	302.50	-0.12	302.00	550.61

B15

$$C_{gas} = (C_{avg} - C_o) * C_{ma} / (C_m - C_o) \quad \text{Eq. 6C-1}$$

where:

- C_{gas} = Effluent gas concentration, dry basis, ppm
- C_{avg} = Average gas concentration indicated by gas analyzer, dry basis, ppm
- C_o = Average of initial and final system calibration bias check responses for the zero gas, ppm
- C_m = Average of initial and final system calibration bias check responses for the upscale calibration gas, ppm
- C_{ma} = Actual concentration of the upscale calibration gas, ppm

8-12-95

SAMPLING SYSTEM BIAS CHECK AND MEASURED VALUE CORRECTION

POLLUTANT: O2
MONITOR SPAN 25

UNIT NO.: /

RUN NUMBER	AVERAGE MEASURED PERCENT	INITIAL ZERO GAS BIAS	FINAL ZERO GAS BIAS	ZERO GAS DRIFT	INITIAL UPSCALE GAS BIAS	FINAL UPSCALE GAS BIAS	UPSACLE GAS DRIFT	CALIBRATION GAS PERCENT	CORRECTED PERCENT, DRY BASIS
1	4.97%	0.10%	0.10%	0.00%	11.30%	11.30%	0.00%	11.60%	5.04%
2	4.91%	0.10%	0.10%	0.00%	11.30%	11.30%	0.00%	11.60%	4.98%
3	4.82%	0.10%	0.10%	0.00%	11.30%	11.10%	-0.80%	11.60%	4.93%

B16

8-73-95

SAMPLING SYSTEM BIAS CHECK AND MEASURED VALUE CORRECTION

POLLUTANT: CO
MONITOR SPAN 1000

UNIT NO.: /

RUN NUMBER	AVERAGE MEASURED PPM	INITIAL ZERO GAS BIAS	FINAL ZERO GAS BIAS	ZERO GAS DRIFT	INITIAL UPSCALE GAS BIAS	FINAL UPSCALE GAS BIAS	UPSACLE GAS DRIFT	GAS CALIBRATION GAS PPM	CORRECTED PPM, DRY BASIS
1	636.27	0.00	0.00	0.00	305.40	304.40	-0.10	302.00	630.22
2	782.10	0.00	0.00	0.00	304.40	306.40	0.20	302.00	773.39
3	842.98	0.00	0.00	0.00	306.40	304.60	-0.18	302.00	833.32

$$C_{gas} = (C_{avg} - C_o) * C_{ma} / (C_m - C_o) \quad \text{Eq. 6C-1}$$

where:

- C_{gas} = Effluent gas concentration, dry basis, ppm
- C_{avg} = Average gas concentration indicated by gas analyzer, dry basis, ppm
- C_o = Average of initial and final system calibration bias check responses for the zero gas, ppm
- C_m = Average of initial and final system calibration bias check responses for the upscale calibration gas, ppm
- C_{ma} = Actual concentration of the upscale calibration gas, ppm

B17

8-13-95

SAMPLING SYSTEM BIAS CHECK AND MEASURED VALUE CORRECTION

POLLUTANT: O2
MONITOR SPAN 25

UNIT NO.: /

RUN NUMBER	AVERAGE MEASURED PERCENT	INITIAL ZERO GAS BIAS	FINAL ZERO GAS BIAS	ZERO GAS DRIFT	INITIAL UPSCALE GAS BIAS	FINAL UPSCALE GAS BIAS	UPSACLE GAS DRIFT	GAS CALIBRATION GAS PERCENT	CORRECTED PERCENT, DRY BASIS
1	4.96%	0.10%	0.10%	0.00%	11.50%	11.50%	0.00%	11.60%	4.95%
2	4.77%	0.10%	0.10%	0.00%	11.50%	11.40%	-0.40%	11.60%	4.77%
3	4.67%	0.10%	0.10%	0.00%	11.40%	11.10%	-1.20%	11.60%	4.75%

B18

8-18-95

SAMPLING SYSTEM BIAS CHECK AND MEASURED VALUE CORRECTION

POLLUTANT: CO
MONITOR SPAN 1000

UNIT NO.: /

RUN NUMBER	AVERAGE MEASURED PPM	INITIAL ZERO GAS BIAS	FINAL ZERO GAS BIAS	ZERO GAS DRIFT	INITIAL UPSCALE GAS BIAS	FINAL UPSCALE GAS BIAS	UPSACLE GAS DRIFT	GAS CALIBRATION GAS PPM	CORRECTED PPM, DRY BASIS
1	444.73	0.00	0.00	0.00	301.50	303.20	0.17	302.00	444.22
2	474.65	0.00	0.10	0.01	303.20	305.20	0.20	302.00	471.25
3	491.11	0.10	0.00	-0.01	305.20	302.40	-0.28	302.00	488.23

B19

$$C_{gas} = (C_{avg} - C_o) * C_{ma} / (C_m - C_o) \quad \text{Eq. 6C-1}$$

where:

- C_{gas} = Effluent gas concentration, dry basis, ppm
- C_{avg} = Average gas concentration indicated by gas analyzer, dry basis, ppm
- C_o = Average of initial and final system calibration bias check responses for the zero gas, ppm
- C_m = Average of initial and final system calibration bias check responses for the upscale calibration gas, ppm
- C_{ma} = Actual concentration of the upscale calibration gas, ppm

8-18-95

SAMPLING SYSTEM BIAS CHECK AND MEASURED VALUE CORRECTION

POLLUTANT: O2
MONITOR SPAN 25

UNIT NO.: 1

RUN NUMBER	AVERAGE MEASURED PERCENT	INITIAL ZERO GAS BIAS	FINAL ZERO GAS BIAS	ZERO GAS DRIFT	INITIAL UPSCALE GAS BIAS	FINAL UPSCALE GAS BIAS	UPSCALE GAS DRIFT	GAS CALIBRATION GAS PERCENT	CORRECTED PERCENT, DRY BASIS
1	4.99%	0.10%	0.10%	0.00%	11.50%	11.40%	-0.40%	11.60%	5.00%
2	5.01%	0.10%	0.30%	0.80%	11.40%	11.10%	-1.20%	11.60%	5.05%
3	4.92%	0.30%	0.20%	-0.40%	11.10%	10.90%	-0.80%	11.60%	5.04%

B20

SAMPLING AND ANALYTICAL PROCEDURES

TESTING EQUIPMENT - EPA METHOD 5B SAMPLING TRAIN

An Anderson Corporation Stack Sampler (Model 201415) was used at the sampling locations(s). The particulate sampling train consisted basically of a glass or stainless steel probe; a variable-heat-controlled filter oven with a calibrated Type K (Chromel/Alumel) thermocouple located at the impinger outlet; a 1/4-hp shaft sealed carbon vane vacuum pump assembly with a vacuum gauge; a control unit with an elapse time indicator, a temperature selector switch, a temperature indicator (potentiometer), temperature controllers, an inclined draft gauge, a calibrated dry gas meter, and a calibrated orifice; and an umbilical with various interconnecting hoses, fitting and valves. An appropriately sized stainless-steel nozzle, a calibrated Type K temperature sensor, a static pressure tube, a calibrated S type pitot tube and a variable-heat-controlled stainless-steel liner with a calibrated Type K (Chromel/Alumel) thermocouple are integral parts of the probe assembly.

The vacuum pump was used to control gas sampling rates. The control unit was used to control probe and oven temperatures. The control unit was also used to monitor elapsed sampling times, temperatures, velocities, static pressure, gas sampling rates and sampled gas volume.

Integrated Gas Sampling Train

Flue gas was collected at the sampling location(s) for analysis with an integrated gas sampling train. The sampling train consisted basically of a Mann-made polystyrene gas filter drying tube; a Thomas 1/20-hp sealed-head diaphragm vacuum pump, and tygon tubing with various interconnecting fittings and valves.

Analyzer (Orsat)

Flue gas concentrations were determined with a Gas Analyzer (Orsat) which measures the percentage of carbon dioxide, the percentage of oxygen and percentage of carbon monoxide to the nearest tenth of a percent.

Programmable Calculator

A Hewlett Packard, Model 32SII, programmable calculator was used to determine the isokinetic sampling rate at each sampling point.

Barometer

The barometric pressure (actual station pressure) was determined from a calibrated Aneroid barometer located near the test site which read directly in inches of mercury to the nearest hundredth of an inch.

SAMPLING PROCEDURES - EPA REFERENCE METHOD 5B (PARTICULATE)

Prior to the field testing, the following procedures were performed: All instruments were checked and calibrated. Gelman Spectro Grade, glass-fiber-mat filters with 99.9 percent retention of 0.3-micron particles were individually numbered, placed in similarly numbered glass petri dishes, oven dried at 320 degrees Fahrenheit for two to three hours, cooled in a desiccator and individually weighed on a Mettler analytical balance (Model H54AR) to the nearest 0.1-milligram, and weighed a minimum of every six hours until two consecutive weights within ± 0.5 milligrams were obtained. Several 250 milliliter crucibles were desiccated for a minimum of 24 hours and weighed in the same manner as the filters and petri dishes. Also, several 200-gram quantities of Type 6-16 mesh indicating silica gel were weighed on an Ohaus beam balance and placed into separate airtight polypropylene storage bottles.

The number of sampling points and positions of the points in the flue at the sampling location(s), and the sampling time at each point were determined prior to the particulate testing. The sampling procedures were performed in accordance with the Environment Protection Agency's Reference Method 5B, "Determination of Particulate Emissions from Stationary Sources" in the July 1, 1994 Federal Register, "Standards of Performance for New Stationary Sources" and subsequent revisions.

Before each test run, a particulate sampling train was prepared in part at the sampling location(s) in the following manner: An appropriately sized sampling nozzle was installed onto the inlet of the sampling probe and capped. The probe was then dimensioned and marked with glass-cloth tape at increments that corresponded with the predetermined sampling positions in the flue. A standard impinger assembly was prepared by adding 200 milliliters of distilled water, to each of the first two glass impingers. The third glass impinger was left dry and the fourth was filled with approximately 400 grams of type 6-16 mesh indicating silica gel. The entire impinger assembly was then placed in an ice bath. A disc filter was removed from its petri dish and placed inside a filter holder. The filter holder was then placed inside a filter oven and assembled to the sampling probe outlet and the impinger unit inlet. Next, an umbilical and sampling hoses were connected to the sampling probe, filter oven, impinger unit, vacuum pump and the control unit, accordingly. The probe and oven were then heated to and held at temperatures between 300 and 340 degrees Fahrenheit. The inclined draft gauges were checked and zeroed.

As soon as the probe and oven temperatures had stabilized the entire sampling train assembly was leak-checked at a minimum of 15 inches of mercury vacuum for one minute and the leakage rate recorded. A leakage rate of less than .02 cfm and no vacuum loss was considered acceptable.

After the particulate sampling train had been assembled, as previously described, the particulate sampling was performed.

The sampling nozzle, probe and filter holder were washed with nanograde acetone. The acetone washing and acetone blank were collected in labeled polypropylene sample bottles and retained for later evaporation, desiccation and weighing.

Flue gas concentrations (percentage of CO₂, percentage of O₂, and percentage of CO) were determined by taking several orsat samples of the gas collected, simultaneously with the particulate sampling throughout the test run, by an integrated gas sampling train. The integrated gas sample was collected from the discharge of the particulate control unit. The sampling train was set at a predetermined constant flow rate to obtain an adequate sample. The concentrations for each test run were recorded on a field test form.

Prior to the particulate sampling, a preliminary temperature and velocity traverse, orsat analysis and calculations were performed to determine a correct nozzle and orifice size, and the factors that would be used in calculating the isokinetic sampling rate for each sampling point. Knowing the actual pressure differential across the pitot tube used, the isokinetic sampling rate was calculated at each sampling point using a Hewlett Packard, Model 32SII, Programmable Calculator.

Three test runs were performed at the sampling location(s). The sampling data for each test run was recorded on a field test form during each of the sampling periods.

After the completion of a test run, the following procedures were performed: A final leak-check was performed at highest vacuum during the test for one minute and the leakage rate recorded. The flue gas moisture collected in the first three impingers was measured and recorded. The moisture laden silica gel in the fourth impinger was transferred to an appropriately marked, airtight polypropylene bottle and retained for later weighing. The weight gain of the silica gel moisture collection was added to the measured moisture condensed for that test run. The sample nozzle, probe and filter holder were capped and taken to a clean area for sample recovery. At the recovery area, the disc filter was carefully removed from the filter holder and transferred to its petri dish for later weighing.

ANALYTICAL PROCEDURES - EPA REFERENCE METHOD 5B (PARTICULATE)

After the field testing was completed, the following procedures were performed: Each silica gel moisture collection was weighed in its storage bottle on an Ohaus beam balance with sensitivity of 0.1-gram. Each disc filter and petri dish was oven dried at 320 degrees Fahrenheit for six hours and cooled in a desiccator for two hours before weighing. Each acetone washing and acetone blank was transferred from its sample bottle to a preweighed crucible for evaporation. When the acetone in a crucible had completely evaporated, it was oven dried at 320 degrees Fahrenheit for six hours and transferred to a desiccator for further drying at room temperature. Each acetone blank collected was used to determine the amount of residual weight each crucible retained due to acetone impurities. Each disc filter and petri dish, acetone washing and acetone blank was weighed on a Mettler analytical balance (Model H54AR) with a sensitivity of 0.1-milligram.

All test instruments were recalibrated to determine the deviation percentage.





Exhibit
PARTICULATE
SAMPLING TRAIN

JEA-SJRPP UNIT 1&2
 PARTICULATE SAMPLE POINTS




<u>POINTS</u>	<u>DISTANCE FROM INSIDE WALL</u>
1	12 7/8"
2	3' 6 7/8"
3	7' 3 "

DIAMETER STACK 24' 6"

CROSS SECTION AREA 471.43 FT²

NOT TO SCALE

 Total Source Analysis, Inc. Environmental Testing Consultants	Exhibit STACK TEST POINT LOCATIONS
--	--

TESTING EQUIPMENT - EPA REFERENCE METHOD 8

Sulfuric Acid Mist and Sulfur Dioxide

A Nutech Corporation Stack Sampler (Model 2010) was used at the sampling location(s). The sampling train consisted basically of an effective length stainless steel probe, a standard glass impinger assembly with a calibrated Type K (Chromel/Alumel) thermocouple located at the impinger outlet; a 3/4-hp shaft sealed carbon vane vacuum pump assembly with a vacuum gauge; control unit with an elapse time indicator, a temperature selector switch, a temperature indicator (potentiometer), temperature controllers, an inclined draft gauge, a calibrated dry gas meter, and a calibrated variable-diameter orifice; and an umbilical and various interconnecting hoses, fitting and valves. An appropriately sized stainless-steel nozzle, a calibrated Type K temperature sensor, a static pressure tube, a calibrated S type pitot tube and a variable-heat-controlled stainless-steel liner with a calibrated Type K (Chromel/Alumel) thermocouple are integral parts of the probe assembly.

The vacuum pump was used to control gas sampling rates. The control unit was used to control probe temperatures. The control unit was also used to monitor elapsed sampling times, temperatures, velocities, static pressures, gas sampling rates and sampled gas volume.

Integrated Gas Sampling Train

Flue gas was collected at the sampling location(s) for analysis with an integrated gas sampling train. The sampling train consisted basically of a Mann-made polystyrene gas filter drying tube; a Thomas 1/20 hp sealed-head diaphragm vacuum pump, a Dwyer flowmeter; a plastic bag housed in a protective aluminum case, and tygon tubing with various interconnecting fittings and valves.

Analyzer (Orsat)

Flue gas concentrations were determined with a Gas Analyzer (Orsat) which measures the percentage of carbon dioxide, percentage of oxygen and percentage of carbon monoxide to the nearest tenth of a percent.

Barometer

The barometric pressure (actual station pressure) was determined from a calibrated Aneroid barometer located near the test site which read directly in inches of mercury to the nearest hundredth of an inch.

SAMPLING PROCEDURES - EPA REFERENCE METHOD 8 (SO₃)

Prior to the field testing, the following procedures were performed: All instruments were checked and calibrated. Before each test run a sampling train was prepared in part at the sampling location(s) in the following manner: An appropriately sized sampling nozzle was installed onto the inlet of a sampling probe and capped. The probe was then dimensioned and marked with glass-cloth tape at increments that corresponded with the predetermined sampling point positions in the flue. A standard impinger assembly was prepared by adding 100 milliliters of 80% Isopropanol to the first glass impinger. A glass filter holder was placed between the first and second impingers to catch sulfuric acid mist carryover, and 100 milliliters of 3% hydrogen peroxide was added to the second and third impingers. The fourth impinger was left dry and the fifth was filled with 250 grams of type 6-16 mesh indicating silica gel.

The entire impinger assembly was then placed into an icebath. Next, an umbilical and sampling hoses were connected to the sampling probe and impinger unit, a vacuum pump and a control unit, accordingly. The probe was then heated to and held at approximately 248 degrees Fahrenheit. All magnehelic gauges were checked and zeroed. As soon as the probe temperatures had stabilized, the entire sampling train assembly was leak-checked at a minimum of 15 inches of mercury vacuum for one minute and the leakage rate recorded. A leakage rate of less than .02 cfm and no vacuum loss was considered acceptable.

After the sampling train had been assembled, the probe heated, and the entire system leak-checked, as previously described, the SO₃ sampling was performed.

Flue gas concentrations (percentage of CO₂, percentage of O₂, and percentage of CO) were determined by taking several Orsat samples of the gas collected, simultaneously with the particulate sampling throughout the test run, by an integrated gas sampling train. The integrated gas sample was collected from the discharge of the particulate control unit. The sampling train was set at a predetermined constant flow rate to obtain an adequate sample. The concentrations for each test run were recorded on a field test form.

ANALYTICAL PROCEDURES - EPA REFERENCE METHOD 8

Container number one: A 100 ml aliquot of this solution was pipetted into a 250-ml Erlenmeyer flask, then 2 to 4 drops of thorin indicator were added, and the sample was titrated to a pink endpoint using 0.0100 normality barium perchlorate. The titration was repeated with a second aliquot of sample and titration values averaged. Replicate titrations must agree within 1 percent or ±0.2 ml., whichever is greater.

Container number two: The solution in the container holding the contents of the second and third impingers were discarded.

Blanks were prepared by adding 2 to 4 drops of thorin indicator to 100 ml of 80 percent isopropanol. The blanks were titrated in the same manner as the samples.

All test instruments were recalibrated to determine the deviation percentage.

EPA METHOD 10

DETERMINATION OF CARBON MONOXIDE EMISSIONS FROM STATIONARY SOURCES

1. Principle

1.1 Principle - An integrated or continuous gas sample is extracted from a sampling point and analyzed for carbon monoxide (CO) content using a nondispersive infrared analyzer (NDIR).

2. Range and Sensitivity

2.1 Range - 0 to 1,000 ppm.

2.2 Sensitivity - minimum detectable concentration is 0.1 ppm for a 0 to 1,000 ppm span.

3. Precision and Accuracy

3.1 Precision - The precision of most NDIR analyzers is approximately ± 2 percent of span.

3.2 Accuracy - The accuracy of most NDIR analyzers is approximately ± 5 percent of span after calibration.

4. Apparatus

4.1 Probe - Stainless steel or sheathed Pyrex glass, equipped with a filter to remove particulate matter.

4.2 Air-cooled Condenser or Equivalent - To remove any excess moisture.

4.3 Valve - Needle valve, or Equivalent, to adjust flow rate.

4.4 Pump - Leak-free diaphragm type, or equivalent, to transport gas.

- 4.5 Rate Meter - Rotometer, or equivalent, to measure a flow range from 0 to 1.0 liter per minute (0.035 cfm).
- 4.6 Flexible Bag - Tedlar, or equivalent, with a capacity of 60 to 90 liters (2 to 3 feet). The bag was leak tested in the laboratory before using by evacuating the bag with a pump followed by a dry gas meter. When evacuation was complete, there was no flow through the meter.

5. Analysis

- 5.1 Carbon Monoxide Analyzer - A Horiba Model 321 or Fuji Model 730 nondispersive infrared analyzer is used. The instrument was demonstrated by the manufacturer to meet or exceed manufacturer's specifications and those described in this method.

6. Calibration Gases

- 6.1 Calibration Gases - Known concentration of CO in nitrogen for instrument span, prepurified grade of nitrogen for zero, and two additional concentrations corresponding approximately to 60 percent and 30 percent span. The span concentration shall not exceed 1.5 times the applicable source performance standard. The calibration gases are certified by the manufacturer to be within ± 2 percent of the specified concentration.
- 6.2 Silica Gel - Indicating type, 6 to 16 mesh, dried at 175 degrees C (347 degrees F) for two hours.
- 6.3 Ascarite

7. Procedure

7.1 Continuous Sampling - Set up the equipment as shown in Figure 10-1 making sure all connections are leak free. Place the probe in the stack at a sampling point and purge the sampling line. Connect the analyzer and begin drawing sample into the analyzer. Allow 5 minutes for the system to stabilize, then record the analyzer reading as required by the test procedure. CO₂ content of the gas may be determined. During the sampling system bias check, the system is operated at the normal sampling rate, no adjustments to the measurement system, other than those necessary to achieve proper calibration gas flow rates at the analyzer, are made. Alternately, introduce the zero and upscale gases until a stable response is achieved. The tester determined the measurement system response time by observing the times required to achieve a stable response for both the zero and upscale gases. Note the longer of the two times as the response time. The sampling system bias check shall be considered invalid if the difference between the gas concentrations displayed by the measurement system for the analyzer calibration error check and for the sampling system bias check exceeds ± 5 percent of the span for either the zero or upscale calibration gas.

APPENDIX

Sample Calculations

NOMENCLATURE
Best Available Copy

acf	= actual cubic feet	P_f	= static pressure in flue in inches water, average
acfm	= actual cubic feet per minute	$\sqrt{\Delta P}$	= square root of velocity head in inches water, average
A	= effective area of flue in square feet	%S	= percent sulfur by weight, dry basis
acm	= actual cubic meters	scf	= standard cubic feet
acmm	= actual cubic meters per minute	scm	= standard cubic meters
A_n	= inside area of sampling nozzle in square feet	T_{std}	= absolute temperature of air in degrees Rankine at standard conditions (528 degrees)
B_{ws}	= water vapor in gas stream, proportion by volume	T_s	= absolute temperature of flue gas in degrees Rankin, average
%C	= percent carbon by weight, dry basis	T_m	= absolute temperature at meter in degrees Rankine, average
%CO	= percent carbon monoxide by volume, dry basis	V_s	= velocity of flue gas in feet (meters) per second
%CO ₂	= percent carbon dioxide by volume, dry basis	V_l	= volume of condensate through the impingers in milliliters
C_p	= pitot tube coefficient	V_{lc}	= volume of liquid collected in condenser in milliliters plus weight of liquid absorbed in silica gel in grams indicated as milliliters
D_l	= dust loading per heat input in pounds (grams) per million Btu (calories) per Fr constant	V_m	= volume of metered gas measured at meter conditions in cubic feet (meters)
D_l'	= dust loading per heat input in pounds (grams) per million Btu (calories) per Fr calculated	V_{ms}	= volume of metered gas corrected to dry standard conditions in cubic feet (meters)
dscf	= dry standard cubic feet	V_o	= volume of flue gas at actual conditions in cubic feet (meters) per minute
dscfh	= dry standard cubic feet per hour	Q_{sd}	= volume of flue gas corrected to dry standard conditions in cubic feet (meters) per hour
dscm	= dry standard cubic meters	V_t	= total volume of flue gas sampled at actual conditions in cubic feet (meters)
dscmh	= dry standard cubic meters per hour	V_w	= volume of water vapor in metered gas corrected to standard conditions in cubic feet (meters)
fps	= feet per second	V_{wc}	= volume of water condensed in impingers corrected to standard conditions
F_r	= ratio factor of dry flue gas volume to heat value of combusted fuel in dry standard cubic feet (meters) per million Btu (calories)	V_{wsg}	= volume of water collected in silica gel corrected to standard conditions
gms	= grams	W_a	= total weight of dust collected per unit volume in grains (grams) per actual cubic feet (meters)
gm-mole	= gram-mole	W_d	= total weight of dust collected per unit volume in pounds (grams) per dry standard cubic feet (meters)
grs	= grains	W_g	= total weight of dust collected in grams
ΔH	= orifice pressure drop in inches water, average	W_h	= total weight of dust collected per unit volume in pounds (grams) per hour, dry basis
%H	= percent hydrogen by weight, dry basis	W_p	= total weight of dust collected in pounds
H_c	= heat of combustion in Btu per pound, dry basis	W_s	= total weight of dust collected per unit volume in grains (grams) per dry standard cubic feet (meters)
hr	= hour	W_{sg}	= impinger silica gel weight gain in grams
%I	= percent isokinetic	Y	= metered gas volume correction factor
In. Hg	= inches mercury	G	= total elapsed sampling time in minutes
lbs	= pounds		
lb-mole	= pound-mole		
%M	= percent moisture by volume		
mmBtu	= million Btu		
mmcal	= million calories		
mm Hg	= millimeters mercury		
mps	= meters per second		
M_s	= molecular weight in pounds (gram) per pound (gram) mole (wet basis)		
%N	= percent nitrogen by weight, dry basis		
%N ₂	= percent nitrogen by difference, dry basis		
%O	= percent oxygen by difference, dry basis		
%O ₂	= percent oxygen by volume, dry basis		
P_b	= barometric pressure in inches mercury		
P_{std}	= standard absolute pressure (29.92 in Hg)		
P_s	= absolute pressure in flue in inches (millimeters) mercury		



- (1) ABSOLUTE FLUE PRESSURE (in. Hg)

$$P_s = (\pm P_f \div 13.6) + P_b$$

- (2) WATER VAPOR VOLUME IN METERED GAS CORRECTED TO STANDARD CONDITIONS (scf)

$$V_{wc} = .04707 \times V_l \quad V_{wsg} = .04715 \times W_{sg}$$

$$V_w = V_{wc} + V_{wsg}$$

- (3) METERED GAS VOLUME CORRECTED TO STANDARD CONDITIONS (scf)

$$V_{ms} = 17.64 \times Y \times V_m \frac{P_b + (\Delta H/13.6)}{T_m}$$

- (4) PERCENT MOISTURE IN FLUE GAS

$$B_{ws} = \frac{V_w}{(V_{ms} + V_w)} \quad \%M = B_{ws} \times 100$$

- (5) AVERAGE RESULTS OF FLUE GAS ANALYSIS

$$\%N_2 \text{ dry} = 100 - (\%CO_2 + \%O_2 + \%CO)$$

- (6) APPROXIMATE MOLECULAR WEIGHT OF FLUE GAS (WET BASIS) (lb/lb-mole)

$$M_s = (18 \times B_{ws}) + \left((.440 (\%CO_2) + .320 (\%O_2) + .280 (\%N_2 + \%CO)) \right) \times (1 - B_{ws})$$

- (7) GAS VELOCITY IN FLUE (fps)

$$V_s = 85.49 \times C_p \times (\sqrt{\Delta P}) \text{ avg. } \sqrt{\frac{T_s}{P_s \times M_s}}$$

- (8) FLUE GAS VOLUME AT ACTUAL CONDITIONS (acfm)

$$V_0 = V_s \times A \times 60$$

- (9) FLUE GAS VOLUME CORRECTED TO DRY STANDARD CONDITIONS (dscfh)

$$Q_{sd} = \frac{T_{std}}{29.92} \times \frac{P_s}{T_s} \times V_0 \times (1 - B_{ws}) \times 60$$

- (10) TOTAL FLUE GAS VOLUME SAMPLED AT ACTUAL CONDITIONS (acf)

$$V_t = \left[V_m \times Y \times \frac{T_s}{T_m} \times \left(\frac{P_b + (\Delta H/13.6)}{P_s} \right) \right] + \left(0.00267 \times V_{lc} \times \frac{T_s}{P_s} \right)$$



(11) DUST CONCENTRATION FOR INDIRECT HEATING UNIT ACTUAL CONDITIONS AND STANDARD CONDITIONS

$$W_g = \text{gms}$$

$$W_p = 0.002205 \times W_g \text{ (lb)}$$

$$W_d = \frac{V_p}{V_{ms}} \text{ (lb/dscf)}$$

$$W_h = W_d \times Q_{sd} \text{ (lb/hr dry)}$$

$$W_a = \frac{7000 \times W_p}{V_t} \text{ (gr/acf)}$$

$$W_s = 7000 \times W_d \text{ (gr/dscf)}$$

$$D_l = \frac{9780 \times 20.9 \times W_d}{(20.9 - \%O_2)} \text{ (lb/mmBtu with constant } 9780^\circ F_r)$$

$$F_r = \frac{10^6 \times [(3.64 \times \%H) + (1.53 \times \%C) + (0.57 \times \%S) + (0.14 \times \%N) - (0.46 \times \%O)]}{H_c} \text{ (dscf/mmBtu)}$$

$$D_l' = \frac{20.9 \times W_d \times F_r}{(20.9 - \%O_2)} \text{ (lb/mmBtu with calculated } F_r)$$

(12) PERCENT OF ISOKINETIC SAMPLING

$$\%I = \frac{1.667 \times T_s \times \left\{ 0.00267 \times V_{lc} + \left[\frac{V_m \times Y}{T_m} \times (P_b + \Delta H/13.6) \right] \right\}}{\Theta \times V_s \times P_s \times A_n}$$



SO₂ SO₃ NOMENCLATURE

%C	=	Percent carbon by weight, dry basis
C _{SO₂}	=	Concentration of sulfur dioxide, dry basis corrected to standard conditions (lb/dscf)
C _{SO₃}	=	Concentration of sulfur trioxide, dry basis corrected to standard conditions (lb/dscf)
ESO ₂	=	Emissions of SO ₂ (lb/mmBtu)
ESO ₃	=	Emissions of SO ₃ (lb/mmBtu)
F	=	F factor, ratio factor of dry flue gas volume to heat of combusted fuel in dry standard cubic feet per million Btu.
%H	=	Percent hydrogen by weight, dry basis
Hc	=	Heat of combustion, dry basis, Btu/lb.
In Hg	=	inches mercury
mls	=	Milliliters of the standard sulfuric acid used to standardize the barium perchlorate solution
MI _t	=	Milliliters required to titrate the standard sulfuric acid solution
%N	=	Percent nitrogen by weight, dry basis
Ns	=	Normality of sulfuric acid as labeled on bottle
Nt	=	normality of barium perchlorate titrant, milliequivalents/ml
%O	=	Percent oxygen by weight, dry basis
%O ₂	=	Percent oxygen by volume, dry basis
Pb	=	Barometric pressure in inches, mercury
Pstd	=	Standard absolute pressure (29.92 in. Hg)
PPM	=	Parts per million
%S	=	Percent sulfure by weight, dry basis
Tm	=	Absolute temperature at meter in degrees Rankine, average
Va	=	Volume of sample aliquot titrated, ml.
Vm	=	Volume dry gas as measured by the dry gas meter, (dcf)
Vmstd	=	Volume dry gas measured by the dry gas meter corrected to standard conditions (dscf)
Vsoln	=	Total volume of solution in which the sulfur dioxide sample is contained, 100 ml.
Vt	=	Volume of barium perchlorate titrant used for the sample, ml (average of replicate titrations)
Vtb	=	Volume of barium perchlorate titrant used for the blank, ml.
Y	=	Dry gas meter calibration factor



Total Source Analysis, Inc.
Environmental Testing Consultants

EPA - SO₃ FORMULAS

- (1) $N_t = \frac{(m/s) \times (Ns)}{Ml_t}$
- (2) $V_{mstd} = 17.64 \frac{(Y) (V_m) (P_b)}{T_m}$
- (3) $C_{SO_3} = 1.081 \times 10^{-4} \frac{(V_t - V_{tb}) N \left(\frac{V_{soin}}{V_a} \right)}{V_{mstd}}$
- (4) $PPM_{SO_3} = C_{SO_3} \times 4.822 \times 10^6$
- (5) $ESO_3 = C_{SO_3} (F) \frac{20.9}{20.9 - \%O_2}$
- (6) $Fr = \frac{10^6 \times [(3.84 \times \%H) + (1.53 \times \%C) + (0.57 \times \%S) + (0.14 \times \%N) - (0.48 \times \%O)] (dsct/mmBtu)}{Hc}$

SAMPLE CALCULATION

- (1) $N_t = \frac{(\text{---} m/s) \times (\text{---} N)}{\text{---} m/s}$
- (2) $dsct = 17.64 \frac{(\text{---}) (\text{---} sf) (\text{---} INHg)}{\text{---} ^\circ R}$
- (3) $lb/dsct = 1.081 \times 10^{-4} \frac{(\text{---} ml - \text{---} ml) \text{---} N \left(\frac{\text{---} ml}{\text{---} ml} \right)}{\text{---} dsct}$
- (4) $ppm = \text{---} lb/dsct \times 8.024 \times 10^6$
- (5) $lb/mBtu = \text{---} lb/dsct \times \text{---} dsct/mBtu \frac{20.9}{(20.9 - \text{---} \%)}$
- (6) $dsct/mBtu = \frac{10^6 \times [(3.84 \times \text{---}) + (1.53 \times \text{---}) + (0.57 \times \text{---}) + (0.14 \times \text{---})]}{\text{---} Btu/lb}$



Total Source Analysis, Inc.
Environmental Testing Consultants

CO CALCULATION

$$\text{lb/dscf} = 0.726 \times 10^{-7} \times \text{PPM}$$

$$\text{lb/MBtu} = \text{lb/dscf} \times \text{F Factor} \times \frac{20.9}{(20.9 - \%O_2)}$$

$$\text{lb/hour} = \text{lb/dscf} \times \text{dscfm} \times 60 \text{ min./hr.}$$



TSA Field Data Sheets

Client J.E.A. S.J.R.P.P.				Date 8/11/95		Page 1 of 2	
Project No. 95-058-FL.		Operator HARLEY C. O'NEILL		Orsat Analysis			
Sampling Location Unit # 1 Stack		Run No. 1					
Filter No. -	Acetone No. -	Condensate 80.0		20.065	14.34	4.92	
Barometric Pressure 30.22		Static Pressure 4.1		Probe Number N-10-6-1F		14.34	4.92
Nozzle Diameter .187	Nozzle Number FL3	Pitot Coefficient .875		Pitot Number N-10-6-1-1F			
Meter Corr. Factor .996		Meter-Orifice 2.999					

Sample Pt. Time Smin 60min Test.	Assumed % Moisture 13%	Leak Test	Before .004 @ 15" HG	After .002 @ 6" HG
--	----------------------------------	-----------	--------------------------------	------------------------------

Sample Point	ΔP	√ΔP	ΔH	Temperature °F						Vac. Pr (in. HG)	Dry Gas Meter Reading in Cu. Ft.
				Stack	Probe	Imp. Out	Oven	Meter In	Meter Out		
Start	0815										162.411
1	1.30	1.140	1.77	170	327	61	322	86	87	4	166.247
2	1.25	1.118	1.12	171	326	60	328	86	86	4	169.898
3	0.95	0.975	0.853	172	332	60	324	86	86	4	172.693
1	1.45	1.204	1.32	177	331	63	329	89	88	4	175.899
2	1.33	1.153	1.21	170	335	58	324	91	88	4	179.010
3	1.25	1.118	1.14	168	331	62	327	91	87	4	182.006
1	1.43	1.196	1.31	169	330	63	328	92	87	4	185.369
2	1.35	1.162	1.24	168	334	62	327	92	87	4	188.836
3	0.97	0.985	0.89	167	331	65	324	93	88	4	191.874
1	1.49	1.221	1.35	169	321	60	327	90	86	4	195.150
2	1.32	1.149	1.20	169	324	62	324	90	86	6	198.608
3	1.12	1.058	1.02	170	321	64	329	91	87	6	201.720
Stop	0930										
AV?		(1.123)	(1.20)	(169.50)				(91.58)		433	(39.309)
								88			Cu/FT.
				ISOkinetic Rate → 103.2%							
				11.0% moisture							

Pitot Tube Leak Check:	Before	<u>OK</u>	After	<u>OK</u>
Integrated Bag Leak Check:	Before	<u>OK</u>	After	<u>OK</u>



Client J.E.A. S.J.R.P.P.			Date 8/11/95		Page 1 of 2
Project No. 95-058-FL.		Operator HARLEY C. O'NEILL			Orsat Analysis CO ₂ + O ₂ O ₂ CO
Sampling Location Unit # Stack		Run No. 2			
Filter No. -	Acetone No. -	Condensate 81.5 ml. 59 19.50			14.35 4.86
Barometric Pressure 30.22		Static Pressure -.55	Probe Number N-10-6-1F		
Nozzle Diameter .187	Nozzle Number FL3	Pitot Coefficient .875	Pitot Number N-10-6-14F		
Meter Corr. Factor .996		Meter-Orifice 2.999			

Sample Pt. Time 5min 60min TEST.	Assumed % Moisture 13%	Leak Test .008 @ 15" Hg	Before	After .004 @ 3" Hg
--	----------------------------------	-----------------------------------	--------	------------------------------

Sample Point	ΔP	√ΔP	ΔH	Temperature °F						Vac. Pr (in. HG)	Dry Gas Meter Reading in Cu. Ft.
				Stack	Probe	Imp. Out	Oven	Meter In	Meter Out		
Start	1014										208.124
1	1.46	1.208	1.33	171	324	60	320	90	85	3	211.796
2	1.39	1.179	1.26	170	322	61	328	90	86	3	215.131
3	1.09	1.044	0.99	168	324	60	332	92	86	3	218.144
1	1.51	1.229	1.39	168	321	59	334	91	90	3	221.440
2	1.34	1.158	1.24	168	322	59	328	94	89	3	224.699
3	1.08	1.039	1.00	169	323	60	328	97	91	3	227.750
1	1.52	1.237	1.41	169	321	63	327	95	93	3	231.149
2	1.43	1.196	1.83	170	322	63	327	101	93	3	234.512
3	1.23	1.109	1.56	171	324	62	329	105	95	3	238.003
1	1.46	1.208	1.43	170	329	61	329	96	96	3	241.396
2	1.31	1.145	1.63	168	331	61	327	106	97	3	245.004
3	1.05	1.025	1.31	169	330	60	324	110	95	3	248.468
Stop	1130										
AVG		(1.148)	(1.364)	(169.25)				(94.292)		3	(40.344) Cu/FT.
		ISO = 103.0									
		moisture = 10.90.									

Pitot Tube Leak Check: Before OK After OK
 Integrated Bag Leak Check: Before OK After OK



Client J.E.A. S.J.R.P.P.			Date 12 AUG. 95			Page 1 of 2			
Project No. 95-058-FL.		Operator HAWLEY C. O'NEILL				Orsat Analysis			
Sampling Location Unit # 1 Stack				Run No. 1		CO ₂	+ O ₂	O ₂	CO
Filter No.	Acetone No.	Condensate 60.0ml 31.0g			14.23		5.04		
Barometric Pressure 30.23		Static Pressure -.54		Probe Number N-10-G-1F					
Nozzle Diameter .187	Nozzle Number FL3	Pitot Coefficient .875		Pitot Number N-10-G-11F					
Meter Corr. Factor .996		Meter-Orifice 2.999							

Sample Pt. Time 5min 60min TEST.	Assumed % Moisture 1190	Leak Test Before .004 @ 15" Hg	Leak Test After .002 @ 5" Hg
-------------------------------------	----------------------------	-----------------------------------	---------------------------------

Sample Point	ΔP	√ΔP	ΔH	Temperature °F						Vac. Pr (in. HG)	Dry Gas Meter Reading in Cu. Ft.
				Stack	Probe	Imp. Out	Oven	Meter In	Meter Out		
Start	0806										316.521
1	1.49	1.221	1.54	170	321	60	324	85	85	4	320.369
2	1.39	1.179	1.31	171	318	60	322	88	86	4	323.959
3	1.25	1.118	1.18	169	319	63	322	88	86	4	227.098
1	1.47	1.212	1.39	170	322	61	327	86	86	3	330.401
2	1.38	1.175	1.31	171	324	61	327	90	87	3	333.746
3	1.08	1.039	1.04	169	325	60	326	94	89	3	336.872
1	1.53	1.237	1.47	170	324	61	325	90	87	5	340.148
2	1.41	1.187	1.35	171	328	64	329	92	90	5.75	343.581
3	1.29	1.136	1.24	170	329	63	325	92	87	5	346.795
1	1.50	1.225	1.44	168	325	61	324	92	86	5	350.159
2	1.43	1.196	1.37	167	322	61	328	96	85	5	353.529
3	1.18	1.086	1.13	169	324	62	324	99	86	5	356.843
Stop	0918										

AV →	(1.168)	(1.314)	(1.375)					(88.917)	4.25	(40.322)
				169.75	TR.					Cu/FT.

ISO = 101.2
9.9% moisture.

SO₃ = 8.72 ppm wet.

Pitot Tube Leak Check: Before OK After OK
 Integrated Bag Leak Check: Before OK After OK



Client J.E.A. S.J.R.P.P.				Date 12 AUG. 95		Page 1 of 2	
Project No. 95-058-FL.		Operator HARLEY C. O'NEILL		Orsat Analysis			
Sampling Location Unit # 1 Stack		Run No. 2					
Filter No. -	Acetone No. -	Condensate 51 ml		38.65	14.22	4.98	
Barometric Pressure 30.23		Static Pressure -.54		Probe Number N-10-G-1F			
Nozzle Diameter .187	Nozzle Number FL3	Pitot Coefficient .875		Pitot Number N-10-G-11F			
Meter Corr. Factor .996		Meter-Orifice 2.999					

Sample Pt. Time 5min 60min TEST.	Assumed % Moisture 1190	Leak Test Before .001 @ 15" HG.	Leak Test After .001 @ 11" HG.
--	-----------------------------------	---	--

Sample Point	ΔP	√ΔP	ΔH	Temperature °F						Vac. Pr (in. HG)	Dry Gas Meter Reading in Cu. Ft.
				Stack	Probe	Imp. Out	Oven	Meter In	Meter Out		
Start	1000										357.038
1	1.51	1.229	1.45	170	324	60	321	95	95	6	360.197
2	1.40	1.183	1.36	171	322	61	327	106	96	7	363.338
3	1.20	1.095	1.20	170	324	62	324	107	100	8	366.595
1	1.49	1.221	1.49	169	322	62	327	107	102	10	370.005
2	1.39	1.179	1.41	168	323	63	328	110	103	10	373.396
3	1.11	1.054	1.13	170	324	60	332	112	103	10	376.775
1	1.52	1.233	1.55	171	327	61	330	113	105	10	380.258
2	1.44	1.200	1.48	170	324	61	330	113	106	11	383.882
3	1.09	1.044	1.13	169	321	60	331	115	108	11	386.994
1	1.50	1.225	1.51	170	322	61	331	105	105	11	390.359
2	1.42	1.192	1.46	171	323	62	332	115	106	11	393.699
3	1.21	1.100	1.24	171	323	62	331	115	106	10	396.982
Stop	1110										

AV →	(1.163)	(1.37)	(170.00)		(109.417)	19.58	(39.944)
					106		Cu/FT.
	ISO = 953						
	moisture = 10.1%						
	PPM = 8.17 wet						

Pitot Tube Leak Check: Before OK After OK
 Integrated Bag Leak Check: Before OK After OK



25-16.5-95

Client J.E.A. S.J.R.P.P.						Date 8-13-95		Page 1 Of 2			
Project No. 95-058-FL			Operator HARLEY C. O'NEILL			Orsat Analysis					
Sampling Location Unit # 1 Stack				Run No. 1		CO₂	+O₂	O₂	CO		
Filter No. -		Acetone No. -		Condensate 72ml		21.29g	14.29	4.95			
Barometric Pressure 30.29			Static Pressure -.55		Probe Number N-10-G-1F						
Nozzle Diameter .187		Nozzle Number FL3		Pitot Coefficient .875		Pitot Number N-10-6-11F					
Meter Corr. Factor .996			Meter-Orifice 2.999								
Sample Pt. Time Smin 60min TEST.			Assumed % Moisture 10%			Leak Test Before .006 @ 15" HG		Leak Test After .006 @ 4" HG			
Sample Point	ΔP	√ΔP	ΔH	Temperature °F						Vac. Pr (in. HG)	Dry Gas Meter Reading in Cu. Ft.
				Stack	Probe	Imp. Out	Oven	Meter In	Meter Out		
Start	0800										450.961
1	1.41	1.187	1.46	169	315	62	329	106	106	4	454.568
2	1.33	1.153	1.39	168	322	58	328	110	105	4	457.997
3	1.15	1.072	1.21	167	322	59	328	112	106	4	461.400
1	1.49	1.221	1.56	168	323	60	330	105	105	4	464.787
2	1.39	1.179	1.47	167	324	61	331	114	109	4	468.523
3	1.18	1.086	1.25	169	324	62	332	117	108	4	471.910
1	1.39	1.179	1.43	170	323	62	332	106	105	4	475.424
2	1.31	1.145	1.38	171	319	64	329	116	110	4	478.895
3	1.18	1.086	1.25	170	322	62	325	116	111	4	482.255
1	1.42	1.192	1.49	167	329	62	325	111	110	4	485.692
2	1.31	1.145	1.41	170	327	62	326	117	111	4	489.294
3	1.11	1.054	1.18	170	324	61	327	116	111	4	492.701
Stop	0910										
AV →		(1.141)	(1.37)	(168.67)				(110.125)		4	(41.740) Cu/ft.
					T _{SO} = 103.5%						
					moisture = 10.1.						
					ppm = 4.99						

Pitot Tube Leak Check: Before OK After OK
 Integrated Bag Leak Check: Before OK After OK



pt. 18-

Client J.E.A. S.J.R.P.P.			Date 8-13-95	Page 1	Of 2
Project No. 95-058-FL.		Operator HARLEY C. O'NEILL		Orsat Analysis	
Sampling Location Unit # Stack			Run No. 3	CO ₂	+ O ₂
Filter No. -	Acetone No.	Condensate 67.00 ml		23.75 g	14.38
Barometric Pressure 30.29		Static Pressure -.55	Probe Number N-10-G-1F		
Nozzle Diameter .187	Nozzle Number FL.3	Pitot Coefficient	Pitot Number N-10-G-11F		
Meter Corr. Factor .996		Meter-Orifice 2.999			

Sample Pt. Time 5min 60min TEST.	Assumed % Moisture 10.9%	Leak Test	Before .008 @ 15" HG	After .006 @ 3" HG
-------------------------------------	-----------------------------	-----------	-------------------------	-----------------------

Sample Point	ΔP	√ΔP	ΔH	Temperature °F						Vac. Pr (in. HG)	Dry Gas Meter Reading in Cu. Ft.
				Stack	Probe	Imp. Out	Oven	Meter In	Meter Out		
Start	1143										351.832
1	1.49	1.22	1.57	271	321	61	327	112	112	3	355.152
2	1.39	1.179	1.47	170	322	60	327	114	113	3	358.339
3	1.28	1.131	1.36	169	323	61	324	115	113	3	361.699
1	1.45	1.204	1.53	169	322	58	323	112	112	3	365.252
2	1.35	1.162	1.43	169	323	59	323	114	113	3	368.804
3	1.05	1.025	1.113	170	324	60	329	114	113	3	372.135
1	1.48	1.217	1.56	170	325	60	327	112	112	3	375.664
2	1.29	1.136	1.37	171	324	61	326	115	113	3	379.151
3	1.10	1.049	1.17	168	325	61	329	114	112	3	382.400
1	1.50	1.225	1.58	170	324	60	327	113	112	3	386.001
2	1.35	1.162	1.43	169	322	60	324	112	112	3	389.517
3	1.17	1.082	1.24	169	323	61	320	113	112	3	392.732
Stop	1255										

AV → (1.149) (1.40) (169.58) (112.875) | 3 | (40.900) Cu./FT.

ISO = 100.3%
moistures 10.1%

Pitot Tube Leak Check: Before OK After OK
Integrated Bag Leak Check: Before OK After OK



Client JEA / S.J.R.P.P.		Date 8-14-95	Page 1	Of 2
Project No. 95-058 FL		Operator HARLEY C. O'NEILL		Orsat Analysis CO ₂ + O ₂ O ₂ CO
Sampling Location Stack Unit 1		Run No. 2		
Filter No. 95-029 FL	Acetone No. -	Condensate 239 ML 17.7		14.2 19.1 4.90
Barometric Pressure 30.23		Static Pressure -.55	Probe Number N-10-G-1F	
Nozzle Diameter .187	Nozzle Number FL 3	Pitot Coefficient .875	Pitot Number N-10-G-11F	
Meter Corr. Factor .996		Meter-Orifice 2.999		

Sample Pt. Time 10 min	Assumed % Moisture 120 min TEST 10.5	Leak Test CO @ 15" H ₂ O	Before CO @ 15" H ₂ O	After CO @ 2" H ₂ O
---------------------------	---	--	-------------------------------------	-----------------------------------

Sample Point	ΔP	√ΔP	ΔH	Temperature °F						Vac. Pr (in. HG)	Dry Gas Meter Reading in Cu. Ft.			
				Stack	Probe	Imp. Out	Oven	Meter In	Meter Out					
START	1050										688.002			
1	1.51	1.229	1.60	163	324	61	327	114	114	2	694.813			
2	1.42	1.192	1.51	164	327	62	324	115	114	2	701.993			
3	1.26	1.118	1.33	165	329	60	322	123	119	2	708.678			
1	1.52	1.233	1.52	167	324	61	327	116	114	2	715.914			
2	1.43	1.196	1.46	164	322	59	324	123	115	2	722.934			
3	1.18	1.086	1.20	168	321	64	327	126	116	2	729.664			
1	1.49	1.221	1.51	163	328	63	326	117	116	2	736.995			
2	1.39	1.179	1.43	164	327	62	326	124	117	2	743.025			
3	1.22	1.105	1.25	163	324	61	326	124	117	2	750.777			
1	1.52	1.233	1.56	164	323	62	327	112	112	2	757.975			
2	1.51	1.229	1.547	164	324	61	325	124	117	2	765.395			
3	1.16	1.049	1.120	163	324	61	322	126	116	2	771.538			
STOP	1300													
AVG.											(1.172) (1.424) (1.640)	(117.96)	2"	(83.536)
														cu ft.

Pitot Tube Leak Check: Before OK After OK
 Integrated Bag Leak Check: Before OK After OK



Client JEA / S.J.R.P.A.					Date 8-14-95					Page 1 of 2	
Project No. 95-058 FL			Operator HARLEY C. O'NEILL			Orsat Analysis					
Sampling Location Stack Unit 1				Run No. 3		CO ₂		+ O ₂		O ₂ CO	
Filter No. 95-030 FL		Acetone No. —		Condensate 245 ML			16.4 14.45		4.46		
Barometric Pressure 30.23			Static Pressure -.55		Probe Number N-10-G-1F						
Nozzle Diameter .187		Nozzle Number FL3		Pilot Coefficient .875		Pilot Number N-10-G-11F					
Meter Corr. Factor .996			Meter-Orifice 2.999								
Sample Pt. Time 10 min 120 min TEST			Assumed % Moisture 13%			Leak Test Before .000 @ 15" HG After .00 @ 2" HG					
Sample Point	ΔP	$\sqrt{\Delta P}$	ΔH	Temperature °F						Vac. Pr (in. HG)	Dry Gas Meter Reading in Cu. Ft.
				Stack	Probe	Imp. Out	Oven	Meter In	Meter Out		
START	1.315										771.646
1	1.49	1.22	1.50	164	329	58	327	115	115	2	777.810
2	1.37	1.179	1.40	164	327	59	329	117	115	2	789.712
3	1.28	1.131	1.28	167	324	61	331	119	115	2	791.454
1	1.50	1.225	1.52	163	327	62	331	116	115	2	798.655
2	1.35	1.162	1.37	164	324	62	330	119	116	2	805.586
3	1.30	1.140	1.34	167	322	59	322	126	118	2	812.337
1	1.50	1.225	1.52	165	327	60	320	117	116	2	819.660
2	1.40	1.183	1.42	165	325	61	323	117	116	2	826.980
3	1.21	1.100	1.23	166	324	62	324	119	117	2	833.996
1	1.52	1.233	1.52	169	327	60	322	126	116	2	841.255
2	1.37	1.170	1.37	166	324	60	322	127	116	2	848.040
3	1.24	1.114	1.27	167	322	61	324	126	115	2	854.600
STOP	1.325										
AVG.		1.174 (1.40)		1.655		1.22 (1.41)		118		82.954 cu ft.	

Pitot Tube Leak Check: Before OK After OK
 Integrated Bag Leak Check: Before OK After OK

Client JEA / S.J.R.P.P.						Date 8-15-95		Page 1 of 2			
Project No. 95-058 FL			Operator HARLEY C. O'NEILL			Orsat Analysis					
Sampling Location Unit 1 Stack				Run No. 1		CO ₂	+ O ₂	O ₂	CO		
Filter No. 95-031 FL		Acetone No. -		Condensate 244 mL		17.4	14.4	5.10			
Barometric Pressure 30.16			Static Pressure -.54		Probe Number N-10-6-1F						
Nozzle Diameter .187		Nozzle Number FL3		Pitot Coefficient .875		Pitot Number N-10-6-11F					
Meter Corr. Factor .996			Meter-Orifice 2.999								
Sample Pt. Time 10 min			Assumed % Moisture 11%			Leak Test Before .008 @ 15" HG		Leak Test After .004 @ 2" HG			
Sample Point	ΔP	√ΔP	ΔH	Temperature °F						Vac. Pr (in. HG)	Dry Gas Meter Reading in Cu. Ft.
				Stack	Probe	Imp. Out	Oven	Meter In	Meter Out		
Start	0800										854.756
1	1.47	1.212	1.57	169	324	61	327	114	114	2	861.995
2	1.29	1.136	1.35	168	325	62	326	117	112	2	868.760
3	1.13	1.063	1.20	168	325	61	327	122	113	2	875.086
1	1.48	1.217	1.55	168	322	59	326	115	113	2	882.289
2	1.37	1.170	1.47	167	324	59	326	126	115	2	889.402
3	1.23	1.109	1.32	167	323	58	326	126	116	2	896.152
1	1.49	1.221	1.56	168	325	59	322	115	115	2	903.338
2	1.37	1.170	1.47	169	324	60	323	126	116	2	910.478
3	1.26	1.122	1.35	170	321	59	324	126	119	2	917.196
1	1.49	1.221	1.58	169	326	62	327	120	116	2	924.401
2	1.34	1.158	1.44	168	322	61	325	126	118	2	931.423
3	1.20	1.095	1.29	169	322	61	325	127	116	2	937.973
Stop	1007										
AVG		(1.158)	(1.43)	(168.33)				(118.458)	2		(83.217)
											cuff.

Pitot Tube Leak Check: Before OK After OK
 Integrated Bag Leak Check: Before OK After OK



Client JEA / S.J.R.P.P.						Date 8-15-95		Page 1 of 2			
Project No. 95-058 FL			Operator HARLEY C. O'NEILL			Orsat Analysis					
Sampling Location Unit 1 Stack					Run No. 2	CO ₂	+ O ₂	O ₂	CO		
Filter No. 95-032 FL		Acetone No. -		Condensate 18.1 266 ML		14.0	5.2				
Barometric Pressure 30.16			Static Pressure - .54		Probe Number N-10-6-1F						
Nozzle Diameter .187		Nozzle Number FL3		Pitot Coefficient .875		Pitot Number N-10-6-11F					
Meter Corr. Factor .996			Meter-Orifice 2.999								
Sample Pt. Time 10 min		Assumed % Moisture 11%			Leak Test		Before .000 @ 15" HG		After .002 @ "HG		
Sample Point	ΔP	$\sqrt{\Delta P}$	ΔH	Stack	Probe	Imp. Out	Oven	Meter In	Meter Out	Vac. Pr (in. HG)	Dry Gas Meter Reading in Cu. Ft.
START	1035										938.168
1	1.53	1.237	1.60	168	321	59	327	119	114	2	945.472
2	1.43	1.196	1.51	164	322	59	324	115	111	2	952.763
3	1.31	1.145	1.40	166	324	61	323	122	115	2	959.602
1	1.51	1.229	1.58	169	327	61	324	116	114	2	967.082
2	1.47	1.212	1.57	166	325	62	325	123	115	2	974.320
3	1.30	1.140	1.39	167	324	60	325	125	116	2	981.318
1	1.52	1.233	1.61	167	326	62	324	120	119	2	988.601
2	1.45	1.209	1.53	166	327	62	327	126	115	2	995.756
3	1.30	1.140	1.38	166	328	59	324	126	117	2	1002.530
1	1.52	1.233	1.61	167	328	59	323	114	114	2	1009.855
2	1.44	1.200	1.53	167	322	59	324	123	115	2	1016.970
3	1.29	1.136	1.37	164	320	60	329	127	116	2	1023.720
Stop	1240										
AVG		(1.192)	(1.51)	(166.92)				(117.917)	(112)		(85.552) Cuf.

Pitot Tube Leak Check: Before OK After OK
 Integrated Bag Leak Check: Before OK After OK

Client JEA / SJRPP						Date 8-15-95		Page 1 of 2			
Project No. 95-058 FL			Operator HARLEY C. O'NEILL			Orsat Analysis					
Sampling Location UNIT 1 STACK					Run No. 3	CO ₂	+ O ₂ %	O₂	CO		
Filter No. 95-033 FL		Acetone No. -		Condensate 256 ML		19.7	14.3	4.8			
Barometric Pressure 30.16		Static Pressure -.54		Probe Number N-10-G-1F							
Nozzle Diameter .187		Nozzle Number PL3		Pitot Coefficient .875		Pitot Number N-10-G-11F					
Meter Corr. Factor .996		Meter-Orifice 2.999									
Sample Pt. Time 10 min		Assumed % Moisture 11%		Leak Test		Before .000 1546		After .00 42" H₂O			
Temperature °F											
Sample Point	ΔP	√ΔP	ΔH	Stack	Probe	Imp. Out	Oven	Meter In	Meter Out	Vac. Pr (in. HG)	Dry Gas Meter Reading in Cu. Ft.
Start	1315										029.983
1	1.52	1.233	1.61	165	321	61	324	112	113	2	032.308
2	1.43	1.196	1.51	164	327	60	323	116	113	2	039.425
3	1.31	1.145	1.39	162	324	60	323	124	116	2	046.241
1	1.50	1.225	1.59	167	319	59	324	115	115	2	053.524
2	1.39	1.179	1.47	169	320	63	324	122	116	2	060.533
3	1.25	1.118	1.32	169	322	63	320	127	119	2	067.180
1	1.51	1.229	1.60	165	321	62	324	115	115	2	074.481
2	1.42	1.192	1.50	167	324	63	324	119	115	2	081.571
3	1.31	1.145	1.39	164	323	60	325	126	119	2	088.385
1	1.52	1.233	1.61	170	331	61	327	114	113	2	095.720
2	1.43	1.196	1.51	169	330	59	321	117	115	2	102.820
3	1.31	1.145	1.41	169	331	62	324	125	120	2	109.675
Stop	1525										
AUG		6.186	(1.49)	(166.75)			(122.500)	112	(184.692)		cuft.

Pitot Tube Leak Check: Before OK After OK
 Integrated Bag Leak Check: Before OK After OK

Client JEA / S.J.R.P.P.						Date 8-16-95		Page 1 Of 2			
Project No. 95-058FL			Operator WIMLEY C. O'NEILL			Orsat Analysis CO ₂ +O ₂ O ₂ CO					
Sampling Location Unit 1 STACK				Run No. 1							
Filter No. 95-034FL		Acetone No. -		Condensate 235 ml		11.6		14.3		5.0	
Barometric Pressure 30.15			Static Pressure -.88		Probe Number N-10-G-11F						
Nozzle Diameter .187		Nozzle Number FL3		Pitot Coefficient .875		Pitot Number N-10-G-1F					
Meter Corr. Factor .996			Meter-Orifice 2.999								
Sample Pt. Time 60 min 120 min test			Assumed % Moisture 13%			Leak Test		Before .000 @ 15" HG		After .000 @ 2" HG	
Sample Point	ΔP	√ΔP	ΔH	Temperature °F						Vac. Pr (in. HG)	Dry Gas Meter Reading in Cu. Ft.
				Stack	Probe	Imp. Out	Oven	Meter In	Meter Out		
Start	0800										110.994
1	1.50	1.225	1.54	169	324	62	322	112	112	2	117.295
2	1.41	1.187	1.41	169	322	58	324	116	112	2	124.055
3	1.29	1.136	1.31	167	322	59	324	122	115	2	130.230
1	1.47	1.212	1.49	167	324	59	323	115	115	2	137.135
2	1.35	1.162	1.37	168	325	60	322	124	115	2	143.774
3	1.18	1.086	1.21	167	324	60	321	127	116	2	150.280
1	1.52	1.233	1.54	165	327	59	322	116	116	2	157.310
2	1.35	1.162	1.37	166	324	59	322	127	116	2	164.028
3	1.09	1.044	1.10	167	325	60	321	126	116	2	170.642
1	1.55	1.245	1.56	167	324	61	322	116	116	2	177.862
2	1.38	1.175	1.416	167	323	61	324	125	117	2	183.995
3	1.11	1.054	1.144	164	323	61	324	126	116	2	190.545
Stop	1025										
AVG		(1.110)	(1.25)	(166.92)				(118.083)	112	2	(79.551) cuft.

Pitot Tube Leak Check: Before OK After OK
 Integrated Bag Leak Check: Before OK After OK



BEST AVAILABLE COPY

Client JEA / S.J.R.P.P.				Date 8-16-95	Page 1 Of 2
Project No. 95-058 FL		Operator HARLEY C. O'NEILL		Orsat Analysis CO ₂ + O ₂ O ₂ CO	
Sampling Location Unit 1 Stack			Run No. 2		
Filter No. 95-035 FL	Acetone No. -	Condensate 235 ML 21.4		14.2	4.8
Barometric Pressure 30.15		Static Pressure -.88	Probe Number N-10-G-1F		
Nozzle Diameter .187	Nozzle Number FL3	Pitot Coefficient .875	Pitot Number N-10-G-11F		
Meter Corr. Factor .996		Meter-Orifice 2.999			

Sample Pt. Time 10 min 120 min test		Assumed % Moisture 13%		Leak Test .000 @ 15" HG .000 @ 2" HG	
--	--	----------------------------------	--	---	--

Sample Point	ΔP	√ΔP	ΔH	Temperature °F						Vac. Pr (in. HG)	Dry Gas Meter Reading in Cu. Ft.
				Stack	Probe	Imp. Out	Oven	Meter In	Meter Out		
Start	1045										191.396
1	1.51	1.229	1.52	167	322	60	320	116	116	2	198.601
2	1.43	1.196	1.47	164	320	61	321	124	116	2	205.625
3	1.31	1.145	1.35	164	324	63	323	124	116	2	212.331
1	1.50	1.225	1.52	163	324	63	324	116	116	2	219.459
2	1.41	1.187	1.43	163	319	60	327	117	116	2	226.371
3	1.32	1.149	1.36	168	322	61	330	126	119	2	233.120
1	1.49	1.221	1.49	169	324	62	329	115	114	2	240.160
2	1.30	1.140	1.31	170	327	60	327	119	115	2	246.754
3	1.26	1.122	1.29	171	326	60	327	125	116	2	253.320
1	1.49	1.221	1.49	169	327	59	325	115	114	2	260.370
2	1.32	1.149	1.34	169	326	58	324	122	116	2	267.060
3	1.22	1.105	1.26	169	329	58	328	126	120	2	273.541
Stop	1250										
AVG		(1.174)	(1.40)	(167.17)				(118.297)		2	(22.145) cu-ft.

Pitot Tube Leak Check: Before OK After OK
 Integrated Bag Leak Check: Before OK After OK



Client J.E.A. / S.J.R.P.P.			Date 8-16-95		Page 1 of 2	
Project No. 95-058 FL		Operator HARLEY C. O'NEILL			Orsat Analysis	
Sampling Location Unit 1 Stack			Run No. 3		CO ₂ + O ₂ O ₂ CO	
Filter No. 95-036 FL		Acetone No. -		Condensate 244 mL		20.4 14.1 4.9
Barometric Pressure 30.15		Static Pressure -.88		Probe Number N-10-6-1F		
Nozzle Diameter .187	Nozzle Number FL3	Pitot Coefficient .875		Pitot Number N-10-6-11F		
Meter Corr. Factor .996		Meter-Orifice 2.999				

Sample Pt. Time 10 min 120 min test		Assumed % Moisture 13%		Leak Test		Before .000 @ 15"		After .000 @ "HG	
--	--	----------------------------------	--	-----------	--	-----------------------------	--	----------------------------	--

Sample Point	ΔP	√ΔP	ΔH	Temperature °F						Vac. Pr (in. HG)	Dry Gas Meter Reading in Cu. Ft.
				Stack	Probe	Imp. Out	Oven	Meter In	Meter Out		
Start	1325										273.700
1	1.51	1.229	1.51	169	321	59	325	115	115	2	280.820
2	1.42	1.192	1.45	168	320	60	322	123	117	2	287.790
3	1.29	1.136	1.32	168	322	61	322	123	118	2	294.421
1	1.50	1.225	1.53	167	321	60	327	116	116	2	301.567
2	1.40	1.183	1.43	169	322	61	328	121	116	2	308.470
3	1.29	1.136	1.32	170	328	62	328	126	119	2	315.120
1	1.50	1.225	1.54	164	327	60	325	116	116	2	322.290
2	1.39	1.179	1.43	168	325	59	321	126	118	2	329.213
3	1.26	1.122	1.31	164	323	60	320	127	119	2	335.821
1	1.51	1.229	1.52	167	322	61	322	116	116	2	342.981
2	1.40	1.183	1.44	165	327	62	327	123	118	2	349.601
3	1.12	1.058	1.15	165	322	60	329	126	118	2	355.795
Stop	1537	1.175	1.41	167.00				119	333	2	382.095
											cuft.
Avg.											

Pitot Tube Leak Check: Before OK After OK
 Integrated Bag Leak Check: Before OK After OK



Client JEA / SJRPP				Date 8-17-95	Page 1	Of 2
Project No. 95-058 FL		Operator HARLEY C. O'NEILL		Orsat Analysis		
Sampling Location Unit 1 Stack			Run No. 1	CO ₂	+ O ₂	O ₂ CO
Filter No. 95-037 EF	Acetone No. -	Condensate 250 ML		14.2	5.1	
Barometric Pressure 30.19		Static Pressure - .83	Probe Number N-10-G-1F			
Nozzle Diameter .187	Nozzle Number FL 3	Pitot Coefficient .875	Pitot Number N-10-G-11F			
Meter Corr. Factor .996		Meter-Orifice 2.999				

Sample Pt. Time 10min 120min TEST	Assumed % Moisture 13%	Leak Test	Before .000 @ 15" Hg	After .00 @ 2" Hg
---	----------------------------------	-----------	--------------------------------	-----------------------------

Sample Point	ΔP	√ΔP	ΔH	Temperature °F						Vac. Pr (in. HG)	Dry Gas Meter Reading in Cu. Ft.
				Stack	Probe	Imp. Out	Oven	Meter In	Meter Out		
Start	0800										355.942
1	1.51	1.229	1.51	168	321	61	325	114	114	2	363.151
2	1.40	1.183	1.40	168	322	61	324	115	114	2	369.902
3	1.24	1.114	1.26	167	323	62	323	120	116	2	376.481
4	1.53	1.237	1.53	168	322	60	323	115	115	2	383.476
2	1.38	1.175	1.40	168	324	60	322	124	115	2	390.301
3	1.05	1.025	1.07	169	327	60	321	125	115	2	396.435
1	1.52	1.233	1.52	169	327	61	321	115	115	2	403.407
2	1.40	1.183	1.44	165	323	60	322	124	119	2	410.239
3	1.11	1.054	1.15	164	324	59	324	125	119	2	416.987
1	1.53	1.237	1.54	167	325	59	324	115	115	2	424.000
2	1.40	1.183	1.44	168	324	60	327	126	119	2	430.821
3	1.19	1.091	1.22	168	325	61	328	127	119	2	437.215
Stop	1010										
Avg		(1.161)	(1.371)	(167.42)				(118.333)	(112)		(81.273) cuft.

Pitot Tube Leak Check: Before OK After OK
 Integrated Bag Leak Check: Before OK After OK



Particulate Field Data Sheet

Client JEA / S.J.R.P.P.						Date 8-17-95						Page 1 Of 2			
Project No. 95-058 FL				Operator HARLEY C. O'NEILL				Orsat Analysis							
Sampling Location Unit 1 Stack						Run No. 2		CO₂		+ O₂		O₂		CO	
Filter No. 95-038 FL		Acetone No.		Condensate 233 mL				14.3		4.8					
Barometric Pressure 30.19				Static Pressure -1.83		Probe Number N-10-G-1F									
Nozzle Diameter .187		Nozzle Number FL3		Pitot Coefficient .875		Pitot Number N-10-G-11F									
Meter Corr. Factor .996				Meter-Orifice 2.999											
Sample Pt. Time 10min 120min Test			Assumed % Moisture 13%			Leak Test		Before .000 15" HG		After .000 2" HG					
Sample Point	ΔP	√ΔP	ΔH	Temperature °F						Vac. Pr (in. HG)	Dry Gas Meter Reading in Cu. Ft.				
				Stack	Probe	Imp. Out	Oven	Meter In	Meter Out						
Start	1035												437.336		
1	1.50	1.225	1.50	168	321	61	324	115	115	2			444.417		
2	1.39	1.179	1.41	168	322	61	327	121	116	2			451.246		
3	1.21	1.100	1.24	169	322	60	329	126	120	2			457.667		
1	1.55	1.245	1.59	164	321	62	329	116	116	2			464.901		
2	1.41	1.187	1.44	165	322	61	325	123	117	2			471.840		
3	1.21	1.100	1.25	165	323	61	327	126	120	2			478.320		
1	1.51	1.229	1.52	166	324	64	329	116	115	2			485.420		
2	1.45	1.204	1.46	166	324	63	328	126	116	2			492.392		
3	1.50	1.225	1.54	166	325	64	328	125	116	2			499.550		
1	1.48	1.217	1.52	165	322	65	321	126	116	2			506.673		
2	1.40	1.183	1.44	164	322	65	326	127	116	2			513.590		
3	1.24	1.114	1.28	163	320	66	320	126	116	2			520.119		
Stop	1245														
AUG		(1.184)	(1.43)	(1.675)				(120.083)	12				(82.783) cu ft.		

Pitot Tube Leak Check: Before OK After OK
 Integrated Bag Leak Check: Before OK After OK



BEST AVAILABLE COPY

Client JEA / SJR.P.P.			Date 8-17-95		Page 1 Of 2
Project No. 95-058 FL		Operator HARLEY C. O'NEILL			Orsat Analysis
Sampling Location Unit 1 Stack			Run No. 3		
Filter No. 95-039 FL	Acetone No. -	Condensate 240 ml		21.6	CO ₂ + O ₂ O ₂ CO
Barometric Pressure 30.19		Static Pressure .83		Probe Number N-10-G-1F	
Nozzle Diameter .187	Nozzle Number FL 3	Pitot Coefficient .875		Pitot Number N-10-G-11F	
Meter Corr. Factor .996		Meter-Orifice 2.999			

Sample Pt. Time 10 min	Assumed % Moisture 120 min TEST	Assumed % Moisture 13%	Leak Test	Before .000 @ 15" HG	After .000 @ 5" HG
----------------------------------	---	----------------------------------	-----------	--------------------------------	------------------------------

Sample Point	ΔP	√ΔP	ΔH	Temperature °F						Vac. Pr (in. HG)	Dry Gas Meter Reading in Cu. Ft.
				Stack	Probe	Imp. Out	Oven	Meter In	Meter Out		
Start	1315										520.226
1	1.51	1.229	1.51	168	324	61	327	115	115	2	527.331
2	1.42	1.192	1.42	167	327	60	324	119	115	2	534.201
3	1.29	1.136	1.29	167	325	58	324	126	118	2	540.760
1	1.50	1.225	1.50	169	324	59	325	116	115	2	547.841
2	1.39	1.179	1.39	171	324	60	324	119	116	2	556.663
3	1.19	1.091	1.22	170	322	61	323	126	120	2	563.056
1	1.51	1.229	1.50	171	320	62	324	116	112	2	570.127
2	1.39	1.179	1.38	172	321	61	324	123	119	2	576.920
3	1.21	1.100	1.24	169	322	63	325	126	119	2	582.370
1	1.55	1.245	1.59	169	327	64	324	115	115	2	589.566
2	1.39	1.179	1.41	169	327	62	325	121	116	2	596.463
3	1.01	1.005	1.04	169	324	64	327	127	121	2	602.375
Stop	1525										
Avg		(1.166 X 1.37 X 1.69.25)						(118.750)	12	2	(52.149) cu ft.

Total Tube Leak Check: Before OK After OK
 Integrated Bag Leak Check: Before OK After OK



Set 19

SO₂ Field Data Sheet

BEST AVAILABLE COPY

Client J.E.A. S.J.R.P.P.						Date 8-18-95						Page 1 Of 2			
Project No. 95-058-FL.				Operator HARLEY C. O'NEILL				Orsat Analysis							
Sampling Location Unit # 1 Stack				Run No. 1		CO ₂		CO		O ₂		CO			
Filter No. N/A		Acetone No. -		Condensate 58.5ml		24.80		14.23		-		5.00			
Barometric Pressure 30.19				Static Pressure .76		Probe Number N-10-G-1F									
Nozzle Diameter .187		Nozzle Number FL 3		Pitot Coefficient .875		Pitot Number N-10-G-11F									
Meter Corr. Factor .996				Meter-Orifice 2.999											
Sample Pt. Time 5min 60min Test.				Assumed % Moisture 13%				Leak Test Before .000 @ 15" Hg				After .000 @ "Hg			
Sample Point	ΔP	√ΔP	ΔH	Temperature °F						Vac. Pr (in. HG)	Dry Gas Meter Reading in Cu. Ft.				
				Stack	Probe	Imp. Out	Oven	Meter In	Meter Out						
Start	0500											602.909			
1	1.53	1.237	1.42	167	324	59	327	95	95	7	606.209				
2	1.39	1.179	1.30	164	323	60	329	95	94	7	609.529				
3	1.01	1.005	0.95	163	324	60	325	95	94	7	612.529				
1	1.51	1.229	1.42	163	323	61	324	96	95	7	615.670				
2	1.30	1.140	1.23	164	320	60	324	100	96	7	618.779				
3	1.03	1.015	0.98	165	321	58	326	102	96	7	621.635				
1	1.52	1.233	1.44	165	322	59	327	100	96	7	625.848				
2	1.23	1.109	1.18	163	321	58	326	104	96	7	628.009				
3	1.01	1.005	0.96	166	324	59	327	106	96	7	630.963				
1	1.52	1.233	1.44	165	322	59	327	100	96	7	634.135				
2	1.31	1.145	1.25	165	320	61	327	102	96	7	637.296				
3	1.04	1.020	0.99	168	325	60	324	104	96	7	640.162				
Stop	0910														
AV →				(1.129)(1.21)(16517)			(97.708)			1.7		(37.253) Cu./Ft.			
ISA = 94.9%															
moisture = 9.9%															
SO ₂ ppm = 7.39															

Pitot Tube Leak Check: Before OK After OK
 Integrated Bag Leak Check: Before OK After OK



E22

Set 26

S03 Field Data Sheet

BEST AVAILABLE COPY

Client J.E.A. S.J.R.P.P.			Date 8-18-95	Page 1	Of 2
Project No. 95-058-FL.		Operator HARLEY C. O'NEILL		Orsat Analysis	
Sampling Location Unit # 1 Stack			Run No. 2	CO ₂	+ O ₂
Filter No. N/A	Acetone No. -	Condensate 66.0 ml		24.45 g	5g
Barometric Pressure 30.19		Static Pressure .76	Probe Number N-10-G-1F	14.28	5.05
Nozzle Diameter .187	Nozzle Number FL3	Pitot Coefficient .875	Pitot Number N-10-G-11F		
Meter Corr. Factor .996		Meter-Orifice 2.999			

Sample Pt. Time 5min 60min TEST.	Assumed % Moisture 13%	Leak Test Before .002 @ 15" H After .002 @ 7" HG
-------------------------------------	---------------------------	--

Sample Point	ΔP	√ΔP	ΔH	Temperature °F						Vac. Pr (in. HG)	Dry Gas Meter Reading in Cu. Ft.
				Stack	Probe	Imp. Out	Oven	Meter In	Meter Out		
Start	0950										650.164
1	1.51	1.229	1.42	164	327	58	325	95	95	6	653.493
2	1.38	1.175	1.36	163	327	56	324	111	107	7	656.777
3	1.29	1.136	1.28	163	326	56	324	115	106	7	660.038
1	1.51	1.229	1.48	166	326	57	329	110	108	7	663.302
2	1.29	1.136	1.28	166	326	57	337	112	109	7	666.500
3	1.15	1.072	1.11	167	323	59	330	118	110	7	669.694
1	1.52	1.233	1.49	166	324	60	331	110	106	7	673.005
2	1.36	1.166	1.30	166	325	63	330	115	111	7	676.161
3	1.14	1.068	1.15	165	327	64	329	121	112	7	679.263
1	1.50	1.225	1.44	166	325	62	329	112	112	7	682.495
2	1.31	1.145	1.30	166	327	60	327	121	112	7	685.554
3	1.15	1.072	1.16	167	324	61	326	122	113	7	688.669
Stop	1100										

AV → (1.157) (1.32) (165.42) (110.88) 16.9 (38.505) Cu./Ft.

ISO = 94.1 %
moisture = 10.6 %

S03 ppm = 10.6 %

Pitot Tube Leak Check: Before OK After OK

Integrated Bag Leak Check: Before OK After OK



E23

Set 21

SO₃ Field Data Sheet

BEST AVAILABLE COPY

Client J.E.A. S.J.R.P.P.						Date 8-10-95						Page 1 of 2			
Project No. 95-058-FL.				Operator HARLEY C. O'NEILL				Orsat Analysis							
Sampling Location Unit # 1 Stack				Run No. 3		CO ₂		+O ₂ 3A		O ₂		CO			
Filter No. N/A		Acetone No. -		Condensate 49.0ml 26.5g				14.25		5.04					
Barometric Pressure 30.19				Static Pressure .76		Probe Number N-10-G-1F									
Nozzle Diameter .187		Nozzle Number FL 3		Pitot Coefficient .875		Pitot Number N-10-G-11F									
Meter Corr. Factor .996				Meter-Orifice 2.999											
Sample Pt. Time 5min 60min Test.				Assumed % Moisture 13%				Leak Test				Before .008 @ "HG		After .004 @ "HG	
Sample Point	ΔP	√ΔP	ΔH	Temperature °F						Vac. Pr (in. HG)	Dry Gas Meter Reading in Cu. Ft.				
				Stack	Probe	Imp. Out	Oven	Meter In	Meter Out						
Start	1135											696.583			
1	1.50	1.225	1.39	169	321	59	327	95	95	7		699.773			
2	1.37	1.170	1.37	169	319	61	326	116	114	7		703.200			
3	1.15	1.072	1.15	169	322	62	323	116	113	7		706.102			
1	1.51	1.229	1.60	164	324	60	326	117	114	7		709.305			
2	1.31	1.145	1.32	163	322	61	327	115	114	7		712.511			
3	1.21	1.100	1.22	163	325	62	324	115	116	7		715.714			
1	1.54	1.241	1.55	165	324	62	326	116	115	7		719.002			
2	1.33	1.153	1.36	165	327	60	329	121	116	7		722.029			
3	1.25	1.118	1.28	167	324	61	327	123	118	7		725.292			
1	1.50	1.225	1.51	167	327	62	325	115	115	7		728.760			
2	1.31	1.145	1.33	168	326	60	329	121	115	7		732.041			
3	1.10	1.049	1.12	165	321	59	327	121	115	7		735.060			
Stop	1240														
AVG		(1.156)	(1.35)	(166.17)				(114.63)		17		(38.477) Cu./Ft.			
ISO = 92.3															
moisture = 9.1%															
SO ₃ ppm = 12.73															

Pitot Tube Leak Check: Before OK After OK
 Integrated Bag Leak Check: Before OK After OK



Client JEA / SJRPP.			Date 8-19-95	Page 2 of 2
Project No. 95-058 FL		Operator J. Keith		Orsat Analysis CO ₂ + O ₂ O ₂ CO
Sampling Location Unit 1 Stack			Run No. 1	
Filter No. 95-040 FL	Acetone No.	Condensate 190 mls		
Barometric Pressure 30.28		Static Pressure -.71	Probe Number N-10-G-1F	
Nozzle Diameter .187	Nozzle Number FL3	Pitot Coefficient .875	Pitot Number N-10-G-11F	
Meter Corr. Factor .996		Meter-Orifice 2.999		

Sample Pt. Time 10 min 120 min test	Assumed % Moisture 13%	Leak Test Before .007 @ 12" H ₂ O After .006 @ 11" H ₂ O
--	---------------------------	--

Sample Point	ΔP	√ΔP	ΔH	Temperature °F						Vac. Pr (in. HG)	Dry Gas Meter Reading in Cu. Ft.
				Stack	Probe	Imp. Out	Oven	Meter In	Meter Out		
Start	08:00										746.584
C 1	1.5	1.225	1.54	153	320	62	340	10.8	1.0	753.82	
2	1.3	1.140	1.34	158	332	63	342	10.6	1.0	760.49	
3	1.2	1.095	1.24	155	330	62	337	10.7	1.0	766.89	
B 1	1.5	1.225	1.54	154	326	63	342	10.5	1.0	774.01	
2	1.4	1.183	1.44	156	340	64	335	10.7	1.0	780.94	
3	1.1	1.049	1.13	153	339	65	334	11.0	1.0	787.13	
A 1	1.5	1.225	1.54	154	327	65	330	11.1	1.5	794.30	
2	1.4	1.183	1.44	154	338	66	336	11.2	1.5	801.23	
3	1.2	1.095	1.24	152	330	66	329	11.3	1.0	807.62	
D 1	1.4	1.183	1.44	153	327	64	333	11.6	1.5	814.57	
2	1.4	1.183	1.44	154	325	65	340	11.6	1.5	821.47	
3	1.2	1.095	1.24	153	332	65	335	11.7	1.0	827.910	
Stop	10:15										
AVG		(1.157)	(1.38)	(1.54)				(11.1)		(81.337)	CuFt.

Hot Tube Leak Check: Before OK After OK
 Integrated Bag Leak Check: Before OK After OK



Client JEA / S.J.R.P.P.						Date 8-19-95		Page 1 of 2			
Project No. 95-058FL			Operator J. KEHL			Orsat Analysis					
Sampling Location UNIT 1 STACK					Run No. 2	CO ₂	+ O ₂	O ₂	CO		
Filter No. 95-041FL		Acetone No.		Condensate 200 m.l.s 17.3		14.3		5.2			
Barometric Pressure 30.28			Static Pressure -.74		Probe Number N-10-G-1F						
Nozzle Diameter .187		Nozzle Number FL 3		Pitot Coefficient .875		Pitot Number N-10-G-11F					
Meter Corr. Factor .996			Meter-Orifice 2.999								
Sample Pt. Time 10 min			Assumed % Moisture 17%			Leak Test		Before .005 @ 12" H₂O	After .005 @ 12" H₂O		
Sample Point	ΔP	√ΔP	ΔH	Temperature °F						Vac. Pr (in. HG)	Dry Gas Meter Reading in Cu. Ft.
				Stack	Probe	Imp. Out	Oven	Meter In	Meter Out		
Start	10:38										828.129
D	1.5	1.225	1.53	153	329	63	339	115	115	2.0	835.29
	1.4	1.183	1.43	154	335	63	330	116	116	2.0	842.17
	1.1	1.049	1.12	153	340	64	334	116	116	1.5	848.31
A	1.4	1.183	1.52	155	334	63	330	120	120	2.0	855.40
	1.4	1.183	1.52	154	340	64	327	121	121	2.0	862.53
	1.2	1.095	1.30	154	335	65	333	122	122	1.5	869.11
B	1.5	1.225	1.63	154	341	65	329	122	122	2.0	876.51
	1.4	1.183	1.52	154	338	65	332	121	121	2.0	883.60
	1.2	1.095	1.30	152	334	66	337	122	122	1.5	890.22
C	1.4	1.183	1.52	154	329	66	334	123	123		897.32
	1.5	1.225	1.63	154	331	65	338	124	124	2.0	904.66
	1.2	1.095	1.30	153	336	66	330	123	123	2.5	911.278
Stop	12:56									2.0	
Avg		(1.160)	(1.44)	(154)				(120)			(83.156) cuft.

Pitot Tube Leak Check: Before OK After OK
 Integrated Bag Leak Check: Before OK After OK



Client JEA / S.J.R.P.P.		Date 8-19-95		Page 1 of 2	
Project No. 95-058 FL		Operator J. KEHL		Orsat Analysis CO ₂ + O ₂ + O ₂ CO 14.4 4.4	
Sampling Location UNIT 1 Stack			Run No. 3		
Filter No. 95-042 FL		Acetone No.		Condensate 215 mls 15.8	
Barometric Pressure 30.28		Static Pressure -.74		Probe Number N-10-G-1F	
Nozzle Diameter .187		Nozzle Number FL3		Pitot Coefficient .875	
Meter Corr. Factor .996		Meter-Orifice 2.999		Pitot Number N-10-6-11F	

Sample Pt. Time 10 min. 120 min test	Assumed % Moisture 1.5%	Leak Test .008 @ 13" H₂O	Before	After
			.007 @ 11" H₂O	

Sample Point	ΔP	√ΔP	ΔH	Temperature °F						Vac. Pr (in. HG)	Dry Gas Meter Reading in Cu. Ft.
				Stack	Probe	Imp. Out	Oven	Meter In	Meter Out		
Start	13:16										911.814
C 1	1.5	1.225	1.63	154	321	61	330	11	6	2.5	919.16
2	1.4	1.183	1.52	154	328	61	336	11	7	2.5	926.31
3	1.1	1.049	1.19	153	332	62	332	11	9	2.0	932.64
B 1	1.5	1.225	1.63	154	329	63	335	12	0	2.5	939.98
2	1.4	1.183	1.52	155	333	62	340	12	0	2.5	947.09
3	1.2	1.095	1.30	154	338	63	337	12	1	2.0	953.71
A 1	1.4	1.183	1.52	154	340	62	334	12	1	2.5	960.83
2	1.4	1.183	1.52	155	338	62	330	12	2	2.5	967.91
3	1.2	1.095	1.30	152	336	63	329	12	1	2.5	978.54
D 1	1.5	1.225	1.63	154	331	63	331	12	2	2.5	985.87
2	1.4	1.183	1.52	154	329	64	334	12	3	2.5	992.95
3	1.2	1.095	1.30	153	325	63	329	12	3	2.0	999.551
Stop	13:32										
Avg		(1.160)	(1.46)	(154)				(12.0)			(987.737) cuft.

Pitot Tube Leak Check: Before OK After OK
 Integrated Bag Leak Check: Before OK After OK



E27

TSA CEMS Log

Client : JEA SJRPP
Site : 0000
Unit : 1
Project : 95-058
Instrument : Run #1
Test Date : 8/11/95

Time : 08:15 thru 09:15:06

Time	1030 O2 %	1029 CO2 %	1028 CO PPm
8:15:59	4.74	14.29	357.22
8:16:59	4.79	14.25	320.82
8:17:59	5.07	14.03	199.32
8:18:59	4.98	14.08	218.01
8:19:59	4.70	14.36	278.66
8:20:59	4.48	14.45	796.51
8:21:59	5.09	13.95	409.58
8:22:59	5.14	14.00	169.02
8:23:59	4.42	14.50	765.53
8:24:59	5.15	13.87	594.63
8:25:59	5.24	13.92	124.26
8:26:59	4.44	14.50	819.94
8:27:59	5.03	13.98	531.32
8:28:59	5.34	13.81	128.52
8:29:58	4.50	14.49	573.56
8:30:58	4.72	14.32	433.54
8:31:58	4.77	14.27	473.64
8:32:58	5.32	13.85	259.03
8:33:58	4.60	14.42	585.77
8:34:58	4.78	14.29	368.36
8:35:58	4.99	14.11	184.48
8:36:58	5.15	14.00	92.87
8:37:58	4.54	14.46	808.72
8:38:58	5.05	14.06	263.62
8:39:58	4.79	14.29	204.39
8:40:58	4.75	14.31	501.98
8:41:58	5.22	13.93	238.51
8:42:58	4.98	14.14	170.44
8:43:58	4.79	14.27	303.33
8:44:58	4.93	14.15	487.47
8:45:58	4.88	14.19	345.25
8:46:58	4.93	14.16	376.26
8:47:58	4.99	14.11	301.36
8:48:58	4.83	14.22	412.80
8:49:58	4.85	14.22	447.77
8:50:58	4.99	14.10	430.45
8:51:58	5.09	14.05	143.37
8:52:58	4.64	14.36	983.06
8:53:58	4.95	14.12	547.62
8:54:58	4.95	14.16	268.19
8:55:58	4.79	14.27	344.17
8:56:58	5.07	14.05	197.31
8:57:58	4.79	14.28	290.25
8:58:58	4.72	14.31	532.61
8:59:58	5.16	13.96	287.29
9:00:58	4.68	14.34	479.20

Client :JEA SJRPP
 Site :0000
 Unit : 1
 Project :95-058
 Comment : Run #1
 Test Date :8/11/95

Time :08:15 thru 09:15:06

Page 2

Time	1030 O2 %	1029 CO2 %	1028 CO PPm
09:01:58	4.83	14.24	451.56
09:02:58	4.79	14.25	521.89
09:03:58	4.91	14.14	401.67
09:04:58	4.87	14.18	515.00
09:05:58	4.87	14.20	286.29
09:06:58	4.74	14.30	509.98
09:07:58	4.86	14.17	377.35
09:08:58	4.75	14.28	433.56
09:09:58	4.94	14.13	342.23
09:10:58	4.91	14.17	282.34
09:11:58	4.73	14.32	439.45
09:12:58	4.80	14.25	516.76
09:13:58	5.03	14.07	280.22
09:14:58	4.86	14.19	255.60
09:15:06	4.84	14.22	267.26
Averages for 61 Points	4.87	14.18	392.31

$\bar{CO}_2 \rightarrow 4.918 \quad 14.343 \quad 399.068$

Client : JEA SJRPP
File : 0000
Unit : R 1
Project : 95-058
Document : Run 2
Start Date : 8/11/95

Time : 10:14 thru 11:14:30

Time	1030 O2 %	1029 CO2 %	1028 CO PPm
10:14:06	4.79	14.23	342.28
10:15:06	4.71	14.32	613.62
10:16:06	4.66	14.35	468.33
10:17:06	5.04	14.04	278.64
10:18:06	4.62	14.39	328.27
10:19:06	4.85	14.19	486.44
10:20:06	4.80	14.25	275.28
10:21:06	4.59	14.41	352.98
10:22:06	4.68	14.32	742.54
10:23:06	5.01	14.07	291.81
10:24:06	4.82	14.23	225.49
10:25:06	4.62	14.40	285.30
10:26:06	4.62	14.37	490.88
10:27:06	5.26	13.84	182.51
10:28:06	4.49	14.47	622.65
10:29:06	4.85	14.18	497.00
10:30:06	4.71	14.31	349.58
10:31:06	4.78	14.24	500.75
10:32:06	5.27	13.84	186.66
10:33:06	4.37	14.54	733.10
10:34:06	4.78	14.23	592.87
10:35:06	4.66	14.34	342.71
10:36:06	4.96	14.09	306.35
10:37:06	4.85	14.21	233.55
10:38:06	4.75	14.26	288.01
10:39:06	4.80	14.22	393.73
10:40:05	4.82	14.22	446.29
10:41:05	4.71	14.29	729.37
10:42:05	4.99	14.07	280.33
10:43:05	4.74	14.29	278.82
10:44:05	4.78	14.24	431.45
10:45:05	4.66	14.33	601.63
10:46:05	4.70	14.30	651.12
10:47:05	4.79	14.25	521.31
10:48:05	4.84	14.20	343.25
10:49:05	4.61	14.37	917.39
10:50:05	4.66	14.35	669.05
10:51:05	4.83	14.21	567.75
10:52:05	4.82	14.22	521.20
10:53:05	4.77	14.22	502.06
10:54:05	4.78	14.24	685.67
10:55:05	4.67	14.33	973.72
10:56:05	4.54	14.45	779.71
10:57:05	4.62	14.41	368.87
10:58:05	4.54	14.45	484.83
10:59:05	4.60	14.41	418.64

Client : JEA SJRPP
Site : 0000
Init : 1
Project : 95-058
Comment : Run#3
Test Date : 8/11/95

Time : 10:14 thru 11:14:30

Time	1030 O2 %	1029 CO2 %	1028 CO PPm
11:00:05	4.81	14.21	315.79
11:01:05	4.79	14.23	245.11
11:02:05	4.78	14.26	181.99
11:03:05	4.84	14.22	161.25
11:04:05	4.53	14.44	347.23
11:05:05	4.74	14.28	630.16
11:06:05	4.73	14.28	298.74
11:07:05	4.82	14.19	221.42
11:08:05	4.95	14.10	171.50
11:09:05	4.88	14.15	304.34
11:10:05	4.96	14.08	135.97
11:11:05	4.98	14.06	347.82
11:12:05	4.87	14.16	291.23
11:13:05	4.94	14.12	100.21
11:14:05	4.62	14.36	454.97

Averages
for 61
Points 4.77 14.25 422.81

avg 4.86 14.35 420.65

Client :JEA SJRPP
Site :0000
Unit : 1
Project :95-058
Comment : Run #3
Test Date :8/11/95

Time :12:13 thru 13:13:49

Page 1

Time	1030 02 %	1029 CO2 %	1028 CO PPm
12:13:09	4.77	14.19	139.36
12:14:09	4.73	14.23	188.61
12:15:09	4.80	14.17	201.37
12:16:09	4.86	14.10	245.91
12:17:09	4.74	14.22	179.88
12:18:09	5.02	13.92	261.53
12:19:08	4.72	14.18	388.79
12:20:08	4.74	14.19	181.49
12:21:08	4.78	14.17	128.57
12:22:08	5.06	13.93	62.03
12:23:08	4.72	14.23	122.55
12:24:08	4.79	14.16	155.42
12:25:08	4.97	14.00	88.90
12:26:08	5.00	13.96	44.93
12:27:08	4.81	14.15	40.99
12:28:08	4.80	14.15	65.05
12:29:08	5.07	13.87	85.80
12:30:08	4.62	14.31	153.49
12:31:08	4.74	14.17	299.35
12:32:08	4.99	13.96	169.65
12:33:08	4.85	14.12	107.57
12:34:08	4.72	14.22	118.58
12:35:08	4.94	14.02	143.46
12:36:08	4.95	13.98	160.59
12:37:08	4.80	14.16	107.12
12:38:08	4.75	14.15	200.36
12:39:08	4.98	13.97	145.38
12:40:08	4.87	14.08	103.67
12:41:08	5.07	13.90	94.91
12:42:08	5.09	13.89	26.00
12:43:08	5.01	13.96	145.27
12:44:08	5.05	13.92	124.36
12:45:08	4.89	14.06	184.25
12:46:08	4.97	14.00	169.53
12:47:08	5.10	13.90	170.53
12:48:08	4.81	14.14	208.01
12:49:08	5.09	13.90	181.67
12:50:08	5.05	13.95	72.91
12:51:08	5.01	13.98	91.75
12:52:08	4.98	14.02	65.05
12:53:08	5.05	13.92	154.53
12:54:08	4.81	14.17	97.85
12:55:08	5.00	14.00	102.27
12:56:08	4.82	14.15	108.04
12:57:08	4.83	14.16	82.86
12:58:08	5.00	14.01	73.77

Client :JEA SJRPP
 Site :0000
 Jnit : 1
 Project :95-058
 Comment : Run #3
 Test Date :8/11/95 Time :12:13 thru 13:13:49

Time	1030 O2 %	1029 CO2 %	1028 CO PPm
12:59:08	4.95	14.09	54.81
13:00:08	4.81	14.21	110.70
13:01:08	4.90	14.11	99.21
13:02:08	4.88	14.15	30.94
13:03:08	4.89	14.14	39.87
13:04:08	4.85	14.16	48.88
13:05:08	4.84	14.17	30.94
13:06:07	5.17	13.88	11.87
13:07:07	4.85	14.18	17.88
13:08:07	4.67	14.30	90.72
13:09:07	5.15	13.88	71.02
13:10:07	4.79	14.23	36.95
13:11:07	4.66	14.30	122.56
13:12:07	5.08	13.91	65.12
13:13:07	4.97	14.10	31.84
13:13:49	4.64	14.34	113.62

Averages
 for 62
 Points 4.89 14.08 119.69

\bar{e} gas 5.01 14.11 119.43

Client : JEA SJRPP
File : 0000
Unit : Run 1
Project : 95-058
Document : Unit # 1
Test Date : 8/12/95

BEST AVAILABLE COPY

Time : 08:00 thru 09:00:19

Time	1030 O2 %	1029 CO2 %	1028 CO PPm
08:00:31	4.90	14.24	487.66
08:01:31	4.97	14.16	424.52
08:02:31	5.03	14.13	395.20
08:03:31	4.87	14.24	617.70
08:04:31	5.02	14.12	727.42
08:05:31	5.30	13.91	367.98
08:06:31	5.04	14.14	366.46
08:07:31	5.21	14.00	331.26
08:08:31	5.60	13.63	135.65
08:09:31	5.30	13.97	78.79
08:10:31	4.58	14.47	1000.37
08:11:31	5.24	13.92	611.53
08:12:31	5.30	13.96	167.22
08:13:31	4.60	14.48	631.05
08:14:31	5.23	13.99	635.90
08:15:31	4.86	14.30	388.41
08:16:31	4.89	14.29	498.84
08:17:31	4.77	14.33	689.70
08:18:31	5.08	14.11	506.23
08:19:31	4.85	14.29	366.49
08:20:31	5.03	14.14	490.95
08:21:31	4.96	14.21	499.87
08:22:31	4.98	14.21	280.20
08:23:30	4.88	14.28	372.66
08:24:30	4.79	14.36	299.26
08:25:30	4.90	14.26	578.76
08:26:30	4.99	14.20	384.62
08:27:30	4.92	14.26	341.27
08:28:30	5.04	14.14	357.63
08:29:30	5.03	14.17	345.20
08:30:30	4.76	14.35	731.33
08:31:30	4.90	14.22	657.84
08:32:30	5.36	13.88	241.37
08:33:30	4.75	14.36	377.70
08:34:30	4.75	14.34	776.62
08:35:30	5.16	14.04	396.54
08:36:30	4.92	14.24	350.35
08:37:30	4.92	14.24	355.03
08:38:30	4.91	14.25	421.49
08:39:30	4.92	14.22	353.36
08:40:30	4.99	14.16	641.97
08:41:30	5.05	14.10	417.19
08:42:30	4.92	14.23	475.44
08:43:30	4.97	14.17	589.62
08:44:30	5.12	14.07	411.31
08:45:30	4.49	14.50	1000.37

Client : JEA SJRPP
 Site : 0000
 Unit : 1
 Project : 95-058
 Comment : Run 1.
 Test Date : 8/12/95 Time : 08:00 thru 09:00:19

Time	1030 O2 %	1029 CO2 %	1028 CO PPm
08:46:30	5.19	14.01	773.80
08:47:30	4.98	14.18	406.56
08:48:30	4.92	14.23	284.50
08:49:30	4.94	14.20	453.21
08:50:30	4.99	14.17	500.79
08:51:30	5.00	14.18	329.45
08:52:30	5.04	14.12	379.39
08:53:30	4.79	14.34	498.00
08:54:30	4.89	14.20	1000.52
08:55:30	5.09	14.12	351.24
08:56:30	4.84	14.28	490.00
08:57:30	5.12	14.06	261.67
08:58:30	4.96	14.22	220.20
08:59:30	4.85	14.28	347.28
09:00:19	5.01	14.14	446.29

Averages
 for 61
 Points 4.97 14.18 464.24

Tgas = 5.04 14.23 460.81

Client : JEA SJRPP
File : 0000
Unit : 1
Project : 95-058
Comment : Run 2
Test Date : 8/12/95

BEST AVAILABLE COPY

Time : 10:00 thru 11:00:16

Time	1030 O2 %	1029 CO2 %	1028 CO PPm
10:00:25	5.11	14.06	448.48
10:01:25	5.00	14.18	535.13
10:02:25	4.92	14.22	489.32
10:03:25	5.02	14.17	353.69
10:04:25	4.84	14.29	444.50
10:05:25	4.88	14.24	722.74
10:06:25	4.99	14.18	588.44
10:07:25	5.08	14.09	445.14
10:08:25	5.05	14.14	304.67
10:09:25	4.76	14.36	568.67
10:10:25	4.72	14.34	920.36
10:11:25	5.01	14.16	531.74
10:12:25	4.99	14.19	280.24
10:13:25	4.74	14.36	596.51
10:14:25	5.01	14.15	557.93
10:15:25	5.10	14.06	393.41
10:16:25	4.72	14.39	361.78
10:17:25	4.96	14.17	753.73
10:18:25	4.83	14.30	415.32
10:19:25	5.01	14.14	419.65
10:20:25	4.86	14.28	480.25
10:21:25	4.88	14.25	487.29
10:22:25	4.96	14.20	476.43
10:23:25	4.88	14.26	437.63
10:24:25	4.87	14.27	399.39
10:25:25	4.80	14.33	400.54
10:26:25	5.01	14.11	383.61
10:27:25	5.01	14.16	286.46
10:28:25	4.61	14.46	567.02
10:29:25	4.99	14.13	777.61
10:30:24	5.02	14.16	381.80
10:31:24	4.74	14.37	503.47
10:32:24	5.00	14.16	601.96
10:33:24	4.84	14.30	365.80
10:34:24	4.97	14.17	396.44
10:35:24	5.02	14.16	178.84
10:36:24	4.93	14.18	593.58
10:37:24	4.66	14.38	795.90
10:38:24	5.12	14.02	590.73
10:39:24	4.99	14.16	373.73
10:40:24	4.78	14.34	379.44
10:41:24	4.88	14.24	525.23
10:42:24	4.90	14.25	472.80
10:43:24	4.68	14.41	564.26
10:44:24	5.11	14.03	607.53
10:45:24	5.06	14.12	392.85

Client : JEA SJRPP
Site : 0000
Unit : 1
Project : 95-058
Comment : *Run 2*
Test Date : 8/12/95

Time : 10:00 thru 11:00:16

Time	1030 O2 %	1029 CO2 %	1028 CO PPm
10:46:24	4.73	14.38	438.40
10:47:24	4.81	14.30	608.64
10:48:24	5.02	14.12	345.48
10:49:24	4.81	14.30	505.38
10:50:24	4.99	14.17	503.89
10:51:24	4.93	14.22	334.34
10:52:24	4.84	14.27	470.51
10:53:24	4.95	14.20	382.02
10:54:24	4.91	14.22	441.49
10:55:24	4.92	14.23	504.88
10:56:24	4.91	14.23	407.45
10:57:24	4.89	14.21	781.21
10:58:24	4.87	14.26	422.65
10:59:24	4.82	14.27	459.32
11:00:16	4.81	14.33	395.34
Averages for 61 Points	4.91	14.22	484.47
<i>Gas =</i>	<i>4.98</i>	<i>14.22</i>	<i>481.31</i>

Client :JEA SJRPP
Site :0000
Unit : 1
Project :95-058
Comment : Run 3
Test Date :8/12/95

Best Available Copy

Time :11:50 thru 12:50:11

Time	1030 O2 %	1029 CO2 %	1028 CO PPm
11:50:05	4.83	14.31	636.96
11:51:05	5.05	14.13	312.46
11:52:05	4.90	14.27	188.68
11:53:05	4.74	14.36	497.58
11:54:05	4.82	14.31	572.30
11:55:05	4.74	14.40	442.32
11:56:05	4.81	14.31	767.35
11:57:05	4.74	14.36	665.58
11:58:05	4.84	14.27	552.79
11:59:05	4.75	14.38	366.59
12:00:05	4.92	14.25	534.74
12:01:05	4.74	14.37	558.60
12:02:05	4.87	14.25	651.78
12:03:05	4.85	14.29	416.38
12:04:05	4.82	14.34	442.52
12:05:05	4.92	14.23	469.56
12:06:05	5.07	14.09	273.65
12:07:05	4.74	14.40	320.62
12:08:05	4.82	14.28	635.80
12:09:05	5.24	13.96	248.54
12:10:05	4.62	14.50	305.45
12:11:05	4.57	14.50	1000.52
12:12:05	4.67	14.41	868.72
12:13:05	4.88	14.27	426.64
12:14:05	4.77	14.36	485.21
12:15:05	4.63	14.47	546.05
12:16:05	4.77	14.36	560.61
12:17:05	4.86	14.30	385.19
12:18:04	4.64	14.44	574.47
12:19:04	4.99	14.15	634.13
12:20:04	4.82	14.31	321.53
12:21:04	4.78	14.34	420.59
12:22:04	4.97	14.17	576.70
12:23:04	4.85	14.27	443.43
12:24:04	4.73	14.36	548.20
12:25:04	4.77	14.33	663.69
12:26:04	5.05	14.11	290.49
12:27:04	4.98	14.18	252.54
12:28:04	4.70	14.40	487.27
12:29:04	4.76	14.34	496.01
12:30:04	4.86	14.24	850.01
12:31:04	4.82	14.26	600.46
12:32:04	4.73	14.33	709.47
12:33:04	4.79	14.30	542.37
12:34:04	4.73	14.34	494.89
12:35:04	4.99	14.12	477.24

Client : JEA SJRPP
 Site : 0000
 Unit : 1
 Project : 95-058
 Comment : Run 3
 Test Date : 8/12/95

Time : 11:50 thru 12:50:11

Time	1030 O2 %	1029 CO2 %	1028 CO PPm
12:36:04	4.72	14.38	356.33
12:37:04	4.67	14.36	855.23
12:38:04	4.94	14.13	1000.37
12:39:04	4.81	14.29	508.22
12:40:04	4.69	14.36	894.74
12:41:04	4.86	14.20	915.81
12:42:04	4.76	14.30	789.37
12:43:04	4.99	14.14	422.99
12:44:04	4.82	14.29	370.60
12:45:04	4.72	14.33	845.52
12:46:04	4.88	14.22	475.06
12:47:04	4.90	14.19	507.23
12:48:04	4.71	14.35	521.21
12:49:04	4.60	14.42	929.50
12:50:04	4.97	14.12	718.00
12:50:11	5.01	14.09	632.67

Averages
 for 62
 Points 4.82 14.28 552.57

$\bar{x}_{95} = 4.93 \quad 14.18 \quad 550.61$

Client : JEA SJRPP
File : 0000
Unit :
Project : 95-058
Document : Run 1
Start Date : 8/13/95

BEST AVAILABLE COPY

Time : 08:00 thru 09:00:14

Time	1030 O2 %	1029 CO2 %	1028 CO PPm
08:00:07	5.21	14.11	432.46
08:01:07	5.07	14.22	610.68
08:02:07	5.17	14.15	311.68
08:03:07	5.15	14.14	543.78
08:04:07	4.85	14.35	1000.67
08:05:07	5.33	14.02	372.76
08:06:07	4.85	14.39	466.26
08:07:07	4.75	14.44	937.57
08:08:07	5.12	14.16	845.30
08:09:07	5.14	14.19	433.81
08:10:07	4.71	14.49	664.59
08:11:07	4.78	14.43	789.89
08:12:07	5.03	14.27	533.90
08:13:07	4.96	14.30	442.29
08:14:07	4.87	14.36	753.65
08:15:07	5.07	14.21	706.41
08:16:07	5.08	14.25	433.04
08:17:07	4.99	14.29	543.57
08:18:07	5.16	14.17	440.50
08:19:07	4.95	14.34	584.17
08:20:07	4.85	14.40	732.21
08:21:06	5.19	14.14	590.81
08:22:06	5.16	14.21	249.38
08:23:06	4.93	14.34	727.46
08:24:06	5.15	14.17	456.12
08:25:06	4.64	14.53	1000.44
08:26:06	5.00	14.28	999.29
08:27:06	4.88	14.38	820.56
08:28:06	5.14	14.19	702.92
08:29:06	4.93	14.38	521.98
08:30:06	4.90	14.35	999.83
08:31:06	5.08	14.26	576.86
08:32:06	4.81	14.47	709.68
08:33:06	4.95	14.32	924.48
08:34:06	4.91	14.38	384.59
08:35:06	5.03	14.29	439.28
08:36:06	4.97	14.34	447.19
08:37:06	5.15	14.20	314.85
08:38:06	4.95	14.35	439.81
08:39:06	4.97	14.31	777.87
08:40:06	5.20	14.13	357.43
08:41:06	4.88	14.38	591.31
08:42:06	5.07	14.25	526.77
08:43:06	4.86	14.40	915.49
08:44:06	4.86	14.41	654.02
08:45:06	5.06	14.27	406.54

Client : JEA SJRPP
 Site : 0000
 Unit : 1
 Project : 95-058
 Comment : Run 1
 Test Date : 8/13/95

Time : 08:00 thru 09:00:14

Page 2

Time	1030 O2 %	1029 CO2 %	1028 CO PPm
08:46:06	4.70	14.54	932.17
08:47:06	4.96	14.37	556.06
08:48:06	4.97	14.32	502.86
08:49:06	4.69	14.55	944.48
08:50:06	4.68	14.53	999.98
08:51:06	5.23	14.10	825.43
08:52:06	4.84	14.43	554.58
08:53:06	5.04	14.24	789.83
08:54:06	4.87	14.42	542.86
08:55:06	4.84	14.41	989.41
08:56:06	4.96	14.32	747.63
08:57:06	4.95	14.37	605.09
08:58:06	4.86	14.38	897.07
08:59:06	4.94	14.38	367.68
09:00:06	4.84	14.42	539.69
09:00:14	4.87	14.40	539.89
Averages for 62 Points	4.96	14.31	636.27

E gas = 4.95 14.29 630.22

Client : JEA SJRPP
Site : 0000
Unit : 1
Project : 95-058
Comment : Rain 2
Test Date : 8/13/95

Time : 09:47 thru 10:47

Page 1

Time	1030 O2 %	1029 CO2 %	1028 CO PPM
09:47:41	4.88	14.44	295.55
09:48:40	4.73	14.52	815.61
09:49:40	5.02	14.26	870.46
09:50:40	4.45	14.71	904.76
09:51:40	4.76	14.46	1000.37
09:52:40	4.88	14.42	574.82
09:53:40	4.76	14.51	498.91
09:54:40	4.79	14.48	653.45
09:55:40	4.70	14.56	861.16
09:56:40	4.80	14.44	1000.52
09:57:40	4.93	14.39	470.78
09:58:40	4.52	14.67	980.56
09:59:40	4.85	14.40	1000.60
10:00:40	4.84	14.43	518.02
10:01:40	4.85	14.45	546.35
10:02:40	4.70	14.51	762.42
10:03:40	4.92	14.38	643.06
10:04:40	4.82	14.44	729.43
10:05:40	4.90	14.38	548.67
10:06:40	4.75	14.48	675.51
10:07:40	4.86	14.37	1000.52
10:08:40	4.93	14.34	720.29
10:09:40	4.89	14.38	512.88
10:10:40	4.78	14.44	800.61
10:11:40	5.02	14.25	631.00
10:12:40	4.78	14.45	698.63
10:13:40	4.75	14.47	893.83
10:14:40	4.76	14.46	792.14
10:15:40	4.89	14.35	724.65
10:16:40	4.79	14.44	551.00
10:17:40	4.82	14.41	648.85
10:18:40	4.63	14.55	888.59
10:19:40	4.67	14.52	896.72
10:20:40	4.74	14.45	899.82
10:21:40	4.81	14.42	884.83
10:22:40	4.59	14.57	1000.45
10:23:40	4.87	14.37	697.02
10:24:40	4.92	14.35	518.82
10:25:40	4.64	14.53	853.56
10:26:40	4.73	14.45	843.49
10:27:40	4.63	14.55	1000.29
10:28:40	4.82	14.40	859.72
10:29:40	4.77	14.44	721.55
10:30:40	4.70	14.51	676.83
10:31:40	4.70	14.48	988.33
10:32:40	4.83	14.38	781.74

Client :JEA SJRPP
 Site :0000
 Unit :1
 Project :95-058
 Comment :Run 2
 Test Date :8/13/95

Time :09:47 thru 10:47

Page 2

	1030	1029	1028
	O2	CO2	CO
Time	%	%	PPm
10:33:40	4.79	14.44	756.98
10:34:40	4.74	14.47	940.64
10:35:39	4.84	14.39	698.49
10:36:39	4.50	14.62	999.75
10:37:39	4.78	14.45	1000.45
10:38:39	4.70	14.50	1000.29
10:39:39	4.74	14.46	791.98
10:40:39	4.64	14.52	1000.22
10:41:39	4.81	14.41	780.10
10:42:39	4.81	14.42	652.53
10:43:39	4.79	14.43	674.96
10:44:39	4.80	14.43	791.69
10:45:39	4.68	14.49	1000.29
10:46:39	4.64	14.52	1000.52
Averages			
for 60			
Points	4.77	14.45	782.10
<i>Egas.</i>	4.77	14.42 <i>TR</i>	773.39

Client : JEA SJRPP
File : 0000
Unit : 1
Project : 95-058
Comment : *Run 3*
Test Date : 8/13/95

Time : 11:43 thru 12:43:23

Time	1030 O2 %	1029 CO2 %	1028 CO PPm
11:43:12	4.63	14.51	999.98
11:44:12	4.74	14.45	951.46
11:45:12	4.76	14.46	780.10
11:46:12	4.71	14.45	999.83
11:47:12	4.74	14.45	938.59
11:48:12	4.60	14.57	912.88
11:49:12	4.54	14.57	1000.45
11:50:12	4.65	14.52	970.54
11:51:12	4.74	14.45	748.11
11:52:12	4.43	14.65	1000.75
11:53:12	4.79	14.40	1000.37
11:54:12	4.86	14.40	489.79
11:55:12	4.42	14.67	1000.29
11:56:12	4.69	14.47	1000.29
11:57:12	4.63	14.55	758.86
11:58:12	4.48	14.62	999.98
11:59:12	4.71	14.46	1000.37
12:00:12	4.73	14.44	1000.45
12:01:12	4.74	14.43	1000.45
12:02:12	4.73	14.46	761.85
12:03:12	4.79	14.39	702.92
12:04:12	4.76	14.44	462.37
12:05:12	4.59	14.58	807.84
12:06:12	4.67	14.50	678.82
12:07:12	4.57	14.56	1000.75
12:08:12	4.67	14.48	918.92
12:09:12	5.00	14.22	519.12
12:10:12	4.36	14.68	1000.14
12:11:12	4.54	14.57	1000.37
12:12:12	4.76	14.42	1000.14
12:13:12	4.69	14.46	1000.45
12:14:12	4.54	14.59	846.53
12:15:12	4.63	14.51	1000.52
12:16:12	4.66	14.49	936.94
12:17:12	4.80	14.39	843.77
12:18:12	4.71	14.47	436.66
12:19:12	4.59	14.54	913.79
12:20:12	4.78	14.40	857.53
12:21:12	4.73	14.45	689.89
12:22:11	4.78	14.41	494.20
12:23:11	4.99	14.24	449.03
12:24:11	4.75	14.47	361.84
12:25:11	4.26	14.74	1000.68
12:26:11	4.69	14.47	1000.29
12:27:11	4.67	14.50	1000.52
12:28:11	4.71	14.49	896.91

Client :JEA SJRPP
 Site :0000
 Unit : 1
 Project :95-058
 Comment : Run 3
 Test Date :8/13/95 Time :11:43 thru 12:43:23

Time	1030 O2 %	1029 CO2 %	1028 CO PPm
12:29:11	4.88	14.35	559.15
12:30:11	4.62	14.57	657.93
12:31:11	4.65	14.50	999.98
12:32:11	4.67	14.49	863.56
12:33:11	4.58	14.57	804.85
12:34:11	4.59	14.53	1000.60
12:35:11	4.77	14.42	847.88
12:36:11	4.78	14.40	1000.45
12:37:11	4.66	14.52	796.09
12:38:11	4.61	14.52	999.83
12:39:11	4.70	14.48	830.21
12:40:11	4.75	14.43	680.66
12:41:11	4.69	14.46	713.58
12:42:11	4.73	14.44	871.76
12:43:11	4.62	14.54	755.91
12:43:23	4.61	14.54	746.04

Averages
 for 62
 Points 4.67 14.48 842.98

Egas 4.75 14.38 833.32

Client : JEA SJRPP
Site : 0000
Unit : 1
Project : 95-058
Comment : Round
Event Date : 8/18/95

Time : 08:00 thru 09:00:12

Page 1

Time	1030 O2 %	1029 CO2 %	1028 CO PPm
08:00:22	4.94	14.29	292.35
08:01:22	5.03	14.19	456.44
08:02:22	5.09	14.17	279.26
08:03:22	5.10	14.16	155.43
08:04:22	5.15	14.12	112.42
08:05:22	5.02	14.24	119.57
08:06:22	4.87	14.32	329.38
08:07:22	4.69	14.49	460.12
08:08:22	4.89	14.31	473.28
08:09:22	5.11	14.15	262.58
08:10:22	5.14	14.12	121.81
08:11:22	5.11	14.15	213.24
08:12:22	4.80	14.41	238.37
08:13:22	4.85	14.37	574.95
08:14:22	4.94	14.30	211.29
08:15:21	4.96	14.28	225.42
08:16:21	4.90	14.31	287.39
08:17:21	5.01	14.21	251.91
08:18:21	4.93	14.29	350.18
08:19:21	5.02	14.22	464.20
08:20:21	4.93	14.31	256.36
08:21:21	4.92	14.27	455.42
08:22:21	4.90	14.31	444.26
08:23:21	4.98	14.24	227.23
08:24:21	4.90	14.32	373.34
08:25:21	4.96	14.26	315.53
08:26:21	5.02	14.23	211.21
08:27:21	4.97	14.27	195.36
08:28:21	4.77	14.39	437.01
08:29:21	5.06	14.15	667.01
08:30:21	4.96	14.27	283.51
08:31:21	5.08	14.16	191.60
08:32:21	4.98	14.27	288.28
08:33:21	5.03	14.20	247.35
08:34:21	4.90	14.32	176.07
08:35:21	5.38	13.88	317.68
08:36:21	4.67	14.46	394.18
08:37:21	4.84	14.26	1000.52
08:38:21	5.67	13.65	308.40
08:39:21	4.64	14.50	554.96
08:40:21	5.68	13.60	262.66
08:41:21	5.06	14.19	161.52
08:42:21	4.50	14.50	1000.52
08:43:21	5.37	13.86	999.83
08:44:21	4.71	14.40	711.45
08:45:21	4.78	14.30	1000.60

Client : JEA SJRPP
 Site : 0000
 Unit : 1
 Project : 95-058
 Comment : Run!
 Test Date : 8/18/95

Time : 08:00 thru 09:00:12

Time	1030 O2 %	1029 CO2 %	1028 CO PPm
08:46:21	5.65	13.68	390.87
08:47:21	4.53	14.52	952.16
08:48:21	5.57	13.62	987.72
08:49:21	5.45	13.81	154.54
08:50:21	4.79	14.29	1000.67
08:51:21	4.89	14.23	803.75
08:52:21	4.93	14.21	575.89
08:53:21	4.84	14.27	694.77
08:54:21	4.97	14.19	527.77
08:55:21	4.98	14.16	481.48
08:56:21	4.93	14.20	625.98
08:57:21	5.01	14.16	417.53
08:58:21	4.79	14.31	955.60
08:59:21	4.98	14.17	676.67
09:00:12	5.01	14.17	521.84

Averages
 for 61
 Points 4.99 14.20 444.73

gas → 5.00 14.23 444.22

BEST AVAILABLE COPY

Unit : JEA SJRPP

id : 0000

Unit : 1

Project : 95-058

Comment : Run 2.

Test Date : 8/18/95 Time : 09:50 thru 10:50

Page 1

Time	1030 O2 %	1029 CO2 %	1028 CO PPm
09:50:48	5.15	14.10	209.36
09:51:48	4.91	14.28	462.66
09:52:48	5.00	14.20	376.91
09:53:48	5.11	14.12	251.91
09:54:48	4.86	14.33	462.01
09:55:48	4.86	14.30	647.08
09:56:48	5.30	13.96	223.07
09:57:48	4.88	14.28	862.25
09:58:48	4.92	14.25	490.10
09:59:48	5.39	13.85	338.46
10:00:48	4.85	14.35	440.56
10:01:48	5.15	14.08	422.26
10:02:48	5.13	14.14	192.31
10:03:48	4.79	14.39	408.39
10:04:48	5.41	13.82	315.26
10:05:48	4.95	14.29	288.91
10:06:48	4.71	14.41	1000.52
10:07:48	5.32	13.92	376.72
10:08:48	5.10	14.11	340.17
10:09:48	4.96	14.25	335.55
10:10:47	5.23	14.02	255.95
10:11:47	4.89	14.32	356.04
10:12:47	4.96	14.22	464.50
10:13:47	4.89	14.29	481.09
10:14:47	5.02	14.18	402.41
10:15:47	5.01	14.20	330.28
10:16:47	5.13	14.10	271.23
10:17:47	4.98	14.21	570.96
10:18:47	5.24	14.01	323.00
10:19:47	5.09	14.14	325.53
10:20:47	4.85	14.26	982.12
10:21:47	5.05	14.13	664.71
10:22:47	5.02	14.19	500.22
10:23:47	4.97	14.19	662.72
10:24:47	5.07	14.16	364.85
10:25:47	4.96	14.22	545.67
10:26:47	5.06	14.15	553.98
10:27:47	5.05	14.17	387.56
10:28:47	4.82	14.34	622.32
10:29:47	4.98	14.22	600.35
10:30:47	5.20	14.00	414.87
10:31:47	5.06	14.19	245.76
10:32:47	4.81	14.32	779.75
10:33:47	4.92	14.23	799.88
10:34:47	5.03	14.18	375.86
10:35:47	5.10	14.13	327.37

Client :JEA SJRPP
 Site :0000
 Jnit : 1
 Project :95-058
 Comment : Run 2
 Test Date :8/18/95 Time :09:50 thru 10:50

Time	1030 O2 %	1029 CO2 %	1028 CO PPm
10:36:47	5.03	14.16	356.73
10:37:47	5.11	14.12	219.41
10:38:47	4.63	14.45	1000.14
10:39:47	4.87	14.27	828.14
10:40:47	5.07	14.12	593.81
10:41:47	5.14	14.07	455.54
10:42:47	5.02	14.18	419.01
10:43:47	5.08	14.12	556.01
10:44:47	5.06	14.14	418.98
10:45:47	4.97	14.22	499.30
10:46:47	4.84	14.32	644.17
10:47:47	5.04	14.13	515.39
10:48:47	5.10	14.11	365.33
10:49:47	4.92	14.24	554.14

Averages
 for 60
 Points 5.01 14.18 474.65

egas : 5.05 14.28 471.25

Client :JEA SJRPP
 Site :0000
 Unit :
 Project :95-058
 Comment : Run 3
 Test Date :8/18/95

Time :11:35 thru 12:35

Time	1030 O2 %	1029 CO2 %	1028 CO PPm
11:35:05	4.90	14.29	512.98
11:36:05	4.95	14.23	582.71
11:37:05	5.12	14.06	314.21
11:38:05	4.99	14.24	211.94
11:39:05	4.98	14.18	587.65
11:40:05	5.17	14.03	346.10
11:41:05	5.11	14.11	239.13
11:42:05	4.80	14.37	321.80
11:43:05	4.66	14.47	932.59
11:44:05	4.67	14.46	1000.52
11:45:05	5.23	13.97	503.44
11:46:05	4.73	14.42	527.78
11:47:05	4.89	14.27	635.63
11:48:05	5.10	14.11	322.34
11:49:05	4.84	14.33	514.67
11:50:05	4.79	14.37	724.67
11:51:05	4.98	14.19	485.65
11:52:05	4.89	14.28	471.85
11:53:05	4.97	14.21	610.63
11:54:05	5.14	14.11	256.47
11:55:05	4.89	14.28	569.93
11:56:05	4.90	14.30	421.52
11:57:05	4.87	14.30	583.31
11:58:05	4.92	14.28	383.69
11:59:05	5.08	14.08	361.41
12:00:05	4.99	14.21	331.82
12:01:05	4.84	14.32	712.32
12:02:05	5.08	14.11	520.35
12:03:05	5.04	14.18	229.76
12:04:05	4.81	14.35	615.54
12:05:05	5.01	14.17	411.49
12:06:04	4.90	14.28	564.68
12:07:04	4.77	14.34	995.61
12:08:04	4.99	14.13	952.35
12:09:04	5.11	14.10	285.63
12:10:04	4.84	14.33	416.09
12:11:04	5.13	14.09	194.76
12:12:04	4.93	14.25	256.47
12:13:04	4.90	14.27	374.59
12:14:04	4.98	14.19	303.50
12:15:04	4.87	14.26	420.05
12:16:04	4.97	14.21	246.81
12:17:04	4.71	14.42	504.17
12:18:04	5.01	14.16	276.53
12:19:04	4.93	14.20	358.17
12:20:04	4.88	14.26	378.07

Client :JEA SJRPP
 Site :0000
 Jnit : 1
 Project :95-058
 Comment : Run 3
 Test Date :8/18/95 Time :11:35 thru 12:35

Time	1030 O2 %	1029 CO2 %	1028 CO PPm
12:21:04	4.85	14.28	563.39
12:22:04	5.17	14.01	321.49
12:23:04	4.56	14.51	829.61
12:24:04	4.87	14.23	1000.60
12:25:04	4.96	14.21	332.46
12:26:04	4.86	14.27	390.26
12:27:04	4.84	14.27	810.83
12:28:04	5.04	14.13	298.50
12:29:04	4.66	14.41	557.85
12:30:04	4.82	14.27	806.84
12:31:04	5.04	14.10	435.39
12:32:04	4.87	14.27	340.28
12:33:04	4.99	14.10	680.84
12:34:04	4.96	14.17	327.08
Averages			
for 60			
Points	4.92	14.23	491.11
	<i>5.04</i>	<i>14.25</i>	<i>488.23</i>

Test Calibration Data

ANALYZER CALIBRATION DATA

Client J.E.A. S.J.R.P.P. Project # 95-058-F1 Test Date 8-11-95
 Source Identification Unit #1 Stable Operator J. Roth

Calibration Data For Sampling Runs: <u>1-</u> Gas Type: <u>CO</u> Span: <u>100</u>	Cylinder Number	Cylinder Value % or PPM	Analyzer Response	Absolute Difference % or PPM	Difference % of Span
ZERO GAS		0.0	0.0	0.0	0.0
LOW-RANGE GAS		14.74	14.80	.06	.06
MID-RANGE GAS		29.73	29.0	.73	.73
HIGH-RANGE GAS <u>up scale</u>		62.0	61.80	.20	.20

Calibration Data For Sampling Runs: <u>1-</u> Gas Type: <u>CO</u> Span: <u>1000</u>	Cylinder Number	Cylinder Value % or PPM	Analyzer Response	Absolute Difference % or PPM	Difference % of Span
ZERO GAS		0.0	0.0	0.0	0.0
LOW-RANGE GAS		-			
MID-RANGE GAS		302.0	305.9	3.90	.39
HIGH-RANGE GAS		603.5	603.7	.20	.03

Calibration Data For Sampling Runs: <u>PE</u> Gas Type: <u>O2</u> Span: <u>25</u>	Cylinder Number	Cylinder Value % or PPM	Analyzer Response	Absolute Difference % or PPM	Difference % of Span
ZERO GAS		0.0	.10	.10	.40
LOW-RANGE GAS		-			
MID-RANGE GAS <u>up scale</u>		11.60	11.60	0.0	0.0
HIGH-RANGE GAS		20.90	20.90	0.0	0.0

Calibration Data For Sampling Runs: <u>1-</u> Gas Type: <u>CO2</u> Span: <u>20</u>	Cylinder Number	Cylinder Value % or PPM	Analyzer Response	Absolute Difference % or PPM	Difference % of Span
ZERO GAS		0.0	0.0	0.0	0.0
LOW-RANGE GAS		-			
MID-RANGE GAS <u>up scale</u>		10.9	11.0	.1	.50
HIGH-RANGE GAS	G1	17.20	17.20	0.0	0.0

ANALYZER CALIBRATION DATA

Client J.E.A. S.J.R.P.P. Project # 95-058-F1 Test Date 8-12-95

Source Identification Unit #1 Stack Operator T. Roth

Calibration Data For Sampling Runs: <u>1-</u> Gas Type: <u>CO</u> Span: <u>100</u>	Cylinder Number	Cylinder Value % or PPM	Analyzer Response	Absolute Difference % or PPM	Difference % of Span
ZERO GAS	UN1066	0.0	0.0	0.0	0.0
LOW-RANGE GAS	ALM023664	14.74	14.25	.49	.49
MID-RANGE GAS	ALM028243	29.73	29.24	.49	.49
HIGH-RANGE GAS <i>upscale</i>	SA 6640	62.0	61.0	1.0	1.0

Calibration Data For Sampling Runs: <u>1-</u> Gas Type: <u>CO</u> Span: <u>1000</u>	Cylinder Number	Cylinder Value % or PPM	Analyzer Response	Absolute Difference % or PPM	Difference % of Span
ZERO GAS	UN1066	0.0	0.0	0.0	0.0
LOW-RANGE GAS	-	-			
MID-RANGE GAS <i>upscale</i>	ALM028668	302.0	305.7	3.70	.37
HIGH-RANGE GAS	ALM012900	603.5	602.2	1.30	.13

Calibration Data For Sampling Runs: <u>1-</u> Gas Type: <u>O2</u> Span: <u>25</u>	Cylinder Number	Cylinder Value % or PPM	Analyzer Response	Absolute Difference % or PPM	Difference % of Span
ZERO GAS	UN1066 0.0	0.0	.10	.10	-.90
LOW-RANGE GAS	-	-			
MID-RANGE GAS <i>upscale</i>	SG9133268	11.60	11.60		0.0
HIGH-RANGE GAS	Amb. Air.	20.90	20.70	-.20	-.80

Calibration Data For Sampling Runs: <u>1-</u> Gas Type: <u>CO2</u> Span: <u>20</u>	Cylinder Number	Cylinder Value % or PPM	Analyzer Response	Absolute Difference % or PPM	Difference % of Span
ZERO GAS	UN1066	0.0	0.0	0.0	0.0
LOW-RANGE GAS	-	-			
MID-RANGE GAS <i>upscale</i>	SG9133059	10.90	11.0	.10	.50
HIGH-RANGE GAS G2	ALM049101	17.20	17.20	0.0	0.0

ANALYZER CALIBRATION DATA

Client J.E.A. S.J.R.P.P. Project # 95-058-F1 Test Date 8-13-95Source Identification Unit #1 Stack Operator T. Roth

Calibration Data For Sampling Runs: <u>1-</u> Gas Type: <u>CO</u> Span: <u>100</u>	Cylinder Number	Cylinder Value % or PPM	Analyzer Response	Absolute Difference % or PPM	Difference % of Span
ZERO GAS	UN1066	0.0	0.0	0.0	0.0
LOW-RANGE GAS	ALM023664	14.74	14.0	.740	.74
MID-RANGE GAS	ALM028243	29.73	29.00	.73	.73
HIGH-RANGE GAS	SA6640	62.0	61.0	1.0	1.0

Calibration Data For Sampling Runs: <u>1-</u> Gas Type: <u>CO</u> Span: <u>1000</u>	Cylinder Number	Cylinder Value % or PPM	Analyzer Response	Absolute Difference % or PPM	Difference % of Span
ZERO GAS	UN1066	0.0	0.0	0.0	0.0
LOW-RANGE GAS	—	—			
MID-RANGE GAS	ALM028068	302.0	305.4	3.40	.34
HIGH-RANGE GAS	ALM02900	603.5	600.6	2.90	.29

Calibration Data For Sampling Runs: <u>1-</u> Gas Type: <u>O2</u> Span: <u>25</u>	Cylinder Number	Cylinder Value % or PPM	Analyzer Response	Absolute Difference % or PPM	Difference % of Span
ZERO GAS	UN1066	0.0	0.0	0.0	0.0
LOW-RANGE GAS	—	—			
MID-RANGE GAS	SG9133268	11.60	11.70	-.10	.40
HIGH-RANGE GAS	Amb. Air.	20.90	20.80	-.10	.40

Calibration Data For Sampling Runs: <u>1-</u> Gas Type: <u>CO2</u> Span: <u>20</u>	Cylinder Number	Cylinder Value % or PPM	Analyzer Response	Absolute Difference % or PPM	Difference % of Span
ZERO GAS	UN1066	0.0	.10	.10	.50
LOW-RANGE GAS	—	—			
MID-RANGE GAS	SG9133059	10.90	11.10	.20	1.0
HIGH-RANGE GAS	G3 ALM049101	17.20	17.20	0.0	0.0

ANALYZER CALIBRATION DATA

Client J.E.A. S.J.R.P.P. Project # 95-058-F1 Test Date 8-18-95

Source Identification Unit# | Stock Operator T. Roth

Calibration Data For Sampling Runs: <u>1-3</u> Gas Type: <u>CO</u> Span: <u>100</u>	Cylinder Number	Cylinder Value % or PPM	Analyzer Response	Absolute Difference % or PPM	Difference % of Span
ZERO GAS	UN1061	0.0	0.0	0.0	0.0
LOW-RANGE GAS	ALM02364	14.74	13.95	.79	.79
MID-RANGE GAS	ALM02P243	29.73	29.00	.73	.73
HIGH-RANGE GAS	SA6640	62.0	60.0 ^{TR}	1.0	1.0

Calibration Data For Sampling Runs: <u>1-3</u> Gas Type: <u>CO</u> Span: <u>1000</u>	Cylinder Number	Cylinder Value % or PPM	Analyzer Response	Absolute Difference % or PPM	Difference % of Span
ZERO GAS	UN1061	0.0	0.0	0.0	0.0
LOW-RANGE GAS	—	—			
MID-RANGE GAS <i>upscal</i>	ALM028068	302.0	303.3	1.3	.130
HIGH-RANGE GAS	ALM012900	603.5	601.6	1.90	.190

Calibration Data For Sampling Runs: <u>1-3</u> Gas Type: <u>O2</u> Span: <u>25</u>	Cylinder Number	Cylinder Value % or PPM	Analyzer Response	Absolute Difference % or PPM	Difference % of Span
ZERO GAS	UN1061	0.0	0.0	0.0	0.0
LOW-RANGE GAS	—	—			
MID-RANGE GAS <i>upscal</i>	SG913328	11.60	11.60	0.0	0.0
HIGH-RANGE GAS	4 th Air.	20.90	20.60	.30	1.20

Calibration Data For Sampling Runs: <u>1-3</u> Gas Type: <u>CO2</u> Span: <u>20</u>	Cylinder Number	Cylinder Value % or PPM	Analyzer Response	Absolute Difference % or PPM	Difference % of Span
ZERO GAS	UN1061	0.0	0.0	0.0	0.0
LOW-RANGE GAS	—	—			
MID-RANGE GAS <i>upscal</i>	SG9133059	10.90	11.0	.10	.50
HIGH-RANGE GAS G4	ALM049101	17.20	17.2	0.0	0.0

SYSTEM CALIBRATION BIAS AND DRIFT DATA

CLIENT JEA SJRPP PROJECT # 95-058-FL TEST DATE 08-11-95

SOURCE IDENTIFICATION UNIT 1 STACK OPERATOR T. ROTH

RUN NO:	1	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	CO						
SPAN:	1000						
ZERO GAS		0.00	0.00	0.00	0.00	0.00	0.00
UPSCALE GAS		61.80	59.90	-0.19	62.00	0.02	0.21
	CMA:	62.00		CO:	0.00	CM:	60.95

RUN NO:	1	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	CO2						
SPAN:	20						
ZERO GAS		0.00	0.10	0.50	0.10	0.50	0.00
UPSCALE GAS		11.00	10.80	-1.00	10.80	-1.00	0.00
	CMA:	10.90		CO:	0.10	CM:	10.80

RUN NO:	1	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	O2						
SPAN:	25						
ZERO GAS		0.10	0.10	0.00	0.10	0.00	0.00
UPSCALE GAS		11.60	11.40	-0.80	11.30	-1.20	-0.40
	CMA:	11.60		CO:	0.10	CM:	11.35

RUN NO:	1	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	Gass						
SPAN:	0						
ZERO GAS		0.00	0.00	ERR	0.00	ERR	ERR
UPSCALE GAS		0.00	0.00	ERR	0.00	ERR	ERR
	CMA:			CO:	0.00	CM:	0.00

TOTAL SOURCE ANALYSIS, INC.

SYSTEM CALIBRATION BIAS AND DRIFT DATA

CLIENT JEA SJRPP PROJECT # 95-058-FL TEST DATE 08-11-95

SOURCE IDENTIFICATION UNIT 1 STACK OPERATOR T. ROTH

RUN NO:	2	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	CO						
SPAN:	1000						
ZERO GAS		0.00	0.00	0.00	0.00	0.00	0.00
UPSCALE GAS		305.90	302.70	-0.32	304.40	-0.15	0.17
	CMA:	302.00		CO:	0.00	CM:	303.55

RUN NO:	2	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	CO2						
SPAN:	20						
ZERO GAS		0.00	0.10	0.50	0.10	0.50	0.00
UPSCALE GAS		11.00	10.80	-1.00	10.90	-0.50	0.50
	CMA:	10.90		CO:	0.10	CM:	10.85

RUN NO:	2	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	O2						
SPAN:	25						
ZERO GAS		0.10	0.10	0.00	0.10	0.00	0.00
UPSCALE GAS		11.60	11.30	-1.20	11.20	-1.60	-0.40
	CMA:	11.60		CO:	0.10	CM:	11.25

RUN NO:	2	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	Gass						
SPAN:	0						
ZERO GAS		0.00	0.00	ERR	0.00	ERR	ERR
UPSCALE GAS		0.00	0.00	ERR	0.00	ERR	ERR
	CMA:			CO:	0.00	CM:	0.00

TOTAL SOURCE ANALYSIS, INC.
 ENVIROMENTAL TESTING CONSULTANTS

SYSTEM CALIBRATION BIAS AND DRIFT DATA

CLIENT JEA SJRPP PROJECT # 95-058-FL TEST DATE 08-11-95

SOURCE IDENTIFICATION UNIT 1 STACK OPERATOR T. ROTH

RUN NO:	3	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	CO						
SPAN:	1000						
ZERO GAS		0.00	0.00	0.00	0.00	0.00	0.00
UPSCALE GAS		305.90	304.40	-0.15	302.30	-0.36	-0.21
	CMA:	302.70		CO:	0.00	CM:	303.35

RUN NO:	3	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	CO2						
SPAN:	20						
ZERO GAS		0.00	0.10	0.50	0.10	0.50	0.00
UPSCALE GAS		11.00	10.90	-0.50	10.90	-0.50	0.00
	CMA:	10.90		CO:	0.10	CM:	10.90

RUN NO:	3	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	O2						
SPAN:	25						
ZERO GAS		0.10	0.10	0.00	0.10	0.00	0.00
UPSCALE GAS		11.60	11.20	-1.60	11.20	-1.60	0.00
	CMA:	11.60		CO:	0.10	CM:	11.20

RUN NO:	3	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	Gass						
SPAN:	0						
ZERO GAS		0.00	0.00	ERR	0.00	ERR	ERR
UPSCALE GAS		0.00	0.00	ERR	0.00	ERR	ERR
	CMA:			CO:	0.00	CM:	0.00

TOTAL SOURCE ANALYSIS, INC.
 ENVIROMENTAL TESTING CONSULTANTS

SYSTEM CALIBRATION BIAS AND DRIFT DATA

CLIENT JEA SJRPP PROJECT # 95-058-FL TEST DATE 08-12-95

SOURCE IDENTIFICATION UNIT 1 STACK OPERATOR T. ROTH

RUN NO:	1	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	CO						
SPAN:	1000						
ZERO GAS		0.00	0.00	0.00	0.00	0.00	0.00
UPSCALE GAS		305.70	304.20	-0.15	304.30	-0.14	0.01
CMA:		302.00		CO:	0.00	CM:	304.25

RUN NO:	1	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	CO2						
SPAN:	20						
ZERO GAS		0.00	0.10	0.50	0.20	1.00	0.50
UPSCALE GAS		11.00	10.90	-0.50	10.90	-0.50	0.00
CMA:		10.90		CO:	0.15	CM:	10.90

RUN NO:	1	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	O2						
SPAN:	25						
ZERO GAS		0.00	0.10	0.40	0.10	0.40	0.00
UPSCALE GAS		11.60	11.30	-1.20	11.30	-1.20	0.00
CMA:		11.60		CO:	0.10	CM:	11.30

RUN NO:	1	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	Gass						
SPAN:	0						
ZERO GAS		0.00	0.00	ERR	0.00	ERR	ERR
UPSCALE GAS		0.00	0.00	ERR	0.00	ERR	ERR
CMA:				CO:	0.00	CM:	0.00

TOTAL SOURCE ANALYSIS, INC.
 ENVIROMENTAL TESTING CONSULTANTS

SYSTEM CALIBRATION BIAS AND DRIFT DATA

CLIENT JEA SJRPP PROJECT # 95-058-FL TEST DATE 08-12-95

SOURCE IDENTIFICATION UNIT 1 STACK OPERATOR T. ROTH

RUN NO:	2	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	CO						
SPAN:	1000						
ZERO GAS		0.00	0.00	0.00	0.10	0.01	0.01
UPSCALE GAS		305.70	304.30	-0.14	303.70	-0.20	-0.06
CMA:		302.00		CO:	0.05	CM:	304.00

RUN NO:	2	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	CO2						
SPAN:	20						
ZERO GAS		0.00	0.20	1.00	0.20	1.00	0.00
UPSCALE GAS		11.00	10.90	-0.50	11.00	0.00	0.50
CMA:		10.90		CO:	0.20	CM:	10.95

RUN NO:	2	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	02						
SPAN:	25						
ZERO GAS		0.00	0.10	0.40	0.10	0.40	0.00
UPSCALE GAS		11.60	11.30	-1.20	11.30	-1.20	0.00
CMA:		11.60		CO:	0.10	CM:	11.30

RUN NO:	2	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	Gass						
SPAN:	0						
ZERO GAS		0.00	0.00	ERR	0.00	ERR	ERR
UPSCALE GAS		0.00	0.00	ERR	0.00	ERR	ERR
CMA:		0.00		CO:	0.00	CM:	0.00

TOTAL SOURCE ANALYSIS, INC.
 ENVIROMENTAL TESTING CONSULTANTS

SYSTEM CALIBRATION BIAS AND DRIFT DATA

CLIENT JEA SJRPP PROJECT # 95-058-FL TEST DATE 08-12-95

SOURCE IDENTIFICATION UNIT 1 STACK OPERATOR T. ROTH

RUN NO:	3	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	CO						
SPAN:	1000						
ZERO GAS		0.00	0.10	0.01	0.00	0.00	-0.01
UPSCALE GAS		305.70	303.70	-0.20	302.50	-0.32	-0.12
CMA:		302.00		CO:	0.05	CM:	303.10

RUN NO:	3	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	CO2						
SPAN:	20						
ZERO GAS		0.00	0.00	0.00	0.20	1.00	1.00
UPSCALE GAS		11.00	11.00	0.00	11.00	0.00	0.00
CMA:		10.90		CO:	0.10	CM:	11.00

RUN NO:	3	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	02						
SPAN:	25						
ZERO GAS		0.00	0.10	0.40	0.10	0.40	0.00
UPSCALE GAS		11.60	11.30	-1.20	11.10	-2.00	-0.80
CMA:		11.60		CO:	0.10	CM:	11.20

RUN NO:	3	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	Gass						
SPAN:	0						
ZERO GAS		0.00	0.00	ERR	0.00	ERR	ERR
UPSCALE GAS		0.00	0.00	ERR	0.00	ERR	ERR
CMA:		0.00		CO:	0.00	CM:	0.00

TOTAL SOURCE ANALYSIS, INC.
 ENVIROMENTAL TESTING CONSULTANTS

SYSTEM CALIBRATION BIAS AND DRIFT DATA

CLIENT JEA SJRPP PROJECT # 95-058-FL TEST DATE 08-13-95

SOURCE IDENTIFICATION UNIT 1 STACK OPERATOR T. ROTH

RUN NO:	1	ANALYZER	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	CO	RESPONSE					
SPAN:	1000						
ZERO GAS		0.00	0.00	0.00	0.00	0.00	0.00
UPSCALE GAS		305.40	305.40	0.00	304.40	-0.10	-0.10
	CMA:	302.00		CO:	0.00	CM:	304.90

RUN NO:	1	ANALYZER	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	CO2	RESPONSE					
SPAN:	20						
ZERO GAS		0.10	0.10	0.00	0.20	0.50	0.50
UPSCALE GAS		11.10	10.90	-1.00	11.00	-0.50	0.50
	CMA:	10.90		CO:	0.15	CM:	10.95

RUN NO:	1	ANALYZER	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	02	RESPONSE					
SPAN:	25						
ZERO GAS		0.00	0.10	0.40	0.10	0.40	0.00
UPSCALE GAS		11.70	11.50	-0.80	11.50	-0.80	0.00
	CMA:	11.60		CO:	0.10	CM:	11.50

RUN NO:	1	ANALYZER	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	Gass	RESPONSE					
SPAN:	0						
ZERO GAS		0.00	0.00	ERR	0.00	ERR	ERR
UPSCALE GAS		0.00	0.00	ERR	0.00	ERR	ERR
	CMA:			CO:	0.00	CM:	0.00

TOTAL SOURCE ANALYSIS, INC.
 ENVIROMENTAL TESTING CONSULTANTS

SYSTEM CALIBRATION BIAS AND DRIFT DATA

CLIENT JEA SJRPP PROJECT # 95-058-FL TEST DATE 08-13-95

SOURCE IDENTIFICATION UNIT 1 STACK OPERATOR T. ROTH

RUN NO:	2	ANALYZER	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	CO	RESPONSE					
SPAN:	1000						
ZERO GAS		0.00	0.00	0.00	0.00	0.00	0.00
UPSCALE GAS		305.40	304.40	-0.10	306.40	0.10	0.20
CMA:		302.00	CO:		0.00	CM:	305.40

RUN NO:	2	ANALYZER	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	CO2	RESPONSE					
SPAN:	20						
ZERO GAS		0.10	0.20	0.50	0.00	-0.50	-1.00
UPSCALE GAS		11.10	11.00	-0.50	10.90	-1.00	-0.50
CMA:		10.90	CO:		0.10	CM:	10.95

RUN NO:	2	ANALYZER	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	O2	RESPONSE					
SPAN:	25						
ZERO GAS		0.00	0.10	0.40	0.10	0.40	0.00
UPSCALE GAS		11.70	11.50	-0.80	11.40	-1.20	-0.40
CMA:		11.60	CO:		0.10	CM:	11.45

RUN NO:	2	ANALYZER	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	Gass	RESPONSE					
SPAN:	0						
ZERO GAS		0.00	0.00	ERR	0.00	ERR	ERR
UPSCALE GAS		0.00	0.00	ERR	0.00	ERR	ERR
CMA:		0.00	CO:		0.00	CM:	0.00

TOTAL SOURCE ANALYSIS, INC.
 ENVIROMENTAL TESTING CONSULTANTS

SYSTEM CALIBRATION BIAS AND DRIFT DATA

CLIENT JEA SJRPP PROJECT # 95-058-FL TEST DATE 08-13-95

SOURCE IDENTIFICATION UNIT 1 STACK OPERATOR T. ROTH

RUN NO:	3	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	CO						
SPAN:	1000						
ZERO GAS		0.00	0.00	0.00	0.00	0.00	0.00
UPSCALE GAS		305.40	306.40	0.10	304.60	-0.08	-0.18
CMA:		302.00		CO:	0.00	CM:	305.50

RUN NO:	3	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	CO2						
SPAN:	20						
ZERO GAS		0.10	0.00	-0.50	0.20	0.50	1.00
UPSCALE GAS		11.10	10.90	-1.00	11.10	0.00	1.00
CMA:		10.90		CO:	0.10	CM:	11.00

RUN NO:	3	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	02						
SPAN:	25						
ZERO GAS		0.00	0.10	0.40	0.10	0.40	0.00
UPSCALE GAS		11.70	11.40	-1.20	11.10	-2.40	-1.20
CMA:		11.60		CO:	0.10	CM:	11.25

RUN NO:	3	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	Gass						
SPAN:	0						
ZERO GAS		0.00	0.00	ERR	0.00	ERR	ERR
UPSCALE GAS		0.00	0.00	ERR	0.00	ERR	ERR
CMA:		0.00		CO:	0.00	CM:	0.00

TOTAL SOURCE ANALYSIS, INC.

ENVIROMENTAL TESTING CONSULTANTS

SYSTEM CALIBRATION BIAS AND DRIFT DATA

CLIENT JEA SJRPP PROJECT # 95-058-FL TEST DATE 08-18-95

SOURCE IDENTIFICATION UNIT 1 STACK OPERATOR T. ROTH

RUN NO:	1	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	CO						
SPAN:	1000						
ZERO GAS		0.00	0.00	0.00	0.00	0.00	0.00
UPSCALE GAS		303.30	301.50	-0.18	303.20	-0.01	0.17
	CMA:	302.00		CO:	0.00	CM:	302.35

RUN NO:	1	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	CO2						
SPAN:	20						
ZERO GAS		0.00	0.10	0.50	0.10	0.50	0.00
UPSCALE GAS		11.00	10.90	-0.50	10.90	-0.50	0.00
	CMA:	10.90		CO:	0.10	CM:	10.90

RUN NO:	1	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	O2						
SPAN:	25						
ZERO GAS		0.00	0.10	0.40	0.10	0.40	0.00
UPSCALE GAS		11.60	11.50	-0.40	11.40	-0.80	-0.40
	CMA:	11.60		CO:	0.10	CM:	11.45

RUN NO:	1	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	Gass						
SPAN:	0						
ZERO GAS		0.00	0.00	ERR	0.00	ERR	ERR
UPSCALE GAS		0.00	0.00	ERR	0.00	ERR	ERR
	CMA:			CO:	0.00	CM:	0.00

TOTAL SOURCE ANALYSIS, INC.
 ENVIROMENTAL TESTING CONSULTANTS

SYSTEM CALIBRATION BIAS AND DRIFT DATA

CLIENT JEA SJRPP PROJECT # 95-058-FL TEST DATE 08-18-95

SOURCE IDENTIFICATION UNIT 1 STACK OPERATOR T. ROTH

RUN NO:	2	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	CO						
SPAN:	1000						
ZERO GAS		0.00	0.00	0.00	0.10	0.01	0.01
UPSCALE GAS		303.30	303.20	-0.01	305.20	0.19	0.20
CMA:		302.00		CO:	0.05	CM:	304.20

RUN NO:	2	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	CO2						
SPAN:	20						
ZERO GAS		0.00	0.10	0.50	0.10	0.50	0.00
UPSCALE GAS		11.00	10.90	-0.50	10.80	-1.00	-0.50
CMA:		10.90		CO:	0.10	CM:	10.85

RUN NO:	2	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	O2						
SPAN:	25						
ZERO GAS		0.00	0.10	0.40	0.30	1.20	0.80
UPSCALE GAS		11.60	11.40	-0.80	11.10	-2.00	-1.20
CMA:		11.60		CO:	0.20	CM:	11.25

RUN NO:	2	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	Gass						
SPAN:	0						
ZERO GAS		0.00	0.00	ERR	0.00	ERR	ERR
UPSCALE GAS		0.00	0.00	ERR	0.00	ERR	ERR
CMA:		0.00		CO:	0.00	CM:	0.00

TOTAL SOURCE ANALYSIS, INC.
 ENVIROMENTAL TESTING CONSULTANTS

SYSTEM CALIBRATION BIAS AND DRIFT DATA

CLIENT JEA SJRPP PROJECT # 95-058-FL TEST DATE 08-18-95

SOURCE IDENTIFICATION UNIT 1 STACK OPERATOR T. ROTH

RUN NO:	3	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	CO						
SPAN:	1000						
ZERO GAS		0.00	0.10	0.01	0.00	0.00	-0.01
UPSCALE GAS		303.30	305.20	0.19	302.40	-0.09	-0.28
CMA:		302.00		CO:	0.05	CM:	303.80

RUN NO:	3	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	CO2						
SPAN:	20						
ZERO GAS		0.00	0.00	0.00	0.10	0.50	0.50
UPSCALE GAS		11.00	10.80	-1.00	11.00	0.00	1.00
CMA:		10.90		CO:	0.05	CM:	10.90

RUN NO:	3	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	02						
SPAN:	25						
ZERO GAS		0.00	0.30	1.20	0.20	0.80	-0.40
UPSCALE GAS		11.60	11.10	-2.00	10.90	-2.80	-0.80
CMA:		11.60		CO:	0.25	CM:	11.00

RUN NO:	3	ANALYZER RESPONSE	INITIAL VALUES		FINAL VALUES		DRIFT % OF SPAN
			SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	SYSTEM RESPONSE	SYSTEM CAL. BIAS % OF SPAN	
GAS TYPE:	Gass						
SPAN:	0						
ZERO GAS		0.00	0.00	ERR	0.00	ERR	ERR
UPSCALE GAS		0.00	0.00	ERR	0.00	ERR	ERR
CMA:		0.00		CO:	0.00	CM:	0.00

TOTAL SOURCE ANALYSIS, INC.
 ENVIROMENTAL TESTING CONSULTANTS

Gas Certification Sheets



Scott Specialty Gases, Inc.

1290 COMBERMERE STREET, TROY, MI 48083

(313) 589-2950 FAX: (313) 589-2134

CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS

Customer
TOTAL SOURCE ANALYSIS
510 DICKSON STREET
WELLINGTON, OH, 44090

Assay Laboratory
Scott Specialty Gases, Inc.
1290 Combermere
Troy, MI 48083

Purchase Order 1344
Scott Project # 558885

ANALYTICAL INFORMATION

Certified to exceed the minimum specifications of EPA Protocol 1 Procedure #G1, Section Number 3.0.4

Cylinder Number ALM023664 **Certification Date** 12-8-93 **Expiration Date** 12-7-96
Cylinder Pressure 1900 psig **Previous Certification Dates** None

ANALYZED CYLINDER

Components **Certified Concentration** **Analytical Uncertainty***
Carbon Monoxide 14.74 ppm ±1% NIST Directly Traceable

Balance Gas: Nitrogen

*Analytical uncertainty is inclusive of usual known error sources which at least includes reference standard error & precision of the measurement processes.

REFERENCE STANDARD

Type **Expiration Date** **Cylinder Number** **Concentration**
CRM 1678 5-12-94 AAL6302 45.76 PPM CO IN N₂

INSTRUMENTATION

Instrument/Model/Serial # **Last Date Calibrated** **Analytical Principle**
CO: Beckman/867/0100157 11-10-93 Non-Dispersive Infrared

ANALYZER READINGS (Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

Components	First Triad Analysis	Second Triad Analysis	Calibration Curve
Carbon Monoxide	Date: 11-29-93 Response Units: mv Z1=0.00 R1=46.80 T1=15.20 R2=46.80 Z2=0.00 T2=15.20 Z3=0.00 T3=15.20 R3=46.80 Avg. Conc. of Cust. Cyl. 14.74 ppm	Date: 12-8-93 Response Units: mv Z1=0.00 R1=46.80 T1=15.20 R2=46.80 Z2=0.00 T2=15.20 Z3=0.00 T3=15.20 R3=46.80 Avg. Conc. of Cust. Cyl. 14.74 ppm	Concentration=A+Bx+Cx ² +Dx ³ +Ex ⁴ r=0.99999 CRM 1678 Constants: A=0.3465483 B=0.9339077 C=0.00095399 D=-0.000003327 E=0
			Concentration=A+Bx+Cx ² +Dx ³ +Ex ⁴
			Concentration=A+Bx+Cx ² +Dx ³ +Ex ⁴

Special Notes

Tim Sanderson
Analyst Tim Sanderson



Scott Specialty Gases, Inc.

1290 COMBERMERE STREET, TROY, MI 48083

(810) 589-2950 FAX: (810) 589-2134

CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS

Customer TOTAL SOURCE ANALYSIS 510 DICKSON STREET WELLINGTON, OH 44090-1171	Assay Laboratory Scott Specialty Gases, Inc 1290 Combermere Troy, MI 48083	Purchase Order : 2004 Scott Project # : 575700
---	--	---

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay and Certification of Gaseous Calibration Standards; Procedure G1; September, 1993.

Cylinder Number : ALM028243	Certificate Date : 1/13/95	Expiration Date : 1/13/98
Cylinder Pressure + : 1900 psig	Previous Certificate Date : None	

ANALYZED CYLINDER

Components Carbon Monoxide	Certified Concentration 29.73 ppm	Analytical Uncertainty* ±1% NIST Directly Traceable
--------------------------------------	---	---

Balance Gas: Nitrogen

+Do not use when cylinder pressure is below 150 psig.

*Analytical accuracy is inclusive of usual known error sources which at least include precision of the measurement processes.

REFERENCE STANDARD

Type NTRM 1679	Expiration Date 8/11/96	Cylinder Number ALM037782	Concentration 97.10 ppm Carbon Monoxide in Nitrogen
--------------------------	-----------------------------------	-------------------------------------	---

INSTRUMENTATION

Instrument/Model/Serial # CO:Horiba/OPE-135/565607092	Last Date Calibrated 1/13/95	Analytical Principle Non-Dispersive Infrared
---	--	--


ANALYZER READINGS (Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

Components	First Triad Analysis	Second Triad Analysis	Calibration Curve
Carbon Monoxide	Date: 1/8/95 Response Units: mv Z1=0.00 R1=80.00 T1=25.00 R2=80.00 Z2=0.00 T2=25.00 Z3=0.00 T3=25.00 R3=80.00 Avg. Conc. of Cust. Cyl. 29.67 ppm	Date: 1/13/95 Response Units: mv Z1=0.00 R1=80.00 T1=25.10 R2=80.00 Z2=0.00 T2=25.10 Z3=0.00 T3=25.10 R3=80.00 Avg. Conc. of Cust. Cyl. 29.79 ppm	$Concentration = A + Bx + Cx^2 + Dx^3 + Ex^4$ r=1.00000 NTRM 1679 Constant: A=0.059415000 B=1.202500000 C=-0.001100400 D=0.000015397 E=0.000000000

Special Notes

Mail

H2


Analyst



610-691-2474
FAX # 610-758-8384

BEST AVAILABLE COPY

LIQUID CARBONIC

CYLINDER GAS PRODUCTS

EAST COAST REGION
145 SHIMERSVILLE RD., BETHLEHEM, PA 18015

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

CUSTOMER S/T CANTON

P.O NUMBER 49763

REFERENCE STANDARD

COMPONENT	NIST SRM NO.	CYLINDER NO.	CONCENTRATION
CARBON MONOXIDE	49.7 PPM GMIS VS. 1678C	CAL-6763	45.2 PPM

ANALYZER READINGS

R=REFERENCE STANDARD

Z=ZERO GAS

C=GAS CANDIDATE

COMPONENT	CARBON MONOXIDE	49.7 PPM	ANALYZER MAKE-MODEL-S/N	SIEMENS ULTRAMAT 5E	33-300										
ANALYTICAL PRINCIPLE	NON-DISPERSIVE INFRARED		LAST CALIBRATION DATE	03/31/95											
FIRST ANALYSIS DATE	04/17/95		SECOND ANALYSIS DATE	04/25/95											
Z	0.00	R	50.8	C	63.4	CONC.	62.0	Z	0.00	R	50.6	C	63.2	CONC.	62.1
R	50.8	Z	0.00	C	63.4	CONC.	62.0	R	50.6	Z	0.00	C	63.2	CONC.	62.1
Z	0.00	C	63.4	R	50.8	CONC.	62.0	Z	0.00	C	63.2	R	50.6	CONC.	62.1
U/M	PPM	MEAN TEST ASSAY		62.0	U/M	PPM	MEAN TEST ASSAY		62.1						

THIS CYLINDER NO.	SA6640	CERTIFIED CONCENTRATION	
HAS BEEN CERTIFIED ACCORDING TO SECTION	EPA-600/R93/224	CARBON MONOXIDE	62.0 ppm
OF TRACEABILITY PROTOCOL NO.	REV. 9/93	NITROGEN	BALANCE
PROCEDURE	G1		
CERTIFIED ACCURACY	± 1 % NIST TRACEABLE		
CYLINDER PRESSURE	1650PSIG		
CERTIFICATION DATE	04/25/95		
EXPIRATION DATE	04/25/98		

ANALYZED BY

Daniel J. Day
DANIEL J. DAY, H3

CERTIFIED BY

Robert Hillard
ROBERT HILLARD



Scott Specialty Gases, Inc.

1290 COMBERMERE STREET, TROY, MI 48083

(810) 589-2950 FAX:(810) 589-2134

CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS

Customer
TOTAL SOURCE ANALYSIS
510 DICKSON STREET
WELLINGTON, OH 44090-1171

Assay Laboratory
Scott Specialty Gases, Inc
1290 Combermere
Troy, MI 48083

Purchase Order : 1477
Scott Project # : 568881

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay and Certification of Gaseous Calibration Standards; Procedure G1; September, 1993.

Cylinder Number : ALM049209
Cylinder Pressure + : 1900 psig

Certificate Date : 7/25/94
Previous Certificate Date : None

Expiration Date : 7/25/97

ANALYZED CYLINDER

Components
Carbon Dioxide

Certified Concentration
10.9 %

Analytical Uncertainty*
±1% NIST Directly Traceable

Balance Gas: Nitrogen

+Do not use when cylinder pressure is below 150 psig.

*Analytical accuracy is inclusive of usual known error sources which at least include precision of the measurement processes.

REFERENCE STANDARD

Type	Expiration Date	Cylinder Number	Concentration
SRM 2745	11/3/96	SX20311	15.75 % Carbon Dioxide in Nitrogen

INSTRUMENTATION

Instrument/Model/Serial #
CO2:Horiba/PIR-2000/02609015

Last Date Calibrated
7/14/94

Analytical Principle
Non-Dispersive Infrared

ANALYZER READINGS (Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

Components
Carbon Dioxide

First Triad Analysis		
Date: 7/25/94	Response Units: mv	
Z1=0.00	R1=120.90	T1=95.90
R2=120.90	Z2=0.00	T2=95.90
Z3=0.00	T3=95.90	R3=120.90
Avg. Conc. of Cust. Cyl. 10.9 %		

Second Triad Analysis

Calibration Curve

Concentration = A + Bx + Cx ² + Dx ³ + Ex ⁴	
r=1.00000	SRM 2745
Constant:	A=-1.415500000
B=0.140570000	C=-0.000842590
D=0.000005418	E=0.000000000

Special Notes

H4


Analyst Rhonda Lundy

CERTIFICATE OF ANALYSIS

EPA PROTOCOL

PERFORMED ACCORDING TO SECTION 2.2, PROCEDURE G1

Production Number: 12940090

Cylinder Number: CC7791

Cylinder Pressure: 2000 psi

NOTICE, THIS CYLINDER IS NOT TO BE USED WHEN PRESSURE IS UNDER 150 psig

Certified Component	Certified Concentration	Date of Certification	Analytical Method
Carbon Dioxide	13.93%	1/23/95	Non-Dispersive Infrared

Expiration Date: 1/23/98


Balance Gas: Nitrogen

REFERENCE STANDARD DATA

SRM Number	Cylinder Number	Concentration
GMIS	CC4109	13.93% Carbon Dioxide

CERTIFIED AT:

AGA Gas Inc.
Specialty & Medical Gas Division
6421 Monclova Road
Maumee, Ohio 43537


Michael Sickmiller
Quality Control Supervisor



Scott Specialty Gases, Inc.

1290 COMBERMERE STREET, TROY, MI 48083

(810) 589-2950 FAX:(810) 589-2134

CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS

Customer

TOTAL SOURCE ANALYSIS
510 DICKSON STREET
WELLINGTON, OH 44090-1171

Assay Laboratory

Scott Specialty Gases, Inc
1290 Combermere
Troy, MI 48083

Purchase Order : 1477
Scott Project # : 568881

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay and Certification of Gaseous Calibration Standards; Procedure G1; September, 1993.

Cylinder Number : ALM049101
Cylinder Pressure + : 1900 psig

Certificate Date : 7/25/94
Previous Certificate Date : None

Expiration Date : 7/25/97

ANALYZED CYLINDER

Components

Carbon Dioxide

Certified Concentration

17.2 %

Analytical Uncertainty*

±1% NIST Directly Traceable

Balance Gas: Nitrogen

+Do not use when cylinder pressure is below 150 psig.

*Analytical accuracy is inclusive of usual known error sources which at least include precision of the measurement processes.

REFERENCE STANDARD

Type	Expiration Date	Cylinder Number	Concentration
SRM 2745	11/3/96	SX20311	15.75 % Carbon Dioxide in Nitrogen

INSTRUMENTATION

Instrument/Model/Serial

CO2:Horiba/PIR-2000/02609015

Last Date Calibrated

7/14/94

Analytical Principle

Non-Dispersive Infrared

ANALYZER READINGS (Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

Components
Carbon Dioxide

First Triad Analysis

Date: 7/25/94 Response Units: mv

Z1=0.00	R1=120.90	T1=127.10
R2=120.90	Z2=0.00	T2=127.10
Z3=0.00	T3=127.10	R3=120.90

Avg. Conc. of Cust. Cyl. 17.2 %

Second Triad Analysis

[Empty box for Second Triad Analysis]

Calibration Curve

Concentration=A+Bx+Cx²+Dx³+Ex⁴


r=1.00000 SRM 2745

Constants: A=-1.415500000

B=0.140570000 C=0.000842590

D=0.000005418 E=0.000000000

Special Notes



Analyst Rhonda Lundy

Air Products and Chemicals, Inc.
SPECIALTY GAS DEPARTMENT
12722 S. WENTWORTH AVENUE
CHICAGO, IL 60628

BEST AVAILABLE COPY

Certificate of Analysis - EPA Protocol Gas Standard

Page 1 of 1

PERFORMED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS (PROCEDURE #G)

Customer: APCI
5420 WARNER RD,
VALLEY VIEW
CLEVELAND OH 44125

Notes:

Order No: 231-01952
Batch No: 861-23317
Cylinder No: SG9133258
Cylinder Pressure*: 2000 psig
Certification Date: 01/23/95
Expiration Date: 01/23/98

PO: Rel:

*** Certified Concentration *** ***** Reference Standards ***** ***** Analytical Instrumentation *****

Component	Certified Concentration	Cylinder #	Standard Number	Concentration	Instrument Make/Model	Serial Number	Last Calibration	Measurement Principal
OXYGEN	11.6 ±.10 %	SG9113455BAL	GMIS	15.0500 %	Shimadzu GC-8A	32029	01/18/95	GC-TCD

Balance Gas: Nitrogen

* Standard should not be used below 150 psig

H7

Analyst: Shaher Aboor
Shaher Aboor

Approved By: Robert McNear
Robert McNear



Scott Specialty Gases, Inc.

1290 COMBERMERE STREET, TROY, MI 48083

(810) 589-2950 FAX:(810) 589-2134

CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS

Customer
TOTAL SOURCE ANALYSIS
510 DICKSON STREET
WELLINGTON, OH 44090-1171

Assay Laboratory
Scott Specialty Gases, Inc
1290 Combermere
Troy, MI 48083

Purchase Order : 1433
Scott Project # : 565319

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay and Certification of Gaseous Calibration Standards; Procedure G1; September, 1993.

Cylinder Number : ALM028068
Cylinder Pressure + : 1900 psig

Certificate Date : 4/28/94
Previous Certificate Date : None

Expiration Date : 4/28/97

ANALYZED CYLINDER

Components

Carbon Monoxide

Certified Concentration

302.0 ppm

Analytical Uncertainty*

±1% NIST Directly Traceable

Balance Gas: Nitrogen

+Do not use when cylinder pressure is below 150 psig.

*Analytical accuracy is inclusive of usual known error sources which at least include precision of the measurement processes.

REFERENCE STANDARD

Type	Expiration Date	Cylinder Number	Concentration
CRM 1681	7/19/95	ALM-024827	966.1 ppm Carbon Monoxide in Nitrogen

INSTRUMENTATION

Instrument/Model/Serial #
CO : Beckman/864/102528

Last Date Calibrated
4/15/94

Analytical Principle
Non-Dispersive Infrared

ANALYZER READINGS (Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

Components	First Triad Analysis	Second Triad Analysis	Calibration Curve
Carbon Monoxide	Date: 3/15/94 Response Units: mv Z1=0.00 R1=100.00 T1=35.40 R2=100.00 Z2=0.00 T2=35.40 Z3=0.00 T3=35.40 R3=100.00 Avg. Conc. of Cust. Cyl. 302.0 ppm	Date: 4/28/94 Response Units: mv Z1=0.00 R1=100.00 T1=35.40 R2=100.00 Z2=0.00 T2=35.40 Z3=0.00 T3=35.40 R3=100.00 Avg. Conc. of Cust. Cyl. 302.0 ppm	Concentration = $A + Bx + Cx^2 + Dx^3 + Ex^4$ r=1.00000 CRM 1681 Constants: A=-0.182760000 B=7.918200000 C=0.017444000 D=0.000000000 E=0.000000000

Special Notes

H8

Analyst Don Eichler, Jr



Scott Specialty Gases, Inc.

1290 COMBERMERE STREET, TROY, MI 48083

(810) 589-2950 FAX:(810) 589-2134

CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS

Customer
TOTAL SOURCE ANALYSIS
510 DICKSON STREET
WELLINGTON, OH 44090-1171

Assay Laboratory
Scott Specialty Gases, Inc
1290 Combermere
Troy, MI 48083

Purchase Order : 1433
Scott Project # : 565319

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay and Certification of Gaseous Calibration Standards; Procedure G1; September, 1993.

Cylinder Number : ALM012900
Cylinder Pressure + : 1900 psig

Certificate Date : 4/28/94
Previous Certificate Date : None

Expiration Date : 4/28/97

ANALYZED CYLINDER

Components

Carbon Monoxide

Certified Concentration

603.5 ppm

Analytical Uncertainty*

±1% NIST Directly Traceable

Balance Gas: Nitrogen

+Do not use when cylinder pressure is below 150 psig.

*Analytical accuracy is inclusive of usual known error sources which at least include precision of the measurement processes.

REFERENCE STANDARD

Type	Expiration Date	Cylinder Number	Concentration
CRM 1681	7/19/95	ALM-024827	966.1 ppm Carbon Monoxide in Nitrogen

INSTRUMENTATION

Instrument/Model/Serial #
CO : Beckman/864/102528

Last Date Calibrated
4/15/94

Analytical Principle
Non-Dispersive Infrared

ANALYZER READINGS (Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

Components	First Triad Analysis			Second Triad Analysis			Calibration Curve	
	Date: 2/8/94	Response Units: mv		Date: 4/28/94	Response Units: mv		Concentration: $A+Bx-Cx^2-Dx^3+Ex^4$	
Carbon Monoxide	Z1=0.00	R1=100.00	T1=68.50	Z1=0.00	R1=100.00	T1=68.50	r=1.00000	CRM 1681
	R2=100.00	Z2=0.00	T2=68.50	R2=100.00	Z2=0.00	T2=68.50	Constant:	A=0.162760000
	Z3=0.00	T3=68.50	R3=100.00	Z3=0.00	T3=68.50	R3=100.00	B=7.918200000	C=0.017444000
	Avg. Conc. of Cust. Cyl. 603.5 ppm			Avg. Conc. of Cust. Cyl. 603.5 ppm			D=0.000000000	E=0.000000000

Special Notes

H9

Don Eichler, Jr.
Analyst Don Eichler, Jr

Calibrations of Test Equipment

Best Available Copy

DRY GAS METER CALIBRATION SHEET

CLIENT: SHOP Q.A.Q.C.
 PROJECT NUMBER: 95-000-PL
 MODULE: RAC # 2
 ORIFICE: 2.999

RUN BY: T.ROTH
 DATE: 5/18/95
 BAROMETRIC PRESSURE 29.99

DELTA H IN.H2O	Vw Initial	Vw Final	Vw Cub.Feet	Vd Initial	Vd Final	Vd Cub.Feet	Tw F	TDi F	TDo F	Td F	Time Min
0.5	8.000	12.067	4.067	675.315	779.246	4.139	66.5	85.0	77.0	81.00	10.0
1.0	13.000	18.619	5.619	680.768	789.387	6.735	66.5	89.0	78.0	83.50	10.0
1.5	20.000	26.800	6.800	687.995	804.795	6.802	67.0	92.0	80.0	86.00	10.0
2.0	29.000	36.935	7.935	697.310	798.245	6.376	67.0	92.0	80.0	86.00	10.0
3.0	39.000	48.370	9.370	707.955	717.330	5.825	67.0	96.0	82.0	89.00	10.0

DELTA H IN.H2O	DELTA H 13.6	MC/Y	Yi	DELTA Ha @1	DELTA Ha @1	METER CORR. FACTOR	ORIFICE
0.50	0.0368	1.011	-0.015	1.837	0.088	0.986	2.999
1.00	0.0735	1.009	-0.013	1.708	0.017	DELTA H @1 1.725	
1.50	0.1103	1.007	-0.011	1.744	-0.019		
2.00	0.1471	0.977	0.019	1.708	0.017		
3.00	0.2208	0.976	0.020	1.827	-0.102		

WHERE: AH = Orifice Setting
 Vw = Volume of Gas of Wet Test Meter
 Vd = Volume of Gas of Dry Gas Meter
 Tw = Temperature of Fluid in Wet Test Meter
 Tdi = Inlet Temperature of Dry Gas Meter
 Tdo = Outlet Temperature of Dry Gas Meter
 Td = Average Temperature of Dry Gas Meter
 Time = Time Required to pull specific cubic feet
 Mc = Dry Gas Meter Correction Factor
 A Ha = Orifice setting that equates to .75 cfm of air at standard conditions
 A Hai = Ha tolerance; tolerance for individual values (+/-) .20 from average
 Yi = Ratio of reading of Wet Test Meter to Dry Gas Meter; tolerance for individual values (+/-) .02 from average

EQUATIONS: Mc (Y)

$$\frac{Vw Pb (Td + 460)}{Vd (Pb + AH/13.6)(Tw + 460)}$$

AH (a)

$$\frac{0.0317 AH}{Pb (Td + 460)} \left| \frac{(Tw + 460)Time}{Vw} \right|^2$$

T. Roth

SHOP Q.A.Q.C.
 85-000-FL
 RAC # 2
 5/18/95

ORIFICE CALCULATIONS

DELTA H	INITIAL	
	F/Min	X ²
0.5	0.4130	0.1706
1.0	0.5735	0.3289
1.5	0.8973	0.4802
2.0	0.8378	0.7016
3.0	0.8925	0.8851

POSSIBLE COMBINATIONS

1 (3.0 - 2.0)	1	3.6278	-17.64%
2 (3.0 - 1.5)	2	3.0070	-0.28%
3 (3.0 - 1.0)	3	3.0481	-1.65%
4 (3.0 - .50)	4	3.0894	-2.36%
5 (2.0 - 1.5)	5	2.3218	22.57%
6 (2.0 - 1.0)	6	2.8833	10.61%
7 (2.0 - .50)	7	2.8248	6.80%
8 (1.5 - 1.0)	8	3.1701	-5.99%
9 (1.5 - .50)	9	3.1680	-5.66%
10 (1.0 - .50)	10	3.1570	-5.31%

AVERAGE ORIFICE 2.9986

Nozzle Calibration


Sized By T. Roth Shop QA QC.

Date	Nozzle	Dimension			Difference	Avg. Diameter
		A	B	C		
2-21-95	F1-01	.120	.120	.120	.000	.120
2-21-95	F1-02	.139	.139	.140	.001	.137
2-21-95	F1-03	.186	.188	.187	.002	.187
2-21-95	F1-04	.187	.187	.187	.000	.187
2-21-95	F1-05					
2-21-95	F1-06	.231	.230	.232	.002	.231
2-21-95	F1-07	.250	.249	.249	.001	.249
2-21-95	F1-08	.248	.249	.248	.001	.248
2-21-95	F1-09	.250	.250	.250	.000	.250
2-21-95	F1-10	.250	.250	.250	.000	.250
2-21-95	F1-11	.252	.252	.251	.001	.252
2-21-95	F1-12	.375	.374	.375	.001	.375
2-21-95	F1-13	.302	.302	.301	.001	.302
2-21-95	F1-14	.305	.306	.306	.001	.306
2-21-95	F1-15	.314	.315	.315	.001	.315
2-21-95	F1-16	.374	.375	.374	.001	.374
2-21-95	F1-17	.372	.373	.372	.001	.372
2-21-95	F1-18	.371	.372	.372	.001	.372
2-21-95	F1-19	.370	.369	.371	.002	.370
2-21-95	F1-20	.438	.437	.438	.001	.438
2-21-95	F1-22	.501	.502	.503	.002	.502
2-21-95	F1-21	.496	.495	.496	.001	.496
2-21-95	F1-23	.501	.501	.501	.000	.501
2-21-95	F1-24	.501	.500	.501	.001	.501
2-21-95	F1-25	.494	.495	.494	.001	.494
2-21-95	F1-27	.496	.495	.498	.002	.498
2-22-95	F1-26	.753	.753	.753	.000	.753

All Dimensions are in inches.



Total Source Analysis, Inc.
Environmental Testing Consultants



Pitot Calibration Form

Client Shop Quality
 Project No. _____
 Test Location Umatilla, FL

Run By T. Roth / J. Toyfel
 Date 2-27-95
 Pitot No. A-10-1-1-FL

● "A" Side Calibration

Run No.	ΔP_{std} cm H ₂ O (in H ₂ O)	ΔP (s) cm H ₂ O (in. H ₂ O)	$C_p(s)$	Deviation $C_p(s) - \bar{C}_p(A)$
1	.840	1.200	.828	-0.360
2	.860	1.267	.816	-0.407
3	.903	1.200	.859	-0.397
Average		\bar{C}_p (Side A)	.834	-0.355

Calculations:

$$C_p(s) = 0.99 \sqrt{\frac{\Delta P \text{ (standard)}}{\Delta P (s)}}$$

$$\text{Deviation} = C_p(s) - \bar{C}_p(A \text{ or } B)$$

$$\text{Average Deviation} = \sigma(A \text{ or } B) = \frac{1}{3} \sum |C_p(s) - \bar{C}_p(A \text{ or } B)|$$

$$|\bar{C}_p(\text{Side A}) - \bar{C}_p(\text{Side B})| = \underline{-0.013}$$

●● "B" Side Calibration

Run No.	ΔP_{std} cm H ₂ O (in H ₂ O)	ΔP (s) cm H ₂ O (in. H ₂ O)	$C_p(s)$	Deviation $C_p(s) - \bar{C}_p(B)$
1	.840	1.200	.828	-0.360
2	.860	1.233	.827	-0.373
3	.903	1.200	.859	-0.397
Average		\bar{C}_p (Side B)	.838	-0.343

Nozzle size used for Calibrations (inches) 1/4" FI-003

Intercomponent Spacings During Calibrations:

Pitot - Nozzle: ± 3/4"

Pitot - Thermocouple: 1/2"

Pitot - Probe Sheath: 1/2"



Total Source Analysis, Inc.
 Environmental Testing Consultants

Pitot Calibration Form

Client Shop Quality
 Project No. _____
 Test Location Umatilla, FL.

Run By T. Roth / J. Tayfel
 Date 2-27-95
 Pitot No. N-10-G1F

● "A" Side Calibration

Run No.	ΔP_{std} cm H ₂ O (in H ₂ O)	ΔP (s) cm H ₂ O (in. H ₂ O)	C _p (s)	Deviation C _p (s) - \bar{C}_p (A)
1	.840	1.133	.852	-0.293
2	.860	1.100	.875	-0.240
3	.903	1.100	.897	-0.197
Average		\bar{C}_p (Side A)	.875	-0.243

Calculations:

$$C_p(s) = 0.99 \sqrt{\frac{\Delta P \text{ (standard)}}{\Delta P (s)}}$$

Deviation = C_p (s) - \bar{C}_p (A or B)

$$\text{Average Deviation} = \sigma (A \text{ or } B) = \frac{1}{n} \sum |C_p(s) - \bar{C}_p(A \text{ or } B)|$$

| \bar{C}_p (Side A) - \bar{C}_p (Side B)| = .022³

●● "B" Side Calibration

Run No.	ΔP_{std} cm H ₂ O (in H ₂ O)	ΔP (s) cm H ₂ O (in. H ₂ O)	C _p (s)	Deviation C _p (s) - \bar{C}_p (B)
1	.840	1.133	.852	-0.293
2	.860	1.133	.863	-0.273
3	.903	1.133	.884	-0.230
Average		\bar{C}_p (Side B)	.866	-0.265

Nozzle size used for Calibrations (inches) 3/8" F1-017

Intercomponent Spacings During Calibrations:

Pitot - Nozzle: 3/4"

Pitot - Thermocouple: 1 1/2"

Pitot - Probe Sheath: 1 1/2"



Total Source Analysis, Inc.
 Environmental Testing Consultants

Laboratory Reports

Run No. 1
 Filter No. 95-028-FL
 Acetone No. FL-01
 Amount liquid lost during transport 0.0 mL
 Acetone blank volume, ml 100.0 mL
 Acetone wash volume, ml 100 mL
 Acetone blank concentration, mg/mg (equation 5-4)** -
 Acetone wash blank, mg (equation 5-5)** -

Run No. 2
 Filter No. 95-029-FL
 Acetone No. FL-01
 Amount liquid lost during transport 0.0 mL
 Acetone blank volume, ml 100.0 mL
 Acetone wash volume, ml 100 mL
 Acetone blank concentration, mg/mg (equation 5-4)** -
 Acetone wash blank, mg (equation 5-5)** -

Container Number	Weight of Particulate Collected g		
	Final Weight	Tare Weight	Weight Gain
1	60.448	60.018	.0030
2	60.4492	60.4336	.0156
Total			.0186
Less acetone blank			.0002
Weight of particulate matter			.0184

Container Number	Weight of Particulate Collected g		
	Final Weight	Tare Weight	Weight Gain
1	60.96	60.61	.0029
2	71.0504	71.0154	.0350
Total			.0379
Less acetone blank			.0002
Weight of particulate matter			.0377

	Volume of Liquid Water Collected	
	Impinger Volume, ml	Silica Gel Weight, g
Final	445.0	266.8
Initial	200.0	250.0
Liquid collected	245.0	16.8
Total Volume Collected	261.8 mL	g ✓ ml

	Volume of Liquid Water Collected	
	Impinger Volume, ml	Silica Gel Weight, g
Final	439.0	267.7g
Initial	200.0	250.0
Liquid collected	239.0	17.7
Total Volume Collected	256.7 mL	g ✓ ml

Run No. 3
 Filter No. 95-030-FL
 Acetone No. FL-01
 Amount liquid lost during transport 0.0 mL
 Acetone blank volume, ml 100.0 mL
 Acetone wash volume, ml 100 mL
 Acetone blank concentration, mg/mg (equation 5-4)** -
 Acetone wash blank, mg (equation 5-5)** -

Run No. Blank
 Filter No. -
 Acetone No. FL-01
 Amount liquid lost during transport 0.0 mL
 Acetone blank volume, ml 100.0 mL
 Acetone wash volume, ml 100.0 mL
 Acetone blank concentration, mg/mg (equation 5-4)** -
 Acetone wash blank, mg (equation 5-5)** -

Container Number	Weight of Particulate Collected g		
	Final Weight	Tare Weight	Weight Gain
1	60.41	59.88	.0053
2	70.8370	70.8063	.0307
Total			.0360
Less acetone blank			.0002
Weight of particulate matter			.0358

Container Number	Weight of Particulate Collected g		
	Final Weight	Tare Weight	Weight Gain
1	-	-	-
2	73.4360	73.4358	.0002
Total			.0002
Less acetone blank			-
Weight of particulate matter			.0002

	Volume of Liquid Water Collected	
	Impinger Volume, ml	Silica Gel Weight, g
Final	445.0	266.4g
Initial	200.0	250.8
Liquid collected	245.0	16.4g
Total Volume Collected	261.4 mL	g ✓ ml

	Volume of Liquid Water Collected	
	Impinger Volume, ml	Silica Gel Weight, g
Final	-	-
Initial	-	-
Liquid collected	-	-
Total Volume Collected	-	- g ✓ ml

*Convert weight of water to volume by dividing total weight increase by density of water (1g/ml): $\frac{\text{Increase, g}}{1\text{g/ml}} = \text{Volume Water, ml}$
 **See Federal Register, Method 5, 6.6, & 6.7.

Client TEA. S.J.R.P.P. Project No. 95-058-FL Date 8-15-95

Run No. 1
 Filter No. 95-031-F1
 Acetone No. F1-01
 Amount liquid lost during transport 0.0
 Acetone blank volume, ml 100.0
 Acetone wash volume, ml 100 mL
 Acetone blank concentration, mg/mg (equation 5-4)** -
 Acetone wash blank, mg (equation 5-5)** -

Container Number	Weight of Particulate Collected g		
	Final Weight	Tare Weight	Weight Gain
1	.6008	.5937	.0071
2	80.6911	80.6842	.0069
Total			.0140
Less acetone blank			.0002
Weight of particulate matter			.0138

	Volume of Liquid Water Collected	
	Impinger Volume, ml.	Silica Gel Weight, g
Final	444.0	261.9
Initial	200.0	250.0
Liquid collected	244.0	17.4
Total Volume Collected	261.9	g ✓ ml

Run No. 2
 Filter No. 95-032-FL
 Acetone No. F1-01
 Amount liquid lost during transport 0.0
 Acetone blank volume, ml 100.0
 Acetone wash volume, ml 100
 Acetone blank concentration, mg/mg (equation 5-4)** -
 Acetone wash blank, mg (equation 5-5)** -

Container Number	Weight of Particulate Collected g		
	Final Weight	Tare Weight	Weight Gain
1	.6072	.6022	.0050
2	74.9549	74.9429	.0120
Total			.0170
Less acetone blank			.0002
Weight of particulate matter			.0168

	Volume of Liquid Water Collected	
	Impinger Volume, ml.	Silica Gel Weight, g
Final	466.0	268.1
Initial	200.0	250.0
Liquid collected	266.0	18.10
Total Volume Collected	284.1	g ✓ ml

Run No. 3
 Filter No. 95-033-F1
 Acetone No. F1-01
 Amount liquid lost during transport 0.0ml
 Acetone blank volume, ml 100.0ml
 Acetone wash volume, ml 100.0ml
 Acetone blank concentration, mg/mg (equation 5-4)** -
 Acetone wash blank, mg (equation 5-5)** -

Container Number	Weight of Particulate Collected g		
	Final Weight	Tare Weight	Weight Gain
1	.5884	.5827	.0057
2	74.7372	74.4244	.0128
Total			.0185
Less acetone blank			.0002
Weight of particulate matter			.0183

	Volume of Liquid Water Collected	
	Impinger Volume, ml.	Silica Gel Weight, g
Final	456.0	269.7
Initial	200.0	250.0
Liquid collected	256.0	19.7
Total Volume Collected	275.7	g ✓ ml

Run No. Blank
 Filter No. -
 Acetone No. F1-01
 Amount liquid lost during transport 0.0
 Acetone blank volume, ml 100.0
 Acetone wash volume, ml -
 Acetone blank concentration, mg/mg (equation 5-4)** -
 Acetone wash blank, mg (equation 5-5)** -

Container Number	Weight of Particulate Collected g		
	Final Weight	Tare Weight	Weight Gain
1			
2	73.4360	73.4358	.0002
Total			.0002
Less acetone blank			-
Weight of particulate matter			.0002

	Volume of Liquid Water Collected	
	Impinger Volume, ml.	Silica Gel Weight, g
Final	-	-
Initial	-	-
Liquid collected	-	-
Total Volume Collected	-	- g ✓ ml

*Convert weight of water to volume by dividing total weight increase by density of water (1g/ml): $\frac{\text{Increase, g}}{1\text{g/ml}} = \text{Volume Water, ml}$

**See Federal Register, Method 5, 6.6, & 6.7.

BEST AVAILABLE COPY

Run No. _____
 Filter No. 95-034-F1
 Acetone No. F1-01
 Amount liquid lost during transport 0.0
 Acetone blank volume, ml 100.0
 Acetone wash volume, ml 100
 Acetone blank concentration, mg/mg (equation 5-4)** _____
 Acetone wash blank, mg (equation 5-5)** _____

Run No. 2
 Filter No. 95-035-F1
 Acetone No. F1-01
 Amount liquid lost during transport 0.0
 Acetone blank volume, ml 100.0
 Acetone wash volume, ml 100
 Acetone blank concentration, mg/mg (equation 5-4)** _____
 Acetone wash blank, mg (equation 5-5)** _____

Container Number	Weight of Particulate Collected g		
	Final Weight	Tare Weight	Weight Gain
1	<u>.5941</u>	<u>.5895</u>	<u>.0005</u>
2	<u>60.4382</u>	<u>60.4309</u>	<u>.0073</u>
Total			<u>.0078</u>
Less acetone blank			<u>.0002</u>
Weight of particulate matter			<u>.0076</u>

Container Number	Weight of Particulate Collected g		
	Final Weight	Tare Weight	Weight Gain
1	<u>.6107</u>	<u>.6061</u>	<u>.0040</u>
2	<u>71.0246</u>	<u>70.9144</u>	<u>.0102</u>
Total			<u>.0142</u>
Less acetone blank			<u>.0002</u>
Weight of particulate matter			<u>.0140</u>

	Volume of Liquid Water Collected	
	Impinger Volume, ml.	Silica Gel Weight, g
Final	<u>435.0</u>	<u>261.6</u>
Initial	<u>200.0</u>	<u>250.0</u>
Liquid collected	<u>235.0</u>	<u>11.6</u>
Total Volume Collected	<u>246.6</u>	<u>g</u> ✓ ml

	Volume of Liquid Water Collected	
	Impinger Volume, ml.	Silica Gel Weight, g
Final	<u>435.0</u>	<u>271.4</u>
Initial	<u>200.0</u>	<u>250.0</u>
Liquid collected	<u>235.0</u>	<u>21.4</u>
Total Volume Collected	<u>256.4</u>	<u>g</u> ✓ ml

No. 3
 Filter No. 95-036-F1
 Acetone No. F1-01
 Amount liquid lost during transport 0.0
 Acetone blank volume, ml 100.0
 Acetone wash volume, ml 100.0
 Acetone blank concentration, mg/mg (equation 5-4)** _____
 Acetone wash blank, mg (equation 5-5)** _____

Run No. Blank
 Filter No. _____
 Acetone No. F1-01
 Amount liquid lost during transport _____
 Acetone blank volume, ml 0.0
 Acetone wash volume, ml 100.0
 Acetone blank concentration, mg/mg (equation 5-4)** _____
 Acetone wash blank, mg (equation 5-5)** _____

Container Number	Weight of Particulate Collected g		
	Final Weight	Tare Weight	Weight Gain
1	<u>.6140</u>	<u>.6082</u>	<u>.0058</u>
2	<u>70.8083</u>	<u>70.8035</u>	<u>.0048</u>
Total			<u>.0106</u>
Less acetone blank			<u>.0002</u>
Weight of particulate matter			<u>.0104</u>

Container Number	Weight of Particulate Collected g		
	Final Weight	Tare Weight	Weight Gain
1			
2	<u>73.4360</u>	<u>73.4358</u>	<u>.0002</u>
Total			<u>.0002</u>
Less acetone blank			
Weight of particulate matter			<u>.0002</u>

	Volume of Liquid Water Collected	
	Impinger Volume, ml.	Silica Gel Weight, g
Final	<u>444.0</u>	<u>270.4</u>
Initial	<u>200.0</u>	<u>250.0</u>
Liquid collected	<u>244.0</u>	<u>20.4</u>
Total Volume Collected	<u>264.4</u>	<u>g</u> ✓ ml

	Volume of Liquid Water Collected	
	Impinger Volume, ml.	Silica Gel Weight, g
Final		
Initial		
Liquid collected		
Total Volume Collected		<u>g</u> ✓ ml

* Convert weight of water to volume by dividing total weight increase by density of water (1g/ml): $\frac{\text{Increase, g}}{1\text{g/ml}} = \text{Volume Water, ml}$
 ** See Federal Register, Method 5, 6.6, & 6.7.

BEST AVAILABLE COPY

Run No. Run 1 Unit 1 Stack
 Filter No. 95-040 F
 Acetone No. _____
 Amount liquid lost during transport _____
 Acetone blank volume, ml _____
 Acetone wash volume, ml _____
 Acetone blank concentration, mg/mg (equation 5-4)** _____
 Acetone wash blank, mg (equation 5-5)** _____

Container Number	Weight of Particulate Collected g		
	Final Weight	Tare Weight	Weight Gain
1	.6138	.6073	.0065
2	80.6891	80.6860	.0031
Total			.0096
Less acetone blank			-.0001
Weight of particulate matter			.0095

	Volume of Liquid Water Collected	
	Impinger Volume, ml.	Silica Gel Weight, g
Final	390.0	265.1
Initial	200.0	250.0
Liquid collected	190.0	15.1
Total Volume Collected	205.1	g* ml

Run No. Run 2 Unit 1 Stack
 Filter No. 95-041 FL
 Acetone No. _____
 Amount liquid lost during transport _____
 Acetone blank volume, ml _____
 Acetone wash volume, ml _____
 Acetone blank concentration, mg/mg (equation 5-4)** _____
 Acetone wash blank, mg (equation 5-5)** _____

Container Number	Weight of Particulate Collected g		
	Final Weight	Tare Weight	Weight Gain
1	.6100	.6066	.0034
2	73.4353	73.4294	.0059
Total			.0093
Less acetone blank			-.0001
Weight of particulate matter			.0092

	Volume of Liquid Water Collected	
	Impinger Volume, ml.	Silica Gel Weight, g
Final	400.0	267.3
Initial	200.0	250.0
Liquid collected	200.0	17.3
Total Volume Collected	217.3	g* ml

Run No. Run 3 Unit 1 Stack
 Filter No. 95-042 FL
 Acetone No. _____
 Amount liquid lost during transport _____
 Acetone blank volume, ml _____
 Acetone wash volume, ml _____
 Acetone blank concentration, mg/mg (equation 5-4)** _____
 Acetone wash blank, mg (equation 5-5)** _____

Container Number	Weight of Particulate Collected g		
	Final Weight	Tare Weight	Weight Gain
1	.6065	.6041	.0024
2	74.9490	74.9438	.0052
Total			.0076
Less acetone blank			-.0001
Weight of particulate matter			.0075

	Volume of Liquid Water Collected	
	Impinger Volume, ml.	Silica Gel Weight, g
Final	415.0	265.8
Initial	200.0	250.0
Liquid collected	215.0	15.8
Total Volume Collected	220.8	g* ml

Run No. Blank
 Filter No. _____
 Acetone No. _____
 Amount liquid lost during transport _____
 Acetone blank volume, ml _____
 Acetone wash volume, ml _____
 Acetone blank concentration, mg/mg (equation 5-4)** _____
 Acetone wash blank, mg (equation 5-5)** _____

Container Number	Weight of Particulate Collected g		
	Final Weight	Tare Weight	Weight Gain
1			
2	73.2579	73.2578	.0001
Total			
Less acetone blank			
Weight of particulate matter			

	Volume of Liquid Water Collected	
	Impinger Volume, ml.	Silica Gel Weight, g
Final		
Initial		
Liquid collected		
Total Volume Collected		g* ml

*Convert weight of water to volume by dividing total weight increase by density of water (1g/ml): $\frac{\text{Increase, g}}{1\text{g/ml}} = \text{Volume Water, ml}$
 **See Federal Register, Method 5, 6.6, & 6.7.

Analytical Data Sheet

Client J.E.A. S.J.R.P.P. Project No. 95-058-FL. Date 8-17-95

Run No. 1
 Filter No. 95-037-F1
 Sample No. F1-01
 Amount liquid lost during transport 0.0
 Acetone blank volume, ml 100.0
 Acetone wash volume, ml 100
 Acetone blank concentration, mg/mg (equation 5-4)** -
 Acetone wash blank, mg (equation 5-5)** -

Container Number	Weight of Particulate Collected g		
	Final Weight	Tare Weight	Weight Gain
1	.6104	.6037	.0067
2	60.4485	60.4284	.0201
Total			.0268
Less acetone blank			.0002
Weight of particulate matter			.0266

	Volume of Liquid Water Collected	
	Impinger Volume, ml.	Silica Gel Weight, g
Final	450.0	270.8
Initial	200.0	250.0
Liquid collected	350.0	20.8
Total Volume Collected	270.8	g. ✓ ml

Run No. 2
 Filter No. 95-038-FL
 Sample No. F1-01
 Amount liquid lost during transport 0.0
 Acetone blank volume, ml 100.0
 Acetone wash volume, ml 100.
 Acetone blank concentration, mg/mg (equation 5-4)** -
 Acetone wash blank, mg (equation 5-5)** -

Container Number	Weight of Particulate Collected g		
	Final Weight	Tare Weight	Weight Gain
1	.5916	.5839	.0077
2	71.0334	71.0145	.0189
Total			.0266
Less acetone blank			.0002
Weight of particulate matter			.0264

	Volume of Liquid Water Collected	
	Impinger Volume, ml.	Silica Gel Weight, g
Final	433.0	273.4
Initial	200.0	250.0
Liquid collected	233.0	23.4
Total Volume Collected	256.4	g. ✓ ml

Io. 3
 Filter No. 95-039-FL
 Acetone No. FL-01
 Amount liquid lost during transport 0.0
 Acetone blank volume, ml 100.0
 Acetone wash volume, ml 100
 Acetone blank concentration, mg/mg (equation 5-4)** -
 Acetone wash blank, mg (equation 5-5)** -

Container Number	Weight of Particulate Collected g		
	Final Weight	Tare Weight	Weight Gain
1	.6062	.5997	.0065
2	70.8138	70.8026	.0112
Total			.0177
Less acetone blank			.0002
Weight of particulate matter			.0175

	Volume of Liquid Water Collected	
	Impinger Volume, ml.	Silica Gel Weight, g
Final	440.0	271.6
Initial	200.0	250.0
Liquid collected	240.0	21.6
Total Volume Collected	261.6	g. ✓ ml

Run No. Blank.
 Filter No. -
 Acetone No. F1-01
 Amount liquid lost during transport 0.0
 Acetone blank volume, ml 100.0 L
 Acetone wash volume, ml -
 Acetone blank concentration, mg/mg (equation 5-4)** -
 Acetone wash blank, mg (equation 5-5)** -

Container Number	Weight of Particulate Collected g		
	Final Weight	Tare Weight	Weight Gain
1	-	-	-
2	73.4360	73.4358	.0002
Total			.0002
Less acetone blank			-
Weight of particulate matter			.0002

	Volume of Liquid Water Collected	
	Impinger Volume, ml.	Silica Gel Weight, g
Final	-	-
Initial	-	-
Liquid collected	-	-
Total Volume Collected	-	g. ✓ ml


* Convert weight of water to volume by dividing total weight increase by density of water (1g/ml): $\frac{\text{Increase, g}}{1\text{g/ml}} = \text{Volume Water, ml}$

** See Federal Register, Method 5, 6.6, & 6.7.

SO₂ Analysis Sheet

Client J.E.A. S.J.R.P.P. Analysis Run By T. Roth Date Aug 11 1995
 Project No. 95-058-FL Plant Site Jacksonville Fla.
 Barium Perchlorate Normality .0099 = $\frac{\text{Mls H}_2\text{SO}_4 \times \text{Normality}}{\text{Mls Barium Titrated}}$ = $\frac{25.0 \times .03}{50.70}$

Sampling Location	Run No.	Sample #	Volume of Solution	Volume of Aliquot	Volume to Titrate
Unit #1 Stack		Blank	1000ml	50.0ml	0.0/0.0
	1	1	160.0ml	25.0 ml	10.6/10.4
	2	2	211.0ml	25.0 ml	8.5/8.9/8.3
96	3	3	224.0ml	25.0 ml	8.7/8.7/



SO₂ Analysis Sheet

Client J.E.A. S.J.R. P.P. Analysis Run By T. Roth Date Aug 12 1995
 Project No. 95-058-FL Plant Site Jacksonville Fla
 Barium Perchlorate Normality 0.0100 = Mls H₂SO₄ X Normality = $\frac{350 \times .02}{49.8}$
Mls Barium Titrated

Sampling Location	Run No.	Sample #	Volume of Solution	Volume of Aliquot	Volume to Titrate
Unit #1 Stack		Blank	1000 mL	50.0 mL	0.0/0.0
	1	1	200 ml	25.0 mL	8.8 / 9.0
57	2	2	175 ml	25.0 ml	11.1 / 11.4 / 11.4
	3	3	171 ml	25.0 ml	12.0 / 12.2



Total Source Analysis, Inc.
 Environmental Samplers

SO₂ Analysis Sheet

Client J.E.A. S.J. R.P.P. Analysis Run By T. Roth Date Aug 13 1995

Project No. 95- Plant Site Jacksonville Fla.

Barium Perchlorate Normality .0100 = $\frac{\text{Mls H}_2\text{SO}_4 \times \text{Normality}}{\text{Mls Barium Titrated}} = \frac{25.0 \times .02}{49.8}$

Sampling Location	Run No.	Sample #	Volume of Solution	Volume of Aliquot	Volume to Titrate
Unit # 1 Stack		Blank	1000ml	50.0ml	0.0 / 0.0
	1	1	196ml	25.0ml	6.6 / 6.5 / 6.5
	2	2	193ml	25.0ml	13.4 / 13.1 / 13.5
J8					
	3	3	198.5ml	25.0ml	27.8 / 28.4 / 28.4



Total Source Analysis, Inc.
Environmental Samplers



SO₂ Analysis Sheet

Client J.E.A. S.J.R.P.P. Analysis Run By T. Roth Date Aug 14 1995
 Project No. 95-058-F1 Plant Site Jacksonville Fla.
 Barium Perchlorate Normality .0100 = $\frac{\text{Mls H}_2\text{SO}_4 \times \text{Normality}}{\text{Mls Barium Titrated}} = \frac{25.0 \times .02}{49.80}$

Sampling Location	Run No.	Sample #	Volume of Solution	Volume of Aliquot	Volume to Titrate
Unit # Stack		Blank	1000ml.	50.0ml	0.0/0.0
	1	1	192.5ml	25.0ml	9.5/9.0/8.9
	2	2	197.0ml	25.0ml	12.8/12.6
J9					
	3	3	165.0ml	25.0ml 10.0ml	7.0/7.2





TOTAL SOURCE ANALYSIS, INC.
ENVIRONMENTAL TESTING CONSULTANTS

510 Dickson • P.O. Box 257 • Wellington, OH 44090
41444 SR19 • P.O. Box 2807 • Umatilla, FL 32784
599 James Rollo Ct. • P.O. Box 272 • Grain Valley, MO 64029
930 Tate Blvd. • Suite 104 • Hickory, NC 28602