

U.S. Postal Service
CERTIFIED MAIL RECEIPT
(Domestic Mail Only; No Insurance Coverage Provided)

7001 0320 0001 3692 7324

OFFICIAL USE

Postage	\$
Certified Fee	
Return Receipt Fee (Endorsement Required)	
Restricted Delivery Fee (Endorsement Required)	
Total Postage & Fees	\$

Postmark
Here

Sent To
Bruce Smith
 Street, Apt. No.,
 or P.O. Box 26324
 City, State, ZIP+4
Jacksonville, FL 32226-6324

PS Form 3800, January 2001 See Reverse for Instructions

SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1 Article Addressed to:

Mr. Bruce Smith
 General Manager
 Cedar Bay Generating Co., L.P.
 P. O. Box 26324
 Jacksonville, FL 32226-6324

COMPLETE THIS SECTION ON DELIVERY

A. Received by (Please Print Clearly) B. Date of Delivery
 12-23

C. Signature
 Agent
 Addressee


D. Is delivery address different from item 1? Yes
 If YES, enter delivery address below: No

3. Service Type
 Certified Mail Express Mail
 Registered Return Receipt for Merchandise
 Insured Mail C.O.D.

4. Restricted Delivery? (Extra Fee) Yes

2 7001 0320 0001 3692 7324

UNITED STATES POSTAL SERVICE



First-Class Mail
Postage & Fees Paid
USPS
Permit No. G-10

• Sender: Please print your name, address, and ZIP+4 in this box •

Dept. of Environmental Protection
Division of Air Resources Mgt.
Bureau of Air Regulation, NSR
2600 Blair Stone Rd., MS 5505
Tallahassee, FL 32399-2400


BUREAU OF AIR REGULATION

DEC 24 2002

RECEIVED

32399/2400





Department of Environmental Protection

Jeb Bush
Governor

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

David B. Struhs
Secretary

December 20, 2002

Mr. Bruce Smith
General Manager
Cedar Bay Generating Company, L.P.
P.O. Box 26324
Jacksonville, Florida 32226-6324

Re: DEP File No. PA 88-24; Modification of Permit No. PSD-FL-137
Cedar Bay Generating Plant / Duval County

The applicant, Cedar Bay Generating Company, L.P., applied on August 29, 2001, to the Department for a modification to PSD permit number PSD-FL-137 for its Cedar Bay Generating Plant located in Duval County. The modification is to allow the facility to co-fire petroleum coke (petcoke) in its three circulating fluidized bed boilers (A, B and C). The applicant has represented to the Department that the petcoke is to be delivered solely by rail.

The Department has reviewed the modification request. The referenced permit is hereby modified as follows:

II.A. Emission Limitations for CBCP Boilers

1. Fluidized Bed Coal Fired Boilers (CFB)

- a. The maximum coal charging rate of each CFB shall neither exceed 104,000 lbs/hr., 39,000 tons per month (30 consecutive days), nor 390,000 tons per year (TPY). This reflects a combined total of 312,000 lbs/hr., 117,000 tons per month, and 1,170,000 TPY for all three CFBs. Petroleum coke (petcoke) may be utilized as a co-firing fuel, and shall not exceed 35% fuel input by weight on a daily basis. {Permitting Note: The limitations on the coal charging rate include both coal and petcoke.}
- d. The sulfur content of the coal shall not exceed 1.2%, by weight, on an annual basis. The sulfur content shall not exceed 1.7%, by weight, on a shipment (train load) basis. When co-firing coal and petcoke, the blended fuel input to the CFBs shall not exceed 3.2 lb/MMBtu equivalent SO₂ content. Compliance shall be determined on a monthly basis via a composite of daily fuel samples.
4. Ammonia (NH₃) slip from the exhaust gases shall not exceed 10 ppmvd when co-firing petcoke or burning coal at 100% capacity and 30 ppmvd when burning oil.
10. Operations Monitoring for each CFB
 - b. All coal, petcoke and No. 2 fuel oil usage shall be recorded on a 24-hr (daily) basis for each CFB. Recycle rejects usage on a volumetric basis shall be estimated and recorded for each 24-hour period in which rejects are burned.
17. The permittee shall submit annual reports to RESD and DEP/BAR summarizing emissions for each calendar year. The reports will commence during the first year in which petcoke is fired

"More Protection, Less Process"

and continue for a total of five calendar years. Such reports are required in order to confirm Cedar Bay's projections of future actual emissions and to demonstrate to the Department's satisfaction that petcoke co-firing did not result in a significant emissions increase. Reporting shall be as follows:

<u>Pollutant</u>	<u>Compliance Procedures</u>
<u>NO_x</u>	<u>Five years of annual reporting by CEMS proving annual facility emissions do not exceed 1799 TPY</u>
<u>CO</u>	<u>Five years of annual reporting by CEMS proving annual facility emissions do not exceed 648 TPY</u>
<u>VOC</u>	<u>Five years of annual reporting by stack test proving annual facility emissions do not exceed 74 TPY</u>
<u>SO₂</u>	<u>Five years of annual reporting by CEMS proving annual facility emissions do not exceed 1985 TPY</u>
<u>SAM</u>	<u>Five years of annual reporting by stack test proving annual facility emissions do not exceed 7.3 TPY</u>
<u>PM₁₀</u>	<u>Five years of annual reporting by stack test proving annual facility emissions do not exceed 198 TPY</u>

II.B.CBCP - Material Handling and Treatment

2. The material handling/usage rates for coal, limestone, fly ash, and bed ash shall not exceed the following:

<u>Material</u>	<u>Handling/Usage Rate</u>	
	<u>TPM</u>	<u>TPY</u>
Coal	117,000	1,170,000
<u>Petcoke</u>	<u>40,950</u>	<u>409,500</u>
Limestone	27,000	320,000 <u>275,000</u>
Fly Ash	28,000	336,000
Bed Ash	8,000 ¹	88,000 ¹

Note: TPM is tons per month based on 30 consecutive days; and, TPY is tons per year.

¹ The Department will require a monitoring system to accurately measure Bed Ash throughput. The applicant will propose (to the Department's satisfaction) the system it recommends to utilize, prior to the initial receipt of petcoke. Actual in-service testing (while combusting coal) will be completed prior to the initial firing of petcoke, demonstrating its adequacy to the Department's satisfaction.

4.b. The PM emissions from the following process and/or equipment, in the material handling and treatment area sources, shall be controlled using wet suppression/removal techniques:


Coal Car Unloading	<u>Petcoke Unloading/Handling Areas</u>
Ash Pellet Hydrator	<u>Petcoke Transfer Areas</u>
Ash Pellet Curing Silo	<u>Petcoke Storage Areas</u>
Ash Pelletizing Pan	

The above listed sources are subject to a VE and a PM emissions limitation requirement of 5% opacity and 0.01 gr/dscf (applicant requested limitation, which is more stringent than what is allowed by rule), respectively, in accordance with Rule 17-296.711, F.A.C. Initial and subsequent compliance tests shall be conducted for VE and PM emissions using EPA Methods 9 and 5, respectively, in accordance with Chapter 17-297, F.A.C., and 40 CFR 60, Appendix A (July, 1992 version).

A copy of this letter shall be filed with the referenced permit and shall become part of the permit. This permit modification is issued pursuant to Chapter 403, Florida Statutes.

Any party to this order (permit modification) has the right to seek judicial review of it under Section 120.68, F.S., by filing a notice of appeal under Rule 9.110 of the Florida Rules of Appellate Procedure with the clerk of the Department of Environmental Protection in the Office of General Counsel, Mail Station #35, 3900 Commonwealth Boulevard, Tallahassee, Florida, 32399-3000, and by filing a copy of the notice of appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The notice must be filed within thirty days after this order is filed with the clerk of the Department.

Executed in Tallahassee, Florida.


Howard L. Rhodes, Director
Division of Air Resources
Management


CERTIFICATE OF SERVICE

The undersigned duly designated deputy agency clerk hereby certifies that this permit modification was sent by certified mail (*) and copies were mailed by U.S. Mail before the close of business on 12/20/02 to the person(s) listed:

Bruce Smith, Cedar Bay *
J. A. Walker, Cedar Bay
Ken Kosky, P.E. Golder Associates
Hamilton S. Oven, P.E.
James L. Manning, P.E., RESD
Doug Neeley, EPA
John Bunyak, NPS
Chris Kirts, DEP-NED
Stafford Campbell, Greater Arlington Civic Council

Clerk Stamp

FILING AND ACKNOWLEDGMENT FILED,
on this date, pursuant to §120.52, Florida Statutes,
with the designated Department Clerk, receipt of
which is hereby acknowledged.

 / December 20, 2002
(Clerk) (Date)