

**HARDEE POWER
PARTNERS LIMITED**

Invenergy

Via Federal Express 7909 6030 4413

March 13, 2008

Via FedEx

Mr. Chris Bradley
Florida Department of Environmental Protection
Southwest District Office
13051 North Telecom Parkway
Temple Terrace, FL 33637-0926

RECEIVED

MAR 14 2008

BUREAU OF AIR REGULATION

Re: Hardee Power Partners Limited
Hardee Power Station
Conditions of Certification PA 89-25
Title V Air Operations Permit No. 0490015-009-AV
2007 Annual Average Capacity Factor Report

Pursuant to Special Condition A.22 of Title V Air Operations Permit No. 0490015-009-AV, Hardee Power Partners Limited hereby submits the enclosed report providing calculations of the 2007 annual average capacity factor and cumulative lifetime average capacity factor for Hardee Power Station Units 1A, 1B, 2A, and the Steam Turbine.

Please feel free to contact Dennis Powell at (863) 375-3266 if you have any questions regarding this information.

I certify that, based on the information and belief formed after reasonable inquiry, the statements and information in the documents are true, accurate, and complete.

Sincerely,



Ralph E. Randall
Plant Manager

Attachment

cc: Florida Department of Environmental Protection
Division of Air Resource Management
Bureau of Air Regulation
Twin Towers Office Building
2600 Blair Stone Rd.
Tallahassee, FL 32399-2400

**ANNUAL CUMULATIVE LIFETIME CAPACITY FACTOR
FOR HARDEE POWER STATION UNITS 1A, 1B, ST, 2A
FOR THE CALENDAR YEAR 2007**

UNIT	UNIT CAPABILITY (MW)	2007 ANNUAL		CUMULATIVE LIFETIME	
		MWH	CAPACITY FACTOR	MWH	CAPACITY FACTOR
CT 1A	86	190,181	25.24%	3,105,995	27.49%
CT 1B	86	186,185	24.71%	3,141,355	27.80%
Steam Turbine	81	194,058	27.35%	3,135,912	29.46%
Total CC	253	570,424	25.74%	9,383,262	28.23%
CT 2A	87	22,132	2.90%	802,071	7.02%
Total	340	592,556	19.90%	10,185,333	22.80%

Note: Commercial operation began January 1, 1993.