

Department of Environmental Protection

Jeb Bush
Governor

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Colleen M. Castille
Secretary

P.E. Certification Statement

Permittee:

Hardee Power Partners
(A Subsidiary of Invenergy, LLC)
Hardee Power Station

Revision
DRAFT Permit Renewal No.: 0490015-007-AV
Facility ID No.: 0490015

Project: Title V Air Operation Permit Revision to update applicable requirements of 40 CFR 60, Subpart GG. Such changes are primarily related to fuel monitoring and additional emissions monitoring options.

I HEREBY CERTIFY that the engineering features described in the above referenced application and related additional information submittals, if any, and subject to the proposed permit conditions, provide reasonable assurance of compliance with applicable provisions of Chapter 403, Florida Statutes, and Florida Administrative Code Chapters 62-4 and 62-204 through 62-297. However, I have not evaluated and I do not certify aspects of the proposal outside of my area of expertise (including but not limited to the electrical, mechanical, structural, hydrological, and geological features).



Jonathan K. Holtom
Jonathan K. Holtom, P.E.
Registration Number: 0052664

10/9/06
Date


Permitting Authority:

Florida Department of Environmental Protection
Division of Air Resources Management
Bureau of Air Regulation
Mail Station #5505
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Telephone: 850/488-0114
Fax: 850/922-6979

"More Protection, Less Process"

Printed on recycled paper.



Jeb Bush
Governor

Department of Environmental Protection

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Colleen M. Castille
Secretary

October 10, 2006

Mr. Alex C. George
V.P. and Responsible Official
Hardee Power Partners (A Subsidiary of Invenergy, LLC)
One South Wacker Drive, Suite 2020
Chicago, Illinois 60606

Re: Title V Air Operation Permit Revision
DRAFT/PROPOSED Permit Project No.: 0490015-007-AV
Hardee Power Station

Dear Mr. George:

One copy of the DRAFT/PROPOSED Permit for the revision of a Title V Air Operation Permit for Hardee Power Station located at 6695 County Road 663 North, Fort Green Springs, Hardee County, is enclosed. The permitting authority's "INTENT TO ISSUE TITLE V AIR OPERATION PERMIT REVISION" and the "PUBLIC NOTICE OF INTENT TO ISSUE TITLE V AIR OPERATION PERMIT REVISION" are also included.

An electronic version of the DRAFT/PROPOSED Title V Air Operation Permit Revision has been posted on the Division of Air Resource Management's world wide web site for the United States Environmental Protection Agency (USEPA) Region 4 office's review. The web site address is:

"<http://www.dep.state.fl.us/air/eproducts/ards/default.asp>"

The "PUBLIC NOTICE OF INTENT TO ISSUE TITLE V AIR OPERATION PERMIT REVISION" must be published as soon as possible. Proof of publication, i.e., newspaper affidavit, must be provided to the permitting authority's office within 7 (seven) days of publication pursuant to Rule 62-110.106(5), F.A.C. Failure to publish the notice and provide proof of publication within the allotted time may result in the denial of the permit pursuant to Rule 62-110.106(11), F.A.C.

Please submit any written comments you wish to have considered concerning the permitting authority's proposed action to Jeff Koerner, P.E., at the above letterhead address. If you have any other questions, please contact Jonathan Holtom, P.E. at 850/921-9531.

Sincerely,

Trina L. Vielhauer, Chief
Bureau of Air Regulation

TLV/jk/jh

Enclosures

"More Protection, Less Process"

Printed on recycled paper.

WRITTEN NOTICE OF INTENT TO ISSUE AIR PERMIT

*In the Matter of an
Application for Air Permit by:*

Mr. Alex C. George
V.P. and Responsible Official
Hardee Power Partners
A Subsidiary of Invenergy, LLC
One South Wacker Drive, Suite 2020
Chicago, Illinois 60606

DRAFT/PROPOSED Permit Project No.: 0490015-007-AV
Hardee Power Station
Hardee County, Florida

Facility Location: The Hardee Power Partners operate the existing Hardee Power Station, which is located at 6695 County Road 663, Fort Green Springs, Hardee County.

Project: The applicant requested a revision to change various permit conditions, that are contained in Air Operation Permit No. 0490015-005-AV, to match the updated requirements of 40 CFR 60, Subpart GG, which was revised on July 8, 2004. Such changes are primarily related to fuel monitoring and additional emissions monitoring options. This permitting action will also be used to replace Appendix TV-4, Title V Conditions (version dated 02/12/02) with Appendix TV-6, Title V Conditions (version dated 6/23/06), as well as other minor administrative corrections as described below. It was determined that a concurrent Air Construction permit revision was not required because the changes contained in this revision do not alter the requirements contained in the construction permits to comply with the applicable portions of 40 CFR 60, Subpart GG. The only referenced attachments that are being issued with this revision are Appendix GG - Standards of Performance for Stationary Gas Turbines and Appendix TV-6, Title V Conditions (version dated 6/23/06), which is replacing the existing Appendix TV-4. The other referenced attachments are unchanged by this permitting action and will remain as issued with the Title V Air Operation Permit Renewal (permit no. 0490015-005-AV) that was effective on January 1, 2005.

Permitting Authority: Applications for air operation permits are subject to review in accordance with the provisions of Chapter 403, Florida Statutes (F.S.) and Chapters 62-4, 62-210, 62-213 and 62-214 of the Florida Administrative Code (F.A.C.). The proposed project is not exempt from air permitting requirements and an air permit is required to approve the requested changes. The Department of Environmental Protection is the Permitting Authority responsible for making a permit determination for this project. The Permitting Authority's physical address is: 111 S. Magnolia Drive, Tallahassee, Florida 32301. The Permitting Authority's mailing address is: 2600 Blair Stone Road, Mail Station 5505, Tallahassee, Florida 32399-2400. The Permitting Authority's telephone number is 850/488-0114.

Notice of Intent to Issue Permit: The Permitting Authority gives notice of its intent to issue an air operation permit to the applicant for the project described above. The applicant has provided reasonable assurance that operation of proposed equipment will not adversely impact air quality and that the project will comply with all appropriate provisions of Chapters 62-4, 62-204, 62-210, 62-212, 62-213, 62-256, 62-257, 62-281, 62-296 and 62-297, F.A.C. The Permitting Authority will issue a Final Permit in accordance with the conditions of this DRAFT/PROPOSED Permit unless a timely petition for an administrative hearing is filed under Sections 120.569 and 120.57, F.S. or unless public comment received in accordance with this notice results in a different decision or a significant change of terms or conditions.

Public Notice: Pursuant to Sections 403.087 & 403.815, F.S. and Rules 62-110.106 & 62-210.350, F.A.C., you (the applicant) are required to publish at your own expense the enclosed "Public Notice of Intent to Issue Air Permit" (Public Notice). The Public Notice shall be published one time only as soon as possible in the legal advertisement section of a newspaper of general circulation in the area affected by this project. The newspaper used must meet the requirements of Sections 50.011 and 50.031, F.S. in the county where the activity is to take place. If you are uncertain that a newspaper meets these

WRITTEN NOTICE OF INTENT TO ISSUE AIR PERMIT

requirements, please contact the Permitting Authority at above address or phone number. Pursuant to Rule 62-110.106(5), F.A.C., the applicant shall provide proof of publication to the Permitting Authority at the above address within seven (7) days of publication. Failure to publish the notice and provide proof of publication may result in the denial of the permit pursuant to Rule 62-110.106(11), F.A.C.

Comments: The Permitting Authority will accept written comments concerning this DRAFT/PROPOSED Permit for a period of fourteen (30) days from the date of publication of the Public Notice. Written comments must be provided to the Permitting Authority at the above address. Any written comments filed will be made available for public inspection. If written comments received result in a significant change to the DRAFT/PROPOSED Permit, the Permitting Authority shall revise the DRAFT/PROPOSED Permit and require, if applicable, another Public Notice.

Petitions: A person whose substantial interests are affected by the proposed permitting decision may petition for an administrative hearing in accordance with Sections 120.569 and 120.57, F.S. The petition must contain the information set forth below and must be filed with (received by) the Department's Agency Clerk in the Office of General Counsel of the Department of Environmental Protection, 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida 32399-3000. Petitions filed by the applicant or any of the parties listed below must be filed within fourteen (14) days of receipt of this Written Notice of Intent to Issue Air Permit. Petitions filed by any persons other than those entitled to written notice under Section 120.60(3), F.S., must be filed within fourteen (14) days of publication of the attached Public Notice or within fourteen (14) days of receipt of this Written Notice of Intent to Issue Air Permit, whichever occurs first. Under Section 120.60(3), F.S., however, any person who asked the Permitting Authority for notice of agency action may file a petition within fourteen (14) days of receipt of that notice, regardless of the date of publication. A petitioner shall mail a copy of the petition to the applicant at the address indicated above, at the time of filing. The failure of any person to file a petition within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under Sections 120.569 and 120.57, F.S., or to intervene in this proceeding and participate as a party to it. Any subsequent intervention will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205, F.A.C.

A petition that disputes the material facts on which the Permitting Authority's action is based must contain the following information: (a) The name and address of each agency affected and each agency's file or identification number, if known; (b) The name, address, and telephone number of the petitioner; the name, address and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how the petitioner's substantial interests will be affected by the agency determination; (c) A statement of how and when each petitioner received notice of the agency action or proposed action; (d) A statement of all disputed issues of material fact. If there are none, the petition must so state; (e) A concise statement of the ultimate facts alleged, including the specific facts the petitioner contends warrant reversal or modification of the agency's proposed action; (f) A statement of the specific rules or statutes the petitioner contends require reversal or modification of the agency's proposed action; and, (g) A statement of the relief sought by the petitioner, stating precisely the action the petitioner wishes the agency to take with respect to the agency's proposed action. A petition that does not dispute the material facts upon which the Permitting Authority's action is based shall state that no such facts are in dispute and otherwise shall contain the same information as set forth above, as required by Rule 28-106.301, F.A.C.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Permitting Authority's final action may be different from the position taken by it in this Written Notice of Intent to Issue Air Permit. Persons whose substantial interests will be affected by any such final decision of the Permitting Authority on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

Mediation: Mediation is not available in this proceeding.

WRITTEN NOTICE OF INTENT TO ISSUE AIR PERMIT

DRAFT/PROPOSED Permit Processing: EPA has agreed to treat the DRAFT Title V Permit as a PROPOSED Title V Permit and to perform its 45-day review provided by the law and regulations concurrently with the public comment period. Although EPA's 45-day review period will be performed concurrently with the public comment period, the deadline for submitting a citizen petition to object to the EPA Administrator will be determined as if EPA's 45-day review period is performed after the public comment period has ended. The FINAL Title V Air Operation Permit will be issued after the conclusion of the 45-day EPA review period so long as no adverse comments are received that results in a different decision or significant change of terms or conditions.

The status regarding EPA's 45-day review of this project and the deadline for submitting a citizen petition can be found at the following website address:

<http://www.epa.gov/region4/air/permits/Florida.htm>

Pursuant to 42 United States Code (U.S.C.) Section 7661d(b)(2), any person may petition the Administrator of the EPA within 60 (sixty) days of the expiration of the Administrator's 45 (forty-five) day review period as established at 42 U.S.C. Section 7661d(b)(1), to object to issuance of any Title V permit. Any petition shall be based only on objections to the Title V permit that were raised with reasonable specificity during the 30 (thirty) day public comment period provided in this notice, unless the petitioner demonstrates to the Administrator of the EPA that it was impracticable to raise such objections within the comment period or unless the grounds for such objection arose after the comment period. Filing of a petition with the Administrator of the EPA does not stay the effective date of any Title V permit properly issued pursuant to the provisions of Chapter 62-213, F.A.C. Petitions filed with the Administrator of EPA must meet the requirements of 42 U.S.C. Section 7661d(b)(2) and must be filed with the Administrator of the EPA at: U.S. EPA, 401 M Street, S.W., Washington, D.C. 20460.

Executed in Tallahassee, Florida.



Trina L. Vielhauer, Chief
Bureau of Air Regulation

WRITTEN NOTICE OF INTENT TO ISSUE AIR PERMIT

CERTIFICATE OF SERVICE

The undersigned duly designated deputy agency clerk hereby certifies that this INTENT TO ISSUE TITLE V AIR OPERATION PERMIT REVISION (including the PUBLIC NOTICE and the DRAFT/PROPOSED Permit package) and all copies were sent electronically (with Received Receipt) before the close of business on 10/11/06 to the person(s) listed:

Mr. Alex C. George, V.P. and R.O., Hardee Power Partners (ageorge@invenergyllc.com)

Mr. Thomas W. Davis, P.E., ECT, Inc. (tdavis@ectinc.com)


Mr. Frank Sarduy, Hardee Power Partners (fsarduy@invenergyservices.com)

Ms. Mara Nasca, DEP – SWD (mara.nasca@dep.state.fl.us)

EPA Region 4

Clerk Stamp

FILING AND ACKNOWLEDGMENT FILED, on this date, pursuant to Section 120.52(7), Florida Statutes, with the designated agency clerk, receipt of which is hereby acknowledged.

 Barbara J. Friday (Clerk) 10/11/06 (Date)

PUBLIC NOTICE OF INTENT TO ISSUE AIR PERMIT

Florida Department of Environmental Protection
DRAFT/PROPOSED Air Permit No. 0490015-007-AV
Hardee Power Partners – Hardee Power Station
Hardee County

Applicant: The applicant for this project is Hardee Power Partners, A Subsidiary of Invenergy, LLC. The applicant's Responsible Official is Mr. Alex C. George, V.P., One South Wacker Drive, Suite 2020, Chicago, Illinois 60606.

Facility Location: The Hardee Power Partners operate the existing Hardee Power Station, which is located at 6695 County Road 663, Fort Green Springs, Hardee County.

Project: The applicant requested a revision to change various permit conditions, that are contained in Air Operation Permit No. 0490015-005-AV, to match the updated requirements of 40 CFR 60, Subpart GG, which was revised on July 8, 2004. Such changes are primarily related to fuel monitoring and additional emissions monitoring options. This permitting action will also be used to replace Appendix TV-4, Title V Conditions (version dated 02/12/02) with Appendix TV-6, Title V Conditions (version dated 6/23/06), as well as other minor administrative corrections as described below. It was determined that a concurrent Air Construction permit revision was not required because the changes contained in this revision do not alter the requirements contained in the construction permits to comply with the applicable portions of 40 CFR 60, Subpart GG. The only referenced attachments that are being issued with this revision are Appendix GG - Standards of Performance for Stationary Gas Turbines and Appendix TV-6, Title V Conditions (version dated 6/23/06), which is replacing the existing Appendix TV-4. The other referenced attachments are unchanged by this permitting action and will remain as issued with the Title V Air Operation Permit Renewal (permit no. 0490015-005-AV) that was effective on January 1, 2005.

Permitting Authority: Applications for air operation permits are subject to review in accordance with the provisions of Chapter 403, Florida Statutes (F.S.) and Chapters 62-4, 62-210, 62-213 and 62-214 of the Florida Administrative Code (F.A.C.). The proposed project is not exempt from air permitting requirements and an air permit is required to approve the requested changes. The Department of Environmental Protection's Bureau of Air Regulation is the Permitting Authority responsible for making a permit determination for this project. The Permitting Authority's physical address is: 111 S. Magnolia Drive, Tallahassee, Florida 32301. The Permitting Authority's mailing address is: 2600 Blair Stone Road, Mail Station 5505, Tallahassee, Florida 32399-2400. The Permitting Authority's telephone number is 850/488-0114.

Project File: A complete project file is available for public inspection during the normal business hours of 8:00 a.m. to 5:00 p.m., Monday through Friday (except legal holidays), at address indicated above for the Permitting Authority. The complete project file includes the DRAFT/PROPOSED Permit, the Technical Evaluation and Preliminary Determination, the application, and the information submitted by the applicant, exclusive of confidential records under Section 403.111, F.S. Interested persons may contact the Permitting Authority's project review engineer for additional information at the address and phone number listed above. A copy of the complete project file is also available at the Department of Environmental Protection's Southwest District Office at 13051 North Telecom Parkway, Temple Terrace, FL 33637-0926 (Telephone: 813/632-7600).

Notice of Intent to Issue Air Permit: The Permitting Authority gives notice of its intent to issue an air permit to the applicant for the project described above. The applicant has provided reasonable assurance that operation of proposed equipment will not adversely impact air quality and that the project will comply with all appropriate provisions of Chapters 62-4, 62-204, 62-210, 62-212, 62-213, 62-296 and 62-297, F.A.C. The Permitting Authority will issue a Final Permit in accordance with the conditions of this DRAFT/PROPOSED Permit unless a timely petition for an administrative hearing is filed under Sections

(Public Notice to be Published in the Newspaper)

PUBLIC NOTICE OF INTENT TO ISSUE AIR PERMIT

120.569 and 120.57, F.S. or unless public comment received in accordance with this notice results in a different decision or a significant change of terms or conditions.

Comments: The Permitting Authority will accept written comments concerning the DRAFT/PROPOSED Permit for a period of thirty (30) days from the date of publication of this Public Notice. Written comments must be post-marked and all facsimile comments must be received by the close of business (5:00 pm), on or before the end of this 30-day period, by the Permitting Authority at the above address. As part of his or her comments, any person may also request that the Permitting Authority hold a public meeting on this permitting action. If the Permitting Authority determines there is sufficient interest for a public meeting, it will publish notice of the time, date, and location in the Florida Administrative Weekly (<http://faw.dos.state.fl.us/>) and in a newspaper of general circulation in the area affected by the permitting action. For additional information, contact the Permitting Authority at the above address or phone number. If written comments or comments received at a public meeting result in a significant change to the DRAFT/PROPOSED Permit, the Permitting Authority shall issue a Revised DRAFT/PROPOSED Permit and require, if applicable, another Public Notice. All comments filed will be made available for public inspection.

Petitions: A person whose substantial interests are affected by the proposed permitting decision may petition for an administrative hearing in accordance with Sections 120.569 and 120.57, F.S. The petition must contain the information set forth below and must be filed with (received by) the Department's Agency Clerk in the Office of General Counsel of the Department of Environmental Protection at 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida 32399-3000. Petitions filed by any persons other than those entitled to written notice under Section 120.60(3), F.S. must be filed within fourteen (14) days of publication of this Public Notice or receipt of a written notice, whichever occurs first. Under Section 120.60(3), F.S., however, any person who asked the Permitting Authority for notice of agency action may file a petition within fourteen (14) days of receipt of that notice, regardless of the date of publication. A petitioner shall mail a copy of the petition to the applicant at the address indicated above, at the time of filing. The failure of any person to file a petition within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under Sections 120.569 and 120.57, F.S., or to intervene in this proceeding and participate as a party to it. Any subsequent intervention will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205, F.A.C.

A petition that disputes the material facts on which the Permitting Authority's action is based must contain the following information: (a) The name and address of each agency affected and each agency's file or identification number, if known; (b) The name, address and telephone number of the petitioner; the name address and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how the petitioner's substantial rights will be affected by the agency determination; (c) A statement of how and when the petitioner received notice of the agency action or proposed action; (d) A statement of all disputed issues of material fact. If there are none, the petition must so state; (e) A concise statement of the ultimate facts alleged, including the specific facts the petitioner contends warrant reversal or modification of the agency's proposed action; (f) A statement of the specific rules or statutes the petitioner contends require reversal or modification of the agency's proposed action; and, (g) A statement of the relief sought by the petitioner, stating precisely the action the petitioner wishes the agency to take with respect to the agency's proposed action. A petition that does not dispute the material facts upon which the Permitting Authority's action is based shall state that no such facts are in dispute and otherwise shall contain the same information as set forth above, as required by Rule 28-106.301, F.A.C.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Permitting Authority's final action may be different from the position taken by it in this Public Notice of Intent to Issue Air Permit. Persons whose substantial interests will be affected by

(Public Notice to be Published in the Newspaper)

PUBLIC NOTICE OF INTENT TO ISSUE AIR PERMIT

any such final decision of the Permitting Authority on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

Mediation: Mediation is not available for this proceeding.

DRAFT/PROPOSED Permit Processing: EPA has agreed to treat the DRAFT Title V Permit as a PROPOSED Title V Permit and to perform its 45-day review provided by the law and regulations concurrently with the public comment period. Although EPA's 45-day review period will be performed concurrently with the public comment period, the deadline for submitting a citizen petition to object to the EPA Administrator will be determined as if EPA's 45-day review period is performed after the public comment period has ended. The FINAL Title V Air Operation Permit will be issued after the conclusion of the 45-day EPA review period so long as no adverse comments are received that results in a different decision or significant change of terms or conditions.

The status regarding EPA's 45-day review of this project and the deadline for submitting a citizen petition can be found at the following website address:

<http://www.epa.gov/region4/air/permits/Florida.htm>

Pursuant to 42 United States Code (U.S.C.) Section 7661d(b)(2), any person may petition the Administrator of the EPA within 60 (sixty) days of the expiration of the Administrator's 45 (forty-five) day review period as established at 42 U.S.C. Section 7661d(b)(1), to object to issuance of any Title V permit. Any petition shall be based only on objections to the Title V permit that were raised with reasonable specificity during the 30 (thirty) day public comment period provided in this notice, unless the petitioner demonstrates to the Administrator of the EPA that it was impracticable to raise such objections within the comment period or unless the grounds for such objection arose after the comment period. Filing of a petition with the Administrator of the EPA does not stay the effective date of any Title V permit properly issued pursuant to the provisions of Chapter 62-213, F.A.C. Petitions filed with the Administrator of EPA must meet the requirements of 42 U.S.C. Section 7661d(b)(2) and must be filed with the Administrator of the EPA at: U.S. EPA, 401 M Street, S.W., Washington, D.C. 20460.

STATEMENT OF BASIS
Hardee Power Partners (A Subsidiary of Invenergy, LLC)
Hardee Power Station
Facility ID No.: 0490015
Hardee County

Title V Air Operation Permit Revision
DRAFT/PROPOSED Permit No.: 0490015-007-AV

This Title V Air Operation Permit Revision is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, 62-213 and 62-214. The above named permittee is hereby authorized to operate the facility shown on the application and approved drawing(s), plans, and other documents, attached hereto or on file with the permitting authority, in accordance with the terms and conditions of this permit. The existing Hardee Power Station is located at 6695 County Road 663, Fort Green Springs, in Hardee County; UTM Coordinates: Zone 17, 404.8 km East and 3,057.4 km North; Latitude: 22° 38' 02" North and Longitude: 81° 38' 02" West.

The purpose of this revision is to change various permit conditions to match the updated requirements of 40 CFR 60, Subpart GG, which was revised on July 8, 2004. This permitting action will also be used to replace Appendix TV-4, Title V Conditions (version dated 02/12/02) with Appendix TV-6, Title V Conditions (version dated 6/23/06), as well as other minor administrative corrections as described below. It was determined that a concurrent Air Construction permit revision was not required because the changes contained in this revision do not alter the requirements contained in the construction permits to comply with the applicable portions of 40 CFR 60, Subpart GG.

Hardee Power Partners (A Subsidiary of Invenergy, LLC), operates a nominal 370 megawatt (MW) electric generation facility located approximately nine miles northwest of Wauchula in Hardee County, Florida. The Hardee Power Station includes four General Electric (GE) dual-fuel fired combustion turbines (CTs). The facility utilizes pipeline natural gas as its primary fuel source, with No. 2 distillate fuel oil serving as a backup fuel.

Three of the CTs (CT-1A, CT-1B and CT-2A) are identical emissions units, GE Model No. PG-7111 EA, and CTs 1A and 1B together comprise a combined-cycle unit operation and CT 2A is a simple cycle unit operation. All of the CTs have a nominal power production output of 75 MW; and, for CTs 1A and 1B, each has a generator nameplate rating of 113 MW (total of the CT and associated HRSG). CT-1A and CT-1B are each equipped with a heat recovery steam generator (HRSG), which feed one common steam turbine (ST). CT-1A and CT-1B are each equipped with a stack to bypass each unit's HRSG. The maximum permitted heat input rate to each CT is 1,312.3 MMBtu/hr while firing oil, and 1,268.4 MMBtu/hr while firing natural gas. Water injection is used to reduce NO_x emissions when firing natural gas and low sulfur distillate oil (backup fuel). These emission units are regulated under Rule 62-210.300, F.A.C., Permits Required; NSPS - 40 CFR 60, Subpart GG, Standards of Performance for Stationary Gas Turbines, adopted and incorporated by reference in Rule 62-204.800(8), F.A.C.; NSPS - 40 CFR 60, Subpart A; Rule 62-212.400, F.A.C., Prevention of Significant Deterioration; PSD-FL-140; and, these units are not affected by the Acid Rain Program since they meet the requirements of 40 CFR 72.6(b)(6). Continuous Assurance Monitoring (CAM) applies for NO_x.

The fourth and latest CT (CT-2B) is also manufactured by GE, Model No. PG-7121 (7EA), and is a simple cycle unit operation. The CT has an electrical generator with a nominal power production output of 75 MW. Dry low-NO_x (DLN) combustion technology will be used to control nitrogen oxide

emissions, when firing the primary fuel of pipeline natural gas. Water injection will be used to control NO_x emissions, when firing low sulfur distillate oil as a backup fuel. Combustion design and clean fuels will be used to minimize emissions of CO, PM/PM₁₀, SAM, SO₂, and VOC. This emissions unit is regulated under Rule 62-210.300, F.A.C., Permits Required; NSPS - 40 CFR 60, Subpart GG, Standards of Performance for Stationary Gas Turbines, adopted and incorporated by reference in Rule 62-204.800(8), F.A.C.; NSPS - 40 CFR 60, Subpart A; Rule 62-212.400, F.A.C., Prevention of Significant Deterioration; Rule 62-212.400(6), F.A.C. (BACT); PSD-FL-140A; and, the applicable provisions of the Acid Rain Program.

Also included in this permit are miscellaneous unregulated and insignificant emissions units and activities.

Based on the renewal Title V permit application received December 22, 2003, this facility is a major source of hazardous air pollutants (HAPs).

The following changes are being made to Title V Air Operation Permit Renewal No. 0490015-005-AV as a result of this permitting action:

1. All occurrences of "Appendix TV-4, Title V Conditions (version dated 2/12/02)" have been replaced by "Appendix TV-6, Title V Conditions (version dated 6/23/06)".
2. To update the contact address for the Southwest District office, Facility-wide Condition 10. is changed as follows:

10. The Permittee shall submit all compliance related notifications and reports required of this permit to the Department's Southwest District office:

Department of Environmental Protection
Southwest District Office
~~3804 Coconut Palm Drive~~ 13051 North Telecom Parkway
~~Tampa, Florida 33619-8218~~ Temple Terrace, FL 33637-0926
Telephone: ~~813/744-6100~~ 813/632-7600
Fax: ~~813/744-6084~~ 813/632-7668

3. To ensure that all applicable requirements from 40 CFR 60, Subpart GG – Standards of Performance for Stationary Gas Turbines are included in the permit, Appendix GG, Standards of Performance for Stationary Gas Turbines has been added to the included attachments.
4. To provide a cross-reference to the attached appendix, the following new Common Condition C.20. has been added:

40 CFR 60, Subpart GG

C.20. These emissions units are also subject to all of the applicable requirements of 40 CFR 60, Subpart GG – Standards of Performance for Stationary Gas Turbines. (See attached Appendix GG, Standards of Performance for Stationary Gas Turbines.)
[40 CFR 60, Subpart GG; and, Rule 62-213.440, F.A.C.]

5. To reflect the July 8, 2004 revisions to 40 CFR 60.334(a) which removed the +/-5% accuracy requirement, Specific Conditions A.10. and B.13. are changed as follows:

A.10. CMS Requirements. The Permittee shall install, operate, and maintain a continuous monitoring system (CMS) to monitor and record the fuel consumption and; the ratio of water to fuel being fired in the turbine. ~~The system shall be accurate to within ± 5.0 percent and shall be approved by the Department.~~

[40 CFR 60.334(a); and, PSD-FL-140]

B.13. CMS Requirements. The permittee shall install, calibrate, operate and maintain a continuous monitoring system (CMS) to monitor and record the fuel consumption and; the ratio of water to fuel being fired in the CT. ~~The system shall be accurate to within ± 5.0 percent and shall be approved by the Department.~~ As an alternative to the monitoring requirements of this condition, the permittee may comply with the monitoring requirements of specific condition **B.17** (See Alternate Monitoring Plan).

[40 CFR 60.334(a)]

6. To update the requirements of 40 CFR 60.334, Specific Conditions A.11. and B.15. are changed as follows:

A.11. Critical Fuel Parameters. The Permittee shall monitor sulfur content and nitrogen content of the fuel being fired in the CTs. Pursuant to the ~~monitoring~~custom monitoring schedule provisions of 40 CFR 60.334(~~hb~~)(2), the frequency of determination of these values shall be as follows:

1. Monitoring of the nitrogen content of No. 2 fuel oil is not required. The sulfur content of distillate fuel oil shall be determined for each shipment of No. 2 fuel oil received; and,
2. Monitoring of the nitrogen content of pipeline natural gas is not required. The sulfur content of pipeline natural gas will be monitored using the applicable monitoring procedures specified in 40 CFR 60.334(h)~~based on twice monthly analyses provided by the natural gas supplier.~~

[40 CFR 60.334(~~hb~~)(1) & (2)]

B.15. Critical Fuel Parameters. The Permittee shall monitor sulfur content and nitrogen content of the fuel being fired in the CT. Pursuant to the ~~monitoring~~custom monitoring schedule provisions of 40 CFR 60.334(~~hb~~)(2), the frequency of determination of these values shall be as follows:

1. Monitoring of the nitrogen content of No. 2 fuel oil is not required. The sulfur content of distillate fuel oil shall be determined for each shipment of No. 2 fuel oil received; and,
2. Monitoring of the nitrogen content of pipeline natural gas is not required. The sulfur content of pipeline natural gas will be monitored using the applicable monitoring procedures specified in 40 CFR 60.334(h)~~based on twice monthly analyses provided by the natural gas supplier.~~

[40 CFR 60.334(~~hb~~)(1) & (2)]

7. To update the requirements of 40 CFR 60.335, Specific Condition A.19. is changed as follows:

A.19. Sulfur Content. The Permittee shall determine compliance with the sulfur content standard in 40 CFR 60.333(b) using applicable test methods and procedures specified in 40 CFR 60.335~~as follows: ASTM D 2880-96, or more recent version, shall be used to determine the sulfur content of liquid fuels and ASTM D 1072-90(94)E-1, D 3031-81(86), D 4084-94, or D 3246-92, or more recent versions, shall be used for the sulfur content of gaseous fuels (incorporated by reference—see 40 CFR 60.17). The applicable ranges of some ASTM methods mentioned above are not adequate to measure the levels of sulfur in some fuel gases. Dilution of samples before analysis (with verification of the dilution ratio) may be used, subject to the approval of the Department.~~

[40 CFR 60.335(d); and, PSD-FL-140]

8. To reflect that the requirements of 40 CFR 60.335(e) are obsolete, Specific Condition A.20. is changed as follows:

~~A.20. Reserved To meet the requirements of 40 CFR 60.334(b), the owner or operator shall use the methods specified in 40 CFR 60.335(a) and 40 CFR 60.335(d) of 40 CFR 60.335 to determine the nitrogen and sulfur contents of the fuel being burned. The analysis may be performed by the owner or operator, a service contractor retained by the owner or operator, the fuel vendor, or any other qualified agency.~~

[40 CFR 60.335(e)]

9. To update the requirements for complying with 40 CFR 60.335, Specific Condition B.16. is changed as follows:

B.16. Fuel Records.

(a) Natural Gas. The permittee shall demonstrate compliance with the fuel sulfur limit for natural gas specified in this permit by maintaining records of the sulfur content of the natural gas being supplied using the applicable monitoring procedures specified in 40 CFR 60.334(h) for each month of operation. Methods for determining the sulfur content of the natural gas shall be made using the applicable test methods and procedures specified in 40 CFR 60.335~~ASTM methods D4084-82, D3246-81,~~ or equivalent methods. These methods shall be used to determine the sulfur content of the natural gas fired in accordance with any EPA-approved custom fuel monitoring schedule (see Alternate Monitoring Plan: specific condition B.17.) or natural gas supplier data or the natural gas sulfur content referenced in 40 CFR 75, Appendix D. The analysis may be performed by the owner or operator, a service contractor retained by the owner or operator, the fuel vendor, or any other qualified agency pursuant to 40 CFR 60.335(e). However, the permittee is responsible for ensuring that the procedures in 40 CFR 60.335 or 40 CFR 75 are used to determine the fuel sulfur content for compliance with the 40 CFR 60.333 SO₂ standards.

(b) Low Sulfur Distillate Oil. For all bulk shipments of low sulfur distillate oil received at this facility, the permittee shall obtain from the fuel vendor an analysis identifying the sulfur content. Methods for determining the sulfur content of the distillate oil shall be made using the applicable test methods and procedures specified in 40 CFR 60.335~~ASTM D129-91, D2622-94, or D4294-90,~~ or equivalent methods. Records shall specify the test method used and shall comply with the requirements of 40 CFR 60.335(d).

[Rules 62-4.070(3) and 62-4.160(15), F.A.C.]

10. To reflect that 40 CFR 60.334 has been revised to include several options for monitoring fuel sulfur contents, Specific Condition B.17. is changed as follows:

B.17. Alternate Monitoring Plan.

1. The following alternate monitoring may be used to demonstrate compliance.

(a) The NO_x CEMS data may be used in lieu of the monitoring system for water-to-fuel ratio and the reporting of excess emissions in accordance with 40 CFR 60.334(c)(1), Subpart GG. ~~Subject to EPA approval, the calibration of the water to fuel ratio monitoring device required in 40 CFR 60.335(e)(2) will be replaced by the 40 CFR 75 certification tests of the NO_x CEMS.~~

(b) The NO_x CEMS data shall be used in lieu of the requirement for reporting excess emissions in accordance with 40 CFR 60.334(c)(1), Subpart GG.

(c) When requested by the Department, the CEMS emission rates for NO_x on this unit shall be corrected to ISO conditions to demonstrate compliance with the NO_x standard established in 40 CFR 60.332.

(d) A **custom fuel monitoring schedule** pursuant to 40 CFR 75, Appendix D, for natural gas, may be used in lieu of the daily sampling requirements of 40 CFR 60.334(~~hb~~)(2) provided the following conditions are met.

(1) The permittee shall apply for an Acid Rain Permit within the deadlines specified in 40 CFR 72.30.

(2) The permittee shall submit a monitoring plan, certified by signature of the Authorized Representative, that commits to using a primary fuel of pipeline supplied natural gas containing no more than 2 grains of sulfur per 100 SCF of gas pursuant to 40 CFR 75.11(d)(2).

(3) Each unit shall be monitored for SO₂ emissions using methods consistent with the requirements of 40 CFR 75 and certified by the USEPA.

This custom fuel-monitoring schedule will only be valid when pipeline natural gas is used as a primary fuel. If the primary fuel for these units is changed to a higher sulfur fuel, SO₂ emissions must be accounted for as required pursuant to 40 CFR 75.11(d).

~~—[40 CFR 60, Subpart GG; and, PSD FL 140A]~~

(e) The permittee shall monitor the sulfur contents of the No. 2 distillate fuel oil (or a superior grade) and natural gas. These values may be provided by the vendor and the frequency of determinations of these values shall be as follows:

~~(1)a. No. 2 Distillate Fuel Oil (or a superior grade).~~ The sulfur content shall be determined on each occasion that fuel is transferred to the storage tanks from any other source. Records of these values shall be kept by the facility for a five year period for regulatory agency inspection purposes.

~~(2)b. Natural Gas. Monitoring shall be conducted in accordance with the applicable provisions of 40 CFR 60.334(h) and 60.335. Alternatively, p~~Pursuant to 40 CFR 60.334(~~hb~~)(2), a custom fuel monitoring schedule for the determination of these values ~~may~~shall be followed for the natural gas fired at this facility ~~and shall be~~ as follows:

(Note: There are no changes to the “Custom Fuel Monitoring Schedule for Natural Gas” in paragraphs 2. and 3. of this condition.)

11. To reflect that language and numbering of 40 CFR 60.334 has been revised regarding the reporting of excess emissions, Specific Condition C.19. is changed as follows:

C.19. Excess Emissions Defined. For the purpose of reports required under 40 CFR 60.7(c) (see specific conditions C.1. through C.4.), periods of excess emissions that shall be reported are defined as follows:

a. *Nitrogen oxides.* For CT-1A, CT-1B and CT-2A, any one-hour period during which the average water-to-fuel ratio, as measured by the continuous monitoring system, falls below the water-to-fuel ratio determined to demonstrate compliance with 40 CFR 60.332 by the performance test required in 40 CFR 60.8 or any period during which the fuel-bound nitrogen of the fuel is greater than the maximum nitrogen content allowed by the fuel-bound nitrogen allowance used during the performance test required in 40 CFR 60.8. Each report shall include the average water-to-fuel ratio, average fuel consumption, ambient conditions, gas turbine load, and nitrogen content of the fuel during the period of excess emissions, and the graphs or figures developed under 40 CFR 60.335(~~a~~).

For CT-2B, NO_x CEMS data will be used in accordance with specific conditions **B.17.(a)** and **(b)**.

b. *Sulfur dioxide*. Any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8 percent, by weight.
[40 CFR 60.334(je)(1) & (2)]

Hardee Power Partners (A Subsidiary of Invenergy, LLC)
Hardee Power Station
Facility ID No. 0490015
Hardee County

Title V Air Operation Permit Revision
DRAFT/PROPOSED Permit No.: 0490015-007-AV

First Revision to Title V Air Operation Permit No.: 0490015-005-AV

Permitting Authority:

State of Florida
Department of Environmental Protection
Division of Air Resources Management
Bureau of Air Regulation

Mail Station #5505
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Telephone: 850/488-0114
Fax: 850/922-6979
Fax: 850/921-9533

Compliance Authority:

Department of Environmental Protection
Southwest District Office
~~3804 Coconut Palm Drive~~ 13051 North Telecom Parkway
~~Tampa, Florida 33619-8218~~ Temple Terrace, FL 33637-0926
Telephone: ~~813/744-6100~~ 813/632-7600
Fax: ~~813/744-6084~~ 813/632-7668

Title V Air Operation Permit Revision
DRAFT/PROPOSED Permit No.: 0490015-007-AV

Table of Contents

<u>Section</u>	<u>Page Number</u>
Placard Page	1
I. Facility Information	2
A. Facility Description.	
B. Summary of Emissions Units	
C. Relevant Documents	
II. Facility-wide Conditions	4
III. Emissions Unit(s) and Conditions	
A. Emission Units 001 - 003, General Electric Model PG-7111EA Combustion Turbines	7
-001: Combined cycle CT with an associated unfired Heat Recovery Steam Generator (HRSG)	
-002: Combined cycle CT with an associated unfired HRSG	
-003: Simple cycle CT	
B. Emission Unit 004, General Electric Model PG-7121 7EA Combustion Turbine	13
-005: Simple cycle CT	
C. Common Conditions	23
IV. Acid Rain Permit	
A. Acid Rain, Phase II	29

Permittee:

Hardee Power Partners
A Subsidiary of Invenergy, LLC
One South Wacker Drive, Suite 2020
Chicago, Illinois 60606

DRAFT/PROPOSED Permit No. 0490015-007-AV**Facility ID No. 0490015****SIC Nos. 49, 4911****Project: Title V Air Operation Permit Revision**

This permitting action is for the Revision of the Title V Air Operation Permit. The Hardee Power Station is located at 6695 County Road 663 North, Fort Green Springs, in Hardee County; UTM Coordinates: Zone 17, 405.02 km East and 3,057.18 km North; Latitude: 27° 38' 13" North and Longitude: 81° 57' 45" West.

This Title V Air Operation Permit Revision is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, 62-213 and 62-214. The above named Permittee is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans, and other documents, attached hereto or on file with the permitting authority, in accordance with the terms and conditions of this permit.

The purpose of this revision is to change various permit conditions to match the updated requirements of 40 CFR 60, Subpart GG, which was revised on July 8, 2004. Such changes are primarily related to fuel monitoring and additional emissions monitoring options. This permitting action will also be used to replace Appendix TV-4, Title V Conditions (version dated 02/12/02) with Appendix TV-6, Title V Conditions (version dated 6/23/06), as well as other minor administrative corrections as described below. It was determined that a concurrent Air Construction permit revision was not required because the changes contained in this revision do not alter the requirements contained in the construction permits to comply with the applicable portions of 40 CFR 60, Subpart GG.

Referenced attachments made a part of this permit:

Appendix G-1, Manufacturer's Performance Curves

Appendix GG, Standards of Performance for Stationary Gas Turbines

Appendix U-1, List of Unregulated Emissions Units and Activities

Appendix I-1, List of Insignificant Emissions Units and Activities

Appendix TV-6, Title V Conditions (Version Dated 6/23/06)

Appendix SS-1, Stack Sampling Facilities (Version Dated 10/07/96)

Table 297.310-1, Calibration Schedule (Version Dated 10/07/96)

Figure 1 - Summary Report-Gaseous And Opacity Excess Emission And Monitoring System Performance Report
(Version Dated 07/96)

Appendix CAM

Effective Date: January 1, 2005**Revision Effective Date:** *(Day 55)***Renewal Application Due Date:** July 5, 2009**Expiration Date:** December 31, 2009

Joseph Kahn, P.E., Director
Division of Air Resource Management

JK/jk/jh

Section I. Facility Information.

Subsection A. Facility Description.

Hardee Power Partners (A Subsidiary of Invenergy, LLC), operates a nominal 370 megawatt (MW) electric generation facility located approximately nine miles northwest of Wauchula in Hardee County, Florida. The Hardee Power Station includes four General Electric (GE) dual-fuel fired combustion turbines (CTs). The facility utilizes pipeline natural gas as its primary fuel source, with No. 2 distillate fuel oil serving as a backup fuel. Three of the CTs (CT-1A, CT-1B and CT-2A) are identical emissions units, GE Model No. PG-7111EA, and CTs 1A and 1B together comprise a combined-cycle unit operation and CT 2A is a simple cycle unit operation. All of the CTs have a nominal power production output of 75 MW; and, for CTs 1A and 1B, each has a generator nameplate rating of 113 MW (total of the CT and associated HRSG). CT-1A and CT-1B are each equipped with a heat recovery steam generator (HRSG), which feed one common steam turbine (ST). CT-1A and CT-1B are each equipped with a stack to bypass each unit's HRSG. The maximum permitted heat input rate to each CT is 1,312.3 MMBtu/hr while firing oil, and 1,268.4 MMBtu/hr while firing natural gas. Water injection is used to reduce NO_x emissions when firing natural gas and low sulfur distillate oil (backup fuel). The fourth and latest CT (CT-2B) is also manufactured by GE, Model No. PG-7121 (7EA), and is a simple cycle unit operation. The CT has an electrical generator with a nominal power production output of 75 MW. Dry low-NO_x (DLN) combustion technology will be used to control nitrogen oxide emissions, when firing the primary fuel of pipeline natural gas. Water injection will be used to control NO_x emissions, when firing low sulfur distillate oil as a backup fuel. Combustion design and clean fuels will be used to minimize emissions of CO, PM/PM₁₀, SAM, SO₂, and VOC.

Compliance Assurance Monitoring (CAM) is applicable to CTs 1A, 1B and 2A, for NO_x.

Also included in this permit are miscellaneous unregulated and insignificant emissions units and activities.

Based on the renewal Title V permit application received December 22, 2003, this facility is a major source of hazardous air pollutants (HAPs).

Subsection B. Summary of Emissions Units

E.U. ID No.	Brief Description
001	CT-1A with an associated unfired HRSG
002	CT-1B with an associated unfired HRSG
003	CT-2A
005	CT-2B

Subsection C. Relevant Documents

The following documents are part of this permit:

Appendix G-1, Manufacturer's Performance Curves
Appendix I-1, List of Insignificant Emissions Units and/or Activities
Appendix U-1, List of Unregulated Emissions Units and/or Activities
Appendix GG, Standards of Performance for Stationary Gas Turbines
Appendix SS-1, Stack Sampling Facilities (version dated 10/7/96)
Appendix TV-6, Title V Conditions (version dated 6/23/06)
Table 297.310-1 Calibration Schedule

The documents listed below are not a part of this permit; however, they are specifically related to this permit.

These documents are provided to the Permittee for information purposes only:

Appendix A-1, Abbreviations, Acronyms, Citations, and Identification Numbers
Appendix H-1, Permit History/ID Number Changes
Statement of Basis

These documents are on file with the permitting authority:

Title V Permit Renewal Application received December 22, 2003
Mr. Byron Burrows' e-mail with attachment (water injection system for CTs 1A, 1B and 2A) received January 21, 2004.
Mr. Byron Burrows' letter and Acid Rain Part Application (DEP Form No. 62-210.900(1)(a)) received January 22, 2004.
RAI dated February 18, 2004.
Mr. Byron Burrows' e-mail with attachments received June 4, 2004.
Mr. Alex C. George's letter with enclosure received August 9, 2004.
Title V Permit Revision Application received July 19, 2006.

Section II. Facility-wide Conditions

The following conditions apply facility-wide:

1. APPENDIX TV-6, TITLE V CONDITIONS, is a part of this permit.

{Permitting Note: APPENDIX TV-6, TITLE V CONDITIONS, is distributed to the Permittee only. Other persons requesting copies of these conditions shall be provided a copy when requested or otherwise appropriate.}

2. **Not federally enforceable.** General Pollutant Emission Limiting Standards. Objectionable Odor Prohibited. No person shall cause, suffer, allow, or permit the discharge of air pollutants which cause or contribute to an objectionable odor.

[Rule 62-296.320(2), F.A.C.]

3. General Particulate Emission Limiting Standards. General Visible Emissions Standard.

Except for emissions units that are subject to a particulate matter or opacity limit set forth or established by rule and reflected by conditions in this permit, no person shall cause, let, permit, suffer or allow to be discharged into the atmosphere the emissions of air pollutants from any activity, the density of which is equal to or greater than that designated as Number 1 on the Ringelmann Chart (20 percent opacity). EPA Method 9 is the method of compliance pursuant to Chapter 62-297, F.A.C.

[Rules 62-296.320(4)(b)1. & 4., F.A.C.]

{Permitting Note: Although the Permittee is not required to perform a visible emissions compliance test to demonstrate compliance with the facility-wide limitations annually or before renewal, if the Department believes that the general visible emissions standard is being violated, the Department may require that the owner or operator perform a visible emissions compliance test per Chapter 62-297.310(7)(b), Special Compliance Tests.}

4. Prevention of Accidental Releases (Section 112(r) of CAA).

a. The permittee shall submit its Risk Management Plan (RMP) to the Chemical Emergency Preparedness and Prevention Office (CEPPO) RMP Reporting Center when, and if, such requirement becomes applicable. Any Risk Management Plans, original submittals, revisions or updates to submittals, should be sent to:

RMP Reporting Center
Post Office Box 1515
Lanham-Seabrook, MD 20703-1515
Telephone: 301/429-5018

and,

b. The permittee shall submit to the permitting authority Title V certification forms or a compliance schedule in accordance with Rule 62-213.440(2), F.A.C.

[40 CFR 68]

5. Unregulated Emissions Units and Activities. Appendix U-1, List of Unregulated Emissions Units and/or Activities, is a part of this permit.

[Rule 62-213.440(1), F.A.C.]

6. Insignificant Emissions Units and/or Activities. Appendix I-1, List of Insignificant Emissions Units and/or Activities, is a part of this permit.

[Rules 62-213.440(1), 62-213.430(6) and 62-4.040(1)(b), F.A.C.]

7. General Pollutant Emission Limiting Standards. Volatile Organic Compounds Emissions or Organic Solvents Emissions. The Permittee shall allow no person to store, pump, handle, process, load, unload or use in any process or installation, volatile organic compounds or organic solvents without applying known and existing vapor emission control devices or systems deemed necessary and ordered by the Department.

[Rule 62-296.320(1)(a), F.A.C.]

{Permitting Note: “Nothing was deemed necessary and ordered at this time.”}

8. Reasonable precautions shall be taken to prevent emissions of unconfined particulate matter at this facility as necessary.

[Rule 62-296.320(4)(c)2., F.A.C.]

9. When appropriate, any recording, monitoring, or reporting requirements that are time-specific shall be in accordance with the effective date of the permit, which defines day one.

[Rule 62-213.440, F.A.C.]

10. The Permittee shall submit all compliance related notifications and reports required of this permit to the Department’s Southwest District office:

Department of Environmental Protection
Southwest District Office
~~3804 Coconut Palm Drive~~ 13051 North Telecom Parkway
~~Tampa, Florida 33619-8218~~ Temple Terrace, FL 33637-0926
Telephone: ~~813/744-6100~~ 813/632-7600
Fax: ~~813/744-6084~~ 813/632-7668

11. Any reports, data, notifications, certifications, and requests required to be sent to the United States Environmental Protection Agency, Region 4, should be sent to:

United States Environmental Protection Agency
Region 4
Air, Pesticides & Toxics Management Division
Air and EPCRA Enforcement Branch, Air Enforcement Section
61 Forsyth Street
Atlanta, Georgia 30303
Telephone: 404/562-9155
Fax: 404/562-9164

12. Statement of Compliance. The annual statement of compliance pursuant to Rule 62-213.440(3)(a)2., F.A.C., shall be submitted to the Department and EPA within 60 (sixty) days after the end of the calendar year using DEP Form No. 62-213.900(7), F.A.C.

[Rules 62-213.440(3) and 62-213.900, F.A.C.]

{Permitting Note: This condition implements the requirements of Rules 62-213.440(3)(a)2. & 3., F.A.C. (see Condition 51. of APPENDIX TV-6, TITLE V CONDITIONS)}

13. Certification by Responsible Official (RO). In addition to the professional engineering certification required for applications by Rule 62-4.050(3), F.A.C., any application form, report, compliance

statement, compliance plan and compliance schedule submitted pursuant to Chapter 62-213, F.A.C., shall contain a certification signed by a responsible official that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete. Any responsible official who fails to submit any required information or who has submitted incorrect information shall, upon becoming aware of such failure or incorrect submittal, promptly submit such supplementary information or correct information.

[Rule 62-213.420(4), F.A.C.]

Please reference the Permit No., Facility ID No., and appropriate Emissions Unit(s) ID No(s). on all correspondence, test report submittals, applications, etc.

Section III. Emissions Units and Conditions.

Subsection A. This section addresses the following emissions unit(s).

E.U. ID No.	Brief Description
001	Combustion Turbine -1A (CT-1A) with an associated unfired HRSG
002	CT-1B with an associated unfired HRSG
003	CT-2A

These emissions units are three identical General Electric (GE) Model No. PG-7111EA dual-fuel fired CTs (CT-1A, CT-1B and CT-2A), each having a nominal power production output of 75 MW; and, for CTs 1A and 1B, each has a generator nameplate rating of 113 MW (total of the CT and associated HRSG). CT-1A and CT-1B are each equipped with an associated unfired heat recovery steam generator (HRSG), which feed one common steam turbine (ST). CT-1A and CT-1B are each equipped with a stack to bypass each unit's HRSG. CTs 1A and 1B comprise a combined-cycle unit operation and CT 2A is a simple cycle unit operation. CAM applies for NO_x.

The facility utilizes pipeline natural gas as its primary fuel source with No. 2 distillate fuel oil serving as a backup fuel. The maximum annual average of the fuel oil sulfur content is 0.3%, by weight, and the maximum fuel oil sulfur content is 0.5%, by weight. Water injection is used to reduce NO_x emissions; and, the water-to-fuel ratio is required to be continuously monitored for NO_x purposes. The maximum permitted heat input rate to each CT is 1,312.3 MMBtu/hr, while firing oil, and 1,268.4 MMBtu/hr, while firing natural gas.

Exhaust gases from the CTs exit a 90 foot high stack (14.5 feet diameter) at approximately 245 °F, with an actual volumetric flow rate of 751,000 acfm. These parameters are based on firing natural gas at 100% base load.

{Permitting Notes: These emission units are regulated under Rule 62-210.300, F.A.C., Permits Required; NSPS - 40 CFR 60, Subpart GG, Standards of Performance for Stationary Gas Turbines, adopted and incorporated by reference in Rule 62-204.800(8), F.A.C.; NSPS - 40 CFR 60, Subpart A; Rule 62-212.400, F.A.C., Prevention of Significant Deterioration; PSD-FL-140; and, the emissions units are not affected by the Acid Rain Program since they meet the requirements of 40 CFR 72.6(b)(6).}

The following specific conditions apply to the emissions unit(s) listed above:

Essential Potential to Emit (PTE) Parameters

A.1. Permitted Capacity. The maximum heat input to each CT, at an ambient temperature of 32° F, shall not exceed 1,312.3 MMBtu/hr, while firing fuel oil, nor 1,268.4 MMBtu/hr, while firing natural gas. [PSD-FL-140]

A.2. Methods of Operation - Fuels. The only fuels allowed to be burned in these emissions units are natural gas or No. 2 fuel oil. The annual average sulfur content of the fuel oil shall not exceed 0.3 percent, by weight; and, the maximum sulfur content shall not exceed 0.5%, by weight. [Rule 62-213.440(1), F.A.C.; and, PSD-FL-140]

A.3. Hours of Operation.

These emissions units are allowed to operate continuously, i.e., 8,760 hours per year.

[PSD-FL-140]

Emission Limitations and Standards

{**Permitting Note:** Unless otherwise specified, the averaging times for specific conditions A.4. thru A.9. are based on the specified averaging time of the applicable test method.}

A.4. Nitrogen Oxides. NO_x emissions from each CT shall not exceed:

- a. 42 ppmvd at 15% O₂ and 215.9 lbs/hr, while firing natural gas; and,
- b. 65 ppmvd at 15% O₂ and 383.8 lbs/hr, while firing fuel oil.

[PSD-FL-140]

A.5. Sulfur Dioxide. SO₂ emissions from each CT shall not exceed 35.8 lbs/hr, while firing natural gas, and 734.4 lbs/hr, while firing fuel oil.

[PSD-FL-140]

A.6. Particulate Matter (PM)/PM₁₀. PM/PM₁₀ emissions from each CT shall not exceed 5 lbs/hr, while firing natural gas, and 10 lbs/hr, while firing fuel oil.

[PSD-FL-140]

A.7. Carbon Monoxide. CO emissions from each CT shall not exceed 10 ppmvd and 31.3 lbs/hr, while firing natural gas, and 26 ppmvd and 93.4 lbs/hr, while firing fuel oil.

[PSD-FL-140]

A.8. Volatile Organic Compounds. VOC emissions from each CT shall not exceed 2 ppmvd and 3.6 lbs/hr, while firing natural gas, and 5 ppmvd and 10.3 lbs/hr, while firing fuel oil.

[PSD-FL-140]

A.9. Visible Emissions. Visible emissions from each CT shall not exceed 10 percent opacity, while firing natural gas, and 20 percent opacity, while firing fuel oil.

[PSD-FL-140]

Monitoring Requirements

A.10. CMS Requirements. The Permittee shall install, operate, and maintain a continuous monitoring system (CMS) to monitor and record the fuel consumption and, the ratio of water to fuel being fired in the turbine. ~~The system shall be accurate to within ±5.0 percent and shall be approved by the Department.~~

[40 CFR 60.334(a); and, PSD-FL-140]

A.11. Critical Fuel Parameters. The Permittee shall monitor sulfur content and nitrogen content of the fuel being fired in the CTs. Pursuant to the ~~monitoring system monitoring schedule~~ provisions of 40 CFR 60.334(~~h~~)(2), the frequency of determination of these values shall be as follows:

1. Monitoring of the nitrogen content of No. 2 fuel oil is not required. The sulfur content of distillate fuel oil shall be determined for each shipment of No. 2 fuel oil received; and,

2. Monitoring of the nitrogen content of pipeline natural gas is not required. The sulfur content of pipeline natural gas will be monitored using the applicable monitoring procedures specified in 40 CFR 60.334(h)~~based on twice monthly analyses provided by the natural gas supplier.~~

[40 CFR 60.334(~~hb~~)(1) & (2)]

Test Methods & Procedures

A.12. Testing of emissions shall be conducted with the emissions unit operating at permitted capacity. Permitted capacity is defined as 90 to 100 percent of the manufacturer's rated heat input achievable for the average ambient (or conditioned) air temperature during the test. If it is impracticable to test at permitted capacity, then the emissions unit may be tested at less than permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test load until a new test is conducted. Once the emissions unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity. Data, curves, and calculations necessary to demonstrate the heat input rate correction at both design and test conditions shall be submitted to the Department with the compliance test report. If testing shows that NO_x emissions exceed the Subpart GG standard when operating at capacity, the Department may require a performance test in accordance with 40 CFR 60.335 testing procedures.

[Rule 62-4.070(3), F.A.C.; and, 40 CFR 60.8(a)]

A.13. Required Number of Test Runs. For mass emission limitations, a compliance test shall consist of three complete and separate determinations of the total air pollutant emission rate through the test section of the stack or duct and three complete and separate determinations of any applicable process variables corresponding to the three distinct time periods during which the stack emission rate was measured provided, however, that three complete and separate determinations shall not be required if the process variables are not subject to variation during a compliance test, or if three determinations are not necessary in order to calculate the emissions unit's emission rate. The three required test runs shall be completed within one consecutive five day period. In the event that a sample is lost or one of the three runs must be discontinued because of circumstances beyond the control of the owner or operator, and a valid third run cannot be obtained within the five day period allowed for the test, the Secretary or his or her designee may accept the results of the two complete runs as proof of compliance, provided that the arithmetic mean of the results of the two complete runs is at least 20 percent below the allowable emission limiting standards.

[Rule 62-297.310(1), F.A.C.]

A.14. Calculation of Emission Rate. The indicated emission rate or concentration shall be the arithmetic average of the emission rate or concentration determined by each of the separate test runs unless otherwise specified in a particular test method or applicable rule.

[Rule 62-297.310(3), F.A.C.]

A.15. Applicable Test Procedures.

(a) Required Sampling Time.

1. Unless otherwise specified in the applicable rule, the required sampling time for each test run shall be no less than one hour and no greater than four hours, and the sampling time at each sampling point shall be of equal intervals of at least two minutes.

2. **Opacity Compliance Tests.** When either EPA Method 9 or DEP Method 9 is specified as the applicable opacity test method, the required minimum period of observation for a compliance test shall be sixty (60) minutes for emissions units which emit or have the potential to emit 100 tons per year or more of particulate matter, and thirty (30) minutes for emissions units which have potential emissions less than 100 tons per year of particulate matter and are not subject to a multiple-valued opacity standard. The opacity test observation period shall include the period during which the highest opacity emissions can reasonably be expected to occur.

Exceptions to these requirements are as follows:

- a. (not applicable)
- b. (not applicable)
- c. The minimum observation period for opacity tests conducted by employees or agents of the Department to verify the day-to-day continuing compliance of a unit or activity with an applicable opacity standard shall be twelve minutes.

(b) Minimum Sample Volume. Unless otherwise specified in the applicable rule, the minimum sample volume per run shall be 25 dry standard cubic feet.

(c) Required Flow Rate Range. For EPA Method 5 particulate sampling, acid mist/sulfur dioxide, and fluoride sampling which uses Greenburg Smith type impingers, the sampling nozzle and sampling time shall be selected such that the average sampling rate will be between 0.5 and 1.0 actual cubic feet per minute, and the required minimum sampling volume will be obtained.

(d) Calibration of Sampling Equipment. Calibration of the sampling train equipment shall be conducted in accordance with the schedule shown in Table 297.310-1. (See attachment.)

(e) Allowed Modification to EPA Method 5. When EPA Method 5 is required, the following modification is allowed: the heated filter may be separated from the impingers by a flexible tube.

[Rule 62-297.310(4), F.A.C.]

A.16. Special Compliance Tests. When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it may require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department.

[Rule 62-297.310(7)(b), F.A.C.; and, SIP approved]

A.17. Waiver of Compliance Test Requirements. If the owner or operator of an emissions unit that is subject to a compliance test requirement demonstrates to the Department, pursuant to the procedure established in Rule 62-297.620, F.A.C., that the compliance of the emissions unit with an applicable weight emission limiting standard can be adequately determined by means other than the designated test procedure, such as specifying a surrogate standard of no visible emissions for particulate matter sources equipped with a bag house or specifying a fuel analysis for sulfur dioxide emissions, the Department shall waive the compliance test requirements for such emissions units and order that the alternate means of determining compliance be used, provided, however, the provisions of Rule 62-297.310(7)(b), F.A.C., shall apply.

[Rule 62-297.310(7)(c), F.A.C.]

A.18. An annual compliance test shall be performed on each CT if the CT operated for more than 400 hours in the preceding 12-month period. Annual compliance tests shall be performed on the CTs while firing natural gas if No. 2 fuel oil was used for 400 hours or less in the preceding 12-month period. Annual compliance tests shall be performed on the CTs while firing No. 2 fuel oil if the No. 2 fuel was used for more than 400 hours in the preceding 12-month period. Tests shall be conducted using the following EPA reference methods in accordance with 40 CFR 60, Appendix A, as adopted by reference in Chapter 62-297, F.A.C.:

- a. Reference Method 5, 5B or 17 for PM/PM₁₀ (fuel oil only).
- b. Reference Method 9 for VE.
- c. Reference Method 10 for CO.
- d. Reference Method 20 for NO_x.
- e. Reference Method 25A for VOC.

f. Other methods may be used for compliance testing after obtaining prior Departmental approval, in writing.

[Rule 62-297.310(7)(a)(4), F.A.C.; and, PSD-FL-140]

A.19. Sulfur Content. The Permittee shall determine compliance with the sulfur content standard in 40 CFR 60.333(b) using applicable test methods and procedures specified in 40 CFR 60.335 as follows: ASTM D 2880-96, or more recent version, shall be used to determine the sulfur content of liquid fuels and ASTM D 1072-90(94)E 1, D 3031-81(86), D 4084-94, or D 3246-92, or more recent versions, shall be used for the sulfur content of gaseous fuels (incorporated by reference—see 40 CFR 60.17). The applicable ranges of some ASTM methods mentioned above are not adequate to measure the levels of sulfur in some fuel gases. Dilution of samples before analysis (with verification of the dilution ratio) may be used, subject to the approval of the Department.

[40 CFR 60.335(d); and, PSD-FL-140]

A.20. Reserved~~To meet the requirements of 40 CFR 60.334(b), the owner or operator shall use the methods specified in 40 CFR 60.335(a) and 40 CFR 60.335(d) of 40 CFR 60.335 to determine the nitrogen and sulfur contents of the fuel being burned. The analysis may be performed by the owner or operator, a service contractor retained by the owner or operator, the fuel vendor, or any other qualified agency.~~

[40 CFR 60.335(e)]

Common Conditions

A.21. These emissions units are also subject to specific conditions C.1. through C.19., contained in Subsection C. **Common Conditions.**

Special Conditions

A.22. On or before April 1 of each year, the Permittee shall submit to DARM and the Department's Southwest District Office an annual report for the previous year showing:

- a. The annual average capacity factor (CF) for each individual generating unit;
- b. The cumulative lifetime average CF for each individual generating unit;
- c. The annual average CF for the Hardee Power Station; and,
- d. The cumulative lifetime average CF for the Hardee Power Station.

The annual average CF shall be calculated by dividing each unit's megawatt hours output of generation by the product of the official megawatt rating of the unit and the number of hours in a year. Cumulative lifetime average CF shall be calculated by dividing the cumulative total of megawatt hours output of

generation by the product of the official combined cycle megawatt rating and the cumulative period of hours since commercial operation.

[PSD-FL-140]

A.23. To determine compliance with the capacity factor condition, the Permittee shall maintain daily records of power generation for each CT.

[PSD-FL-140]

A.24. Should any annual report demonstrate that the cumulative lifetime CF for the Hardee Power Station exceeds 60% at any time, the Permittee shall install SCR or another technology of equal or greater NO_x reduction capability. In no event shall any such SCR or equivalent NO_x control technology installation and compliance testing occur later than 30 months from the date that the Permittee requested or the facility exceeded the 60% cumulative average CF.

[PSD-FL-140]

A.25. If start/black start capability for the CTs is provided by a combustion unit, the Department shall be notified of the type and model, output capacity, anticipated hours of operation, and the air emissions of the unit.

[PSD-FL-140]

Miscellaneous

A.26. Modification. Any change in the method of operation, fuels, equipment, or phase design, shall be submitted for approval to the Department's permitting authority.

[Rules 62-210.300(1) & (1)(a); and, PSD-FL-140]

A.27. Sampling Facilities. Permanent stack sampling facilities shall be installed for the bypass stack (CT) and the main stack (HRSG) in accordance with Rule 62-297.310(6), F.A.C.

[Rules 62-204.800 and 62-297.310(6), F.A.C.; 40 CFR 60.8(e); and, PSD-FL-140]

Section III. Emissions Units and Conditions.

Subsection B. This section addresses the following emissions unit.

E.U. ID No.	Brief Description
005	Combustion Turbine-2B (CT-2B)

This emissions unit is a General Electric Model No. PG-7121 (7EA), which is a dual-fuel fired CT with an electrical generator having a nominal power production output of 75 MW. Dry low-NO_x (DLN) combustion technology will be used to control nitrogen oxide emissions when firing the primary fuel of pipeline natural gas. Water injection will be used to control NO_x emissions when firing low sulfur distillate oil as a backup fuel. Combustion design and clean fuels will be used to minimize emissions of CO, PM/PM₁₀, SAM, SO₂, and VOC. CAM does not apply.

Exhaust gases from the CT will exit an 85 feet high rectangular stack (9 feet by 19 feet) at approximately 1000 °F with a volumetric flow rate of 1,465,518 acfm. These parameters are based on firing natural gas at 100% base load, cooling the CT inlet air to 59 °F, and ambient conditions of 60% relative humidity and 14.7 psi.

{Permitting Notes: This emissions unit is regulated under Rule 62-210.300, F.A.C., Permits Required; NSPS - 40 CFR 60, Subpart GG, Standards of Performance for Stationary Gas Turbines, adopted and incorporated by reference in Rule 62-204.800(8), F.A.C.; NSPS - 40 CFR 60, Subpart A; Rule 62-212.400, F.A.C., Prevention of Significant Deterioration; Rule 62-212.400(6), F.A.C. (BACT); PSD-FL-140A; and, the applicable provisions of the Acid Rain Program.}

The following specific conditions apply to the emissions unit listed above:

Essential Potential to Emit (PTE) Parameters

B.1. Permitted Capacity. The CT shall operate only in simple-cycle mode and generate a nominal 75 MW of electrical power. Operation of this emissions unit shall not exceed 880 MMBtu per hour of heat input from firing natural gas nor 950 MMBtu per hour of heat input from firing low sulfur distillate oil. The maximum heat inputs are based on the lower heating value (LHV) of each fuel, an inlet air supply cooled to 59 °F, a relative humidity of 60%, an ambient air pressure of 14.7 psi, and 100% base load. Therefore, maximum heat input rates will vary depending upon ambient conditions and the CT characteristics. Manufacturer's performance curves, corrected for site conditions or equations for correction to other ambient conditions, have been provided and are a part of this permit. See Attachment G-1.

[PSD-FL-140A]

B.2. Methods of Operation - Fuels. The CT shall be fired by pipeline natural gas containing no more than 2 grains of sulfur per 100 dry standard cubic feet of gas. As a backup fuel, the CT may be fired with No. 2 distillate oil (or a superior grade) containing no more than 0.05% sulfur content, by weight. Compliance with limits on fuel sulfur content shall be demonstrated by the record keeping requirements and/or the conditions of the Alternate Monitoring Plan specified in this permit. It is noted that these limitations are much more stringent than the NSPS sulfur dioxide limitation and assure compliance with 40 CFR 60.333 and 60.334. See specific conditions **B.9., B.15. thru B.17. and C.19.b.**

[PSD-FL-140A]

B.3. Hours of Operation. The hours of operation of the CT are not limited when firing natural gas (8760 hours per year). The CT shall not fire low sulfur distillate oil for more than 876 hours during any consecutive 12 months. Operation below 50% of baseline operation shall be limited to two (2) hours per unit cycle (breaker open to breaker closed).

[Rule 62-212.400(6), F.A.C. (BACT); and, PSD-FL-140A]

B.4. Simple Cycle Operation. The CT shall operate only in simple cycle mode. This requirement is based on the permittee's request, which formed the basis of the NO_x BACT determination and resulted in the emission standards specified in this permit. Specifically, the NO_x BACT determination eliminated several control alternatives based on technical considerations and costs due to the elevated temperatures of the exhaust gas. Any request to convert this unit to combined cycle operation by installing a new heat recovery steam generator or connecting this unit to an existing heat recovery steam generator shall require the permittee to perform a new NO_x BACT analysis and the approval of the Department through a permit modification. The results of this analysis may validate the initial BACT determination or result in the submittal of a full PSD permit application, new control equipment, and new emissions standards.

[Rule 62-212.400(6)(b), F.A.C.; and, PSD-FL-140A]

Performance Restrictions

B.5. Operating Procedures. The Best Available Control Technology (BACT) determinations established by this permit rely on "good operating practices" to minimize emissions. Therefore, all operators and supervisors shall be properly trained to operate and maintain the CT and pollution control devices in accordance with the guidelines and procedures established by each equipment manufacturer. The training shall include good operating practices as well as methods of minimizing excess emissions.

[Rule 62-4.070(3), F.A.C.; Rule 62-212.400(6), F.A.C. (BACT); and, PSD-FL-140A]

B.6. Plant Operation - Problems. If temporarily unable to comply with any of the conditions of the permit due to breakdown of equipment or destruction by fire, wind or other cause, the owner or operator shall notify the Compliance Authority as soon as possible, but at least within one (1) working day, excluding weekends and holidays. The notification shall include: pertinent information as to the cause of the problem; the steps being taken to correct the problem and prevent future recurrence; and, where applicable, the owner's intent toward reconstruction of destroyed facilities. Such notification does not release the permittee from any liability for failure to comply with the conditions of this permit and the regulations.

[Rule 62-4.130, F.A.C.; and, PSD-FL-140A]

Emission Limitations and Standards

{**Permitting Note:** Unless otherwise specified, the averaging times for specific conditions **B.7.**, **B.8.**, and **B.10.** thru **B.12.**, are based on the specified averaging time of the applicable test method.}

B.7. Nitrogen Oxides.

(a) **Gas Firing:** When firing natural gas in the CT, NO_x emissions shall not exceed 32.0 lbs/hr nor 9.0 ppmvd, corrected to 15% oxygen, based on a 3-hour test average. In addition, NO_x emissions shall not exceed 9.0 ppmvd, corrected to 15% oxygen, based on a 24-hour block average for data collected from the continuous emissions monitor.

(b) **Oil Firing:** When firing low sulfur distillate oil in the CT, NO_x emissions shall not exceed 167.0 lbs/hr nor 42.0 ppmvd, corrected to 15% oxygen, based on a 3-hour test average. In addition, NO_x emissions shall not exceed 42.0 ppmvd, corrected to 15% oxygen, based on a 3-hour block average for data collected from the continuous emissions monitor.

NO_x emissions are defined as emissions of oxides of nitrogen measured as NO₂. Compliance with the 3-hour (applicable during distillate fuel oil-firing) and 24-hour (applicable during natural gas-firing) block averages shall be demonstrated by collecting and reporting data in accordance with the conditions for the NO_x continuous emissions monitor specified by this permit.

[PSD-FL-140A]

B.8. Carbon Monoxide.

(a) Gas Firing: When firing natural gas in the CT, CO emissions shall not exceed 43.0 lbs/hr nor 20.0 ppmvd, corrected to 15% oxygen, based on a 3-hour test average.

(b) Oil Firing: When firing low sulfur distillate oil in the CT, CO emissions shall not exceed 43.0 lbs/hr nor 20.0 ppmvd, corrected to 15% oxygen, based on a 3-hour test average.

[PSD-FL-140A]

B.9. Sulfur Dioxide and Sulfuric Acid Mist (SAM). SO₂ and SAM emissions shall be limited by the good combustion techniques and the fuel sulfur limitations specified in this permit: natural gas containing no more than 2 grains of sulfur per 100 dry standard cubic feet of gas and No. 2 distillate oil (or a superior grade) containing no more than 0.05% sulfur content, by weight.

[PSD-FL-140A]

B.10. Particulate Matter/PM₁₀. PM/PM₁₀ emissions from the CT shall be limited by the good combustion techniques and the fuel sulfur limitations specified in this permit: natural gas containing no more than 2 grains of sulfur per 100 dry standard cubic feet of gas and No. 2 distillate oil (or a superior grade) containing no more than 0.05% sulfur content, by weight.

[PSD-FL-140A]

B.11. Visible Emissions. As a surrogate for PM/PM₁₀ emissions, visible emissions from the operation of the CT shall not exceed 10% opacity, based on a 6-minute average.

[PSD-FL-140A]

B.12. Volatile Organic Compounds (VOCs).

(a) Gas Firing: When firing natural gas in the CT, VOC emissions shall not exceed 2.0 lbs/hr nor 2.0 ppmvd, based on a 3-hour test average.

(b) Oil Firing: When firing low sulfur distillate oil in the CT, VOC emissions shall not exceed 5.0 lbs/hr nor 4.0 ppmvd, based on a 3-hour test average.

The VOC emissions shall be measured and reported in terms of methane.

[PSD-FL-140A]

Monitoring Requirements.

B.13. CMS Requirements. The permittee shall install, calibrate, operate and maintain a continuous monitoring system (CMS) to monitor and record the fuel consumption ~~and~~ the ratio of water to fuel being fired in the CT. ~~The system shall be accurate to within ± 5.0 percent and shall be approved by the Department.~~ As an alternative to the monitoring requirements of this condition, the permittee may comply with the monitoring requirements of specific condition B.17 (See Alternate Monitoring Plan).
[40 CFR 60.334(a)]

B.14. NO_x CEMS. The permittee shall install, calibrate, operate, and maintain a continuous emission monitoring system (CEMS) to measure and record NO_x and oxygen concentrations in the CT exhaust stack. A monitor for carbon dioxide may be used in place of the oxygen monitor, but the system shall be capable of correcting the emissions to 15% oxygen. NO_x data collected by the CEMS shall be used to demonstrate compliance with the 3-hour (applicable to distillate fuel oil-firing) and 24-hour (applicable to natural gas-firing) block emissions standards for NO_x. The block averages shall be determined by calculating the arithmetic average of all hourly emission rates for the respective averaging period. Each 1-hour average shall be expressed in units of ppmvd, corrected to 15% oxygen, and calculated using at least two valid data points at least 15 minutes apart. Valid hourly emission rates shall not include periods of startup, shutdown, or malfunction unless prohibited by Rule 62-210.700, F.A.C. (See specific condition B.33.(b)). When NO_x monitoring data is not available, substitution for missing data shall be handled as required by Title IV (40 CFR 75) to calculate any specified averaging period.

(a) The monitoring devices shall comply with the certification and quality assurance, and any other applicable requirements of: Rule 62-297.520, F.A.C., including certification of each device in accordance with 40 CFR 60, Appendix B, Performance Specifications 2 and 3; 40 CFR 60.7(a)(5); 40 CFR 60.13; 40 CFR 60, Appendix F; and, 40 CFR Part 75.

(b) Continuous emission monitoring data required by this permit shall be collected and recorded during all periods of operation including startup, shutdown, and malfunction, except for continuous monitoring system breakdowns, repairs, calibration checks, and zero and span adjustments. Although recorded, emissions during periods of startup, shutdown and malfunction are subject to the excess emission conditions specified in this permit. When the CEMS reports NO_x emissions in excess of the standards allowed by this permit, the owner or operator shall notify the Compliance Authority within one (1) working day of: the nature, extent, and duration of the excess emissions; the cause of the excess emissions; and the actions taken to correct the problem. The Department may request a written report summarizing the excess emissions incident.

[Rules 62-204.800, 62-210.700, 62-4.130 and 62-4.160(8), F.A.C.; 40 CFR 60.7; and, PSD-FL-140A]

B.15. Critical Fuel Parameters. The Permittee shall monitor sulfur content and nitrogen content of the fuel being fired in the CT. Pursuant to the ~~monitoring~~~~custom monitoring schedule~~ provisions of 40 CFR 60.334(~~h~~)(2), the frequency of determination of these values shall be as follows:

1. Monitoring of the nitrogen content of No. 2 fuel oil is not required. The sulfur content of distillate fuel oil shall be determined for each shipment of No. 2 fuel oil received; and,

2. Monitoring of the nitrogen content of pipeline natural gas is not required. The sulfur content of pipeline natural gas will be monitored using the applicable monitoring procedures specified in 40 CFR 60.334(h)~~based on twice monthly analyses provided by the natural gas supplier.~~

[40 CFR 60.334(~~h~~)(1) & (2)]

Compliance Demonstrations

B.16. Fuel Records.

(a) Natural Gas. The permittee shall demonstrate compliance with the fuel sulfur limit for natural gas specified in this permit by maintaining records of the sulfur content of the natural gas being supplied ~~using the applicable monitoring procedures specified in 40 CFR 60.334(h) for each month of operation.~~ Methods for determining the sulfur content of the natural gas shall be made using the applicable test methods and procedures specified in 40 CFR 60.335 ~~ASTM methods D4084-82, D3246-81,~~ or equivalent methods. These methods shall be used to determine the sulfur content of the natural gas fired in accordance with any EPA-approved custom fuel monitoring schedule (see Alternate Monitoring Plan: specific condition B.17.) or natural gas supplier data or the natural gas sulfur content referenced in 40 CFR 75, Appendix D. The analysis may be performed by the owner or operator, a service contractor retained by the owner or operator, the fuel vendor, or any other qualified agency pursuant to 40 CFR 60.335(e). However, the permittee is responsible for ensuring that the procedures in 40 CFR 60.335 or 40 CFR 75 are used to determine the fuel sulfur content for compliance with the 40 CFR 60.333 SO₂ standards.

(b) Low Sulfur Distillate Oil. For all bulk shipments of low sulfur distillate oil received at this facility, the permittee shall obtain from the fuel vendor an analysis identifying the sulfur content. Methods for determining the sulfur content of the distillate oil shall be made using the applicable test methods and procedures specified in 40 CFR 60.335 ~~ASTM D129-91, D2622-94, or D4294-90,~~ or equivalent methods. Records shall specify the test method used and shall comply with the requirements of 40 CFR 60.335(d). [Rules 62-4.070(3) and 62-4.160(15), F.A.C.]

B.17. Alternate Monitoring Plan.

1. The following alternate monitoring may be used to demonstrate compliance.

(a) The NO_x CEMS data may be used in lieu of the monitoring system for water-to-fuel ratio and the reporting of excess emissions in accordance with 40 CFR 60.334(c)(1), Subpart GG. ~~Subject to EPA approval, the calibration of the water to fuel ratio monitoring device required in 40 CFR 60.335(e)(2) will be replaced by the 40 CFR 75 certification tests of the NO_x CEMS.~~

(b) The NO_x CEMS data shall be used in lieu of the requirement for reporting excess emissions in accordance with 40 CFR 60.334(c)(1), Subpart GG.

(c) When requested by the Department, the CEMS emission rates for NO_x on this unit shall be corrected to ISO conditions to demonstrate compliance with the NO_x standard established in 40 CFR 60.332.

(d) A **custom fuel monitoring schedule** pursuant to 40 CFR 75, Appendix D, for natural gas, may be used in lieu of the daily sampling requirements of 40 CFR 60.334(h)(2) provided the following conditions are met.

(1) The permittee shall apply for an Acid Rain Permit within the deadlines specified in 40 CFR 72.30.

(2) The permittee shall submit a monitoring plan, certified by signature of the Authorized Representative, that commits to using a primary fuel of pipeline supplied natural gas containing no more than 2 grains of sulfur per 100 SCF of gas pursuant to 40 CFR 75.11(d)(2).

(3) Each unit shall be monitored for SO₂ emissions using methods consistent with the requirements of 40 CFR 75 and certified by the USEPA.

This custom fuel-monitoring schedule will only be valid when pipeline natural gas is used as a primary fuel. If the primary fuel for these units is changed to a higher sulfur fuel, SO₂ emissions must be accounted for as required pursuant to 40 CFR 75.11(d).

~~[40 CFR 60, Subpart GG; and, PSD-FL 140A]~~

(e) The permittee shall monitor the sulfur contents of the No. 2 distillate fuel oil (or a superior grade) and natural gas. These values may be provided by the vendor and the frequency of determinations of these values shall be as follows:

(1)a- No. 2 Distillate Fuel Oil (or a superior grade). The sulfur content shall be determined on each occasion that fuel is transferred to the storage tanks from any other source. Records of these values shall be kept by the facility for a five year period for regulatory agency inspection purposes.

(2)b- Natural Gas. Monitoring shall be conducted in accordance with the applicable provisions of 40 CFR 60.334(h) and 60.335. Alternatively, pursuant to 40 CFR 60.334(h)(2), a custom fuel monitoring schedule for the determination of these values may shall be followed for the natural gas fired at this facility and shall be as follows:

Custom Fuel Monitoring Schedule for Natural Gas

2. Sulfur Monitoring.

(a) Analysis for fuel sulfur content of the natural gas shall be conducted using one of the approved ASTM reference methods for the measurement of sulfur in gaseous fuels, or an approved alternative method. The reference methods are ASTM D1072-80, ASTM D3031-81, ASTM D3246-81, and ASTM D4084-82 as referenced in 40 CFR 60.335(b)(2), or the latest edition(s).

(b) This custom fuel monitoring schedule shall become effective on the date this permit becomes effective. Effective the date of this custom schedule, sulfur monitoring shall be conducted twice monthly for six months. If this monitoring shows little variability in the fuel sulfur content, and indicates consistent compliance with 40 CFR 60.333 and the conditions of this permit, then sulfur monitoring shall be conducted once per quarter for six quarters. If monitoring data is provided by the applicant which demonstrates consistent compliance with the requirements herein the applicant may begin monitoring as per the requirements of paragraph 2(c), below.

(c) If after the monitoring required in paragraph 2(b), above, or herein, the sulfur content of the fuel shows little variability and, calculated as sulfur dioxide, represents consistent compliance with the sulfur dioxide emission limits specified under 40 CFR 60.333 and the conditions of this permit, sample analysis shall be conducted twice per annum. This monitoring shall be conducted during the first and third quarters of each calendar year.

(d) Should any sulfur analysis as required in paragraphs 2(b) or 2(c), above, indicate non-compliance with 40 CFR 60.333 and the conditions of this permit, the owner or operator shall notify the Department of such excess emissions and the custom schedule shall be re-examined. Sulfur monitoring shall be conducted weekly during the interim period when this custom schedule is being re-examined.

3. If there is a change in fuel supply, the owner or operator must notify the Department of such change for re-examination of this custom schedule. A substantial change in natural gas quality (i.e., sulfur content varying by more than 10 grains/1000 dry standard cubic feet of gas) shall be considered as a change in fuel supply. Sulfur monitoring shall be conducted weekly during the interim period when this custom schedule is being re-examined.

4. Records of sample analysis and fuel supply pertinent to this custom schedule shall be retained for a

period of five years, and be available for inspection by personnel of federal, state, and local air pollution control agencies.

[40 CFR 60.334(b); and, PSD-FL-140A]

B.18. Monthly Operations Summary. By the fifth calendar day of each month, the owner or operator shall record the following information in a written (or electronic) log for the previous month of operation: the amount of hours each fuel was fired; the quantity of each fuel fired; the calculated average heat input of each fuel fired in MMBtu per hour, based on the lower heating value; and, the average sulfur content of each fuel. In addition, the owner or operator shall record the hours of oil firing for the previous 12 months of operation. The Monthly Operations Summary shall be maintained on site in a legible format available for inspection or printed at the Department's request.

[Rule 62-4.160(15), F.A.C.; and, PSD-FL-140A]

Test Methods & Procedures

B.19. Combustion Turbine Testing Capacity. Testing of emissions shall be conducted with the CT operating at permitted capacity. Permitted capacity is defined as 90-100 percent of the maximum heat input rate allowed by the permit, corrected for the average ambient air temperature during the test (with 100 percent represented by a curve depicting heat input vs. ambient temperature). If it is impracticable to test at permitted capacity, the source may be tested at less than permitted capacity. However, subsequent operation is limited by adjusting the entire heat input vs. ambient temperature curve downward by an increment equal to the difference between the maximum permitted heat input (corrected for ambient temperature) and 110 percent of the value reached during the test until a new test is conducted. Once the unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purposes of additional compliance testing to regain the authority to operate at the permitted capacity. Emissions performance tests shall meet all applicable requirements of Chapters 62-204 and 62-297, F.A.C.

[Rules 62-4.070(3) and 62-297.310(2), F.A.C.; and, PSD-FL-140A]

B.20. Calculation of Emission Rate. The indicated emission rate or concentration shall be the arithmetic average of the emission rate or concentration determined by each of the three separate test runs unless otherwise specified in a particular test method or applicable rule.

[Rule 62-297.310(3), F.A.C.]

B.21. Applicable Test Procedures.

(a) **Required Sampling Time.**

1. Unless otherwise specified in the applicable rule, the required sampling time for each test run shall be no less than one hour and no greater than four hours, and the sampling time at each sampling point shall be of equal intervals of at least two minutes.

[Rule 62-297.310(4)(a)1., F.A.C.]

2. The minimum observation period for a visible emissions compliance test shall be sixty (60) minutes. The observation period shall include the period during which the highest opacity can reasonably be expected to occur.

[Rule 62-297.310(4)(a)2., F.A.C.]

(b) **Minimum Sample Volume.** Unless otherwise specified in the applicable rule or test method, the minimum sample volume per run shall be 25 dry standard cubic feet.

[Rule 62-297.310(4)(b), F.A.C.]

(d) **Calibration of Sampling Equipment.** Calibration of the sampling train equipment shall be conducted in accordance with the schedule shown in Table 297.310-1, F.A.C.

[Rules 62-297.310(4)(a), (b) & (d), F.A.C.]

B.22. Determination of Process Variables.

(a) Required Equipment. The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.

[Rule 62-297.310(5)(a), F.A.C.]

(b) Accuracy of Equipment. Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value.

[Rule 62-297.310(5)(b), F.A.C.]

B.23. Sampling Facilities. The permittee shall design the CT stack to accommodate adequate testing and sampling locations in order to determine compliance with the applicable emission limits specified by this permit. Permanent stack sampling facilities shall be installed in accordance with Rule 62-297.310(6), F.A.C.

[Rules 62-204.800 and 62-297.310(6), F.A.C.; and, 40 CFR 60.8(e)]

B.24. Required Number of Test Runs. For mass emission limitations, a compliance test shall consist of three complete and separate determinations of the total air pollutant emission rate through the test section of the stack or duct and three complete and separate determinations of any applicable process variables corresponding to the three distinct time periods during which the stack emission rate was measured provided, however, that three complete and separate determinations shall not be required if the process variables are not subject to variation during a compliance test, or if three determinations are not necessary in order to calculate the unit's emission rate. The three required test runs shall be completed within one consecutive five day period. In the event that a sample is lost or one of the three runs must be discontinued because of circumstances beyond the control of the owner or operator, and a valid third run cannot be obtained within the five day period allowed for the test, the Secretary or his or her designee may accept the results of the two complete runs as proof of compliance, provided that the arithmetic mean of the results of the two complete runs is at least 20 percent below the allowable emission limiting standards.

[Rule 62-297.310(1), F.A.C.]

B.25. Test Notification. The permittee shall notify the Compliance Authority in writing at least 30 days prior to initial performance test and at least 15 days prior to any other required tests.

[Rule 62-297.310(7)(a)9., F.A.C.; 40 CFR 60.7; and, 40 CFR 60.8]

B.26. Annual Performance Tests. Annual performance tests for CO, NO_x, and visible emissions from the CT shall be conducted while firing natural gas if low sulfur distillate oil was used for 400 hours or less in the preceding 12-month period. Annual performance tests shall be conducted for CO, NO_x, and visible emissions from the CT while firing low sulfur distillate oil if the distillate oil was used for more than 400 hours in the preceding 12-month period. Tests required on an annual basis shall be conducted at least once during each federal fiscal year (October 1st to September 30th). When conducted at permitted capacity, the annual NO_x continuous monitor RATA required pursuant to 40 CFR 75 may be substituted for the annual compliance stack test.

[Rule 62-297.310(7)(a)4., F.A.C.]

B.27. Tests Prior to Permit Renewal. During the federal fiscal year (October 1st to September 30th) prior to renewing the air operation permit, the permittee shall also conduct individual performance tests for VOC emissions while firing natural gas and low sulfur distillate oil.

[Rule 62-297.310(7)(a)3., F.A.C.]

B.28. Tests After Substantial Modifications. All performance tests required for initial startup shall also be conducted after any substantial modification and appropriate shake-down period of air pollution control equipment including the replacement of dry low-NO_x combustors. Shakedown periods shall not exceed 100 days after re-starting the CT.

[Rule 62-297.310(7)(a)4., F.A.C.]

B.29. VE Tests After Shutdown. Any combustion turbine that does not operate for more than 400 hours per year shall conduct a visible emissions (VE) compliance test once per each five-year period, coinciding with the term of its air operation permit.

[Rule 62-297.310(7)(a)8., F.A.C.]

B.30. Special Compliance Tests. When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it may require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department.

[Rule 62-297.310(7)(b), F.A.C.; and, SIP approved]

B.31. Waiver of Compliance Test Requirements. If the owner or operator of an emissions unit that is subject to a compliance test requirement demonstrates to the Department, pursuant to the procedure established in Rule 62-297.620, F.A.C., that the compliance of the emissions unit with an applicable weight emission limiting standard can be adequately determined by means other than the designated test procedure, such as specifying a surrogate standard of no visible emissions for particulate matter sources equipped with a bag house or specifying a fuel analysis for sulfur dioxide emissions, the Department shall waive the compliance test requirements for such emissions units and order that the alternate means of determining compliance be used, provided, however, the provisions of Rule 62-297.310(7)(b), F.A.C., shall apply.

[Rule 62-297.310(7)(c), F.A.C.]

B.32. Performance Test Methods. Compliance tests shall be performed in accordance with the following reference methods as described in 40 CFR 60, Appendix A, and adopted by reference in Chapter 62-204.800, F.A.C.

(a) EPA Method 7E, "Determination of Nitrogen Oxide Emissions from Stationary Sources". This method may be used to determine compliance with the annual 3-hour NO_x limit.

(b) EPA Method 9, "Visual Determination of the Opacity of Emissions from Stationary Sources" for VE.

(c) EPA Method 10, "Determination of Carbon Monoxide Emissions from Stationary Sources" for CO. All CO tests shall be conducted concurrently with NO_x emissions tests.

(d) EPA Method 20, "Determination of Oxides of Nitrogen Oxide, Sulfur Dioxide and Diluent Emissions from Stationary Gas Turbines." This test shall be used to determine compliance for the initial performance tests and may be used to determine compliance with the annual 3-hour NO_x limit.

(e) EPA Methods 18, 25 and/or 25A, "Determination of Volatile Organic Concentrations."

No other test methods may be used for compliance testing unless prior DEP approval is received, in writing, from the DEP Emissions Monitoring Section Administrator in accordance with an alternate sampling procedure pursuant to Rule 62-297.620, F.A.C.
[Rule 62-297.310(7)(a)(4), F.A.C.; and, PSD-FL-140A]

Excess Emissions

B.33. Excess Emissions.

(a) **Excess Emissions Allowed.** Excess emissions resulting from startup, shutdown, or malfunction of the CT shall be permitted provided that best operational practices are adhered to and the duration of excess emissions shall be minimized. Excess emissions resulting from startup to simple cycle mode shall not exceed one (1) hour. In no case shall excess emissions from startup, shutdown, and malfunction exceed two hours in any 24-hour period. If excess emissions occur due to malfunction, the owner or operator shall notify the Compliance Authority within one (1) working day of: the nature, extent, and duration of the excess emissions; the cause of the excess emissions; and, the actions taken to correct the problem.

[Rule 62-210.700, F.A.C.; and, PSD-FL-140A]

(b) **Excess Emissions Prohibited.** Excess emissions caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure that may reasonably be prevented during startup, shutdown or malfunction, shall be prohibited. These emissions shall be included in the calculation of the 24-hour NO_x averages for compliance determinations.

[PSD-FL-140A]

Common Conditions

B.34. These emissions units are also subject to specific conditions **C.1.** through **C.19.**, contained in **Subsection C. Common Conditions.**

Miscellaneous

B.35. Modification. No emissions unit shall be constructed or modified without obtaining an air construction permit from the Department. Such permit shall be obtained prior to beginning construction or modification.

[Rules 62-210.300(1) & (1)(a); and, PSD-FL-140A]

B.36. New or Additional Conditions. For good cause shown and after notice and an administrative hearing, if requested, the Department may require the permittee to conform to new or additional conditions. The Department shall allow the permittee a reasonable time to conform to the new or additional conditions, and on application of the permittee, the Department may grant additional time.

[Rule 62-4.080, F.A.C.; and, PSD-FL-140A]

Section III. Emissions Units and Conditions.

Subsection C. Common Conditions.

E.U. ID No.	Brief Description
001	CT-1A with an associated unfired HRSG
002	CT-1B with an associated unfired HRSG
003	CT-2A
005	CT-2B

Except as otherwise specified under Section III., Subsections A. through C., the following specific conditions apply to the emissions unit(s) listed above:

General Provisions - 40 CFR 60, Subpart A

C.1. Excess Emissions Reporting. If excess emissions occur due to malfunction, the owner or operator shall notify the Compliance Authority within one (1) working day of: the nature, extent, and duration of the excess emissions; the cause of the excess emissions; and, the actions taken to correct the problem. In addition, the Department may request a written summary report of the incident. Following the NSPS format (40 CFR 60.7, Subpart A), periods of startup, shutdown, malfunction, shall be monitored, recorded, and reported as excess emissions when emission levels exceed the standards specified in this permit. Within thirty (30) days following each calendar quarter, the permittee shall submit a report on any periods of excess emissions that occurred during the previous calendar quarter to the Compliance Authority. This quarterly report shall follow the format provided in Figure 1 (see attached) of this permit.

[Rules 62-4.130, 62-204.800 and 62-210.700(6), F.A.C.; and, 40 CFR 60.7]

C.2. Quarterly Report. The Permittee shall submit a quarterly excess emissions and monitoring systems performance report. All reports shall be postmarked by the 30th day following the end of each calendar half (or quarter, as appropriate). Written reports of excess emissions shall include the following information:

1. The magnitude of excess emissions computed in accordance with 40 CFR 60.13(h), any conversion factor(s) used, and the date and time of commencement and completion of each time period of excess emissions. The process operating time during the reporting period.
2. Specific identification of each period of excess emissions that occurs during startups, shutdowns and malfunctions of the affected facility. The nature and cause of any malfunction (if known), the corrective action taken or preventative measures adopted.
3. The date and time identifying each period during which the continuous monitoring system was inoperative except for zero and span checks and the nature of the system repairs or adjustments.
4. When no excess emissions have occurred or the continuous monitoring system(s) have not been inoperative, repaired, or adjusted, such information shall be stated in the report.

[40 CFR 60.7(c)]

C.3. Summary Report. The summary report form shall contain the information and be in the format shown in Figure 1 (attached) unless otherwise specified by the Department. One summary report form shall be submitted for each pollutant monitored.

1. If the total duration of excess emissions for the reporting period is less than one percent of the operating time for the reporting period and CMS downtime for the reporting period is less than five

percent of the total operating time for the reporting period, only the summary report form shall be submitted and the excess emission report described in 40 CFR 60.7(c) need not be submitted unless requested by the Department.

2. If the total duration of excess emissions for the reporting period is one percent or greater of the total operating time for the reporting period or the total CMS downtime for the reporting period is five percent or greater of the total operating time for the reporting period, the summary report form and the excess emission report described in 40 CFR 60.7(c) shall both be submitted.

[40 CFR 60.7(d)]

C.4. Reporting Frequency.

(1) Notwithstanding the frequency of reporting requirements specified in 40 CFR 60.7(c), an owner or operator who is required by an applicable subpart to submit excess emissions and monitoring systems performance reports (and summary reports) on a quarterly (or more frequent) basis may reduce the frequency of reporting for that standard to semiannual if the following conditions are met:

- (i) For 1 full year (e.g., 4 quarterly or 12 monthly reporting periods), the affected facility's excess emissions and monitoring systems reports submitted to comply with a standard under 40 CFR 60 continually demonstrate that the facility is in compliance with the applicable standard;
- (ii) The owner or operator continues to comply with all recordkeeping and monitoring requirements specified in 40 CFR 60, Subpart A, and the applicable standard; and,
- (iii) The Department does not object to a reduced frequency of reporting for the affected facility, as provided in 40 CFR 60.7(e)(2).

(2) The frequency of reporting of excess emissions and monitoring systems performance (and summary) reports may be reduced only after the owner or operator notifies the Department in writing of his or her intention to make such a change and the Department does not object to the intended change. In deciding whether to approve a reduced frequency of reporting, the Department may review information concerning the source's entire previous performance history during the required recordkeeping period prior to the intended change, including performance test results, monitoring data, and evaluations of an owner or operator's conformance with operation and maintenance requirements. Such information may be used by the Department to make a judgment about the source's potential for noncompliance in the future. If the Department disapproves the Permittee's request to reduce the frequency of reporting, the Department will notify the Permittee in writing within 45 days after receiving notice of the owner or operator's intention. The notification from the Department to the Permittee will specify the grounds on which the disapproval is based. In the absence of a notice of disapproval within 45 days, approval is automatically granted.

(3) As soon as monitoring data indicate that the affected facility is not in compliance with any emission limitation or operating parameter specified in the applicable standard, the frequency of reporting shall revert to the frequency specified in the applicable standard, and the Permittee shall submit an excess emissions and monitoring systems performance report (and summary report, if required) at the next appropriate reporting period following the noncomplying event. After demonstrating compliance with the applicable standard for another full year, the Permittee may again request approval from the Department to reduce the frequency of reporting for that standard as provided for in 40 CFR 60.7(e)(1) and (e)(2).

[40 CFR 60.7(e)]

C.5. Records Retention. The Permittee shall maintain a file of all measurements, including continuous monitoring system, monitoring device, and performance testing measurements; all continuous monitoring system performance evaluations; all continuous monitoring system or monitoring device calibration checks; adjustments and maintenance performed on these systems or devices; and, all other information required by 40 CFR 60 recorded in a permanent form suitable for inspection. The file shall be retained for at least 5 (five) years following the date of such measurements, maintenance, reports, and records.

[40 CFR 60.7(f); and, Rule 62-213.440(1)(b)2.b., F.A.C.]

C.6. If requested by the Department pursuant to specific conditions **A.12.** and **B.19.**, performance tests shall be conducted and data reduced in accordance with the test methods and procedures contained in 40 CFR 60, Subpart GG, unless the Department (1) specifies or approves, in specific cases, the use of a reference method with minor changes in methodology, (4) waives the requirement for performance tests because the owner or operator of a source has demonstrated by other means to the Department's satisfaction that the affected facility is in compliance with the standard, or (5) approves shorter sampling times and smaller sample volumes when necessitated by process variables or other factors. Nothing in 40 CFR 60.8 shall be construed to abrogate the Department's authority to require testing under section 114 of the Act.

[40 CFR 60.8(b)(1), (4) & (5)]

C.7. If requested by the Department pursuant to specific conditions **A.12.** and **B.19.**, performance tests shall be conducted under such conditions as the Department shall specify to the plant operator based on representative performance of the affected facility. The owner or operator shall make available to the Department such records as may be necessary to determine the conditions of the performance tests. Operations during periods of startup, shutdown, and malfunction shall not constitute representative conditions for the purpose of a performance test nor shall emissions in excess of the level of the applicable emission limit during periods of startup, shutdown, and malfunction be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard.

[40 CFR 60.8(c)]

C.8. Department Notification.

(a) The Permittee shall provide to the Department's Southwest District office at least 15 days prior notice of any compliance or performance test, except as specified under other subparts, to afford the District office the opportunity to have an observer present. Test results shall be submitted to the District office no later than 45 days after completion of the test.

[40 CFR 60.8(d); and, Rule 62-297.310(7)(a)8., F.A.C.]

(b) The Permittee shall give written notification to the Department when there is any modification to this facility. This notice shall be submitted timely and in advance of any critical date involved to allow sufficient time for review, discussion, and revision of plans, if necessary. Such notice shall include, but not be limited to, information describing the precise nature of the change; modifications to any emission control system; production capacity of the facility before and after the change; and, the anticipated completion date of the change.

[Rules 62-4.050(1) thru (7) and 62-4.070(1), F.A.C.]

Compliance with Standards and Maintenance Requirements

C.9. The Permittee shall follow the manufacturer's instructions during periods of start-up, shutdown, malfunction, or load change to ensure that the best operational practices to minimize emissions will be adhered to and the duration of any excess emissions will be minimized. The instructions shall be kept on file at the plant site and made available for inspection upon request by the Department.

[40 CFR 60.11(d)]

C.10. Credible Evidence. For the purpose of submitting compliance certifications or establishing whether or not a person has violated or is in violation of any standard in 40 CFR 60, nothing in 40 CFR 60 shall preclude the use, including the exclusive use, of any credible evidence or information, relevant to whether a source would have been in compliance with applicable requirements if the appropriate performance or compliance test or procedure had been performed.

[40 CFR 60.11(g)]

C.11. Circumvention. No owner or operator subject to the provisions of 40 CFR 60 shall build, erect, install, or use any article, machine, equipment or process, the use of which conceals an emission which would otherwise constitute a violation of an applicable standard. Such concealment includes, but is not limited to, the use of gaseous diluents to achieve compliance with an opacity standard or with a standard which is based on the concentration of a pollutant in the gases discharged to the atmosphere.
[40 CFR 60.12]

Monitoring Requirements

C.12. After receipt and consideration of written application, the Department may approve alternatives to any monitoring procedures or requirements of 40 CFR 60 including, but not limited to the following:

- (1) Alternative monitoring requirements when installation of a continuous monitoring system or monitoring device specified by 40 CFR 60 would not provide accurate measurements due to liquid water or other interferences caused by substances with the effluent gases.
- (2) Alternative monitoring requirements when the affected facility is infrequently operated.
- (3) Alternative monitoring requirements to accommodate continuous monitoring systems that require additional measurements to correct for stack moisture conditions.
- (4) Alternative locations for installing continuous monitoring systems or monitoring devices when the owner or operator can demonstrate that installation at alternate locations will enable accurate and representative measurements.
- (5) Alternative methods of converting pollutant concentration measurements to units of the standards.
- (6) Alternative procedures for performing daily checks of zero and span drift that do not involve use of span gases or test cells.
- (7) Alternatives to the ASTM test methods or sampling procedures specified by any subpart.
- (8) Alternative continuous monitoring systems that do not meet the design or performance requirements in Performance Specification 1, 40 CFR 60, Appendix B, but adequately demonstrate a definite and consistent relationship between its measurements and the measurements of opacity by a system complying with the requirements in Performance Specification 1. The Department may require that such demonstration be performed for each affected facility.
- (9) Alternative monitoring requirements when the effluent from a single affected facility or the combined effluent from two or more affected facilities are released to the atmosphere through more than one point.

[40 CFR 60.13(i)]

Modifications

C.13. The addition of an affected facility to a stationary source as an expansion to that source or as a replacement for an existing facility shall not by itself bring within the applicability of 40 CFR 60 any other facility within that source.

[40 CFR 60.14(c)]

C.14. Special provisions set forth under an applicable subpart of 40 CFR 60 shall supersede any conflicting provisions of this section.

[40 CFR 60.14(f)]

Additional Reporting and Recordkeeping Requirements

C.15. Annual Operating Report. The permittee shall submit the Annual Operating Report for Air Pollutant Emitting Facility (DEP Form No. 62-210.900(5)) that summarizes the actual operating rates and emissions from this facility. Annual operating reports shall be submitted to the Department's Southwest District's Compliance Authority by March 1st of each year.

[Rule 62-210.370(3), F.A.C.]

C.16. Emissions Performance Test Reports.

(a) The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Department's Southwest District on the results of each such test.

(b) The required test report shall be filed with the Department's Southwest District as soon as practical but no later than 45 days after the last sampling run of each test is completed.

(c) The test report shall provide sufficient detail on the emissions unit tested and the test procedures used to allow the Department's Southwest District to determine if the test was properly conducted and the test results properly computed. As a minimum, the test report, other than for an EPA or DEP Method 9 test, shall provide the following information:

1. The type, location, and designation of the emissions unit tested.
2. The facility at which the emissions unit is located.
3. The owner or operator of the emissions unit.
4. The normal type and amount of fuels used and materials processed, and the types and amounts of fuels used and material processed during each test run.
5. The means, raw data and computations used to determine the amount of fuels used and materials processed, if necessary to determine compliance with an applicable emission limiting standard.
6. The type of air pollution control devices installed on the emissions unit, their general condition, their normal operating parameters (pressure drops, total operating current and GPM scrubber water), and their operating parameters during each test run.
7. A sketch of the duct within 8 stack diameters upstream and 2 stack diameters downstream of the sampling ports, including the distance to any upstream and downstream bends or other flow disturbances.
8. The date, starting time and duration of each sampling run.
9. The test procedures used, including any alternative procedures authorized pursuant to Rule 62-297.620, F.A.C. Where optional procedures are authorized in this chapter, indicate which option was used.
10. The number of points sampled and configuration and location of the sampling plane.
11. For each sampling point for each run, the dry gas meter reading, velocity head, pressure drop across the stack, temperatures, average meter temperatures and sample time per point.
12. The type, manufacturer and configuration of the sampling equipment used.
13. Data related to the required calibration of the test equipment.

14. Data on the identification, processing and weights of all filters used.
15. Data on the types and amounts of any chemical solutions used.
16. Data on the amount of pollutant collected from each sampling probe, the filters, and the impingers, are reported separately for the compliance test.
17. The names of individuals who furnished the process variable data, conducted the test, analyzed the samples and prepared the report.
18. All measured and calculated data required to be determined by each applicable test procedure for each run.
19. The detailed calculations for one run that relate the collected data to the calculated emission rate.
20. The applicable emission standard, and the resulting maximum allowable emission rate for the emissions unit, plus the test result in the same form and unit of measure.
21. A certification that, to the knowledge of the owner or his authorized agent, all data submitted are true and correct. When a compliance test is conducted for the Department or its agent, the person who conducts the test shall provide the certification with respect to the test procedures used. The owner or his authorized agent shall certify that all data required and provided to the person conducting the test are true and correct to his knowledge.

[Rule 62-297.310(8), F.A.C.]

Excess Emissions

{Permitting Note: The Excess Emissions Rule at Rule 62-210.700, F.A.C., cannot vary any requirement of an NSPS, NESHAP, or Acid Rain program provision.}

C.17. Excess emissions from the CTs resulting from start-up, shutdown, malfunction, or load change shall be acceptable providing (1) best operational practices to minimize emissions are adhered to and (2) the duration of excess emissions shall be minimized, but in no case exceed two hours in any 24-hour period unless specifically authorized by the Department for a longer duration.

[Rule 62-210.700(1), F.A.C.]

C.18. Reserved. See specific condition **B.33.(b)**.

C.19. Excess Emissions Defined. For the purpose of reports required under 40 CFR 60.7(c) (see specific conditions **C.1.** through **C.4.**), periods of excess emissions that shall be reported are defined as follows:

- a. *Nitrogen oxides.* For CT-1A, CT-1B and CT-2A, any one-hour period during which the average water-to-fuel ratio, as measured by the continuous monitoring system, falls below the water-to-fuel ratio determined to demonstrate compliance with 40 CFR 60.332 by the performance test required in 40 CFR 60.8 or any period during which the fuel-bound nitrogen of the fuel is greater than the maximum nitrogen content allowed by the fuel-bound nitrogen allowance used during the performance test required in 40 CFR 60.8. Each report shall include the average water-to-fuel ratio, average fuel consumption, ambient conditions, gas turbine load, and nitrogen content of the fuel during the period of excess emissions, and the graphs or figures developed under 40 CFR 60.335(a).

For CT-2B, NO_x CEMS data will be used in accordance with specific conditions **B.17.(a)** and **(b)**.

b. *Sulfur dioxide*. Any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8 percent, by weight.
[40 CFR 60.334(je)(1) & (2)]

40 CFR 60, Subpart GG

C.20. These emissions units are also subject to all of the applicable requirements of 40 CFR 60, Subpart GG – Standards of Performance for Stationary Gas Turbines. (See attached Appendix GG, Standards of Performance for Stationary Gas Turbines.)
[40 CFR 60, Subpart GG; and, Rule 62-213.440, F.A.C.]

Section IV. This section is the Acid Rain Part.

Operated by: Hardee Power Partners

ORIS Code: 50949

Subsection A. This subsection addresses Acid Rain, Phase II.

The emissions unit listed below is regulated under Acid Rain, Phase II.

E.U. ID No.	Brief Description
005	Combustion Turbine-2B

A.1. The Phase II permit application submitted for this facility, as approved by the Department, is a part of this permit. The owners and operators of this Phase II acid rain unit must comply with the standard requirements and special provisions set forth in the application listed below:

a. DEP Form No. 62-210.900(1)(a), dated/signed 12/22/03.

[Chapter 62-213 and Rule 62-214.320, F.A.C.]

A.2. Sulfur dioxide (SO₂) allowance allocations and nitrogen oxide (NO_x) requirements for each Acid Rain unit are as follows:

E.U. ID No.	EPA ID	Year	2005	2006	2007	2008	2009
005	2B	SO ₂ allowances, under Table 2 of 40 CFR Part 73	0*	0*	0*	0*	0*

*The number of allowances held by an Acid Rain source in a unit account may differ from the number allocated by the USEPA under Table 2 of 40 CFR 73.

A.3. Emission Allowances. Emissions from sources subject to the Federal Acid Rain Program (Title IV) shall not exceed any allowances that the source lawfully holds under the Federal Acid Rain Program. Allowances shall not be used to demonstrate compliance with a non-Title IV applicable requirement of the Act.

1. No permit revision shall be required for increases in emissions that are authorized by allowances acquired pursuant to the Federal Acid Rain Program, provided that such increases do not require a permit revision pursuant to Rule 62-213.400(3), F.A.C.

2. No limit shall be placed on the number of allowances held by the source under the Federal Acid Rain Program.

3. Allowances shall be accounted for under the Federal Acid Rain Program.

[Rule 62-213.440(1)(c), F.A.C.]

A.4. Fast-Track Revisions of Acid Rain Parts. Those Acid Rain sources making a change described at Rule 62-214.370(4), F.A.C., may request such change as provided in Rule 62-213.413, F.A.C., Fast-Track Revisions of Acid Rain Parts.

[Rules 62-213.413 and 62-214.370(4), F.A.C.]

A.5. Comments, notes, and justifications: None.

A.6. Where an applicable requirement of the Act is more stringent than an applicable requirement of regulations promulgated under Title IV of the Act, both provisions shall be incorporated into the permit and shall be enforceable by the Administrator.

[40 CFR 70.6(a)(1)(ii); and, Rule 62-210.200, Definitions - Applicable Requirements, F.A.C.]

Appendix GG-Standards of Performance for Stationary Gas Turbines

§ 60.330 Applicability and designation of affected facility.

(a) The provisions of this subpart are applicable to the following affected facilities: All stationary gas turbines with a heat input at peak load equal to or greater than 10.7 gigajoules (10 million Btu) per hour, based on the lower heating value of the fuel fired.

(b) Any facility under paragraph (a) of this section which commences construction, modification, or reconstruction after October 3, 1977, is subject to the requirements of this part except as provided in paragraphs (e) and (j) of § 60.332.

§ 60.331 Definitions.

As used in this subpart, all terms not defined herein shall have the meaning given them in the Act and in subpart A of this part.

(a) *Stationary gas turbine* means any simple cycle gas turbine, regenerative cycle gas turbine or any gas turbine portion of a combined cycle steam/electric generating system that is not self propelled. It may, however, be mounted on a vehicle for portability.

(b) *Simple cycle gas turbine* means any stationary gas turbine which does not recover heat from the gas turbine exhaust gases to preheat the inlet combustion air to the gas turbine, or which does not recover heat from the gas turbine exhaust gases to heat water or generate steam.

(c) *Regenerative cycle gas turbine* means any stationary gas turbine which recovers heat from the gas turbine exhaust gases to preheat the inlet combustion air to the gas turbine.

(d) *Combined cycle gas turbine* means any stationary gas turbine which recovers heat from the gas turbine exhaust gases to heat water or generate steam.

(e) *Emergency gas turbine* means any stationary gas turbine which operates as a mechanical or electrical power source only when the primary power source for a facility has been rendered inoperable by an emergency situation.

(f) *Ice fog* means an atmospheric suspension of highly reflective ice crystals.

(g) *ISO standard day conditions* means 288 degrees Kelvin, 60 percent relative humidity and 101.3 kilopascals pressure.

(h) *Efficiency* means the gas turbine manufacturer's rated heat rate at peak load in terms of heat input per unit of power output based on the lower heating value of the fuel.

(i) *Peak load* means 100 percent of the manufacturer's design capacity of the gas turbine at ISO standard day conditions.

(j) *Base load* means the load level at which a gas turbine is normally operated.

- (k) *Fire-fighting turbine* means any stationary gas turbine that is used solely to pump water for extinguishing fires.
- (l) *Turbines employed in oil/gas production or oil/gas transportation* means any stationary gas turbine used to provide power to extract crude oil/natural gas from the earth or to move crude oil/natural gas, or products refined from these substances through pipelines.
- (m) A *Metropolitan Statistical Area* or *MSA* as defined by the Department of Commerce.
- (n) *Offshore platform gas turbines* means any stationary gas turbine located on a platform in an ocean.
- (o) *Garrison facility* means any permanent military installation.
- (p) *Gas turbine model* means a group of gas turbines having the same nominal air flow, combustor inlet pressure, combustor inlet temperature, firing temperature, turbine inlet temperature and turbine inlet pressure.
- (q) *Electric utility stationary gas turbine* means any stationary gas turbine constructed for the purpose of supplying more than one-third of its potential electric output capacity to any utility power distribution system for sale.
- (r) *Emergency fuel* is a fuel fired by a gas turbine only during circumstances, such as natural gas supply curtailment or breakdown of delivery system, that make it impossible to fire natural gas in the gas turbine.
- (s) *Unit operating hour* means a clock hour during which any fuel is combusted in the affected unit. If the unit combusts fuel for the entire clock hour, it is considered to be a full unit operating hour. If the unit combusts fuel for only part of the clock hour, it is considered to be a partial unit operating hour.
- (t) *Excess emissions* means a specified averaging period over which either:
- (1) The NO_x emissions are higher than the applicable emission limit in Sec. 60.332;
 - (2) The total sulfur content of the fuel being combusted in the affected facility exceeds the limit specified in Sec. 60.333; or
 - (3) The recorded value of a particular monitored parameter is outside the acceptable range specified in the parameter monitoring plan for the affected unit.
- (u) *Natural gas* means a naturally occurring fluid mixture of hydrocarbons (e.g., methane, ethane, or propane) produced in geological formations beneath the Earth's surface that maintains a gaseous state at standard atmospheric temperature and pressure under ordinary conditions. Natural gas contains 20.0 grains or less of total sulfur per 100 standard cubic feet. Equivalents of this in other units are as follows: 0.068 weight percent total sulfur, 680 parts per million by weight (ppmw) total sulfur, and 338 parts per million by volume (ppmv) at 20 degrees Celsius total sulfur. Additionally, natural gas must either be composed of at least 70 percent methane by volume or have a gross calorific value between 950 and 1100 British thermal units (Btu) per standard cubic foot. Natural gas does not include the following gaseous fuels: landfill gas, digester gas, refinery gas, sour gas, blast furnace gas, coal-derived gas, producer gas, coke oven gas, or any gaseous fuel produced in a process which might result in highly variable sulfur content or heating value.

(v) Duct burner means a device that combusts fuel and that is placed in the exhaust duct from another source, such as a stationary gas turbine, internal combustion engine, kiln, etc., to allow the firing of additional fuel to heat the exhaust gases before the exhaust gases enter a heat recovery steam generating unit.

(w) Lean premix stationary combustion turbine means any stationary combustion turbine where the air and fuel are thoroughly mixed to form a lean mixture for combustion in the combustor. Mixing may occur before or in the combustion chamber. A unit which is capable of operating in both lean premix and diffusion flame modes is considered a lean premix stationary combustion turbine when it is in the lean premix mode, and it is considered a diffusion flame stationary combustion turbine when it is in the diffusion flame mode.

(x) Diffusion flame stationary combustion turbine means any stationary combustion turbine where fuel and air are injected at the combustor and are mixed only by diffusion prior to ignition. A unit which is capable of operating in both lean premix and diffusion flame modes is considered a lean premix stationary combustion turbine when it is in the lean premix mode, and it is considered a diffusion flame stationary combustion turbine when it is in the diffusion flame mode.

(y) Unit operating day means a 24-hour period between 12:00 midnight and the following midnight during which any fuel is combusted at any time in the unit. It is not necessary for fuel to be combusted continuously for the entire 24-hour period.

§ 60.332 Standard for nitrogen oxides.

(a) On and after the date on which the performance test required by § 60.8 is completed, every owner or operator subject to the provisions of this subpart as specified in paragraphs (b), (c), and (d) of this section shall comply with one of the following, except as provided in paragraphs (e), (f), (g), (h), (i), (j), (k), and (l) of this section.

(1) No owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any stationary gas turbine, any gases which contain nitrogen oxides in excess of:

$$STD = 0.0075 \frac{Y}{F} F$$

where:

STD = allowable ISO corrected (if required as given in Sec. 60.335(b)(1)) NO_x emission concentration (percent by volume at 15 percent oxygen and on a dry basis),
Y = manufacturer's rated heat rate at manufacturer's rated load (kilojoules per watt hour) or, actual measured heat rate based on lower heating value of fuel as measured at actual peak load for the facility. The value of Y shall not exceed 14.4 kilojoules per watt hour, and
F = NO_x emission allowance for fuel-bound nitrogen as defined in paragraph (a)(4) of this section.

(2) No owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any stationary gas turbine, any gases which contain nitrogen oxides in excess of:

$$STD = 0.050 \frac{(14.4)}{Y} F$$

where:

STD = allowable ISO corrected (if required as given in Sec. 60.335(b)(1)) NO_x emission concentration (percent by volume at 15 percent oxygen and on a dry basis),

Y = manufacturer's rated heat rate at manufacturer's rated peak load (kilojoules per watt hour), or actual measured heat rate based on lower heating value of fuel as measured at actual peak load for the facility. The value of Y shall not exceed 14.4 kilojoules per watt hour, and

F = NO_x emission allowance for fuel-bound nitrogen as defined in paragraph (a)(4) of this section.

(3) The use of F in paragraphs (a)(1) and (2) of this section is optional. That is, the owner or operator may choose to apply a NO_x allowance for fuel-bound nitrogen and determine the appropriate F-value in accordance with paragraph (a)(4) of this section or may accept an F-value of zero.

(4) If the owner or operator elects to apply a NO_x emission allowance for fuel-bound nitrogen, F shall be defined according to the nitrogen content of the fuel during the most recent performance test required under Sec. 60.8 as follows:

Fuel-bound nitrogen (% by weight)	F (NO _x % by volume)
N ≤ 0.015.....	0
0.015 < N ≤ 0.1.....	0.04(N)
0.1 < N ≤ 0.25.....	0.004 + 0.0067(N - 0.1)
N > 0.25.....	0.005

Where:

N = the nitrogen content of the fuel (percent by weight).or:

Manufacturers may develop and submit to EPA custom fuel-bound nitrogen allowances for each gas turbine model they manufacture. These fuel-bound nitrogen allowances shall be substantiated with data and must be approved for use by the Administrator before the initial performance test required by Sec. 60.8. Notices of approval of custom fuel-bound nitrogen allowances will be published in the Federal Register.

(b) Electric utility stationary gas turbines with a heat input at peak load greater than 107.2 gigajoules per hour (100 million Btu/hour) based on the lower heating value of the fuel fired shall comply with the provisions of paragraph (a)(1) of this section.

(c) Stationary gas turbines with a heat input at peak load equal to or greater than 10.7 gigajoules per hour (10 million Btu/hour) but less than or equal to 107.2 gigajoules per hour (100 million Btu/hour) based on the lower heating value of the fuel fired, shall comply with the provisions of paragraph (a)(2) of this section.

(d) Stationary gas turbines with a manufacturer's rated base load at ISO conditions of 30 megawatts or less except as provided in § 60.332(b) shall comply with paragraph (a)(2) of this section.

(e) Stationary gas turbines with a heat input at peak load equal to or greater than 10.7 gigajoules per hour (10 million Btu/hour) but less than or equal to 107.2 gigajoules per hour (100 million Btu/hour) based on the lower heating value of the fuel fired and that have commenced construction prior to October 3, 1982 are exempt from paragraph (a) of this section.

(f) Stationary gas turbines using water or steam injection for control of NO_x emissions are exempt from paragraph (a) when ice fog is deemed a traffic hazard by the owner or operator of the gas turbine.

(g) Emergency gas turbines, military gas turbines for use in other than a garrison facility, military gas turbines installed for use as military training facilities, and fire fighting gas turbines are exempt from paragraph (a) of this section.

(h) Stationary gas turbines engaged by manufacturers in research and development of equipment for both gas turbine emission control techniques and gas turbine efficiency improvements are exempt from paragraph (a) on a case-by-case basis as determined by the Administrator.

(i) Exemptions from the requirements of paragraph (a) of this section will be granted on a case-by-case basis as determined by the Administrator in specific geographical areas where mandatory water restrictions are required by governmental agencies because of drought conditions. These exemptions will be allowed only while the mandatory water restrictions are in effect.

(j) Stationary gas turbines with a heat input at peak load greater than 107.2 gigajoules per hour that commenced construction, modification, or reconstruction between the dates of October 3, 1977, and January 27, 1982, and were required in the September 10, 1979, Federal Register (44 FR 52792) to comply with paragraph (a)(1) of this section, except electric utility stationary gas turbines, are exempt from paragraph (a) of this section.

(k) Stationary gas turbines with a heat input greater than or equal to 10.7 gigajoules per hour (10 million Btu/hour) when fired with natural gas are exempt from paragraph (a)(2) of this section when being fired with an emergency fuel.

(l) Regenerative cycle gas turbines with a heat input less than or equal to 107.2 gigajoules per hour (100 million Btu/hour) are exempt from paragraph (a) of this section.

§ 60.333 Standard for sulfur dioxide.

On and after the date on which the performance test required to be conducted by § 60.8 is completed, every owner or operator subject to the provision of this subpart shall comply with one or the other of the following conditions:

(a) No owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any stationary gas turbine any gases which contain sulfur dioxide in excess of 0.015 percent by volume at 15 percent oxygen and on a dry basis.

(b) No owner or operator subject to the provisions of this subpart shall burn in any stationary gas turbine any fuel which contains total sulfur in excess of 0.8 percent by weight (8000 ppmw).

§ 60.334 Monitoring of operations.

(a) Except as provided in paragraph (b) of this section, the owner or operator of any stationary gas turbine subject to the provisions of this subpart and using water or steam injection to control NO_x emissions shall install, calibrate, maintain and operate a continuous monitoring system to monitor and record the fuel consumption and the ratio of water or steam to fuel being fired in the turbine.

(b) The owner or operator of any stationary gas turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and which uses water or steam injection to control NO_x emissions may, as an alternative to operating the continuous monitoring system described in paragraph (a) of this section, install, certify, maintain, operate, and quality-assure a continuous emission monitoring system (CEMS) consisting of NO_x and O₂ monitors. As an alternative, a CO₂ monitor may be used to adjust the measured NO_x concentrations to 15 percent O₂ by either converting the CO₂ hourly averages to equivalent O₂ concentrations using Equation F-14a or F-14b in appendix F to part 75 of this chapter and making the adjustments to 15 percent O₂, or by using the CO₂ readings directly to make the adjustments, as described in Method 20. If the option to use a CEMS is chosen, the CEMS shall be installed, certified, maintained and operated as follows:

(1) Each CEMS must be installed and certified according to PS 2 and 3 (for diluent) of 40 CFR part 60, appendix B, except the 7-day calibration drift is based on unit operating days, not calendar days. Appendix F, Procedure 1 is not required. The relative accuracy test audit (RATA) of the NO_x and diluent monitors may be performed individually or on a combined basis, i.e., the relative accuracy tests of the CEMS may be performed either:

(i) On a ppm basis (for NO_x) and a percent O₂ basis for oxygen; or

(ii) On a ppm at 15 percent O₂ basis; or

(iii) On a ppm basis (for NO_x) and a percent CO₂ basis (for a CO₂ monitor that uses the procedures in Method 20 to correct the NO_x data to 15 percent O₂).

(2) As specified in Sec. 60.13(e)(2), during each full unit operating hour, each monitor must complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each 15-minute quadrant of the hour, to validate the hour. For partial unit operating hours, at least one valid data point must be obtained for each quadrant of the hour in which the unit operates. For unit operating hours in which required quality assurance and maintenance activities are performed on the CEMS, a minimum of two valid data points (one in each of two quadrants) are required to validate the hour.

(3) For purposes of identifying excess emissions, CEMS data must be reduced to hourly averages as specified in Sec. 60.13(h).

(i) For each unit operating hour in which a valid hourly average, as described in paragraph (b)(2) of this section, is obtained for both NO_x and diluent, the data acquisition and handling system must calculate and record the hourly NO_x emissions in the units of the applicable NO_x emission standard under Sec. 60.332(a), i.e., percent NO_x by volume, dry basis, corrected to 15 percent O₂ and International Organization for Standardization (ISO) standard conditions (if required as given in Sec. 60.335(b)(1)). For any hour in which the hourly average O₂ concentration exceeds 19.0 percent O₂, a diluent cap value of 19.0 percent O₂ may be used in the emission calculations.

(ii) A worst case ISO correction factor may be calculated and applied using historical ambient data. For the purpose of this calculation, substitute the maximum humidity of ambient air (H_o), minimum ambient temperature (T_a), and minimum combustor inlet absolute pressure (P_o) into the ISO correction equation.

(iii) If the owner or operator has installed a NO_x CEMS to meet the requirements of part 75 of this chapter, and is continuing to meet the ongoing requirements of part 75 of this chapter, the CEMS may be used to meet the requirements of this section, except that the missing data substitution methodology provided for at 40 CFR part 75, subpart D, is not required for purposes of identifying excess emissions. Instead, periods of missing CEMS data are to be reported as monitor downtime in the excess emissions and monitoring performance report required in Sec. 60.7(c).

(c) For any turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and which does not use steam or water injection to control NO_x emissions, the owner or operator may, for purposes of determining excess emissions, use a CEMS that meets the requirements of paragraph (b) of this section. Also, if the owner or operator has previously submitted and received EPA or local permitting authority approval of a petition for an alternative procedure of continuously monitoring compliance with the applicable NO_x emission limit under Sec. 60.332, that approved procedure may continue to be used, even if it deviates from paragraph (a) of this section.

(d) The owner or operator of any new turbine constructed after July 8, 2004, and which uses water or steam injection to control NO_x emissions may elect to use either the requirements in paragraph (a) of this section for continuous water or steam to fuel ratio monitoring or may use a NO_x CEMS installed, certified, operated, maintained, and quality-assured as described in paragraph (b) of this section.

(e) The owner or operator of any new turbine that commences construction after July 8, 2004, and which does not use water or steam injection to control NO_x emissions may elect to use a NO_x CEMS installed, certified, operated, maintained, and quality-assured as described in paragraph (b) of this section. An acceptable alternative to installing a CEMS is described in paragraph (f) of this section.

(f) The owner or operator of a new turbine who elects not to install a CEMS under paragraph (e) of this section, may instead perform continuous parameter monitoring as follows:

(1) For a diffusion flame turbine without add-on selective catalytic reduction controls (SCR), the owner or operator shall define at least four parameters indicative of the unit's NO_x formation characteristics and shall monitor these parameters continuously.

(2) For any lean premix stationary combustion turbine, the owner or operator shall continuously monitor the appropriate parameters to determine whether the unit is operating in the lean premixed (low- NO_x) combustion mode.

(3) For any turbine that uses SCR to reduce NO_x emissions, the owner or operator shall continuously monitor appropriate parameters to verify the proper operation of the emission controls.

(4) For affected units that are also regulated under part 75 of this chapter, if the owner or operator elects to monitor NO_x emission rate using the methodology in appendix E to part 75 of this chapter, or the low mass emissions methodology in Sec. 75.19 of this chapter, the requirements of this paragraph (f) may be met by performing the parametric monitoring described in section 2.3 of appendix E or in Sec. 75.19(c)(1)(iv)(H) of this chapter.

(g) The steam or water to fuel ratio or other parameters that are continuously monitored as described in paragraphs (a), (d) or (f) of this section shall be monitored during the performance test required under Sec. 60.8, to establish acceptable values and ranges. The owner or operator may supplement the performance test data with engineering analyses, design specifications, manufacturer's recommendations and other relevant information to define the acceptable parametric ranges more precisely. The owner or operator shall develop and keep on-site a parameter monitoring plan which explains the procedures used to document proper operation of the NO_x emission controls. The plan shall include the parameter(s) monitored and the acceptable range(s) of the parameter(s) as well as the basis for designating the parameter(s) and acceptable range(s). Any supplemental data such as engineering analyses, design specifications, manufacturer's recommendations and other relevant information shall be included in the monitoring plan. For affected units that are also subject to part 75 of this chapter and that use the low mass emissions methodology in Sec. 75.19 of this chapter or the NO_x emission measurement methodology in appendix E to part 75, the owner or operator may meet the requirements of this paragraph by developing and keeping on-site (or at a central location for unmanned facilities) a quality-assurance plan, as described in Sec. 75.19 (e)(5) or in section 2.3 of appendix E and section 1.3.6 of appendix B to part 75 of this chapter.

(h) The owner or operator of any stationary gas turbine subject to the provisions of this subpart:

(1) Shall monitor the total sulfur content of the fuel being fired in the turbine, except as provided in paragraph (h)(3) of this section. The sulfur content of the fuel must be determined using total sulfur methods described in Sec. 60.335(b)(10). Alternatively, if the total sulfur content of the gaseous fuel during the most recent performance test was less than 0.4 weight percent (4000 ppmw), ASTM D4084-82, 94, D5504-01, D6228-98, or Gas Processors Association Standard 2377-86 (all of which are incorporated by reference-see Sec. 60.17), which measure the major sulfur compounds may be used; and

(2) Shall monitor the nitrogen content of the fuel combusted in the turbine, if the owner or operator claims an allowance for fuel bound nitrogen (i.e., if an F-value greater than zero is being or will be used by the owner or operator to calculate STD in Sec. 60.332). The nitrogen content of the fuel shall be determined using methods described in Sec. 60.335(b)(9) or an approved alternative.

(3) Notwithstanding the provisions of paragraph (h)(1) of this section, the owner or operator may elect not to monitor the total sulfur content of the gaseous fuel combusted in the turbine, if the gaseous fuel is demonstrated to meet the definition of natural gas in Sec. 60.331(u), regardless of whether an existing custom schedule approved by the administrator for subpart GG requires such monitoring. The owner or operator shall use one of the following sources of information to make the required demonstration:

(i) The gas quality characteristics in a current, valid purchase contract, tariff sheet or transportation contract for the gaseous fuel, specifying that the maximum total sulfur content of the fuel is 20.0 grains/100 scf or less; or

(ii) Representative fuel sampling data which show that the sulfur content of the gaseous fuel does not exceed 20 grains/100 scf. At a minimum, the amount of fuel sampling data specified in section 2.3.1.4 or 2.3.2.4 of appendix D to part 75 of this chapter is required.

(4) For any turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and for which a custom fuel monitoring schedule has previously been approved, the owner or operator may, without submitting a special petition to the Administrator, continue monitoring on this schedule.

(i) The frequency of determining the sulfur and nitrogen content of the fuel shall be as follows:

(1) Fuel oil. For fuel oil, use one of the total sulfur sampling options and the associated sampling frequency described in sections 2.2.3, 2.2.4.1, 2.2.4.2, and 2.2.4.3 of appendix D to part 75 of this chapter (i.e., flow proportional sampling, daily sampling, sampling from the unit's storage tank after each addition of fuel to the tank, or sampling each delivery prior to combining it with fuel oil already in the intended storage tank). If an emission allowance is being claimed for fuel-bound nitrogen, the nitrogen content of the oil shall be determined and recorded once per unit operating day.

(2) Gaseous fuel. Any applicable nitrogen content value of the gaseous fuel shall be determined and recorded once per unit operating day. For owners and operators that elect not to demonstrate sulfur content using options in paragraph (h)(3) of this section, and for which the fuel is supplied without intermediate bulk storage, the sulfur content value of the gaseous fuel shall be determined and recorded once per unit operating day.

(3) Custom schedules. Notwithstanding the requirements of paragraph (i)(2) of this section, operators or fuel vendors may develop custom schedules for determination of the total sulfur content of gaseous fuels, based on the design and operation of the affected facility and the characteristics of the fuel supply. Except as provided in paragraphs (i)(3)(i) and (i)(3)(ii) of this section, custom schedules shall be substantiated with data and shall be approved by the Administrator before they can be used to comply with the standard in Sec. 60.333.

(i) The two custom sulfur monitoring schedules set forth in paragraphs (i)(3)(i)(A) through (D) and in paragraph (i)(3)(ii) of this section are acceptable, without prior Administrative approval:

(A) The owner or operator shall obtain daily total sulfur content measurements for 30 consecutive unit operating days, using the applicable methods specified in this subpart. Based on the results of the 30 daily samples, the required frequency for subsequent monitoring of the fuel's total sulfur content shall be as specified in paragraph (i)(3)(i)(B), (C), or (D) of this section, as applicable.

(B) If none of the 30 daily measurements of the fuel's total sulfur content exceeds 0.4 weight percent (4000 ppmw), subsequent sulfur content monitoring may be performed at 12 month intervals. If any of the samples taken at 12-month intervals has a total sulfur content between 0.4 and 0.8 weight percent (4000 and 8000 ppmw), follow the procedures in paragraph (i)(3)(i)(C) of this section. If any measurement exceeds 0.8 weight percent (8000 ppmw), follow the procedures in paragraph (i)(3)(i)(D) of this section.

(C) If at least one of the 30 daily measurements of the fuel's total sulfur content is between 0.4 and 0.8 weight percent (4000 and 8000 ppmw), but none exceeds 0.8 weight percent (8000 ppmw), then:

(1) Collect and analyze a sample every 30 days for three months. If any sulfur content measurement exceeds 0.8 weight percent (8000 ppmw), follow the procedures in paragraph (i)(3)(i)(D) of this section. Otherwise, follow the procedures in paragraph (i)(3)(i)(C)(2) of this section.

(2) Begin monitoring at 6-month intervals for 12 months. If any sulfur content measurement exceeds 0.8 weight percent (8000 ppmw), follow the procedures in paragraph (i)(3)(i)(D) of this section. Otherwise, follow the procedures in paragraph (i)(3)(i)(C)(3) of this section.

(3) Begin monitoring at 12-month intervals. If any sulfur content measurement exceeds 0.8 weight percent (8000 ppmw), follow the procedures in paragraph (i)(3)(i)(D) of this section. Otherwise, continue to monitor at this frequency.

(D) If a sulfur content measurement exceeds 0.8 weight percent (8000 ppmw), immediately begin daily monitoring according to paragraph (i)(3)(i)(A) of this section. Daily monitoring shall continue until 30 consecutive daily samples, each having a sulfur

content no greater than 0.8 weight percent (8000 ppmw), are obtained. At that point, the applicable procedures of paragraph (i)(3)(i)(B) or (C) of this section shall be followed.

(ii) The owner or operator may use the data collected from the 720-hour sulfur sampling demonstration described in section 2.3.6 of appendix D to part 75 of this chapter to determine a custom sulfur sampling schedule, as follows:

(A) If the maximum fuel sulfur content obtained from the 720 hourly samples does not exceed 20 grains/100 scf (i.e., the maximum total sulfur content of natural gas as defined in Sec. 60.331(u)), no additional monitoring of the sulfur content of the gas is required, for the purposes of this subpart.

(B) If the maximum fuel sulfur content obtained from any of the 720 hourly samples exceeds 20 grains/100 scf, but none of the sulfur content values (when converted to weight percent sulfur) exceeds 0.4 weight percent (4000 ppmw), then the minimum required sampling frequency shall be one sample at 12 month intervals.

(C) If any sample result exceeds 0.4 weight percent sulfur (4000 ppmw), but none exceeds 0.8 weight percent sulfur (8000 ppmw), follow the provisions of paragraph (i)(3)(i)(C) of this section.

(D) If the sulfur content of any of the 720 hourly samples exceeds 0.8 weight percent (8000 ppmw), follow the provisions of paragraph (i)(3)(i)(D) of this section.

(j) For each affected unit required to continuously monitor parameters or emissions, or to periodically determine the fuel sulfur content or fuel nitrogen content under this subpart, the owner or operator shall submit reports of excess emissions and monitor downtime, in accordance with Sec. 60.7(c). Excess emissions shall be reported for all periods of unit operation, including startup, shutdown and malfunction. For the purpose of reports required under Sec. 60.7(c), periods of excess emissions and monitor downtime that shall be reported are defined as follows:

(1) Nitrogen oxides.

(i) For turbines using water or steam to fuel ratio monitoring:

(A) An excess emission shall be any unit operating hour for which the average steam or water to fuel ratio, as measured by the continuous monitoring system, falls below the acceptable steam or water to fuel ratio needed to demonstrate compliance with Sec. 60.332, as established during the performance test required in Sec. 60.8. Any unit operating hour in which no water or steam is injected into the turbine shall also be considered an excess emission.

(B) A period of monitor downtime shall be any unit operating hour in which water or steam is injected into the turbine, but the essential parametric data needed to determine the steam or water to fuel ratio are unavailable or invalid.

(C) Each report shall include the average steam or water to fuel ratio, average fuel consumption, ambient conditions (temperature, pressure, and humidity), gas turbine load, and (if applicable) the nitrogen content of the fuel during each excess emission. You do not have to report ambient conditions if you opt to use the worst case ISO correction factor as specified in Sec. 60.334(b)(3)(ii), or if you are not using the ISO correction equation under the provisions of Sec. 60.335(b)(1).

(ii) If the owner or operator elects to take an emission allowance for fuel bound nitrogen, then excess emissions and periods of monitor downtime are as described in paragraphs (j)(1)(ii)(A) and (B) of this section.

(A) An excess emission shall be the period of time during which the fuel-bound nitrogen (N) is greater than the value measured during the performance test required in Sec. 60.8 and used to determine the allowance. The excess emission begins on the date and hour of the sample which shows that N is greater than the performance test value, and

ends with the date and hour of a subsequent sample which shows a fuel nitrogen content less than or equal to the performance test value.

(B) A period of monitor downtime begins when a required sample is not taken by its due date. A period of monitor downtime also begins on the date and hour that a required sample is taken, if invalid results are obtained. The period of monitor downtime ends on the date and hour of the next valid sample.

(iii) For turbines using NO_x and diluent CEMS:

(A) An hour of excess emissions shall be any unit operating hour in which the 4-hour rolling average NO_x concentration exceeds the applicable emission limit in Sec. 60.332(a)(1) or (2). For the purposes of this subpart, a "4-hour rolling average NO_x concentration" is the arithmetic average of the average NO_x concentration measured by the CEMS for a given hour (corrected to 15 percent O₂ and, if required under Sec. 60.335(b)(1), to ISO standard conditions) and the three unit operating hour average NO_x concentrations immediately preceding that unit operating hour.

(B) A period of monitor downtime shall be any unit operating hour in which sufficient data are not obtained to validate the hour, for either NO_x concentration or diluent (or both).

(C) Each report shall include the ambient conditions (temperature, pressure, and humidity) at the time of the excess emission period and (if the owner or operator has claimed an emission allowance for fuel bound nitrogen) the nitrogen content of the fuel during the period of excess emissions. You do not have to report ambient conditions if you opt to use the worst case ISO correction factor as specified in Sec. 60.334(b)(3)(ii), or if you are not using the ISO correction equation under the provisions of Sec. 60.335(b)(1).

(iv) For turbines required under paragraph (f) of this section to monitor combustion parameters or parameters that document proper operation of the NO_x emission controls:

(A) An excess emission shall be a 4-hour rolling unit operating hour average in which any monitored parameter does not achieve the target value or is outside the acceptable range defined in the parameter monitoring plan for the unit.

(B) A period of monitor downtime shall be a unit operating hour in which any of the required parametric data are either not recorded or are invalid.

(2) Sulfur dioxide. If the owner or operator is required to monitor the sulfur content of the fuel under paragraph (h) of this section:

(i) For samples of gaseous fuel and for oil samples obtained using daily sampling, flow proportional sampling, or sampling from the unit's storage tank, an excess emission occurs each unit operating hour included in the period beginning on the date and hour of any sample for which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8 weight percent and ending on the date and hour that a subsequent sample is taken that demonstrates compliance with the sulfur limit.

(ii) If the option to sample each delivery of fuel oil has been selected, the owner or operator shall immediately switch to one of the other oil sampling options (i.e., daily sampling, flow proportional sampling, or sampling from the unit's storage tank) if the sulfur content of a delivery exceeds 0.8 weight percent. The owner or operator shall continue to use one of the other sampling options until all of the oil from the delivery has been combusted, and shall evaluate excess emissions according to paragraph (j)(2)(i) of this section. When all of the fuel from the delivery has been burned, the owner or operator may resume using the as-delivered sampling option.

(iii) A period of monitor downtime begins when a required sample is not taken by its due date. A period of monitor downtime also begins on the date and hour of a

required sample, if invalid results are obtained. The period of monitor downtime shall include only unit operating hours, and ends on the date and hour of the next valid sample.

(3) *Ice fog*. Each period during which an exemption provided in § 60.332(f) is in effect shall be reported in writing to the Administrator quarterly. For each period the ambient conditions existing during the period, the date and time the air pollution control system was deactivated, and the date and time the air pollution control system was reactivated shall be reported. All quarterly reports shall be postmarked by the 30th day following the end of each calendar quarter.

(4) *Emergency fuel*. Each period during which an exemption provided in § 60.332(k) is in effect shall be included in the report required in § 60.7(c). For each period, the type, reasons, and duration of the firing of the emergency fuel shall be reported.

(5) All reports required under Sec. 60.7(c) shall be postmarked by the 30th day following the end of each calendar quarter.

Sec. 60.335 Test methods and procedures.

(a) The owner or operator shall conduct the performance tests required in Sec. 60.8, using either

(1) EPA Method 20,

(2) ASTM D6522-00 (incorporated by reference, see Sec. 60.17), or

(3) EPA Method 7E and either EPA Method 3 or 3A in appendix A to this part, to determine NO_x and diluent concentration.

(4) Sampling traverse points are to be selected following Method 20 or Method 1, (non-particulate procedures) and sampled for equal time intervals. The sampling shall be performed with a traversing single-hole probe or, if feasible, with a stationary multi-hole probe that samples each of the points sequentially. Alternatively, a multi-hole probe designed and documented to sample equal volumes from each hole may be used to sample simultaneously at the required points.

(5) Notwithstanding paragraph (a)(4) of this section, the owner or operator may test at few points than are specified in Method 1 or Method 20 if the following conditions are met:

(i) You may perform a stratification test for NO_x and diluent pursuant to

(A) [Reserved]

(B) The procedures specified in section 6.5.6.1(a) through (e) appendix A to part 75 of this chapter.

(ii) Once the stratification sampling is completed, the owner or operator may use the following alternative sample point selection criteria for the performance test:

(A) If each of the individual traverse point NO_x concentrations, normalized to 15 percent O₂, is within 10 percent of the mean normalized concentration for all traverse points, then you may use 3 points (located either 16.7, 50.0, and 83.3 percent of the way across the stack or duct, or, for circular stacks or ducts greater than 2.4 meters (7.8 feet) in diameter, at 0.4, 1.2, and 2.0 meters from the wall). The 3 points shall be located along the measurement line that exhibited the highest average normalized NO_x concentration during the stratification test; or

(B) If each of the individual traverse point NO_x concentrations, normalized to 15 percent O₂, is within 5 percent of the mean normalized concentration for all traverse points, then you may sample at a single point, located at least 1 meter from the stack wall or at the stack centroid.

(6) Other acceptable alternative reference methods and procedures are given in paragraph (c) of this section.

(b) The owner or operator shall determine compliance with the applicable nitrogen oxides emission limitation in Sec. 60.332 and shall meet the performance test requirements of Sec. 60.8 as follows:

(1) For each run of the performance test, the mean nitrogen oxides emission concentration (NO_{x_0}) corrected to 15 percent O_2 shall be corrected to ISO standard conditions using the following equation. Notwithstanding this requirement, use of the ISO correction equation is optional for: Lean premix stationary combustion turbines; units used in association with heat recovery steam generators (HRSG) equipped with duct burners; and units equipped with add-on emission control devices:

$$\text{NO}_x = (\text{NO}_{x_0})(P_r/P_o)^{0.5} e^{19(H_o - 0.00633)} (288[\text{deg}]\text{K}/T_a)^{1.53}$$

Where:

NO_x = emission concentration of NO_x at 15 percent O_2 and ISO standard ambient conditions, ppm by volume, dry basis,

NO_{x_0} = mean observed NO_x concentration, ppm by volume, dry basis, at 15 percent O_2 ,

P_r = reference combustor inlet absolute pressure at 101.3 kilopascals ambient pressure, mm Hg,

P_o = observed combustor inlet absolute pressure at test, mm Hg,

H_o = observed humidity of ambient air, g $\text{H}_2\text{O}/\text{g}$ air,

e = transcendental constant, 2.718, and

T_a = ambient temperature, [deg]K.

(2) The 3-run performance test required by Sec. 60.8 must be performed within 5 percent at 30, 50, 75, and 90-to-100 percent of peak load or at four evenly-spaced load points in the normal operating range of the gas turbine, including the minimum point in the operating range and 90-to-100 percent of peak load, or at the highest achievable load point if 90-to-100 percent of peak load cannot be physically achieved in practice. If the turbine combusts both oil and gas as primary or backup fuels, separate performance testing is required for each fuel. Notwithstanding these requirements, performance testing is not required for any emergency fuel (as defined in Sec. 60.331).

(3) For a combined cycle turbine system with supplemental heat (duct burner), the owner or operator may elect to measure the turbine NO_x emissions after the duct burner rather than directly after the turbine. If the owner or operator elects to use this alternative sampling location, the applicable NO_x emission limit in Sec. 60.332 for the combustion turbine must still be met.

(4) If water or steam injection is used to control NO_x with no additional post-combustion NO_x control and the owner or operator chooses to monitor the steam or water to fuel ratio in accordance with Sec. 60.334(a), then that monitoring system must be operated concurrently with each EPA Method 20, ASTM D6522-00 (incorporated by reference, see Sec. 60.17), or EPA Method 7E run and shall be used to determine the fuel consumption and the steam or water to fuel ratio necessary to comply with the applicable Sec. 60.332 NO_x emission limit.

(5) If the owner operator elects to claim an emission allowance for fuel bound nitrogen as described in Sec. 60.332, then concurrently with each reference method run, a representative sample of the fuel used shall be collected and analyzed, following the applicable procedures described in Sec. 60.335(b)(9). These data shall be used to determine the maximum fuel nitrogen content for which the established water (or steam) to fuel ratio will be valid.

(6) If the owner or operator elects to install a CEMS, the performance evaluation of the CEMS may either be conducted separately (as described in paragraph (b)(7) of this section) or as part of the initial performance test of the affected unit.

(7) If the owner or operator elects to install and certify a NO_x CEMS under Sec. 60.334(e), then the initial performance test required under Sec. 60.8 may be done in the following alternative manner:

(i) Perform a minimum of 9 reference method runs, with a minimum time per run of 21 minutes, at a single load level, between 90 and 100 percent of peak (or the highest physically achievable) load.

(ii) Use the test data both to demonstrate compliance with the applicable NO_x emission limit under Sec. 60.332 and to provide the required reference method data for the RATA of the CEMS described under Sec. 60.334(b).

(iii) The requirement to test at three additional load levels is waived.

(8) If the owner or operator is required under Sec. 60.334(f) to monitor combustion parameters or parameters indicative of proper operation of NO_x emission controls, the appropriate parameters shall be continuously monitored and recorded during each run of the initial performance test, to establish acceptable operating ranges, for purposes of the parameter monitoring plan for the affected unit, as specified in Sec. 60.334(g).

(9) To determine the fuel bound nitrogen content of fuel being fired (if an emission allowance is claimed for fuel bound nitrogen), the owner or operator may use equipment and procedures meeting the requirements of:

(i) For liquid fuels, ASTM D2597-94 (Reapproved 1999), D6366-99, D4629-02, D5762-02 (all of which are incorporated by reference, see Sec. 60.17); or

(ii) For gaseous fuels, shall use analytical methods and procedures that are accurate to within 5 percent of the instrument range and are approved by the Administrator.

(10) If the owner or operator is required under Sec. 60.334(i)(1) or (3) to periodically determine the sulfur content of the fuel combusted in the turbine, a minimum of three fuel samples shall be collected during the performance test. Analyze the samples for the total sulfur content of the fuel using:

(i) For liquid fuels, ASTM D129-00, D2622-98, D4294-02, D1266-98, D5453-00 or D1552-01 (all of which are incorporated by reference, see Sec. 60.17); or

(ii) For gaseous fuels, ASTM D1072-80, 90 (Reapproved 1994); D3246-81, 92, 96; D4468-85 (Reapproved 2000); or D6667-01 (all of which are incorporated by reference, see Sec. 60.17). The applicable ranges of some ASTM methods mentioned above are not adequate to measure the levels of sulfur in some fuel gases. Dilution of samples before analysis (with verification of the dilution ratio) may be used, subject to the prior approval of the Administrator.

(11) The fuel analyses required under paragraphs (b)(9) and (b)(10) of this section may be performed by the owner or operator, a service contractor retained by the owner or operator, the fuel vendor, or any other qualified agency.

(c) The owner or operator may use the following as alternatives to the reference methods and procedures specified in this section:

(1) Instead of using the equation in paragraph (b)(1) of this section, manufacturers may develop ambient condition correction factors to adjust the nitrogen oxides emission level measured by the performance test as provided in Sec. 60.8 to ISO standard day conditions.

APPENDIX TV-6, TITLE V CONDITIONS (version dated 06/23/06)

[Note: This attachment includes "canned conditions" developed from the "Title V Core List."]

{Permitting note: APPENDIX TV-6, TITLE V CONDITIONS, is distributed to the permittee only. Other persons requesting copies of these conditions shall be provided one copy when requested or otherwise appropriate.}

Chapter 62-4, F.A.C.

1. **Not federally enforceable. General Prohibition.** Any stationary installation which will reasonably be expected to be a source of pollution shall not be operated, maintained, constructed, expanded, or modified without the appropriate and valid permits issued by the Department, unless the source is exempted by Department rule. The Department may issue a permit only after it receives reasonable assurance that the installation will not cause pollution in violation of any of the provisions of Chapter 403, F.S., or the rules promulgated thereunder. A permitted installation may only be operated, maintained, constructed, expanded or modified in a manner that is consistent with the terms of the permit.

[Rule 62-4.030, Florida Administrative Code (F.A.C.); and, Section 403.087, Florida Statute (F.S.)]

2. **Not federally enforceable. Procedures to Obtain Permits and Other Authorizations: Applications.**

(1) Any person desiring to obtain a permit from the Department shall apply on forms prescribed by the Department and shall submit such additional information as the Department by law may require.

(2) All applications and supporting documents shall be filed in quadruplicate with the Department.

(3) To ensure protection of public health, safety, and welfare, any construction, modification, or operation of an installation which may be a source of pollution, shall be in accordance with sound professional engineering practices pursuant to Chapter 471, F.S. All applications for a Department permit shall be certified by a professional engineer registered in the State of Florida except, when the application is for renewal of an air pollution operation permit at a non-Title V source as defined in Rule 62-210.200, F.A.C., or where professional engineering is not required by Chapter 471, F.S. Where required by Chapter 471 or 492, F.S., applicable portions of permit applications and supporting documents which are submitted to the Department for public record shall be signed and sealed by the professional(s) who prepared or approved them.

(4) Processing fees for air construction permits shall be in accordance with Rule 62-4.050(4), F.A.C.

(5)(a) To be considered by the Department, each application must be accompanied by the proper processing fee. The fee shall be paid by check, payable to the Department of Environmental Protection. The fee is non-refundable except as provided in Section 120.60, F.S., and in this section.

(b) When an application is received without the required fee, the Department shall acknowledge receipt of the application and shall immediately notify the applicant by certified mail that the required fee was not received and advise the applicant of the correct fee. The Department shall take no further action until the correct fee is received. If a fee was received by the Department which is less than the amount required, the Department shall return the fee along with the written notification.

(c) Upon receipt of the proper application fee, the permit processing time requirements of Sections 120.60(2) and 403.0876, F.S., shall begin.

(d) If the applicant does not submit the required fee within ten days of receipt of written notification, the Department shall either return the unprocessed application or arrange with the applicant for the pick up of the application.

(e) If an applicant submits an application fee in excess of the required fee, the permit processing time requirements of Sections 120.60(2) and 403.0876, F.S., shall begin upon receipt, and the Department shall refund to the applicant the amount received in excess of the required fee.

(6) Any substantial modification to a complete application shall require an additional processing fee determined pursuant to the schedule set forth in Rule 62-4.050, F.A.C., and shall restart the time requirements of Sections 120.60 and 403.0876, F.S. For purposes of this subsection, the term "substantial modification" shall mean a modification which is reasonably expected to lead to substantially different environmental impacts which require a detailed review.

(7) Modifications to existing permits proposed by the permittee which require substantial changes in the existing permit or require substantial evaluation by the Department of potential impacts of the proposed modifications shall require the same fee as a new application for the same time duration except for modification under Chapter 62-45, F.A.C.

[Rule 62-4.050, F.A.C.]

APPENDIX TV-6, TITLE V CONDITIONS (version dated 06/23/06) (continued)

3. Standards for Issuing or Denying Permits. Except as provided at Rule 62-213.460, F.A.C., the issuance of a permit does not relieve any person from complying with the requirements of Chapter 403, F.S., or Department rules.
[Rule 62-4.070(7), F.A.C.]

4. Modification of Permit Conditions.

(1) For good cause and after notice and an administrative hearing, if requested, the Department may require the permittee to conform to new or additional conditions. The Department shall allow the permittee a reasonable time to conform to the new or additional conditions and on application of the permittee the Department may grant additional time. For the purpose of this section, good cause shall include, but not be limited to, any of the following: (also, see Condition No. 38.)

(a) A showing that an improvement in effluent or emission quality or quantity can be accomplished because of technological advances without unreasonable hardship.

(b) A showing that a higher degree of treatment is necessary to effect the intent and purpose of Chapter 403, F.S.

(c) A showing of any change in the environment or surrounding conditions that requires a modification to conform to applicable air or water quality standards.

(e) Adoption or revision of Florida Statutes, rules, or standards which require the modification of a permit condition for compliance.

(2) A permittee may request a modification of a permit by applying to the Department.

(3) A permittee may request that a permit be extended as a modification of the permit. Such a request must be submitted to the Department in writing before the expiration of the permit. Upon timely submittal of a request for extension, unless the permit automatically expires by statute or rule, the permit will remain in effect until final agency action is taken on the request. For construction permits, an extension shall be granted if the applicant can demonstrate reasonable assurances that, upon completion, the extended permit will comply with the standards and conditions required by applicable regulation. For all other permits, an extension shall be granted if the applicant can demonstrate reasonable assurances that the extended permit will comply with the standards and conditions applicable to the original permit. A permit for which the permit application fee was prorated in accordance with Rule 62-4.050(4)(v), F.A.C., shall not be extended. In no event shall a permit be extended or remain in effect longer than the time limits established by statute or rule.

[Rule 62-4.080, F.A.C.]

5. Renewals. Prior to 180 days before the expiration of a permit issued pursuant to Chapter 62-213, F.A.C., the permittee shall apply for a renewal of a permit using forms incorporated by reference in the specific rule chapter for that kind of permit. A renewal application shall be timely and sufficient. If the application is submitted prior to 180 days before expiration of the permit, it will be considered timely and sufficient. If the renewal application is submitted at a later date, it will not be considered timely and sufficient unless it is submitted and made complete prior to the expiration of the operation permit. When the application for renewal is timely and sufficient, the existing permit shall remain in effect until the renewal application has been finally acted upon by the Department or, if there is court review of the Department's final agency action, until a later date is required by Section 120.60, F.S., provided that, for renewal of a permit issued pursuant to Chapter 62-213, F.A.C., the applicant complies with the requirements of Rules 62-213.420(1)(b)3. and 4., F.A.C.

[Rule 62-4.090, F.A.C.]

6. Suspension and Revocation.

(1) Permits shall be effective until suspended, revoked, surrendered, or expired and shall be subject to the provisions of Chapter 403, F.S., and rules of the Department.

(2) Failure to comply with pollution control laws and rules shall be grounds for suspension or revocation.

(3) A permit issued pursuant to Chapter 62-4, F.A.C., shall not become a vested property right in the permittee. The Department may revoke any permit issued by it if it finds that the permit holder or his agent:

(a) Submitted false or inaccurate information in his application or operational reports.

(b) Has violated law, Department orders, rules or permit conditions.

(c) Has failed to submit operational reports or other information required by Department rules.

(d) Has refused lawful inspection under Section 403.091, F.S.

(4) No revocation shall become effective except after notice is served by personal services, certified mail, or newspaper notice pursuant to Section 120.60(7), F.S., upon the person or persons named therein and a hearing held if requested within the time specified in the notice. The notice shall specify the provision of the law, or rule alleged to be violated, or the permit condition or Department order alleged to be violated, and the facts alleged to constitute a violation thereof.

[Rule 62-4.100, F.A.C.]

APPENDIX TV-6, TITLE V CONDITIONS (version dated 06/23/06) (continued)

7. **Not federally enforceable. Financial Responsibility.** The Department may require an applicant to submit proof of financial responsibility and may require the applicant to post an appropriate bond to guarantee compliance with the law and Department rules. [Rule 62-4.110, F.A.C.]

8. **Transfer of Permits.**

(1) Within 30 days after the sale or legal transfer of a permitted facility, an "Application for Transfer of Permit" (DEP Form 62-1.201(1)) must be submitted to the Department. This form must be completed with the notarized signatures of both the permittee and the proposed new permittee. For air permits, an "Application for Transfer of Air Permit" (DEP Form 62-210.900(7)) shall be submitted.

(2) The Department shall approve the transfer of a permit unless it determines that the proposed new permittee cannot provide reasonable assurances that conditions of the permit will be met. The determination shall be limited solely to the ability of the new permittee to comply with the conditions of the existing permit, and it shall not concern the adequacy of these permit conditions. If the Department proposes to deny the transfer, it shall provide both the permittee and the proposed new permittee a written objection to such transfer together with notice of a right to request a Chapter 120, F.S., proceeding on such determination.

(3) Within 30 days of receiving a properly completed Application for Transfer of Permit form, the Department shall issue a final determination. The Department may toll the time for making a determination on the transfer by notifying both the permittee and the proposed new permittee that additional information is required to adequately review the transfer request. Such notification shall be served within 30 days of receipt of an Application for Transfer of Permit form, completed pursuant to Rule 62-4.120(1), F.A.C. If the Department fails to take action to approve or deny the transfer within 30 days of receipt of the completed Application for Transfer of Permit form, or within 30 days of receipt of the last item of timely requested additional information, the transfer shall be deemed approved.

(4) The permittee is encouraged to apply for a permit transfer prior to the sale or legal transfer of a permitted facility. However, the transfer shall not be effective prior to the sale or legal transfer.

(5) Until this transfer is approved by the Department, the permittee and any other person constructing, operating, or maintaining the permitted facility shall be liable for compliance with the terms of the permit. The permittee transferring the permit shall remain liable for corrective actions that may be required as a result of any violations occurring prior to the sale or legal transfer of the facility.

[Rule 62-4.120, F.A.C.]

9. **Plant Operation-Problems.** If the permittee is temporarily unable to comply with any of the conditions of the permit due to breakdown of equipment or destruction by hazard of fire, wind or by other cause, the permittee shall immediately notify the Department. Notification shall include pertinent information as to the cause of the problem, and what steps are being taken to correct the problem and to prevent its recurrence, and where applicable, the owner's intent toward reconstruction of destroyed facilities. Such notification does not release the permittee from any liability for failure to comply with Department rules. (also, see Condition No. 10.)

[Rule 62-4.130, F.A.C.]

10. For purposes of notification to the Department pursuant to Condition No. 9., Condition No. 12.(8), and Rule 62-4.130, F.A.C., Plant Operation-Problems, "immediately" shall mean the same day, if during a workday (i.e., 8:00 a.m. - 5:00 p.m.), or the first business day after the incident, excluding weekends and holidays; and, for purposes of 40 CFR 70.6(a)(3)(iii)(B), "prompt" shall have the same meaning as "immediately". [also, see Conditions Nos. 9. and 12.(8).]

[40 CFR 70.6(a)(3)(iii)(B)]

11. **Not federally enforceable. Review.** Failure to request a hearing within 14 days of receipt of notice of proposed or final agency action on a permit application or as otherwise required in Chapter 62-103, F.A.C., shall be deemed a waiver of the right to an administrative hearing.

[Rule 62-4.150, F.A.C.]

12. **Permit Conditions.** All permits issued by the Department shall include the following general conditions:

(1) The terms, conditions, requirements, limitations and restrictions set forth in this permit, are "permit conditions" and are binding and enforceable pursuant to Sections 403.141, 403.727, or 403.859 through 403.861, F.S. The permittee is placed on notice that the Department will review this permit periodically and may initiate enforcement action for any violation of these conditions.

APPENDIX TV-6, TITLE V CONDITIONS (version dated 06/23/06) (continued)

- (2) This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviation from the approved drawings, exhibits, specifications, or conditions of this permit may constitute grounds for revocation and enforcement action by the Department.
- (3) As provided in Subsections 403.987(6) and 403.722(5), F.S., the issuance of this permit does not convey any vested rights or any exclusive privileges. Neither does it authorize any injury to public or private property or any invasion of personal rights, nor any infringement of federal, state, or local laws or regulations. This permit is not a waiver of or approval of any other Department permit that may be required for other aspects of the total project which are not addressed in this permit.
- (4) This permit conveys no title to land or water, does not constitute State recognition or acknowledgment of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the State. Only the Trustees of the Internal Improvement Trust Fund may express State opinion as to title.
- (5) This permit does not relieve the permittee from liability for harm or injury to human health or welfare, animal, or plant life, or property caused by the construction or operation of this permitted source, or from penalties therefore; nor does it allow the permittee to cause pollution in contravention of F.S. and Department rules, unless specifically authorized by an order from the Department.
- (6) The permittee shall properly operate and maintain the facility and systems of treatment and control (and related appurtenances) that are installed and used by the permittee to achieve compliance with the conditions of this permit, as required by Department rules. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to achieve compliance with the conditions of the permit and when required by Department rules.
- (7) The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, upon presentation of credentials or other documents as may be required by law and at reasonable times, access to the premises where the permitted activity is located or conducted to:
- (a) Have access to and copy any records that must be kept under conditions of the permit;
 - (b) Inspect the facility, equipment, practices, or operations regulated or required under this permit; and
 - (c) Sample or monitor any substances or parameters at any location reasonably necessary to assure compliance with this permit or Department rules. Reasonable time may depend on the nature of the concern being investigated.
- (8) If, for any reason, the permittee does not comply with or will be unable to comply with any condition or limitation specified in this permit, the permittee shall immediately provide the Department with the following information: **(also, see Condition No. 10.)**
- (a) A description of and cause of noncompliance; and
 - (b) The period of noncompliance, including dates and times; or, if not corrected, the anticipated time the noncompliance is expected to continue, and steps being taken to reduce, eliminate, and prevent recurrence of the noncompliance. The permittee shall be responsible for any and all damages which may result and may be subject to enforcement action by the Department for penalties or for revocation of this permit.
- (9) In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the Florida Statutes or Department rules, except where such use is prescribed by Sections 403.111 and 403.73, F.S. Such evidence shall only be used to the extent it is consistent with the Florida Rules of Civil Procedure and appropriate evidentiary rules.
- (10) The permittee agrees to comply with changes in Department rules and Florida Statutes after a reasonable time for compliance; provided, however, the permittee does not waive any other rights granted by Florida Statutes or Department rules.
- (11) This permit is transferable only upon Department approval in accordance with Rule 62-4.120, F.A.C., as applicable. The permittee shall be liable for any non-compliance of the permitted activity until the transfer is approved by the Department.
- (12) This permit or a copy thereof shall be kept at the work site of the permitted activity.
- (14) The permittee shall comply with the following:
- (a) Upon request, the permittee shall furnish all records and plans required under Department rules. During enforcement actions, the retention period for all records will be extended automatically unless otherwise stipulated by the Department.
 - (b) The permittee shall hold at the facility or other location designated by this permit records of all monitoring information (including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation) required by the permit, copies of all reports required by this permit, and records of all data used to complete the application for this permit. These materials shall be retained at least five (5) years from the date of the sample, measurement, report, or application unless otherwise specified by Department rule.
 - (c) Records of monitoring information shall include:
 - 1. The date, exact place, and time of sampling or measurements;
 - 2. The person responsible for performing the sampling or measurements;
 - 3. The dates analyses were performed;
 - 4. The person responsible for performing the analyses;

APPENDIX TV-6, TITLE V CONDITIONS (version dated 06/23/06) (continued)

5. The analytical techniques or methods used;

6. The results of such analyses.

(15) When requested by the Department, the permittee shall within a reasonable time furnish any information required by law which is needed to determine compliance with the permit. If the permittee becomes aware the relevant facts were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be corrected promptly.

[Rules 62-4.160 and 62-213.440(1)(b), F.A.C.]

13. Construction Permits.

(1) No person shall construct any installation or facility which will reasonably be expected to be a source of air ~~or water~~ pollution without first applying for and receiving a construction permit from the Department unless exempted by statute or Department rule. In addition to the requirements of Chapter 62-4, F.A.C., applicants for a Department Construction Permit shall submit the following as applicable:

(a) A completed application on forms furnished by the Department.

(b) An engineering report covering:

1. Plant description and operations,
2. Types and quantities of all waste material to be generated whether liquid, gaseous or solid,
3. Proposed waste control facilities,
4. The treatment objectives,
5. The design criteria on which the control facilities are based, and
6. Other information deemed relevant.

Design criteria submitted pursuant to Rule 62-4.210(1)(b)5., F.A.C., shall be based on the results of laboratory and pilot-plant scale studies whenever such studies are warranted. The design efficiencies of the proposed waste treatment facilities and the quantities and types of pollutants in the treated effluents or emissions shall be indicated. Work of this nature shall be subject to the requirements of Chapter 471, F.S. Where confidential records are involved, certain information may be kept confidential pursuant to Section 403.111, F.S.

(c) The owners' written guarantee to meet the design criteria as accepted by the Department and to abide by Chapter 403, F.S., and the rules of the Department as to the quantities and types of materials to be discharged from the installation. The owner may be required to post an appropriate bond or other equivalent evidence of financial responsibility to guarantee compliance with such conditions in instances where the owner's financial resources are inadequate or proposed control facilities are experimental in nature.

(2) The construction permit may contain conditions and an expiration date as determined by the Secretary or the Secretary's designee.

(3) When the Department issues a permit to construct, the permittee shall be allowed a period of time, specified in the permit, to construct, and to operate and test to determine compliance with Chapter 403, F.S., and the rules of the Department and, where applicable, to apply for and receive an operation permit. The Department may require tests and evaluations of the treatment facilities by the permittee at his/her expense.

[Rule 62-4.210, F.A.C.]

14. **Not federally enforceable.** Operation Permit for New Sources. To properly apply for an operation permit for new sources the applicant shall submit the appropriate fee and certification that construction was completed, noting any deviations from the conditions in the construction permit and test results where appropriate.

[Rule 62-4.220, F.A.C.]

Chapters 28-106 and 62-110, F.A.C.

15. Public Notice, Public Participation, and Proposed Agency Action. The permittee shall comply with all of the requirements for public notice, public participation, and proposed agency action pursuant to Rules 62-110.106 and 62-210.350, F.A.C.

[Rules 62-110.106, 62-210.350 and 62-213.430(1)(b), F.A.C.]

16. Administrative Hearing. The permittee shall comply with all of the requirements for a petition for administrative hearing or waiver of right to administrative proceeding pursuant to Rules 28-106.201, 28-106.301 and 62-110.106, F.A.C.

[Rules 28-106.201, 28-106.301 and 62-110.106, F.A.C.]

APPENDIX TV-6, TITLE V CONDITIONS (version dated 06/23/06) (continued)

Chapter 62-204, F.A.C.

17. **Asbestos.** This permit does not authorize any demolition or renovation of the facility or its parts or components which involves asbestos removal. This permit does not constitute a waiver of any of the requirements of Chapter 62-257, F.A.C., and 40 CFR 61, Subpart M, National Emission Standard for Asbestos, adopted and incorporated by reference in Rule 62-204.800, F.A.C.

Compliance with Chapter 62-257, F.A.C., and 40 CFR 61, Subpart M, Section 61.145, is required for any asbestos demolition or renovation at the source.

[40 CFR 61; Rule 62-204.800, F.A.C.; and, Chapter 62-257, F.A.C.]

Chapter 62-210, F.A.C.

18. **Permits Required.** Unless exempted from permitting pursuant to Rule 62-210.300(3)(a) or (b), F.A.C., or Rule 62-4.040, F.A.C., or unless specifically authorized by provision of Rule 62-210.300(4), F.A.C., or Rule 62-213.300, F.A.C., the owner or operator of any facility or emissions unit which emits or can reasonably be expected to emit any air pollutant shall obtain an appropriate permit from the Department prior to beginning construction, reconstruction pursuant to 40 CFR 60.15 or 63.2, modification, or the addition of pollution control equipment; or to authorize initial or continued operation of the emissions unit; or to establish a PAL or Air Emissions Bubble. All emissions limitations, controls, and other requirements imposed by such permits shall be at least as stringent as any applicable limitations and requirements contained in or enforceable under the State Implementation Plan (SIP) or that are otherwise federally enforceable. Except as provided at Rule 62-213.460, F.A.C., issuance of a permit does not relieve the owner or operator of a facility or an emissions unit from complying with any applicable requirements, any emission limiting standards or other requirements of the air pollution rules of the Department or any other such requirements under federal, state, or local law.

(1) Air Construction Permits.

(a) Unless exempt from permitting pursuant to Rule 62-210.300(3)(a) or (b), F.A.C., or Rule 62-4.040, F.A.C., an air construction permit shall be obtained by the owner or operator of any proposed new, reconstructed, or modified facility or emissions unit, or any new pollution control equipment prior to the beginning of construction, reconstruction pursuant to 40 CFR 60.15 or 63.2, or modification of the facility or emissions unit or addition of the pollution control equipment; or to establish a PAL; in accordance with all applicable provisions of Chapter 62-210, F.A.C., Chapter 62-212, F.A.C., and Chapter 62-4, F.A.C. Except as provided under Rule 62-213.415, F.A.C., the owner or operator of any facility seeking to create or change an air emissions bubble shall obtain an air construction permit in accordance with all the applicable provisions of Chapter 62-210, F.A.C., Chapters 62-212 and 62-4, F.A.C. The construction permit shall be issued for a period of time sufficient to allow construction, reconstruction or modification of the facility or emissions unit or addition of the air pollution control equipment; and operation while the owner or operator of the new, reconstructed or modified facility or emissions unit or the new pollution control equipment is conducting tests or otherwise demonstrating initial compliance with the conditions of the construction permit.

(b) Notwithstanding the expiration of an air construction permit, all limitations and requirements of such permit that are applicable to the design and operation of the permitted facility or emissions unit shall remain in effect until the facility or emissions unit is permanently shut down, except for any such limitation or requirement that is obsolete by its nature (such as a requirement for initial compliance testing) or any such limitation or requirement that is changed in accordance with the provisions of Rule 62-210.300(1)(b)1., F.A.C. Either the applicant or the Department can propose that certain conditions be considered obsolete. Any conditions or language in an air construction permit that are included for informational purposes only, if they are transferred to the air operation permit, shall be transferred for informational purposes only and shall not become enforceable conditions unless voluntarily agreed to by the permittee or otherwise required under Department rules.

1. Except for those limitations or requirements that are obsolete, all limitations and requirements of an air construction permit shall be included and identified in any air operation permit for the facility or emissions unit. The limitations and requirements included in the air operation permit can be changed, and thereby superseded, through the issuance of an air construction permit, federally enforceable state air operation permit, federally enforceable air general permit, or Title V air operation permit; provided, however, that:

a. Any change that would constitute an administrative correction may be made pursuant to Rule 62-210.360, F.A.C.;

b. Any change that would constitute a modification, as defined at Rule 62-210.200, F.A.C., shall be accomplished only through the issuance of an air construction permit; and

c. Any change in a permit limitation or requirement that originates from a permit issued pursuant to 40 CFR 52.21, Rule 62-204.800(11)(d)2., F.A.C., Rule 62-212.400, F.A.C., Rule 62-212.500, F.A.C., or any former codification of Rule 62-212.400 or Rule 62-212.500, F.A.C., shall be accomplished only through the issuance of a new or revised air construction permit under Rule 62-204.800(11)(d)2., Rule 62-212.400 or Rule 62-212.500, F.A.C., as appropriate.

2. The force and effect of any change in a permit limitation or requirement made in accordance with the provisions of Rule 62-210.300(1)(b)1., F.A.C., shall be the same as if such change were made to the original air construction permit.

3. Nothing in Rule 62-210.300(1)(b), F.A.C., shall be construed as to allow operation of a facility or emissions unit without a valid air operation permit.

APPENDIX TV-6, TITLE V CONDITIONS (version dated 06/23/06) (continued)

(2) **Air Operation Permits.** Upon expiration of the air operation permit for any existing facility or emissions unit, subsequent to construction or modification, or subsequent to the creation of or change to a bubble, and demonstration of compliance with the conditions of the construction permit for any new or modified facility or emissions unit, any air emissions bubble, or as otherwise provided in Chapter 62-210, F.A.C., or Chapter 62-213, F.A.C., the owner or operator of such facility or emissions unit shall obtain a renewal air operation permit, an initial air operation permit or air general permit, or an administrative correction or revision of an existing air operation permit, whichever is appropriate, in accordance with all applicable provisions of Chapter 62-210, F.A.C., Chapter 62-213, F.A.C., and Chapter 62-4, F.A.C.

(a) **Minimum Requirements for All Air Operation Permits.** At a minimum, a permit issued pursuant to this subsection shall:

1. Specify the manner, nature, volume and frequency of the emissions permitted, and the applicable emission limiting standards or performance standards, if any;
2. Require proper operation and maintenance of any pollution control equipment by qualified personnel, where applicable in accordance with the provisions of any operation and maintenance plan required by the air pollution rules of the Department.
3. Contain an effective date stated in the permit which shall not be earlier than the date final action is taken on the application and be issued for a period, beginning on the effective date, as provided below.

a. The operation permit for an emissions unit which is in compliance with all applicable rules and in operational condition, and which the owner or operator intends to continue operating, shall be issued or renewed for a five-year period, except that, for Title V sources subject to Rule 62-213.420(1)(a)1., F.A.C., operation permits shall be extended until 60 days after the due date for submittal of the facility's Title V permit application as specified in Rule 62-213.420(1)(a)1., F.A.C.

b. Except as provided in Rule 62-210.300(2)(a)3.d., F.A.C., the operation permit for an emissions unit which has been shut down for six months or more prior to the expiration date of the current operation permit, shall be renewed for a period not to exceed five years from the date of shutdown, even if the emissions unit is not maintained in operational condition, provided:

- (i) the owner or operator of the emissions unit demonstrates to the Department that the emissions unit may need to be reactivated and used, or that it is the owner's or operator's intent to apply to the Department for a permit to construct a new emissions unit at the facility before the end of the extension period; and
- (ii) the owner or operator of the emissions unit agrees to and is legally prohibited from providing the allowable emission permitted by the renewed permit as an emissions offset to any other person under Rule 62-212.500, F.A.C.; and
- (iii) the emissions unit was operating in compliance with all applicable rules as of the time the source was shut down.

c. Except as provided in Rule 62-210.300(2)(a)3.d., F.A.C., the operation permit for an emissions unit which has been shut down for five years or more prior to the expiration date of the current operation permit shall be renewed for a maximum period not to exceed ten years from the date of shutdown, even if the emissions unit is not maintained in operational condition, provided the conditions given in Rule 62-210.300(2)(a)3.b., F.A.C., are met and the owner or operator demonstrates to the Department that failure to renew the permit would constitute a hardship, which may include economic hardship.

d. The operation permit for an electric utility generating unit on cold standby or long-term reserve shutdown shall be renewed for a five-year period, and additional five-year periods, even if the unit is not maintained in operational condition, provided the conditions given in Rules 62-210.300(2)(a)3.b.(i) through (iii), F.A.C., are met.

4. In the case of an emissions unit permitted pursuant to Rules 62-210.300(2)(a)3.b., c., and d., F.A.C., include reasonable notification and compliance testing requirements for reactivation of such emissions unit and provide that the owner or operator demonstrate to the Department prior to reactivation that such reactivation would not constitute reconstruction pursuant to Rule 62-204.800(8), F.A.C.

[Rules 62-210.300(1) & (2), F.A.C.]

19. **Not federally enforceable. Notification of Startup.** The owners or operator of any emissions unit or facility which has a valid air operation permit which has been shut down more than one year, shall notify the Department in writing of the intent to start up such emissions unit or facility, a minimum of 60 days prior to the intended startup date.

- (a) The notification shall include information as to the startup date, anticipated emission rates or pollutants released, changes to processes or control devices which will result in changes to emission rates, and any other conditions which may differ from the valid outstanding operation permit.

APPENDIX TV-6, TITLE V CONDITIONS (version dated 06/23/06) (continued)

(b) If, due to an emergency, a startup date is not known 60 days prior thereto, the owner shall notify the Department as soon as possible after the date of such startup is ascertained.

[Rule 62-210.300(5), F.A.C.]

20. Emissions Unit Reclassification.

(a) Any emissions unit whose operation permit has been revoked as provided for in Chapter 62-4, F.A.C., shall be deemed permanently shut down for purposes of Rule 62-212.500, F.A.C. Any emissions unit whose permit to operate has expired without timely renewal or transfer may be deemed permanently shut down, provided, however, that no such emissions unit shall be deemed permanently shut down if, within 20 days after receipt of written notice from the Department, the emissions unit owner or operator demonstrates that the permit expiration resulted from inadvertent failure to comply with the requirements of Rule 62-4.090, F.A.C., and that the owner or operator intends to continue the emissions unit in operation, and either submits an application for an air operation permit or complies with permit transfer requirements, if applicable.

(b) If the owner or operator of an emissions unit which is so permanently shut down, applies to the Department for a permit to reactivate or operate such emissions unit, the emissions unit will be reviewed and permitted as a new emissions unit.

[Rule 62-210.300(6), F.A.C.]

21. Transfer of Air Permits.

(a) An air permit is transferable only after submission of an Application for Transfer of Air Permit (DEP Form 62-210.900(7)) and Department approval in accordance with Rule 62-4.120, F.A.C. For Title V permit transfers only, a complete application for transfer of air permit shall include the requirements of 40 CFR 70.7(d)(1)(iv), adopted and incorporated by reference at Rule 62-204.800, F.A.C. Within 30 days after approval of the transfer of permit, the Department shall update the permit by an administrative permit correction pursuant to Rule 62-210.360, F.A.C.

(b) For an air general permit, the provision of Rules 62-210.300(7)(a) and 62-4.120, F.A.C., do not apply. Thirty (30) days before using an air general permit, the new owner must submit an air general permit notification to the Department in accordance with Rule 62-210.300(4), F.A.C., or Rule 62-213.300(2)(b), F.A.C.

[Rule 62-210.300(7), F.A.C.]

22. Public Notice and Comment.

(1) Public Notice of Proposed Agency Action.

(a) A notice of proposed agency action on permit application, where the proposed agency action is to issue the permit, shall be published by any applicant for:

1. An air construction permit;
2. An air operation permit, permit renewal or permit revision subject to Rule 62-210.300(2)(b), F.A.C., (i.e., a FESOP), except as provided in Rule 62-210.300(2)(b)1.b., F.A.C.; or
3. An air operation permit, permit renewal, or permit revision subject to Chapter 62-213, F.A.C., except Title V air general permits or those permit revisions meeting the requirements of Rule 62-213.412(1), F.A.C.

(b) The notice required by Rule 62-210.350(1)(a), F.A.C., shall be published in accordance with all otherwise applicable provisions of Rule 62-110.106, F.A.C. A public notice under Rule 62-210.350(1)(a)1., F.A.C., for an air construction permit may be combined with any required public notice under Rule 62-210.350(1)(a)2. or 3., F.A.C., for air operation permits. If such notices are combined, the public notice must comply with the requirements for both notices.

(c) Except as otherwise provided at Rules 62-210.350(2), (5), and (6), F.A.C., each notice of intent to issue an air construction permit shall provide a 14-day period for submittal of public comments.

(2) Additional Public Notice Requirements for Emissions Units Subject to Prevention of Significant Deterioration or Nonattainment - Area Preconstruction Review.

(a) Before taking final agency action on a construction permit application for any proposed new or modified facility or emissions unit subject to the preconstruction review requirements of Rule 62-212.400 or 62-212.500, F.A.C., the Department shall comply with all applicable provisions of Rule 62-110.106, F.A.C., and provide an opportunity for public comment which shall include as a minimum the following:

1. A complete file available for public inspection in at least one location in the district affected which includes the information submitted by the owner or operator, exclusive of confidential records under Section 403.111, F.S., and the Department's analysis of the effect of the proposed construction or modification on ambient air quality, including the Department's preliminary determination of whether the permit should be approved or disapproved;
2. A 30-day period for submittal of public comments; and

APPENDIX TV-6, TITLE V CONDITIONS (version dated 06/23/06) (continued)

3. A notice, by advertisement in a newspaper of general circulation in the county affected, specifying the nature and location of the proposed facility or emissions unit, whether BACT or LAER has been determined, the degree of PSD increment consumption expected, if applicable, and the location of the information specified in paragraph 1. above; and notifying the public of the opportunity for submitting comments and requesting a public hearing.
- (b) The notice provided for in Rule 62-210.350(2)(a)3., F.A.C., shall be prepared by the Department and published by the applicant in accordance with all applicable provisions of Rule 62-110.106, F.A.C., except that the applicant shall cause the notice to be published no later than thirty (30) days prior to final agency action.
- (c) A copy of the notice provided for in Rule 62-210.350(2)(a)3., F.A.C., shall also be sent by the Department to the Regional Office of the U. S. Environmental Protection Agency and to all other state and local officials or agencies having cognizance over the location of such new or modified facility or emissions unit, including local air pollution control agencies, chief executives of city or county government, regional land use planning agencies, and any other state, Federal Land Manager, or Indian Governing Body whose lands may be affected by emissions from the new or modified facility or emissions unit.
- (d) A copy of the notice provided for in Rule 62-210.350(2)(a)3., F.A.C., shall be displayed in the appropriate district, branch and local program offices.
- (e) An opportunity for public hearing shall be provided in accordance with Chapter 120, F.S., and Rule 62-110.106, F.A.C.
- (f) Any public comments received shall be made available for public inspection in the location where the information specified in Rule 62-210.350(2)(a)1., F.A.C., is available and shall be considered by the Department in making a final determination to approve or deny the permit.
- (g) The final determination shall be made available for public inspection at the same location where the information specified in Rule 62-210.350(2)(a)1., F.A.C., was made available.
- (h) For a proposed new or modified emissions unit which would be located within 100 kilometers of any Federal Class I area or whose emissions may affect any Federal Class I area, and which would be subject to the preconstruction review requirements of Rule 62-212.400 or 62-212.500, F.A.C.:
1. The Department shall mail or transmit to the Administrator a copy of the initial application for an air construction permit and notice of every action related to the consideration of the permit application.
 2. The Department shall mail or transmit to the Federal Land Manager of each affected Class I area a copy of any written notice of intent to apply for an air construction permit; the initial application for an air construction permit, including all required analyses and demonstrations; any subsequently submitted information related to the application; the preliminary determination and notice of proposed agency action on the permit application; and any petition for an administrative hearing regarding the application or the Department's proposed action. Each such document shall be mailed or transmitted to the Federal Land Manager within fourteen (14) days after its receipt by the Department.
- (3) Additional Public Notice Requirements for Facilities Subject to Operation Permits for Title V Sources.
- (a) Before taking final agency action to issue a new, renewed, or revised air operation permit subject to Chapter 62-213, F.A.C., the Department shall comply with all applicable provisions of Rule 62-110.106, F.A.C., and provide an opportunity for public comment which shall include as a minimum the following:
1. A complete file available for public inspection in at least one location in the district affected which includes the information submitted by the owner or operator, exclusive of confidential records under Section 403.111, F.S.; and
 2. A 30-day period for submittal of public comments.
- (b) The notice provided for in Rule 62-210.350(3)(a), F.A.C., shall be prepared by the Department and published by the applicant in accordance with all applicable provisions of Rule 62-110.106, F.A.C., except that the applicant shall cause the notice to be published no later than thirty (30) days prior to final agency action. If written comments received during the 30-day comment period on a draft permit result in the Department's issuance of a revised draft permit in accordance with Rule 62-213.430(1), F.A.C., the Department shall require the applicant to publish another public notice in accordance with Rule 62-210.350(1)(a), F.A.C.
- (c) The notice shall identify:
1. The facility;
 2. The name and address of the office at which processing of the permit occurs;
 3. The activity or activities involved in the permit action;
 4. The emissions change involved in any permit revision;
 5. The name, address, and telephone number of a Department representative from whom interested persons may obtain additional information, including copies of the permit draft, the application, and all relevant supporting materials, including any permit application, compliance plan, permit, monitoring report, and compliance statement required pursuant to Chapter 62-213, F.A.C. (except for information entitled to confidential treatment pursuant to Section 403.111, F.S.), and all other materials available to the Department that are relevant to the permit decision;

APPENDIX TV-6, TITLE V CONDITIONS (version dated 06/23/06) (continued)

6. A brief description of the comment procedures required by Rule 62-210.350(3), F.A.C.;
7. The time and place of any hearing that may be held, including a statement of procedure to request a hearing (unless a hearing has already been scheduled); and
8. The procedures by which persons may petition the Administrator to object to the issuance of the proposed permit after expiration of the Administrator's 45-day review period.

[Rules 62-210.350(1) thru (3), F.A.C.]

23. Administrative Permit Corrections.

- (1) A facility owner shall notify the Department by letter of minor corrections to information contained in a permit. Such notifications shall include:
 - (a) Typographical errors noted in the permit;
 - (b) Name, address or phone number change from that in the permit;
 - (c) A change requiring more frequent monitoring or reporting by the permittee;
 - (d) A change in ownership or operational control of a facility, subject to the following provisions:
 1. The Department determines that no other change in the permit is necessary;
 2. The permittee and proposed new permittee have submitted an Application for Transfer of Air Permit, and the Department has approved the transfer pursuant to Rule 62-210.300(7), F.A.C.; and
 3. The new permittee has notified the Department of the effective date of sale or legal transfer.
 - (e) Changes listed at 40 CFR 72.83(a)(1), (2), (6), (9) and (10), adopted and incorporated by reference at Rule 62-204.800, F.A.C., and changes made pursuant to Rules 62-214.340(1) and (2), F.A.C., to Title V sources subject to emissions limitations or reductions pursuant to 42 USC ss. 7651-7651o;
 - (f) Changes listed at 40 CFR 72.83(a)(11) and (12), adopted and incorporated by reference at Rule 62-204.800, F.A.C., to Title V sources subject to emissions limitations or reductions pursuant to 42 USC ss. 7651-7651o, provided the notification is accompanied by a copy of any EPA determination concerning the similarity of the change to those listed at Rule 62-210.360(1)(e), F.A.C.; and
 - (g) Any other similar minor administrative change at the source.
- (2) Upon receipt of any such notification, the Department shall within 60 days correct the permit and provide a corrected copy to the owner.
- (3) After first notifying the owner, the Department shall correct any permit in which it discovers errors of the types listed at Rules 62-210.360(1)(a) and (b), F.A.C., and provide a corrected copy to the owner.
- (4) For Title V source permits, other than general permits, a copy of the corrected permit shall be provided to EPA and any approved local air program in the county where the facility or any part of the facility is located.

[Rule 62-210.360, F.A.C.]

24. Emissions Computation and Reporting.

- (1) **Applicability.** This rule sets forth required methodologies to be used by the owner or operator of a facility for computing actual emissions, baseline actual emissions, and net emissions increase, as defined at Rule 62-210.200, F.A.C., and for computing emissions for purposes of the reporting requirements of subsection 62-210.370(3) and paragraph 62-212.300(1)(e), F.A.C., or of any permit condition that requires emissions be computed in accordance with this rule. This rule is not intended to establish methodologies for determining compliance with the emission limitations of any air permit.
- (2) **Computation of Emissions.** For any of the purposes set forth in subsection 62-210.370(1), F.A.C., the owner or operator of a facility shall compute emissions in accordance with the requirements set forth in this subsection.
 - (a) **Basic Approach.** The owner or operator shall employ, on a pollutant-specific basis, the most accurate of the approaches set forth below to compute the emissions of a pollutant from an emissions unit; provided, however, that nothing in this rule shall be construed to require installation and operation of any continuous emissions monitoring system (CEMS), continuous parameter monitoring system (CPMS), or predictive emissions monitoring system (PEMS) not otherwise required by rule or permit, nor shall anything in this rule be construed to require performance of any stack testing not otherwise required by rule or permit.
 1. If the emissions unit is equipped with a CEMS meeting the requirements of paragraph 62-210.370(2)(b), F.A.C., the owner or operator shall use such CEMS to compute the emissions of the pollutant, unless the owner or operator demonstrates to the department that an alternative approach is more accurate because the CEMS represents still-emerging technology.
 2. If a CEMS is not available or does not meet the requirements of paragraph 62-210.370(2)(b), F.A.C., but emissions of the pollutant can be computed pursuant to the mass balance methodology of paragraph 62-210.370(2)(c), F.A.C., the owner or operator shall use such methodology, unless the owner or operator demonstrates to the department that an alternative approach is more accurate.
 3. If a CEMS is not available or does not meet the requirements of paragraph 62-210.370(2)(b), F.A.C., and emissions cannot be computed pursuant to the mass balance methodology, the owner or operator shall use an emission factor meeting the requirements of paragraph 62-210.370(2)(d), F.A.C., unless the owner or operator demonstrates to the department that an alternative approach is more accurate.
 - (b) **Continuous Emissions Monitoring System (CEMS).**
 1. An owner or operator may use a CEMS to compute emissions of a pollutant for purposes of this rule provided:
 - a. The CEMS complies with the applicable certification and quality assurance requirements of 40 CFR Part 60, Appendices B and F, or, for an acid rain unit, the certification and quality assurance requirements of 40 CFR Part 75, all adopted by reference at Rule 62-204.800, F.A.C.; or

APPENDIX TV-6, TITLE V CONDITIONS (version dated 06/23/06) (continued)

- b. The owner or operator demonstrates that the CEMS otherwise represents the most accurate means of computing emissions for purposes of this rule.
 2. Stack gas volumetric flow rates used with the CEMS to compute emissions shall be obtained by the most accurate of the following methods as demonstrated by the owner or operator:
 - a. A calibrated flowmeter that records data on a continuous basis, if available; or
 - b. The average flow rate of all valid stack tests conducted during a five-year period encompassing the period over which the emissions are being computed, provided all stack tests used shall represent the same operational and physical configuration of the unit.
 3. The owner or operator may use CEMS data in combination with an appropriate f-factor, heat input data, and any other necessary parameters to compute emissions if such method is demonstrated by the owner or operator to be more accurate than using a stack gas volumetric flow rate as set forth at subparagraph 62-210.370(2)(b)2., F.A.C., above.
 - (c) Mass Balance Calculations.
 1. An owner or operator may use mass balance calculations to compute emissions of a pollutant for purposes of this rule provided the owner or operator:
 - a. Demonstrates a means of validating the content of the pollutant that is contained in or created by all materials or fuels used in or at the emissions unit; and
 - b. Assumes that the emissions unit emits all of the pollutant that is contained in or created by any material or fuel used in or at the emissions unit if it cannot otherwise be accounted for in the process or in the capture and destruction of the pollutant by the unit's air pollution control equipment.
 2. Where the vendor of a raw material or fuel which is used in or at the emissions unit publishes a range of pollutant content from such material or fuel, the owner or operator shall use the highest value of the range to compute the emissions, unless the owner or operator demonstrates using site-specific data that another content within the range is more accurate.
 3. In the case of an emissions unit using coatings or solvents, the owner or operator shall document, through purchase receipts, records and sales receipts, the beginning and ending VOC inventories, the amount of VOC purchased during the computational period, and the amount of VOC disposed of in the liquid phase during such period.
 - (d) Emission Factors.
 1. An owner or operator may use an emission factor to compute emissions of a pollutant for purposes of this rule provided the emission factor is based on site-specific data such as stack test data, where available, unless the owner or operator demonstrates to the department that an alternative emission factor is more accurate. An owner or operator using site-specific data to derive an emission factor, or set of factors, shall meet the following requirements.
 - a. If stack test data are used, the emission factor shall be based on the average emissions per unit of input, output, or gas volume, whichever is appropriate, of all valid stack tests conducted during at least a five-year period encompassing the period over which the emissions are being computed, provided all stack tests used shall represent the same operational and physical configuration of the unit.
 - b. Multiple emission factors shall be used as necessary to account for variations in emission rate associated with variations in the emissions unit's operating rate or operating conditions during the period over which emissions are computed.
 - c. The owner or operator shall compute emissions by multiplying the appropriate emission factor by the appropriate input, output or gas volume value for the period over which the emissions are computed. The owner or operator shall not compute emissions by converting an emission factor to pounds per hour and then multiplying by hours of operation, unless the owner or operator demonstrates that such computation is the most accurate method available.
 2. If site-specific data are not available to derive an emission factor, the owner or operator may use a published emission factor directly applicable to the process for which emissions are computed. If no directly-applicable emission factor is available, the owner or operator may use a factor based on a similar, but different, process.
 - (e) Accounting for Emissions During Periods of Missing Data from CEMS, PEMS, or CPMS. In computing the emissions of a pollutant, the owner or operator shall account for the emissions during periods of missing data from CEMS, PEMS, or CPMS using other site-specific data to generate a reasonable estimate of such emissions.
 - (f) Accounting for Emissions During Periods of Startup and Shutdown. In computing the emissions of a pollutant, the owner or operator shall account for the emissions during periods of startup and shutdown of the emissions unit.
 - (g) Fugitive Emissions. In computing the emissions of a pollutant from a facility or emissions unit, the owner or operator shall account for the fugitive emissions of the pollutant, to the extent quantifiable, associated with such facility or emissions unit.
 - (h) Recordkeeping. The owner or operator shall retain a copy of all records used to compute emissions pursuant to this rule for a period of five years from the date on which such emissions information is submitted to the department for any regulatory purpose.
- (3) Annual Operating Report for Air Pollutant Emitting Facility.
 - (a) The Annual Operating Report for Air Pollutant Emitting Facility (DEP Form No. 62-210.900(5)) shall be completed each year.
 - (c) The annual operating report shall be submitted to the appropriate Department of Environmental Protection (DEP) division, district or DEP-approved local air pollution control program office by March 1 of the following year.
 - (d) Beginning with 2007 annual emissions, emissions shall be computed in accordance with the provisions of Rule 62-210.370(2), F.A.C., for purposes of the annual operating report.

[Rules 62-210.370(1), (2) and (3)(a), (c) & (d), F.A.C.]

APPENDIX TV-6, TITLE V CONDITIONS (version dated 06/23/06) (continued)

25. Circumvention. No person shall circumvent any air pollution control device, or allow the emission of air pollutants without the applicable air pollution control device operating properly.

[Rule 62-210.650, F.A.C.]

26. Forms and Instructions. The forms used by the Department in the stationary source control program are adopted and incorporated by reference in this section. The forms are listed by rule number, which is also the form number, with the subject, title and effective date. Copies of forms may be obtained by writing to the Department of Environmental Protection, Division of Air Resource Management, 2600 Blair Stone Road, Tallahassee, Florida 32399-2400, or by accessing the Division's website at www.dep.state.fl.us/air. The requirement of Rule 62-4.050(2), F.A.C., to file application forms in quadruplicate is waived if an air permit application is submitted using the Department's electronic application form.

(1) Application for Air Permit - Long Form, Form and Instructions (Effective 02-02-2006).

(a) Acid Rain Part, Form and Instructions (Effective 06-16-2003).

1. Repowering Extension Plan, Form and Instructions (Effective 07/01/1995).

2. New Unit Exemption, Form and Instructions (Effective 04/16/2001).

3. Retired Unit Exemption, Form and Instructions (Effective 04/16/2001).

4. Phase II NOx Compliance Plan, Form and Instructions (Effective 01/06/1998).

5. Phase II NOx Averaging Plan, Form (Effective 01/06/1998).

(b) Reserved.

(5) Annual Operating Report for Air Pollutant Emitting Facility, Form and Instructions (Effective 02/11/1999).

(7) Application for Transfer of Air Permit – Title V Source, (Effective 04/16/2001).

[Rule 62-210.900, F.A.C.]

Chapter 62-213, F.A.C.

27. Responsible Official.

(1) Each Title V source must identify a responsible official on each application for Title V permit, permit revision, and permit renewal. For sources with only one responsible official, this is how the Title V source designates the responsible official.

(2) Each Title V source may designate more than one responsible official, provided a primary responsible official is designated as responsible for the certifications of all other designated responsible officials. Any action taken by the primary responsible official shall take precedence over any action taken by any other designated responsible official.

(3) Any facility initially designating more than one responsible official or changing the list of responsible officials must submit a Responsible Official Notification Form (DEP Form No. 62-213.900(8)) designating all responsible officials for a Title V source, stating which responsible official is the primary responsible official, and providing an effective date for any changes to the list of responsible officials. Each individual listed on the Responsible Official Notification Form must meet the definition of responsible official given at Rule 62-210.200, F.A.C.

(4) A Title V source with only one responsible official shall submit DEP Form No. 62-213.900(8) for a change in responsible official.

(5) No person shall take any action as a responsible official at a Title V source unless designated a responsible official as required by this rule, except that the existing responsible official of any Title V source which has a change in responsible official during the term of the permit and before the effective date of this rule may continue to act as a responsible official until the first submittal of DEP Form No. 62-213.900(8) or the next application for Title V permit, permit revision or permit renewal, whichever comes first.

[Rules 62-213.202(1) thru (5), F.A.C.]

28. Annual Emissions Fee. Each Title V source permitted to operate in Florida must pay between January 15 and March 1 of each year, upon written notice from the Department, an annual emissions fee in an amount determined as set forth in Rule 62-213.205(1), F.A.C.

(1)(g) If the Department has not received the fee by February 15 of the year following the calendar year for which the fee is calculated, the Department will send the primary responsible official of the Title V source a written warning of the consequences for failing to pay the fee by March 1. If the fee is not postmarked by March 1 of the year due, the Department shall impose, in addition to the fee, a penalty of 50 percent of the amount of the fee unpaid plus interest on such amount computed in accordance with Section 220.807, F.S. If the Department determines that a submitted fee was inaccurately calculated, the Department shall either refund to the permittee any amount overpaid or notify the permittee of any amount underpaid. The Department shall not impose a penalty or interest on any amount underpaid, provided that the permittee has timely remitted payment of at least 90 percent of the amount determined to be due and remits full payment within 60 days after receipt of notice of the amount underpaid. The Department shall waive the collection of underpayment and shall not refund overpayment of the fee, if the amount is less than 1 percent of the fee due, up to \$50.00. The Department shall make every effort to provide a timely assessment of the adequacy of the submitted fee. Failure to

APPENDIX TV-6, TITLE V CONDITIONS (version dated 06/23/06) (continued)

pay timely any required annual emissions fee, penalty, or interest constitutes grounds for permit revocation pursuant to Rule 62-4.100, F.A.C.

(1)(i) Any documentation of actual hours of operation, actual material or heat input, actual production amount, or actual emissions used to calculate the annual emissions fee shall be retained by the owner for a minimum of five (5) years and shall be made available to the Department upon request.

(1)(j) A completed DEP Form 62-213.900(1), "Major Air Pollution Source Annual Emissions Fee Form", must be submitted by a responsible official with the annual emissions fee.

[Rules 62-213.205, (1)(g), (1)(i) & (1)(j), F.A.C.]

29. Reserved.

30. Reserved.

31. Air Operation Permit Fees. No permit application processing fee, renewal fee, modification fee or amendment fee is required for an operation permit for a Title V source.

[Rule 62-213.205(4), F.A.C.]

32. Permits and Permit Revisions Required. All Title V sources are subject to the permit requirements of Chapter 62-213, F.A.C., except those Title V sources permissible pursuant to Rule 62-213.300, F.A.C., Title V Air General Permits.

(1) No Title V source may operate except in compliance with Chapter 62-213, F.A.C.

(2) Except as provided in Rule 62-213.410, F.A.C., no source with a permit issued under the provisions of Chapter 62-213, F.A.C., shall make any changes in its operation without first applying for and receiving a permit revision if the change meets any of the following:

- (a) Constitutes a modification;
- (b) Violates any applicable requirement;
- (c) Exceeds the allowable emissions of any air pollutant from any unit within the source;
- (d) Contravenes any permit term or condition for monitoring, testing, recordkeeping, reporting or of a compliance certification requirement;
- (e) Requires a case-by-case determination of an emission limitation or other standard or a source specific determination of ambient impacts, or a visibility or increment analysis under the provisions of Chapter 62-212 or 62-296, F.A.C.;
- (f) Violates a permit term or condition which the source has assumed for which there is no corresponding underlying applicable requirement to which the source would otherwise be subject;
- (g) Results in the trading of emissions among units within a source except as specifically authorized pursuant to Rule 62-213.415, F.A.C.;
- (h) Results in the change of location of any relocatable facility identified as a Title V source pursuant to paragraph (a)-(e), (g) or (h) of the definition of "major source of air pollution" at Rule 62-210.200, F.A.C.;
- (i) Constitutes a change at an Acid Rain Source under the provisions of 40 CFR 72.81(a)(1), (2), or (3), (b)(1) or (b)(3), hereby incorporated by reference;
- (j) Constitutes a change in a repowering plan, nitrogen oxides averaging plan, or nitrogen oxides compliance deadline extension at an Acid Rain Source;

[Rules 62-213.400(1) & (2), F.A.C.]

33. Changes Without Permit Revision. Title V sources having a valid permit issued pursuant to Chapter 62-213, F.A.C., may make the following changes without permit revision, provided that sources shall maintain source logs or records to verify periods of operation:

- (1) Permitted sources may change among those alternative methods of operation;
- (2) A permitted source may implement operating changes, as defined in Rule 62-210.200, F.A.C., after the source submits any forms required by any applicable requirement and provides the Department and EPA with at least 7 days written notice prior to implementation. The source and the Department shall attach each notice to the relevant permit;
 - (a) The written notice shall include the date on which the change will occur, and a description of the change within the permitted source, the pollutants emitted and any change in emissions, and any term or condition becoming applicable or no longer applicable as a result of the change;
 - (b) The permit shield described in Rule 62-213.460, F.A.C., shall not apply to such changes;
- (3) Permitted sources may implement changes involving modes of operation only in accordance with Rule 62-213.415, F.A.C.

[Rule 62-213.410, F.A.C.]

APPENDIX TV-6, TITLE V CONDITIONS (version dated 06/23/06) (continued)

34. Immediate Implementation Pending Revision Process.

(1) Those permitted Title V sources making any change that constitutes a modification pursuant to the definition of modification at Rule 62-210.200, F.A.C., but which would not constitute a modification pursuant to 42 USC 7412(a) or to 40 CFR 52.01, 60.2, or 61.15, adopted and incorporated by reference at Rule 62-204.800, F.A.C., may implement such change prior to final issuance of a permit revision, provided the change:

- (a) Does not violate any applicable requirement;
- (b) Does not contravene any permit term or condition for monitoring, testing, recordkeeping or reporting, or any compliance certification requirement;
- (c) Does not require or change a case-by-case determination of an emission limitation or other standard, or a source-specific determination of ambient impacts, or a visibility or increment analysis under the provisions of Chapter 62-212 or 62-296, F.A.C.;
- (d) Does not seek to establish or change a permit term or condition for which there is no corresponding underlying applicable requirement and which the source has assumed to avoid an applicable requirement to which the source would otherwise be subject including any federally enforceable emissions cap or federally enforceable alternative emissions limit.

(2) A Title V source may immediately implement such changes after they have been incorporated into the terms and conditions of a new or revised construction permit issued pursuant to Chapter 62-212, F.A.C., and after the source provides to EPA, the Department, each affected state and any approved local air program having geographic jurisdiction over the source, a copy of the source's application for operation permit revision. The Title V source may conform its application for construction permit to include all information required by Rule 62-213.420, F.A.C., in lieu of submitting separate application forms.

(3) The Department shall process the application for operation permit revision in accordance with the provisions of Chapter 62-213, F.A.C., except that the Department shall issue a draft permit revision or a determination to deny the revision within 60 days of receipt of a complete application for operation permit revision or, if the Title V source has submitted a construction permit application conforming to the requirements of Rule 62-213.420, F.A.C., the Department shall issue a draft permit or a determination to deny the revision at the same time the Department issues its determination on issuance or denial of the construction permit application. The Department shall not take final action on the operation permit revision application until all the requirements of Rules 62-213.430(1)(a), (c), (d), and (e), F.A.C., have been complied with.

(4) Pending final action on the operation permit revision application, the source shall implement the changes in accordance with the terms and conditions of the source's new or revised construction permit. If any terms and conditions of the new or revised construction permit have not been complied with prior to the issuance of the draft operation permit revision, the operation permit shall include a compliance plan in accordance with the provisions of Rule 62-213.440(2), F.A.C.

(5) The permit shield described in Rule 62-213.460, F.A.C., shall not apply to such changes until after the Department takes final action to issue the operation permit revision.

(6) If the Department denies the source's application for operation permit revision, the source shall cease implementation of the proposed changes.

[Rule 62-213.412, F.A.C.]

35. Permit Applications.

(1) Duty to Apply. For each Title V source, the owner or operator shall submit a timely and complete permit application in compliance with the requirements of Rules 62-213.420, F.A.C., and Rules 62-4.050(1) through (3), F.A.C.

(a) Timely Application.

3. For purposes of permit renewal, a timely application is one that is submitted in accordance with Rule 62-4.090, F.A.C.

(b) Complete Application.

1. Any applicant for a Title V permit, permit revision or permit renewal must submit an application on DEP Form No. 62-210.900(1), which must include all the information specified by Rule 62-213.420(3), F.A.C., except that an application for permit revision must contain only that information related to the proposed change(s) from the currently effective Title V permit and any other requirements that become applicable at the time of application. The applicant shall include information concerning fugitive emissions and stack emissions in the application. Each application for permit, permit revision or permit renewal shall be certified by a responsible official in accordance with Rule 62-213.420(4), F.A.C.

2. For those applicants submitting initial permit applications pursuant to Rule 62-213.420(1)(a)1., F.A.C., a complete application shall be an application that substantially addresses all the information required by the application form number 62-210.900(1), and such applications shall be deemed complete within sixty days of receipt of a signed and certified application unless the Department notifies the applicant of incompleteness within that time. For all other applicants, the applications shall be deemed complete sixty days after receipt, unless the Department, within sixty days after receipt of a signed application for permit, permit revision or permit renewal, requests additional documentation or information needed

APPENDIX TV-6, TITLE V CONDITIONS (version dated 06/23/06) (continued)

to process the application. An applicant making timely and complete application for permit, or timely application for permit renewal as described by Rule 62-4.090(1), F.A.C., shall continue to operate the source under the authority and provisions of any existing valid permit or Florida Electrical Power Plant Siting Certification, and in accordance with applicable requirements of the Acid Rain Program, until the conclusion of proceedings associated with its permit application or until the new permit becomes effective, whichever is later, provided the applicant complies with all the provisions of Rules 62-213.420(1)(b)3. and 4., F.A.C. Failure of the Department to request additional information within sixty days of receipt of a properly signed application shall not impair the Department's ability to request additional information pursuant to Rules 62-213.420(1)(b)3. and 4., F.A.C.

3. For those permit applications submitted pursuant to the provisions of Rule 62-213.420(1)(a)1., F.A.C., the Department shall notify the applicant if the Department becomes aware at any time during processing of the application that the application contains incorrect or incomplete information. The applicant shall submit the corrected or supplementary information to the Department within ninety days unless the applicant has requested and been granted additional time to submit the information. Failure of an applicant to submit corrected or supplementary information requested by the Department within ninety days or such additional time as requested and granted shall render the application incomplete.

4. For all applications other than those addressed at Rule 62-213.420(1)(b)3., F.A.C., should the Department become aware, during processing of any application that the application contains incorrect information, or should the Department become aware, as a result of comment from an affected State, an approved local air program, EPA, or the public that additional information is needed to evaluate the application, the Department shall notify the applicant within 30 days. When an applicant becomes aware that an application contains incorrect or incomplete information, the applicant shall submit the corrected or supplementary information to the Department. If the Department notifies an applicant that corrected or supplementary information is necessary to process the permit, and requests a response, the applicant shall provide the information to the Department within ninety days of the Department request unless the applicant has requested and been granted additional time to submit the information or, the applicant shall, within ninety days, submit a written request that the Department process the application without the information. Failure of an applicant to submit corrected or supplementary information requested by the Department within ninety days, or such additional time as requested and granted, or to demand in writing within ninety days that the application be processed without the information shall render the application incomplete. Nothing in this section shall limit any other remedies available to the Department.

[Rules 62-213.420(1)(a)3. and 62-213.420(1)(b)1., 2., 3. & 4., F.A.C.]

36. Confidential Information. Whenever an applicant submits information under a claim of confidentiality pursuant to Section 403.111, F.S., the applicant shall also submit a copy of all such information and claim directly to EPA. (also, see Condition No. 50.) [Rule 62-213.420(2), F.A.C.]

37. Standard Application Form and Required Information. Applications shall be submitted under Chapter 62-213, F.A.C., on forms provided by the Department and adopted by reference in Rule 62-210.900(1), F.A.C. The information as described in Rule 62-210.900(1), F.A.C., shall be included for the Title V source and each emissions unit. An application must include information sufficient to determine all applicable requirements for the Title V source and each emissions unit and to evaluate a fee amount pursuant to Rule 62-213.205, F.A.C.

[Rule 62-213.420(3), F.A.C.]

38. a. Permit Renewal and Expiration. Permits being renewed are subject to the same requirements that apply to permit issuance at the time of application for renewal. Permit renewal applications shall contain that information identified in Rules 62-210.900(1) and 62-213.420(3), F.A.C. Unless a Title V source submits a timely application for permit renewal in accordance with the requirements of Rule 62-4.090(1), F.A.C., the existing permit shall expire and the source's right to operate shall terminate. No Title V permit will be issued for a new term except through the renewal process.

b. Permit Revision Procedures. Permit revisions shall meet all requirements of Chapter 62-213, F.A.C., including those for content of applications, public participation, review by approved local programs and affected states, and review by EPA, as they apply to permit issuance and permit renewal, except that permit revisions for those activities implemented pursuant to Rule 62-213.412, F.A.C., need not meet the requirements of Rule 62-213.430(1)(b), F.A.C. The Department shall require permit revision in accordance with the provisions of Rule 62-4.080, F.A.C., and 40 CFR 70.7(f), whenever any source becomes subject to any condition listed at 40

APPENDIX TV-6, TITLE V CONDITIONS (version dated 06/23/06) (continued)

CFR 70.7(f)(1), hereby adopted and incorporated by reference. The below requirements from 40 CFR 70.7(f) are adopted and incorporated by reference in Rule 62-213.430(4), F.A.C.:

o **40 CFR 70.7(f): Reopening for Cause.** (also, see Condition No. 4.)

(1) This section contains provisions from 40 CFR 70.7(f) that specify the conditions under which a Title V permit shall be reopened prior to the expiration of the permit. A Title V permit shall be reopened and revised under any of the following circumstances:

(i) Additional applicable requirements under the Act become applicable to a major Part 70 source with a remaining permit term of 3 or more years. Such a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which the permit is due to expire, unless the original permit or any of its terms and conditions has been extended pursuant to 40 CFR 70.4(b)(10)(i) or (ii).

(ii) Additional requirements (including excess emissions requirements) become applicable to an affected source under the acid rain program. Upon approved by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

(iii) The permitting authority or EPA determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.

(iv) The Administrator or the permitting authority determines that the permit must be revised or revoked to assure compliance with the applicable requirements.

(2) Proceedings to reopen and issue a permit shall follow the same procedures as apply to initial permit issuance and shall affect only those parts of the permit for which cause to reopen exists. Such reopening shall be made as expeditiously as practicable.

(3) Reopenings under 40 CFR 70.7(f)(1) shall not be initiated before a notice of such intent is provided to the Part 70 source by the permitting authority at least 30 days in advance of the date that the permit is to be reopened, except that the permitting authority may provide a shorter time period in the case of an emergency.

[Rules 62-213.430(3) & (4), F.A.C.; and, 40 CFR 70.7(f)]

39. Insignificant Emissions Units or Pollutant-Emitting Activities.

(a) All requests for determination of insignificant emissions units or activities made pursuant to Rule 62-213.420(3)(n), F.A.C., shall be processed in conjunction with the permit, permit renewal or permit revision application submitted pursuant to Chapter 62-213, F.A.C. Insignificant emissions units or activities shall be approved by the Department consistent with the provisions of Rule 62-4.040(1)(b), F.A.C. Emissions units or activities which are added to a Title V source after issuance of a permit under Chapter 62-213, F.A.C., shall be incorporated into the permit at its next renewal, provided such emissions units or activities have been exempted from the requirement to obtain an air construction permit and also qualify as insignificant pursuant to Rule 62-213.430(6), F.A.C.

(b) An emissions unit or activity shall be considered insignificant if all of the following criteria are met:

1. Such unit or activity would be subject to no unit-specific applicable requirement;
2. Such unit or activity, in combination with other units or activities proposed as insignificant, would not cause the facility to exceed any major source threshold(s) as defined in Rule 62-213.420(3)(c)1., F.A.C., unless it is acknowledged in the permit application that such units or activities would cause the facility to exceed such threshold(s);
3. Such unit or activity would not emit or have the potential to emit:
 - a. 500 pounds per year or more of lead and lead compounds expressed as lead;
 - b. 1,000 pounds per year or more of any hazardous air pollutant;
 - c. 2,500 pounds per year or more of total hazardous air pollutants; or
 - d. 5.0 tons per year or more of any other regulated pollutant.

[Rule 62-213.430(6), F.A.C.]

40. Permit Duration. Permits for sources subject to the Federal Acid Rain Program shall be issued for terms of five years, provided that the initial Acid Rain Part may be issued for a term less than five years where necessary to coordinate the term of such part with the term of a Title V permit to be issued to the source. Operation permits for Title V sources may not be extended as provided in Rule 62-4.080(3), F.A.C., if such extension will result in a permit term greater than five years.

[Rule 62-213.440(1)(a), F.A.C.]

41. Monitoring Information. All records of monitoring information shall specify the date, place, and time of sampling or measurement and the operating conditions at the time of sampling or measurement, the date(s) analyses were performed, the company or entity that performed the analyses, the analytical techniques or methods used, and the results of such analyses.

[Rule 62-213.440(1)(b)2.a., F.A.C.]

APPENDIX TV-6, TITLE V CONDITIONS (version dated 06/23/06) (continued)

42. Retention of Records. Retention of records of all monitoring data and support information shall be for a period of at least 5 years from the date of the monitoring sample, measurement, report, or application. Support information includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.

[Rule 62-213.440(1)(b)2.b., F.A.C.]

43. Monitoring Reports. The permittee shall submit reports of any required monitoring at least every six (6) months. All instances of deviations from permit requirements must be clearly identified in such reports.

[Rule 62-213.440(1)(b)3.a., F.A.C.]

44. Deviation from Permit Requirements Reports. The permittee shall report in accordance with the requirements of Rules 62-210.700(6) and 62-4.130, F.A.C., deviations from permit requirements, including those attributable to upset conditions as defined in the permit. Reports shall include the probable cause of such deviations, and any corrective actions or preventive measures taken.

[Rule 62-213.440(1)(b)3.b., F.A.C.]

45. Reports. All reports shall be accompanied by a certification by a responsible official, pursuant to Rule 62-213.420(4), F.A.C.

[Rule 62-213.440(1)(b)3.c., F.A.C.]

46. If any portion of the final permit is invalidated, the remainder of the permit shall remain in effect.

[Rule 62-213.440(1)(d)1., F.A.C.]

47. It shall not be a defense for a permittee in an enforcement action that maintaining compliance with any permit condition would necessitate halting of or reduction of the source activity.

[Rule 62-213.440(1)(d)3., F.A.C.]

48. Any Title V source shall comply with all the terms and conditions of the existing permit until the Department has taken final action on any permit renewal or any requested permit revision, except as provided at Rule 62-213.412(2), F.A.C.

[Rule 62-213.440(1)(d)4., F.A.C.]

49. A situation arising from sudden and unforeseeable events beyond the control of the source which causes an exceedance of a technology-based emissions limitation because of unavoidable increases in emissions attributable to the situation and which requires immediate corrective action to restore normal operation, shall be an affirmative defense to an enforcement action in accordance with the provisions and requirements of 40 CFR 70.6(g)(2) and (3), hereby adopted and incorporated by reference.

[Rule 62-213.440(1)(d)5., F.A.C.]

50. Confidentiality Claims. Any permittee may claim confidentiality of any data or other information by complying with Rule 62-213.420(2), F.A.C. (also, see Condition No. 36.)

[Rule 62-213.440(1)(d)6., F.A.C.]

51. Statement of Compliance. (a)2. The permittee shall submit a Statement of Compliance with all terms and conditions of the permit that includes all the provisions of 40 CFR 70.6(c)(5)(iii), incorporated by reference at Rule 62-204.800, F.A.C., using DEP Form No. 62-213.900(7). Such statement shall be accompanied by a certification in accordance with Rule 62-213.420(4), F.A.C., for Title V requirements and with Rule 62-214.350, F.A.C., for Acid Rain requirements. Such statements shall be submitted (postmarked) to the Department and EPA:

a. Annually, within 60 days after the end of each calendar year during which the Title V permit was effective, or more frequently if specified by Rule 62-213.440(2), F.A.C., or by any other applicable requirement; and

b. Within 60 days after submittal of a written agreement for transfer of responsibility as required pursuant to 40 CFR 70.7(d)(1)(iv), adopted and incorporated by reference at Rule 62-204.800, F.A.C., or within 60 days after permanent shutdown of a facility permitted under Chapter 62-213, F.A.C.; provided that, in either such case, the reporting period shall be the portion of the calendar year the permit was effective up to the date of transfer of responsibility or permanent facility shutdown, as applicable.

3. In lieu of individually identifying all applicable requirements and specifying times of compliance with, non-compliance with, and deviation from each, the responsible official may use DEP Form No. 62-213.900(7) as such statement of compliance so long as the responsible official identifies all reportable deviations from and all instances of non-compliance with any applicable requirements and includes all information required by the federal regulation relating to each reportable deviation and instance of non-compliance.

APPENDIX TV-6, TITLE V CONDITIONS (version dated 06/23/06) (continued)

(b) *The responsible official may treat compliance with all other applicable requirements as a surrogate for compliance with Rule 62-296.320(2), Objectionable Odor Prohibited.*

[Rules 62-213.440(3)(a)2. & 3. and (b), F.A.C.]

52. **Permit Shield.** Except as provided in Chapter 62-213, F.A.C., compliance with the terms and conditions of a permit issued pursuant to Chapter 62-213, F.A.C., shall, as of the effective date of the permit, be deemed compliance with any applicable requirements in effect, provided that the source included such applicable requirements in the permit application. Nothing in Rule 62-213.460, F.A.C., or in any permit shall alter or affect the ability of EPA or the Department to deal with an emergency, the liability of an owner or operator of a source for any violation of applicable requirements prior to or at the time of permit issuance, or the requirements of the Federal Acid Rain Program.

[Rule 62-213.460, F.A.C.]

53. **Forms and Instructions.** The forms used by the Department in the Title V source operation program are adopted and incorporated by reference in Rule 62-213.900, F.A.C. The form is listed by rule number, which is also the form number, and with the subject, title, and effective date. Copies of forms may be obtained by writing to the Department of Environmental Protection, Division of Air Resource Management, 2600 Blair Stone Road, Tallahassee, Florida 32399-2400, or by contacting the appropriate permitting authority.

(1) Major Air Pollution Source Annual Emissions Fee Form. (Effective 01/03/2001)

(7) Statement of Compliance Form. (Effective 06/02/2002)

(8) Responsible Official Notification Form. (Effective 06/02/2002)

[Rule 62-213.900, F.A.C.: Forms (1), (7) and (8)]

Chapter 62-256, F.A.C.

54. **Not federally enforceable. Open Burning.** This permit does not authorize any open burning nor does it constitute any waiver of the requirements of Chapter 62-256, F.A.C. Source shall comply with Chapter 62-256, F.A.C., for any open burning at the source.

[Chapter 62-256, F.A.C.]

Chapter 62-281, F.A.C.

55. **Refrigerant Requirements.** Any facility having refrigeration equipment, including air conditioning equipment, which uses a Class I or II substance (listed at 40 CFR 82, Subpart A, Appendices A and B), and any facility which maintains, services, or repairs motor vehicles using a Class I or Class II substance as refrigerant must comply with all requirements of 40 CFR 82, Subparts B and F, and with Rule 62-281.100, F.A.C. Those requirements include the following restrictions:

(1) Any facility having any refrigeration equipment normally containing 50 (fifty) pounds of refrigerant, or more, must keep servicing records documenting the date and type of all service and the quantity of any refrigerant added pursuant to 40 CFR 82.166;

(2) No person repairing or servicing a motor vehicle may perform any service on a motor vehicle air conditioner (MVAC) involving the refrigerant for such air conditioner unless the person has been properly trained and certified as provided at 40 CFR 82.34 and 40 CFR 82.40, and properly uses equipment approved pursuant to 40 CFR 82.36 and 40 CFR 82.38, and complies with 40 CFR 82.42;

(3) No person may sell or distribute, or offer for sale or distribution, any substance listed as a Class I or Class II substance at 40 CFR 82, Subpart A, Appendices A and B, except in compliance with Rule 62-281.100, F.A.C., and 40 CFR 82.34(b), 40 CFR 82.42, and/or 40 CFR 82.166;

(4) No person maintaining, servicing, repairing, or disposing of appliances may knowingly vent or otherwise release into the atmosphere any Class I or Class II substance used as a refrigerant in such equipment and no other person may open appliances (except MVACs as defined at 40 CFR 82.152) for service, maintenance or repair unless the person has been properly trained and certified pursuant to 40 CFR 82.161 and unless the person uses equipment certified for that type of appliance pursuant to 40 CFR 82.158 and unless the person observes the practices set forth at 40 CFR 82.156 and 40 CFR 82.166;

(5) No person may dispose of appliances (except small appliances, as defined at 40 CFR 82.152) without using equipment certified for that type of appliance pursuant to 40 CFR 82.158 and without observing the practices set forth at 40 CFR 82.156 and 40 CFR 82.166;

(6) No person may recover refrigerant from small appliances, MVACs and MVAC-like appliances (as defined at 40 CFR 82.152), except in compliance with the requirements of 40 CFR 82, Subpart F.

[40 CFR 82; and, Chapter 62-281, F.A.C. (**Chapter 62-281, F.A.C., is not federally enforceable**)]

APPENDIX TV-6, TITLE V CONDITIONS (version dated 06/23/06) (continued)

Chapter 62-296, F.A.C.

56. Industrial, Commercial, and Municipal Open Burning Prohibited. Open burning in connection with industrial, commercial, or municipal operations is prohibited, except when:

- (a) Open burning is determined by the Department to be the only feasible method of operation and is authorized by an air permit issued pursuant to Chapter 62-210 or 62-213, F.A.C.; or
- (b) An emergency exists which requires immediate action to protect human health and safety; or
- (c) A county or municipality would use a portable air curtain incinerator to burn yard trash generated by a hurricane, tornado, fire or other disaster and the air curtain incinerator would otherwise be operated in accordance with the permitting exemption criteria of Rule 62-210.300(3), F.A.C.

[Rule 62-296.320(3), F.A.C.]

57. Unconfined Emissions of Particulate Matter.

(4)(c)1. No person shall cause, let, permit, suffer or allow the emissions of unconfined particulate matter from any activity, including vehicular movement; transportation of materials; construction; alteration; demolition or wrecking; or industrially related activities such as loading, unloading, storing or handling; without taking reasonable precautions to prevent such emissions.

3. Reasonable precautions include the following:

- a. Paving and maintenance of roads, parking areas and yards.
- b. Application of water or chemicals to control emissions from such activities as demolition of buildings, grading roads, construction, and land clearing.
- c. Application of asphalt, water, oil, chemicals or other dust suppressants to unpaved roads, yards, open stock piles and similar activities.
- d. Removal of particulate matter from roads and other paved areas under the control of the owner or operator of the facility to prevent reentrainment, and from buildings or work areas to prevent particulate from becoming airborne.
- e. Landscaping or planting of vegetation.
- f. Use of hoods, fans, filters, and similar equipment to contain, capture and/or vent particulate matter.
- g. Confining abrasive blasting where possible.
- h. Enclosure or covering of conveyor systems.

4. In determining what constitutes reasonable precautions for a particular facility, the Department shall consider the cost of the control technique or work practice, the environmental impacts of the technique or practice, and the degree of reduction of emissions expected from a particular technique or practice.

[Rules 62-296.320(4)(c)1., 3., & 4. F.A.C.]

[electronic file name: tv-6.doc]

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection A. Emissions Units 001 and 002

Method	Description of Method and Comments
20	Determination of Nitrogen Oxides, Sulfur Dioxide and Diluent Emissions from Stationary Gas Turbines
25, 25A, 25B	Method for Determining Gaseous Organic Concentrations (Flame Ionization)
101A	Determination of Hg Emissions
104	Determination of Be Emissions
108	Determination of Hg Emissions

The above methods are described in 40 CFR 60, Appendix A, and adopted by reference in Rule 62-204.800, F.A.C. No other methods may be used unless prior written approval is received from the Department. [62-297.401, F.A.C.; PPS PA 81-14/SA1; PSD-FL-084; and 40 CFR 60.49Da]

- A.26. Common Testing Requirements.** Unless otherwise specified, tests shall be conducted in accordance with the requirements and procedures specified in Appendix TR, Facility-Wide Testing Requirements, of this permit. [Rule 62-297.310, F.A.C.]
- A.27. Annual Compliance Tests Required.** During each federal fiscal year (October 1st to September 30th), each EU shall be tested to demonstrate compliance with the emissions standards for particulate matter, NO_x, SO₂ and visible emissions. [Rule 62-297.310(7), F.A.C.; and PPS PA 81-14/SA1]
- A.28. Compliance Tests Prior To Renewal.** Compliance tests shall be performed for particulate matter, NO_x, SO₂, visible emissions, carbon monoxide, volatile organic compounds, sulfuric acid mist, mercury, beryllium, lead and fluoride once every 5 years. The tests shall occur prior to obtaining a renewed operating permit to demonstrate compliance with the emission limits in Specific Conditions A.5. – A.16. [Rules 62-210.300(2)(a) and 62-297.310(7)(a), F.A.C.]

Recordkeeping and Reporting Requirements

- A.29. Reporting Requirements.** See Appendix RR, Facility-Wide Reporting Requirements, for reporting requirements.
- A.30. Fuel Sampling Record.** Samples of all fuel oil and coal fired in the boilers shall be taken and analyzed for sulfur content, ash content, and heating value. Accordingly, samples shall be taken of each fuel oil shipment received. Coal sulfur content shall be determined and recorded on a daily basis in accordance with EPA Reference Method 19. Records of all the analyses shall be kept for public inspection for a minimum of five years. [Rule 62-213.440, F.A.C. and PSD-FL-084]

Other Requirements

- A.31. Used Oil.** Burning of on-specification used oil is allowed at this facility in accordance with all other conditions of this permit and the following conditions:
 - a. *On-specification Used Oil Allowed as Fuel.* This permit allows the burning of used fuel oil meeting EPA “on-specification” used oil specifications, with a maximum sulfur content of 1.5 percent by weight for Units 1 and 2 and 0.5 percent by weight for the auxiliary boiler. The PCB concentration of used oil shall be less than 50 ppm. Used oil that does not meet the specifications for on-specification used oil shall not be burned at this facility. On-specification used oil shall meet the following specifications: [40 CFR 279, Subpart B.]
 - Arsenic shall not exceed 5.0 ppm;
 - Cadmium shall not exceed 2.0 ppm;
 - Chromium shall not exceed 10.0 ppm;

Friday, Barbara

To: 'ageorge@invenergyllc.com'; 'tdavis@ectinc.com'; 'fsarduy@invenergyservices.com'; Nasca, Mara
Cc: Holtom, Jonathan
Subject: PROPOSED Title V Permit Revision No.: 0490015-007-AV - Hardee Power Partners
Attachments: 0490015.007.AV.P_pdf[1].zip

Dear Sir/Madam:

Please send a "reply" message verifying receipt of the attached document(s); this may be done by selecting "Reply" on the menu bar of your e-mail software and then selecting "Send". We must receive verification of receipt and your reply will preclude subsequent e-mail transmissions to verify receipt of the document(s).

The document(s) may require immediate action within a specified time frame. Please open and review the document(s) as soon as possible.

The document is in Adobe Portable Document Format (pdf). Adobe Acrobat Reader can be downloaded for free at the following internet site: <http://www.adobe.com/products/acrobat/readstep.html>.

The Bureau of Air Regulation is issuing electronic documents for permits, notices and other correspondence in lieu of hard copies through the United States Postal System, to provide greater service to the applicant and the engineering community. Please advise this office of any changes to your e-mail address or that of the Engineer-of-Record.

Thank you,

DEP, Bureau of Air Regulation

10/24/2006

Friday, Barbara

From: Tom Davis [tdavis@ectinc.com]
Sent: Thursday, October 12, 2006 8:50 AM
To: Friday, Barbara
Subject: RE: DRAFT/PROPOSED Title V Permit Revision No.: 0490015-007-AV - Hardee Power Partners

From: Friday, Barbara [mailto:Barbara.Friday@dep.state.fl.us]
Sent: Wednesday, October 11, 2006 12:34 PM
To: ageorge@invenergyllc.com; tdavis@ectinc.com; fsarduy@invenergyservices.com; Nasca, Mara
Cc: Holtom, Jonathan
Subject: DRAFT/PROPOSED Title V Permit Revision No.: 0490015-007-AV - Hardee Power Partners

Dear Sir/Madam:

Please send a "reply" message verifying receipt of the attached document(s); this may be done by selecting "Reply" on the menu bar of your e-mail software and then selecting "Send". We must receive verification of receipt and your reply will preclude subsequent e-mail transmissions to verify receipt of the document(s).

The document(s) may require immediate action within a specified time frame. Please open and review the document(s) as soon as possible.

The document is in Adobe Portable Document Format (pdf). Adobe Acrobat Reader can be downloaded for free at the following internet site: <http://www.adobe.com/products/acrobat/readstep.html>.

The Bureau of Air Regulation is issuing electronic documents for permits, notices and other correspondence in lieu of hard copies through the United States Postal System, to provide greater service to the applicant and the engineering community. Please advise this office of any changes to your e-mail address or that of the Engineer-of-Record.

Thank you,

DEP, Bureau of Air Regulation

10/12/2006

Friday, Barbara

From: System Administrator
To: Nasca, Mara
Sent: Tuesday, October 24, 2006 10:47 AM
Subject: Delivered:PROPOSED Title V Permit Revision No.: 0490015-007-AV - Hardee Power Partners

Your message

To: 'ageorge@inverenergyllc.com'; 'tdavis@ectinc.com'; 'fsarduy@inverenergyservices.com'; Nasca, Mara
Cc: Holtom, Jonathan
Subject: PROPOSED Title V Permit Revision No.: 0490015-007-AV - Hardee Power Partners
Sent: 10/24/2006 10:47 AM

was delivered to the following recipient(s):

Nasca, Mara on 10/24/2006 10:47 AM

Friday, Barbara

From: Exchange Administrator
Sent: Tuesday, October 24, 2006 10:48 AM
To: Friday, Barbara
Subject: Delivery Status Notification (Relay)

Attachments: ATT127676.txt; PROPOSED Title V Permit Revision No.: 0490015-007-AV - Hardee Power Partners



ATT127676.txt
(284 B)



PROPOSED Title V
Permit Revisi...

This is an automatically generated Delivery Status Notification.

Your message has been successfully relayed to the following recipients, but the requested delivery status notifications may not be generated by the destination.

tdavis@ectinc.com

Friday, Barbara

From: System Administrator
To: ageorge@invenergyllc.com
Sent: Tuesday, October 24, 2006 10:48 AM
Subject: Delivered:Message delivered: PROPOSED Title V Permit Revision No.: 0490015-007-AV - Hardee Power Partners

Your message

To: ageorge@invenergyllc.com; tdavis@ectinc.com; fsarduy@invenergyservices.com; Nasca, Mara
Cc: Holtom, Jonathan
Subject: PROPOSED Title V Permit Revision No.: 0490015-007-AV - Hardee Power Partners
Sent: 10/24/2006 10:47 AM

was delivered to the following recipient(s):

ageorge@invenergyllc.com on 10/24/2006 10:46 AM

Friday, Barbara

From: Holtom, Jonathan
Sent: Monday, October 23, 2006 4:43 PM
To: 'Forney.Kathleen@epamail.epa.gov'
Cc: Friday, Barbara
Subject: Draft/Proposed Permit for Hardee Power

Hi Katy,

This is your notification that the Public Notice for the combined DRAFT/PROPOSED permit for Hardee Power Station was published on October 19. The public comment period will end on November 18. Barbara Friday posted the DRAFT/PROPOSED permit for the Draft portion of it on October 11 and will repost it as a PROPOSED action for your review. If I understand this new process correctly, if there are no public comments in response to the Public Notice, and if you do not have any veto items, then this combined permit will be ready to be issued as a FINAL Title V revision 45 days from today (which I think will be December 3rd).

If you have any questions, please feel free to contact me. I hope all is well up your way.

Jonathan Holtom, P.E.
North Permitting Section, Bureau of Air Regulation
(850) 921-9531
SunCom 291-9531

10/24/2006

**HARDEE POWER
PARTNERS LIMITED**

Invenergy

October 20, 2006

Ms. Trina L. Vielhauer
Florida Department of Environmental Protection
2600 Blair Stone Road
Mail Station 5505
Tallahassee, Florida 32399-2400

RECEIVED
OCT 23 2006
BUREAU OF AIR REGULATION

Re: Hardee Power Partners Limited
Hardee Power Station
Title V Air Operation Permit No. 0490015-005-AV
Proof of Public Notice Publication

Dear Ms. Vielhauer:

In accordance with Rule 62-110.106(5), F.A.C., Hardee Power Partners Limited hereby submits the enclosed proof of publication of Public Notice for the draft/proposed Air Permit No. 0490015-007-AV. The Public Notice was published in the Wauchula Herald-Advocate on October 18, 2006.

Please feel free to contact Frank Sarduy at (813) 314-2459 if you have any questions regarding this information.

Sincerely,



Ralph E. Randall
Plant Manager

Friday, Barbara

To: 'ageorge@invenergyllc.com'; 'tdavis@ectinc.com'; 'fsarduy@invenergyservices.com'; Nasca, Mara
Cc: Holtom, Jonathan
Subject: DRAFT/PROPOSED Title V Permit Revision No.: 0490015-007-AV - Hardee Power Partners
Attachments: 0490015.007.AV.P_pdf[1].zip; 0490015.007.AV.D_pdf[1].zip

Dear Sir/Madam:

Please send a "reply" message verifying receipt of the attached document(s); this may be done by selecting "Reply" on the menu bar of your e-mail software and then selecting "Send". We must receive verification of receipt and your reply will preclude subsequent e-mail transmissions to verify receipt of the document(s).

The document(s) may require immediate action within a specified time frame. Please open and review the document(s) as soon as possible.

The document is in Adobe Portable Document Format (pdf). Adobe Acrobat Reader can be downloaded for free at the following internet site: <http://www.adobe.com/products/acrobat/readstep.html>.

The Bureau of Air Regulation is issuing electronic documents for permits, notices and other correspondence in lieu of hard copies through the United States Postal System, to provide greater service to the applicant and the engineering community. Please advise this office of any changes to your e-mail address or that of the Engineer-of-Record.

Thank you,

DEP, Bureau of Air Regulation

10/11/2006

Friday, Barbara

From: System Administrator
To: ageorge@invenergyllc.com
Sent: Wednesday, October 11, 2006 12:38 PM
Subject: Delivered:Message delivered: DRAFT/PROPOSED Title V Permit Revision No.:
0490015-007-AV - Hardee Power Partners

Your message

To: ageorge@invenergyllc.com; tdavis@ectinc.com; fsarduy@invenergyservices.com; Nasca, Mara
Cc: Holtom, Jonathan
Subject: DRAFT/PROPOSED Title V Permit Revision No.: 0490015-007-AV - Hardee Power Partners
Sent: 10/11/2006 12:34 PM

was delivered to the following recipient(s):

ageorge@invenergyllc.com on 10/11/2006 12:34 PM

Friday, Barbara

From: Exchange Administrator
Sent: Wednesday, October 11, 2006 12:37 PM
To: Friday, Barbara
Subject: Delivery Status Notification (Relay)

Attachments: ATT720686.txt; DRAFT/PROPOSED Title V Permit Revision No.: 0490015-007-AV - Hardee Power Partners



ATT720686.txt (284 B) DRAFT/PROPOSED Title V Permit ...

This is an automatically generated Delivery Status Notification.

Your message has been successfully relayed to the following recipients, but the requested delivery status notifications may not be generated by the destination.

tdavis@ectinc.com

Friday, Barbara

From: Mail Delivery Subsystem [MAILER-DAEMON@host.serversanddomains.com]
Sent: Wednesday, October 11, 2006 12:35 PM
To: Friday, Barbara
Subject: Return receipt

Attachments: ATT720498.txt; ATT720499.txt



ATT720498.txt (379 B) ATT720499.txt (2 KB)

The original message was received at Wed, 11 Oct 2006 12:34:52 -0400 from tlhexsprot2.floridadep.net [199.73.152.8] (may be forged)

----- The following addresses had successful delivery notifications -----
<fsarduy@invenergyservices.com> (relayed to non-DSN-aware mailer)

----- Transcript of session follows ----- <fsarduy@invenergyservices.com>... relayed;
expect no further notifications

Friday, Barbara

From: Frank Sarduy [fsarduy@invenergyservices.com]
Sent: Wednesday, October 11, 2006 12:41 PM
To: Friday, Barbara
Subject: Read: DRAFT/PROPOSED Title V Permit Revision No.: 0490015-007-AV - Hardee Power Partners
Attachments: ATT720960.txt

Your message

To: ageorge@invenergyllc.com; tdavis@ectinc.com; fsarduy@invenergyservices.com; Nasca, Mara
Cc: Holtom, Jonathan
Subject: DRAFT/PROPOSED Title V Permit Revision No.: 0490015-007-AV - Hardee Power Partners
Sent: 10/11/2006 12:33 PM

was read on 10/11/2006 12:40 PM.

Friday, Barbara

From: Frank Sarduy [fsarduy@invenergyservices.com]
Sent: Wednesday, October 11, 2006 1:06 PM
To: Friday, Barbara
Subject: RE: DRAFT/PROPOSED Title V Permit Revision No.: 0490015-007-AV - Hardee Power Partners

I received your e-mail.

Regards,

Frank Sarduy
Environmental Manager
Invenergy Services LLC
10150 Highland Manor Drive
Suite 200
Tampa FL 33610

Phone (813) 314-2459
Fax (813) 433-5485

This electronic message and all contents contain information which may be privileged, confidential or otherwise protected from disclosure. The information is intended to be for the addressee(s) only. If you are not an addressee, any disclosure, copy, distribution or use of the contents of this message is prohibited. If you have received this electronic message in error, please notify the sender by reply e-mail and destroy the original message and all copies.

From: Friday, Barbara [mailto:Barbara.Friday@dep.state.fl.us]
Sent: Wednesday, October 11, 2006 12:34 PM
To: ageorge@invenergyllc.com; tdavis@ectinc.com; fsarduy@invenergyservices.com; Nasca, Mara
Cc: Holtom, Jonathan
Subject: DRAFT/PROPOSED Title V Permit Revision No.: 0490015-007-AV - Hardee Power Partners

Dear Sir/Madam:

Please send a "reply" message verifying receipt of the attached document(s); this may be done by selecting "Reply" on the menu bar of your e-mail software and then selecting "Send". We must receive verification of receipt and your reply will preclude subsequent e-mail transmissions to verify receipt of the document(s).

The document(s) may require immediate action within a specified time frame. Please open and review the document(s) as soon as possible.

The document is in Adobe Portable Document Format (pdf). Adobe Acrobat Reader can be downloaded for free at the following internet site: <http://www.adobe.com/products/acrobat/readstep.html>.

The Bureau of Air Regulation is issuing electronic documents for permits, notices and other correspondence in lieu of hard copies through the United States Postal System, to provide greater service to the applicant and the engineering community. Please advise this office of any changes to your e-mail address or that of the Engineer-of-Record.

10/11/2006

Thank you,

DEP, Bureau of Air Regulation

Friday, Barbara

From: System Administrator
To: Nasca, Mara
Sent: Wednesday, October 11, 2006 12:35 PM
Subject: Delivered:DRAFT/PROPOSED Title V Permit Revision No.: 0490015-007-AV - Hardee Power Partners

Your message

To: 'ageorge@invenergyllc.com'; 'tdavis@ectinc.com'; 'fsarduy@invenergyservices.com'; Nasca, Mara
Cc: Holtom, Jonathan
Subject: DRAFT/PROPOSED Title V Permit Revision No.: 0490015-007-AV - Hardee Power Partners
Sent: 10/11/2006 12:34 PM

was delivered to the following recipient(s):

Nasca, Mara on 10/11/2006 12:34 PM

Friday, Barbara

From: Nasca, Mara
To: Friday, Barbara
Sent: Wednesday, October 11, 2006 2:25 PM
Subject: Read: DRAFT/PROPOSED Title V Permit Revision No.: 0490015-007-AV - Hardee Power Partners

Your message

To: 'ageorge@invenergyllc.com'; 'tdavis@ectinc.com'; 'fsarduy@invenergyservices.com'; Nasca, Mara
Cc: Holtom, Jonathan
Subject: DRAFT/PROPOSED Title V Permit Revision No.: 0490015-007-AV - Hardee Power Partners
Sent: 10/11/2006 12:34 PM

was read on 10/11/2006 2:25 PM.

Friday, Barbara

From: Nasca, Mara
Sent: Wednesday, October 11, 2006 2:25 PM
To: Friday, Barbara
Cc: Zhang-Torres
Subject: RE: DRAFT/PROPOSED Title V Permit Revision No.: 0490015-007-AV - Hardee Power Partners

thanks

-----Original Message-----

From: Friday, Barbara
Sent: Wednesday, October 11, 2006 12:34 PM
To: 'ageorge@invenergyllc.com'; 'tdavis@ectinc.com'; 'fsarduy@invenergyservices.com'; Nasca, Mara
Cc: Holtom, Jonathan
Subject: DRAFT/PROPOSED Title V Permit Revision No.: 0490015-007-AV - Hardee Power Partners

Dear Sir/Madam:

Please send a "reply" message verifying receipt of the attached document(s); this may be done by selecting "Reply" on the menu bar of your e-mail software and then selecting "Send". We must receive verification of receipt and your reply will preclude subsequent e-mail transmissions to verify receipt of the document(s).

The document(s) may require immediate action within a specified time frame. Please open and review the document(s) as soon as possible.

The document is in Adobe Portable Document Format (pdf). Adobe Acrobat Reader can be downloaded for free at the following internet site: <http://www.adobe.com/products/acrobat/readstep.html>.

The Bureau of Air Regulation is issuing electronic documents for permits, notices and other correspondence in lieu of hard copies through the United States Postal System, to provide greater service to the applicant and the engineering community. Please advise this office of any changes to your e-mail address or that of the Engineer-of-Record.

Thank you,

DEP, Bureau of Air Regulation

Friday, Barbara

From: Casey, Lee (SWM) [le1@miamidade.gov]
Sent: Wednesday, October 11, 2006 4:55 PM
To: Friday, Barbara
Cc: Ganguli, Asok (SWM)
Subject: RE: 0250348006AC0250348007AVIncompletenessLetter

The message has been received by the Miami-Dade County Department of Solid Waste Management.

Lee S. Casey, REM
 Sr. Division Director, Technical Services & Environmental Affairs Division
 Miami-Dade County Department of Solid Waste Management
 305-514-6672
www.miamidade.gov
"Delivering Excellence Every Day"

-----Original Message-----

From: Woods-Richardson, Kathleen (SWM)
Sent: Monday, October 09, 2006 1:54 PM
To: Castro, Vicente (SWM); Ganguli, Asok (SWM)
Cc: Casey, Lee (SWM); McDuffie, Stacey (SWM)
Subject: FW: 0250348006AC0250348007AVIncompletenessLetter

Please prepare response

Kathleen Woods-Richardson
 Director
 Miami-Dade County Solid Waste Management
 305-514-6628 Phone * 305-514-6886 Fax
"Delivering Excellence Every Day"

From: Friday, Barbara [mailto:Barbara.Friday@dep.state.fl.us]
Sent: Monday, October 09, 2006 1:50 PM
To: Graziani, Darrel; dbuff@golder.com; Woods-Richardson, Kathleen (SWM)
Cc: Cascio, Tom; Gibson, Victoria
Subject: 0250348006AC0250348007AVIncompletenessLetter

Dear Sir/Madam:

Please send a "reply" message verifying receipt of the attached document(s); this may be done by selecting "Reply" on the menu bar of your e-mail software and then selecting "Send". We must receive verification of receipt and your reply will preclude subsequent e-mail transmissions to verify receipt of the document(s).

The document(s) may require immediate action within a specified time frame. Please open and review the document(s) as soon as possible.

The document is in Adobe Portable Document Format (pdf). Adobe Acrobat Reader can be downloaded for free at the following internet site: <http://www.adobe.com/products/acrobat/readstep.html>.

The Bureau of Air Regulation is issuing electronic documents for permits, notices and other

10/12/2006

correspondence in lieu of hard copies through the United States Postal System, to provide greater service to the applicant and the engineering community. Please advise this office of any changes to your e-mail address or that of the Engineer-of-Record.

Thank you,

DEP, Bureau of Air Regulation

Friday, Barbara

From: Mailer-Daemon@ectinc.com
Sent: Wednesday, October 11, 2006 6:29 PM
To: Friday, Barbara
Subject: Confirm: `DRAFT/PROPOSED Title V Permit Revision No.: 0490015-007-AV - Hardee Power Partners' received

A message which requested delivery confirmation recently arrived at this server. This server honors all delivery confirmation requests whether generated from local mail traffic or from mail received via an outside source (such as SMTP/POP).

Message-ID: <5280B20498F24C46A51A87E86A0C8F97038BC7@tlhexsmb5.floridadep.net>
To : tdavis@ectinc.com
From : Barbara.Friday@dep.state.fl.us
Subject : DRAFT/PROPOSED Title V Permit Revision No.: 0490015-007-AV - Hardee Power Partners
Date : Wed, 11 Oct 2006 12:33:39 -0400

Receiving Domain: ectinc.com