

**RECEIVED**

MAY 19 2006

BUREAU OF AIR REGULATION

**AIR PERMIT APPLICATION  
TO REVISE  
BOILER NOS. 1 AND 2  
MODIFIED OIL-FIRING SYSTEM  
U.S. SUGAR CORPORATION  
CLEWISTON, FLORIDA**


**Prepared For:  
United States Sugar Corporation  
111 Ponce DeLeon Ave.  
Clewiston, Florida 33440**

**Prepared By:  
Golder Associates Inc.  
6241 NW 23rd Street, Suite 500  
Gainesville, Florida 32653-1500**

**May 2006  
0637563**

**DISTRIBUTION:  
3 Copies – FDEP, Tallahassee  
1 Copy – FDEP, Ft. Myers  
2 Copies – U.S. Sugar  
2 Copies – Golder Associates Inc.**

**APPLICATION FOR AIR PERMIT – LONG FORM**



# Department of Environmental Protection

## Division of Air Resource Management

### APPLICATION FOR AIR PERMIT - LONG FORM

#### I. APPLICATION INFORMATION

**Air Construction Permit** – Use this form to apply for an air construction permit at a facility operating under a federally enforceable state air operation permit (FESOP) or Title V air permit. Also use this form to apply for an air construction permit:

- For a proposed project subject to prevention of significant deterioration (PSD) review, nonattainment area (NAA) new source review, or maximum achievable control technology (MACT) review; or
- Where the applicant proposes to assume a restriction on the potential emissions of one or more pollutants to escape a federal program requirement such as PSD review, NAA new source review, Title V, or MACT; or
- Where the applicant proposes to establish, revise, or renew a plantwide applicability limit (PAL).

**Air Operation Permit** – Use this form to apply for:

- an initial federally enforceable state air operation permit (FESOP); or
- an initial/revise/renewal Title V air operation permit.

**Air Construction Permit & Title V Air Operation Permit (Concurrent Processing Option)** – Use this form to apply for both an air construction permit and a revised or renewal Title V air operation permit incorporating the proposed project.

To ensure accuracy, please see form instructions.

#### Identification of Facility

1. Facility Owner/Company Name: <b>United States Sugar Corporation</b>	
2. Site Name: <b>U.S. Sugar Clewiston Mill</b>	
3. Facility Identification Number: <b>0510003</b>	
4. Facility Location...: Street Address or Other Locator: <b>W.C. Owens Ave. and S.R. 832</b> City: <b>Clewiston</b> County: <b>Henry</b> Zip Code: <b>33440</b>	
5. Relocatable Facility? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6. Existing Title V Permitted Facility? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

#### Application Contact

1. Application Contact Name: <b>William A. Raiola, Senior Vice President, Sugar Processing Operations</b>	
2. Application Contact Mailing Address... Organization/Firm: <b>United States Sugar Corporation</b> Street Address: <b>111 Ponce DeLeon Ave.</b> City: <b>Clewiston</b> State: <b>Florida</b> Zip Code: <b>33440</b>	
3. Application Contact Telephone Numbers... Telephone: <b>(863) 983-8121</b> ext.      Fax: <b>(863) 902-2729</b>	
4. Application Contact Email Address: <b>braiola@ussugar.com</b>	

#### Application Processing Information (DEP Use)

1. Date of Receipt of Application: <b>5/19/06</b>	3. PSD Number (if applicable):
2. Project Number(s): <b>0510003-036-AE</b>	4. Siting Number (if applicable):

# APPLICATION INFORMATION

## Purpose of Application

**This application for air permit is submitted to obtain: (Check one)**

### **Air Construction Permit**

- Air construction permit.
- Air construction permit to establish, revise, or renew a plantwide applicability limit (PAL).
- Air construction permit to establish, revise, or renew a plantwide applicability limit (PAL), and separate air construction permit to authorize construction or modification of one or more emissions units covered by the PAL.

### **Air Operation Permit**

- Initial Title V air operation permit.
- Title V air operation permit revision.
- Title V air operation permit renewal.
- Initial federally enforceable state air operation permit (FESOP) where professional engineer (PE) certification is required.
- Initial federally enforceable state air operation permit (FESOP) where professional engineer (PE) certification is not required.

### **Air Construction Permit and Revised/Renewal Title V Air Operation Permit (Concurrent Processing)**

- Air construction permit and Title V permit revision, incorporating the proposed project.
- Air construction permit and Title V permit renewal, incorporating the proposed project.

**Note: By checking one of the above two boxes, you, the applicant, are requesting concurrent processing pursuant to Rule 62-213.405, F.A.C. In such case, you must also check the following box:**

- I hereby request that the department waive the processing time requirements of the air construction permit to accommodate the processing time frames of the Title V air operation permit.

## Application Comment

**Air Construction Permit application to modify the fuel oil burners on Boiler Nos. 1 and 2.**

# APPLICATION INFORMATION

## Scope of Application

Emissions Unit ID Number	Description of Emissions Unit	Air Permit Type	Air Permit Proc. Fee
001	Boiler No. 1	AC1D	n/a
002	Boiler No. 2	AC1D	n/a

### Application Processing Fee


Check one:  Attached - Amount: \$ \_\_\_\_\_

Not Applicable

## FACILITY INFORMATION

### Owner/Authorized Representative Statement

**Complete if applying for an air construction permit or an initial FESOP.**

1. Owner/Authorized Representative Name : <b>William A. Raiola, Senior Vice President, Sugar Processing Operations</b>
2. Owner/Authorized Representative Mailing Address... Organization/Firm: <b>United States Sugar Corporation</b> Street Address: <b>111 Ponce de Leon Avenue</b> City: <b>Clewiston</b> State: <b>Florida</b> Zip Code: <b>33440</b>
3. Owner/Authorized Representative Telephone Numbers... Telephone: <b>(863) 983-8121</b> ext. Fax: <b>(863)902-2729</b>
4. Owner/Authorized Representative Email Address: <b>braiola@ussugar.com</b>
5. Owner/Authorized Representative Statement:  <i>I, the undersigned, am the owner or authorized representative of the facility addressed in this air permit application. I hereby certify, based on information and belief formed after reasonable inquiry, that the statements made in this application are true, accurate and complete and that, to the best of my knowledge, any estimates of emissions reported in this application are based upon reasonable techniques for calculating emissions. The air pollutant emissions units and air pollution control equipment described in this application will be operated and maintained so as to comply with all applicable standards for control of air pollutant emissions found in the statutes of the State of Florida and rules of the Department of Environmental Protection and revisions thereof and all other requirements identified in this application to which the facility is subject. I understand that a permit, if granted by the department, cannot be transferred without authorization from the department, and I will promptly notify the department upon sale or legal transfer of the facility or any permitted emissions unit.</i>   Signature _____ Date <u>05/16/06</u>

# APPLICATION INFORMATION

## Professional Engineer Certification

1. Professional Engineer Name: <b>David A. Buff</b> Registration Number: <b>19011</b>
2. Professional Engineer Mailing Address... Organization/Firm: <b>Golder Associates Inc.**</b> Street Address: <b>6241 NW 23<sup>rd</sup> Street, Suite 500</b> City: <b>Gainesville</b> State: <b>FL</b> Zip Code: <b>32653</b>
3. Professional Engineer Telephone Numbers... Telephone: <b>(352) 336-5600</b> ext. <b>545</b> Fax: <b>(352) 336-6603</b>
4. Professional Engineer Email Address: <b>dbuff@golder.com</b>
5. Professional Engineer Statement: <i>I, the undersigned, hereby certify, except as particularly noted herein*, that:</i> <i>(1) To the best of my knowledge, there is reasonable assurance that the air pollutant emissions unit(s) and the air pollution control equipment described in this application for air permit, when properly operated and maintained, will comply with all applicable standards for control of air pollutant emissions found in the Florida Statutes and rules of the Department of Environmental Protection; and</i> <i>(2) To the best of my knowledge, any emission estimates reported or relied on in this application are true, accurate, and complete and are either based upon reasonable techniques available for calculating emissions or, for emission estimates of hazardous air pollutants not regulated for an emissions unit addressed in this application, based solely upon the materials, information and calculations submitted with this application.</i> <i>(3) If the purpose of this application is to obtain a Title V air operation permit (check here <input type="checkbox"/>, if so), I further certify that each emissions unit described in this application for air permit, when properly operated and maintained, will comply with the applicable requirements identified in this application to which the unit is subject, except those emissions units for which a compliance plan and schedule is submitted with this application.</i> <i>(4) If the purpose of this application is to obtain an air construction permit (check here <input checked="" type="checkbox"/>, if so) or concurrently process and obtain an air construction permit and a Title V air operation permit revision or renewal for one or more proposed new or modified emissions units (check here <input type="checkbox"/>, if so), I further certify that the engineering features of each such emissions unit described in this application have been designed or examined by me or individuals under my direct supervision and found to be in conformity with sound engineering principles applicable to the control of emissions of the air pollutants characterized in this application.</i> <i>(5) If the purpose of this application is to obtain an initial air operation permit or operation permit revision or renewal for one or more newly constructed or modified emissions units (check here <input type="checkbox"/>, if so), I further certify that, with the exception of any changes detailed as part of this application, each such emissions unit has been constructed or modified in substantial accordance with the information given in the corresponding application for air construction permit and with all provisions contained in such permit.</i>  <i>David A. Buff</i> Signature _____ Date <u>5/17/06</u> (seal)

\* Attach any exception to certification statement.

\*\* Board of Professional Engineers Certificate of Authorization #00001670

# FACILITY INFORMATION

## II. FACILITY INFORMATION

### A. GENERAL FACILITY INFORMATION

#### Facility Location and Type

1. Facility UTM Coordinates... Zone <b>17</b> East (km) <b>506.1</b> North (km) <b>2956.9</b>		2. Facility Latitude/Longitude... Latitude (DD/MM/SS) <b>26/44/06</b> Longitude (DD/MM/SS) <b>80/56/19</b>	
3. Governmental Facility Code: <b>0</b>	4. Facility Status Code: <b>A</b>	5. Facility Major Group SIC Code: <b>20</b>	6. Facility SIC(s): <b>2061, 2062</b>
7. Facility Comment :			

#### Facility Contact

1. Facility Contact Name: <b>William A. Raiola, Senior Vice President, Sugar Processing Operations</b>
2. Facility Contact Mailing Address... Organization/Firm: <b>United States Sugar Corporation</b> Street Address: <b>111 Ponce DeLeon Ave.</b> City: <b>Clewiston</b> State: <b>FL</b> Zip Code: <b>33440</b>
3. Facility Contact Telephone Numbers: Telephone: <b>(863) 983-8121</b> ext. Fax: <b>(863) 902-2729</b>
4. Facility Contact Email Address:

#### Facility Primary Responsible Official

Complete if an "application responsible official" is identified in Section I. that is not the facility "primary responsible official."

1. Facility Primary Responsible Official Name:
2. Facility Primary Responsible Official Mailing Address... Organization/Firm: Street Address: City: State: Zip Code:
3. Facility Primary Responsible Official Telephone Numbers... Telephone: ( ) - ext. Fax: ( ) -
4. Facility Primary Responsible Official Email Address:



## FACILITY INFORMATION

### Facility Regulatory Classifications

Check all that would apply *following* completion of all projects and implementation of all other changes proposed in this application for air permit. Refer to instructions to distinguish between a "major source" and a "synthetic minor source."

1. <input type="checkbox"/> Small Business Stationary Source	<input type="checkbox"/> Unknown
2. <input type="checkbox"/> Synthetic Non-Title V Source	
3. <input checked="" type="checkbox"/> Title V Source	
4. <input checked="" type="checkbox"/> Major Source of Air Pollutants, Other than Hazardous Air Pollutants (HAPs)	
5. <input type="checkbox"/> Synthetic Minor Source of Air Pollutants, Other than HAPs	
6. <input checked="" type="checkbox"/> Major Source of Hazardous Air Pollutants (HAPs)	
7. <input type="checkbox"/> Synthetic Minor Source of HAPs	
8. <input checked="" type="checkbox"/> One or More Emissions Units Subject to NSPS (40 CFR Part 60)	
9. <input type="checkbox"/> One or More Emissions Units Subject to Emission Guidelines (40 CFR Part 60)	
10. <input checked="" type="checkbox"/> One or More Emissions Units Subject to NESHAP (40 CFR Part 61 or Part 63)	
11. <input type="checkbox"/> Title V Source Solely by EPA Designation (40 CFR 70.3(a)(5))	
12. Facility Regulatory Classifications Comment:	

# FACILITY INFORMATION

## List of Pollutants Emitted by Facility

1. Pollutant Emitted	2. Pollutant Classification	3. Emissions Cap [Y or N]?
Particulate Matter Total - PM	A	No
Sulfur Dioxide - SO	A	No
Nitrogen Oxides - NO	A	No
Carbon Monoxide - CO	A	No
Particulate Matter - PM <sub>10</sub>	A	No
Sulfuric Acid Mist - SAM	A	No
Total Hazardous Air Pollutants - HAPs	A	No
Volatile Organic Compounds - VOC	A	No
Acetaldehyde - H001	A	No
Benzene - H017	A	No
Formaldehyde - H095	A	No
Phenol - H144	A	No
Polycyclic Organic Matter - H151	A	No
Styrene - H163	A	No
Toluene - H169	A	No
Naphthalene - H132	A	No
Dibenzofuran - H058	A	No

**FACILITY INFORMATION**

**B. EMISSIONS CAPS**

Facility-Wide or Multi-Unit Emissions Caps

1. Pollutant Subject to Emissions Cap	2. Facility Wide Cap [Y or N]? (all units)	3. Emissions Unit ID No.s Under Cap (if not all units)	4. Hourly Cap (lb/hr)	5. Annual Cap (ton/yr)	6. Basis for Emissions Cap
7. Facility-Wide or Multi-Unit Emissions Cap Comment:					

## FACILITY INFORMATION

### C. FACILITY ADDITIONAL INFORMATION

#### Additional Requirements for All Applications, Except as Otherwise Stated

1. Facility Plot Plan: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Previously Submitted, Date: <u>05/2005</u>
2. Process Flow Diagram(s): (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Previously Submitted, Date: <u>05/2005</u>
3. Precautions to Prevent Emissions of Unconfined Particulate Matter: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Previously Submitted, Date: _____

#### Additional Requirements for Air Construction Permit Applications

1. Area Map Showing Facility Location: <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable (existing permitted facility)
2. Description of Proposed Construction, Modification, or Plantwide Applicability Limit (PAL): <input checked="" type="checkbox"/> Attached, Document ID: <u>Attachment A</u>
3. Rule Applicability Analysis: <input checked="" type="checkbox"/> Attached, Document ID: <u>Attachment A</u>
4. List of Exempt Emissions Units (Rule 62-210.300(3), F.A.C.): <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable (no exempt units at facility)
5. Fugitive Emissions Identification: <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
6. Air Quality Analysis (Rule 62-212.400(7), F.A.C.): <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
7. Source Impact Analysis (Rule 62-212.400(5), F.A.C.): <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
8. Air Quality Impact since 1977 (Rule 62-212.400(4)(e), F.A.C.): <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
9. Additional Impact Analyses (Rules 62-212.400(8) and 62-212.500(4)(e), F.A.C.): <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
10. Alternative Analysis Requirement (Rule 62-212.500(4)(g), F.A.C.): <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable

**FACILITY INFORMATION**

**Additional Requirements for FESOP Applications**

1. List of Exempt Emissions Units (Rule 62-210.300(3)(a) or (b)1., F.A.C.):  
 Attached, Document ID: \_\_\_\_\_  Not Applicable (no exempt units at facility)

**Additional Requirements for Title V Air Operation Permit Applications**

1. List of Insignificant Activities (Required for initial/renewal applications only):  
 Attached, Document ID: \_\_\_\_\_  Not Applicable (revision application)

2. Identification of Applicable Requirements (Required for initial/renewal applications, and for revision applications if this information would be changed as a result of the revision being sought):

- Attached, Document ID: \_\_\_\_\_  
 Not Applicable (revision application with no change in applicable requirements)

3. Compliance Report and Plan (Required for all initial/revision/renewal applications):  
 Attached, Document ID: \_\_\_\_\_

Note: A compliance plan must be submitted for each emissions unit that is not in compliance with all applicable requirements at the time of application and/or at any time during application processing. The department must be notified of any changes in compliance status during application processing.

4. List of Equipment/Activities Regulated under Title VI (If applicable, required for initial/renewal applications only):

- Attached, Document ID: \_\_\_\_\_  
 Equipment/Activities On site but Not Required to be Individually Listed  
 Not Applicable

5. Verification of Risk Management Plan Submission to EPA (If applicable, required for initial/renewal applications only) :

- Attached, Document ID: \_\_\_\_\_  Not Applicable

6. Requested Changes to Current Title V Air Operation Permit:

- Attached, Document ID: \_\_\_\_\_  Not Applicable

**Additional Requirements Comment**

## EMISSIONS UNIT INFORMATION

Section [1]

Boiler No. 1

### III. EMISSIONS UNIT INFORMATION

**Title V Air Operation Permit Application** - For Title V air operation permitting only, emissions units are classified as regulated, unregulated, or insignificant. If this is an application for Title V air operation permit, a separate Emissions Unit Information Section (including subsections A through I as required) must be completed for each regulated and unregulated emissions unit addressed in this application for air permit. Some of the subsections comprising the Emissions Unit Information Section of the form are optional for unregulated emissions units. Each such subsection is appropriately marked. Insignificant emissions units are required to be listed at Section II, Subsection C.

**Air Construction Permit or FESOP Application** - For air construction permitting or federally enforceable state air operation permitting, emissions units are classified as either subject to air permitting or exempt from air permitting. The concept of an "unregulated emissions unit" does not apply. If this is an application for air construction permit or FESOP, a separate Emissions Unit Information Section (including subsections A through I as required) must be completed for each emissions unit subject to air permitting addressed in this application for air permit. Emissions units exempt from air permitting are required to be listed at Section II, Subsection C.

**Air Construction Permit and Revised/Renewal Title V Air Operation Permit Application** - Where this application is used to apply for both an air construction permit and a revised/renewal Title V air operation permit, each emissions unit is classified as either subject to air permitting or exempt from air permitting for air construction permitting purposes and as regulated, unregulated, or insignificant for Title V air operation permitting purposes. **The air construction permitting classification must be used to complete the Emissions Unit Information Section of this application for air permit.** A separate Emissions Unit Information Section (including subsections A through I as required) must be completed for each emissions unit subject to air permitting addressed in this application for air permit. Emissions units exempt from air construction permitting and insignificant emissions units are required to be listed at Section II, Subsection C.

If submitting the application form in hard copy, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application must be indicated in the space provided at the top of each page.

**EMISSIONS UNIT INFORMATION**

Section [1]

Boiler No. 1

**A. GENERAL EMISSIONS UNIT INFORMATION**

**Title V Air Operation Permit Emissions Unit Classification**

1. Regulated or Unregulated Emissions Unit? (Check one, if applying for an initial, revised or renewal Title V air operation permit. Skip this item if applying for an air construction permit or FESOP only.)

The emissions unit addressed in this Emissions Unit Information Section is a regulated emissions unit.

The emissions unit addressed in this Emissions Unit Information Section is an unregulated emissions unit.

**Emissions Unit Description and Status**

1. Type of Emissions Unit Addressed in this Section: (Check one)

This Emissions Unit Information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).

This Emissions Unit Information Section addresses, as a single emissions unit, a group of process or production units and activities which has at least one definable emission point (stack or vent) but may also produce fugitive emissions.

This Emissions Unit Information Section addresses, as a single emissions unit, one or more process or production units and activities which produce fugitive emissions only.

2. Description of Emissions Unit Addressed in this Section:  
**Boiler No. 1**

3. Emissions Unit Identification Number: **001**

4. Emissions Unit Status Code: <b>A</b>	5. Commence Construction Date:	6. Initial Startup Date:	7. Emissions Unit Major Group SIC Code: <b>20</b>	8. Acid Rain Unit? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
--	--------------------------------	--------------------------	--	--

9. Package Unit:  
Manufacturer: \_\_\_\_\_ Model Number: \_\_\_\_\_

10. Generator Nameplate Rating: \_\_\_\_\_ MW

11. Emissions Unit Comment:  
**Vibrating grate boiler fired by carbonaceous fuel and No. 2 fuel oil with a maximum sulfur content of 0.05% by weight.**

# EMISSIONS UNIT INFORMATION

Section [1]

Boiler No. 1

## A. GENERAL EMISSIONS UNIT INFORMATION

### Title V Air Operation Permit Emissions Unit Classification

1. Regulated or Unregulated Emissions Unit? (Check one, if applying for an initial, revised or renewal Title V air operation permit. Skip this item if applying for an air construction permit or FESOP only.)

The emissions unit addressed in this Emissions Unit Information Section is a regulated emissions unit.

The emissions unit addressed in this Emissions Unit Information Section is an unregulated emissions unit.

### Emissions Unit Description and Status

1. Type of Emissions Unit Addressed in this Section: (Check one)

This Emissions Unit Information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).

This Emissions Unit Information Section addresses, as a single emissions unit, a group of process or production units and activities which has at least one definable emission point (stack or vent) but may also produce fugitive emissions.

This Emissions Unit Information Section addresses, as a single emissions unit, one or more process or production units and activities which produce fugitive emissions only.

2. Description of Emissions Unit Addressed in this Section:

**Boiler No. 1**

3. Emissions Unit Identification Number: **001**

4. Emissions Unit Status Code: <b>A</b>	5. Commence Construction Date:	6. Initial Startup Date:	7. Emissions Unit Major Group SIC Code: <b>20</b>	8. Acid Rain Unit? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
--	--------------------------------	--------------------------	--	--

9. Package Unit:

Manufacturer:

Model Number:

10. Generator Nameplate Rating: **MW**

11. Emissions Unit Comment:

**Vibrating grate boiler fired by carbonaceous fuel and No. 2 fuel oil with a maximum sulfur content of 0.05% by weight.**



**EMISSIONS UNIT INFORMATION**

**Section [1]**

**Boiler No. 1**

**Emissions Unit Control Equipment**

1. Control Equipment/Method(s) Description:  
**Joy Turbulaire Impingement Scrubber, Size 125, Type D**

2. Control Device or Method Code(s): **001**



**EMISSIONS UNIT INFORMATION**

Section [1]

Boiler No. 1

**C. EMISSION POINT (STACK/VENT) INFORMATION**

(Optional for unregulated emissions units.)

**Emission Point Description and Type**

1. Identification of Point on Plot Plan or Flow Diagram: <b>BLR-1</b>		2. Emission Point Type Code: <b>1</b>	
3. Descriptions of Emission Points Comprising this Emissions Unit for VE Tracking:			
4. ID Numbers or Descriptions of Emission Units with this Emission Point in Common:			
5. Discharge Type Code: <b>V</b>	6. Stack Height: <b>213 feet</b>		7. Exit Diameter: <b>8.0 feet</b>
8. Exit Temperature: <b>150°F</b>	9. Actual Volumetric Flow Rate: <b>250,000 acfm</b>		10. Water Vapor: <b>%</b>
11. Maximum Dry Standard Flow Rate: <b>dscfm</b>		12. Nonstack Emission Point Height: <b>feet</b>	
13. Emission Point UTM Coordinates... Zone: East (km): North (km):		14. Emission Point Latitude/Longitude... Latitude (DD/MM/SS) Longitude (DD/MM/SS)	
15. Emission Point Comment:			

**EMISSIONS UNIT INFORMATION**

Section [1]  
Boiler No. 1

**D. SEGMENT (PROCESS/FUEL) INFORMATION**

**Segment Description and Rate: Segment 1 of 2**

1. Segment Description (Process/Fuel Type): <b>External combustion boilers; Industrial; Bagasse; All boiler sizes</b>		
2. Source Classification Code (SCC): <b>1-02-011-01</b>		3. SCC Units: <b>Tons Burned</b>
4. Maximum Hourly Rate: <b>68.75</b>	5. Maximum Annual Rate: <b>602,250</b>	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur: <b>0.09 (dry basis)</b>	8. Maximum % Ash: <b>8.4 (dry basis)</b>	9. Million Btu per SCC Unit: <b>7.2</b>
10. Segment Comment: <b>Based on 495 MMBtu/hr and 3,600 Btu/lb wet bagasse. Wet bagasse averages approximately 52-percent moisture.</b>		

**Segment Description and Rate: Segment 2 of 2**

1. Segment Description (Process/Fuel Type): <b>External combustion boilers; Industrial; Distillate oil; Grades 1 and 2.</b>		
2. Source Classification Code (SCC): <b>1-02-005-01</b>		3. SCC Units: <b>1,000 Gallons Burned</b>
4. Maximum Hourly Rate: <b>0.963</b>	5. Maximum Annual Rate: <b>6,000</b>	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur: <b>0.05</b>	8. Maximum % Ash:	9. Million Btu per SCC Unit: <b>135</b>
10. Segment Comment: <b>Maximum hourly and annual rates based on 130 MMBtu/hr and 6,000,000 gallons of No. 2 fuel oil per year. Also includes facility generated on-spec used oil and up to 500 cubic yards per season of petroleum contaminated soils.</b>		

**EMISSIONS UNIT INFORMATION**

Section [1]

Boiler No. 1

**E. EMISSIONS UNIT POLLUTANTS**

**List of Pollutants Emitted by Emissions Unit**

1. Pollutant Emitted	2. Primary Control Device Code	3. Secondary Control Device Code	4. Pollutant Regulatory Code
PM	001		EL
PM10	001		NS
SO2	001		EL
NOx			NS
CO			NS
VOC			NS
SAM			NS
PB	001		NS
HAPs (Total Hazardous Air Pollutants)			NS
H001 (Acetaldehyde)			NS
H006 (Acrolein)			NS
H017 (Benzene)			NS
H021 (Beryllium)	001		NS
H052 (p-cresol)			NS
H058 (Dibenzofurans)			NS
H095 (Formaldehyde)			NS
H106 (Hydrogen Chloride)			NS
H114 (Mercury)	001		NS
H132 (Naphthalene)			NS
H144 (Phenol)			NS
H151 (POMs)			NS
H163 (Styrene)			NS
H169 (Toluene)			NS

**EMISSIONS UNIT INFORMATION**

**POLLUTANT DETAIL INFORMATION**

Section [1]  
Boiler No. 1

Page [1] of [6]  
Particulate Matter - Total

**F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION –  
POTENTIAL/ESTIMATED FUGITIVE EMISSIONS**

(Optional for unregulated emissions units.)

**Potential/Estimated Fugitive Emissions**

Complete for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.

1. Pollutant Emitted: <b>PM</b>		2. Total Percent Efficiency of Control:	
3. Potential Emissions: <b>123.8 lb/hour      542.0 tons/year</b>		4. Synthetically Limited? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
5. Range of Estimated Fugitive Emissions (as applicable): to      tons/year			
6. Emission Factor: <b>0.25 lb/MMBtu</b>  Reference: <b>Permit No. 0510003-017-AV</b>		7. Emissions Method Code: <b>0</b>	
8.a. Baseline Actual Emissions (if required): tons/year		8.b. Baseline 24-month Period: From:      To:	
9.a. Projected Actual Emissions (if required): tons/year		9.b. Projected Monitoring Period: <input type="checkbox"/> 5 years <input type="checkbox"/> 10 years	
10. Calculation of Emissions: <b>Bagasse: 495 MMBtu/hr x 0.25 lb/MMBtu = 123.75 lb/hr</b> <b>123.75 lb/hr x 8,760 hr/yr x ton/2000 lb = 542.0 TPY</b>			
11. Potential Fugitive and Actual Emissions Comment: <b>Maximum emissions representative of bagasse firing.</b>			

**EMISSIONS UNIT INFORMATION**

**POLLUTANT DETAIL INFORMATION**

Section [1]  
Boiler No. 1

Page [1] of [6]  
Particulate Matter - Total

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -  
ALLOWABLE EMISSIONS**

Complete if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

**Allowable Emissions** Allowable Emissions 1 of 2

1. Basis for Allowable Emissions Code: <b>OTHER</b>	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: <b>0.25 lb/MMBtu</b>	4. Equivalent Allowable Emissions: <b>123.8 lb/hour      542.0 tons/year</b>
5. Method of Compliance: <b>EPA Method 5 or 17</b>	
6. Allowable Emissions Comment (Description of Operating Method): <b>Permit No. 0510003-017-AV. Emissions representative of bagasse firing only.</b>	

**Allowable Emissions** Allowable Emissions 2 of 2

1. Basis for Allowable Emissions Code: <b>RULE</b>	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: <b>0.1 lb/MMBtu</b>	4. Equivalent Allowable Emissions: <b>13.0 lb/hour      41.7 tons/year</b>
5. Method of Compliance: <b>EPA Method 5 or 17</b>	
6. Allowable Emissions Comment (Description of Operating Method): <b>Rule 62-296.410(1)(b)2, F.A.C., and Permit No. 0510003-027-AC. Emissions representative of fuel oil firing. Annual emissions based on 6,000,000 gallons per any consecutive 12 months.</b>	

**Allowable Emissions** Allowable Emissions \_\_\_\_\_ of \_\_\_\_\_

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: <b>lb/hour      tons/year</b>
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

**F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION –  
POTENTIAL/ESTIMATED FUGITIVE EMISSIONS**

(Optional for unregulated emissions units.)

**Potential/Estimated Fugitive Emissions**

**Complete for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.**

1. Pollutant Emitted: <b>PM10</b>		2. Total Percent Efficiency of Control:	
3. Potential Emissions: <b>115.1 lb/hour                      504.1 tons/year</b>		4. Synthetically Limited? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
5. Range of Estimated Fugitive Emissions (as applicable): to                      tons/year			
6. Emission Factor: <b>93% of PM</b>  Reference: <b>Test data</b>		7. Emissions Method Code: <b>1</b>	
8.a. Baseline Actual Emissions (if required): tons/year		8.b. Baseline 24-month Period: From:                      To:	
9.a. Projected Actual Emissions (if required): tons/year		9.b. Projected Monitoring Period: <input type="checkbox"/> 5 years <input type="checkbox"/> 10 years	
10. Calculation of Emissions: <b>123.8 lb/hr x 0.93 = 115.1 lb/hr</b> <b>542.0 TPY x 0.93 = 504.1 TPY</b>			
11. Potential Fugitive and Actual Emissions Comment: <b>Maximum emissions representative of bagasse firing.</b>			



**EMISSIONS UNIT INFORMATION**

**POLLUTANT DETAIL INFORMATION**

Section [1]  
Boiler No. 1

Page [2] of [6]  
Particulate Matter - PM10

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -  
ALLOWABLE EMISSIONS**

Complete if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

**Allowable Emissions** Allowable Emissions \_\_\_\_ of \_\_\_\_

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour                      tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

**Allowable Emissions** Allowable Emissions \_\_\_\_ of \_\_\_\_

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour                      tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

**Allowable Emissions** Allowable Emissions \_\_\_\_ of \_\_\_\_

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour                      tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

**EMISSIONS UNIT INFORMATION**

**POLLUTANT DETAIL INFORMATION**

Section [1]  
Boiler No. 1

Page [3] of [6]  
Sulfur Dioxide

**F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION –  
POTENTIAL/ESTIMATED FUGITIVE EMISSIONS**

(Optional for unregulated emissions units.)

Potential/Estimated Fugitive Emissions

Complete for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.

1. Pollutant Emitted: <b>SO2</b>		2. Total Percent Efficiency of Control:	
3. Potential Emissions: 29.7 lb/hour      130.1 tons/year		4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
5. Range of Estimated Fugitive Emissions (as applicable): to      tons/year			
6. Emission Factor: <b>0.06 lb/MMBtu and 0.05% of S Oil</b>  Reference: <b>Industry Test Data</b>		7. Emissions Method Code: <b>1</b>	
8.a. Baseline Actual Emissions (if required): tons/year		8.b. Baseline 24-month Period: From:      To:	
9.a. Projected Actual Emissions (if required): tons/year		9.b. Projected Monitoring Period: <input type="checkbox"/> 5 years <input type="checkbox"/> 10 years	
10. Calculation of Emissions: Bagasse: 495 MMBtu/hr x 0.06 lb/MMBtu = 29.7 lb/hr Fuel Oil: 130 MMBtu/hr x 0.053 lb/MMBtu = 6.9 lb/hr  Annual: 29.7 lb/hr x 8,760 hr/yr x ton/2,000 lb= 130.1 TPY			
11. Potential Fugitive and Actual Emissions Comment: See Attachment UC-EU1-F1.10 for potential emissions due to fuel oil firing. Fuel oil emission factor of 0.053 lb/MMBtu is based on a density of 7.2 lb/gal, heating value of 135,000 Btu/gal, and sulfur content of 0.05 percent by weight.			

**EMISSIONS UNIT INFORMATION**

**POLLUTANT DETAIL INFORMATION**

Section [1]  
Boiler No. 1

Page [3] of [6]  
Sulfur Dioxide

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -  
ALLOWABLE EMISSIONS**

**Complete if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.**

**Allowable Emissions** Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: <b>OTHER</b>	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: <b>0.05% sulfur oil</b>	4. Equivalent Allowable Emissions: <b>6.9 lb/hour                      22.2 tons/year</b>
5. Method of Compliance: <b>Fuel oil analysis.</b>	
6. Allowable Emissions Comment (Description of Operating Method): <b>Requested limit. Emissions representative of fuel oil firing. Annual emissions based on 6,000,000 gallons per any consecutive 12 months. See Attachment UC-EU1-F1.10 for calculations.</b>	

**Allowable Emissions** Allowable Emissions \_\_\_\_ of \_\_\_\_

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour                      tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

**Allowable Emissions** Allowable Emissions \_\_\_\_ of \_\_\_\_

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour                      tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

**EMISSIONS UNIT INFORMATION**

**POLLUTANT DETAIL INFORMATION**

Section [1]  
Boiler No. 1

Page [4] of [6]  
Nitrogen Oxides

**F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION –  
POTENTIAL/ESTIMATED FUGITIVE EMISSIONS**

**(Optional for unregulated emissions units.)**

**Potential/Estimated Fugitive Emissions**

**Complete for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.**

1. Pollutant Emitted: <b>NOx</b>		2. Total Percent Efficiency of Control:	
3. Potential Emissions: <b>99.0 lb/hour                      433.6 tons/year</b>		4. Synthetically Limited? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
5. Range of Estimated Fugitive Emissions (as applicable): to                      tons/year			
6. Emission Factor: <b>0.20 lb/MMBtu</b>  Reference: <b>Industry test data</b>		7. Emissions Method Code: <b>1</b>	
8.a. Baseline Actual Emissions (if required): tons/year		8.b. Baseline 24-month Period: From:                      To:	
9.a. Projected Actual Emissions (if required): tons/year		9.b. Projected Monitoring Period: <input type="checkbox"/> 5 years <input type="checkbox"/> 10 years	
10. Calculation of Emissions: <b>Bagasse: 0.20 lb/MMBtu x 495 MMBtu/hr = 99.0 lb/hr</b> <b>99.0 lb/hr x 8,760 hr/yr x ton/2,000 lb = 433.6 TPY</b>  <b>Fuel oil: 0.17 lb/MMBtu x 130 MMBtu/hr = 22.1 lb/hr</b> <b>834,000 MMBtu/yr x 0.17 lb/MMBtu x ton/2,000 lb = 70.9 TPY</b>			
11. Potential Fugitive and Actual Emissions Comment: <b>See Attachment UC-EU1-F1.10 for potential emissions due to fuel oil firing.</b>			

**EMISSIONS UNIT INFORMATION**

**POLLUTANT DETAIL INFORMATION**

Section [1]  
Boiler No. 1

Page [4] of [6]  
Nitrogen Oxides

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -  
ALLOWABLE EMISSIONS**

Complete if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions Allowable Emissions \_\_\_\_ of \_\_\_\_

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour                      tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

Allowable Emissions Allowable Emissions \_\_\_\_ of \_\_\_\_

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour                      tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

Allowable Emissions Allowable Emissions \_\_\_\_ of \_\_\_\_

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour                      tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

**EMISSIONS UNIT INFORMATION**

**POLLUTANT DETAIL INFORMATION**

Section [1]  
Boiler No. 1

Page [5] of [6]  
Carbon Monoxide

**F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION –  
POTENTIAL/ESTIMATED FUGITIVE EMISSIONS**

**(Optional for unregulated emissions units.)**

**Potential/Estimated Fugitive Emissions**

**Complete for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.**

1. Pollutant Emitted: <b>CO</b>		2. Total Percent Efficiency of Control:	
3. Potential Emissions: <b>3,217.5 lb/hour    14,092.7 tons/year</b>		4. Synthetically Limited? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
5. Range of Estimated Fugitive Emissions (as applicable): to                  tons/year			
6. Emission Factor: <b>6.5 lb/MMBtu</b>  Reference: <b>Industry test data</b>		7. Emissions Method Code: <b>1</b>	
8.a. Baseline Actual Emissions (if required): tons/year		8.b. Baseline 24-month Period: From:                  To:	
9.a. Projected Actual Emissions (if required): tons/year		9.b. Projected Monitoring Period: <input type="checkbox"/> 5 years <input type="checkbox"/> 10 years	
10. Calculation of Emissions: <b>Bagasse: 6.5 lb/MMBtu x 495 MMBtu/hr = 3,217.5 lb/hr</b> <b>3,217.5 lb/hr x 8,760 hr/yr / 2,000 lb/ton = 14,092.7 TPY</b>  <b>Fuel oil: 0.037 lb/MMBtu x 130 MMBtu/hr = 4.8 lb/hr</b> <b>834,000 MMBtu/yr x 0.037 lb/MMBtu x ton/2,000 lb = 15.4 TPY</b>			
11. Potential Fugitive and Actual Emissions Comment: <b>See Attachment UC-EU1-F1.10 for potential emissions due to fuel oil firing.</b>			

**EMISSIONS UNIT INFORMATION**

**POLLUTANT DETAIL INFORMATION**

Section [1]  
Boiler No.1

Page [5] of [6]  
Carbon Monoxide

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -  
ALLOWABLE EMISSIONS**

**Complete if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.**

**Allowable Emissions** Allowable Emissions \_\_\_\_ of \_\_\_\_

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour                      tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

**Allowable Emissions** Allowable Emissions \_\_\_\_ of \_\_\_\_

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour                      tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

**Allowable Emissions** Allowable Emissions \_\_\_\_ of \_\_\_\_

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour                      tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

**EMISSIONS UNIT INFORMATION**

**POLLUTANT DETAIL INFORMATION**

Section [1]  
Boiler No. 1

Page [6] of [6]  
Volatile Organic Compounds

**F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION –  
POTENTIAL/ESTIMATED FUGITIVE EMISSIONS**

**(Optional for unregulated emissions units.)**

**Potential/Estimated Fugitive Emissions**

**Complete for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.**

1. Pollutant Emitted: <b>VOC</b>		2. Total Percent Efficiency of Control:	
3. Potential Emissions: <b>742.5 lb/hour      3,252.2 tons/year</b>		4. Synthetically Limited? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
5. Range of Estimated Fugitive Emissions (as applicable): to      tons/year			
6. Emission Factor: <b>1.50 lb/MMBtu</b>  Reference: <b>Industry test data</b>		7. Emissions Method Code: <b>1</b>	
8.a. Baseline Actual Emissions (if required): tons/year		8.b. Baseline 24-month Period: From:      To:	
9.a. Projected Actual Emissions (if required): tons/year		9.b. Projected Monitoring Period: <input type="checkbox"/> 5 years <input type="checkbox"/> 10 years	
10. Calculation of Emissions: <b>Bagasse: 1.50 lb/MMBtu x 495 MMBtu/hr = 742.5 lb/hr</b> <b>742.5 lb/hr x 8,760 hr/yr / 2,000 lb/ton = 3,252.2 TPY</b>  <b>Fuel oil: 0.0015 lb/MMBtu x 130 MMBtu/hr = 0.2 lb/hr</b> <b>834,000 MMBtu/yr x 0.0015 lb/MMBtu x ton/2,000 lb = 0.62 TPY</b>			
11. Potential Fugitive and Actual Emissions Comment: <b>See Attachment UC-EU1-F1.10 for potential emissions due to fuel oil firing.</b>			



**EMISSIONS UNIT INFORMATION**

**POLLUTANT DETAIL INFORMATION**

Section [1]  
Boiler No. 1

Page [6] of [6]  
Volatile Organic Compounds

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -  
ALLOWABLE EMISSIONS**

**Complete if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.**

**Allowable Emissions** Allowable Emissions \_\_\_\_ of \_\_\_\_

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour                      tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

**Allowable Emissions** Allowable Emissions \_\_\_\_ of \_\_\_\_

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour                      tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

**Allowable Emissions** Allowable Emissions \_\_\_\_ of \_\_\_\_

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour                      tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

**EMISSIONS UNIT INFORMATION**

Section [1]

Boiler No. 1

**G. VISIBLE EMISSIONS INFORMATION**

Complete if this emissions unit is or would be subject to a unit-specific visible emissions limitation.

**Visible Emissions Limitation:** Visible Emissions Limitation 1 of 1

1. Visible Emissions Subtype: <b>VE30</b>	2. Basis for Allowable Opacity: <input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other
3. Allowable Opacity: Normal Conditions: <b>30 %</b> Exceptional Conditions: <b>40 %</b> Maximum Period of Excess Opacity Allowed: <b>2 min/hour</b>	
4. Method of Compliance: <b>DEP Method 9</b>	
5. Visible Emissions Comment: <b>Permit No. 0510003-017-AV and 0510003-027-AC, and Rule 62-296.410(1)(b)1., F.A.C.</b>	

**Visible Emissions Limitation:** Visible Emissions Limitation \_\_\_\_ of \_\_\_\_

1. Visible Emissions Subtype:	2. Basis for Allowable Opacity: <input type="checkbox"/> Rule <input type="checkbox"/> Other
3. Allowable Opacity: Normal Conditions:                      %                      Exceptional Conditions:                      % Maximum Period of Excess Opacity Allowed:                      min/hour	
4. Method of Compliance:	
5. Visible Emissions Comment:	

**EMISSIONS UNIT INFORMATION**

Section [1]

Boiler No. 1

**H. CONTINUOUS MONITOR INFORMATION**

Complete if this emissions unit is or would be subject to continuous monitoring.

**Continuous Monitoring System:** Continuous Monitor 1 of 6

1. Parameter Code: <b>PRS</b>	2. Pollutant(s):
3. CMS Requirement:	<input type="checkbox"/> Rule <input checked="" type="checkbox"/> Other
4. Monitor Information... Manufacturer: <b>Custom Design</b> Model Number: Serial Number:	
5. Installation Date:	6. Performance Specification Test Date:
7. Continuous Monitor Comment: <b>Monitors pressure drop across wet scrubber. Monitored to ensure proper operation of scrubber. Permit No. 0510003-017-AV.</b>	

**Continuous Monitoring System:** Continuous Monitor 2 of 6

1. Parameter Code: <b>FLOW</b>	2. Pollutant(s):
3. CMS Requirement:	<input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other
4. Monitor Information... Manufacturer: <b>ITT Barton or equivalent</b> Model Number: <b>Flowco F500</b> Serial Number: <b>See Comment</b>	
5. Installation Date:	6. Performance Specification Test Date:
7. Continuous Monitor Comment: <b>Permit No. 0510003-017-AV. Monitors fuel oil flow to Boiler No. 1. No serial # or installation date provided because monitors are routinely replaced to ensure optimum performance.</b>	

# EMISSIONS UNIT INFORMATION

Section [1]

Boiler No. 1

## H. CONTINUOUS MONITOR INFORMATION

Complete if this emissions unit is or would be subject to continuous monitoring.

**Continuous Monitoring System:** Continuous Monitor 3 of 6

1. Parameter Code: <b>Nozzle Pressure</b>	2. Pollutant(s):
3. CMS Requirement:	<input type="checkbox"/> Rule <input checked="" type="checkbox"/> Other
4. Monitor Information... Manufacturer: <b>ABB-Kent Taylor or equivalent</b> Model Number: <b>621G</b> Serial Number:	
5. Installation Date:	6. Performance Specification Test Date:
7. Continuous Monitor Comment: <b>Monitors wet scrubber spray nozzle pressure. Permit No. 0510003-017-AV.</b>	

**Continuous Monitoring System:** Continuous Monitor 4 of 6

1. Parameter Code: <b>Steam Temp</b>	2. Pollutant(s):
3. CMS Requirement:	<input type="checkbox"/> Rule <input checked="" type="checkbox"/> Other
4. Monitor Information... Manufacturer: <b>Preferred Instruments or equivalent</b> Model Number: <b>PCC-III Controller</b> Serial Number:	
5. Installation Date:	6. Performance Specification Test Date:
7. Continuous Monitor Comment: <b>Monitors steam temperature. Permit No. 0510003-017-AV.</b>	

**EMISSIONS UNIT INFORMATION**

Section [1]

Boiler No. 1

**H. CONTINUOUS MONITOR INFORMATION**

Complete if this emissions unit is or would be subject to continuous monitoring.

**Continuous Monitoring System:** Continuous Monitor 5 of 6

1. Parameter Code: <b>Steam Pressure</b>	2. Pollutant(s):
3. CMS Requirement:	<input type="checkbox"/> Rule <input checked="" type="checkbox"/> Other
4. Monitor Information... Manufacturer: <b>ABB-Kent Taylor or equivalent</b> Model Number: <b>621G</b> Serial Number:	
5. Installation Date:	6. Performance Specification Test Date:
7. Continuous Monitor Comment: <b>Monitors steam pressure. Permit No. 0510003-017-AV.</b>	

**Continuous Monitoring System:** Continuous Monitor 6 of 6

1. Parameter Code: <b>FLOW</b>	2. Pollutant(s):
3. CMS Requirement:	<input type="checkbox"/> Rule <input checked="" type="checkbox"/> Other
4. Monitor Information... Manufacturer: <b>ABB-Kent Taylor or equivalent</b> Model Number: <b>621D</b> Serial Number:	
5. Installation Date:	6. Performance Specification Test Date:
7. Continuous Monitor Comment: <b>Monitors steam flow rate. Permit No. 0510003-017-AV.</b>	

# EMISSIONS UNIT INFORMATION

Section [1]

Boiler No. 1

## I. EMISSIONS UNIT ADDITIONAL INFORMATION

### Additional Requirements for All Applications, Except as Otherwise Stated

1. Process Flow Diagram (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Previously Submitted, Date <b>05/2005</b>
2. Fuel Analysis or Specification (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) <input checked="" type="checkbox"/> Attached, Document ID: <b>UC-EU1-I2</b> <input type="checkbox"/> Previously Submitted, Date _____
3. Detailed Description of Control Equipment (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Previously Submitted, Date <b>05/2005</b>
4. Procedures for Startup and Shutdown (Required for all operation permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Previously Submitted, Date _____ <input checked="" type="checkbox"/> Not Applicable (construction application)
5. Operation and Maintenance Plan (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Previously Submitted, Date _____ <input checked="" type="checkbox"/> Not Applicable
6. Compliance Demonstration Reports/Records <input type="checkbox"/> Attached, Document ID: _____ Test Date(s)/Pollutant(s) Tested: _____ <input type="checkbox"/> Previously Submitted, Date: _____ Test Date(s)/Pollutant(s) Tested: _____ <input type="checkbox"/> To be Submitted, Date (if known): _____ Test Date(s)/Pollutant(s) Tested: _____ <input checked="" type="checkbox"/> Not Applicable Note: For FESOP applications, all required compliance demonstration records/reports must be submitted at the time of application. For Title V air operation permit applications, all required compliance demonstration reports/records must be submitted at the time of application, or a compliance plan must be submitted at the time of application.
7. Other Information Required by Rule or Statute <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable

## EMISSIONS UNIT INFORMATION

Section [1]

Boiler No. 1

### Additional Requirements for Air Construction Permit Applications

1. Control Technology Review and Analysis (Rules 62-212.400(10) and 62-212.500(7), F.A.C.; 40 CFR 63.43(d) and (e)) <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
2. Good Engineering Practice Stack Height Analysis (Rule 62-212.400(4)(d), F.A.C., and Rule 62-212.500(4)(f), F.A.C.) <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
3. Description of Stack Sampling Facilities (Required for proposed new stack sampling facilities only) <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable

### Additional Requirements for Title V Air Operation Permit Applications

1. Identification of Applicable Requirements <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
2. Compliance Assurance Monitoring <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
3. Alternative Methods of Operation <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
4. Alternative Modes of Operation (Emissions Trading) <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
5. Acid Rain Part Application <input type="checkbox"/> Certificate of Representation (EPA Form No. 7610-1) <input type="checkbox"/> Copy Attached, Document ID: _____ <input type="checkbox"/> Acid Rain Part (Form No. 62-210.900(1)(a)) <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Previously Submitted, Date: _____ <input type="checkbox"/> Repowering Extension Plan (Form No. 62-210.900(1)(a)1.) <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Previously Submitted, Date: _____ <input type="checkbox"/> New Unit Exemption (Form No. 62-210.900(1)(a)2.) <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Previously Submitted, Date: _____ <input type="checkbox"/> Retired Unit Exemption (Form No. 62-210.900(1)(a)3.) <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Previously Submitted, Date: _____ <input type="checkbox"/> Phase II NOx Compliance Plan (Form No. 62-210.900(1)(a)4.) <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Previously Submitted, Date: _____ <input type="checkbox"/> Phase II NOx Averaging Plan (Form No. 62-210.900(1)(a)5.) <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Previously Submitted, Date: _____ <input type="checkbox"/> Not Applicable

**EMISSIONS UNIT INFORMATION**

**Section [1]**

**Boiler No. 1**

**Additional Requirements Comment**



**ATTACHMENT UC-EU1-F1.10**

**POTENTIAL EMISSIONS  
DUE TO FUEL OIL FIRING**

ATTACHMENT UC-EU1-F1.10  
 FUTURE POTENTIAL EMISSIONS DUE TO FUEL OIL FIRING BOILER NO. 1  
 U. S. Sugar Corporation Clewiston

Regulated Pollutant	No. 2 Fuel Oil Combustion					
	Emission Factor (lb/MMBtu)	Ref.	Activity Factor		Hourly Emissions (lb/hr)	Annual Emissions (TPY)
			Hourly <sup>a</sup> MMBtu/hr	Annual <sup>b</sup> MMBtu/yr		
Particulate Matter (PM)	0.015	1	130	834,000	1.9	6.2
Particulate Matter (PM <sub>10</sub> )	0.007	2	130	834,000	1.0	3.1
Sulfur dioxide (SO <sub>2</sub> )	0.053	3	130	834,000	6.9	22.2
Nitrogen oxides (NO <sub>x</sub> )	0.17	4	130	834,000	22.1	70.9
Carbon monoxide (CO)	0.037	1	130	834,000	4.8	15.4
Volatile Organic Compounds (VOC)	1.5E-03	1	130	834,000	0.2	0.62
Sulfuric acid mist (SAM)	0.0026	1	130	834,000	0.3	1.1
Lead (Pb)	9.0E-06	5	130	834,000	1.2E-03	3.8E-05
Beryllium (Be)	3.0E-06	5	130	834,000	3.9E-04	1.3E-05
Mercury (Hg)	3.0E-06	5	130	834,000	3.9E-04	1.3E-03

## References:

- Factors for No. 2 fuel oil combustion: AP-42 Tables 1.3-1 and 1.3-3 (9/98). For sulfuric acid mist, factor shown is for SO<sub>3</sub>. Convert to H<sub>2</sub>SO<sub>4</sub> by multiplying by 98/80. Factors were converted to lb/MMBtu by dividing by 135,000 Btu/gal (min).  
 PM = 2 lb/1000 gal  
 CO = 5 lb/1000 gal  
 SO<sub>3</sub> = 5.7S lb/1000 gal, where S = 0.05      VOC = 0.2 lb/1000 gal
- Factors for distillate fuel oil, PM<sub>10</sub> is 50% of PM based on AP-42, Table 1.3-6 (9/98).
- Based on stoichiometric calculation: 7.2 lbs/gal; 135,000 Btu/gal (min); 0.05% sulfur.
- Based on stack testing conducted on Boiler No. 1 and 2 on Feb. 10-11, 2006.
- Factors for No. 2 fuel oil combustion, AP-42 Table 1.3-10 (9/98).

## Footnotes:

- <sup>a</sup> Based on maximum heat input due to No. 2 fuel oil combustion, from manufacturer specifications.
- <sup>b</sup> Based on No. 2 fuel oil usage of 6,000,000 gallons per year and heating value of 139,000 Btu/gal (max).

**ATTACHMENT UC-EU1-I2**

**FUEL ANALYSIS**

## ATTACHMENT UC-EU1-I2

## BOILER NOS. 1 AND 2

## FUEL ANALYSIS

Parameter	Fuel	
	Carbonaceous Fuel <sup>a</sup>	No. 2 Fuel Oil (0.05% S max)
Density (lb/gal)	--	7.2 <sup>c</sup>
Approximate Heating Value (Btu/lb)	3,600 <sup>b</sup>	19,910
Approximate Heating Value (Btu/gal)	--	135,000 - 139,000
<u>Ultimate Analysis (dry basis):</u>		
Carbon	48.10%	87.3% <sup>d</sup>
Hydrogen	5.90%	12.6% <sup>d</sup>
Nitrogen	0.35%	0.22% <sup>d</sup>
Oxygen	40.90%	0.04% <sup>d</sup>
Sulfur	0.08% - 0.24%	0.05%
Ash/Inorganic	0.87% - 8.4%	<0.001% <sup>c</sup>
Moisture	49% - 55%	0.05%

## Note:

<sup>a</sup> Source: Clewiston Mill fuel analysis averages.

<sup>b</sup> Wet basis for bagasse. Represents normal minimum.

<sup>c</sup> Source: Marathon Ashland Petroleum LLC; Coastal Fuels.

<sup>d</sup> Source: Perry's Chemical Engineer's Handbook. Sixth Edition, 1984.

Represents average fuel characteristics.

**ATTACHMENT UC-EU1-I7**

**OTHER INFORMATION  
REQUIRED BY RULE OR STATUTE**

**ATTACHMENT UC-EU1-I7****IDENTIFICATION OF APPLICABLE REQUIREMENTS**

62-296.410(1)(b), F.A.C.: Carbonaceous Fuel Burning Equipment  
62-296.410(3), F.A.C.: Carbonaceous Fuel Burning Equipment  
62-297.310(1), F.A.C.: General Compliance Test Requirements  
62-297.310(2)(b), F.A.C.: General Compliance Test Requirements  
62-297.310(3), F.A.C.: General Compliance Test Requirements  
62-297.310(4), F.A.C.: General Compliance Test Requirements  
62-297.310(5), F.A.C.: General Compliance Test Requirements  
62-297.310(6), F.A.C.: General Compliance Test Requirements  
62-297.310(7)(a)3., F.A.C.: General Compliance Test Requirements  
62-297.310(7)(a)4., F.A.C.: General Compliance Test Requirements  
62-297.310(7)(a)5., F.A.C.: General Compliance Test Requirements  
62-297.310(7)(a)9., F.A.C.: General Compliance Test Requirements  
62-297.310(7)(a)10., F.A.C.: General Compliance Test Requirements  
62-297.310(8), F.A.C.: General Compliance Test Requirements  
62-297.401(1), F.A.C.: EPA Test Method 1  
62-297.401(2), F.A.C.: EPA Test Method 2  
62-297.401(3), F.A.C.: EPA Test Method 3  
62-297.401(4), F.A.C.: EPA Test Method 4  
62-297.401(5), F.A.C.: EPA Test Method 5  
62-297.401(6), F.A.C.: EPA Test Method 6  
62-297.401(6)(c), F.A.C.: EPA Test Method 6C  
62-297.401(7), F.A.C.: EPA Test Method 7  
62-297.401(7)(e), F.A.C.: EPA Test Method 7E  
62-297.401(8), F.A.C.: EPA Test Method 8  
62-297.401(9), F.A.C.: EPA Test Method 9  
62-297.401(10), F.A.C.: EPA Test Method 10

62-297.401(18), F.A.C.: EPA Test Method 18

62-297.401(25)(a), F.A.C.: EPA Test Method 25A

40 CFR 63.1 – 63.16 – Subpart A – General Provisions: Boiler No. 1 is subject to the notification requirements of Subpart DDDDD.

40 CFR 63.7485 – Subpart DDDDD – Applicability: Boiler No. 1 is an industrial boiler of size > 10 MMBtu/hr located at a major source of HAPs.

40 CFR 63.7490 – Subpart DDDDD – Applicability: Boiler No. 1 is subject to the requirements of Subpart DDDDD for existing boilers.

40 CFR 63.7495 – Subpart DDDDD – Compliance Dates – Boiler No. 1 must meet notification requirements and comply by September 13, 2007.

40 CFR 63.7499 – Subpart DDDDD – Subcategories: Boiler No. 1 is in the large solid fuel subcategory.

40 CFR 63.7506 – Subpart DDDDD – Limited Requirements: Boiler No. 1 must only meet the notification requirements of 63.9(b) at this time.

40 CFR 63.7545 – Subpart DDDDD – Notifications: Boiler No. 1 must submit the required notification by March 12, 2005.

## EMISSIONS UNIT INFORMATION

Section [2]

Boiler No. 2

### III. EMISSIONS UNIT INFORMATION

**Title V Air Operation Permit Application** - For Title V air operation permitting only, emissions units are classified as regulated, unregulated, or insignificant. If this is an application for Title V air operation permit, a separate Emissions Unit Information Section (including subsections A through I as required) must be completed for each regulated and unregulated emissions unit addressed in this application for air permit. Some of the subsections comprising the Emissions Unit Information Section of the form are optional for unregulated emissions units. Each such subsection is appropriately marked. Insignificant emissions units are required to be listed at Section II, Subsection C.

**Air Construction Permit or FESOP Application** - For air construction permitting or federally enforceable state air operation permitting, emissions units are classified as either subject to air permitting or exempt from air permitting. The concept of an "unregulated emissions unit" does not apply. If this is an application for air construction permit or FESOP, a separate Emissions Unit Information Section (including subsections A through I as required) must be completed for each emissions unit subject to air permitting addressed in this application for air permit. Emissions units exempt from air permitting are required to be listed at Section II, Subsection C.

**Air Construction Permit and Revised/Renewal Title V Air Operation Permit Application** - Where this application is used to apply for both an air construction permit and a revised/renewal Title V air operation permit, each emissions unit is classified as either subject to air permitting or exempt from air permitting for air construction permitting purposes and as regulated, unregulated, or insignificant for Title V air operation permitting purposes. **The air construction permitting classification must be used to complete the Emissions Unit Information Section of this application for air permit.** A separate Emissions Unit Information Section (including subsections A through I as required) must be completed for each emissions unit subject to air permitting addressed in this application for air permit. Emissions units exempt from air construction permitting and insignificant emissions units are required to be listed at Section II, Subsection C.

If submitting the application form in hard copy, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application must be indicated in the space provided at the top of each page.



**EMISSIONS UNIT INFORMATION**

Section [2]

Boiler No. 2

**A. GENERAL EMISSIONS UNIT INFORMATION**

**Title V Air Operation Permit Emissions Unit Classification**

1. Regulated or Unregulated Emissions Unit? (Check one, if applying for an initial, revised or renewal Title V air operation permit. Skip this item if applying for an air construction permit or FESOP only.)

The emissions unit addressed in this Emissions Unit Information Section is a regulated emissions unit.

The emissions unit addressed in this Emissions Unit Information Section is an unregulated emissions unit.

**Emissions Unit Description and Status**

1. Type of Emissions Unit Addressed in this Section: (Check one)

This Emissions Unit Information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).

This Emissions Unit Information Section addresses, as a single emissions unit, a group of process or production units and activities which has at least one definable emission point (stack or vent) but may also produce fugitive emissions.

This Emissions Unit Information Section addresses, as a single emissions unit, one or more process or production units and activities which produce fugitive emissions only.

2. Description of Emissions Unit Addressed in this Section:  
**Boiler No. 2**

3. Emissions Unit Identification Number: **002**

4. Emissions Unit Status Code: <b>A</b>	5. Commence Construction Date:	6. Initial Startup Date:	7. Emissions Unit Major Group SIC Code: <b>20</b>	8. Acid Rain Unit? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
--	--------------------------------	--------------------------	--	--

9. Package Unit:  
Manufacturer: \_\_\_\_\_ Model Number: \_\_\_\_\_

10. Generator Nameplate Rating: \_\_\_\_\_ MW

11. Emissions Unit Comment: **Vibrating grate boiler fired by carbonaceous fuel and No. 2 fuel oil with a maximum sulfur content of 0.05% by weight.**

**EMISSIONS UNIT INFORMATION**

**Section [2]**

**Boiler No. 2**

**Emissions Unit Control Equipment**

1. Control Equipment/Method(s) Description:  
**Joy Turbulair Impingement Scrubber, Size 125, Type D**

2. Control Device or Method Code(s): **001**

## EMISSIONS UNIT INFORMATION

Section [2]

Boiler No. 2

### B. EMISSIONS UNIT CAPACITY INFORMATION

(Optional for unregulated emissions units.)

#### Emissions Unit Operating Capacity and Schedule

1. Maximum Process or Throughput Rate:		
2. Maximum Production Rate: <b>215,000 lb/hr steam</b>		
3. Maximum Heat Input Rate: <b>447 million Btu/hr</b>		
4. Maximum Incineration Rate:	pounds/hr	
	tons/day	
5. Requested Maximum Operating Schedule:		
	<b>24 hours/day</b>	<b>7 days/week</b>
	<b>52 weeks/year</b>	<b>8,760 hours/year</b>
6. Operating Capacity/Schedule Comment: <b>Maximum heat input based on 1-hour maximum steam rate (above) for carbonaceous fuel of 215,000 lb/hr steam. Maximum heat input for No. 2 fuel oil is 130 MMBtu/hr and 6,000,000 gal/yr.</b>		

**EMISSIONS UNIT INFORMATION**

Section [2]  
Boiler No. 2

**C. EMISSION POINT (STACK/VENT) INFORMATION**  
(Optional for unregulated emissions units.)

**Emission Point Description and Type**

1. Identification of Point on Plot Plan or Flow Diagram: <b>BLR-2</b>		2. Emission Point Type Code:	
3. Descriptions of Emission Points Comprising this Emissions Unit for VE Tracking:			
4. ID Numbers or Descriptions of Emission Units with this Emission Point in Common:			
5. Discharge Type Code: <b>V</b>	6. Stack Height: <b>213 feet</b>	7. Exit Diameter: <b>8.0 feet</b>	
8. Exit Temperature: <b>150 °F</b>	9. Actual Volumetric Flow Rate: <b>250,000 acfm</b>	10. Water Vapor: <b>%</b>	
11. Maximum Dry Standard Flow Rate: dscfm		12. Nonstack Emission Point Height: feet	
13. Emission Point UTM Coordinates... Zone: East (km): North (km):		14. Emission Point Latitude/Longitude... Latitude (DD/MM/SS) Longitude (DD/MM/SS)	
15. Emission Point Comment:			

**EMISSIONS UNIT INFORMATION**

Section [2]

Boiler No. 2

**D. SEGMENT (PROCESS/FUEL) INFORMATION****Segment Description and Rate: Segment 1 of 2**

1. Segment Description (Process/Fuel Type): <b>External combustion boilers; Industrial; Bagasse; All boiler sizes</b>		
2. Source Classification Code (SCC): <b>1-02-011-01</b>	3. SCC Units: <b>Tons burned</b>	
4. Maximum Hourly Rate: <b>62.08</b>	5. Maximum Annual Rate: <b>543,850</b>	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur: <b>0.09 (dry basis)</b>	8. Maximum % Ash: <b>8.4 (dry basis)</b>	9. Million Btu per SCC Unit: <b>7.2</b>
10. Segment Comment: <b>Based on 447 MMBtu/hr and 3,600 Btu/lb wet bagasse. Wet bagasse averages approximately 52-percent moisture.</b>		

**Segment Description and Rate: Segment 2 of 2**

1. Segment Description (Process/Fuel Type): <b>External combustion boilers; Industrial; Bagasse; Distillate Oil; Grades 1 and 2.</b>		
2. Source Classification Code (SCC): <b>1-02-005-01</b>	3. SCC Units: <b>1,000 Gallons Burned</b>	
4. Maximum Hourly Rate: <b>0.963</b>	5. Maximum Annual Rate: <b>6,000</b>	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur: <b>0.05</b>	8. Maximum % Ash:	9. Million Btu per SCC Unit: <b>135</b>
10. Segment Comment: <b>Maximum hourly and annual rates based on 130 MMBtu/hr and 6,000,000 gallons of No. 2 fuel oil per year. Also includes facility generated on-spec used oil and up to 500 cubic yards per season of petroleum contaminated soils.</b>		

**EMISSIONS UNIT INFORMATION**

Section [2]

Boiler No. 2

**E. EMISSIONS UNIT POLLUTANTS**

**List of Pollutants Emitted by Emissions Unit**

1. Pollutant Emitted	2. Primary Control Device Code	3. Secondary Control Device Code	4. Pollutant Regulatory Code
PM	001		EL
PM10	001		NS
SO2	001		EL
NOx			NS
CO			NS
VOC			NS
SAM			NS
PB	001		NS
HAPs (Total Hazardous Air Pollutants)			NS
H001 (Acetaldehyde)			NS
H006 (Acrolein)			NS
H017 (Benzene)			NS
H021 (Beryllium)	001		NS
H052 (p-cresol)			NS
H058 (Dibenzofurans)			NS
H095 (Formaldehyde)			NS
H106 (Hydrogen Chloride)			NS
H114 (Mercury)	001		NS
H132 (Naphthalene)			NS
H144 (Phenol)			NS
H151 (POMs)			NS
H163 (Styrene)			NS
H169 (Toluene)			NS

**EMISSIONS UNIT INFORMATION**

**POLLUTANT DETAIL INFORMATION**

Section [2]  
Boiler No. 2

Page [1] of [6]  
Particulate Matter - Total

**F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION –  
POTENTIAL/ESTIMATED FUGITIVE EMISSIONS**

(Optional for unregulated emissions units.)

**Potential/Estimated Fugitive Emissions**

Complete for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.

1. Pollutant Emitted: <b>PM</b>		2. Total Percent Efficiency of Control:	
3. Potential Emissions: <b>111.8 lb/hour                      490 tons/year</b>		4. Synthetically Limited? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
5. Range of Estimated Fugitive Emissions (as applicable): to                      tons/year			
6. Emission Factor: <b>0.25 lb/MMBtu</b>  Reference: <b>Permit No. 0510003-017-AV</b>		7. Emissions Method Code: <b>0</b>	
8.a. Baseline Actual Emissions (if required): tons/year		8.b. Baseline 24-month Period: From:                      To:	
9.a. Projected Actual Emissions (if required): tons/year		9.b. Projected Monitoring Period: <input type="checkbox"/> 5 years <input type="checkbox"/> 10 years	
10. Calculation of Emissions: <b>Bagasse: 447 MMBtu/hr x 0.25 lb/MMBtu = 111.8 lb/hr</b> <b>111.8 lb/hr x 8,760 hr/yr x ton/2,000 lb = 490 TPY</b>			
11. Potential Fugitive and Actual Emissions Comment: <b>Maximum emissions representative of bagasse firing.</b>			

**EMISSIONS UNIT INFORMATION**

**POLLUTANT DETAIL INFORMATION**

Section [2]  
Boiler No. 2

Page [1] of [6]  
Particulate Matter - PM

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -  
ALLOWABLE EMISSIONS**

Complete if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

**Allowable Emissions** Allowable Emissions 1 of 2

1. Basis for Allowable Emissions Code: <b>OTHER</b>	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: <b>0.25 lb/MMBtu</b>	4. Equivalent Allowable Emissions: <b>111.8 lb/hour      490 tons/year</b>
5. Method of Compliance: <b>EPA Method 5 or 17</b>	
6. Allowable Emissions Comment (Description of Operating Method): <b>Permit No. 0510003-017-AV. Emissions representative of bagasse firing only.</b>	

**Allowable Emissions** Allowable Emissions 2 of 2

1. Basis for Allowable Emissions Code: <b>RULE</b>	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: <b>0.1 lb/MMBtu</b>	4. Equivalent Allowable Emissions: <b>13.0 lb/hour      41.7 tons/year</b>
5. Method of Compliance: <b>EPA Method 5 or 17</b>	
6. Allowable Emissions Comment (Description of Operating Method): <b>Rule 62-296.410(1)(b)2, F.A.C., and Permit No. 0510003-017-AV. Emissions representative of fuel oil firing. Annual emissions based on 6,000,000 gallons per any consecutive 12 months.</b>	

**Allowable Emissions** Allowable Emissions      of     

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: <b>lb/hour      tons/year</b>
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	



**EMISSIONS UNIT INFORMATION**

**POLLUTANT DETAIL INFORMATION**

Section [2]  
Boiler No. 2

Page [2] of [6]  
Particulate Matter - PM10

**FI. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION –  
POTENTIAL/ESTIMATED FUGITIVE EMISSIONS**

**(Optional for unregulated emissions units.)**

**Potential/Estimated Fugitive Emissions**

**Complete for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.**

1. Pollutant Emitted: <b>PM10</b>		2. Total Percent Efficiency of Control:	
3. Potential Emissions: <b>104.0 lb/hour                      455.7 tons/year</b>		4. Synthetically Limited? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
5. Range of Estimated Fugitive Emissions (as applicable): to                      tons/year			
6. Emission Factor: <b>93% of PM</b>  Reference: <b>Test data</b>		7. Emissions Method Code: <b>1</b>	
8.a. Baseline Actual Emissions (if required): tons/year		8.b. Baseline 24-month Period: From:                      To:	
9.a. Projected Actual Emissions (if required): tons/year		9.b. Projected Monitoring Period: <input type="checkbox"/> 5 years <input type="checkbox"/> 10 years	
10. Calculation of Emissions: <b>111.8 lb/hr x 0.93 = 104.0 lb/hr</b>  <b>490 TPY x 0.93 = 455.7 TPY</b>			
11. Potential Fugitive and Actual Emissions Comment: <b>Maximum emissions representative of bagasse firing.</b>			

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -  
ALLOWABLE EMISSIONS**

Complete if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

**Allowable Emissions** Allowable Emissions \_\_\_\_ of \_\_\_\_

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour                      tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

**Allowable Emissions** Allowable Emissions \_\_\_\_ of \_\_\_\_

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour                      tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

**Allowable Emissions** Allowable Emissions \_\_\_\_ of \_\_\_\_

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour                      tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

**EMISSIONS UNIT INFORMATION**

**POLLUTANT DETAIL INFORMATION**

Section [2]  
Boiler No. 2

Page [3] of [6]  
Sulfur Dioxide

**F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION –  
POTENTIAL/ESTIMATED FUGITIVE EMISSIONS**

(Optional for unregulated emissions units.)

**Potential/Estimated Fugitive Emissions**

Complete for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.

1. Pollutant Emitted: <b>SO2</b>		2. Total Percent Efficiency of Control:	
3. Potential Emissions: <b>26.82 lb/hour                      117.5 tons/year</b>		4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
5. Range of Estimated Fugitive Emissions (as applicable): to                      tons/year			
6. Emission Factor: <b>0.06 lb/MMBtu and 0.05% of S oil.</b>  Reference: <b>Industry test data</b>		7. Emissions Method Code: <b>1</b>	
8.a. Baseline Actual Emissions (if required): tons/year		8.b. Baseline 24-month Period: From:                      To:	
9.a. Projected Actual Emissions (if required): tons/year		9.b. Projected Monitoring Period: <input type="checkbox"/> 5 years <input type="checkbox"/> 10 years	
10. Calculation of Emissions: <b>Bagasse: 447 MMBtu/hr x 0.06 lb/MMBtu = 26.82 lb/hr</b> <b>Fuel Oil: 130 MMBtu/hr x 0.053 lb/MMBtu = 6.9 lb/hr</b>  <b>Annual: 26.82 lb/hr x 8,760 hr/yr x ton/2,000 lb = 117.5 TPY</b>			
11. Potential Fugitive and Actual Emissions Comment: <b>Fuel oil based on 0.05% sulfur oil. See Attachment UC-EU2-F1.10 for potential emissions due to fuel oil firing.</b>			

**EMISSIONS UNIT INFORMATION**

**POLLUTANT DETAIL INFORMATION**

Section [2]  
Boiler No. 2

Page [3] of [6]  
Sulfur Dioxide

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -  
ALLOWABLE EMISSIONS**

Complete if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

**Allowable Emissions** Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: <b>OTHER</b>	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: <b>0.05% sulfur oil</b>	4. Equivalent Allowable Emissions: <b>6.9 lb/hour                      22.2 tons/year</b>
5. Method of Compliance: <b>Fuel oil analysis</b>	
6. Allowable Emissions Comment (Description of Operating Method): <b>Requested limit. Emissions representative of fuel oil firing. Annual emissions based on 6,000,000 gallons per any consecutive 12 months. See Attachment UC-EU2-F1.10 for calculations.</b>	

**Allowable Emissions** Allowable Emissions \_\_\_\_ of \_\_\_\_

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour                      tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

**Allowable Emissions** Allowable Emissions \_\_\_\_ of \_\_\_\_

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour                      tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

**EMISSIONS UNIT INFORMATION**

**POLLUTANT DETAIL INFORMATION**

Section [2]  
Boiler No. 2

Page [4] of [6]  
Nitrogen Oxides

**F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION –  
POTENTIAL/ESTIMATED FUGITIVE EMISSIONS**

(Optional for unregulated emissions units.)

**Potential/Estimated Fugitive Emissions**

**Complete for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.**

1. Pollutant Emitted: <b>NOx</b>		2. Total Percent Efficiency of Control:	
3. Potential Emissions: <b>89.4 lb/hour                      391.6 tons/year</b>		4. Synthetically Limited? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
5. Range of Estimated Fugitive Emissions (as applicable): to                      tons/year			
6. Emission Factor: <b>0.20 lb/MMBtu</b>  Reference: <b>Industry test data</b>		7. Emissions Method Code: <b>1</b>	
8.a. Baseline Actual Emissions (if required): tons/year		8.b. Baseline 24-month Period: From:                      To:	
9.a. Projected Actual Emissions (if required): tons/year		9.b. Projected Monitoring Period: <input type="checkbox"/> 5 years <input type="checkbox"/> 10 years	
10. Calculation of Emissions: <b>Bagasse: 0.20 lb/MMBtu x 447 MMBtu/hr = 89.4 lb/hr</b> <b>89.4 lb/hr x 8,760 hr/yr x ton/2,000 lb = 391.6 TPY</b>  <b>Fuel oil: 0.17 lb/MMBtu x 130 MMBtu/hr = 22.1 lb/hr</b> <b>834,000 MMBtu/yr x 0.17 lb/MMBtu x ton/2,000 lb = 70.9 TPY</b>			
11. Potential Fugitive and Actual Emissions Comment: <b>See Attachment UC-EU2-F1.10 for potential emissions due to fuel oil firing.</b>			

**EMISSIONS UNIT INFORMATION**

**POLLUTANT DETAIL INFORMATION**

Section [2]  
Boiler No. 2

Page [4] of [6]  
Nitrogen Oxides

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -  
ALLOWABLE EMISSIONS**

**Complete if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.**

**Allowable Emissions** Allowable Emissions \_\_\_\_\_ of \_\_\_\_\_

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour                      tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

**Allowable Emissions** Allowable Emissions \_\_\_\_\_ of \_\_\_\_\_

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour                      tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

**Allowable Emissions** Allowable Emissions \_\_\_\_\_ of \_\_\_\_\_

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour                      tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

**EMISSIONS UNIT INFORMATION**

**POLLUTANT DETAIL INFORMATION**

Section [2]  
Boiler No. 2

Page [5] of [6]  
Carbon Monoxide

**F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION –  
POTENTIAL/ESTIMATED FUGITIVE EMISSIONS**

(Optional for unregulated emissions units.)

**Potential/Estimated Fugitive Emissions**

Complete for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.

1. Pollutant Emitted: <b>CO</b>		2. Total Percent Efficiency of Control:	
3. Potential Emissions: <b>2,905.5 lb/hour      12,726.1 tons/year</b>		4. Synthetically Limited? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
5. Range of Estimated Fugitive Emissions (as applicable): to                      tons/year			
6. Emission Factor: <b>6.5 lb/MMBtu</b>  Reference: <b>Industry test data</b>		7. Emissions Method Code: <b>1</b>	
8.a. Baseline Actual Emissions (if required): tons/year		8.b. Baseline 24-month Period: From:              To:	
9.a. Projected Actual Emissions (if required): tons/year		9.b. Projected Monitoring Period: <input type="checkbox"/> 5 years <input type="checkbox"/> 10 years	
10. Calculation of Emissions: <b>Bagasse: 6.5 lb/MMBtu x 447 MMBtu/hr = 2,905.5 lb/hr</b> <b>2,905.5 lb/hr x 8,760 hr/yr / 2,000 lb/ton = 12,726.1 TPY</b>  <b>Fuel oil: 0.037 lb/MMBtu x 130 MMBtu/hr = 4.8 lb/hr</b> <b>834,000 MMBtu/yr x 0.037 lb/MMBtu x ton/2,000 lb = 15.4 TPY</b>			
11. Potential Fugitive and Actual Emissions Comment: <b>See Attachment UC-EU2-F1.10 for potential emissions due to fuel oil firing.</b>			

**EMISSIONS UNIT INFORMATION**

**POLLUTANT DETAIL INFORMATION**

Section [2]  
Boiler No. 2

Page [5] of [6]  
Carbon Monoxide

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -  
ALLOWABLE EMISSIONS**

Complete if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

**Allowable Emissions** Allowable Emissions \_\_\_\_ of \_\_\_\_

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour                      tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

**Allowable Emissions** Allowable Emissions \_\_\_\_ of \_\_\_\_

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour                      tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

**Allowable Emissions** Allowable Emissions \_\_\_\_ of \_\_\_\_

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour                      tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	



**F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION –  
POTENTIAL/ESTIMATED FUGITIVE EMISSIONS**

(Optional for unregulated emissions units.)

**Potential/Estimated Fugitive Emissions**

Complete for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.

1. Pollutant Emitted: <b>VOC</b>		2. Total Percent Efficiency of Control:	
3. Potential Emissions: <b>670.5 lb/hour                      2,936.8 tons/year</b>		4. Synthetically Limited? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
5. Range of Estimated Fugitive Emissions (as applicable): to                      tons/year			
6. Emission Factor: <b>1.50 lb/MMBtu</b>  Reference: <b>Industry test data</b>		7. Emissions Method Code: <b>1</b>	
8.a. Baseline Actual Emissions (if required): tons/year		8.b. Baseline 24-month Period: From:                      To:	
9.a. Projected Actual Emissions (if required): tons/year		9.b. Projected Monitoring Period: <input type="checkbox"/> 5 years <input type="checkbox"/> 10 years	
10. Calculation of Emissions: <b>Bagasse: 1.50 lb/MMBtu x 447 MMBtu/hr = 670.5 lb/hr</b> <b>670.5 lb/hr x 8,760 hr/yr / 2,000 lb/ton = 2,936.8 TPY</b>  <b>Fuel oil: 0.0015 lb/MMBtu x 130 MMBtu/hr = 0.2 lb/hr</b> <b>834,000 MMBtu/yr x 0.015 lb/MMBtu x ton/2,000 lb = 0.62 TPY</b>			
11. Potential Fugitive and Actual Emissions Comment: <b>See Attachment UC-EU2-F1.10 for potential emissions due to fuel oil firing.</b>			

**EMISSIONS UNIT INFORMATION**Section [2]  
Boiler No. 2**POLLUTANT DETAIL INFORMATION**Page [6] of [6]  
Volatile Organic Compounds**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -  
ALLOWABLE EMISSIONS****Complete if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.****Allowable Emissions** Allowable Emissions \_\_\_\_ of \_\_\_\_

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour                      tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

**Allowable Emissions** Allowable Emissions \_\_\_\_ of \_\_\_\_

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour                      tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

**Allowable Emissions** Allowable Emissions \_\_\_\_ of \_\_\_\_

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour                      tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

**EMISSIONS UNIT INFORMATION**

Section [2]

Boiler No. 2

**G. VISIBLE EMISSIONS INFORMATION**

Complete if this emissions unit is or would be subject to a unit-specific visible emissions limitation.

**Visible Emissions Limitation:** Visible Emissions Limitation 1 of 1

1. Visible Emissions Subtype: <b>VE30</b>	2. Basis for Allowable Opacity: <input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other
3. Allowable Opacity: Normal Conditions: <b>30 %</b> Exceptional Conditions: <b>40 %</b> Maximum Period of Excess Opacity Allowed: <b>2 min/hour</b>	
4. Method of Compliance: <b>DEP Method 9</b>	
5. Visible Emissions Comment:  <b>Permit Nos. 0510003-017-AV and 0510003-027-AC, and Rule 62-296.410(1)(b)1., F.A.C.</b>	

**Visible Emissions Limitation:** Visible Emissions Limitation \_\_\_\_ of \_\_\_\_

1. Visible Emissions Subtype:	2. Basis for Allowable Opacity: <input type="checkbox"/> Rule <input type="checkbox"/> Other
3. Allowable Opacity: Normal Conditions:                      %                      Exceptional Conditions:                      % Maximum Period of Excess Opacity Allowed:                      min/hour	
4. Method of Compliance:	
5. Visible Emissions Comment:	

**EMISSIONS UNIT INFORMATION**

Section [2]

Boiler No. 2

**H. CONTINUOUS MONITOR INFORMATION**

Complete if this emissions unit is or would be subject to continuous monitoring.

**Continuous Monitoring System:** Continuous Monitor 1 of 6

1. Parameter Code: <b>PRS</b>	2. Pollutant(s):
3. CMS Requirement:	<input type="checkbox"/> Rule <input checked="" type="checkbox"/> Other
4. Monitor Information... Manufacturer: <b>Custom Design</b> Model Number: Serial Number:	
5. Installation Date:	6. Performance Specification Test Date:
7. Continuous Monitor Comment: <b>Monitors pressure drop across wet scrubber. Monitored to ensure proper operation of scrubber. Permit No. 0510003-017-AV.</b>	

**Continuous Monitoring System:** Continuous Monitor 2 of 6

1. Parameter Code: <b>FLOW</b>	2. Pollutant(s):
3. CMS Requirement:	<input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other
4. Monitor Information... Manufacturer: <b>ITT Barton or equivalent</b> Model Number: <b>Flowco F500</b> Serial Number: <b>See Comment</b>	
5. Installation Date:	6. Performance Specification Test Date:
7. Continuous Monitor Comment: <b>Permit No. 0510003-017-AV. Monitors fuel oil flow to Boiler No. 2. No serial # or installation date provided because monitors are routinely replaced to ensure optimum performance.</b>	

**EMISSIONS UNIT INFORMATION**

Section [2]

Boiler No. 2

**H. CONTINUOUS MONITOR INFORMATION**

Complete if this emissions unit is or would be subject to continuous monitoring.

**Continuous Monitoring System:** Continuous Monitor 3 of 6

1. Parameter Code: <b>Nozzle Pressure</b>	2. Pollutant(s):
3. CMS Requirement:	<input type="checkbox"/> Rule <input checked="" type="checkbox"/> Other
4. Monitor Information... Manufacturer: <b>ABB-Kent Taylor or equivalent</b> Model Number: <b>621G</b> Serial Number:	
5. Installation Date:	6. Performance Specification Test Date:
7. Continuous Monitor Comment: <b>Monitors wet scrubber spray nozzle pressure. Permit No. 0510003-017-AV.</b>	

**Continuous Monitoring System:** Continuous Monitor 4 of 6

1. Parameter Code: <b>Steam Temp</b>	2. Pollutant(s):
3. CMS Requirement:	<input type="checkbox"/> Rule <input checked="" type="checkbox"/> Other
4. Monitor Information... Manufacturer: <b>Preferred Instruments or equivalent</b> Model Number: <b>PCC-III Controller</b> Serial Number:	
5. Installation Date:	6. Performance Specification Test Date:
7. Continuous Monitor Comment: <b>Monitors steam temperature. Permit No. 0510003-017-AV.</b>	

**EMISSIONS UNIT INFORMATION**

Section [2]

Boiler No. 2

**H. CONTINUOUS MONITOR INFORMATION**

Complete if this emissions unit is or would be subject to continuous monitoring.

**Continuous Monitoring System:** Continuous Monitor 5 of 6

1. Parameter Code: <b>Steam Pressure</b>	2. Pollutant(s):
3. CMS Requirement:	<input type="checkbox"/> Rule <input checked="" type="checkbox"/> Other
4. Monitor Information... Manufacturer: <b>ABB-Kent Taylor or equivalent</b> Model Number: <b>621G</b> Serial Number:	
5. Installation Date:	6. Performance Specification Test Date:
7. Continuous Monitor Comment: <b>Monitors steam pressure. Permit No. 0510003-017-AV.</b>	

**Continuous Monitoring System:** Continuous Monitor 6 of 6

1. Parameter Code: <b>FLOW</b>	2. Pollutant(s):
3. CMS Requirement:	<input type="checkbox"/> Rule <input checked="" type="checkbox"/> Other
4. Monitor Information... Manufacturer: <b>ABB-Kent Taylor or equivalent</b> Model Number: <b>621D</b> Serial Number:	
5. Installation Date:	6. Performance Specification Test Date:
7. Continuous Monitor Comment: <b>Monitors steam flow rate. Permit No. 0510003-017-AV.</b>	

# EMISSIONS UNIT INFORMATION

Section [2]

Boiler No. 2

## I. EMISSIONS UNIT ADDITIONAL INFORMATION

### Additional Requirements for All Applications, Except as Otherwise Stated

1. Process Flow Diagram (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Previously Submitted, Date <b>05/2005</b>
2. Fuel Analysis or Specification (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) <input checked="" type="checkbox"/> Attached, Document ID: <b>UC-EU2-I2</b> <input type="checkbox"/> Previously Submitted, Date _____
3. Detailed Description of Control Equipment (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Previously Submitted, Date <b>05/2005</b>
4. Procedures for Startup and Shutdown (Required for all operation permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Previously Submitted, Date _____ <input checked="" type="checkbox"/> Not Applicable (construction application)
5. Operation and Maintenance Plan (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Previously Submitted, Date _____ <input checked="" type="checkbox"/> Not Applicable
6. Compliance Demonstration Reports/Records <input type="checkbox"/> Attached, Document ID: _____ Test Date(s)/Pollutant(s) Tested: _____ <input type="checkbox"/> Previously Submitted, Date: _____ Test Date(s)/Pollutant(s) Tested: _____ <input type="checkbox"/> To be Submitted, Date (if known): _____ Test Date(s)/Pollutant(s) Tested: _____ <input checked="" type="checkbox"/> Not Applicable Note: For FESOP applications, all required compliance demonstration records/reports must be submitted at the time of application. For Title V air operation permit applications, all required compliance demonstration reports/records must be submitted at the time of application, or a compliance plan must be submitted at the time of application.
7. Other Information Required by Rule or Statute <input checked="" type="checkbox"/> Attached, Document ID: <b>UC-EU2-I7</b> <input type="checkbox"/> Not Applicable

**EMISSIONS UNIT INFORMATION**

Section [2]

Boiler No. 2

**Additional Requirements for Air Construction Permit Applications**

1. Control Technology Review and Analysis (Rules 62-212.400(10) and 62-212.500(7), F.A.C.; 40 CFR 63.43(d) and (e)) <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
2. Good Engineering Practice Stack Height Analysis (Rule 62-212.400(4)(d), F.A.C., and Rule 62-212.500(4)(f), F.A.C.) <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
3. Description of Stack Sampling Facilities (Required for proposed new stack sampling facilities only) <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable

**Additional Requirements for Title V Air Operation Permit Applications**

1. Identification of Applicable Requirements <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
2. Compliance Assurance Monitoring <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
3. Alternative Methods of Operation <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
4. Alternative Modes of Operation (Emissions Trading) <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
5. Acid Rain Part Application <input type="checkbox"/> Certificate of Representation (EPA Form No. 7610-1) <input type="checkbox"/> Copy Attached, Document ID: _____ <input type="checkbox"/> Acid Rain Part (Form No. 62-210.900(1)(a)) <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Previously Submitted, Date: _____ <input type="checkbox"/> Repowering Extension Plan (Form No. 62-210.900(1)(a)1.) <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Previously Submitted, Date: _____ <input type="checkbox"/> New Unit Exemption (Form No. 62-210.900(1)(a)2.) <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Previously Submitted, Date: _____ <input type="checkbox"/> Retired Unit Exemption (Form No. 62-210.900(1)(a)3.) <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Previously Submitted, Date: _____ <input type="checkbox"/> Phase II NOx Compliance Plan (Form No. 62-210.900(1)(a)4.) <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Previously Submitted, Date: _____ <input type="checkbox"/> Phase II NOx Averaging Plan (Form No. 62-210.900(1)(a)5.) <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Previously Submitted, Date: _____ <input type="checkbox"/> Not Applicable



**EMISSIONS UNIT INFORMATION**

**Section [2]**

**Boiler No. 2**

**Additional Requirements Comment**

**ATTACHMENT UC-EU2-F1.10**

**POTENTIAL EMISSIONS  
DUE TO FUEL OIL FIRING**

**ATTACHMENT UC-EU2-F1.10  
FUTURE POTENTIAL EMISSIONS DUE TO FUEL OIL FIRING, BOILER NO. 2,  
U. S. Sugar Corporation Clewiston**

Regulated Pollutant	No. 2 Fuel Oil Combustion					
	Emission Factor (lb/MMBtu)	Ref.	Activity Factor		Hourly Emissions (lb/hr)	Annual Emissions (TPY)
			Hourly <sup>a</sup> MMBtu/hr	Annual <sup>b</sup> MMBtu/yr		
Particulate Matter (PM)	0.015	1	130	834,000	1.9	6.2
Particulate Matter (PM <sub>10</sub> )	0.007	2	130	834,000	1.0	3.1
Sulfur dioxide (SO <sub>2</sub> )	0.053	3	130	834,000	6.9	22.2
Nitrogen oxides (NO <sub>x</sub> )	0.17	4	130	834,000	22.1	70.9
Carbon monoxide (CO)	0.037	1	130	834,000	4.8	15.4
Volatile Organic Compounds (VOC)	1.5E-03	1	130	834,000	0.2	0.62
Sulfuric acid mist (SAM)	0.0026	1	130	834,000	0.3	1.1
Lead (Pb)	9.0E-06	5	130	834,000	1.2E-03	3.8E-05
Beryllium (Be)	3.0E-06	5	130	834,000	3.9E-04	1.3E-05
Mercury (Hg)	3.0E-06	5	130	834,000	3.9E-04	1.3E-03

References:

- Factors for No. 2 fuel oil combustion: AP-42 Tables 1.3-1 and 1.3-3 (9/98). For sulfuric acid mist, factor shown is for SO<sub>3</sub>. Convert to H<sub>2</sub>SO<sub>4</sub> by multiplying by 98/80. Factors were converted to lb/MMBtu by dividing by 135,000 Btu/gal (min).  
 PM = 2 lb/1000 gal  
 CO = 5 lb/1000 gal  
 SO<sub>3</sub> = 5.7S lb/1000 gal, where S = 0.05      VOC = 0.2 lb/1000 gal
- Factors for distillate fuel oil, PM<sub>10</sub> is 50% of PM based on AP-42, Table 1.3-6 (9/98).
- Based on stoichiometric calculation: 7.2 lbs/gal; 135,000 Btu/gal (min); 0.05% sulfur.
- Based on stack testing conducted on Boiler No. 1 and 2 on Feb. 10-11, 2006.
- Factors for No. 2 fuel oil combustion, AP-42 Table 1.3-10 (9/98).

Footnotes:

- Based on maximum heat input due to No. 2 fuel oil combustion, from manufacturer specifications.
- Based on No. 2 fuel oil usage of 6,000,000 gallons per year and heating value of 139,000 Btu/gal (max).

**ATTACHMENT UC-EU2-I7**

**OTHER INFORMATION  
REQUIRED BY RULE OR STATUTE**

**ATTACHMENT UC-EU2-I7****IDENTIFICATION OF APPLICABLE REQUIREMENTS**

62-296.410(1)(b), F.A.C.: Carbonaceous Fuel Burning Equipment  
62-296.410(3), F.A.C.: Carbonaceous Fuel Burning Equipment  
62-297.310(1), F.A.C.: General Compliance Test Requirements  
62-297.310(2)(b), F.A.C.: General Compliance Test Requirements  
62-297.310(3), F.A.C.: General Compliance Test Requirements  
62-297.310(4), F.A.C.: General Compliance Test Requirements  
62-297.310(5), F.A.C.: General Compliance Test Requirements  
62-297.310(6), F.A.C.: General Compliance Test Requirements  
62-297.310(7)(a)3., F.A.C.: General Compliance Test Requirements  
62-297.310(7)(a)4., F.A.C.: General Compliance Test Requirements  
62-297.310(7)(a)5., F.A.C.: General Compliance Test Requirements  
62-297.310(7)(a)9., F.A.C.: General Compliance Test Requirements  
62-297.310(7)(a)10., F.A.C.: General Compliance Test Requirements  
62-297.310(8), F.A.C.: General Compliance Test Requirements  
62-297.401(1), F.A.C.: EPA Test Method 1  
62-297.401(2), F.A.C.: EPA Test Method 2  
62-297.401(3), F.A.C.: EPA Test Method 3  
62-297.401(4), F.A.C.: EPA Test Method 4  
62-297.401(5), F.A.C.: EPA Test Method 5  
62-297.401(6), F.A.C.: EPA Test Method 6  
62-297.401(6)(c), F.A.C.: EPA Test Method 6C  
62-297.401(7), F.A.C.: EPA Test Method 7  
62-297.401(7)(e), F.A.C.: EPA Test Method 7E  
62-297.401(8), F.A.C.: EPA Test Method 8  
62-297.401(9), F.A.C.: EPA Test Method 9  
62-297.401(10), F.A.C.: EPA Test Method 10

62-297.401(18), F.A.C.: EPA Test Method 18

62-297.401(25)(a), F.A.C.: EPA Test Method 25A

40 CFR 63.1 – 63.16 – Subpart A – General Provisions: Boiler No. 2 is subject to the notification requirements of Subpart DDDDD.

40 CFR 63.7485 – Subpart DDDDD – Applicability: Boiler No. 2 is an industrial boiler of size > 10 MMBtu/hr located at a major source of HAPs.

40 CFR 63.7490 – Subpart DDDDD – Applicability: Boiler No. 2 is subject to the requirements of Subpart DDDDD for existing boilers.

40 CFR 63.7495 – Subpart DDDDD – Compliance Dates – Boiler No. 2 must meet notification requirements and comply by September 13, 2007.

40 CFR 63.7499 – Subpart DDDDD – Subcategories: Boiler No. 2 is in the large solid fuel subcategory.

40 CFR 63.7506 – Subpart DDDDD – Limited Requirements: Boiler No. 2 must only meet the notification requirements of 63.9(b) at this time.

40 CFR 63.7545 – Subpart DDDDD – Notifications: Boiler No. 2 must submit the required notification by March 12, 2005.

**ATTACHMENT A**

**SUPPLEMENTAL INFORMATION FOR  
CONSTRUCTION PERMIT APPLICATION**

**TABLE OF CONTENTS**

<u>SECTION</u>	<u>PAGE</u>
1.0 INTRODUCTION.....	1
2.0 PROJECT DESCRIPTION.....	3
2.1 Proposed Project .....	3
2.2 Project Emissions.....	4
3.0 AIR QUALITY REVIEW REQUIREMENTS AND APPLICABILITY.....	5
3.1 PSD Review .....	5
3.2 New Source Performance Standards.....	6
3.2.1 Modification .....	6
3.2.2 Reconstruction .....	7



## 1.0 INTRODUCTION

United States Sugar Corporation (U.S. Sugar) owns and operates a sugar mill and refinery located in Clewiston, Hendry County, Florida. The mill and refinery currently operate under Permit No. 0510003-017-AV. U.S. Sugar harvests sugarcane and transports it to the Clewiston Mill, where the cane is processed into raw sugar in the mill. U.S. Sugar processes most of the raw sugar into refined white sugar in an onsite sugar refinery, while the remaining raw sugar is shipped to customers.

U.S. Sugar operates five sugar mill boilers at the Clewiston Mill. The five boilers provide steam to the sugar mill as well as to the sugar refinery. Boiler Nos. 1, 2, and 4 operate primarily during the crop season, which is typically October through June, to provide steam to the sugar mill and refinery. Boilers No. 7 and No. 8 can operate year-round to provide steam to the sugar mill during the crop season and steam to the sugar refinery during the off-crop season. Boiler Nos. 1, 2, and 4 can operate as backup units during the off-season when Boiler No. 7 is down for maintenance, repair, or during periods of unusually low steam demand.

Boiler Nos. 1 and 2 were previously permitted to burn bagasse and No. 6 fuel oil. The maximum heat input due to bagasse is 495 million British thermal units per hour (MMBtu/hr) for Boiler No. 1 and 447 MMBtu/hr for Boiler No. 2. The maximum heat input to each boiler from fuel oil only was limited to 248 MMBtu/hr and 1,500 gallons per hour (gal/hr).

In August 2004, U.S. Sugar proposed to replace the existing No. 6 fuel oil burners on Boiler Nos. 1 and 2 with new No. 2 fuel oil burners. The new burner system for each boiler was to have two burners and be rated for a maximum heat input of 208 MMBtu/hr. The burner design emission rate for nitrogen oxides (NO<sub>x</sub>) was 0.15 pounds per million British thermal units (lb/MMBtu).

In February 2005, the Florida Department of Environmental Protection (FDEP) issued an air construction permit (Permit No. 0510003-027-AC) which allowed installation of the burners. The permit required that U.S. Sugar burn distillate fuel oil with a maximum sulfur content of 0.05 percent, instead of the previously permitted No. 6 fuel oil with a maximum sulfur content of 2.5 percent. The permitted steam rate from bagasse firing, bagasse firing rates and bagasse heat input rates did not change as a result of the changes to the fuel oil system.

The primary reason for increasing the steaming rate on oil for Boiler Nos.1 and 2 was to more reliably supply the sugar mill and refinery with adequate steam in the event that bagasse becomes unavailable during the crop season. Typically, if Boiler Nos. 1 and 2 are operating during the crop season or the off-season, other boilers are also operating due to the steam demands of the sugar mill and/or the refinery. In this case, if the bagasse supply is interrupted, all of the operating boilers would be affected, but the more reliable fuel oil firing capability of Boiler Nos. 1 and 2 would be more able to provide adequate steam production to support the mill and/or the refinery. Also, during a temporary interruption in the supply of bagasse, it is not possible to quickly startup one of the other mill boilers to provide additional steam, because of the period of time required for startup. Maintaining steam production under conditions when bagasse supply is interrupted is critical to the reliable and efficient operation of the sugar mill and refinery.

To implement this increase, U.S. Sugar made certain physical modifications to the fuel oil burner system, including replacing the existing burners. However, U.S. Sugar installed only one fuel oil burner in each boiler; rated for a heat input of 130 MMBtu/hr. Also, U.S. Sugar conducted performance tests on each boiler for NO<sub>x</sub> emissions when burning fuel oil only at the maximum rate, in order to validate the actual installed burner capacity and the NO<sub>x</sub> emissions. Therefore, this revised permit application is being submitted in order to update the information presented in the original application.

The remainder of this report is divided into two sections. Section 2.0 describes the proposed project in further detail, including air emissions. Section 3.0 provides a review of regulatory requirements applicable to the project.

## 2.0 PROJECT DESCRIPTION

### 2.1 Proposed Project

Boiler Nos. 1 and 2 are each spreader stoker, vibrating grate-type boilers, both originally constructed at the Clewiston Mill in 1968. Particulate matter (PM) emissions from each boiler are controlled by Joy Turbulaire spray impingement-type scrubbers. Boiler Nos. 1 and 2 are currently permitted to burn bagasse and No. 2 fuel oil. The maximum heat input for bagasse firing is 496 MMBtu/hr for Boiler No. 1 and 447 MMBtu/hr for Boiler No. 2. Based on Permit No. 0510003-027-AC, the maximum sulfur content of the fuel oil is limited to 0.05 percent. The maximum heat input to each boiler from fuel oil only is limited to 208 MMBtu/hr, and the maximum fuel oil burning rate is limited to 1,541 gal/hr and 3,500,000 gallons per year (gal/yr).

In 2005, U.S. Sugar replaced the existing No. 6 fuel oil burners on Boiler Nos. 1 and 2 with new No. 2 fuel oil burners, as allowed under permit no. 0510003-027-AC. However, U.S. Sugar installed only one (1) No. 2 fuel oil burner, each rated at 130 MMBtu/hr, in each boiler. U.S. Sugar is required to burn distillate fuel oil with a maximum of 0.05 percent sulfur in the burners. Maximum annual fuel oil burning is now proposed to be limited to 6,000,000 gal/yr, total for both boilers combined.

The new burners will allow each boiler to produce up to approximately 97,400 lb/hr steam when firing fuel oil only, as calculated below:

$$130 \text{ MMBtu/hr} \times 80\text{-percent efficiency} \div 1,068 \text{ Btu/lb steam} = 97,378 \text{ lb/hr steam}$$

This calculation is based on an estimated 80-percent thermal efficiency when burning fuel oil only. The manufacturers design specifications for the new burners is provided in Attachment B.

In January 2006, U.S. Sugar conducted initial performance tests on the new burners in each boiler, in order to validate the capacity on fuel oil and the NO<sub>x</sub> emission rate. The results of these tests are shown in Attachment C (a full test report has been submitted to the FDEP). As shown in Attachment C, the burners were able to achieve 121 MMBtu/hr (Boiler No. 1) and 126 MMBtu/hr (Boiler No. 2) when burning fuel oil only. These rates are more than 90 percent of the design heat input of 130 MMBtu/hr.

The performance test results are demonstrated that actual NO<sub>x</sub> emissions from the Boiler No. 1 burner were 0.17 lb/MMBtu, and from the Boiler No. 2 burner was 0.14 lb/MMBtu. The actual emissions from Boiler No. 1 are above the design emission rate of 0.15 lb/MMBtu.

Based on the change in design firing rates for the fuel oil burners, and the higher than expected NO<sub>x</sub> emission rate, the project emissions have been updated, and are presented in Section 2.2.

## 2.2 Project Emissions

The estimated future potential hourly and annual emissions for the modified fuel oil firing in Boiler Nos. 1 and 2 are presented in Attachments UC-EU1-F1.10 and UC-EU2-F1.10. Emissions due to bagasse firing will not change; and, therefore, emissions due to bagasse firing are not addressed in these attachments.

The emission factors used for particulate matter (both PM and PM<sub>10</sub>), carbon monoxide (CO), volatile organic compounds (VOCs), sulfuric acid mist (SAM), lead, mercury, and beryllium are from the Environmental Protection Agency's (EPA's) Publication AP-42, Section 3, which presents factors for No. 2 fuel oil combustion. The activity factors are based on the proposed maximum fuel oil heat input of 130 MMBtu/hr and the proposed annual limit of 6,000,000 gal/yr of fuel oil for both boilers combined. To provide more flexibility in operations, U.S. Sugar is requesting an overall cap on Boilers No. 1 and 2 annual fuel oil usage, rather than individual annual limits.

Emissions of sulfur dioxide (SO<sub>2</sub>) are based on a stoichiometric calculation, using the maximum future sulfur content of 0.05 percent, and the density for very low sulfur No. 2 fuel oil of 7.2 lb/gal. Emissions of NO<sub>x</sub> are based on the higher of the two initial performance tests results, i.e., 0.17 lb/MMBtu, in order to be conservative.

The past actual emissions from Boiler Nos. 1 and 2 due to fuel oil firing are presented in Table 1, and are the same as presented in the original application. Detailed calculations are shown in Attachment D. The past actual emissions are based on the average emissions from 2002 and 2003. The emissions are from U.S. Sugar's Annual Operating Reports (AORs) submitted to the FDEP for each respective year. Lead, beryllium, mercury, and SAM have not been required to be reported in the AORs, so these emissions were calculated using AP-42 factors for No. 2 fuel oil combustion and the activity factors for each respective year.

### 3.0 AIR QUALITY REVIEW REQUIREMENTS AND APPLICABILITY

The following discussion pertains to the federal and state air regulatory requirements and their applicability to the proposed increase in fuel oil firing rate.

#### 3.1 PSD Review

Under federal and State of Florida Prevention of Significant Deterioration (PSD) review requirements, all major new or modified sources of air pollutants regulated under the Clean Air Act (CAA) must be reviewed and a pre-construction permit issued. Florida's State Implementation Plan, which contains PSD regulations, has been approved by EPA; therefore, PSD approval authority has been granted to FDEP.

A "major facility" is defined as any one of 28 named source categories that have the potential to emit 100 tons per year (TPY) or more or any other stationary facility that has the potential to emit 250 TPY or more of any pollutant regulated under CAA. "Potential to emit" means the capability, at maximum design capacity, to emit a pollutant after the application of control equipment.

A "major modification" is defined under PSD regulations as a change at an existing major facility that increases emissions by greater than significant amounts. The net change in emissions due to the proposed project is presented in Table 2. The net increase due to the project is determined by subtracting Boiler Nos. 1 and 2's past actual emissions due to fuel oil firing from the future potential emissions resulting from fuel oil firing. Emissions due to bagasse firing are not included since these emissions will not be affected by the proposed project.

The net increase due to the project is compared to PSD significant emission rates in Table 2. As shown in Table 2, the increases due to this project do not exceed any PSD significant emission rates and therefore, PSD review is not applicable. In addition, U.S. Sugar believes PSD review is not applicable for the following reasons:

- The maximum steam rate for the boiler will not be affected;
- Steam rates, heat input rates and firing rates for bagasse will not be affected;
- U.S. Sugar intends to burn bagasse when it is available; and

- Emission factors for No. 2 fuel oil in terms of lb/MMBtu are lower than for No. 6 fuel oil or for bagasse burning, so emissions will not increase while Boiler Nos. 1 and 2 are firing very low sulfur No. 2 fuel oil.

### 3.2 New Source Performance Standards

The New Source Performance Standards (NSPS) are a set of national emission standards that apply to specific categories of new sources. NSPS Subpart Db is applicable to each steam-generating unit for which construction, modification, or reconstruction is commenced after June 9, 1984, and that has a maximum design heat input rate of 100 MMBtu/hr or greater. Subpart Db regulates SO<sub>2</sub>, NO<sub>x</sub>, and PM emissions from steam generating units.

Two provisions under the general NSPS regulations (40 CFR Subpart 60, Subpart A) could potentially subject Boiler Nos. 1 and 2 to the Subpart Db NSPS. These are discussed in the following sections.

#### 3.2.1 Modification

Boiler Nos. 1 and 2 are both “existing facilities” under the NSPS definitions, and are not currently subject to Subpart Db. Boiler Nos. 1 and 2 were originally constructed at the Clewiston Mill in 1968, and the existing oil burners were installed at that time. To become subject to NSPS, the proposed changes to Boiler Nos. 1 and 2 would need to meet the definition of “modification” as defined by 40 CFR 60.2. Modification is defined as:

“Any physical change in, or change in method of operation of, an existing facility which increase the amount of any air pollutant (to which a standard applies) emitted into the atmosphere by that facility or which results in the emission of any air pollutant (to which a standard applies) into the atmosphere not previously emitted.”

The emission increase is based on hourly emissions. To determine if the proposed changes to Boiler Nos. 1 and 2 qualify as a “modification”, the current hourly SO<sub>2</sub>, NO<sub>x</sub>, and PM emissions were compared to the future potential emissions. These are the pollutants regulated under 40 CFR 60, Subpart Db. This comparison is presented in Table 3. The current hourly emissions are based on the previously permitted No. 6 fuel oil firing rate of 248 MMBtu/hr and 1,500 gal/hr. Emission factors are based on the same factors used to calculate past actual emissions for the AOR. The future hourly potential emissions are based on Attachments UC-EU1-F1.10 and UC-EU2-F1.10.

As shown in Table 3, the proposed changes will not result in an hourly increase of SO<sub>2</sub>, NO<sub>x</sub>, or PM emissions. Therefore, the proposed changes to Boiler Nos. 1 and 2 will not meet the definition of "modification" under the NSPS, and Subpart Db requirements will not apply.

### 3.2.2 Reconstruction

A modification to an affected source is potentially subject to the NSPS if the modification meets the definition of "reconstruction". Reconstruction, as defined in 40 CFR 60.15, is triggered if the cost of the new components of the project exceeds 50 percent of the fixed capital cost of a comparable new boiler.

The fixed capital cost of installing the new fuel oil burner systems in Boiler Nos. 1 and 2 is approximately \$400,000 per boiler. The estimated cost of a completely new boiler, comparable in size and function to Boiler Nos. 1 and 2, is approximately \$7 million (excluding air pollution control equipment, which is not part of the "affected source" under NSPS Subpart Db). Therefore, the planned project cost represents less than 6 percent of the cost of a new boiler. Therefore, reconstruction is not triggered under NSPS.

**TABLE 1**  
**PAST ACTUAL EMISSIONS DUE TO FUEL OIL BURNING, BOILER NOS. 1 and 2**  
**U.S. Sugar Corporation, Clewiston Mill**

Regulated Pollutant	Boiler No. 1		Boiler No. 2		Boiler No. 1 + Boiler No. 2 2-Yr Average (TPY)
	Actual Emissions <sup>a</sup> (TPY)		Actual Emissions <sup>a</sup> (TPY)		
	2002	2003	2002	2003	
Particulate Matter (PM)	6.18	5.06	5.63	4.09	10.48
Particulate Matter (PM <sub>10</sub> )	5.25	4.30	4.79	3.48	8.91
Sulfur Dioxide (SO <sub>2</sub> )	46.41	38.64	42.28	31.27	79.30
Nitrogen Oxides (NO <sub>x</sub> )	18.90	15.67	17.22	12.68	32.24
Carbon Monoxide (CO)	2.01	1.67	1.83	1.35	3.43
Volatile Organic Compound (VOC)	0.11	0.09	0.10	0.08	0.19
Sulfur Acid Mist (SAM)	2.05	1.70	1.86	1.38	3.50
Lead - Total	6.07E-04	5.04E-04	5.53E-04	4.08E-04	1.04E-03
Beryllium (Be)	1.12E-05	9.27E-06	1.02E-05	7.50E-06	1.91E-05
Mercury (Hg)	4.54E-05	3.77E-05	4.14E-05	3.05E-05	7.75E-05

## Footnotes:

<sup>a</sup> Based on Annual Operating Report submitted to FDEP for 2002 and 2003, except for:

SAM, Be and Hg not reported on the AOR; emissions based on AP-42 factors, see Attachment B.



**TABLE 2**  
**NET CHANGE IN EMISSIONS DUE TO BURNING 6,000,000 GAL/YR OF FUEL OIL IN BOILER NOS. 1 and 2,**  
**U.S. Sugar Corporation Clewiston**

Regulated Pollutant	Boiler Nos. 1 & 2			PSD Significant Emission Rate (TPY)	PSD Review Applies?
	Boiler Nos. 1 & 2 Past Actual Emissions <sup>a</sup> (TPY)	Future Potential Emissions <sup>b</sup> (TPY)	Net Change in Emissions (TPY)		
Particulate Matter (PM)	10.48	6.2	-4.3	25	NO
Particulate Matter (PM <sub>10</sub> )	8.91	3.1	-5.8	15	NO
Sulfur Dioxide (SO <sub>2</sub> )	79.30	22.2	-57.1	40	NO
Nitrogen Oxides (NO <sub>x</sub> )	32.24	70.9	38.7	40	NO
Carbon Monoxide (CO)	3.43	15.4	12.0	100	NO
Volatile Organic Compound (VOC)	0.19	0.6	0.4	40	NO
Sulfur Acid Mist (SAM)	3.50	1.1	-2.42	0.6	NO
Lead (Pb)	1.04E-03	3.8E-05	-1.0E-03	7	NO
Beryllium (Be)	1.91E-05	1.3E-05	-6.6E-06	4.0E-04	NO
Mercury (Hg)	7.75E-05	1.3E-03	1.2E-03	0.1	NO

Footnotes:

<sup>a</sup> Based on emissions due to fuel oil firing in Boiler Nos. 1 and 2 for calendar years 2002 and 2003. See Table 1.

<sup>b</sup> Based on proposed fuel oil firing rates. See Attachments UC-EU1-F1.10 and UC-EU2-F1.10 for calculations.

**TABLE 3  
CURRENT VERSUS FUTURE MAXIMUM HOURLY EMISSIONS  
DUE TO FUEL OIL FIRING IN BOILER NOS. 1 AND 2  
U.S. Sugar Corporation Clewiston**

Regulated Pollutant	Maximum Hourly Emissions		Increase in Maximum Hourly Emissions? (Yes/No)
	Current <sup>a</sup> (lb/hr)	Future <sup>b</sup> (lb/hr)	
Particulate Matter (PM)	22.8	1.9	No
Sulfur Dioxide (SO <sub>2</sub> )	172.5	6.9	No
Nitrogen Oxides (NO <sub>x</sub> )	70.5	22.1	No

Footnotes:

<sup>a</sup> Based on 1,500 gal/hr, and emission factors shown in Attachment B.

<sup>b</sup> Based on Attachments UC-EU1-F1.10 and UC-EU2-F1.10.

**ATTACHMENT B**

**VENDOR INFORMATION ON INSTALLED BURNERS**

# SunBelt

ENERGY SYSTEMS, INC.

Wednesday, March 09, 2005

Mr. Bret Nesbitt  
US Sugar Corp.  
PO Drawer 1207  
Clewiston, FL 33440-1207

**FILE COPY**

Reference: U.S. Sugar  
Boiler Nos. 1 & 2 Retrofit (Revision 2)

Bret,

~~Per your request~~ we are pleased to submit our proposal for the supply of two (2) Peabody type MSC low NOx burners for U.S. Sugar Boilers No. 1 & 2 (1 burner per boiler). Based on a review of the existing throat opening and furnace geometry, we can fire up 130 MMBTU/HR with a single burner in one of the existing openings. This equates to 63% of the total heat input of 208 MMBTU/HR previously specified on oil. The new burner air side pressure drop will be 12"WC based on ambient air firing. We have reviewed the existing FD fan curve and have determined that the existing fan can accommodate the new combustion air flow and burner pressure drop. This fan review has incorporated an assumed 6" WC pressure loss upstream of the burner (ductwork, baffling, etc.). We acknowledge that the existing fan also supplies combustion air for the bagasse firing and oil will (occasionally) be co-fired with bagasse. As we are not aware of the combustion air requirements for the bagasse, we cannot confirm if the above heat input is achievable for all combinations of bagasse / oil co-firing.

## INTRODUCTION

Our scope of supply for each boiler is detailed herein and is summarized as follows:

- One HPC Model MSC low NOx burner with non-insulated front plate suitable for firing steam atomized No. 2 fuel oil with provisions to add natural gas firing in the future.
- One opposed blade damper w/ external bearings complete w/ pneumatic actuator and positioner
- One non-insulated windbox
- One NFPA Class 3 propane ignition ignitor assembly
- PLC based Single-Burner Burner Management System
- One set, Burner tools (Oil unit holder and wrench set and throat sweep)
- One NFPA 85 oil, atomizing steam, and propane valve system including
  - One Burner valve rack
  - All rack electrical connections will be terminated in rack mounted NEMA-4 termination cabinet.
- One Local start / stop cabinet with pushbuttons and indicating lights.

The burner will be designed for a heat release of 130 MM BTU/hr when firing steam-atomized No. 2 oil and will be suitable for the addition of future gas firing. Our offer is based on the equipment for both boilers being identical.

Each burner will be supplied with a steam-atomized center-fired oil gun, gas-electric FP ignitor with flame proving rod and one Peabody FV-03 dual fuel flame scanner. Included is a NEMA-4 enclosure to provide local start / stop and to house the flame scanner control cards. One single-burner windbox is included for each boiler. The ductwork to supply ambient combustion air to the windbox will be fitted with the above mentioned damper.

Electrical integration of this equipment into a Burner Management System will be by others.

**Site Conditions:**

Elevation	100 FASL
Plant Location	Clewiston, FL
Ambient Temperature	80°F
Insurance/Code Requirements	NFPA
Area Classification	Non-hazardous
Electrical Power Available	1/60/120
Plant Air Available	80 PSIG (assumed)

**Boiler Data:**

No. of boilers	2
Boiler Manufacturer	Riley
Steam Capacity	150,000 PPH (bagasse) 130,000 PPH (oil)
Burners per Boiler	1
Air Temperature to Burners	100°F (max)
Furnace Pressure	Negative
Inside Furnace Dimensions	
Width:	16.5 ft.
Height:	26 ft
Depth:	18.9 ft

**Burner Data:**

Burner Model	MSC 600
Nominal Throat Diameter	23 -5/8"
Register Draft Loss @ MCR	12" W.C. @ 100°F
Estimated Flame Length	17.5 Ft.
Estimated Flame Diameter	6.0 Ft.

**Burner Design Specification:**

Heat Input per Burner	130 MM BTU/hr
No. Burners per Boiler	1
Burner Excess Air @ MCR	15%
Combustion Air Flow per Burner	112,411 PPH
Combustion Air Temperature	100°F
Oil Pressure at Burner	120 psig
Steam Pressure at Burner	20 psi greater than oil pressure
Gas Pressure at Ignitor	1-2 psig
Burner Turndown:	8-1

**Fuel Data:**

Type	No. 2 Fuel Oil
Higher Heating Value	19,200 BTU/lb.
Pressure Available	150 psig (assumed)
Viscosity at Burner	35 SSU
Fuel bound Nitrogen	0.015% wt

**Guaranteed Emissions:**

	<u>No. 2 Oil</u>
NOx	0.15 lb / MM BTU
Particulate:	0.10 lb / MMBTU
Opacity:	<30%

NOx is based on oil with maximum 0.02% fuel bound nitrogen being fired with 100°F combustion air.

Emissions stated above are applicable for boiler loading from 25% to 100% of oil MCR. Based on the above information we are pleased to propose the following scope of supply:

**Base Scope of Supply – Per Boiler:**

- 1- Peabody type MSC low NOx burner assembly as described in the attached literature, comprised of the following:
  - 1- Peabody type MSC low NOx burner assembly with non-insulated frontplate. The frontplate will contain two openings each with carrier sleeve, one for the ignitor and one for the steam-atomized oil gun. The front-plate will also contain one peephole with sightglass and one scanner mount with adjustable ball swivel assembly & air purge.
  - 1- Flexible steam atomized oil unit, inside mix, low NOx design complete with flexible metallic oil and steam hoses, burner couplings for easy removal of oil unit, and manual valves for each of the oil, steam and purge services.
  - 1- Peabody Type FP gas-electric ignitor complete with flame proving rod, gas hose, ignition harness and transformer in a NEMA-4 enclosure. Ignitor flame proving relay will be mounted in boiler local start / stop cabinet

**NOTE: The burner materials of construction include the following:**

- |                            |                     |
|----------------------------|---------------------|
| • Primary air swirler:     | 310 Stainless Steel |
| • Primary air casing       | 310 Stainless Steel |
| • Burner inlet air cone:   | 304 Stainless Steel |
| • Oil unit support sleeve: | 304 Stainless Steel |

- 1- Set, burner tools consisting of one burner holder and wrench set to facilitate oil replacement, and one refractory throat form to prepare the proper contour of the plastic refractory throat.
- 4- Peabody Instruction Manuals
- 1- Heavy duty rectangular single burner windbox fabricated of 1/4" steel plate with open back for welding to the boiler front plate. The windbox will be provided with an opening in one side for connection to an air duct and forced draft fan. Fan provided by owner. For ease of maintenance and installation, we include a bolted access door with handles for entry into the windbox. Additionally, we provide the air inlet connection with a perforated steel plate to assure proper air dispersion across the windbox inlet. **Preliminary windbox dimensions are 6' high x 6.5' wide x 5' deep.**
- 1- Set Peabody FV-03 flame scanners consisting of:
  - 1- FV-03 dual fuel flame scanner
  - 1- Microprocessor control card (mounted in local start / stop cabinet)
  - 1- Mounting rack (mounted in local start / stop cabinet)
  - 1- 50 ft. flame scanner cable
  - 1- KP-01 hand-held programmer

1- NEMA -4 Local Start / Stop Panel including:

- 1 – Scanner mounting rack and one microprocessor card
- 1 – Ignitor flame proving relay
- 2 – Burner start pushbuttons
- 2 – Burner stop pushbuttons
- 2 – Burner Ready Lights
- 2 – Burner Firing Lights
- 2 – Flame Strength Meters

1- Individual ignitor valve train rack with NEMA 4 junction box, pre-piped and pre-wired to the extent possible consisting of the following components:

For Ignitor Gas

- 1- Wye type strainer
- 1- Pressure regulator
- 2- Solenoid shut-off valves
- 1- Solenoid vent valve (outlet plugged for propane service)
- 2- Manual bleed & leak test valves
- 1- Pressure gage with isolation valve
- 1- Manual shut-off ball valve

For No. 2 Oil

- 1- Manual shut-off ball valve
- 1- Wye type strainer
- 1- Pressure gauge w/isolation valve
- 1- Manual flow meter bypass valve(s)
- 1- Low oil pressure switch
- 1- High oil pressure switch
- 1- Manual bleed & leak test valve
- 1- Fisher pneumatic flow/ combustion control valve
- 1- Worcester pneumatic shut-off valve
- 1- Scotch Tri-fecta fuel oil / steam control valve
- 1- Manual shut-off to constant differential pressure regulator
- 1- Differential pressure switch
- 1- Check valve
- 1- Manual shut-off /isolation valve(s)



For Atomizing Steam

- 1- Steam trap
- 1- Wye type strainer
- 1- Fisher atomizing steam flow control valve
- 1- Manual shut-off ball valve
- 1- Check valve
- 1- Automatic shut-off valve, pneumatically operated
- 1- Purge automatic shut-off valve, pneumatically operated
- 1- Purge line check valve
- 1- Cooling steam automatic shut-off valve, pneumatically operated
- 1- Cooling steam orifice plate
- 1- Cooling steam check valve
- 1- Pressure gauge w/siphon loop & isolation valve

- 1- Single Burner BMS consisting of the following mounted and wired to a terminal strip:
  - 1- Allen Bradley *Control Logix*
  - 1- Allen Bradley power supply
  - 1- Set, Allen Bradley I/O Modules
  - 1- Set, pushbuttons and status lights
  - 1- Utility outlet
  - 1- Alarm horn
  - 1- Set, circuit breakers, grounding bars and terminals
  
- 1- Two (2) sets Ignitor modification kits (for use on Unit 7) to include flame relays, NEMA 4 panel, ionization probe, and related retrofit hardware for flame rectified flame proving. Replacement flame relays (2) will also be provided for the refurbishment of Unit 4's flame rectifying flame proven system.
  
- 2- Two (2) Fisher pneumatic differential pressure steam regulators and pressure transmitter for use on Units 4 and 7.
  
- 3- The parts for Units 4 and 7 are to be installed by the owner (USSC). Supervision and start-up for these items to be performed by SunBelt Energy Systems Inc.

**Firm Price – Both Boilers:**

**Valve Racks per ANSI B31.1**

Our firm price for the above burners, windboxes, ANSI B31.1 construction valve racks, flame scanner equipment, ducting, installation, and start-up (see Commissioning) for **both boilers** is:

**\$670,820.00 Net**

***SIX HUNDRED SEVENTY THOUSAND EIGHT HUNDRED TWENTY U.S. DOLLARS***

**Terms of Payment:**

Progress Payments per USSC / SunBelt Energy previous agreement(s)

5% with order

10% upon drawing submittal

~~60%~~ on shipping equipment

25% on project completion and successful start-up

All invoices are due and payable 30 days after date of issue.

**Validity:**

This proposal is valid for 30 days from the date of issue.

**Schedule**

Based on current workload, shipment availability of the above equipment from receipt of order and all necessary data to allow us to proceed is estimated as follows:

	<u>Weeks</u>
Drawings preparation and submittal for approval	3
Customer review and approval	1
Equipment manufacture	11
Equipment inspection, testing and crating	<u>1</u>
TOTAL Estimated Delivery	16

**Exclusions:**

- All sales taxes and duties.
- Permits and Approvals.
- Supply of site utilities to contact termination points.
- Combustion air fan
- Field wiring.
- Certification testing for emissions.
- Motor starters.
- Spare parts

**Terms and Conditions:**

The acceptance of our quotation includes acceptance of the attached SunBelt Energy Systems Inc. Standard Terms and Conditions of Sale and of the special conditions (if any) stated in this proposal.

**Notwithstanding the inclusion of any modified terms and conditions contained in any purchase order or contract issued against this proposal, SunBelt Energy Systems, Inc. nor its suppliers or subcontractors will not be liable for any special, incidental or consequential loss or damage. In addition, SunBelt Energy Systems Inc. liability on any claim of any kind shall in no case exceed the contract price.**

This proposal and any subsequent order are subject to scope, design and delivery schedules as presented. Any change in such scope, design and/or delivery may require quoted price revision(s).

Acceptance of any order placed against this proposal will be subject to verification of all technical data acceptable commercial terms and the approval of an officer of SunBelt Energy Systems Inc.. In addition, any contract incorporating the provision of performance bonds will be subject to legal review prior to our acceptance.

**Guarantees/Warranty:**

Except as detailed below the equipment offered in this proposal is guaranteed for a period of 12 months from start-up or 18 months from shipment, whichever occurs first. This guarantee is subject to the conditions of SunBelt Energy Systems Inc. and its supplier, Hamworthy Peabody, Standard Terms and Conditions of Sale.

**Commissioning:**

This proposal includes commissioning / start-up for each boiler not to exceed three (3) days on-site per boiler. (Total six days on-site) Any additional days required as a result of others will be billed at SunBelt Energy Systems Inc. standard commissioning rate of \$550.00 per man day. Travel and living expenses will be billed at cost plus 10%. Services are charged on a portal to portal basis. Rates are based on eight hour working days.

Comments:

1. SunBelt Energy Systems reserves the right to inspect the boiler/furnace during the proposal and/or contract stages to verify furnace conditions.
2. Our quotation is based on the premise that all existing boiler design criteria (i.e. steam flow, temperature, pressure, etc.) reflects the actual operating conditions prior to burner change and upon request Purchaser can document such operating conditions.
3. All performance guarantees are contingent upon initial check-out and start-up by qualified SunBelt Energy Systems Inc. service personnel.
4. Performance guarantees/predictions are based on furnace conditions that do not adversely affect the testing for such guarantees. These conditions include, but are not limited to, tight boiler wall construction so as to not allow short circuiting of flue gas; tube surfaces free of scaling and loose particles and refractory surfaces free of loose particles. Emissions testing protocol is to be submitted to and reviewed by the burner supplier, Hamworthy Peabody Combustion, prior to any formal testing.
5. All equipment is for installation in a non-hazardous area.
6. This offer is based on the equipment for both boilers being identical.
7. Saturated steam required for oil atomization to be supplied from the steam drum with a suitable PRV supplied and fitted by the owner (USSC).
8. Due to the limited space between Boilers 1 & 2 flexible oil units are included to facilitate installation and removal of the oil units.
9. Main steam isolation and header throttling valves are to be relocated by the owner (USSC) to accommodate the straight runs of combustion air ducting required per the utilization of ambient air from the existing force draft fan(s).
10. The required service plant air (for pneumatically operated valves), the combustion fuel sources (both #2 fuel oil and propane) and the atomizing steam, are to be made available by the owner (USSC) within close proximity of the burner deck to facilitate tie-in.

We thank you for the opportunity to service the US Sugar account. If you have any questions and/or comments, please call.

Sincerely,

Fred Odom  
SunBelt Energy Systems, Inc.

**ATTACHMENT C**

**INITIAL PERFORMANCE TEST RESULTS**



**PERFORMANCE TEST REPORT  
FOR  
OXIDES OF NITROGEN EMISSIONS**

**BOILERS 1 AND 2  
IMPINGEMENT WET SCRUBBER OUTLETS  
TRAVELING GRATE  
CLEWISTON, FLORIDA**

**FDEP PERMIT NUMBER 0510003-027-AC  
(OIL BURNER MODIFICATION)**

**DISTILLATE OIL FIRING**

**FEBRUARY 10 AND 21, 2006**

**PREPARED FOR:**

**U.S. SUGAR CORPORATION  
SOUTH W.C. OWEN AVENUE  
CLEWISTON, FLORIDA 33440**

**PREPARED BY:**

**AIR CONSULTING AND ENGINEERING, INC.  
2106 N.W. 67TH PLACE, SUITE 4  
GAINESVILLE, FLORIDA 32653  
(352) 335-1889**

**238-06-01**

**Table 1. Emission Summary for Distillate Oil Firing  
Boilers 1 and 2  
United States Sugar Corporation - Clewiston Mill  
Clewiston, Florida  
February 10 and 21, 2006**

Run Number	Time	Flow Rate dscfm	NOx Emissions		Sulfur %	Steam			Firing Rate gal/hr	Heat Input Oil* MMBTU/hr	
			ppm	lbs/MMBTU		Temperature F	Pressure psig	Steam Rate lbs/hr			
<b><u>Boiler 1 - 2/10/2006</u></b>											
1	1036-1136	132002	21.78	0.170	20.59	0.03	640.20	606.20	64167	896.7	121.1
<b><u>Boiler 2 - 2/21/2006</u></b>											
1	1116-1216	156427	15.68	0.139	17.57	0.03	590.60	582.40	85846	936.0	126.4

\* Heat Input calculated from fuel consumption and HHV of 135,000 btu/gal, density 6.83 lb/gal

$$\text{MMBTU/hr} = \frac{(\text{gal/hr}) \times (135,000 \text{ btu/gal})}{10^6}$$

$$\text{lbs/hr} = \text{ppm} \times (2.595 \times 10^{-9}) \times \text{MWNOx} \times (\text{FlowRate, dscfm}) \times (60 \text{ min/hr})$$

$$\text{MWNOx} = 46 \text{ lb/lb-mole}$$

$$\text{lbs/MMBTU} = \text{lbs/hr} / \text{Heat Input (MMBTU/hr)}$$

**Design Emission Rate:**

**NOx = 0.15 lbs/MMBTU**

**S = 0.05 % by weight**

**Permitted Heat Input = 130 MMBTU/hr**

**ATTACHMENT D**

**2002 AND 2003 EMISSIONS INFORMATION  
FROM ANNUAL OPERATING REPORTS**



**TABLE D-1  
2002 EMISSIONS OF CRITERIA POLLUTANTS FOR U.S. SUGAR CORPORATION CLEWISTON BOILER NO. 1**

Regulated Pollutant	Emission Factors								Total Annual Emissions (TPY)
	Carbonaceous Fuel				No. 6 Fuel Oil				
	Emission Factor (lb/ton)	Reference	Annual Fuel Usage (TPY)	Annual Emissions (TPY)	Emission Factor (lb/1,000 gal)	Reference	Annual Fuel Usage (Gallons/yr)	Annual Emissions (TPY)	
<u>Criteria and Precursor Air Pollutants</u>									
Particulate Matter (PM)	1.296	1	188,782	122.33	15.36	4 (b)	804,298	6.18	128.51
Particulate Matter (PM <sub>10</sub> )	1.205	(a)	188,782	113.77	13.06	(a)	804,298	5.25	119.02
Sulfur Dioxide (SO <sub>2</sub> )	0.073	1	188,782	6.89	115.40	5 (b)	804,298	46.41	53.30
Nitrogen Oxides (NO <sub>x</sub> )	0.677	1	188,782	63.90	47	5	804,298	18.90	82.80
Carbon Monoxide (CO)	49.262	1	188,782	4,649.89	5	5	804,298	2.01	4,651.90
Volatile Organic Compounds (VOC)	1.668	2	188,782	157.44	0.28	6	804,298	0.11	157.56
Sulfuric Acid Mist (SAM)	0.0032	8	188,782	0.30	5.09	8	804,298	2.05	2.35
Lead - Total (PB)	4.45E-04	3	188,782	0.04	1.51E-03	7	804,298	6.07E-04	0.04
Beryllium (Be)	--	--	--	--	2.78E-05	7	804,298	1.12E-05	1.12E-05
Mercury (Hg)	--	--	--	--	1.13E-04	7	804,298	4.54E-05	4.54E-05

Note:

(a) Assuming 93% of PM is PM<sub>10</sub> for bagasse, and 85% of PM is PM<sub>10</sub> for No. 6 fuel oil.

(b) Average sulfur content of the fuel mix is 1.47%.

Unless otherwise specified, heating values for each fuel are as follows: 3,600 Btu/lb for wet bagasse and 153,645 Btu/gal for No. 6 fuel oil.

- |  |                 |                 |             |
|--|-----------------|-----------------|-------------|
| 1. Based on compliance test data, conducted by Air Consulting and Engineering: | PM              | 0.180 lb/MMBtu  | 11/20/2002  |
|  | SO <sub>2</sub> | 0.0101 lb/MMBtu | 12/8/2000   |
|  | NO <sub>x</sub> | 0.094 lb/MMBtu  | 1/3/1995    |
|  | CO              | 6.842 lb/MMBtu  | 1994 - 1995 |

2. Based on test data for similar bagasse boiler. (Bryant Boilers 1, 2, and 3 average = 0.232 lb/MMBtu.)

3. Based on EPA's AP-42 Table 1.6-5, "Emission Factors for Trace Elements from Wood Waste Combustion with PM controls" (2/99).

4. Based on emission limit of 0.1 lb/MMBtu for PM while firing No. 6 fuel oil.

5. Based on AP-42 Table 1.3-1, "Criteria Pollutant Emission Factors for Fuel Oil Combustion" (9/98), No. 6 fuel oil, normal firing. Assume 50% SO<sub>2</sub> removal from scrubber.

6. Based on AP-42 Table 1.3-3, "Emission Factors for Total Organic Compounds (TOC), Methane, and Nonmethane TOC (NMTOC) from Uncontrolled Fuel Oil Combustion" (9/98).

7. Based on AP-42 Table 1.3-11, "Emission Factors for Metals from Uncontrolled No. 6 Fuel Oil Combustion" (9/98).

8. From AP-42 Table 1.3-1: SO<sub>3</sub> represents 3.6% of SO<sub>2</sub>; then convert to H<sub>2</sub>SO<sub>4</sub> (x 98/80).

**TABLE D-2  
2002 EMISSIONS OF CRITERIA POLLUTANTS FOR U.S. SUGAR CORPORATION CLEWISTON BOILER NO. 2**

Regulated Pollutant	Emission Factors								Total Annual Emissions (TPY)
	Carbonaceous Fuel				No. 6 Fuel Oil				
	Emission Factor (lb/ton)	Reference	Annual Fuel Usage (TPY)	Annual Emissions (TPY)	Emission Factor (lb/1,000 gal)	Reference	Annual Fuel Usage (Gallons/vr)	Annual Emissions (TPY)	
<u>Criteria and Precursor Air Pollutants</u>									
Particulate Matter (PM)	1.296	1	225,369	146.04	15.36	5 (b)	732,805	5.63	151.67
Particulate Matter (PM <sub>10</sub> )	1.205	(a)	225,369	135.82	13.06	(a)	732,805	4.79	140.60
Sulfur Dioxide (SO <sub>2</sub> )	0.073	2	225,369	8.23	115.40	6 (b)	732,805	42.28	50.51
Nitrogen Oxides (NO <sub>x</sub> )	0.727	1	225,369	81.92	47	6	732,805	17.22	99.14
Carbon Monoxide (CO)	70.834	1	225,369	7,981.89	5	6	732,805	1.83	7,983.73
Volatile Organic Compounds (VOC)	1.668	3	225,369	187.96	0.28	7	732,805	0.10	188.06
Sulfuric Acid Mist (SAM)	0.0032	9	225,369	0.36	5.09	9	732,805	1.86	2.23
Lead - Total	4.45E-04	4	225,369	0.05	1.51E-03	8	732,805	5.53E-04	0.05
Beryllium (Be)	--	--	--	--	2.78E-05	8	732,805	1.02E-05	1.02E-05
Mercury (Hg)	--	--	--	--	1.13E-04	8	732,805	4.14E-05	4.14E-05

Note:

(a) Assuming 93% of PM is PM<sub>10</sub> for bagasse, and 85% of PM is PM<sub>10</sub> for No. 6 fuel oil.

(b) Average sulfur content of the fuel mix is 1.47%.

Unless otherwise specified, heating values for each fuel are as follows: 3,600 Btu/lb for wet bagasse and 153,645 Btu/gal for No. 6 fuel oil.

- Based on compliance test data, conducted by Air Consulting and Engineering:
 

PM	0.180 lb/MMBtu	12/17/2002
NO <sub>x</sub>	0.101 lb/MMBtu	1/4/1995
CO	9.838 lb/MMBtu	1994 - 1995
- Based on compliance test data, conducted by Air Consulting and Engineering for Boiler No. 1, 0.0101 lb/MMBtu (12/8/00).
- Based on test data for similar bagasse boiler. (Bryant Boilers 1, 2, and 3 average = 0.232 lb/MMBtu.)
- Based on EPA's AP-42 Table 1.6-5, "Emission Factors for Trace Elements from Wood Waste Combustion with PM Controls". (2/99).
- Based on emission limit of 0.1 lb/MMBtu for PM while firing No. 6 fuel oil.
- Based on AP-42 Table 1.3-1, "Criteria Pollutant Emission Factors for Fuel Oil Combustion" (9/98), No. 6 fuel oil, normal firing. Assume 50% SO<sub>2</sub> removal from scrubber.
- Based on AP-42 Table 1.3-3, "Emission Factors for Total Organic Compounds (TOC), Methane, and Nonmethane TOC (NMTOC) from Uncontrolled Fuel Oil Combustion" (9/98).
- Based on AP-42 Table 1.3-11, "Emission Factors for Metals from Uncontrolled No. 6 Fuel Oil Combustion" (9/98).
- From AP-42 Table 1.3-1: SO<sub>3</sub> represents 3.6% of SO<sub>2</sub>; then convert to H<sub>2</sub>SO<sub>4</sub> (x 98/80).

**TABLE D-3  
2003 EMISSIONS OF CRITERIA POLLUTANTS FOR U.S. SUGAR CORPORATION CLEWISTON BOILER NO. 1**

Regulated Pollutant	Emission Factors								Total Annual Emissions (TPY)
	Carbonaceous Fuel				No. 6 Fuel Oil				
	Emission Factor (lb/ton)	Reference	Annual Fuel Usage (TPY)	Annual Emissions (TPY)	Emission Factor (lb/1,000 gal)	Reference	Annual Fuel Usage (Gallons/yr)	Annual Emissions (TPY)	
<u>Criteria and Precursor Air Pollutants</u>									
Particulate Matter (PM)	1.267	1	176,732	111.96	15.17	4 (b)	666,974	5.06	117.02
Particulate Matter (PM <sub>10</sub> )	1.178	(a)	176,732	104.12	12.89	(a)	666,974	4.30	108.42
Sulfur Dioxide (SO <sub>2</sub> )	0.073	1	176,732	6.45	115.87	5 (b)	666,974	38.64	45.09
Nitrogen Oxides (NO <sub>x</sub> )	0.677	1	176,732	59.82	47	5	666,974	15.67	75.50
Carbon Monoxide (CO)	49,262	1	176,732	4,353.09	5	5	666,974	1.67	4,354.75
Volatile Organic Compounds (VOC)	1.778	2	176,732	157.11	0.28	6	666,974	0.09	157.21
Sulfuric Acid Mist (SAM)	0.0032	8	176,732	0.28	5.11	8	666,974	1.70	1.99
Lead - Total (PB)	2.45E-05	3	176,732	0.002	1.51E-03	7	666,974	5.04E-04	0.003
Beryllium (Be)	--	--	--	--	2.78E-05	7	666,974	9.27E-06	9.27E-06
Mercury (Hg)	--	--	--	--	1.13E-04	7	666,974	3.77E-05	3.77E-05

Note:

(a) Assuming 93% of PM is PM<sub>10</sub> for bagasse, and 85% of PM is PM<sub>10</sub> for No. 6 fuel oil.

(b) Average sulfur content of the fuel mix is 1.476%.

Unless otherwise specified, heating values for each fuel are as follows: 3,600 Btu/lb for wet bagasse and 151,704 Btu/gal for No. 6 fuel oil.

1. Based on compliance test data, conducted by Air Consulting and Engineering:	PM	0.176 lb/MMBtu	11/14/2003
	SO <sub>2</sub>	0.0101 lb/MMBtu	12/8/2000
	NO <sub>x</sub>	0.094 lb/MMBtu	1/3/1995
	CO	6.842 lb/MMBtu	1994 - 1995

2. Based on test data for similar bagasse boiler. (Bryant Boilers 1, 2, and 3 average = 0.247 lb/MMBtu.)

3. Based on average industry test data of 3.4E-06 lb/MMBtu or less.

4. Based on emission limit of 0.1 lb/MMBtu for PM while firing No. 6 fuel oil.

5. Based on AP-42 Table 1.3-1, "Criteria Pollutant Emission Factors for Fuel Oil Combustion" (9/98), No. 6 fuel oil, normal firing. Assume 50% SO<sub>2</sub> removal from scrubber.

6. Based on AP-42 Table 1.3-3, "Emission Factors for Total Organic Compounds (TOC), Methane, and Nonmethane TOC (NMTOC) from Uncontrolled Fuel Oil Combustion" (9/98).

7. Based on AP-42 Table 1.3-11, "Emission Factors for Metals from Uncontrolled No. 6 Fuel Oil Combustion" (9/98).

8. From AP-42 Table 1.3-1: SO<sub>3</sub> represents 3.6% of SO<sub>2</sub>; then convert to H<sub>2</sub>SO<sub>4</sub> (x 98/80).

**TABLE D-4  
2003 EMISSIONS OF CRITERIA POLLUTANTS FOR U.S. SUGAR CORPORATION CLEWISTON BOILER NO. 2**

Regulated Pollutant	Emission Factors								Total Annual Emissions (TPY)
	Carbonaceous Fuel				No. 6 Fuel Oil				
	Emission Factor (lb/ton)	Reference	Annual Fuel Usage (TPY)	Annual Emissions (TPY)	Emission Factor (lb/1,000 gal)	Reference	Annual Fuel Usage (Gallons/yr)	Annual Emissions (TPY)	
<u>Criteria and Precursor Air Pollutants</u>									
Particulate Matter (PM)	1.433	1	216,540	155.15	15.17	5 (b)	539,742	4.09	159.24
Particulate Matter (PM <sub>10</sub> )	1.333	(a)	216,540	144.29	12.89	(a)	539,742	3.48	147.77
Sulfur Dioxide (SO <sub>2</sub> )	0.360	2	216,540	38.98	115.87	6 (b)	539,742	31.27	70.25
Nitrogen Oxides (NO <sub>x</sub> )	0.727	1	216,540	78.71	47	6	539,742	12.68	91.40
Carbon Monoxide (CO)	70.834	1	216,540	7,669.20	5	6	539,742	1.35	7,670.55
Volatile Organic Compounds (VOC)	1.778	3	216,540	192.50	0.28	7	539,742	0.08	192.58
Sulfuric Acid Mist (SAM)	0.0159	9	216,540	1.72	5.11	9	539,742	1.38	3.10
Lead - Total	2.45E-05	4	216,540	0.003	1.51E-03	8	539,742	4.08E-04	0.003
Beryllium (Be)	--	--	--	--	2.78E-05	8	539,742	7.50E-06	7.50E-06
Mercury (Hg)	--	--	--	--	1.13E-04	8	539,742	3.05E-05	3.05E-05

Note:

(a) Assuming 93% of PM is PM<sub>10</sub> for bagasse, and 85% of PM is PM<sub>10</sub> for No. 6 fuel oil.

(b) Average sulfur content of the fuel mix is 1.476%.

Unless otherwise specified, heating values for each fuel are as follows: 3,600 Btu/lb for wet bagasse and 151,704 Btu/gal for No. 6 fuel oil.

- Based on compliance test data, conducted by Air Consulting and Engineering:
 

PM	0.199 lb/MMBtu	11/18/2003
NO <sub>x</sub>	0.101 lb/MMBtu	1/4/1995
CO	9.838 lb/MMBtu	1994 - 1995
- Based on average industry test data of 0.05 lb/MMBtu or less.
- Based on test data for similar bagasse boiler. (Bryant Boilers 1, 2, and 3 average = 0.247 lb/MMBtu.)
- Based on average industry test data of 3.4E-06 lb/MMBtu or less.
- Based on emission limit of 0.1 lb/MMBtu for PM while firing No. 6 fuel oil.
- Based on AP-42 Table 1.3-1, "Criteria Pollutant Emission Factors for Fuel Oil Combustion" (9/98), No. 6 fuel oil, normal firing. Assume 50% SO<sub>2</sub> removal from scrubber.
- Based on AP-42 Table 1.3-3, "Emission Factors for Total Organic Compounds (TOC), Methane, and Nonmethane TOC (NMTOC) from Uncontrolled Fuel Oil Combustion" (9/98).
- Based on AP-42 Table 1.3-11, "Emission Factors for Metals from Uncontrolled No. 6 Fuel Oil Combustion" (9/98).
- From AP-42 Table 1.3-1: SO<sub>3</sub> represents 3.6% of SO<sub>2</sub>; then convert to H<sub>2</sub>SO<sub>4</sub> (x 98/80).