

Golder Associates Inc.

6241 NW 23rd Street, Suite 500
Gainesville, FL USA 32653
Telephone (352) 336-5600
Fax (352) 336-6603
www.golder.com



April 25, 2007

063-7602
RECEIVED
APR 27 2007
BUREAU OF AIR REGULATION

Florida Department of Environmental Protection
Bob Martinez Center
2600 Blair Stone Road
Tallahassee, FL 32399-2400

Attention: Mr. Jeff Koerner, Air Permitting South

**RE: UNITED STATES SUGAR CORPORATION
CLEWISTON MILL (FACILITY NO. 0510003)
TITLE V RENEWAL APPLICATION**

Dear Mr. Jeff Koerner:

As per your letter dated March 30, 2007, please find enclosed four copies of the updated application pages for inclusion in the Title V air permit renewal for the Clewiston Mill. The revised application pages are being submitted to incorporate the following air construction permits and revisions into the Title V renewal permit:

- Increased capacity of Clewiston Boiler No. 8 (Permit No. 0510003-037-AC).
- Modified New White Sugar Dryer No. 2 (Permit No. 0510003-038-AC).
- Revised Compliance Assurance Monitoring (CAM) Plan parameters, tables, and graphs based on 2006 stack testing results for Boiler Nos. 1, 2, and 7. Revised parameters for Boiler No. 4 were addressed in the control equipment parameter modification application that is currently being submitted to the Florida Department of Environmental Protection (FDEP).

The modified oil firing requirements for Boiler Nos. 1, 2, and 4 in Permit No. 0510003-039-AC were addressed in the Title V request for additional information (RAI) response submitted to FDEP in September 2006. However, a typographical error was discovered in the page for the NO_x emissions for Boiler No. 4. Therefore, revised pages are attached.

If you have any questions, please do not hesitate to call me at (352) 336-5600.

Sincerely,

GOLDER ASSOCIATES INC.

David A. Buff, P.E., Q.E.P.
Principal Engineer




E. Claire Booth, E.I.
Staff Engineer

cc: Mr. Don Griffin, USSC
Mr. Peter Briggs, USSC
Mr. Ron Blackburn, FDEP SD Office
Mr. James Stormer, Palm Beach County Health Department

Enclosures

DB/CB/all

Y:\Projects\2006\0637602 US Sugar\Title V Revision\FINAL042507\L042507-602.doc

		EXPRESS	
GND		Pieces: 1/1	
FM: DEP AIR RESOURCE MGMT P. Adams DIRECTOR OFFICE STE 23 111 S MAGNOLIA DR TALLAHASSEE, FL 32301 UNITED STATES Phone: 850.921.9505		ORIGIN: TLH Sender's ref: 37550201000 A7 AY230	
To: DEP SOUTH DISTRICT MR. A. J. SATYI 2295 VICTORIA AIR RESOURCE FORT MYERS, FL UNITED STATES		POSTCODE: 33902 TEL: 239-332-6975	
Description: 0510003-040		Weight: 1 lbs for 1 pcs e: 2007-08-06	
(ZL)US33902		07TH Day	
		FMYW 7C FSC	
		WAYBILL: 21905955750 (Non-Negotiable)	

*Barbara -
 This goes in
 the U.S. super
 with V file
 0510003-040-AV about
 path*




▲ PEEL HERE **PEEL HERE ▲**

Please fold or cut in half
DO NOT PHOTOCOPY




Using a photocopy could delay the delivery of your package and will result in additional shipping charge

SENDER'S RECEIPT Waybill #: 21905955750		Rate Estimate: 3.09 Protection: Not Required Description: 0510003-040-AV 6/1/07 letter from U.S. Sugar	
To(Company): DEP South District Air Resources 2295 Victoria Avenue, Suite 364 Fort Myers, FL 33902 UNITED STATES		Weight (lbs.): 1 Dimensions: 0 x 0 x 0	
Attention To: Mr. A. J. Satyi Phone#: 239-332-6975		Ship Ref: 37550201000 A7 AY230 Service Level: Ground (Est. delivery in 1 business day(s))	
Sent By: P. Adams Phone#: 850-921-9505		Special Svc: Date Printed: 6/6/2007 Bill Shipment To: Sender Bill To Acct: 778941286	

DHL Signature (optional) _____ Route _____ Date _____ Time _____
 For Tracking, please go to www.dhl-usa.com or call 1-800-225-5345
 Thank you for shipping with DHL

Create new shipment  View pending shipments  Print waybill 



		GND		Pieces: 1/1
EXPRESS		ORIGIN: TLH		Sender's ref: 31550201000 A7 AY230
FM: DEP AIR RESOURCE MGMT P. Adams DIRECTOR OFFICE STE 23 111 S MAGNOLIA DR TALLAHASSEE, FL 32301 UNITED STATES Phone: 850-921-9505		To: U.S. EPA REGION 4 MR. GREGG M. WORLEY 611 FORSYTH STREET AIR PERMITS SECTION ATLANTA, GA 30303 UNITED STATES		POSTCODE: 30303
Description: 0510003-040-AC 6/1/07 letter from U.S. Sugar Weight: 1 lbs for 1 pcs Date: 2007-06-06		TEL: 404-562-9141		Day: 07TH
DHL standard terms and conditions apply.				
		HARB 6V ATT		
(2L)US30303				
WAYBILL: 21906093753		(Non-Negotiable)		



Please fold or cut in half
DO NOT PHOTOCOPY

Using a photocopy could delay the delivery of your package and will result in additional shipping charge

SENDER'S RECEIPT
 Waybill #: 21906093753

To(Company):
 U.S. EPA Region 4
 Air Permits Section
 61 Forsyth Street

Atlanta, GA 30303
 UNITED STATES

Attention To: Mr. Gregg M. Worley
 Phone#: 404-562-9141

Sent By: P. Adams
 Phone#: 850-921-9505

Rate Estimate: 3.09
 Protection: Not Required
 Description: 0510003-040-AC 6/1/07 letter from U.S. Sugar

Weight (lbs.): 1
 Dimensions: 0 x 0 x 0

Ship Ref: 37550201000 A7 AY230
 Service Level: Ground (Est. delivery in 1 business day(s))

Special Svc:

Date Printed: 6/6/2007
 Bill Shipment To: Sender
 Bill To Acct: 778941286

DHL Signature (optional) _____ Route _____ Date _____ Time _____

For Tracking, please go to www.dhl-usa.com or call 1-800-225-5345
 Thank you for shipping with DHL

Create new shipment 

View pending shipments

Print waybill 



Golder Associates Inc.

6241 NW 23rd Street, Suite 500
Gainesville, FL USA 32653
Telephone (352) 336-5600
Fax (352) 336-6603
www.golder.com



June 1, 2007

RECEIVED

07387562

JUN 05 2007

BUREAU OF AIR REGULATION

Florida Department of Environmental Protection
Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, FL 32399-2400

Attention: Mr. Jeffery F. Koerner, Air Permitting North

**RE: UNITED STATES SUGAR CORPORATION - CLEWISTON MILL
PROJECT NO. 0510003-040-AV
HEALTH-BASED COMPLIANCE ALTERNATIVE DEMONSTRATION
REQUEST FOR ADDITIONAL INFORMATION**

Dear Mr. Koerner:

United States Sugar Corporation (U.S. Sugar) has received the Florida Department of Environmental Protection's (FDEP) request for additional information (RAI) dated November 13, 2006 regarding the health-based compliance alternative (HBCA) Title V permit revision application. Each of the FDEP's requests is answered below, in the same order as they appear in the RAI letter.

Comment 1. EPA has given final approval to the AERMOD air quality model. The air quality modeling analysis provided with this project is based on the ISC-Prime model, which is no longer a guideline model. Please revise the analysis by using the AERMOD model. The Department reserves the right to ask additional questions regarding the revised analysis.

Response: The air quality modeling analysis has been performed using the AERMOD air quality model. All corresponding tables and figures have been revised accordingly and are included with this response.

Comment 2. See Table 2-2, "Stack and Operating Parameters Used in the HBCA Modeling Analysis". Boiler 4 is used as a backup boiler during the off-crop season. However, Boiler 4 is not identified in any of the scenarios for the off-crop season. Please explain.

Response: To obtain the worst-case annual impacts, each boiler was modeled at maximum capacity during the crop season. Boiler No. 4 is limited to 2,880,000 MMBtu/yr heat input. If this heat input is spread uniformly over the crop season (5,088 hr/yr), the resulting hourly heat input is 566 MMBtu/hr. Since this heat input is less than Boiler No. 4's maximum permitted 24-hour heat input rate of 633 MMBtu/hr, it was assumed that all of Boiler No. 4's annual heat input occurred during the crop season. Therefore, no off-crop season operation was assumed for Boiler No. 4. However, this was for modeling purposes only, and in no way should limit the year-round operation of Boiler No. 4, subject to the annual heat input limitation.

Comment 3. Table 4-2 of the application (Maximum Annual HCl-Equivalent Emissions During the Crop Season) indicates that a factor of 7% was applied to Cl₂ emissions from Boilers 7 and 8 based on test data for Boiler 8, as summarized in Table A-4. Please provide all other Cl₂ and HCl test data available for Boilers 7 and 8. Were the cyclone pre-controls operated as wet cyclones or dry cyclones? Please identify the operating conditions for the controls.

Response: Since the original submittal, additional performance tests for HCl and Cl₂ have been conducted on Boiler Nos. 7 and 8. The results are presented in Appendix A. The results of the January 25, 2007, test on Boiler No. 7 while burning bagasse is presented in Table A-4a. The results of the January 5, 2007, test on Boiler No. 8 while burning bagasse and the August 22, 2006, test on Boiler No. 8 while burning wood chips are presented in Table A-4b. Three 1-hour test runs were performed on each boiler, and EPA Method 26A was used to determine the HCl and Cl₂ concentrations. Based on these results, U.S. Sugar has revised the HCl and Cl₂ emissions. The HCl and Cl₂ emission test summary pages and corresponding fuel analysis results are included in Appendix B.

The procedure used to derive the HCl and Cl₂ emission rates were as follows:

1. We used the 90th percentile confidence level of the historical fuel analysis data and assumed 100 percent of Cl in the fuel is emitted out the stack, i.e., no control for Cl. The historical bagasse analysis data, as presented in Tables A-1 and A-2, has been revised to account for the more recent bagasse analysis results. In addition, the Boiler MACT bagasse analysis results were treated as one data point in order to not bias the statistical results, since the historical data is based on weekly composites of multiple daily samples beginning in 2002.
2. For both bagasse and wood fuel, the percentage of chlorine in the fuel emitted as Cl₂ was determined from the stack tests and analysis of fuel samples obtained during the stack tests. A safety factor of 2 was applied to these percentages for bagasse, and a safety factor of 3 was used for wood chips.
3. We assumed a percentage of Cl₂ was emitted out the stack, based on the results of the stack testing, with the remainder of the total chlorine in the fuel emitted as HCl, to be conservative.

This methodology was used to justify that most of the chlorine in the fuel is not emitted as Cl₂. The stack tests, summarized in Tables A-4a and A-4b, reveal that most of the chlorine in the fuel is actually absorbed in the fly ash. The tests show that only 6 percent of the total chlorine in bagasse is emitted as Cl₂ from Boiler No. 7, and only 8 percent of the total chlorine in bagasse is emitted as Cl₂ from Boiler No. 8. In addition, only 1 percent of chlorine in wood chips is emitted as Cl₂ from Boiler No. 8. The percentages were increased as described above in order to estimate worst-case emissions.

Since wood chips will normally only be burned during the off-crop season in Boiler Nos. 7 and 8, the HCl and Cl₂ emissions from this fuel were removed from the crop season emissions table. Table 4-2 is used to summarize emissions during the crop season, which are based solely on burning bagasse in all boilers. The revised Table 4-2 has been prepared and is included with this response.

The cyclone pre-controls on Boiler Nos. 7 and 8 were operated as wet cyclones during all HCl/Cl₂ testing. However, as described previously, no credit is being taken for removal of Cl in the control system.

During the January 25, 2007, bagasse test on Boiler No. 7, the water flow ranged from 24,240 to 32,340 gph and the total ESP power input ranged from 92 to 115 kilowatts (kW). During the January 5, 2007, bagasse test on Boiler No. 8, the water flow ranged from 12,000 to 27,000 gph and the total ESP power input ranged from 29 to 36 kW. During the August 22, 2006, wood chip test on Boiler No. 8, the water flow rate was 21,000 gph and the total ESP power input ranged from 20 to 46 kW.

The proposed Title V emission limits for HCl and Cl₂ for the boilers will be expressed in terms of lb/MMBtu (refer to revised Table 5-1 attached). These emission limits incorporate the HCl and Cl₂ test data, with appropriate safety factors.

Comment 4. Table 4-2 of the application (Maximum Annual HCl-Equivalent Emissions During the Crop Season) indicated that a factor of 15% was applied to Cl₂ emissions from Boilers 1, 2 and 4. Please provide the basis for the assumption of a 15% factor for Boilers 1, 2 and 4? Please provide all other Cl₂ and HCl test data available for Boilers 1, 2, and 4. The note in this table indicates that the factor will be verified by stack testing. Please identify the number of tests, the proposed EPA reference methods, and the expected timeframe during which the tests will be conducted.

Response: Stack tests were recently performed on Boiler Nos. 1 and 4 to obtain more accurate HCl and Cl₂ emissions. The stack test on Boiler No. 1 was performed on November 28, 2006, and the stack test on Boiler No. 4 was performed on December 1, 2006. Because Boiler Nos. 1 and 2 are nearly identical, the HCl and Cl₂ emission factors from the Boiler No. 1 test were applied to Boiler No. 2. The results of these two tests are presented in Table A-4a. Three 1-hour test runs were performed on each boiler, and EPA Method 26A was used to determine the HCl and Cl₂ concentrations. The HCl and Cl₂ emission test summary pages and corresponding fuel analyses results are included in Appendix A.

The procedures used to derive the HCl and Cl₂ emission rates for Boiler Nos. 1, 2 and 4 were the same as those described in the response to Comment 3 above. This methodology was used to justify that most of the chlorine in the fuel is not emitted as Cl₂. The stack tests indicate that only 4 percent of the total chlorine in the bagasse fuel burned in Boiler No. 1 and Boiler No. 4 is emitted as Cl₂. The same emission factor and percentage used for Boiler No. 1 was applied to Boiler No. 2 since they are nearly identical boilers.

The proposed Title V emission limits for HCl and Cl₂ for the boilers will be expressed in terms of lb/MMBtu (refer to revised Table 5-1 attached). These emission limits incorporate the HCl and Cl₂ test data, with appropriate safety factors.

Comment 5. When using fuel analyses in the HBCA, the NESHAP Subpart DDDDD provisions in 4(a)(1) require you assume that any chlorine detected will be emitted as Cl₂, when using fuel analyses. Was this done? Please explain.

Response: It was assumed that all chlorine in the fuel is emitted out the stack, but not as 100 percent Cl₂. Although 40 CFR 63, Appendix A, states that any detected chlorine must be assumed to be emitted as chlorine gas when using fuel analyses, this does not realistically portray the emissions from the boilers at the Clewiston Mill. Typically, for this type of combustion source, the majority of chlorine in the fuel is either absorbed or emitted as HCl. To assume that any chlorine detected is emitted as Cl₂ is a gross over-estimation. Tables A-4a and A-4b demonstrate that very little chlorine

in the fuel is emitted as Cl_2 . In any event, the proposed Title V limits in Table 5-1 reflect lb/MMBtu emission limits for both HCl and Cl_2 , which were used in the HBCA demonstration.

Comment 6. Please identify any specific deviations in the proposed fuel sampling and analysis protocol that differ from the NESHAP Subpart DDDDD provisions.

Response: Appendix A of the original HBCA application contains the fuel sampling and analysis protocol for bagasse and wood chips for the Boiler MACT testing. This fuel sampling and analysis protocol describes any deviations from the NESHAP Subpart DDDDD provisions. In addition, Table A-6 in Appendix A also identifies any deviations in the fuel sampling and analysis procedures from the NESHAP Subpart DDDDD provisions.

The main deviation in the bagasse fuel sampling and analysis protocol is that grab samples were obtained from the moving conveyor since it is not possible to "stop" the bagasse conveyor belts. Stopping the conveyor belts disrupts the boiler fuel feed, and therefore, boiler operation since the conveyor belt directly feeds the bagasse feeders on each boiler. In addition, there is no intermediate storage of bagasse between the bagasse storage pile, the conveyor belt, and the bagasse feeders.

During the off-crop season, wood chips are moved from the wood chip storage pile to the biomass fuel conveying system via front-end loader. The wood chips are dropped into a feed hopper, and the feed hopper discharges to a conveyor belt. The main deviation in the wood chips sampling and analysis protocol is that grab samples are obtained from the feed hopper just downstream of the point where wood chips are introduced into the feeder box. This allows the fuel samples to be taken as the wood chips are transported directly into the conveying system.

Comment 7. See Table 4-6, "Maximum Predicted Manganese Impacts". Please identify the calculations for the Hazard Quotient for manganese. For the predicted maximum impacts identified in this table, please provide a map of the facility and surrounding areas (i.e., Figure 4-2) showing the points of maximum predicted impacts. On this map, also identify accessible public areas such as residences, schools, parks, etc.

Response: The hazard quotient for manganese is calculated by dividing the maximum predicted impacts in micrograms per cubic meter ($\mu\text{g}/\text{m}^3$) by the manganese criteria value of $0.05 \mu\text{g}/\text{m}^3$.

The manganese emissions have been revised to reflect the updated emission factors for bagasse and wood chips, and to account for wood chip burning only during the off-crop season in Boiler Nos. 7 and 8. Tables 4-1 and 4-3 have been revised and are included with this response. Impacts at the property line and beyond were modeled using the AERMOD model and Ft. Myers meteorological data for years 2001 through 2005. As per discussions and correspondence with Cleve Holladay, Ft. Myers meteorological data is more appropriate to use in AERMOD than meteorological data from Palm Beach International Airport. Even though the Palm Beach International Airport meteorological data has historically been used to model impacts at the Clewiston Mill, it was recently determined that the surface roughness at the Clewiston Mill is more closely related to the surface roughness at Ft. Myers as compared to the surface roughness at the Palm Beach International Airport. Because of the very sensitive nature of the AERMOD model to surface roughness, it is more appropriate to use the Ft. Myers data.

The modeling results, which are presented in the revised Table 4-6, demonstrate that the maximum impacts occur at the property line. A map of the facility and surrounding areas is provided in

Figure 1 attached, which identifies sensitive receptor locations, and Figure 2 shows isopleths of the predicted annual average Mn impacts, the point of maximum impact.

Comment 8. See Table 4-7, "Maximum Predicted HCl-Equivalent Impacts". Please identify the calculations for the Hazard Quotients for Cl₂ and HCl as well as the overall Hazard Index. For the predicted maximum impacts identified in this table, please provide a map of the facility and surrounding areas (i.e., Figure 4-2) showing the points of maximum predicted impacts. On this map, also identify accessible public areas such as residences, schools, parks, etc.

Response: The hazard quotient for HCl is calculated by dividing the maximum predicted impacts in $\mu\text{g}/\text{m}^3$ by the HCl criteria value of $20 \mu\text{g}/\text{m}^3$. The hazard index is calculated by summing the hazard quotients for multiple substances and/or exposure pathways.

In Table 4-7 of the original HBCA application, the hazard index was not utilized since only the impacts from one pollutant (HCl-equivalent) were determined. Instead, the hazard quotient was used. The maximum predicted HCl impacts in Table 4-7 are based on the HCl-equivalent emissions, which takes into account both HCl and Cl₂ emissions. The modeling results are the same whether the HCl-equivalent is modeled or the HCl and Cl₂ emissions are taken into account separately. Therefore, the HCl-equivalent emissions were modeled. The results of this modeling were then compared to the HCl criteria value of $20 \mu\text{g}/\text{m}^3$.

In addition to the typographical error in the column title in Table 4-7, the HCl-equivalent emissions have been revised to reflect the updated emission factors for bagasse and wood chips, and to account for wood chip burning only during the off-crop season in Boiler Nos. 7 and 8. Tables 4-2 and 4-4 have been revised and are included with this response.

Impacts at the property line and beyond were modeled using the AERMOD model and Ft. Myers meteorological data for years 2001 through 2005. The modeling results, which are presented in the revised Table 4-7, demonstrate that the maximum impacts occur at the property line. A map of the facility and surrounding areas is provided in Figure 3 attached, which shows isopleths of the predicted annual average HCl impacts, the point of maximum impact, and identifies sensitive receptor locations.

Comment 9. Appendix A, 4(e) states, "During the emissions test, you must collect operating parameter monitoring system data at least every 15 minutes during the entire emissions test and establish the site-specific operating requirements in Tables 3 or 4, as appropriate, of subpart DDDDD using data from the monitoring system and the procedures specified in §63.7530 of subpart DDDDD." Please provide the monitoring data and specify the applicable operating limits.

Response: Because we are assuming zero control for Cl, i.e., no control device efficiency was relied upon for the HCl and Cl₂ emissions; we are not proposing any operating limits. The operating parameters for particulate matter (PM) control were submitted in the original Title V Compliance Assurance Monitoring (CAM) Plan and subsequent revisions.

Copies of the 15-minute monitoring data for the HCl/Cl₂ stack tests summarized in Tables A-4a and A-4b are included in Appendix A of this response.

Comment 10. In addition to the Title V permit parameters presented in Table 5-1, please include the following: emission release type, stack height, stack area, stack gas

temperature, stack gas exit velocity, type of control devices, control equipment operating limits, and fuel mix (annual average). Identify any restrictions (and the boilers) for which the HBCA analysis was based on less than 100% operation.

Response: Table 5-1 has been updated to include the above mentioned information as enforceable and non-enforceable Title V parameters. The annual average fuel mixtures for the crop and off-crop seasons are presented in Tables 5-2 and 5-3, respectively. The average of the historical bagasse data was used to determine the annual average fuel mix.

The off-crop season emissions were based on a 300,000 lb/hr steam restriction. Three different potential scenarios were evaluated based on the 300,000 lb/hr total steam restriction. These scenarios include operating all the boilers (Boiler Nos. 1, 2, 4, 7, and 8) during the crop season with various boilers operating during the off-crop season. The first off-crop season scenario includes burning wood chips in Boiler No. 7 only, the second off-crop season scenario includes burning wood chips in Boiler No. 8 only, and the third off-crop season scenario includes burning bagasse in Boiler Nos. 1 and 2.

Comment 11. Boilers 1, 2, 4, 7, and 8 are permitted to fire bagasse and distillate oil. Only Boiler 8 is permitted to fire wood. The addition of wood as a permitted fuel for other boilers would require a new HBCA analysis. Please comment.


Response: Because of plans to burn wood chips in Boiler Nos. 7 and 8 primarily during the off-crop season, emissions from this fuel are included in the revised tables for these boilers only (Tables 4-3 and 4-4). There are no plans to burn wood chips in Boiler Nos. 1, 2, and 4 at this time. U.S. Sugar is aware that adding wood chips as a permitted fuel for these boilers would require a new HBCA analysis.

Signed responsible official (R.O.) and professional engineer (P.E.) certification statements are included with this RAI response.

Thank you for consideration of this information. If you have any questions, please do not hesitate to call me at (352) 336-5600.

Sincerely,

GOLDER ASSOCIATES INC.



David A. Buff, P.E., Q.E.P.
Principal Engineer



E. Claire Booth, E.I.
Staff Engineer

CB/DB/kjp

Enclosures


cc: Peter Briggs, USSC
Keith Tingberg, USSC

Y:\Projects\2007\07387562 USSC RANL053007-562.doc

FACILITY INFORMATION

Application Responsible Official Certification

Complete if applying for an initial/revised/renewal Title V permit or concurrent processing of an air construction permit and a revised/renewal Title V permit. If there are multiple responsible officials, the "application responsible official" need not be the "primary responsible official."

1. Application Responsible Official Name: Neil Smith, Vice President and General Manager, Sugar Manufacturing
2. Application Responsible Official Qualification (Check one or more of the following options, as applicable): <input checked="" type="checkbox"/> For a corporation, the president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision-making functions for the corporation, or a duly authorized representative of such person if the representative is responsible for the overall operation of one or more manufacturing, production, or operating facilities applying for or subject to a permit under Chapter 62-213, F.A.C. <input type="checkbox"/> For a partnership or sole proprietorship, a general partner or the proprietor, respectively. <input type="checkbox"/> For a municipality, county, state, federal, or other public agency, either a principal executive officer or ranking elected official. <input type="checkbox"/> The designated representative at an Acid Rain source.
3. Application Responsible Official Mailing Address... Organization/Firm: United States Sugar Corporation Street Address: 111 Ponce de Leon Ave. City: Clewiston State: FL Zip Code: 33440
4. Application Responsible Official Telephone Numbers... Telephone: (863) 902-2703 ext. Fax: (863) 902-2729
5. Application Responsible Official Email Address: nsmith@ussugar.com
6. Application Responsible Official Certification: <i>I, the undersigned, am a responsible official of the Title V source addressed in this air permit application. I hereby certify, based on information and belief formed after reasonable inquiry, that the statements made in this application are true, accurate and complete and that, to the best of my knowledge, any estimates of emissions reported in this application are based upon reasonable techniques for calculating emissions. The air pollutant emissions units and air pollution control equipment described in this application will be operated and maintained so as to comply with all applicable standards for control of air pollutant emissions found in the statutes of the State of Florida and rules of the Department of Environmental Protection and revisions thereof and all other applicable requirements identified in this application to which the Title V source is subject. I understand that a permit, if granted by the department, cannot be transferred without authorization from the department, and I will promptly notify the department upon sale or legal transfer of the facility or any permitted emissions unit. Finally, I certify that the facility and each emissions unit are in compliance with all applicable requirements to which they are subject except as identified in compliance plan(s) submitted with this application.</i> Signature  _____ Date <u>5/11/07</u>

Professional Engineer Certification

1. Professional Engineer Name: David A. Buff Registration Number: 19011
2. Professional Engineer Mailing Address... Organization/Firm: Golder Associates Inc.** Street Address: 6241 NW 23rd Street, Suite 500 City: Gainesville State: FL Zip Code: 32653
3. Professional Engineer Telephone Numbers... Telephone: (352) 336-5600 ext. 545 Fax: (352) 336-6603
4. Professional Engineer Email Address: dbuff@golder.com
5. Professional Engineer Statement: <i>I, the undersigned, hereby certify, except as particularly noted herein*, that:</i> <i>(1) To the best of my knowledge, there is reasonable assurance that the air pollutant emissions unit(s) and the air pollution control equipment described in this application for air permit, when properly operated and maintained, will comply with all applicable standards for control of air pollutant emissions found in the Florida Statutes and rules of the Department of Environmental Protection; and</i> <i>(2) To the best of my knowledge, any emission estimates reported or relied on in this application are true, accurate, and complete and are either based upon reasonable techniques available for calculating emissions or, for emission estimates of hazardous air pollutants not regulated for an emissions unit addressed in this application, based solely upon the materials, information and calculations submitted with this application.</i> <i>(3) If the purpose of this application is to obtain a Title V air operation permit (check here <input type="checkbox"/>, if so), I further certify that each emissions unit described in this application for air permit, when properly operated and maintained, will comply with the applicable requirements identified in this application to which the unit is subject, except those emissions units for which a compliance plan and schedule is submitted with this application.</i> <i>(4) If the purpose of this application is to obtain an air construction permit (check here <input type="checkbox"/>, if so) or concurrently process and obtain an air construction permit and a Title V air operation permit revision or renewal for one or more proposed new or modified emissions units (check here <input checked="" type="checkbox"/>, if so), I further certify that the engineering features of each such emissions unit described in this application have been designed or examined by me or individuals under my direct supervision and found to be in conformity with sound engineering principles applicable to the control of emissions of the air pollutants characterized in this application.</i> <i>(5) If the purpose of this application is to obtain an initial air operation permit or operation permit revision or renewal for one or more newly constructed or modified emissions units (check here <input type="checkbox"/>, if so), I further certify that, with the exception of any changes detailed as part of this application, each such emissions unit has been constructed or modified in substantial accordance with the information given in the corresponding application for air construction permit and with all provisions contained in such permit.</i> <i>David A. Buff</i> _____ Signature Date <u>6/1/07</u> (seal)

* Attach any exception to certification statement.
** Board of Professional Engineers Certificate of Authorization #00001670

TABLE 2-2
STACK AND OPERATING PARAMETERS AND LOCATIONS USED IN THE HBCA MODELING ANALYSIS, U.S. SUGAR, CLEWISTON MILL

Emission Unit	Model ID	UTM Coordinates ^a		Relative Location ^b				Stack Data ^c				Heat Input (MMBtu/hr)	Steam Rate (lb/hr)	Operating Data ^e				
		East (m)	North (m)	X		Y		Height		Diameter				Temperature		Gas Flow (acfm)	Velocity	
				ft	m	ft	m	ft	m	ft	m			°F	°K		ft/s	m/s
Maximum Permitted - Crop Season																		
Boiler No. 1	BLR1O	506,184.6	2,956,934.8	185	56	-5	-1.5	213	64.9	8.0	2.44	496	245,000	150	339	250,000	82.9	25.3
Boiler No. 2	BLR2O	506,171.8	2,956,934.8	143	44	-5	-1.5	213	64.9	8.0	2.44	447	215,000	150	339	250,000	82.9	25.3
Boiler No. 4 ^f	BLR4O	506,128.2	2,956,936.3	0	0	0	0.0	150	45.7	8.2	2.50	566 ^g	268,246	160	344	251,257	79.3	24.2
Boiler No. 7 ^f	BLR7O	506,095.7	2,956,956.1	-107	-33	65	19.8	225	68.6	8.0	2.44	738	350,000	272	406	337,000	111.7	34.1
Boiler No. 8 ^f	BLR8O	506,046.2	2,956,987.3	-269	-82	167	51.0	199	60.7	10.9	3.32	1,077	575,000	255	397	437,000	78.1	23.8
												1,653,246						
Maximum Permitted - Off-Crop Season																		
Scenario A																		
Boiler No. 7 ^f	BLR7F	506,095.7	2,956,956.1	-107	-33	65	19.8	225	68.6	8.0	2.44	738	350,000	272	406	337,000	111.7	34.1
Scenario B																		
Boiler No. 8 ^f	BLR8F	506,046.2	2,956,987.3	-269	-82	167	51.0	199	60.7	10.9	3.32	1,077	575,000	255	397	437,000	78.1	23.8
Scenario C																		
Boiler No. 1	BLR1F	506,184.6	2,956,934.8	185	56	-5	-1.5	213	64.9	8.0	2.44	496	245,000	150	339	250,000	82.9	25.3
Boiler No. 2	BLR2F	506,171.8	2,956,934.8	143	44	-5	-1.5	213	64.9	8.0	2.44	447	215,000	150	339	250,000	82.9	25.3
												460,000						
300,000 lb/hr steam - Off-Crop Season																		
Scenario A																		
Boiler No. 7 ^f	BLR7F	506,095.7	2,956,956.1	-107	-33	65	19.8	225	68.6	8.0	2.44	633	300,000	272	406	289,000	95.8	29.2
Scenario B																		
Boiler No. 8 ^f	BLR8F	506,046.2	2,956,987.3	-269	-82	167	51.0	199	60.7	10.9	3.32	562	300,000	255	397	297,109	37.0	11.3
Scenario C ^d																		
Boiler No. 1	BLR1F	506,184.6	2,956,934.8	185	56	-5	-1.5	213	64.9	8.0	2.44	323	159,789	150	339	163,050	54.1	16.5
Boiler No. 2	BLR2F	506,171.8	2,956,934.8	143	44	-5	-1.5	213	64.9	8.0	2.44	292	140,223	150	339	163,050	54.1	16.5
												300,012						

^a Universal Transverse Mercator Coordinates, Zone 17, North American Datum of 1927 (NAD27).
^b Relative to Boiler No. 4.
^c Stack and operating data based on Title V renewal application (2005), unless otherwise noted.
^d Both boilers operating at 65.22% load, which equates to a total of 300,000 lb/hr steam. Boiler No. 2 is nearly identical to Boiler No. 1.
^e Boiler No. 4 limited to 2,850,000 MMBtu/yr, which equates to 566 MMBtu/hr for the crop season (5,058 hours).
^f Temperature and flow rate based on the average of the 2006 and 2007 stack test results.

TABLE 4-1
 MAXIMUM ANNUAL MANGANESE EMISSIONS DURING THE CROP SEASON, CLEWISTON MILL (SITE SPECIFIC DEMONSTRATION)

Boiler ID	Model ID	Emission Estimation Method	Heat Input (MMBtu/hr)	Steam Rate (lb/hr)	Hours of Operation (hr/yr) ^a	Mn Emission Factor (lb/MMBtu) ^b	Maximum Crop Season Mn Emissions (TPY)	Mn Emissions For 7-Months	
								(lb/hr)	(g/s)
Boiler No. 1	BLR1O	Bagasse Fuel Analysis	496	245,000	5,088	1.40E-03	1.767	0.694	0.0875
Boiler No. 2	BLR2O	Bagasse Fuel Analysis	447	215,000	5,088	1.40E-03	1.592	0.626	0.0789
Boiler No. 4 ^c	BLR4O	Bagasse Fuel Analysis	566	268,246	5,088	1.40E-03	2.016	0.792	0.0998
Boiler No. 7	BLR7O	Bagasse Fuel Analysis	738	350,000	5,088	1.40E-03	2.628	1.033	0.1302
Boiler No. 8	BLR8O	Bagasse Fuel Analysis	1,077	575,000	5,088	1.40E-03	3.836	1.508	0.1900
Total All Boilers				1,653,246			11.839	4.654	0.586

^a Based on 7 months of operation during the crop season (October - April), which is equivalent to 212 days.

^b Based on the 90th percentile of historical bagasse data (see Table A-2).

^c Boiler No. 4 limited to 2,880,000 MMBtu/yr heat input, which equates to 566 MMBtu/hr for 5,088 hr/yr.

TABLE 4.2
 MAXIMUM ANNUAL HCl-EQUIVALENT EMISSIONS DURING THE CROP SEASON, CLEWISTON MILL (SITE SPECIFIC DEMONSTRATION)

Boiler ID	Model ID	Emission Estimation Method	Heat Input (MMBtu/hr)	Steam Rate (lb/hr)	Hours of Operation (hr/yr) ^a	Chlorine Fuel Analysis Factor ^b (lb/MMBtu)	Percentages of Chlorine in Fuel Emitted as ^c		HCl Emission Factor (lb/MMBtu)	Cl ₂ Emission Factor (lb/MMBtu)	HCl Crop Season Emission Rate (TPY)	Cl ₂ Crop Season Emission Rate (TPY)	Crop Season Toxicity- Weighted Emission Rate (HCl-Equivalents) (TPY) ^d	HCl-Equivalent Emissions for 7-Months	
							HCl	Cl ₂						(lb/yr)	(g/s)
Boiler No 1	BLR10	Bagasse Fuel Analysis/Stack Tests	496	245,000	5,088	0.089	92%	5%	0.0819	0.0071	103.32	8.98	1,001.7	393.8	49.6
Boiler No 2	BLR20	Bagasse Fuel Analysis/Stack Tests	447	215,000	5,085	0.089	92%	8%	0.0819	0.0071	93.11	8.10	902.8	354.9	44.7
Boiler No 4	BLR10	Bagasse Fuel Analysis/Stack Tests	566 ^e	265,246	5,088	0.089	92%	8%	0.0819	0.0071	117.90	10.25	1,143.1	449.3	56.6
Boiler No 7	BLR70	Bagasse Fuel Analysis/Stack Tests	735	350,000	5,088	0.089	88%	12%	0.0783	0.0107	147.04	20.05	2,152.2	846.0	106.6
Boiler No 8	BLR80	Bagasse Fuel Analysis/Stack Tests	1,077	575,000	5,088	0.089	80%	16%	0.0738	0.0112	204.83	39.02	4,108.4	1,614.2	203.4
Total All Boilers				1,653,246									9,306.2	3,659.1	460.9

^a Based on 7 months of operation during the crop season (October - April), which is equivalent to 712 days

^b Based on the 95th percentile of historical bagasse data (see Table A-2)

^c Percentages of chlorine in fuel emitted are based on stack tests (see Tables A-4a and A-4b). A safety factor of 2 was added to the Cl₂ percentages. The same emission factor was applied to Boiler Nos. 1 and 2 because they are nearly identical.

^d Based on Equation 2 in Appendix A (Subpart DDDDD). KV_{HCl} is 0.02 mg/m³ and KV_{Cl_2} is 0.0702 mg/m³.

^e Boiler No. 4 limited to 2,880,000 MMBtu/yr heat input, which equates to 566 MMBtu/hr (at 5,088 hr/yr).

TABLE 4-3
 MAXIMUM ANNUAL MANGANESE EMISSIONS DURING THE OFF-CROP SEASON, U.S. SUGAR, CLEWISTON MILL (SITE SPECIFIC DEMONSTRATION)

Off-Crop Season Scenario	Boiler ID	Model ID	Emission Estimation Method	Heat Input (MMBtu/hr)	Steam Rate (lb/hr)	Hours of Operation (hr/yr) ^a	Emission Factor (lb/MMBtu) ^b	Maximum Off-Crop Season Mn Emissions (TPY)	Mn Emissions For 5-Months	
									(lb/hr)	(g/s)
Scenario A										
	Boiler No. 7	BLR7F	Wood Chip Fuel Analysis	633	300,000	3,672	4.90E-03	5.691	3.100	0.3905
Scenario B										
	Boiler No. 8	BLR8F	Wood Chip Fuel Analysis	562	300,000	3,672	4.90E-03	5.055	2.753	0.3469
Scenario C										
	Boiler No. 1	BLR1F	Bagasse Fuel Analysis	323	159,789	3,672	1.40E-03	0.832	0.453	0.0571
	Boiler No. 2	BLR2F	Bagasse Fuel Analysis	292	140,223	3,672	1.40E-03	0.749	0.408	0.0514
Boiler Nos. 1 & 2 Total					300,012			1.581	0.861	0.1085

^a Based on 5 months of operation during the off-crop season (May - September), which is equivalent to 153 days.

^b Based on the 90th percentile of historical bagasse and wood chips fuel analysis data (see Tables A-2 and A-3, respectively).

TABLE 4-4
MAXIMUM ANNUAL HCl-EQUIVALENT EMISSIONS DURING THE OFF-CROP SEASON, U.S. SUGAR, CLEVELAND MILL (S111 SPECIFIC DEMONSTRATION)

Off-Crop Season Scenario	Boiler ID	Model ID	Emission Estimation Method	Heat Input (MMBtu/hr) ^a	Steam Rate (lb/hr)	Hours of Operation (hr/yr) ^b	Chlorine Fuel Analysis Factor ^c (lb/MMBtu)	Percentage of Chlorine in Fuel Emitted as HCl ^d (%)		HCl Emission Factor (lb/MMBtu)	Cl ₂ Emission Factor (lb/MMBtu)	HCl Off-Crop Season Emission Rate (TPY)	Cl ₂ Off-Crop Season Emission Rate (TPY)	Off-Crop Season Toxicity-Weighted Emission Rate (HCl-Equivalents) (TPY) ^e	HCl-Equivalent Emissions for 5 Months (lb-hr) (g/s)	
Scenario A	Boiler No. 7	BLR7E	Wood chip fuel analysis/stack tests	633	300,000	3,672	0.310	97%	3%	0.301	0.0693	349.23	10.80	1,429.34	778.51	98.09
Scenario B	Boiler No. 8	BLR8E	Wood chip fuel analysis/stack tests	562	300,600	3,672	0.310	97%	3%	0.301	0.0693	310.72	9.29	1,269.68	691.55	87.13
Scenario C	Boiler No. 1	BLR1E	Bagasse fuel analysis/stack tests	323	189,289	3,672	0.089	92%	8%	0.082	0.0071	35.63	4.23	471.51	258.81	32.36
	Boiler No. 2	BLR2E	Bagasse fuel analysis/stack tests	292	140,223	3,672	0.089	92%	8%	0.082	0.0071	33.33	3.51	424.93	231.44	29.16
	Boiler Nos. 1 & 2 Total					309,012								896.44	488.26	61.52

^a Based on 300,000 lb/hr steam during the off-crop season (see Table 2-2).

^b Based on 5 months of operation during the off-crop season (May - September), which is equivalent to 133 days.

^c Based on the 99th percentile of fuel analysis data.

^d Percentages of chlorine in fuel emissions are based on stack tests (see Tables A-2a and A-3). A safety factor of 2 was added to the 1% percentages for bagasse; a safety factor of 3 was added for wood chips. The same emission factor was applied to Boiler Nos. 1 and 2 because they are nearly identical. U.S. Sugar is in the process of permitting wood chip burning in Boiler No. 7 for the off-crop season. The wood chip emission factor for Boiler No. 8 was used, since these are similar boilers.

^e Based on Equation 2 in Appendix A (Subpart DDDDD). KV_{HCl} is 0.02 mg/m³ and KV_{Cl_2} is 0.0032 mg/m³.

TABLE 4-6
MAXIMUM PREDICTED MANGANESE IMPACTS, U.S. SUGAR, CLEWISTON MILL

Scenario	Averaging Period	Year	Maximum Predicted Impact ($\mu\text{g}/\text{m}^3$)	Receptor Location ^a		Mn Criteria ($\mu\text{g}/\text{m}^3$)	Hazard Quotient ^b
				East (m)	North (m)		
Case A	Annual	2001	0.035	507,930	2,954,950	0.05	0.70
		2002	0.032	503,630	2,956,950		0.64
		2003	0.032	504,430	2,958,750		0.64
		2004	0.031	503,630	2,956,950		0.62
		2005	0.031	504,730	2,958,550		0.62
Case B	Annual	2001	0.038	504,230	2,958,550	0.05	0.76
		2002	0.035	503,630	2,956,950		0.70
		2003	0.034	504,430	2,958,650		0.68
		2004	0.034	504,130	2,958,250		0.68
		2005	0.034	504,130	2,958,150		0.68
Case C	Annual	2001	0.030	504,530	2,958,350	0.05	0.60
		2002	0.027	504,130	2,957,050		0.54
		2003	0.026	504,630	2,958,550		0.52
		2004	0.026	503,630	2,956,950		0.52
		2005	0.027	504,830	2,958,450		0.54

^a UTM coordinates in Zone 17, NAD 27.

^b The Hazard Quotient is calculated by dividing the maximum predicted impacts in $\mu\text{g}/\text{m}^3$ by the Mn criteria value of $0.05 \mu\text{g}/\text{m}^3$.

Note: Concentrations are highest predicted with AERMOD model and 5-years of meteorological data from Ft. Myers, 2001-2005.

TABLE 4-7
MAXIMUM PREDICTED HCL-EQUIVALENT IMPACTS, U.S. SUGAR, CLEWISTON MILL

Scenario	Averaging Period	Year	Maximum Predicted Impact ($\mu\text{g}/\text{m}^3$)	Receptor Location ^a		HCl Criteria ($\mu\text{g}/\text{m}^3$)	Hazard Quotient ^b
				East (m)	North (m)		
Case A	Annual	2001	20.1	507,730	2,955,250	20	1.0
		2002	17.1	504,130	2,957,050		0.9
		2003	17.9	504,630	2,958,550		0.9
		2004	17.0	503,630	2,956,950		0.9
		2005	17.6	504,830	2,958,450		0.9
Case B	Annual	2001	20.9	504,630	2,958,250	20	1.0
		2002	18.0	504,130	2,957,050		0.9
		2003	18.6	504,730	2,958,350		0.9
		2004	17.7	504,130	2,956,950		0.9
		2005	18.3	504,830	2,958,350		0.9
Case C	Annual	2001	20.5	504,930	2,957,950	20	1.0
		2002	17.9	504,330	2,956,950		0.9
		2003	18.1	504,930	2,958,150		0.9
		2004	17.6	504,130	2,956,950		0.9
		2005	18.3	505,030	2,958,150		0.9

^a UTM coordinates in Zone 17, NAD 27.

^b The Hazard Quotient is calculated by dividing the maximum predicted impacts in $\mu\text{g}/\text{m}^3$ by the HCl criteria value of $20 \mu\text{g}/\text{m}^3$.

Note: Concentrations are highest predicted with AERMOD model and 5-years of meteorological data from Ft. Myers, 2001-2005.

TABLE 5-1
TITLE V PERMIT LIMITS FOR SI RPART ODDISH (SUGAR, C) WINDSOR MILL

Unit	Process Parameter	Title V enforceable conditions				Stack and Operating Parameters (from enforceable Title V conditions)									
		Limit	Units	Average Time	Fuel Type	Emissions Release Type	Stack Height		Stack Area		Stack Gas Temperature		Exit Velocities		
							m	ft	m ²	ft ²	K	°F	m/s	ft/s	Control Device
Boiler No 1	Maximum Heat Input	406	MWh/hr	1 hr	Bagasse										
	Maximum Steam Rate	245,000	lb/hr	24 hr	Bagasse										
	Mo Emissions	1.40E-01	B-NM3/hr	--	Bagasse	Vertical Stack	44.9	213	2.1	50.33	339	151	25.1	51.0	Wet Scrubber
	CO Emissions	0.0027	B-NM3/hr	--	Bagasse										
Boiler No 2	Maximum Heat Input	447	MWh/hr	1 hr	Bagasse										
	Maximum Steam Rate	215,000	lb/hr	24 hr	Bagasse										
	Mo Emissions	1.40E-01	B-NM3/hr	--	Bagasse	Vertical Stack	44.9	213	2.0	50.33	339	151	25.1	51.0	Wet Scrubber
	CO Emissions	0.0027	B-NM3/hr	--	Bagasse										
Boiler No 4	Maximum Heat Input	633	MWh/hr	1 hr	Bagasse										
	Maximum Heat Input	600	MWh/hr	24 hr	Bagasse										
	Maximum Heat Input	2,450,000	MWh/yr	Annual	Bagasse	Vertical Stack	65.2	159	1.1	12.51	311	180	24.2	29.4	Wet Scrubber
	Mo Emissions	1.3E-01	B-NM3/hr	--	Bagasse										
Boiler No 7	Maximum Heat Input	817	MWh/hr	1 hr	Bagasse										
	Maximum Steam Rate	552,000	lb/hr	24 hr	Bagasse										
	Mo Emissions	1.10E-01	B-NM3/hr	--	Bagasse	Vertical Stack	68.6	275	1.8	51.11	306	271	31.1	111.9	ESP, Wet Scrubber
	CO Emissions	0.011	B-NM3/hr	--	Bagasse										
Boiler No 8	Maximum Heat Input	1,145	MWh/hr	1 hr	Bagasse										
	Maximum Steam Rate	525,000	lb/hr	24 hr	Bagasse										
	Maximum Heat Input	1,072	MWh/hr	24 hr	Bagasse	Vertical Stack	60.3	199	1.5	41.18	302	255	24.9	28.1	ESP, Dry Sand Separator, Wet Cyclone, SNEK
	Mo Emissions	1.40E-01	B-NM3/hr	--	Bagasse										
ADDITIONAL CROP SEASON LIMITATIONS	Boiler Nos 1, 2, 4, 7, 8	Maximum Operating Hours (each boiler)	3,000	hr/yr	--										
	Boiler Nos 1, 2, 4, 7, 8	Total Maximum Steam Rate	1,000,000	lb/hr	--										
ADDITIONAL OFF-CROP SEASON LIMITATIONS	Boiler Nos 1, 2, 4, 7, 8	Maximum Operating Hours (each boiler)	1,672	hr/yr	--										
	Boiler No 1	Maximum Steam Rate	300,000	lb/hr	--	Vertical Stack	44.9	213	4.0	50.33	332	151	16.5	33.1	Wet Scrubber
Boiler No 2	Maximum Steam Rate	300,000	lb/hr	--	Vertical Stack	44.9	213	4.0	50.33	332	151	16.5	33.1	Wet Scrubber	
Boiler No 7	Maximum Steam Rate	300,000	lb/hr	--											
	Mo Emissions	4.0E-01	B-NM3/hr	--	Wood Chips	Vertical Stack	64.6	225	1.5	51.11	456	271	29.2	92.4	ESP, Wet Sand Separator
	CO Emissions	0.040	B-NM3/hr	--	Wood Chips										
	CO Emissions	0.100	B-NM3/hr	--	Wood Chips										
Boiler No 8	Maximum Steam Rate	300,000	lb/hr	--											
	Mo Emissions	4.0E-01	B-NM3/hr	--	Wood Chips	Vertical Stack	60.3	199	1.6	51.18	302	255	11.1	32.1	ESP, Dry Sand Separator, Wet Cyclone, SNEK
	CO Emissions	0.100	B-NM3/hr	--	Wood Chips										
	CO Emissions	0.100	B-NM3/hr	--	Wood Chips										

**TABLE 5-2
MAXIMUM ANNUAL FUEL MIXTURES DURING THE CROP SEASON, U.S. SUGAR, CLEWISTON MILL**

Boiler ID	Fuel Type	24-Hour Heat Input (MMBtu/hr)	Hours of Operation ^a (hr/yr)	Heating Value ^b (Btu/lb)	Maximum Fuel Usage (TPY)
Boiler No. 1	Bagasse	496	5,088	3,819	330,407
Boiler No. 2	Bagasse	447	5,088	3,819	297,766
Boiler No. 4 ^c	Bagasse	566	5,088	3,819	377,037
Boiler No. 7	Bagasse	738	5,088	3,819	491,614
Boiler No. 8	Bagasse	1,077	5,088	3,819	717,436

^a Based on 7 months of operation during the crop season (October - April) , which is equivalent to 212 days.

^b Based on 3,819 Btu/lb for bagasse and the maximum 24-hour heat input capacity of each boiler. The heating value for bagasse is based on the average of historical fuel data (2002-2007) as presented in Table A-1.


^c Boiler No. 4 limited to 2,880,000 MMBtu/yr heat input, which equates to 566 MMBtu/hr for 5,088 hr/yr.

TABLE 5-3
MAXIMUM ANNUAL FUEL MIXTURES DURING THE OFF-CROP SEASON, U.S. SUGAR, CLEWISTON MILL

Off-Crop Season Scenario	Boiler ID	Fuel Type	24-Hour Heat Input (MMBtu/hr)	Hours of Operation ^a (hr/yr)	Heating Value ^b (Btu/lb)	Maximum Fuel Usage (TPY)
Scenario A	Boiler No. 7	Wood Chips	633	3,672	4,905	236,939
Scenario B	Boiler No. 8	Wood Chips	562	3,672	4,905	210,363
Scenario C	Boiler No. 1	Bagasse	323	3,672	3,819	155,284
	Boiler No. 2	Bagasse	292	3,672	3,819	140,380

^a Based on 5 months of operation during the off-crop season (May - September), which is equivalent to 153 days.

^b Based on 3,819 Btu/lb for bagasse, 4,905 Btu/lb for wood chips, and the maximum 24-hour heat input capacity of each boiler. The heating value for bagasse is based on the average of historical fuel data (2002-2007) as presented in Table A-1. The heating value for wood chips is based on the average of the June and August 2006 fuel sampling results, as presented in Table A-3.




Sensitive Area


- 1 - Hendry Family Care Center
- 2 - Clewiston Primary School
- 3 - Mount Calvary Baptist Church
- 4 - Missionary Baptist Church
- 5 - Clewiston Middle School
- 6 - Iglesia Misionara Mundial
- 7 - Kingdom hall of Jehovah's Witness
- 8 - Clewiston Seventh Day
- 9 - First Missionary Baptist Church
- 10 - Evangel Assembly of God
- 11 - Hendry Regional Medical Center
- 12 - Clewiston High School
- 13 - First United Methodist Church of Clewiston
- 14 - St. Martin's Episcopal Church
- 15 - Iglesia De Dios Pentecostal
- 16 - First Baptist Church Clewiston
- 17 - Community Prayer Worship Center
- 18 - Family Home Care
- 19 - Clewiston Intermediate School
- 20 - Community Presbyterian Church
- 21 - Faith Lutheran Church
- 22 - Clewiston Church of Christ
- 23 - School
- 24 - Park
- 25 - Auditorium
- 26 - Elementary School

REFERENCE

Projection: Transverse Mercator Datum: NAD 27 Coordinate System: UTM Zone 17




PROJECT	U.S. Sugar Corporation Clewiston Mill
TITLE	Locations of Sensitive Areas





LEGEND

- MN Hazard Quotient Contours
 - 0.2
 - 0.4
 - 0.6
- ★ Location of Maximum = 0.77
- ⊙ Sensitive Area
- - - Clewiston Mill Boundary

REFERENCE
 Projection: Transverse Mercator Datum: NAD 83 Coordinate System: UTM Zone 17



PROJECT	U.S. Sugar Corporation Clewiston Mill	
TITLE	Manganese Hazard Quotient Contours	
 GOLDER ASSOCIATES CONSULTANTS & ENGINEERS	PROJECT NO: 070002 CLIENT: U.S. Sugar Corporation DATE: 08/11/2009 DRAWN BY: J. [unreadable] CHECKED BY: [unreadable]	SCALE: AS SHOWN REVISED: 08/11/2009 FIGURE 2




LEGEND

- HCl Hazard Quotient Contours**
- 0.2
 - - - 0.4
 - 0.6
 - 0.8
 - 1.0
- ★ Location of Maximum = 1.04
 - ⊙ Sensitive Area
 - Clewiston Mill Boundary

REFERENCE

Projection: Transverse Mercator Datum: NAD 27 Coordinate System: UTM Zone 17



PROJECT:	U.S. Sugar Corporation Clewiston Mill	
TITLE:	HCl Hazard Quotient Contours	
	PROJECT NUMBER	SCALE: 1:500
	DRAWN BY	DATE
	CHECKED BY	DATE
	APPROVED BY	DATE
		FIGURE 3

APPENDIX A

TABLE A1
PROXIMATE, ULTIMATE, AND HEAT CONTENT ANALYSIS RESULTS FOR BAGASSE FROM U.S. SUGAR CLEMISTON

Parameter	Units	Analysis Results (dry basis) for Sample Weeks (collection dates)																				
		11/1-1/20/02	1/21-2/3/02	2/4-2/10/02	2/11-2/17/02	2/18-2/24/02	2/25-3/3/02	3/4-3/10/02	3/11-3/17/02	3/18-3/24/02	3/25-3/31/02	4/1-4/7/02	4/8-4/14/02	4/15-4/21/02	4/22-4/28/02	4/29-5/5/02	5/6-5/12/02	5/13-5/19/02	5/20-5/26/02	5/27-6/2/02	6/3-6/9/02	
No. of Samples Computed		39	42	41	42	43	39	41	42	41	42	41	39	23	26	42	28	36	34	38	30	32
Moisture	% as received	52.86	52.01	50.49	50.06	49.99	50.31	50.18	50.84	51.32	41.60	52.56	54.36	51.20	50.95	51.48	51.66	51.12	51.56	52.96	52.84	55.07
Ash	%	4.04	2.95	5.32	5.04	5.14	3.61	3.15	2.61	3.91	1.23	3.74	0.87	8.40	6.19	7.30	6.65	3.31	4.19	4.12	5.56	5.60
Ash	Bt-NM(Htu)	5.10	6.54	6.90	6.39	6.54	4.48	3.98	3.25	4.91	4.03	4.65	6.00	10.96	8.09	9.54	8.75	4.17	5.02	5.21	7.05	7.16
Volatiles	%	85.41	86.38	87.24	82.95	83.42	81.52	85.69	87.68	87.31	81.64	81.82	83.75	79.86	76.99	81.43	81.59	83.90	83.65	85.91	87.96	82.31
Fixed C	%	10.55	10.67	11.41	12.10	11.44	11.87	11.56	9.71	8.79	12.73	11.41	11.76	11.34	12.22	11.27	11.76	12.29	12.16	9.97	11.46	12.07
HHV	Htu Bt, as received	3,735	3,828	3,871	3,918	4,005	4,012	3,941	3,951	3,872	3,869	3,823	3,721	3,740	3,813	3,715	3,675	3,880	4,047	3,711	3,715	3,517
HHV	Htu Bt, dry	7,522	7,598	7,525	7,884	7,852	8,033	7,911	8,037	7,951	7,994	8,058	8,111	7,664	7,900	7,655	7,602	7,936	8,356	7,696	7,878	7,827
MMH	Htu(Bt)	8,204	8,240	8,301	8,338	8,313	8,376	8,189	8,370	8,301	8,263	8,397	8,368	8,428	8,456	8,315	8,190	8,230	8,752	8,261	8,381	8,330
MAF	Htu(Bt)	8,256	8,220	8,264	8,301	8,277	8,376	8,168	8,253	8,276	8,261	8,372	8,333	8,366	8,440	8,261	8,143	8,208	8,722	8,246	8,342	8,291
Air Dry Loss	%	52.23	51.65	50.60	48.75	48.10	49.83	49.58	50.05	49.85	50.75	51.98	53.59	50.58	49.72	50.64	50.85	50.26	50.97	52.53	52.19	54.07
Carbon	%	47.59	47.65	47.06	46.91	46.78	47.75	48.12	48.26	47.61	48.34	47.53	48.26	46.35	46.64	46.11	49.51	50.78	50.94	49.91	49.21	48.88
Hydrogen	%	5.47	5.60	5.63	5.51	5.98	5.90	6.10	6.49	6.01	6.31	6.41	5.23	4.71	5.21	4.90	6.39	5.16	6.39	6.62	6.46	6.59
Nitrogen	%	0.16	0.34	0.36	0.28	0.33	0.10	0.76	0.41	0.16	0.38	0.41	0.29	0.25	0.31	0.33	0.33	0.31	0.38	0.30	0.30	0.50
Sulfur	%	0.06	0.05	0.07	0.03	0.07	0.07	0.04	0.04	0.01	0.05	0.07	0.09	0.05	0.05	0.07	0.07	0.09	0.08	0.08	0.07	0.09
Oxygen	%	42.37	43.37	41.56	42.07	41.80	42.19	42.23	42.19	42.05	41.69	41.80	41.26	40.24	41.34	41.29	37.05	39.62	38.09	38.91	38.76	38.54
SO ₂	Bt-NM(Htu)	0.15	0.13	0.15	0.08	0.18	0.14	0.10	0.10	0.10	0.13	0.18	0.22	0.13	0.13	0.19	0.19	0.21	0.19	0.15	0.18	0.24
Factor																						
Ed	du (Htu)Btu	9,139	9,203	9,390	9,221	9,403	9,354	9,607	9,722	9,197	9,716	9,562	9,414	9,043	9,659	9,072	10,794	10,195	10,025	10,367	10,315	10,367

Note: % = percent
 Htu(Bt) = British thermal unit per pound
 C = carbon
 HHV = higher heating value
 Bt-NM(Htu) = pounds per million British thermal unit
 Htu = moisture and ash free, dry basis heating value without ash included
 MAF = mineral and matter free, heating value without sulfur and ash included
 SO₂ = sulfur dioxide

TABLE 1
PROXIMATE, ELEMENTAL, AND HEAT CONTENT ANALYSIS RESULTS FOR BAGASSE FROM A SUGAR REFINERY

Parameter	Units	Boiler MAC 4 Results																								Boiler MAC 4 Energy Average ^a	Range			Parameter
		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24		Min	Max	Avg	
No. of Samples Compensed																														
Moisture	% as received	54.24	56.02	59.17	57.27	58.61	58.16	59.95	59.41	49.91	49.80	46.23	58.48	55.50	45.52	54.16	57.30	59.04	52.42	51.82	51.55	52.23	53.03	57.53	44.07	44.94	55.07	51.74	Moisture	
Ash	%	10.64	7.08	5.07	3.58	6.19	4.19	4.78	3.21	5.12	6.49	5.23	5.80	6.47	3.11	5.29	22.00	16.57	5.16	3.32	3.25	4.22	4.86	9.15	6.52	4.42	14.40	7.12	Ash	
Ash	lb/MMBtu	14.42	9.11	6.39	4.82	8.87	5.26	6.61	3.89	7.00	8.45	7.44	8.33	10.75	2.86	7.54	14.14	6.84	4.39	4.54	5.27	6.80	12.82	9.01	1.25	19.96	6.56	Ash		
Volatiles	%	37.65	41.26	43.28	44.71	42.05	47.41	43.94	41.86	25.12	24.51	27.84	43.44	41.73	24.57	32.02	48.52	27.51	43.18	43.65	42.71	41.11	41.90	29.67	40.16	29.86	47.68	33.32	Volatiles	
Fixed C	%	11.71	11.66	13.55	11.51	11.73	12.40	11.26	14.91	16.02	14.49	16.89	14.76	11.80	13.25	15.44	10.18	11.92	13.66	12.98	12.16	11.47	13.14	11.84	12.55	8.79	12.79	11.15	Fixed C	
HHV	Btu/lb, as received	3,373	3,616	3,240	3,441	3,255	3,137	3,218	4,118	4,025	4,094	4,560	3,311	3,458	3,700	3,152	3,014	3,257	3,669	3,890	3,817	3,903	3,710	3,105	3,578	3,527	4,043	3,519	HHV	
HHV	Btu/lb, dry	7,378	7,799	7,923	8,130	7,994	7,962	8,185	8,103	7,816	7,920	8,168	7,712	7,265	7,560	7,447	6,453	7,217	7,324	8,041	7,826	8,002	7,969	7,217	7,289	7,402	8,354	7,944	HHV	
MMF	Btu/lb	8,335	8,412	8,381	8,517	8,426	8,119	8,639	8,601	8,705	8,668	8,593	8,290	8,348	8,293	7,771	8,746	8,330	8,217	8,342	8,190	8,363	8,552	8,640	8,434	8,189	8,252	8,350	MMF	
MMF	Btu/lb	8,256	8,161	8,346	8,410	8,382	8,110	8,496	8,500	8,612	8,522	8,556	8,218	8,343	8,258	8,136	8,769	8,350	8,157	8,321	8,113	8,213	8,501	8,264	8,161	8,244	8,222	8,315	MMF	
Air Dry Loss	%	51.74	55.35	58.24	56.50	57.92	57.27	58.15	48.08	47.21	45.83	41.22	47.68	44.20	54.92	51.55	52.59	55.21	51.21	50.32	51.44	46.97	50.74	57.42	52.91	45.10	54.07	50.15	Air Dry Loss	
Carbon	%	45.26	44.29	48.91	46.04	46.15	49.61	46.32	52.22	49.50	50.00	50.42	51.14	50.06	49.28	45.52	42.47	42.21	52.54	53.32	52.56	52.29	51.07	44.21	41.66	36.11	50.94	48.47	Carbon	
Hydrogen	%	5.58	5.28	5.80	5.29	5.45	5.62	5.43	7.82	5.14	5.41	5.68	6.01	4.97	5.96	5.17	5.19	5.25	5.66	5.80	5.43	5.96	5.27	5.14	5.74	4.11	8.62	5.90	Hydrogen	
Nitrogen	%	0.52	0.47	0.49	0.55	0.42	0.44	0.42	0.31	0.26	0.41	0.40	0.18	0.52	0.55	0.18	0.49	0.45	0.27	0.28	0.29	0.33	0.42	0.55	0.43	0.25	0.43	0.35	Nitrogen	
Sulfur	%	0.05	0.16	0.07	0.10	0.16	0.07	0.06	0.05	0.05	0.05	0.05	0.10	0.07	0.07	0.04	0.05	0.01	0.08	0.06	0.06	0.04	0.07	0.05	0.09	0.03	0.09	0.06	Sulfur	
Oxygen	%	37.43	34.31	39.66	40.11	39.63	40.03	39.57	39.69	46.61	37.76	18.21	37.10	46.41	35.62	14.20	30.80	35.20	35.92	36.56	36.07	37.26	15.71	14.72	32.07	32.15	43.37	34.12	Oxygen	
SO ₂	lb/MMBtu	0.14	0.16	0.18	0.17	0.18	0.16	0.18	0.15	0.11	0.21	0.21	0.26	0.19	0.24	0.15	0.16	0.19	0.21	0.20	0.15	0.11	0.19	0.15	0.24	0.05	0.24	0.15	SO ₂	
Factor																														
Ed	lb/MMBtu	9,927	9,967	9,821	9,415	9,431	9,801	9,345	9,753	9,422	10,510	9,883	10,416	10,455	10,716	10,442	10,561	10,254	10,611	10,904	10,913	10,582	10,471	10,111	10,211	9,910	10,394	9,871	Ed	

Note: % = percent
 Btu/lb = British thermal unit per pound
 C = Celsius
 HHV = higher heating value
 lb/MMBtu = pounds per 1000 British thermal units
 MMF = moisture and ash free, dry basis heating value with ash included
 MMF = mineral and matter free, heating value without sulfur and ash included
 SO₂ = sulfur dioxide

^a The average of the Boiler MAC 4 tests was used to determine the total average, minimum, and maximum. This was done for consistency with the historical bagasse data which is based on weekly compiles.

TABLE A-2
METABOLIC ANALYSIS FOR BAGGAGE FROM 1 & 2 BAGGAGE

Parameter	Unit	Concentration (ppm) based on Sample Weight (mg) (mg/kg)																			
		114 020607	114 020608	114 020609	114 020610	114 020611	114 020612	114 020613	114 020614	114 020615	114 020616	114 020617	114 020618	114 020619	114 020620	114 020621	114 020622	114 020623	114 020624	114 020625	114 020626
Adipic acid	ppm	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
Benzoic acid	ppm	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
Chloroacetic acid	ppm	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
Formic acid	ppm	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
Glucuronic acid	ppm	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
Malic acid	ppm	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
Succinic acid	ppm	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
Valeric acid	ppm	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
Total	ppm	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
Moisture	%	10.1	10.1	10.1	10.1	10.1	10.1	10.1	10.1	10.1	10.1	10.1	10.1	10.1	10.1	10.1	10.1	10.1	10.1	10.1	10.1
Total	%	10.1	10.1	10.1	10.1	10.1	10.1	10.1	10.1	10.1	10.1	10.1	10.1	10.1	10.1	10.1	10.1	10.1	10.1	10.1	10.1

* For element mass data and mg/kg level, 100% detection based on the minimum, maximum, average, and standard deviation, mean calculated on taking one half of detection limit. (Detection Limit given and included in the table)

** For element mass, average and standard deviation for metals and toxic elements on the basis of all samples, with a lower detection limit.

*** For element mass (not calculated based on the following equation):

$$DL = (t_{(1-\alpha/2, n-1)} \times s) / \sqrt{n}$$

DL = 95% confidence interval detection limit (mg/kg)

s = standard deviation of sample measurements (mg/kg)

n = number of samples

† For element mass (not calculated based on the following equation):

$$DL = (t_{(1-\alpha/2, n-1)} \times s) / \sqrt{n}$$

DL = 95% confidence interval detection limit (mg/kg)

s = standard deviation of sample measurements (mg/kg)

n = number of samples

TABLE A.7 METALS AND CHEMICAL ANALYSES FOR PACAGE FROM S. BONAER LLEWELLOW

Table with 3 main sections: 'Concentrations by Metal in Sample 3 (in 1000ths g/g)', 'TOTAL PALETTE STEELING', and 'TOTAL PALETTE STEELING'. Each section contains columns for Element, Unit, and various sample numbers (e.g., 317-27301, 317-27302, etc.).

* In parentheses, the reported value minus the mean, standard error, and standard deviation (in parentheses) are given for all of the elements. Duplicate samples were not included in the analysis.
† Mean, standard error, and standard deviation are given for mercury as a total only on the pad-metal sample with a 1-mb dispersion limit.
** An arbitrary long dispersion limit on the dispersion analysis (L) (L) is 19.642 (L)
p = mean + (SD) * z
p = 95% confidence limit (padding amount) (L) (L)
p = 99% confidence limit (padding amount) (L) (L)
SD = standard deviation of padding amount (L) (L)
L = dispersion limit (L) for 95% confidence probability (L) for a dispersion of (L)
n = number of samples
†† An arbitrary long dispersion limit on the dispersion analysis (L) (L) is 19.642 (L)
‡ The number of the data set (L) was used to document the data for the elements, mercury, and 95% confidence level. The use of the number (L) was used to document the data for the elements.

Parameter	Unit	ROBE MALT 1997 ¹				Range			Parameter
		1997	1998	1999	2000	Min	Max	Std	
Chlorine	ppm	296	342	349	336	137	336	5%	Chlorine
Asenic	ppm	—	—	—	—	0.1	0.11	0.01	Asenic
Dehydro	ppm	—	—	—	—	0.1	0.05	0.08	Dehydro
Cellulose	ppm	—	—	—	—	0.1	0.05	0.08	Cellulose
Chromium	ppm	—	—	—	—	0.6	0.72	0.61	Chromium
Lead	ppm	—	—	—	—	0.1	0.15	0.05	Lead
Manganese	ppm	19.6	2.8	9.6	14.8	11.7	7.4	11.3	Manganese
Mercury	ppm	—	—	—	—	0.1	0.03	0.11	Mercury
Nickel	ppm	—	—	—	—	0.1	0.06	0.12	Nickel
Selenium	ppm	—	—	—	—	0.1	0.06	0.12	Selenium
Mercury	ppm	0.01	0.01	0.01	0.01	0.02	0.01	0.11	Mercury
Aluminum	%	51.6	51.2	51.1	51.0	53.3	40.0	55.3	Aluminum
Moisture	%	—	—	—	—	—	—	—	Moisture
Phosphorus	%	—	—	—	—	—	—	—	Phosphorus

Parameter	Unit	ROBE MALT 1997 ¹				Range			Standard Deviation	95% Confidence Interval	Parameter
		1997	1998	1999	2000	Min	Max	Std			
ADP	lb/b	7.419	6.462	5.966	7.217	5.297	8.224	2.471	—	ADP	
Chlorine	lb/100lb	0.072	0.141	0.147	0.019	0.057	0.111	0.092	0.067	0.044	
Asenic	lb/100lb	—	—	—	—	2.21E-05	1.61E-05	1.16E-05	1.09E-05	—	
Dehydro	lb/100lb	—	—	—	—	1.70E-05	1.43E-05	1.15E-05	1.27E-05	—	
Cellulose	lb/100lb	—	—	—	—	1.98E-05	1.41E-05	1.34E-05	1.07E-05	—	
Chromium	lb/100lb	—	—	—	—	3.07E-04	1.70E-04	9.90E-05	1.41E-04	—	
Lead	lb/100lb	—	—	—	—	2.94E-01	1.24E-01	1.08E-01	3.20E-01	—	
Manganese	lb/100lb	2.41E-01	5.74E-01	1.14E-01	2.12E-01	1.60E-01	3.04E-01	1.60E-01	1.19E-01	—	
Mercury	lb/100lb	—	—	—	—	1.60E-01	1.24E-01	8.07E-01	1.23E-01	—	
Nickel	lb/100lb	—	—	—	—	1.23E-01	1.07E-01	1.23E-01	—	—	
Selenium	lb/100lb	—	—	—	—	1.23E-01	1.07E-01	1.23E-01	—	—	
Aluminum	lb/100lb	—	—	—	—	1.70E-03	1.94E-03	1.70E-03	2.90E-03	—	
Moisture	lb/100lb	—	—	—	—	1.84E-04	1.47E-04	1.46E-04	9.40E-05	—	
Phosphorus	lb/100lb	—	—	—	—	1.23E-01	1.07E-01	1.23E-01	—	—	
Mercury	lb/100lb	1.23E-01	1.23E-01	1.23E-01	1.23E-01	1.23E-01	1.23E-01	1.23E-01	1.23E-01	—	
Manganese	lb/100lb	2.41E-01	5.74E-01	1.14E-01	2.12E-01	1.60E-01	3.04E-01	1.60E-01	1.19E-01	—	

¹ For concentrations that are 1000 times below detection limit the maximum, minimum, average, and standard deviation were calculated by using one-half of the detection limit. Duplicate samples were not included in the calculation.

² Information not used in range and standard deviation for mercury and lead due to the analytical limits for both of these parameters.

³ 95% confidence interval calculated based on the following equation: $100 \pm 1.96 \frac{SD}{\sqrt{n}}$

$\mu = \text{mean} - \frac{SD}{\sqrt{n}}$

$\sigma = 95\%$ confidence interval parameter given above the first line

$n = \text{number of samples}$

$SD = \text{standard deviation of parameter concentrations in samples}$

$\mu = \text{mean theoretical value} \pm 95\%$ confidence interval (0.1 to 1 degree of freedom)

$n = \text{number of samples}$

⁴ Data has been calculated and verified based on all parameter ranges. For a more detailed report by e-mail.

⁵ The range of the ROBE MALT was used to determine the 95% average, maximum, minimum, and 95% confidence interval. This was done for comparison with the base data reported above based on only 6 samples.

TABLE A-3
WOOD CHIP ANALYSIS - U.S. SUGAR CLEWISTON - BOILER NO. 8

Parameter	Units	Analysis Results - Wood Chip Samples						Average
		Sample 1 6/1/2006	Sample 2 6/1/2006	Sample 3 6/1/2006	1036-1142 8/22/2006	1320-1426 8/22/2006	1530-1636 8/22/2006	
No. of Samples Compositied		5	5	5	3	3	3	
Moisture	% , as received	32.24	33.95	30.20	36.57	32.72	33.93	33.27
Ash	% , as received	5.73	8.52	8.86	12.08	12.02	11.70	9.82
Ash	% , dry basis	8.46	12.90	12.70	19.04	17.87	17.71	14.78
HHV	Btu/lb, as received	5,434	4,901	5,157	4,397	4,757	4,782	4,905
HHV	Btu/lb, dry basis	8,018	7,421	7,388	6,932	7,071	7,238	7,345
Nitrogen	% , as received	0.44	0.30	0.29	0.33	0.32	0.36	0.34
Nitrogen	% , dry basis	0.65	0.45	0.42	0.52	0.48	0.54	0.51
Chlorine	% , as received	0.173	0.132	0.122	0.092	0.095	0.107	0.12
Chlorine	% , dry basis	0.255	0.200	0.175	0.145	0.141	0.161	0.18
Chlorine	lb/MMBtu	0.318	0.269	0.237	0.209	0.199	0.222	0.24
								Standard deviation = 0.04
								t-distribution = 1.475884
								90th percentile = 0.31
Mercury	ppm, as received	0.04	0.03	0.03	0.01	0.01	0.01	0.02
Mercury	ppm, dry basis	0.05	0.04	0.04	0.02	0.02	0.02	0.03
Mercury	lb/MMBtu	6.2E-06	5.4E-06	5.4E-06	2.9E-06	2.8E-06	2.8E-06	4.3E-06
								Standard deviation = 1.6E-06
								t-distribution = 1.475884
								90th percentile = 6.6E-06
Arsenic	ppm, as received	3.1	3.4	12.4	--	--	--	6.3
Arsenic	ppm, dry basis	4.5	5.1	17.7	--	--	--	9.1
Arsenic	lb/MMBtu	5.7E-04	6.9E-04	2.4E-03	--	--	--	1.2E-03
Beryllium	ppm, dry basis	<0.08	<0.1	<0.1	--	--	--	0.1
Beryllium	lb/MMBtu	1.0E-05	1.3E-05	1.4E-05	--	--	--	1.2E-05
Cadmium	ppm, dry basis	0.69	0.88	0.72	--	--	--	0.76
Cadmium	lb/MMBtu	8.5E-05	1.2E-04	9.8E-05	--	--	--	1.0E-04
Chromium	ppm, dry basis	12.7	14.2	16.5	--	--	--	14.5
Chromium	lb/MMBtu	1.6E-03	1.9E-03	2.2E-03	--	--	--	1.9E-03
Lead	ppm, dry basis	6.3	6.3	5.8	--	--	--	6.1
Lead	lb/MMBtu	7.8E-04	8.5E-04	7.9E-04	--	--	--	8.1E-04
Manganese	ppm, dry basis	34.3	37.0	25.1	19.0	18.0	19.0	25.4
Manganese	lb/MMBtu	4.3E-03	5.0E-03	3.4E-03	2.7E-03	2.5E-03	2.6E-03	3.4E-03
								Standard deviation = 1.0E-03
								t-distribution = 1.475884
								90th percentile = 4.9E-03
Nickel	ppm, dry basis	1.7	2.6	1.3	--	--	--	1.8
Nickel	lb/MMBtu	2.1E-04	3.5E-04	1.7E-04	--	--	--	2.4E-04
Selenium	ppm, as received	0.06	0.06	0.06	--	--	--	0.06
Selenium	ppm, dry basis	0.08	0.09	0.09	--	--	--	0.09
Selenium	lb/MMBtu	1.0E-05	1.2E-05	1.2E-05	--	--	--	1.1E-05
TSM*	ppm, dry basis	60.3	66.2	67.3	--	--	--	64.6
TSM*	lb/MMBtu	7.5E-03	8.9E-03	9.1E-03	--	--	--	8.5E-03
								Standard deviation = 8.7E-04
								t-distribution = 1.885618
								90th percentile = 0.010

Note: % = percent
 Btu/lb = British thermal unit per pound
 HHV = higher heating value
 lb/MMBtu = pound per million British thermal units
 ppm = parts per milion
 TSM = total selected metals (arsenic, beryllium, cadmium, chromium, lead, manganese, nickel and selenium)

Footnotes:
 * For informational purposes only. Boiler No. 8 complies with the MACT limit for PM.

TABLE 4-4
HCL AND Cl₂ STACK TEST RESULTS ON BOILER NOS. 1, 4, AND 7, U.S. SUGAR CORP. WISCONSIN

Parameter	Source of Data	Boiler No. 1				Boiler No. 4				Boiler No. 7			
		11/29/06 0919-1022	11/23/06 1107-1209	11/28/06 1301-1307	Average	12/1/06 1226-1402	12/1/06 1446-1531	12/1/06 1622-1735	Average	1/25/07 0909-1013	1/25/07 1106-1210	1/25/07 1325-1429	Average
Fuel Type		89% Bagasse/11% Oil	91% Bagasse/9% Oil	97% Bagasse/3% Oil		83% Bagasse/17% Oil	81% Bagasse/19% Oil	81% Bagasse/19% Oil		100% Bagasse	100% Bagasse	100% Bagasse	
F-Factor (dsc/MMBtu) *	Fuel Analysis	10.45	10.455	10.216	10.529	10.482	10.501	10.254	10.432	10.552	10.471	10.391	10.481
Stack Flow (acfm)	Stack Test	228,163	246,409	271,574	262,169	228,163	228,163	228,163	228,163	318,415	301,630	301,314	307,120
Stack Flow (dscfm)	Stack Test	122,830	160,360	152,745	145,312	122,830	122,830	122,830	122,830	183,293	174,015	175,714	178,241
Stack Temp (deg F)	Stack Test	154.8	156.6	158.8	156.7	151.3	152.8	152.3	152.1	275.6	272.8	271.3	273.2
Oxygen (%) - dry basis	Stack Test	11.0	12.0	11.0	11.0	10.5	9.7	10.1	10.1	10.6	9.8	10.7	10.4
Steam Production (lb/hr)	Stack Test	165,882	171,045	165,217	167,381	245,070	245,000	246,038	245,703	301,597	319,697	290,569	305,754
Heat Input from F-Factor (MMBtu/hr)	Stack Test	231	392	323	316	352	374	371	366	520	531	495	515
Hydrogen Chloride (lb/hr)	Stack Test	0.54	1.33	1.22	1.03	0.94	0.91	0.69	0.85	0.93	0.75	2.81	1.50
Hydrogen Chloride (lb/MMBtu)	Stack Test	0.0023	0.0031	0.0038	0.0032	0.0027	0.0024	0.0019	0.0023	0.0015	0.0014	0.0057	0.0030
Chlorine Gas (lb/hr)	Stack Test	0.19	0.16	0.15	0.44	0.56	0.57	0.50	0.54	1.13	1.31	1.28	1.24
Chlorine Gas (lb/MMBtu)	Stack Test	0.0017	0.0012	0.0015	0.0014	0.0016	0.0013	0.0013	0.0015	0.0022	0.0025	0.0026	0.0024
Chlorine (lb/MMBtu)	Fuel Analysis	0.056	0.033	0.016	0.039	0.034	0.015	0.031	0.032	0.042	0.012	0.039	0.041
		Percentage of chlorine in fuel emitted as HCl =				Percentage of chlorine in fuel emitted as HCl =				Percentage of chlorine in fuel emitted as HCl =			
		8%				6%				7%			
		Percentage of chlorine in fuel emitted as Cl ₂ =				Percentage of chlorine in fuel emitted as Cl ₂ =				Percentage of chlorine in fuel emitted as Cl ₂ =			
		4%				4%				6%			

Notes
 lb/hr = pound per hour
 MMBtu/hr = million British thermal units per hour
 acfm = actual cubic foot per minute
 dscfm = dry standard cubic foot per minute
 F = Fahrenheit
 % = percent
 lb/MMBtu = pound per million British thermal units
 dsc/MMBtu = dry standard cubic foot per million British thermal units

* Fuel factors for Boiler No. 1 and Boiler No. 4 are representative of the combination of bagasse and oil firing.

TABLE A-4b
HCL AND CL₂ STACK TEST RESULTS ON BOILER NO. 8, U.S. SUGAR CLEWISTON

Parameter	Source of Data	Boiler No. 8 ^a				Boiler No. 8 ^a				
		1/5-07 1058-1158	1/5-07 1345-1445	1/5-07 1622-1722	Average	8/22/06 1036-1142	8/22/06 1320-1426	8/22-06 1530-1636	Average	
Fuel Type		Bagasse	Bagasse	Bagasse		Wood Chips	Wood Chips	Wood Chips		
F-Factor (dscf/MMBtu)	Fuel Analysis	10,504	10,804	10,843	10,850	11,162	11,501	11,005	11,223	
Stack Flow (acfm)	Stack Test	421,959	429,330	443,786	431,692	262,552	256,382	257,466	258,800	
Stack Flow (dscfm)	Stack Test	216,073	216,113	219,030	217,072	148,855	146,795	148,794	148,148	
Stack Temp. (deg. F)	Stack Test	353	358	362	358	315	313	315	314	
Oxygen (%) - dry basis	Stack Test	9.3	8.7	7.6	8.5	10.4	10.4	10.3	10.4	
Steam Production (lb/hr)	DAHS	499,726	520,774	510,811	510,270	202,398	202,350	199,188	201,312	
Heat Input from F-Factor (MMBtu/hr)	Stack Test	795	832	831	820	404	384	411	400	
Hydrogen Chloride (lb/hr)	Stack Test	0.74	3.02	1.17	1.64	31.63	37.05	33.23	33.97	
Hydrogen Chloride (lb/MMBtu)	Stack Test	0.0011	0.0043	0.0015	0.0023	0.0784	0.0966	0.0808	0.0852	
Chlorine Gas (lb/hr)	Stack Test	2.03	1.89	1.98	1.97	0.56	0.44	0.40	0.47	
Chlorine Gas (lb/MMBtu)	Stack Test	0.0031	0.0027	0.0026	0.0028	0.0014	0.0011	0.0010	0.0012	
Chlorine (lb/MMBtu)	Fuel Analysis	0.042	0.026	0.032	0.033	0.209	0.199	0.222	0.210	
Percentage of chlorine in fuel emitted as HCl =					7%	Percentage of chlorine in fuel emitted as HCl =				41%
Percentage of chlorine in fuel emitted as Cl ₂ =					8%	Percentage of chlorine in fuel emitted as Cl ₂ =				1%

Notes:


- lb/hr = pound per hour
- MMBtu/hr = million British thermal units per hour
- acfm = actual cubic foot per minute
- dscfm = dry standard cubic foot per minute
- F = Fahrenheit
- % = percent
- lb/MMBtu = pound per million British thermal units
- dscf/MMBtu = dry standard cubic foot per million British thermal units

^a Measured at the east inlet to the wet cyclones.

APPENDIX B

BOILER 1

11/28/06



**SOURCE TEST REPORT
FOR
HYDROCHLORIC ACID, AND CHLORINE EMISSIONS**

**BOILER 1
IMPINGEMENT WET SCRUBBER OUTLET
TRAVELING GRATE
CLEWISTON, FLORIDA**

**FDEP PERMIT NUMBER 0510003-017-AV
I D NUMBER 001**

MACT PERFORMANCE TEST

NOVEMBER 28, 2006

PREPARED FOR:

**U.S. SUGAR CORPORATION
SOUTH W.C. OWEN AVENUE
CLEWISTON, FLORIDA 33440**

PREPARED BY:

**AIR CONSULTING AND ENGINEERING, INC.
2106 N.W. 67TH PLACE, SUITE 4
GAINESVILLE, FLORIDA 32653
(352) 335-1889**

238-06-01

**Table 1. Emission Summary
Boiler 1
United States Sugar Corporation - Clewiston Mill
Clewiston, Florida
November 28, 2006**

Run Number	Time	Oxygen %	CO2 %	Flow Rate dscfm	Steam Rate lbs/hr	Fuel Factor dscf/MMBTU	Heat Input MMBTUH	HCl Emissions		Cl2 Emissions	
								lbs/hr	lbs/MMBTU	lbs/hr	lbs/MMBTU
1	0919-1022	14.0	7.0	122830	165882	10416	233.5	0.54	0.0023	0.39	0.0017
2	1107-1209	12.0	8.5	160360	171045	10455	391.9	1.33	0.0034	0.46	0.0012
3	1303-1407	13.0	9.0	152745	165217	10716	323.3	1.22	0.0038	0.48	0.0015
Average	—	13.0	8.2	145312	167381	10529	316.2	1.03	0.0032	0.44	0.0015

$$\text{lbs/MMBTU HCl} = \frac{[(\text{mg}) \times (\text{lbs}/453,600\text{mg})] \times \text{F-Factor} \times 20.9}{\text{VMstd.} \quad (20.9\text{-}\%O_2)}$$

$$\text{Heat Input} = \text{MMBTUH} = \frac{(\text{dscfm} \times 60 \text{ min/hr}) \times (20.9\text{-}\%O_2)}{\text{F-Factor} \quad 20.9}$$

AIR CONSULTING AND ENGINEERING, INC.
2106 NW 67th Place, Suite 4, Gainesville, Florida 32653

HCL and CL2 Laboratory Results

Boiler 1
United States Sugar Corporation - Clewiston Mill
Clewiston, Florida
November 28, 2006

Run	HCL as Chloride mg	HCL mg	Chlorine as Chloride mg	Chlorine Gas mg
1	1.6	1.54	3.0	1.1
2	2.9	2.88	2.9	1.0
3	2.8	2.78	3.0	1.1
0.1N H2SO4Blank	0.1			
0.1N NAOH Blank			1.9	

Molecular Weight CL = 35.453 lb/lb-mole
Molecular Weight HCL = 36.453 lb/lb-mole

$$\text{mg HCL} = (\text{mg CL} - \text{CL Blank (0.1NH}_2\text{SO}_4)) \times \frac{\text{MW HCL}}{\text{MW CL}}$$

$$\text{mg CL}_2 = (\text{mg CL} - \text{CL Blank (0.1N NaOH)})$$

AIR CONSULTING AND ENGINEERING, INC.

FUEL FACTOR CALCULATION

COMPANY NAME: United States Sugar Corporation - Clewiston Mill
SOURCE: Boiler 1
FUEL FIRED: Bagasse

Run	1	2	3
F-Factor (scf/MMBTU) Bagasse	10571	10541	10764
F-Factor (scf/MMBTU) Oil	9190	9190	9190
Heat Input from Oil (MMBTUH)	38.9	22.6	10.6
Total Heat Input (MMBTUH)	346.5	355.4	346.2
Fuel % Bagasse	88.77	93.64	96.94
Fuel % Oil	11.23	6.36	3.06
F-Factor (scf/MMBTU) (Bagasse & Oil)	10416	10455	10716

F-Factor (scf/MMBTU) (Bagasse & Oil) =
(F-Factor Bagasse x % Bagasse in Fuel) + (F-Factor Oil x % Oil in Fuel)

Fuel % Oil = $\frac{\text{Heat Input Oil}}{\text{Total Heat Input}} \times 100\%$

AIR CONSULTING AND ENGINEERING, INC.

FUEL FACTOR CALCULATION

COMPANY NAME: United States Sugar Corporation - Clewiston Mill
SOURCE: Boiler 1
FUEL FIRED: Bagasse

Run	1	2	3
	wet	wet	wet
Date	11/28/06	11/28/06	11/28/06
Time			
Carbon (%)	20.82	22.28	22.05
Hydrogen (%)	2.53	2.70	2.65
Nitrogen (%)	0.20	0.23	0.24
Sulfur (%)	0.04	0.03	0.04
Oxygen (%)	15.52	16.38	15.81
HHV (BTU/lb)	3214	3456	3360
F-Factor (scf/MMBTU)	10571	10541	10764

Sample Calculation - Run 1

$$F_w = \frac{K[(Kh_w * \%H) + (Kc_w * \%C) + (Ks_w * \%S) + (Kn_w * \%N) - (Ko_w * \%O)]}{GCV_w}$$

$$= \frac{10E6[3.64(2.53) + 1.53(20.82) + 0.57(0.04) + 0.14(0.2) - 0.46(15.52)]}{3214}$$

$$= 10571$$

Where:

- %H Concentration of hydrogen from the ultimate fuel analysis on a wet basis (as received)
- %C Concentration of carbon from the ultimate fuel analysis on a wet basis (as received)
- %S Concentration of sulfur from the ultimate fuel analysis on a wet basis (as received)
- %N Concentration of nitrogen from the ultimate fuel analysis on a wet basis (as received)
- %O Concentration of oxygen from the ultimate fuel analysis on a wet basis (as received)
- Khd conversion factor (3.64 scf/lb-%)
- Kc conversion factor (1.53 scf/lb-%)
- Ks conversion factor (0.57 scf/lb-%)
- Kn conversion factor (0.14 scf/lb-%)
- Ko conversion factor (0.46 scf/lb-%)
- K conversion factor (10E6 BTU/MMBTU)
- GCV gross calorific heating value (BTU/lb HHV) wet


Hazen Research, Inc.

 4601 Indiana Street
 Golden, CO 80403 USA
 Tel: (303) 279-4501
 Fax: (303) 278-1528

 Date January 17 2007
 HRI Project 002-SA2
 HRI Series No. L136/06-1
 Date Rec'd. 12/13/06
 Cust. P.O.#

 Air Consulting and Engineering
 Dagmar Fick
 2106 NW 67th Place
 Gainesville, FL 32606

 Sample Identification
 Boiler 1 Run 1

Reporting Basis >	As Rec'd	Dry	Air Dry
Proximate (%)			
Moisture	58.48	0.00	1.90
Ash	2.41	5.80	5.69
Volatile	34.64	83.44	81.85
Fixed C	4.47	10.76	10.56
Total	100.00	100.00	100.00
Sulfur	0.04	0.10	0.10
Btu/lb (HHV)	3214	7742	7595
MMF Btu/lb	3298	8259	
MAF Btu/lb		8218	
Air Dry Loss (%)	57.68		

Ultimate (%)			
Moisture	58.48	0.00	1.90
Carbon	20.82	50.14	49.19
Hydrogen	2.53	6.09	5.98
Nitrogen	0.20	0.48	0.47
Sulfur	0.04	0.10	0.10
Ash	2.41	5.80	5.69
Oxygen*	15.52	37.39	36.67
Total	100.00	100.00	100.00
Chlorine**	0.011	0.028	0.027

Forms of Sulfur (as S,%)

Sulfate		
Pyritic		
Organic		
Total	0.04	0.10

Water Soluble Alkalies (%)

 Na2O
 K2O

 Lb. Alkali/MM Btu=
 Lb. Ash/MM Btu= 7.49
 Lb. SO2/MM Btu= 0.26
 HGI= @ % Moisture
 As Rec'd. Sp.Gr.=
 Free Swelling Index=
 F-Factor(dry), DSCF/MM BTU= 10,570

Report Prepared By:

 Gerard H. Cunningham
 Fuels Laboratory Supervisor

* Oxygen by Difference.

** Not usually reported as part of the ultimate analysis.


Hazen Research, Inc.

 4501 Indiana Street
 Golden, CO 80403 USA
 Tel: (303) 279-4501
 Fax: (303) 278-1528

 Date January 17 2007
 HRI Project 002-SA2
 HRI Series No. L136/06-2
 Date Rec'd. 12/13/06
 Cust. P.O.#

 Air Consulting and Engineering
 Dagmar Fick
 2106 NW 67th Place
 Gainesville, FL 32606

 Sample Identification
 Boiler 1 Run 2

Reporting Basis >	As Rec'd	Dry	Air Dry
Proximate (%)			
Moisture	55.50	0.00	1.76
Ash	2.88	6.47	6.36
Volatile	36.37	81.73	80.29
Fixed C	5.25	11.80	11.59
Total	100.00	100.00	100.00

Sulfur	0.03	0.07	0.07
Btu/lb (HHV)	3456	7765	7628
MMF Btu/lb	3566	8348	
MAF Btu/lb		8303	
Air Dry Loss (%)	54.70		

Ultimate (%)			
Moisture	55.50	0.00	1.76
Carbon	22.28	50.06	49.18
Hydrogen	2.70	6.07	5.96
Nitrogen	0.23	0.52	0.51
Sulfur	0.03	0.07	0.07
Ash	2.88	6.47	6.36
Oxygen*	16.38	36.81	36.16
Total	100.00	100.00	100.00
Chlorine**	0.012	0.026	0.026

Forms of Sulfur (as S, %)

Sulfate		
Pyritic		
Organic		
Total	0.03	0.07

 Lb. Alkali/MM Btu=
 Lb. Ash/MM Btu= 8.34
 Lb. SO₂/MM Btu= 0.18
 HGI= @ % Moisture
 As Rec'd. Sp.Gr.=
 Free Swelling Index=
 F-Factor(dry), DSCF/MM BTU= 10,543

Water Soluble Alkalies (%)

 Na₂O
 K₂O

Report Prepared By:

 Gerard H. Cunningham
 Fuels Laboratory Supervisor

* Oxygen by Difference.

** Not usually reported as part of the ultimate analysis.


Hazen Research, Inc.

 4601 Indiana Street
 Golden, CO 80403 USA
 Tel: (303) 279-4501
 Fax: (303) 278-1528

 Date January 17 2007
 HRI Project 002-SA2
 HRI Series No. L136/06-3
 Date Rec'd. 12/13/06
 Cust. P.O.#

 Air Consulting and Engineering
 Dagmar Fick
 2106 NW 67th Place
 Gainesville, FL 32606

 Sample Identification
 Boiler 1 Run 3

 Reporting
 Basis >

As Rec'd

Dry

Air Dry

Proximate (%)

Moisture	55.59	0.00	1.48
Ash	3.62	8.14	8.02
Volatile	34.90	78.57	77.41
Fixed C	5.89	13.29	13.09
Total	100.00	100.00	100.00
Sulfur	0.04	0.09	0.09
Btu/lb (HHV)	3360	7566	7454
MMF Btu/lb	3495	8295	
MAF Btu/lb		8236	
Air Dry Loss (%)	54.92		

Ultimate (%)

Moisture	55.59	0.00	1.48
Carbon	22.05	49.64	48.91
Hydrogen	2.65	5.96	5.87
Nitrogen	0.24	0.55	0.54
Sulfur	0.04	0.09	0.09
Ash	3.62	8.14	8.02
Oxygen*	15.81	35.62	35.09
Total	100.00	100.00	100.00
Chlorine**	0.015	0.035	0.034

Forms of Sulfur (as S,%)

Sulfate		
Pyritic		
Organic		
Total	0.04	0.09

 Lb. Alkali/MM Btu=
 Lb. Ash/MM Btu= 10.76
 Lb. SO₂/MM Btu= 0.24
 HGI= @ % Moisture
 As Rec'd. Sp.Gr.=
 Free Swelling Index=
 F-Factor(dry), DSCF/MM BTU= 10,760

Water Soluble Alkalies (%)

 Na₂O
 K₂O

Report Prepared By:

 Gerard H. Cunningham
 Fuels Laboratory Supervisor

* Oxygen by Difference.

** Not usually reported as part of the ultimate analysis.

**Hazen Research, Inc.**


4601 Indiana Street
 Golden, CO 80403 USA
 Tel: (303) 279-4501
 Fax: (303) 278-1528

Date: January 17, 2007
 Project No: 002-SA2
 Control No: L138/06
 Received: 12/13/06

Air Consulting and Engineering
 Dagmar Fick
 2106 NW 67th Place, Suite 4
 Gainesville, FL 32606

Sample Number: K317/06	-1	-2	-3	-4	-5	-6
Sample Identification:	B1 Run1	B1 Run 2	B1 Run 3	B4 Run 2	B4 Run 3	B4 Run 4
Air Dry Loss, %	57.68	54.70	54.92	53.55	52.59	55.29
Residual Moisture, %	1.90	1.76	1.48	1.79	1.48	1.68
As Received Moisture, %	58.48	55.50	55.59	54.38	53.29	56.04
Mercury (Air Dry Basis), mg/kg	0.05	0.05	0.05	0.06	0.06	0.04
Mercury (As Received Basis), mg/kg	0.02	0.02	0.02	0.03	0.03	0.02
Mercury (Dry Basis), mg/kg	0.05	0.05	0.05	0.06	0.06	0.04

By:


 Gerard H. Cunningham
 Fuel Laboratory Manager



Hazen Research, Inc.
4601 Indiana Street
Golden, CO 80403 USA
Tel: (303) 279-4501
Fax: (303) 278-1528

Air Consulting and Engineering
Dagmar Fick
2106 NW 67th Place, Suite 4
Gainesville, FL 32606

Date: Jan. 17, 2007
PROJ. # 002-SA2
CTRL # L136/06
REC'D 12/13/06

Sample No: L136/06-7
Sample Identification: Boiler 1 Fuel Oil 11/28/06

ULTIMATE

Water, %	0.005
Ash, %	<0.001
Sulfur, %	0.023
Carbon, %	88.16
Hydrogen, %	11.60
Nitrogen, %	0.11
Oxygen, %*	0.10

PROXIMATE

Water, %	0.005
Ash, %	<0.001
Volatile Matter, %	100.00
Fixed Carbon, %*	<0.01

CALORIFIC VALUE

BTU/lb	18473
--------	-------

By:
Gerard H. Cunningham
Fuel Laboratory Manager

* by difference

BOILER 4

12/1/06

**SOURCE TEST REPORT
FOR
HYDROCHLORIC ACID AND CHLORINE EMISSIONS**

**BOILER 4
IMPINGEMENT WET SCRUBBER OUTLET
TRAVELING GRATE
CLEWISTON, FLORIDA**

**FDEP PERMIT NUMBER 051-0003-017-AV
EMISSION UNIT 009**

MACT PERFORMANCE TEST

DECEMBER 1, 2006

PREPARED FOR:

**U.S. SUGAR CORPORATION
SOUTH W.C. OWEN AVENUE
CLEWISTON, FLORIDA 33440**

PREPARED BY:

**AIR CONSULTING AND ENGINEERING, INC.
2106 N.W. 67TH PLACE
GAINESVILLE, FLORIDA 32653
(352) 335-1889**

238-06-01

Table 1. Emission Summary
Boiler 4
United States Sugar Corporation - Clewiston Mill
Clewiston, Florida
December 1, 2006

Run Number	Time	Oxygen %	CO2 %	Flow Rate dscfm	Steam Rate lbs/hr	Fuel Factor dscf/MMBTU	Heat Input MMBTUH	HCl Emissions		Cl2 Emissions	
								lbs/hr	lbs/MMBTU	lbs/hr	lbs/MMBTU
2	1256-1402	10.5	9.8	122830	245070	10482	351.6	0.94	0.0027	0.56	0.0016
3	1446-1551	9.7	10.5	122830	255000	10561	374.0	0.91	0.0024	0.57	0.0015
4	1622-1735	10.1	10.2	122830	246038	10254	371.1	0.69	0.0019	0.50	0.0013
Average	--	10.1	10.1	122830	248703	10432	365.5	0.85	0.0023	0.54	0.0015

Note: Run 1 was voided - problems with the HCl Train

$$\text{lbs/MMBTU HCl} = \frac{[(\text{mg}) \times (\text{lbs}/453,600\text{mg})]}{\text{VMstd.}} \times \text{F-Factor} \times \frac{20.9}{(20.9\text{-}\%O_2)}$$

$$\text{Heat Input} = \text{MMBTUH} = \frac{(\text{dscfm} \times 60 \text{ min/hr})}{\text{F-Factor}} \times \frac{(20.9\text{-}\%O_2)}{20.9}$$

AIR CONSULTING AND ENGINEERING, INC.
2106 NW 67th Place, Suite 4, Gainesville, Florida 32653

HCL and CL2 Laboratory Results

Boiler 4
United States Sugar Corporation - Clewiston Mill
Clewiston, Florida
December 1, 2006

Run	HCL as Chloride mg	HCL mg	Chlorine as Chloride mg	Chlorine Gas mg	
1	4.7	4.73	1.8	-0.10	Run voided
2	2.2	2.16	3.2	1.30	
3	2.1	2.06	3.2	1.30	
4	1.6	1.54	3.0	1.10	
0.1N H2SO4Blank	0.1				
0.1N NAOH Blank			1.9		

Molecular Weight CL = 35.453 lb/lb-mole
Molecular Weight HCL = 36.453 lb/lb-mole

$$\text{mg HCL} = (\text{mg CL} - \text{CL Blank (0.1NH}_2\text{SO}_4)) \times \frac{\text{MW HCL}}{\text{MW CL}}$$

$$\text{mg CL}_2 = (\text{mg CL} - \text{CL Blank (0.1N NaOH)})$$

AIR CONSULTING AND ENGINEERING, INC.

FUEL FACTOR CALCULATION

COMPANY NAME: United States Sugar Corporation - Clewiston Mill
 SOURCE: Boiler # 4
 FUEL FIRED: Bagasse

Run	1	2	3
F-Factor (scf/MMBTU) Bagasse	10739	10814	10466
F-Factor (scf/MMBTU) Oil	9190	9190	9190
Heat Input from Oil (MMBTUH)	86.1	86.3	86.3
Total Heat Input (MMBTUH)	519.7	554.2	518.4
Fuel % Bagasse	83.43	84.43	83.35
Fuel % Oil	16.57	15.57	16.65
F-Factor (scf/MMBTU) (Bagasse & Oil)	10482	10561	10254

F-Factor (scf/MMBTU) (Bagasse & Oil) =
 (F-Factor Bagasse x % Bagasse in Fuel) + (F-Factor Oil x % Oil in Fuel)

Fuel % Oil = $\frac{\text{Heat Input Oil}}{\text{Total Heat Input}} \times 100\%$

1413 780 20-09076

AIR CONSULTING AND ENGINEERING, INC.

FUEL FACTOR CALCULATION

COMPANY NAME: United States Sugar Corporation - Clewiston Mill
SOURCE: Boiler #4
FUEL FIRED: Bagasse

Run	2	3	4
	wet	wet	wet
Date	12/1/06	12/1/06	12/1/06
Time			
Carbon (%)	21.81	19.84	20.98
Hydrogen (%)	2.68	2.42	2.58
Nitrogen (%)	0.22	0.23	0.21
Sulfur (%)	0.04	0.02	0.03
Oxygen (%)	15.61	14.38	15.51
HHV (BTU/lb)	3352	3014	3287
F-Factor (scf/MMBTU)	10739	10814	10466

Sample Calculation - Run 1

$$F_w = \frac{K[(K_{hw} * \%H) + (K_{cw} * \%C) + (K_{sw} * \%S) + (K_{nw} * \%N) - (K_{ow} * \%O)]}{GCV_w}$$

$$= \frac{10E6[3.64(2.68) + 1.53(21.81) + 0.57(0.04) + 0.14(0.22) - 0.46(15.61)]}{3352}$$

$$= 10739$$

Where:

- %H Concentration of hydrogen from the ultimate fuel analysis on a wet basis (as received)
- %C Concentration of carbon from the ultimate fuel analysis on a wet basis (as received)
- %S Concentration of sulfur from the ultimate fuel analysis on a wet basis (as received)
- %N Concentration of nitrogen from the ultimate fuel analysis on a wet basis (as received)
- %O Concentration of oxygen from the ultimate fuel analysis on a wet basis (as received)
- K_{hd} conversion factor (3.64 scf/lb-%)
- K_c conversion factor (1.53 scf/lb-%)
- K_s conversion factor (0.57 scf/lb-%)
- K_n conversion factor (0.14 scf/lb-%)
- K_o conversion factor (0.46 scf/lb-%)
- K conversion factor (10E6 BTU/MMBTU)
- GCV gross calorific heating value (BTU/lb HHV) wet

10/22/06 20-09076


Hazen Research, Inc.

 4601 Indiana Street
 Golden, CO 80403 USA
 Tel: (303) 279-4501
 Fax: (303) 278-1528

 Date January 17 2007
 HRI Project 002-SA2
 HRI Series No. L136/06-4
 Date Rec'd. 12/13/06
 Cust. P.O.#

 Air Consulting and Engineering
 Dagmar Fick
 2106 NW 67th Place
 Gainesville, FL 32606

 Sample Identification
 Boiler 4 Run 2

Reporting Basis >

As Rec'd

Dry

Air Dry

Proximate (%)

Moisture	54.38	0.00	1.79
Ash	5.26	11.54	11.33
Volatile	35.13	77.02	75.64
Fixed C	5.23	11.44	11.24
Total	<u>100.00</u>	<u>100.00</u>	<u>100.00</u>
Sulfur	0.04	0.09	0.09
Btu/lb (HHV)	3352	7347	7216
MMF Btu/lb	3552	8393	
MAF Btu/lb		8306	
Air Dry Loss (%)		53.55	

Ultimate (%)

Moisture	54.38	0.00	1.79
Carbon	21.81	47.82	46.96
Hydrogen	2.68	5.87	5.77
Nitrogen	0.22	0.48	0.47
Sulfur	0.04	0.09	0.09
Ash	5.26	11.54	11.33
Oxygen*	<u>15.61</u>	<u>34.20</u>	<u>33.59</u>
Total	<u>100.00</u>	<u>100.00</u>	<u>100.00</u>
Chlorine**	0.012	0.025	0.025

Forms of Sulfur (as S,%)

Sulfate		
Pyritic		
Organic		
Total	0.04	0.09

 Lb. Alkali/MM Btu=
 Lb. Ash/MM Btu= 15.70
 Lb. SO₂/MM Btu= 0.25
 HGI= @ % Moisture
 As Rec'd, Sp.Gr.=
 Free Swelling Index=
 F-Factor(dry), DSCF/MM BTU= 10,742

Water Soluble Alkalies (%)

 Na₂O
 K₂O

Report Prepared By

 Gerard H. Cunningham
 Fuels Laboratory Supervisor

* Oxygen by Difference.

** Not usually reported as part of the ultimate analysis.

An Employee-Owned Company

 5060.0
 2000.0
 747
 643


Hazen Research, Inc.

 4601 Indiana Street
 Golden, CO 80403 USA
 Tel: (303) 279-4501
 Fax: (303) 278-1528

 Date January 17 2007
 HRI Project 002-SA2
 HRI Series No. L136/06-5
 Date Rec'd. 12/13/06
 Cust. P.O.#

 Air Consulting and Engineering
 Dagmar Fick
 2106 NW 67th Place
 Gainesville, FL 32606

 Sample Identification
 Boiler 4 Run 3

Reporting Basis >

As Rec'd

Dry

Air Dry

Proximate (%)

Moisture	53.30	0.00	1.49
Ash	9.81	21.00	20.69
Volatile	32.00	68.52	67.50
Fixed C	4.89	10.48	10.32
Total	100.00	100.00	100.00
Sulfur	0.02	0.05	0.05
Btu/lb (HHV)	3014	6453	6357
MMF Btu/lb	3370	8346	
MAF Btu/lb		8169	
Air Dry Loss (%)	52.59		

Ultimate (%)

Moisture	53.30	0.00	1.49
Carbon	19.84	42.47	41.84
Hydrogen	2.42	5.19	5.11
Nitrogen	0.23	0.49	0.48
Sulfur	0.02	0.05	0.05
Ash	9.81	21.00	20.69
Oxygen*	14.38	30.80	30.34
Total	100.00	100.00	100.00
Chlorine**	0.014	0.029	0.029

Forms of Sulfur (as S.%)

Sulfate		
Pyritic		
Organic		
Total	0.02	0.05

 Lb. Alkali/MM Btu=
 Lb. Ash/MM Btu= 32.55
 Lb. SO₂/MM Btu= 0.16
 HGI= @ % Moisture
 As Rec'd. Sp.Gr.=
 Free Swelling Index=
 F-Factor(dry).DSCF/MM BTU= 10,818

Water Soluble Alkalies (%)

 Na₂O
 K₂O

 Report Prepared By:

 Gerard H. Cunningham
 Fuels Laboratory Supervisor

* Oxygen by Difference.

** Not usually reported as part of the ultimate analysis.

 1060-0
 20-09076
 1/17/07



Hazen Research, Inc.
 4901 Indiana Street
 Golden, CO 80403 USA
 Tel: (303) 279-4501
 Fax: (303) 278-1528

Date January 17 2007
 HRI Project 002-SA2
 HRI Series No. L136/06-6
 Date Rec'd. 12/13/06
 Cust. P.O.#

Air Consulting and Engineering
 Dagmar Fick
 2106 NW 67th Place
 Gainesville, FL 32606

Sample Identification
 Boiler 4 Run 4

Reporting Basis >	As Rec'd	Dry	Air Dry
Proximate (%)			
Moisture	56.04	0.00	1.68
Ash	4.65	10.57	10.39
Volatile	34.07	77.51	76.21
Fixed C	<u>5.24</u>	<u>11.92</u>	<u>11.72</u>
Total	100.00	100.00	100.00
Sulfur	0.03	0.07	0.07
Btu/lb (HHV)	3287	7477	7351
MMF Btu/lb	3459	8440	
MAF Btu/lb		8360	
Air Dry Loss (%)	55.29		

Ultimate (%)			
Moisture	56.04	0.00	1.68
Carbon	20.98	47.73	46.93
Hydrogen	2.58	5.86	5.76
Nitrogen	0.21	0.48	0.47
Sulfur	0.03	0.07	0.07
Ash	4.65	10.57	10.39
Oxygen*	<u>15.51</u>	<u>35.29</u>	<u>34.70</u>
Total	100.00	100.00	100.00
Chlorine**	0.010	0.023	0.023

Forms of Sulfur (as S,%)			
Sulfate			
Pyritic			
Organic			
Total	0.03	0.07	

Lb. Alkali/MM Btu=
 Lb. Ash/MM Btu= 14.13
 Lb. SO2/MM Btu= 0.19
 HGI= @ % Moisture
 As Rec'd. Sp.Gr.=
 Free Swelling Index=
 F-Factor(dry), DSCF/MM BTU= 10.463

Water Soluble Alkalies (%)

Na2O
 K2O

Report Prepared By:

 Gerard H. Cunningham
 Fuels Laboratory Supervisor

* Oxygen by Difference.
 ** Not usually reported as part of the ultimate analysis.

**Hazen Research, Inc.**

4601 Indiana Street
 Golden, CO 80403 USA
 Tel: (303) 279-4501
 Fax: (303) 278-1528

Air Consulting and Engineering
 Dagmar Fick
 2106 NW 67th Place, Suite 4
 Gainesville, FL 32606

Date: January 17, 2007
 Project No: 002-SA2
 Control No: L138/06
 Received: 12/13/06

Sample Number: K317/06	-1	-2	-3	-4	-5	-6
Sample Identification:	B1 Run 1	B1 Run 2	B1 Run 3	B4 Run 2	B4 Run 3	B4 Run 4
Air Dry Loss, %	57.68	54.70	54.92	53.55	52.59	55.29
Residual Moisture, %	1.90	1.76	1.48	1.79	1.48	1.68
As Received Moisture, %	58.48	55.50	55.59	54.38	53.29	56.04
Mercury (Air Dry Basis), mg/kg	0.05	0.05	0.05	0.06	0.06	0.04
Mercury (As Received Basis), mg/kg	0.02	0.02	0.02	0.03	0.03	0.02
Mercury (Dry Basis), mg/kg	0.05	0.05	0.05	0.06	0.06	0.04

By: 

Gerard H. Cunningham
 Fuel Laboratory Manager



Hazen Research, Inc.
4601 Indiana Street
Golden, CO 80403 USA
Tel: (303) 279-4501
Fax: (303) 278-1528

Air Consulting and Engineering
Dagmar Fick
2106 NW 67th Place, Suite 4
Gainesville, FL 32606

Date: Jan. 17, 2007
PROJ. # 002-SA2
CTRL # L136/06
REC'D 12/13/06

Sample No: L136/06-7
Sample Identification: Boiler 1 Fuel Oil 11/28/06

ULTIMATE

Water, %	0.005
Ash, %	<0.001
Sulfur, %	0.023
Carbon, %	88.16
Hydrogen, %	11.60
Nitrogen, %	0.11
Oxygen, %*	0.10

PROXIMATE


Water, %	0.005
Ash, %	<0.001
Volatile Matter, %	100.00
Fixed Carbon, %*	<0.01

CALORIFIC VALUE

BTU/lb	19473
--------	-------

* by difference

By:
Gerard H. Cunningham
Fuel Laboratory Manager



4

- BOILER MAIN
- OIL
- FURNACE TEMP & PRES
- FD AIR
- ID AIR
- OF AIR

1 Hour Span

Alarm Time	Alarm Date	Tagname	Tag Description

BOILER 7

1/25/07

**SOURCE TEST REPORT
FOR
HYDROCHLORIC ACID AND CHLORINE EMISSIONS**

**BOILER NUMBER 7 – ESP OUTLET
VIBRATING GRATE**

**U.S. SUGAR CORPORATION – CLEWISTON MILL
CLEWISTON, FLORIDA**

FDEP PERMIT 0510003-017-AV

MACT PERFORMANCE TEST

JANUARY 25, 2007

PREPARED FOR:

**U.S. SUGAR CORPORATION
SOUTH W.C. OWEN AVENUE
CLEWISTON, FLORIDA 33440**

PREPARED BY:

**AIR CONSULTING AND ENGINEERING, INC.
2106 NW 67TH PLACE, SUITE 4
GAINESVILLE, FLORIDA 32653
(352) 335-1889**

238-06-01

**Table 1. Emission Summary
 Boiler 7
 United States Sugar Corporation - Clewiston Mill
 Clewiston, Florida
 January 25, 2007**

Run Number	Time	Oxygen %	CO2 %	Flow Rate dscfm	Fuel Factor dscf/MMBTU (Fuel Analysis)	Steam Rate lbs/hr	Heat Input MMBTUH	HCl Emissions		Cl2 Emissions	
								lbs/hr	lbs/MMBTU	lbs/hr	lbs/MMBTU
1	0909-1013	10.6	9.8	185293	10582	307597	519.8	0.93	0.0018	1.13	0.0022
2	1106-1210	9.8	10.6	174015	10471	319097	530.5	0.75	0.0014	1.31	0.0025
3	1325-1429	10.7	9.7	175714	10391	290569	494.7	2.81	0.0057	1.28	0.0026
Average	--	10.4	10.0	178341	10481	305754	515.0	1.50	0.0030	1.24	0.0024

$$\text{lbs/MMBTU HCl} = \frac{[(\text{mg}) \times (\text{lbs}/453,600\text{mg})]}{\text{VMstd.}} \times \text{F-Factor} \times \frac{20.9}{(20.9-\%O_2)}$$

$$\text{Heat Input} = \text{MMBTUH} = \frac{(\text{dscfm} \times 60 \text{ min/hr}) \times (20.9-\%O_2)}{\text{F-Factor} \times 20.9}$$

HCL and CL2 Laboratory Results

Boiler 7
United States Sugar Corporation - Clewiston Mill
Clewiston, Florida
January 25, 2007

Run	HCL as Chloride mg	HCL mg	Chlorine as Chloride mg	Chlorine Gas mg
1	2.1	2.06	5.5	2.5
2	1.7	1.65	5.9	2.9
3	6.1	6.17	5.8	2.8

0.1N H2SO4Blank	0.10			
0.1N NAOH Blank			3	

Molecular Weight CL = 35.453 lb/lb-mole
Molecular Weight HCL = 36.453 lb/lb-mole

$$\text{mg HCL} = (\text{mg CL} - \text{CL Blank (0.1NH}_2\text{SO}_4)) \times \frac{\text{MW HCL}}{\text{MW CL}}$$

$$\text{mg CL}_2 = (\text{mg CL} - \text{CL Blank (0.1N NaOH)})$$

AIR CONSULTING AND ENGINEERING, INC.

FUEL FACTOR CALCULATION

COMPANY NAME: United States Sugar Corporation - Clewiston Mill
SOURCE: Boiler 7
FUEL FIRED: Bagasse

Run	1	2	3
	dry	dry	dry
Date	1/25/07	1/25/07	1/25/07
Time			
Carbon (%)	52.29	51.07	49.29
Hydrogen (%)	5.96	5.77	5.68
Nitrogen (%)	0.33	0.42	0.35
Sulfur (%)	0.04	0.07	0.05
Oxygen (%)	37.16	35.71	34.74
HHV (BTU/lb)	8002	7909	7717
F-Factor (dscf/MMBTU)	10582	10471	10391

Sample Calculation - Run 1

$$F_d = \frac{K[(K_h d \% H) + (K_c \% C) + (K_s \% S) + (K_n \% N) - (K_o \% O)]}{GCV_d}$$

$$= \frac{10E6[3.64(5.96) + 1.53(52.29) + 0.57(0.04) + 0.14(0.33) - 0.46(37.16)]}{8002}$$

$$= 10582$$

Where:

%H Concentration of hydrogen from the ultimate fuel analysis on a wet basis (as received)
 %C Concentration of carbon from the ultimate fuel analysis on a wet basis (as received)
 %S Concentration of sulfur from the ultimate fuel analysis on a wet basis (as received)
 %N Concentration of nitrogen from the ultimate fuel analysis on a wet basis (as received)
 %O Concentration of oxygen from the ultimate fuel analysis on a wet basis (as received)
 K_h conversion factor (3.64 scf/lb-%)
 K_c conversion factor (1.53 scf/lb-%)
 K_s conversion factor (0.57 scf/lb-%)
 K_n conversion factor (0.14 scf/lb-%)
 K_o conversion factor (0.46 scf/lb-%)
 K conversion factor (10E6 BTU/MMBTU)
 GCV gross calorific heating value (BTU/lb HHV) dry

MERCURY EMISSIONS

HHV dry: 7876 BTU/lb dry

Hg dry: 0.01 mg/kg = $0.01 \times 10E-6$ kg/kg = $1.0 \times 10E-8$ lb/lb

lbs/mmBTU Hg = $\frac{1.0 \times 10E-8 \text{ lb/lb}}{7876 \times 10E-6 \text{ mmBTU/lb}} = 1.27 \times 10E-6$



Hazen Research, Inc.

4601 Indiana Street
Golden, CO 80403 USA
Tel: (303) 279-4501
Fax: (303) 278-1528

Date February 15 2007
HRI Project 009-555
HRI Series No. A344/07-1
Date Rec'd. 01/30/07
Cust. P.O.#

Golder Associates, Inc.
David Buff
6241 NW 23rd Street, Suite 500
Gainesville, FL 32653

Sample Identification
USSC-BLR7-012507-C1

Reporting Basis >	As Rec'd	Dry	Air Dry
Proximate (%)			
Moisture	51.23	0.00	8.03
Ash	2.06	4.22	3.88
Volatile	41.12	84.31	77.54
Fixed C	5.59	11.47	10.55
Total	100.00	100.00	100.00

Sulfur	0.02	0.04	0.04
Btu/lb (HHV)	3903	8002	7359
MMF Btu/lb	3991	8383	
MAF Btu/lb		8354	
Air Dry Loss (%)	46.97		

Ultimate (%)			
Moisture	51.23	0.00	8.03
Carbon	25.50	52.29	48.09
Hydrogen	2.91	5.96	5.48
Nitrogen	0.16	0.33	0.30
Sulfur	0.02	0.04	0.04
Ash	2.06	4.22	3.88
Oxygen*	18.12	37.16	34.18
Total	100.00	100.00	100.00
Chlorine**	0.016	0.034	0.031

Forms of Sulfur (as S,%)

Sulfate		
Pyritic		
Organic		
Total	0.02	0.04

Lb. Alkali/MM Btu=
Lb. Ash/MM Btu= 5.27
Lb. SO2/MM Btu= 0.11
HGI= @ % Moisture
As Rec'd. Sp.Gr.=
Free Swelling Index=
F-Factor(dry), DSCF/MM BTU= 10,582

Report Prepared By:

Gerard H. Cunningham
Fuels Laboratory Supervisor

* Oxygen by Difference.

** Not usually reported as part of the ultimate analysis.



Hazen Research, Inc.

4601 Indiana Street
Golden, CO 80403 USA
Tel: (303) 279-4501
Fax: (303) 278-1528

Date February 15 2007
HRI Project 009-555
HRI Series No. A344/07-2
Date Rec'd. 01/30/07
Cust. P.O.#

Golder Associates, Inc.
David Buff
6241 NW 23rd Street, Suite 500
Gainesville, FL 32653

Sample Identification
USSC-BLR7-012507-C2

Reporting Basis >

	As Rec'd	Dry	Air Dry
Proximate (%)			
Moisture	53.08	0.00	4.76
Ash	3.27	6.96	6.63
Volatile	38.42	81.90	78.00
Fixed C	5.23	11.14	10.61
Total	100.00	100.00	100.00

Sulfur	0.03	0.07	0.07
Btu/lb (HHV)	3710	7909	7532
MMF Btu/lb	3845	8552	
MAF Btu/lb		8501	
Air Dry Loss (%)	50.74		

Ultimate (%)

Moisture	53.08	0.00	4.76
Carbon	23.96	51.07	48.64
Hydrogen	2.71	5.77	5.50
Nitrogen	0.20	0.42	0.40
Sulfur	0.03	0.07	0.07
Ash	3.27	6.96	6.63
Oxygen*	16.75	35.71	34.00
Total	100.00	100.00	100.00

Chlorine**	0.015	0.033	0.031
------------	-------	-------	-------

Forms of Sulfur (as S,%)

Sulfate		
Pyritic		
Organic		
Total	0.03	0.07

Lb. Alkali/MM Btu=
Lb. Ash/MM Btu= 8.80
Lb. SO2/MM Btu= 0.19
HGI= @ % Moisture
As Rec'd. Sp.Gr.=
Free Swelling Index=
F-Factor(dry), DSCF/MM BTU= 10.473

Water Soluble Alkalies (%)

Na2O
K2O

Report Prepared By:

Gerard H. Cunningham
Fuels Laboratory Supervisor

* Oxygen by Difference.

** Not usually reported as part of the ultimate analysis.



Hazen Research, Inc.
 4801 Indiana Street
 Golden, CO 80403 USA
 Tel: (303) 279-4501
 Fax: (303) 278-1528

Date February 15 2007
 HRI Project 009-555
 HRI Series No. A344/07-3
 Date Rec'd. 01/30/07
 Cust. P.O.#

Golder Associates, Inc.
 David Buff
 6241 NW 23rd Street, Suite 500
 Gainesville, FL 32653

Sample Identification
 USSC-BLR7-012507-C3

Reporting Basis >	As Rec'd	Dry	Air Dry
Proximate (%)			
Moisture	52.03	0.00	3.28
Ash	4.75	9.89	9.57
Volatile	37.69	78.57	75.99
Fixed C	5.53	11.54	11.16
Total	100.00	100.00	100.00
Sulfur	0.02	0.05	0.05
Btu/lb (HHV)	3702	7717	7464
MMF Btu/lb	3901	8640	
MAF Btu/lb		8564	
Air Dry Loss (%)		50.40	

Ultimate (%)			
Moisture	52.03	0.00	3.28
Carbon	23.64	49.29	47.67
Hydrogen	2.72	5.68	5.49
Nitrogen	0.17	0.35	0.34
Sulfur	0.02	0.05	0.05
Ash	4.75	9.89	9.57
Oxygen*	16.67	34.74	33.60
Total	100.00	100.00	100.00
Chlorine**	0.014	0.030	0.029

Forms of Sulfur (as S,%)

Sulfate		
Pyritic		
Organic		
Total	0.02	0.05

Lb. Alkali/MM Btu=
 Lb. Ash/MM Btu= 12.82
 Lb. SO₂/MM Btu= 0.13
 HGI= @ % Moisture
 As Rec'd. Sp.Gr.=
 Free Swelling Index=
 F-Factor(dry), DSCF/MM BTU= 10,390

Water Soluble Alkalies (%)

Na₂O
 K₂O

Report Prepared By

Gerard H. Cunningham
 Fuels Laboratory Supervisor

* Oxygen by Difference.

** Not usually reported as part of the ultimate analysis.



Hazen Research, Inc.

4601 Indiana Street
Golden, CO 80403 USA
Tel: (303) 279-4501
Fax: (303) 278-1528

Date: February 15, 2007
Project No: 009-555
Control No: A344/07
Received: 01/30/07

Golder Associates, Inc.
David Buff
6241 NW 23rd Street, Suite 500
Gainesville, Florida 32653


Sample Number: A344/07	-1	-2	-3
Sample Identification: USSC-BLR7	012507-C1	012507-C2	012507-C3
Air Dry Loss, %	46.97	50.74	50.40
Residual Moisture, %	8.03	4.76	3.28
As Received Moisture, %	51.23	53.08	52.03
Ash (Air Dry Basis), %	3.88	6.63	9.57
Ash (As Received Basis), %	2.06	3.27	4.75
Ash (Dry Basis), %	4.22	6.96	9.89
Mercury (Air Dry Basis), mg/kg	<0.01	0.01	0.01
Mercury (As Received Basis), mg/kg	<0.005	0.005	0.005
Mercury (Dry Basis), mg/kg	<0.01	0.01	0.01
Metals in Ash			
Manganese, mg/kg	150	130	180
Dry Whole Fuel Basis			
Manganese, mg/kg	6	9	18

The ash was prepared at 600 degrees Celsius.
The 'dry whole' fuel values are calculated values.

By: 
Gerard H. Cunningham
Fuel Laboratory Manager

BOILER 8

1/5/07



**SOURCE TEST REPORT
FOR
PARTICULATE MATTER, HYDROCHLORIC ACID,
AND CHLORINE EMISSIONS**

**BOILER 8
EAST INLET DUCT TO CYCLONE
CLEWISTON, FLORIDA**

**FDEP PERMIT NUMBER 051-0003-030-AC
PSD-FL-333B
EMISSION UNIT 028**

MACT PERFORMANCE TEST

JANUARY 5, 2007

PREPARED FOR:

**U.S. SUGAR CORPORATION
111 PONCE DELEON AVENUE
CLEWISTON, FLORIDA 33440**

PREPARED BY:

**AIR CONSULTING AND ENGINEERING, INC.
2106 N.W. 67TH PLACE
GAINESVILLE, FLORIDA 32653
(352) 335-1889**

238-06-01

Table 1. Emission Summary
Boiler 8
United States Sugar Corporation - Clewiston Mill
Clewiston, Florida
January 5, 2007

Run Number	Time	Oxygen %	CO2 %	Flow Rate dscfm	Fuel Factor dscf/MMBTU Fuel Analysis	Steam Rate lbs/hr Boiler Parameters	Heat Input MMBTUH Fuel Analysis	HCl Emissions		Cl2 Emissions	
								lbs/hr	lbs/MMBTU	lbs/hr	lbs/MMBTU
1	1058-1158	9.3	10.8	216073	10904	499726	660.5	0.74	0.0011	2.03	0.0031
2	1345-1445	8.7	11.3	216113	10804	520274	699.4	3.02	0.0043	1.89	0.0027
3	1622-1722	7.6	12.5	219030	10843	510811	773.0	1.17	0.0015	1.98	0.0026
Average	—	8.5	11.5	217072	10850	510270	711.0	1.64	0.0023	1.96	0.0028

$$\text{lbs/MMBTU HCl} = \frac{[(\text{mg}) \times (\text{lbs}/453,600\text{mg})]}{\text{VMstd.}} \times \text{F-Factor} \times \frac{20.9}{(20.9 - \%O_2)}$$

$$\text{Heat Input} = \text{MMBTUH} = \frac{(\text{dscfm} \times 60 \text{ min/hr})}{\text{F-Factor}} \times \frac{(20.9 - \%O_2)}{20.9}$$

where: mg = from HCl/Cl2 analysis (Appendix C)
 VMstd. = sample volume (Appendix A)

HCL and CL2 Laboratory Results

Boiler 8
United States Sugar Corporation - Clewiston Mill
Clewiston, Florida
January 5, 2007

Run	HCL as Chloride mg	HCL mg	Chlorine as Chloride mg	Chlorine Gas mg
1	1.3	1.09	5.4	3.0
2	4.6	4.48	5.2	2.8
3	1.9	1.71	5.3	2.9

0.1N H2SO4Blank	0.24			
0.1N NAOH Blank			2.4	

Molecular Weight CL = 35.453 lb/lb-mole
Molecular Weight HCL = 36.453 lb/lb-mole

$$\text{mg HCL} = (\text{mg CL} - \text{CL Blank (0.1NH}_2\text{SO}_4)) \times \frac{\text{MW HCL}}{\text{MW CL}}$$

$$\text{mg CL}_2 = (\text{mg CL} - \text{CL Blank (0.1N NaOH)})$$

AIR CONSULTING AND ENGINEERING, INC.

FUEL FACTOR CALCULATION

COMPANY NAME: United States Sugar Corporation - Clewiston Mill
SOURCE: Boiler 8
FUEL FIRED: Bagasse

Run	1	2	3
	dry	dry	dry
Date	1/5/07	1/5/07	1/5/07
Time			
Carbon (%)	52.94	53.32	52.36
Hydrogen (%)	5.56	5.99	6
Nitrogen (%)	0.27	0.28	0.28
Sulfur (%)	0.08	0.48	0.06
Oxygen (%)	35.99	36.56	36.07
HHV (BTU/lb)	7774	8041	7879
F-Factor (dscf/MMBTU)	10904	10804	10843

Sample Calculation - Run 1

$$F_d = \frac{K[(Khd\%H) + (Kc\%C) + (Ks\%S) + (Kn\%N) - (Ko\%O)]}{GCV}$$

$$= \frac{10E6[3.64(5.56) + 1.53(52.94) + 0.57(0.08) + 0.14(0.27) - 0.46(35.99)]}{7774}$$

$$= 10904$$

Where:

- %H Concentration of hydrogen from the ultimate fuel analysis on a wet basis (as received)
- %C Concentration of carbon from the ultimate fuel analysis on a wet basis (as received)
- %S Concentration of sulfur from the ultimate fuel analysis on a wet basis (as received)
- %N Concentration of nitrogen from the ultimate fuel analysis on a wet basis (as received)
- %O Concentration of oxygen from the ultimate fuel analysis on a wet basis (as received)
- Khd conversion factor (3.64 scf/lb-%)
- Kc conversion factor (1.53 scf/lb-%)
- Ks conversion factor (0.57 scf/lb-%)
- Kn conversion factor (0.14 scf/lb-%)
- Ko conversion factor (0.46 scf/lb-%)
- K conversion factor (10E6 BTU/MMBTU)
- GCV gross calorific heating value (BTU/lb HHV) dry

MERCURY EMISSIONS

HHV dry: 7898 BTU/lb dry

Hg dry: 0.0133 mg/kg = $0.0133 \times 10E-6$ kg/kg = $1.33 \times 10E-8$ lb/lb

lbs/mmBTU Hg = $\frac{1.33 \times 10E-8 \text{ lb/lb}}{7898 \times 10E-6 \text{ mmBTU/lb}} = 1.68 \times 10E-6$



Hazen Research, Inc.
 4601 Indiana Street
 Golden, CO 80403 USA
 Tel: (303) 279-4501
 Fax: (303) 278-1528

Date February 5 2007
 HRI Project 009-555
 HRI Series No. A110/07-1
 Date Rec'd. 01/11/07
 Cust. P.O.#

Golder Associates, Inc.
 David Buff
 6241 NW 23rd Street, Suite 500
 Gainesville, FL 32653

Sample Identification
 010507-1 01/05/07 11 AM

Reporting Basis >	As Rec'd	Dry	Air Dry
Proximate (%)			
Moisture	52.42	0.00	1.47
Ash	2.45	5.16	5.08
Volatile	39.58	83.18	81.96
Fixed C	5.55	11.66	11.49
Total	100.00	100.00	100.00
Sulfur	0.04	0.08	0.08
Btu/lb (HHV)	3699	7774	7660
MMF Btu/lb	3799	8232	
MAF Btu/lb		8197	
Air Dry Loss (%)	51.71		

Ultimate (%)			
Moisture	52.42	0.00	1.47
Carbon	25.19	52.94	52.16
Hydrogen	2.64	5.56	5.48
Nitrogen	0.13	0.27	0.27
Sulfur	0.04	0.08	0.08
Ash	2.45	5.16	5.08
Oxygen*	17.13	35.99	35.46
Total	100.00	100.00	100.00
Chlorine**	0.016	0.033	0.033

Forms of Sulfur (as S,%)

Sulfate		
Pyritic		
Organic		
Total	0.04	0.08

Lb. Alkali/MM Btu=
 Lb. Ash/MM Btu= 6.63
 Lb. SO2/MM Btu= 0.21
 HGI= @ % Moisture
 As Rec'd. Sp.Gr.=
 Free Swelling Index=
 F-Factor(dry).DSCF/MM BTU= 10,902

Water Soluble Alkalies (%)

Na2O
 K2O

Report Prepared By:

 Gerard H. Cunningham
 Fuels Laboratory Supervisor

* Oxygen by Difference.

** Not usually reported as part of the ultimate analysis.



Hazen Research, Inc.

4601 Indiana Street
Golden, CO 80403 USA
Tel: (303) 279-4501
Fax: (303) 278-1528

Date February 5 2007
HRI Project 009-555
HRI Series No. A110/07-2
Date Rec'd. 01/11/07
Cust. P.O.#

Golder Associates, Inc.
David Buff
6241 NW 23rd Street, Suite 500
Gainesville, FL 32653

Sample Identification
010507-2 01/05/07 2 PM

Reporting Basis >	As Rec'd	Dry	Air Dry
Proximate (%)			
Moisture	51.62	0.00	2.62
Ash	1.63	3.37	3.28
Volatile	40.47	83.65	81.46
Fixed C	6.28	12.98	12.64
Total	100.00	100.00	100.00

Sulfur	0.23	0.48	0.47
Btu/lb (HHV)	3890	8041	7830
MMF Btu/lb	3953	8342	
MAF Btu/lb		8321	
Air Dry Loss (%)	50.32		

Ultimate (%)			
Moisture	51.62	0.00	2.62
Carbon	25.79	53.32	51.92
Hydrogen	2.90	5.99	5.84
Nitrogen	0.13	0.28	0.27
Sulfur	0.23	0.48	0.47
Ash	1.63	3.37	3.28
Oxygen*	17.70	36.56	35.60
Total	100.00	100.00	100.00

Chlorine**	0.010	0.021	0.020
------------	-------	-------	-------

Forms of Sulfur (as S, %)

Sulfate		
Pyritic		
Organic		
Total	0.23	0.48

Lb. Alkali/MM Btu= _____
 Lb. Ash/MM Btu= 4.19
 Lb. SO₂/MM Btu= 1.20
 HGI= @ % Moisture
 As Rec'd. Sp.Gr.= _____
 Free Swelling Index= _____
 F-Factor(dry), DSCF/MM BTU= 10.806

Water Soluble Alkalies (%)

Na₂O
K₂O

Report Prepared By:

 Gerard H. Cunningham
 Fuels Laboratory Supervisor

* Oxygen by Difference.
 ** Not usually reported as part of the ultimate analysis.



Hazen Research, Inc.

4601 Indiana Street
Golden, CO 80403 USA
Tel: (303) 279-4501
Fax: (303) 278-1528

Date February 5 2007
HRI Project 009-555
HRI Series No. A110/07-3
Date Rec'd. 01/11/07
Cust. P.O.#

Golder Associates, Inc.
David Buff
6241 NW 23rd Street, Suite 500
Gainesville, FL 32653

Sample Identification
010507-3 01/15/07 4 PM

Reporting Basis >	As Rec'd	Dry	Air Dry
Proximate (%)			
Moisture	51.55	0.00	1.37
Ash	2.53	5.23	5.16
Volatile	39.88	82.31	81.18
Fixed C	6.04	12.46	12.29
Total	100.00	100.00	100.00
Sulfur	0.03	0.06	0.06
Btu/lb (HHV)	3817	7879	7771
MMF Btu/lb	3923	8350	
MAF Btu/lb		8313	
Air Dry Loss (%)	50.88		

Ultimate (%)			
Moisture	51.55	0.00	1.37
Carbon	25.37	52.36	51.64
Hydrogen	2.91	6.00	5.92
Nitrogen	0.14	0.28	0.28
Sulfur	0.03	0.06	0.06
Ash	2.53	5.23	5.16
Oxygen*	17.47	36.07	35.57
Total	100.00	100.00	100.00
Chlorine**	0.012	0.025	0.025

Forms of Sulfur (as S.%)

Sulfate		
Pyritic		
Organic		
Total	0.03	0.06

Lb. Alkali/MM Btu=
Lb. Ash/MM Btu= 6.64
Lb. SO2/MM Btu= 0.15
HGI= @ % Moisture
As Rec'd. Sp.Gr.=
Free Swelling Index=
F-Factor(dry), DSCF/MM BTU= 10,843

Water Soluble Alkalies (%)

Na2O
K2O

Report Prepared By

Gerard H. Cunningham
Fuels Laboratory Supervisor

* Oxygen by Difference.

** Not usually reported as part of the ultimate analysis.



Hazen Research, Inc.


4601 Indiana Street
Golden, CO 80403 USA
Tel: (303) 279-4501
Fax: (303) 278-1528

Date: February 5, 2007
Project No: 009-555
Control No: A110/07
Received: 01/11/07

Golder Associates, Inc.
David Buff
6241 NW 23rd Street, Suite 500
Gainesville, Florida 32653

Sample Number: A110/07	-1	-2	-3
Sample Identification:	010507-1 11AM	010507-2 2PM	010507-1 4PM
Air Dry Loss, %	51.71	50.32	50.88
Residual Moisture, %	1.47	2.62	1.37
As Received Moisture, %	52.42	51.62	51.55
Ash (Air Dry Basis), %	5.08	3.28	5.16
Ash (As Received Basis), %	2.45	1.63	2.53
Ash (Dry Basis), %	5.16	3.37	5.23
Mercury (Air Dry Basis), mg/kg	0.02	0.01	0.01
Mercury (As Received Basis), mg/kg	0.01	0.005	0.005
Mercury (Dry Basis), mg/kg	0.02	0.01	0.01
Metals In Ash			
Manganese, mg/kg	440	549	359
Dry Whole Fuel Basis			
Manganese, mg/kg	23	18	19

The ash was prepared at 600 degrees Celsius.
The 'dry whole' fuel values are calculated values.

By: 
Gerard H. Cunningham
Fuel Laboratory Manager

Boiler No. 8 - ESP Report
1/5/2007 (C-1)

Time	Power Input 1 (kW)	Power Input 2 (kW)	Power Input 3 (kW)	Power Input 4 (kW)	Power Input 5 (kW)	Power Input Total (kW)
10:58	8.92	Down	Down	10.93	12.40	32.25
10:59	7.48	Down	Down	10.17	12.45	30.10
11:00	7.95	Down	Down	10.68	12.58	31.22
11:01	7.62	Down	Down	10.50	12.00	30.12
11:02	8.23	Down	Down	11.17	12.50	31.90
11:03	8.85	Down	Down	11.57	12.63	33.05
11:04	8.67	Down	Down	11.08	12.33	32.08
11:05	7.07	Down	Down	11.28	12.13	30.48
11:06	7.45	Down	Down	11.02	12.30	30.77
11:07	7.65	Down	Down	10.62	12.30	30.57
11:08	8.03	Down	Down	10.58	12.60	31.22
11:09	6.15	Down	Down	10.80	12.65	29.60
11:10	7.65	Down	Down	10.55	12.63	30.83
11:11	7.15	Down	Down	9.57	12.53	29.25
11:12	8.20	Down	Down	10.18	12.78	31.17
11:13	6.73	Down	Down	8.78	12.48	28.00
11:14	5.77	Down	Down	8.70	12.62	27.08
11:15	6.70	Down	Down	9.03	11.63	27.37
11:16	8.23	Down	Down	10.08	11.92	30.23
11:17	8.10	Down	Down	10.07	11.90	30.07
11:18	7.85	Down	Down	10.18	11.97	30.00
11:19	7.93	Down	Down	10.52	11.97	30.42
11:20	8.28	Down	Down	10.57	11.97	30.82
11:21	7.83	Down	Down	10.47	11.97	30.27
11:22	7.07	Down	Down	10.82	11.93	29.82
11:23	8.28	Down	Down	10.78	12.00	31.07
11:24	8.48	Down	Down	10.90	12.35	31.73
11:25	8.10	Down	Down	11.13	12.20	31.43
11:26	7.92	Down	Down	11.12	12.35	31.38
11:27	7.17	Down	Down	11.02	12.15	30.33
11:28	8.57	Down	Down	11.25	12.47	32.28
11:29	8.75	Down	Down	11.38	12.00	32.13
11:30	7.87	Down	Down	10.98	12.35	31.20
11:31	6.72	Down	Down	10.73	12.40	29.85
11:32	7.70	Down	Down	10.98	12.00	30.68
11:33	8.17	Down	Down	11.08	12.00	31.25
11:34	7.53	Down	Down	10.92	12.10	30.55
11:35	8.27	Down	Down	11.05	12.20	31.52
11:36	7.32	Down	Down	11.20	11.97	30.48
11:37	8.33	Down	Down	10.92	12.17	31.42
11:38	8.75	Down	Down	11.45	12.10	32.30
11:39	7.53	Down	Down	10.40	11.93	29.87
11:40	7.38	Down	Down	10.63	11.90	29.92
11:41	6.70	Down	Down	10.03	11.90	28.63
11:42	7.70	Down	Down	10.35	12.08	30.13
11:43	6.45	Down	Down	9.80	11.85	28.10
11:44	7.38	Down	Down	10.37	12.03	29.78
11:45	8.20	Down	Down	10.77	12.02	30.98
11:46	8.48	Down	Down	11.17	11.97	31.62
11:47	6.30	Down	Down	10.53	11.90	28.73
11:48	7.63	Down	Down	10.97	11.85	30.45
11:49	6.10	Down	Down	11.33	11.75	29.18
11:50	7.03	Down	Down	10.57	11.80	29.40
11:51	7.10	Down	Down	11.08	11.97	30.15
11:52	6.85	Down	Down	10.85	12.02	29.72
11:53	8.43	Down	Down	8.62	11.93	28.98
11:54	8.35	Down	Down	8.98	11.90	29.23
11:55	8.50	Down	Down	9.67	12.13	30.30
11:56	5.92	Down	Down	8.85	11.77	26.53
11:57	7.65	Down	Down	10.68	11.87	30.20
11:58	8.28	Down	Down	11.02	11.90	31.20
Average =	7.66	N/A	N/A	10.55	12.14	30.35

Boiler No. 8 - ESP Report
1/5/2007 (C-2)


Time	Power Input 1 (kW)	Power Input 2 (kW)	Power Input 3 (kW)	Power Input 4 (kW)	Power Input 5 (kW)	Power Input Total (kW)
13:45	7.27	Down	Down	11.30	11.72	30.28
13:46	6.80	Down	Down	11.18	11.77	29.75
13:47	6.83	Down	Down	10.95	11.73	29.52
13:48	6.47	Down	Down	11.70	11.68	29.85
13:49	7.27	Down	Down	10.97	11.68	29.92
13:50	7.32	Down	Down	11.15	11.85	30.32
13:51	6.77	Down	Down	11.00	11.03	28.80
13:52	8.02	Down	Down	11.55	11.52	31.08
13:53	8.02	Down	Down	11.43	11.55	31.00
13:54	7.67	Down	Down	11.45	11.45	30.57
13:55	6.63	Down	Down	11.08	11.32	29.03
13:56	6.37	Down	Down	11.72	11.65	29.73
13:57	8.38	Down	Down	11.60	11.73	31.72
13:58	8.32	Down	Down	11.90	11.87	32.08
13:59	7.78	Down	Down	11.27	11.65	30.70
14:00	7.40	Down	Down	11.13	12.25	30.78
14:01	8.08	Down	Down	11.08	12.83	32.00
14:02	8.33	Down	Down	11.87	12.95	33.15
14:03	7.47	Down	Down	11.57	12.30	31.33
14:04	6.72	Down	Down	10.47	12.22	29.40
14:05	8.03	Down	Down	10.92	11.67	30.62
14:06	7.67	Down	Down	11.20	11.68	30.55
14:07	7.98	Down	Down	11.25	11.18	30.42
14:08	7.30	Down	Down	10.73	11.67	29.70
14:09	7.12	Down	Down	10.83	11.75	29.70
14:10	6.98	Down	Down	11.02	11.48	29.48
14:11	5.93	Down	Down	10.10	11.28	27.32
14:12	5.97	Down	Down	10.10	10.80	26.87
14:13	7.03	Down	Down	9.18	11.03	27.25
14:14	6.82	Down	Down	10.20	11.93	28.95
14:15	7.03	Down	Down	10.50	11.77	29.30
14:16	6.27	Down	Down	10.17	11.72	28.15
14:17	5.63	Down	Down	10.10	11.62	27.35
14:18	4.93	Down	Down	10.25	11.12	26.30
14:19	5.17	Down	Down	9.67	10.77	25.60
14:20	5.80	Down	Down	8.00	10.95	24.75
14:21	5.72	Down	Down	9.70	11.07	26.48
14:22	6.45	Down	Down	9.80	11.60	27.85
14:23	5.93	Down	Down	10.48	11.92	28.33
14:24	5.62	Down	Down	10.42	11.67	27.70
14:25	5.58	Down	Down	10.15	11.68	27.42
14:26	6.60	Down	Down	10.37	11.65	28.62
14:27	7.58	Down	Down	10.70	11.90	30.18
14:28	7.78	Down	Down	10.57	11.93	30.28
14:29	7.38	Down	Down	11.02	11.63	30.03
14:30	6.93	Down	Down	10.47	11.50	28.90
14:31	7.15	Down	Down	10.48	11.25	28.88
14:32	7.53	Down	Down	10.63	11.68	29.85
14:33	6.53	Down	Down	10.25	11.43	28.22
14:34	4.67	Down	Down	9.58	11.05	25.30
14:35	6.55	Down	Down	10.17	11.30	28.02
14:36	7.13	Down	Down	10.50	11.57	29.20
14:37	8.40	Down	Down	10.70	11.70	30.80
14:38	7.90	Down	Down	10.68	11.25	29.83
14:39	8.40	Down	Down	10.82	11.60	30.82
14:40	8.12	Down	Down	10.78	11.47	30.37
14:41	7.50	Down	Down	10.13	11.62	29.25
14:42	5.90	Down	Down	10.15	10.85	26.90
14:43	6.70	Down	Down	10.43	11.15	28.28
14:44	5.30	Down	Down	10.03	11.17	26.50
14:45	4.82	Down	Down	9.38	10.78	24.98
Average =	6.91	N/A	N/A	10.64	11.57	29.12

Boiler No. 8 - ESP Report
1/5/2007 (C-3)

Time	Power Input 1 (kW)	Power Input 2 (kW)	Power Input 3 (kW)	Power Input 4 (kW)	Power Input 5 (kW)	Power Input Total (kW)
16:22	5.53	Down	Down	7.98	13.97	27.48
16:23	6.62	Down	Down	6.93	13.72	27.27
16:24	6.80	Down	Down	8.23	13.22	28.25
16:25	6.42	Down	Down	6.42	16.17	29.00
16:26	6.12	Down	Down	9.82	29.90	45.83
16:27	8.18	Down	Down	10.27	15.40	33.85
16:28	5.65	Down	Down	8.67	13.53	27.85
16:29	7.53	Down	Down	7.55	13.87	28.95
16:30	7.45	Down	Down	8.50	13.82	29.77
16:31	7.08	Down	Down	7.28	14.18	28.55
16:32	6.45	Down	Down	7.53	14.23	28.22
16:33	7.38	Down	Down	8.10	14.87	30.35
16:34	8.08	Down	Down	7.87	14.23	30.18
16:35	7.53	Down	Down	9.82	14.38	31.73
16:36	7.83	Down	Down	10.22	14.55	32.60
16:37	5.58	Down	Down	7.33	14.03	26.95
16:38	7.02	Down	Down	7.93	14.77	29.72
16:39	7.23	Down	Down	8.18	15.02	30.43
16:40	6.12	Down	Down	8.00	15.10	29.22
16:41	7.43	Down	Down	7.53	14.38	29.35
16:42	6.83	Down	Down	6.97	13.88	27.68
16:43	8.18	Down	Down	7.70	14.45	30.33
16:44	6.05	Down	Down	8.25	14.92	29.22
16:45	5.82	Down	Down	8.10	14.42	28.33
16:46	7.78	Down	Down	8.25	14.83	30.87
16:47	7.07	Down	Down	6.75	14.67	28.48
16:48	6.55	Down	Down	9.17	16.30	32.02
16:49	5.07	Down	Down	9.65	18.88	33.60
16:50	7.10	Down	Down	8.58	19.35	35.03
16:51	6.45	Down	Down	9.35	23.05	38.85
16:52	6.25	Down	Down	8.43	19.02	33.70
16:53	7.78	Down	Down	7.62	24.77	40.17
16:54	7.62	Down	Down	9.20	66.78	83.60
16:55	6.25	Down	Down	10.10	39.73	56.08
16:56	8.50	Down	Down	11.35	30.30	50.15
16:57	9.02	Down	Down	10.00	30.02	49.03
16:58	8.22	Down	Down	11.02	38.77	58.00
16:59	8.27	Down	Down	9.02	27.10	44.38
17:00	10.68	Down	Down	11.03	23.23	44.95
17:01	10.58	Down	Down	12.35	20.67	43.60
17:02	7.43	Down	Down	10.77	17.92	36.12
17:03	8.73	Down	Down	11.17	17.20	37.10
17:04	10.38	Down	Down	12.77	16.80	39.95
17:05	6.95	Down	Down	12.78	16.65	36.38
17:06	6.63	Down	Down	11.82	16.30	34.75
17:07	7.83	Down	Down	8.33	15.80	31.97
17:08	8.13	Down	Down	8.93	16.15	33.22
17:09	8.72	Down	Down	9.60	17.30	35.62
17:10	10.43	Down	Down	13.05	17.10	40.58
17:11	6.43	Down	Down	11.53	17.10	35.07
17:12	8.77	Down	Down	9.00	16.20	33.97
17:13	8.17	Down	Down	12.68	16.22	37.07
17:14	9.37	Down	Down	10.85	16.38	36.60
17:15	8.27	Down	Down	12.95	16.22	37.43
17:16	5.48	Down	Down	9.27	15.93	30.68
17:17	8.45	Down	Down	11.23	16.30	35.98
17:18	11.92	Down	Down	14.05	16.65	42.62
17:19	8.23	Down	Down	10.68	17.08	36.00
17:20	10.38	Down	Down	10.47	17.47	38.32
17:21	9.85	Down	Down	14.47	17.18	41.50
17:22	9.28	Down	Down	13.27	17.92	40.47
Average =	7.67	N/A	N/A	9.62	18.69	35.98

BOILER 8

8/22/06



**SOURCE TEST REPORT
FOR
PARTICULATE MATTER, MERCURY, CHLORINE AND
HYDROCHLORIC ACID EMISSIONS**

**BOILER 8
UNITED STATES SUGAR CORPORATION
CLEWISTON, FLORIDA**

**FDEP PERMIT NUMBER 051-0003-030-AC
PSD-FL-333B
EMISSION UNIT 028**

**MACT PERFORMANCE TEST
WOOD CHIP FIRING**

AUGUST 22, 2006

PREPARED FOR:

**U.S. SUGAR CORPORATION
111 PONCE DELEON AVENUE
CLEWISTON, FLORIDA 33440**

PREPARED BY:

**AIR CONSULTING AND ENGINEERING, INC.
2106 NW 67TH PLACE, SUITE 4
GAINESVILLE, FLORIDA 32653
(352) 335-1889**

238-05-01

**Table 2. Hydrochloric Acid Emission Summary
Boiler 8 - Inlet to Wet Cyclones
United States Sugar Corporation
Clewiston, Florida
August 22, 2006**

Run Number	Time	Oxygen %	CO2 %	Steam Rate lbs/hr Plant Data	Fuel Factor dscf/MMBTU Fuel Analysis	Heat Input* MMBTUH	Flow Rate dscfm	HCl Emissions		Cl2 Emissions	
								lbs/hr	lbs/MMBTU	lbs/hr	lbs/MMBTU
1	1036-1136	11.5	9.6	202933	11162	403.5	148855	28.14	0.0785	1.10	0.0031
2	1320-1420	12.5	7.7	202604	11501	383.6	146795	29.73	0.0967	0.90	0.0029
3	1530-1630	11.4	8.9	199219	11005	411.4	148794	29.93	0.0809	0.79	0.0021
Average	—	11.8	8.8	201585	11223	399.5	148148	29.27	0.0854	0.93	0.0027

Note: Results were not blank corrected
HCl and Cl2 were not measured isokinetically, emissions in lbs/hr were calculated using the stack flow rate

* The heat input was calculated using the stack flow rate and stack O2 measurements

$$\text{lbs/MMBTU HCl} = \frac{[(\text{mg}) \times (\text{lbs}/453.600\text{mg})] \times \text{F-Factor} \times 20.9}{\text{VMstd.} \times 20.9 - \%O_2}$$

Laboratory Results
Boiler 8

Run	HCL as Chloride mg	HCL mg	Chlorine as Chloride mg	Chlorine mg
1	60.0	61.69	1.2	2.40
2	64.0	65.81	1	2.00
3	64.0	65.81	0.87	1.74
H2SO4Blank	0.1	0.10		
NAOH Blank			0.1	0.20

CL = 35.453 lb/lb-mole
HCL = 36.453 lb/lb-mole
Chlorine = 70.906 lb/lb-mole

AIR CONSULTING AND ENGINEERING, INC.

FUEL FACTOR CALCULATION

COMPANY NAME: United States Sugar Corporation
SOURCE: Boiler 8
FUEL FIRED: Wood Chips

Run	1	2	3
	wet	wet	wet
Date	8/22/06	8/22/06	8/22/06
Time			
Carbon (%)	29.34	32.33	31.56
Hydrogen (%)	3.43	3.79	3.55
Nitrogen (%)	0.33	0.32	0.36
Sulfur (%)	0.05	0.06	0.06
Oxygen (%)	18.20	18.76	18.84
HHV (BTU/lb)	4397	4757	4782
F-Factor (scf/MMBTU)	11162	11501	11005

Sample Calculation - Run 1

$$F_w = \frac{K[(K_{hw} \%H) + (K_{cw} \%C) + (K_{sw} \%S) + (K_{nw} \%N) - (K_{ow} \%O)]}{GCV_w}$$

$$= \frac{10E6[3.64(3.43) + 1.53(29.34) + 0.57(0.05) + 0.14(0.33) - 0.46(18.2)]}{4397}$$

$$= 11162$$

Where:

- %H Concentration of hydrogen from the ultimate fuel analysis on a wet basis (as received)
- %C Concentration of carbon from the ultimate fuel analysis on a wet basis (as received)
- %S Concentration of sulfur from the ultimate fuel analysis on a wet basis (as received)
- %N Concentration of nitrogen from the ultimate fuel analysis on a wet basis (as received)
- %O Concentration of oxygen from the ultimate fuel analysis on a wet basis (as received)
- K_{hd} conversion factor (3.64 scf/lb-%)
- K_c conversion factor (1.53 scf/lb-%)
- K_s conversion factor (0.57 scf/lb-%)
- K_n conversion factor (0.14 scf/lb-%)
- K_o conversion factor (0.46 scf/lb-%)
- K conversion factor (10E6 BTU/MMBTU)
- GCV gross calorific heating value (BTU/lb HHV) wet



Hazen Research, Inc.
 4601 Indiana Street
 Golden, CO 80403 USA
 Tel: (303) 279-4501
 Fax: (303) 278-1528

Date September 14 2006
 HRI Project 009-555
 HRI Series No. H301/06-1
 Date Rec'd. 08/29/06
 Cust. P.O.#

Golder Associates, Inc.
 David Buff
 6241 NW 23rd Street, Suite 500
 Gainesville, FL 32653

Sample Identification
 USSC-082206-1 Wood Chips

Reporting Basis >	As Rec'd	Dry	Air Dry
Proximate (%)			
Moisture	36.57	0.00	1.85
Ash	12.08	19.04	18.69
Volatile	40.87	64.43	63.24
Fixed C	10.48	16.53	16.22
Total	100.00	100.00	100.00

Sulfur	0.05	0.08	0.08
Btu/lb. (HHV)	4397	6932	6804
MMF Btu/lb	5056	8727	
MAF Btu/lb		8563	
Air Dry Loss (%)	35.37		

Ultimate (%)			
Moisture	36.57	0.00	1.85
Carbon	29.34	46.26	45.40
Hydrogen	3.43	5.41	5.31
Nitrogen	0.33	0.52	0.51
Sulfur	0.05	0.08	0.08
Ash	12.08	19.04	18.69
Oxygen*	18.20	28.69	28.16
Total	100.00	100.00	100.00
Chlorine**	0.092	0.145	0.142

Forms of Sulfur (as S,%)

Sulfate		
Pyritic		
Organic		
Total	0.05	0.08

Water Soluble Alkalies (%)

Na2O
 K2O

Lb. Alkali/MM Btu=
 Lb. Ash/MM Btu= 27.47
 Lb. SO2/MM Btu= 0.24
 HGI= @ % Moisture
 As Rec'd. Sp.Gr.=
 Free Swelling Index=
 F-Factor(dry), DSCF/MM BTU= 11.165

Report Prepared By:

Gerard H. Cunningham
 Fuels Laboratory Supervisor

* Oxygen by Difference.

** Not usually reported as part of the ultimate analysis.



Hazen Research, Inc.
 4601 Indiana Street
 Golden, CO 80403 USA
 Tel: (303) 279-4501
 Fax: (303) 278-1528

Date September 14 2006
 HRI Project 009-555
 HRI Series No. H301/06-2
 Date Rec'd. 08/29/06
 Cust. P.O.#

Golder Associates, Inc.
 David Buff
 6241 NW 23rd Street, Suite 500
 Gainesville, FL 32653

Sample Identification
 USSC-082206-2 Wood Chips

Reporting Basis >	As Rec'd	Dry	Air Dry
Proximate (%)			
Moisture	32.72	0.00	2.18
Ash	12.02	17.87	17.48
Volatile	45.61	67.80	66.32
Fixed C	9.65	14.33	14.02
Total	100.00	100.00	100.00
Sulfur	0.06	0.09	0.09
Btu/lb (HHV)	4757	7071	6917
MMF Btu/lb	5466	8762	
MAF Btu/lb		8609	
Air Dry Loss (%)		31.22	

Ultimate (%)			
Moisture	32.72	0.00	2.18
Carbon	32.33	48.06	47.01
Hydrogen	3.79	5.63	5.51
Nitrogen	0.32	0.48	0.47
Sulfur	0.06	0.09	0.09
Ash	12.02	17.87	17.48
Oxygen*	18.76	27.87	27.26
Total	100.00	100.00	100.00
Chlorine**	0.095	0.141	0.138

Forms of Sulfur (as S,%)

Sulfate		
Pyritic		
Organic		
Total	0.06	0.09

Lb. Alkali/MM Btu=
 Lb. Ash/MM Btu= 25.27
 Lb. SO₂/MM Btu= 0.26
 HGI= @ % Moisture
 As Rec'd. Sp.Gr.=
 Free Swelling Index=
 F-Factor(dry), DSCF/MM BTU= 11,500

Water Soluble Alkalies (%)

Na₂O
 K₂O

Report Prepared By:
 Gerard H. Cunningham
 Fuels Laboratory Supervisor

* Oxygen by Difference.

** Not usually reported as part of the ultimate analysis.



Hazen Research, Inc.
 4601 Indiana Street
 Golden, CO 80403 USA
 Tel: (303) 279-4501
 Fax: (303) 278-1528

Date September 14 2006
 HRI Project 009-555
 HRI Series No. H301/06-3
 Date Rec'd. 08/29/06
 Cust. P.O.#

Golder Associates, Inc.
 David Buff
 6241 NW 23rd Street, Suite 500
 Gainesville, FL 32653

Sample Identification
 USSC-082206-3 Wood Chips

Reporting Basis >	As Rec'd	Dry	Air Dry
Proximate (%)			
Moisture	33.93	0.00	4.54
Ash	11.70	17.71	16.91
Volatile	45.10	68.26	65.16
Fixed C	9.27	14.03	13.39
Total	100.00	100.00	100.00

Sulfur	0.06	0.08	0.08
Btu/lb (HHV)	4782	7238	6909
MMF Btu/lb	5472	8950	
MAF Btu/lb		8796	
Air Dry Loss (%)	30.79		

Ultimate (%)

Moisture	33.93	0.00	4.54
Carbon	31.56	47.77	45.60
Hydrogen	3.55	5.38	5.13
Nitrogen	0.36	0.54	0.52
Sulfur	0.06	0.08	0.08
Ash	11.70	17.71	16.91
Oxygen*	18.84	28.52	27.22
Total	100.00	100.00	100.00
Chlorine**	0.107	0.161	0.154

Forms of Sulfur (as S,%)

Sulfate		
Pyritic		
Organic		
Total	0.06	0.08

Lb. Alkali/MM Btu=
 Lb. Ash/MM Btu= 24.47
 Lb. SO₂/MM Btu= 0.23
 HGI= @ % Moisture
 As Rec'd. Sp. Gr.=
 Free Swelling Index=
 F-Factor(dry).DSCF/MM BTU= 11.007

Water Soluble Alkalies (%)

Na₂O
 K₂O

Report Prepared By:

 Gerard H. Cunningham
 Fuels Laboratory Supervisor

* Oxygen by Difference.

** Not usually reported as part of the ultimate analysis.




Hazen Research, Inc.
 4801 Indiana Street
 Golden, CO 80403 USA
 Tel: (303) 279-4501
 Fax: (303) 278-1528

Date: Sept. 14, 2006
 Project No: 009-555
 Control No: H301/06
 Received: 08/29/06

Golder Associates, Inc.
 David Buff
 6241 NW 23rd Street, Suite 500
 Gainesville, Florida 32653

Sample Number: H301/06	-1	-2	-3
Sample Identification: USSC-060106	-4	-6	-8
Air Dry Loss, %	35.37	31.22	30.79
Residual Moisture, %	1.85	2.18	4.54
As Received Moisture, %	36.57	32.72	33.93
Ash (Air Dry Basis), %	18.69	17.48	16.91
Ash (As Received Basis), %	12.08	12.02	11.70
Ash (Dry Basis), %	19.04	17.87	17.71
Mercury (Air Dry Basis), mg/kg	0.02	0.02	0.02
Mercury (As Received Basis), mg/kg	0.01	0.01	0.01
Mercury (Dry Basis), mg/kg	0.02	0.02	0.02
Metals In Ash			
Manganese, mg/kg	98	100	110
Dry Whole Fuel Basis			
Manganese, mg/kg	19	18	19

The ash was prepared at 600 degrees Celsius.
 The 'dry whole' fuel values are calculated values.

By: 
 Gerard H. Cunningham
 Fuel Laboratory Manager

Boiler 8 - Wet Cyclone Report
8/22/2006 (C-1)

Time ^a	Water Flow Rate 1 (gal/hr)	Water Flow 1 (On/Off)	Pressure Drop 1 (inches H ₂ O)	Water Flow Rate 2 (gal/hr)	Water Flow 2 (On/Off)	Pressure Drop 2 (inches H ₂ O)
9:36	21,010	On	0.32	21,000	On	0.34
9:37	20,990	On	0.51	21,000	On	0.51
9:38	21,000	On	0.48	20,990	On	0.29
9:39	21,010	On	0.31	21,010	On	0.33
9:40	21,000	On	0.42	21,000	On	0.39
9:41	21,010	On	0.43	21,000	On	0.37
9:42	21,000	On	0.40	21,000	On	0.36
9:43	20,990	On	0.40	21,000	On	0.39
9:44	21,010	On	0.37	21,000	On	0.33
9:45	20,990	On	0.43	21,000	On	0.38
9:46	21,000	On	0.37	21,010	On	0.31
9:47	20,990	On	0.39	20,990	On	0.38
9:48	21,010	On	0.39	21,010	On	0.39
9:49	21,000	On	0.42	20,990	On	0.32
9:50	21,000	On	0.41	21,010	On	0.36
9:51	21,010	On	0.39	20,990	On	0.29
9:52	21,000	On	0.52	21,000	On	0.35
9:53	21,000	On	0.48	21,000	On	0.36
9:54	21,000	On	0.31	21,010	On	0.24
9:55	20,980	On	0.52	21,010	On	0.42
9:56	21,010	On	0.40	20,990	On	0.38
9:57	21,000	On	0.51	21,000	On	0.46
9:58	20,990	On	0.39	20,990	On	0.26
9:59	21,000	On	0.45	21,010	On	0.37
10:00	21,010	On	0.32	21,000	On	0.23
10:01	20,980	On	0.42	21,010	On	0.48
10:02	21,010	On	0.32	20,990	On	0.34
10:03	21,000	On	0.25	21,000	On	0.18
10:04	21,000	On	0.40	21,000	On	0.39
10:05	21,000	On	0.43	21,010	On	0.39
10:06	21,000	On	0.40	21,010	On	0.29
10:07	21,000	On	0.36	20,990	On	0.34
10:08	21,000	On	0.38	21,000	On	0.16
10:09	21,000	On	0.46	21,000	On	0.28
10:10	21,000	On	0.47	21,010	On	0.26
10:11	21,000	On	0.30	21,000	On	0.29
10:12	21,000	On	0.49	21,000	On	0.33
10:13	21,000	On	0.32	21,010	On	0.29
10:14	21,000	On	0.24	20,990	On	0.22
10:15	21,000	On	0.38	20,990	On	0.28
10:16	21,000	On	0.49	21,000	On	0.44
10:17	20,990	On	0.37	21,000	On	0.28
10:18	21,000	On	0.44	21,010	On	0.43
10:19	21,000	On	0.57	21,000	On	0.45
10:20	21,000	On	0.47	21,000	On	0.44
10:21	21,010	On	0.50	21,010	On	0.40
10:22	20,990	On	0.46	21,000	On	0.45
10:23	21,000	On	0.36	20,990	On	0.36
10:24	21,000	On	0.42	20,990	On	0.42
10:25	21,000	On	0.33	21,000	On	0.33
10:26	20,990	On	0.53	21,000	On	0.48
10:27	21,000	On	0.38	21,000	On	0.42
10:28	21,000	On	0.43	21,000	On	0.29
10:29	21,010	On	0.38	20,990	On	0.30
10:30	20,990	On	0.32	21,010	On	0.36
10:31	21,010	On	0.31	21,000	On	0.24
10:32	20,990	On	0.44	20,990	On	0.42
10:33	21,000	On	0.44	21,000	On	0.50
10:34	21,010	On	0.45	21,010	On	0.38
10:35	21,000	On	0.49	21,000	On	0.44
10:36	21,010	On	0.31	20,990	On	0.40
Average	21,000	N/A	0.41	21,000	N/A	0.35

^a The CEMS DAHS does not account for Daylight Savings Time, therefore, the CEMS data corresponding to the stack test runs is one-hour behind actual time.

Boiler 8 - ESP Report
8/22/2006 (C-1)

Time *	Secondary Power Input 1	Secondary Power Input 2	Secondary Power Input 3	Secondary Power Input 4	Secondary Power Input 5	Secondary Power Input Total
	(kW)	(kW)	(kW)	(kW)	(kW)	(kW)
9:36	0.18	0.00	14.55	30.53	0.00	45.27
9:37	0.40	0.00	12.95	32.17	0.00	45.52
9:38	0.27	0.00	13.72	28.85	0.00	42.83
9:39	0.27	0.00	13.70	26.68	0.00	40.65
9:40	0.25	0.00	13.97	32.67	0.00	46.88
9:41	0.18	0.00	14.98	32.87	0.00	48.03
9:42	0.18	0.00	15.07	31.27	0.00	46.52
9:43	0.30	0.00	14.50	31.53	0.00	46.33
9:44	0.25	0.00	14.63	31.18	0.00	46.07
9:45	0.27	0.00	14.53	31.17	0.00	45.97
9:46	0.27	0.00	14.35	29.93	0.00	44.55
9:47	0.25	0.00	14.40	31.50	0.00	46.15
9:48	0.20	0.00	14.40	31.97	0.00	46.57
9:49	0.25	0.00	13.82	28.48	0.00	42.55
9:50	0.18	0.00	14.35	32.37	0.00	46.90
9:51	0.20	0.00	14.40	32.02	0.00	46.62
9:52	0.17	0.00	14.35	31.17	0.00	45.68
9:53	0.13	0.00	14.30	31.37	0.00	45.80
9:54	0.17	0.00	13.55	31.08	0.00	44.80
9:55	0.13	0.00	14.35	31.65	0.00	46.13
9:56	0.23	0.00	13.12	31.82	0.00	45.17
9:57	0.33	0.00	14.53	31.42	0.00	46.28
9:58	0.20	0.00	14.60	31.73	0.00	46.53
9:59	0.13	0.00	14.68	31.37	0.00	46.18
10:00	0.18	0.00	14.45	31.85	0.00	46.48
10:01	0.17	0.00	14.05	31.60	0.00	45.82
10:02	0.28	0.00	14.15	31.97	0.00	46.40
10:03	0.30	0.00	14.25	30.97	0.00	45.52
10:04	0.20	0.00	13.88	30.93	0.00	45.02
10:05	0.23	0.00	14.07	31.48	0.00	45.78
10:06	0.25	0.00	14.40	30.67	0.00	45.32
10:07	0.18	0.00	14.40	31.08	0.00	45.67
10:08	0.20	0.00	14.13	30.25	0.00	44.58
10:09	0.13	0.00	13.90	30.62	0.00	44.65
10:10	0.23	0.00	14.57	31.45	0.00	46.25
10:11	0.27	0.00	14.63	30.93	0.00	45.83
10:12	0.32	0.00	14.35	31.43	0.00	46.10
10:13	0.20	0.00	14.45	30.80	0.00	45.45
10:14	0.17	0.00	14.35	31.18	0.00	45.70
10:15	0.22	0.00	14.35	30.87	0.00	45.43
10:16	0.20	0.00	14.25	31.12	0.00	45.57
10:17	0.23	0.00	14.25	31.18	0.00	45.67
10:18	0.10	0.00	14.20	31.02	0.00	45.32
10:19	0.18	0.00	14.10	30.85	0.00	45.13
10:20	0.27	0.00	14.05	30.65	0.00	44.97
10:21	0.22	0.00	14.25	31.38	0.00	45.85
10:22	0.25	0.00	13.98	30.65	0.00	44.88
10:23	0.27	0.00	14.20	30.92	0.00	45.38
10:24	0.23	0.00	14.10	30.70	0.00	45.03
10:25	0.17	0.00	14.30	30.80	0.00	45.27
10:26	0.20	0.00	14.35	31.40	0.00	45.95
10:27	0.13	0.00	13.77	30.95	0.00	44.85
10:28	0.17	0.00	14.32	31.05	0.00	45.53
10:29	0.20	0.00	14.35	31.52	0.00	46.07
10:30	0.17	0.00	14.30	31.12	0.00	45.58
10:31	0.20	0.00	14.27	30.80	0.00	45.27
10:32	0.13	0.00	14.32	31.68	0.00	46.13
10:33	0.20	0.00	14.22	30.47	0.00	44.88
10:34	0.20	0.00	13.92	31.40	0.00	45.52
10:35	0.33	0.00	14.25	31.58	0.00	46.17
10:36	0.23	0.00	14.10	30.65	0.00	44.98
Average	0.22	0.00	14.23	31.09	0.00	45.54

* The CEMS DAHS does not account for Daylight Savings Time, therefore, the CEMS data corresponding to the stack test runs is one-hour behind actual time.

Boiler 8 - Wet Cyclone Report
8/22/2006 (C-2)

Time *	Water Flow Rate 1 (gal/hr)	Water Flow 1 (On/Off)	Pressure Drop 1 (inches H ₂ O)	Water Flow Rate 2 (gal/hr)	Water Flow 2 (On/Off)	Pressure Drop 2 (inches H ₂ O)
12:20	21,000	On	0.34	21,010	On	0.33
12:21	21,000	On	0.35	21,000	On	0.31
12:22	21,000	On	0.52	21,000	On	0.48
12:23	21,000	On	0.44	21,000	On	0.37
12:24	21,000	On	0.48	21,000	On	0.41
12:25	21,010	On	0.36	21,000	On	0.29
12:26	21,000	On	0.54	21,000	On	0.37
12:27	21,000	On	0.47	21,000	On	0.44
12:28	21,000	On	0.37	21,010	On	0.28
12:29	21,010	On	0.44	21,000	On	0.32
12:30	21,000	On	0.43	21,000	On	0.30
12:31	21,000	On	0.63	21,000	On	0.52
12:32	21,010	On	0.23	21,010	On	0.17
12:33	21,010	On	0.50	21,000	On	0.39
12:34	21,000	On	0.45	21,010	On	0.29
12:35	20,980	On	0.37	21,000	On	0.30
12:36	21,000	On	0.46	21,000	On	0.42
12:37	21,010	On	0.52	21,000	On	0.44
12:38	21,000	On	0.44	21,010	On	0.41
12:39	21,000	On	0.48	21,000	On	0.48
12:40	21,010	On	0.43	21,010	On	0.40
12:41	20,990	On	0.53	20,990	On	0.38
12:42	21,010	On	0.40	21,010	On	0.35
12:43	21,010	On	0.44	21,010	On	0.31
12:44	21,000	On	0.47	20,990	On	0.47
12:45	20,980	On	0.39	21,000	On	0.32
12:46	21,000	On	0.31	20,990	On	0.24
12:47	21,020	On	0.36	21,000	On	0.33
12:48	21,000	On	0.51	21,010	On	0.33
12:49	21,000	On	0.26	21,000	On	0.29
12:50	21,000	On	0.29	20,990	On	0.21
12:51	21,010	On	0.37	21,010	On	0.36
12:52	20,990	On	0.33	21,010	On	0.29
12:53	21,000	On	0.61	21,000	On	0.47
12:54	21,010	On	0.50	20,990	On	0.36
12:55	20,990	On	0.40	21,000	On	0.18
12:56	20,990	On	0.58	21,000	On	0.43
12:57	21,010	On	0.47	21,000	On	0.39
12:58	21,000	On	0.38	21,000	On	0.36
12:59	20,990	On	0.29	21,010	On	0.26
13:00	21,000	On	0.38	21,000	On	0.30
13:01	21,000	On	0.47	21,000	On	0.37
13:02	21,010	On	0.45	21,000	On	0.46
13:03	21,000	On	0.39	21,000	On	0.34
13:04	21,010	On	0.55	21,000	On	0.40
13:05	20,990	On	0.35	21,000	On	0.33
13:06	21,010	On	0.44	20,990	On	0.43
13:07	21,000	On	0.57	21,010	On	0.59
13:08	20,990	On	0.44	20,990	On	0.35
13:09	21,000	On	0.41	21,010	On	0.33
13:10	21,000	On	0.24	21,000	On	0.17
13:11	21,010	On	0.27	21,000	On	0.22
13:12	20,990	On	0.39	21,000	On	0.38
13:13	21,000	On	0.34	20,990	On	0.37
13:14	21,000	On	0.39	21,010	On	0.43
13:15	21,000	On	0.38	21,000	On	0.30
13:16	21,000	On	0.38	21,010	On	0.34
13:17	21,000	On	0.47	20,990	On	0.45
13:18	21,000	On	0.42	21,000	On	0.43
13:19	21,000	On	0.31	21,000	On	0.26
13:20	20,990	On	0.51	21,000	On	0.23
Average	21,001	N/A	0.42	21,001	N/A	0.35

* The CEMS DAHS does not account for Daylight Savings Time, therefore, the CEMS data corresponding to the stack test runs is one-hour behind actual time.

Boiler 8- ESP Report
8/22/2006 (C-2)

Time *	Secondary Power	Secondary Power	Secondary Power	Secondary Power	Secondary Power	Secondary Power
	Input 1	Input 2	Input 3	Input 4	Input 5	Input Total
	(kW)	(kW)	(kW)	(kW)	(kW)	(kW)
12:20	0.22	0.00	0.00	20.75	0.00	20.97
12:21	0.20	0.00	0.00	20.07	0.00	20.27
12:22	0.20	0.00	0.00	19.93	0.00	20.13
12:23	0.17	0.00	0.00	20.32	0.00	20.48
12:24	0.33	0.00	0.00	19.85	0.00	20.18
12:25	0.17	0.00	0.00	19.68	0.00	19.85
12:26	0.20	0.00	0.00	20.82	0.00	21.02
12:27	0.15	0.00	0.00	19.98	0.00	20.13
12:28	0.27	0.00	0.00	20.53	0.00	20.80
12:29	0.18	0.00	0.00	19.47	0.00	19.65
12:30	0.23	0.00	0.00	19.57	0.00	19.80
12:31	0.25	0.00	0.00	19.57	0.00	19.82
12:32	0.10	0.00	0.00	19.43	0.00	19.53
12:33	0.18	0.00	0.00	17.82	0.00	18.00
12:34	0.17	0.00	0.00	18.65	0.00	18.82
12:35	0.17	0.00	0.00	19.23	0.00	19.40
12:36	0.10	0.00	0.00	19.80	0.00	19.90
12:37	0.20	0.00	0.00	20.42	0.00	20.62
12:38	0.17	0.00	0.00	20.22	0.00	20.38
12:39	0.25	0.00	0.00	19.93	0.00	20.18
12:40	0.17	0.00	0.00	16.35	0.00	16.52
12:41	0.20	0.00	0.00	20.30	0.00	20.50
12:42	0.25	0.00	0.00	19.40	0.00	19.65
12:43	0.20	0.00	0.00	20.68	0.00	20.88
12:44	0.17	0.00	0.00	19.50	0.00	19.67
12:45	0.32	0.00	0.00	20.05	0.00	20.37
12:46	0.20	0.00	0.00	19.95	0.00	20.15
12:47	0.20	0.00	0.00	20.25	0.00	20.45
12:48	0.13	0.00	0.00	19.05	0.00	19.18
12:49	0.20	0.00	0.00	20.50	0.00	20.70
12:50	0.30	0.00	0.00	19.87	0.00	20.17
12:51	0.20	0.00	0.00	19.93	0.00	20.13
12:52	0.22	0.00	0.00	19.77	0.00	19.98
12:53	0.20	0.00	0.00	19.30	0.00	19.50
12:54	0.17	0.00	0.00	18.88	0.00	19.05
12:55	0.23	0.00	0.00	19.45	0.00	19.68
12:56	0.27	0.00	0.00	20.47	0.00	20.73
12:57	0.23	0.00	0.00	20.12	0.00	20.35
12:58	0.37	0.00	0.00	20.33	0.00	20.70
12:59	0.17	0.00	0.00	19.72	0.00	19.88
13:00	0.20	0.00	0.00	19.55	0.00	19.75
13:01	0.23	0.00	0.00	19.67	0.00	19.90
13:02	0.20	0.00	0.00	20.13	0.00	20.33
13:03	0.22	0.00	0.00	20.07	0.00	20.28
13:04	0.25	0.00	0.00	19.63	0.00	19.88
13:05	0.22	0.00	0.00	18.12	0.00	18.33
13:06	0.23	0.00	0.00	20.85	0.00	21.08
13:07	0.33	0.00	0.00	19.63	0.00	19.97
13:08	0.15	0.00	0.00	16.65	0.00	16.80
13:09	0.17	0.00	0.00	19.40	0.00	19.57
13:10	0.13	0.00	0.00	19.35	0.00	19.48
13:11	0.20	0.00	0.00	20.62	0.00	20.82
13:12	0.15	0.00	0.00	18.78	0.00	18.93
13:13	0.27	0.00	0.00	21.35	0.00	21.62
13:14	0.13	0.00	0.00	20.97	0.00	21.10
13:15	0.27	0.00	0.00	20.85	0.00	21.12
13:16	0.25	0.00	0.00	19.98	0.00	20.23
13:17	0.23	0.00	0.00	20.50	0.00	20.73
13:18	0.20	0.00	0.00	19.07	0.00	19.27
13:19	0.17	0.00	0.00	19.60	0.00	19.77
13:20	0.13	0.00	0.00	20.62	0.00	20.75
Average	0.21	0.00	0.00	19.76	0.00	19.97

* The CEMS DAHS does not account for Daylight Savings Time, therefore, the CEMS data corresponding to the stack test runs is one-hour behind actual time.

Boiler 8 - Wet Cyclone Report
8/22/2006 (C-3)

Time *	Water Flow Rate 1 (gal/hr)	Water Flow 1 (On/Off)	Pressure Drop 1 (inches H ₂ O)	Water Flow Rate 2 (gal/hr)	Water Flow 2 (On/Off)	Pressure Drop 2 (inches H ₂ O)
14:30	20,990	On	0.50	21,000	On	0.37
14:31	21,010	On	0.40	21,010	On	0.35
14:32	20,990	On	0.44	21,000	On	0.43
14:33	21,010	On	0.36	21,000	On	0.21
14:34	21,000	On	0.37	21,000	On	0.44
14:35	21,000	On	0.40	21,000	On	0.22
14:36	21,010	On	0.34	21,000	On	0.37
14:37	20,990	On	0.45	21,000	On	0.36
14:38	21,010	On	0.29	21,000	On	0.24
14:39	21,000	On	0.30	21,000	On	0.15
14:40	21,000	On	0.45	21,000	On	0.38
14:41	21,000	On	0.44	21,000	On	0.24
14:42	21,010	On	0.49	21,010	On	0.34
14:43	21,000	On	0.52	21,000	On	0.41
14:44	21,010	On	0.48	21,000	On	0.37
14:45	20,990	On	0.33	21,010	On	0.33
14:46	21,000	On	0.34	21,000	On	0.22
14:47	20,990	On	0.63	21,010	On	0.43
14:48	21,000	On	0.44	20,990	On	0.43
14:49	21,000	On	0.47	20,990	On	0.38
14:50	21,000	On	0.47	21,000	On	0.42
14:51	21,000	On	0.57	21,010	On	0.31
14:52	21,010	On	0.35	20,990	On	0.30
14:53	20,990	On	0.63	21,000	On	0.46
14:54	21,000	On	0.49	20,990	On	0.35
14:55	21,000	On	0.44	21,000	On	0.40
14:56	21,020	On	0.33	20,990	On	0.38
14:57	21,000	On	0.58	21,010	On	0.48
14:58	21,000	On	0.35	21,000	On	0.40
14:59	21,010	On	0.35	21,010	On	0.28
15:00	21,010	On	0.62	21,000	On	0.47
15:01	20,990	On	0.42	20,990	On	0.22
15:02	21,000	On	0.49	20,990	On	0.48
15:03	20,990	On	0.37	21,010	On	0.23
15:04	20,990	On	0.51	21,000	On	0.26
15:05	21,020	On	0.48	21,000	On	0.39
15:06	21,000	On	0.47	20,990	On	0.39
15:07	21,010	On	0.43	20,990	On	0.46
15:08	21,000	On	0.47	21,000	On	0.32
15:09	21,000	On	0.37	21,000	On	0.35
15:10	21,010	On	0.49	21,000	On	0.46
15:11	21,010	On	0.45	21,000	On	0.31
15:12	21,000	On	0.50	21,000	On	0.43
15:13	20,990	On	0.49	21,010	On	0.43
15:14	21,000	On	0.38	21,000	On	0.34
15:15	21,000	On	0.46	21,000	On	0.40
15:16	21,010	On	0.38	21,000	On	0.30
15:17	21,000	On	0.50	21,000	On	0.44
15:18	21,000	On	0.39	20,990	On	0.29
15:19	21,000	On	0.42	20,990	On	0.29
15:20	21,000	On	0.42	21,000	On	0.39
15:21	21,000	On	0.56	21,010	On	0.35
15:22	21,000	On	0.46	21,000	On	0.44
15:23	21,010	On	0.47	21,000	On	0.44
15:24	21,000	On	0.46	21,000	On	0.46
15:25	21,010	On	0.50	21,000	On	0.40
15:26	20,990	On	0.48	21,000	On	0.34
15:27	20,990	On	0.35	21,000	On	0.35
15:28	21,010	On	0.44	21,010	On	0.39
15:29	20,990	On	0.49	20,990	On	0.41
15:30	21,010	On	0.42	21,000	On	0.39
Average	21,001	N/A	0.44	21,000	N/A	0.36

* The CEMS DAHS does not account for Daylight Savings Time, therefore, the CEMS data corresponding to the stack test runs is one-hour behind actual time.

Boiler 8 - ESP Report
8/22/2006 (C-3)

Time *	Secondary Power Input 1	Secondary Power Input 2	Secondary Power Input 3	Secondary Power Input 4	Secondary Power Input 5	Secondary Power Input Total
	(kW)	(kW)	(kW)	(kW)	(kW)	(kW)
14:30	0.37	0.00	0.00	22.07	0.00	22.43
14:31	0.25	0.00	0.00	22.15	0.00	22.40
14:32	0.20	0.00	0.00	21.77	0.00	21.97
14:33	0.20	0.00	0.00	21.77	0.00	21.97
14:34	0.20	0.00	0.00	21.20	0.00	21.40
14:35	0.27	0.00	0.00	20.82	0.00	21.08
14:36	0.25	0.00	0.00	20.50	0.00	20.75
14:37	0.20	0.00	0.00	20.25	0.00	20.45
14:38	0.27	0.00	0.00	20.43	0.00	20.70
14:39	0.20	0.00	0.00	20.95	0.00	21.15
14:40	0.17	0.00	0.00	20.32	0.00	20.48
14:41	0.17	0.00	0.00	19.48	0.00	19.65
14:42	0.20	0.00	0.00	20.85	0.00	21.05
14:43	0.18	0.00	0.00	20.63	0.00	20.82
14:44	0.27	0.00	0.00	20.10	0.00	20.37
14:45	0.17	0.00	0.00	20.15	0.00	20.32
14:46	0.28	0.00	0.00	19.80	0.00	20.08
14:47	0.22	0.00	0.00	19.55	0.00	19.77
14:48	0.17	0.00	0.00	19.92	0.00	20.08
14:49	0.20	0.00	0.00	20.18	0.00	20.38
14:50	0.23	0.00	0.00	19.98	0.00	20.22
14:51	0.30	0.00	0.00	18.02	0.00	18.32
14:52	0.23	0.00	0.00	18.73	0.00	18.97
14:53	0.27	0.00	0.00	19.05	0.00	19.32
14:54	0.17	0.00	0.00	20.23	0.00	20.40
14:55	0.18	0.00	0.00	19.85	0.00	20.03
14:56	0.17	0.00	0.00	19.43	0.00	19.60
14:57	0.35	0.00	0.00	21.08	0.00	21.43
14:58	0.20	0.00	0.00	20.52	0.00	20.72
14:59	0.25	0.00	0.00	20.25	0.00	20.50
15:00	0.27	0.00	0.00	20.77	0.00	21.03
15:01	0.10	0.00	0.00	20.60	0.00	20.70
15:02	0.13	0.00	0.00	19.95	0.00	20.08
15:03	0.22	0.00	0.00	20.22	0.00	20.43
15:04	0.27	0.00	0.00	19.95	0.00	20.22
15:05	0.20	0.00	0.00	19.95	0.00	20.15
15:06	0.33	0.00	0.00	20.42	0.00	20.75
15:07	0.20	0.00	0.00	19.68	0.00	19.88
15:08	0.20	0.00	0.00	19.45	0.00	19.65
15:09	0.20	0.00	0.00	17.77	0.00	17.97
15:10	0.20	0.00	0.00	19.77	0.00	19.97
15:11	0.30	0.00	0.00	19.48	0.00	19.78
15:12	0.20	0.00	0.00	19.85	0.00	20.05
15:13	0.28	0.00	0.00	19.82	0.00	20.10
15:14	0.25	0.00	0.00	20.00	0.00	20.25
15:15	0.17	0.00	0.00	20.02	0.00	20.18
15:16	0.20	0.00	0.00	19.50	0.00	19.70
15:17	0.17	0.00	0.00	19.52	0.00	19.68
15:18	0.23	0.00	0.00	19.43	0.00	19.67
15:19	0.25	0.00	0.00	19.55	0.00	19.80
15:20	0.17	0.00	0.00	19.83	0.00	20.00
15:21	0.17	0.00	0.00	19.77	0.00	19.93
15:22	0.22	0.00	0.00	19.87	0.00	20.08
15:23	0.22	0.00	0.00	19.65	0.00	19.87
15:24	0.23	0.00	0.00	19.42	0.00	19.65
15:25	0.23	0.00	0.00	19.48	0.00	19.72
15:26	0.23	0.00	0.00	19.55	0.00	19.78
15:27	0.13	0.00	0.00	19.32	0.00	19.45
15:28	0.35	0.00	0.00	20.05	0.00	20.40
15:29	0.10	0.00	0.00	19.68	0.00	19.78
15:30	0.17	0.00	0.00	19.82	0.00	19.98
Average	0.22	0.00	0.00	20.04	0.00	20.25

* The CEMS DAHS does not account for Daylight Savings Time, therefore, the CEMS data corresponding to the stack test runs is one-hour behind actual time.