



Department of Environmental Protection

Jeb Bush
Governor

Marjory Stoneman Douglas Building
3900 Commonwealth Boulevard
Tallahassee, Florida 32399-3000

David B. Struhs
Secretary

NOTICE OF ADMINISTRATIVELY CORRECTED TITLE V OPERATION PERMIT

In the Matter of a Request for Administrative Correction:


Karen Sheffield, P.E.
General Manager
Tampa Electric Company
P.O. Box 111
Tampa, FL 33601-0111

FINAL Permit No.: 0570040-014-AV
F.J. Gannon Station

Enclosed is an ADMINISTRATIVELY CORRECTED page to the initial Title V operation permit, 0570040-014-AV for the operation of the F.J. Gannon Station located at Port Sutton Road, Tampa, Hillsborough County. This correction is issued pursuant to Rule 62-210.360, Florida Administrative Code and Chapter 403, Florida Statutes (F.S.). This change is made at the applicant's request dated March 19, 2001, to incorporate the operation and maintenance procedures for the pug mill into the Title V permit. This corrective action does not alter the effective dates of the existing permit.

Any party to this order (permit) has the right to seek judicial review of the permit pursuant to Section 120.68, F.S., by the filing of a Notice of Appeal pursuant to Rule 9.110, Florida Rules of Appellate Procedure, with the Clerk of the Department in the Legal Office; and, by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The Notice of Appeal must be filed within 30 (thirty) days from the date this Notice is filed with the Clerk of the Department.

Executed in Tallahassee, Florida.


C. H. Fancy, P.E.
Chief
Bureau of Air Regulation


CERTIFICATE OF SERVICE

The undersigned duly designated deputy agency clerk hereby certifies that this NOTICE OF ADMINISTRATIVELY CORRECTED PERMIT (including the corrected page(s)) was sent by certified mail (*) and copies were mailed by U.S. Mail before the close of business on 4/5/01 to the person(s) listed or as otherwise noted:

Ms. Karen Sheffield, P.E.*
Mr. Jerry Campbell, EPC
Ms. Gracy R. Danois, U.S. EPA, Region 4 (INTERNET E-mail Memorandum)

Clerk Stamp

FILING AND ACKNOWLEDGMENT FILED, on this date, pursuant to §120.52(7), Florida Statutes, with the designated Department Clerk, receipt of which is hereby acknowledged.


(Clerk) 4/5/01
(Date)

"More Protection, Less Process"

Printed on recycled paper.

ADMINISTRATIVE PERMIT CORRECTION
FINAL Permit No.: 0570040-014-AV
F.J. Gannon Station

Condition G.5.B. is hereby changed FROM:

B. The following observations, checks and operations apply to this source and shall be conducted on the schedule specified:

Daily:

1. Baghouse pressure drop - inspect the manometer. Log information. Change filter bags if necessary.
2. Visually inspect baghouse for abnormal emissions.
3. Walk through system listening for proper operation (audible leaks, proper fan and motor functions, bag cleaning etc.)
4. Observe indicators on control panel for abnormal operating conditions.
5. Unplug hopper if necessary.

[Rule 62-296.700(6), F.A.C.]

TO:

B. The following observations, checks and operations apply to this source and shall be conducted on the schedule specified:

Daily:

1. Baghouse pressure drop - inspect the manometer. Log information. Change filter bags if necessary.
2. Visually inspect baghouse for abnormal emissions.
3. Walk through system listening for proper operation (audible leaks, proper fan and motor functions, bag cleaning etc.)
4. Observe indicators on control panel for abnormal operating conditions.
5. Unplug hopper if necessary.

Monthly:

1. Inspect pug mill internals for excessive ash on paddles. If paddles are not free and clean, mill must be washed out.
2. Check pug mill drive belt tension and adjust as needed.
3. Check the pug mill for missing paddles and replace as necessary.
4. Check the pug mill for missing nozzles and replace as necessary.
5. Check pug mill aeration blower discharge pressure.
6. Check pug mill aeration blower oil levels and fill as needed.
7. Check water separators on instrument air lines going to flyash valve controls for proper operations. Make sure these lines are free of water.

[Rule 62-296.700(6), F.A.C.]

SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:
 Karen Sheffield, P.E.
 General Manager
 Tampa Electric Company
 P.O. Box 111
 Tampa, Florida 33601-0111

2. Article Number (Copy from service label)
 7099 3400 0000 1449 5144

PS Form 3811, July 1999

COMPLETE THIS SECTION ON DELIVERY

A. Received by (Please Print Clearly) B. Date of Delivery
 4/19/11

C. Signature
 X *[Signature]* Agent Addressee

D. Is delivery address different from item 1? Yes No
 If YES, enter delivery address below:

3. Service Type
 Certified Mail Express Mail
 Registered Return Receipt for Merchandise
 Insured Mail C.O.D.

4. Restricted Delivery? (Extra Fee) Yes

Domestic Return Receipt 102595-99-M-1789

7099 3400 0000 1449 5144

**U.S. Postal Service
 CERTIFIED MAIL RECEIPT
 - (Domestic Mail Only; No Insurance Coverage Provided)**

Article Sent To:
 Karen Sheffield, P.E.

Postage	\$
Certified Fee	
Return Receipt Fee (Endorsement Required)	
Restricted Delivery Fee (Endorsement Required)	
Total Postage & Fees	\$

Postmark Here

Name (Please Print Clearly) (to be completed by mailer)
 Karen Sheffield, P.E.
 Street, Apt. No., or PO Box No.
 P.O. Box 111
 City, State, ZIP+4
 Tampa, Florida 33601-0111