



State of Florida  
Department of Air and Water Pollution Control

Application For Permit to Operate Air Pollution  
Control Facilities

Applicant  
(Owner or authorized agent)

H. A. Moshell, Jr.  
General Manager of Production

(Name and Title)

Name of Establishment

TAMPA ELECTRIC COMPANY  
F. J. Gannon Station - No. 1 Boiler

(Corporation, Company, Political SD, Firm, etc.)

Mailing Address

P.O. Box 111 Tampa, Florida 33601

Location of Pollution Source

Port Sutton Road Tampa  
(Number and Street) (City)

Hillsborough  
(County)

Nature of Industrial Operation

Generation of Electricity

Permit Applied For Operating:

New Source

Existing Source

Existing Source after modification

Existing Source after Expansion

Existing Source After relocation,  
expansion or reconstruction

Project Engineer:

B. D. Kitching

Name

TAMPA ELECTRIC COMPANY

Firm

P.O. Box 111, Tampa, Florida 33601  
Mailing Address

Signature

6503  
Florida Registration Number

For Department's Use Only

Permit No.

UNIT # 1

Date:

The undersigned owner or authorized representative\* of TAMPA ELECTRIC COMPANY  
is fully aware that the statements made in this form and the attached exhibits and statements constitute the  
application for a Operating Permit from the Florida Department of Air and Water Pollution  
Control and certifies that the information in this application is true, correct and complete to the best of his  
knowledge and belief. Further, the undersigned agrees to comply with the provisions of Chapter 403 Florida  
Statutes and all the rules and regulations of the Department or revisions thereof. He also understands that the  
Permit is non transferable and, if granted a permit, will promptly notify the Department upon sale or legal  
transfer of the permitted establishment.

H. A. Moshell, Jr.

Signature of owner or agent.

H. A. Moshell, Jr.

General Manager of Production

Name and Title

Date: 2/25/71

\*Attach letter of authorization.


**Information Regarding Pollution Sources  
and Proposed Control Facilities**

1. Estimated cost of ~~proposed~~ control facilities \$ 468,290
2. Prepare and attach an 8½" x 11" flow diagram, without revealing trade secrets, identifying the individual operations and/or processes. Indicate where raw materials enter, where solid and liquid waste exit, where gaseous emissions and/or airborne particulates are evolved and where finished products are obtained.  
P. 3-D1
3. Include an 8½" x 11" plot plan showing location of manufacturing processes and location of outlets for airborne emissions. Relate all flows to the flow diagram.  
P. 3-D2
4. Submit an 8½" x 11" plot plan showing the exact location of the establishment and points of discharge in relation to the surrounding area, residences and other permanent structures and roadways.  
P. 3-D3

**I General**

**A. Raw Materials and Chemicals Used.**

Description	Utilization Tons/day, Lbs./day, etc.	Approximate Contaminant Content		Relate to Flow Diagram
		Type	Percent Dry Weight	
NONE				



Ground El. 9'

3-D1

SD - Smoke Detector


FLOW DIAGRAM  
BOILER NO. 1 - CANNON STATION  
TAMPA ELECTRIC CO.

Rev. 2/7/66

KEY PLAN  
Scale 1"=100'

BEST AVAILABLE COPY

403 Highway No. 41 Section Line



PLAN  
SCALE 1"=100'0"

Note:  
 Chain Line Force  
 Disturbance Surface  
 Refer to Drawings for PLOT PLAN 4031 GARRISON TRANSFORMERS and SEE 312-22-104  
 RAILROAD AND HIGHWAY  
 FACILITIES OF TAMPA ELECTRIC CO. by 11-17-53. SUPERSEDES 312-22-104  
 Revised 9-9-55.

**PLOT PLAN**

UNIT NO. 6 - GARRISON STATION  
TAMPA ELECTRIC COMPANY

GEORGE A. WILSON ENGINEERING CORPORATION

DRAWING NO. 10045-FY-1A

NO.	DATE	DESCRIPTION	BY	CHECKED	APPROVED
1		ISSUED FOR J.O. 11109			
2					
3					

3-D2

28

27

F. J. Gannon Station



Black Point

Sutton

ATLANTIC COAST

BAY

SCALE 1:24 000




3-D3

15

Delany  
3000' 00" N  
88  
3087' 00" N  
87

Archie



**B. Fuels**

Type (Be Specific)	Daily Consumption	Gross Maximum Heat Output	Relate to Flow Diagram
Coal	1,770,000 lb/day	2.01 x 10 <sup>10</sup> BTU/day 840 MM Btu/day	(1)

**C. Products**

Description	Average Daily Production (Tons/Day, Lbs/Hr. etc.)
Electricity	2,035 MWH/day = 85 MW

D. Normal operation: Hours/Day 24 Day and Week 7 days/week

If operation or process is seasonal, describe: \_\_\_\_\_

**II Identification of Air Contaminants**

Compounds of:

- |          |                                     |              |                                     |  |
|----------|-------------------------------------|--------------|-------------------------------------|--|
| Chlorine | <input type="checkbox"/>            | Also —       |                                     |  |
| Flourine | <input type="checkbox"/>            | Hydrocarbons | <input type="checkbox"/>            | Acid Mists <input type="checkbox"/>    |
| Nitrogen | <input type="checkbox"/>            | Smoke        | <input type="checkbox"/>            | Odors <input type="checkbox"/>         |
| Sulfur   | <input checked="" type="checkbox"/> | Fly Ash      | <input checked="" type="checkbox"/> | Radioisotopes <input type="checkbox"/> |
|          |                                     | Dusts        | <input type="checkbox"/>            | Other _____ <input type="checkbox"/>   |

Specific Compounds SO<sub>2</sub>, SO<sub>3</sub>

**III Air Pollution Control Devices**

Contaminant	Control Device	Relate to Flow Diagram	See Note 1 Operating Efficiency	Conditions (Particle Size Range, Temp. etc.)
Fly Ash	Electrostatic Precipitator	(2)	91.3%	29.9ft/sec 309 <sup>0</sup> F
SO <sub>x</sub>	None			

Provide a brief description of the control device or treatment system. Attach separate sheets giving details regarding principle of operation, manufacturer, model, size, type and capacity of control/treatment device and the basis for calculating its efficiency. Show any bypasses of the control device and specify when such bypasses are to be used and under what conditions.

This piece of equipment is designed to remove solid particulate matter from the flue gases leaving the boiler.

A cutaway view of a typical electrostatic precipitator is shown on Page 5-D1. Gas flow through the precipitator is between the parallel plates designated as "collecting surfaces".

The operating principle and basis for calculating the efficiency are shown on page 5-D2 and 5-D3 respectively. Some additional information regarding the precipitator for this unit follows.


Manufacturer - Research-Cottrell

Design air flow - 377,000 CFM

Guaranteed removal efficiency - 90.0%  
at design conditions

There are no by-passes of the precipitator.





Discharge electrode rappers—choice of pneumatic or electrical in a weather enclosure; separate control system allows full flexibility of intensity and cycling.

High Voltage Power Supply Transformer—full range KVA, depending on size and specified efficiency of precipitator

Rectifier—silicon type, oil immersed; connected by bridge circuit; full or half wave DC output

Collecting surface rappers—choice of pneumatic or electrical in a weather enclosure, with flexible cycling and intensity controls.

Insulator compartments—house insulators and electrode rappers; fabricated of mild steel; can be equipped with heaters to minimize condensation.

Casing—column and beam construction with shell fabricated of mild steel.

Collecting surfaces—flat plate design with roll-formed pockets improves clean-plate sparking voltages, provides less duct turbulence for maximum efficiency, improves rappability.

Discharge electrodes—coppered, stainless or mild steel; carried on steel frames; supported on insulators; tensioned by cast iron weights

Hoppers—pyramidal, fabricated of mild steel; baffled to prevent gas sneak-by; can be equipped with vibrators

# GENERAL SPECIFICATIONS

5-D1

## OPERATING PRINCIPLE OF ELECTROSTATIC PRECIPITATOR

Particles suspended in a gaseous medium enter the precipitator, passing through ionized zones around high voltage electrode wires. These high voltage electrodes, through a corona effect, emit negatively charged ions into the gases surrounding the electrode.

The negatively charged gas field around each electrode wire ionizes passing particulates, causing the particulates to migrate to the electrode of opposite polarity, the collector plates.

The charged particulates gather on the grounded collector plates and lose their charge. Rappers shake loose the agglomerate which fall into the collection hoppers for removal.

## BASIS FOR CALCULATING PRECIPITATOR EFFICIENCY

A method similar to ASME Power Test Code - 27 is used to determine dust loadings. Very briefly the method is as follows:

1. Unit is base loaded for 2 to 4 hours (steady load).
2. Velocity profile of the inlet and outlet ducts is determined using a pitot tube, draft gauge, and thermocouple.
3. Inlet and outlet ducts are sampled simultaneously and isokinetically using alundum thimbles as the filtering medium.
4. Amount of dust per unit time is obtained and efficiency is arrived at by using the following formula:

$$\frac{\text{Inlet dust concentration} - \text{Outlet dust concentration}}{\text{Inlet dust concentration}} \times 100 = \text{efficiency}$$



### V. Discharged Emmissions to Atmosphere

#### A. Discharge Points and Design Conditions

Discharge Point Description	Relate to Flow Diagram	Height above Ground (ft.)	Cross Sect. Area (sq. ft.)	Note 2		Temp. of Discharge (°F)
				Hrs./Day	days/Year	
Stack	(3)	200	156	23.6	350	309

#### B. Tabulation of Discharged Contaminants

		Note 3 Total Contaminants Discharged					
Discharge Point - Relate to Flow Diagram	Flow Rate at Std. Cond. (cfm)	Particulates		Other Contaminants <del>(CO, SO2, NOx, etc.)</del>			
		Gr/ft3 (Std. Cond.)	lbs./Day	Gr/ft3 (Std. Cond.)	lbs/Day	Gr/ft3 (Std. Cond.)	lbs/Day
Avg. Cond. Stack - (3)	191,000	0.154	5,960	3.82	132,200		
Peak Cond. Stack - (3)	253,000	0.154	-	3.82	-		
Totals							

NOTE: Standard conditions used are 20° C and 1 atm.

## VI. Treatment and Disposal of Liquid and Solid Waste

1. Identify the contaminants which will be discharged as liquid or solid wastes.  
Bottom slag (ash)
2. Describe the treatment and disposal of liquid and solid wastes. Indicate the concentrations and volume of individual contaminants in treated wastes before disposal.

There is 204,040 lb/day of slag produced.

The bottom slag is tapped from the bottom of the furnace as a molten liquid. It falls into a tank of water where it rapidly cools and shatters into small pieces (approximately 1/4" in diameter). This water - solid mixture is pumped to a dewatering bin where the water is drained off.

The slag is then carried off by truck to a stockpiling area on the power plant site.

The solid slag is hard, glassy, insoluble in water, and chemically inert. A typical mineral analysis of slag is as follows:

SiO<sub>2</sub> - 41.06%, Fe<sub>2</sub>O<sub>3</sub> - 27.46%, Al<sub>2</sub>O<sub>3</sub> - 17.00%, CaO - 5.47%, SO<sub>3</sub> - 4.91%,  
K<sub>2</sub>O - 1.88%, TiO<sub>2</sub> - 0.83%, MgO - 0.67%, P<sub>2</sub>O<sub>5</sub> - 0.37%, Na<sub>2</sub>O - 0.25%,  
Undetermined - 0.10%.

**NOTE 1:** The operating efficiency shown for the electrostatic precipitator is the efficiency obtained by tests which were conducted in April, 1958. These tests were conducted at the designed maximum continuous load on the boiler. Tests are scheduled and due to be completed by December 31, 1971, which will reflect current efficiencies at the average operating condition. This information will be forwarded to the department as soon as the tests have been completed.

The test method to be used will be similar to the method adopted by the Department of Air and Water Pollution Control for the sampling of solid particulate matter from power plant stack gases.

**NOTE 2:** The hrs/day figure shown was arrived at by dividing the hours per year that the boiler was in operation for the year 1969 by the number of days in 1969 that the boiler operated.

**NOTE 3:** The grain loading shown for the average operating condition and the peak emission condition is the grain loading that was obtained by test at the design maximum continuous load on the boiler. This means that, theoretically, the grain loading for the average operating condition should be less than that shown and the grain loading for the peak emission condition could be greater than that shown. Tests are scheduled to obtain what the values actually are.