



STATE OF FLORIDA
DEPARTMENT OF POLLUTION CONTROL

POST OFFICE BOX 9295
500 EAST CENTRAL AVENUE
WINTER HAVEN, FLORIDA 33880

PETER P. BALJET
EXECUTIVE DIRECTOR

W.D. FREDERICK, JR.
CHAIRMAN

June 12, 1975
Hillsborough County - AP

Mr. R. D. Welch
Tampa Electric Company
P. O. Box 111
Tampa, Florida 33601

Re: Permit AO29-2092
AO29-2093
AO29-2191 ✓

Dear Mr. Welch:

The Department of Pollution Control Regulations require that visible emissions meet compliance of 20 percent opacity by July 1, 1975. (Chapter 17-2.04(1))

- 1) Visible Emissions-No person shall cause, let, permit, suffer or allow to be discharged into the atmosphere any air pollutants from:
 - a) Existing Sources, until July 1, 1975, the density of which is equal to or greater than that designated as Number 2 on the Ringelmann Chart or the opacity of which is equal to or greater than 40 percent.
 - b) New Sources, and after July 1, 1975, existing sources, the density of which is equal to or greater than that designated as Number 1 on the Ringelmann Chart or the opacity of which is equal to or greater than 20 percent.
 - c) This subsection 17-2.04(1) does not apply to emissions emitted in accordance with specified emission limiting standards or in accordance with the process weight table (Table I) provided in this chapter.
 - d) If the presence of uncombined water is the only reason for failure to meet visible emission standards given in this section such failure shall not be a violation of this rule.

This letter is to notify you that visible emission test for each point source shall be submitted to the DPC West Central office in Winter Haven, by a certified observer no later than July 1, 1975.

If you have conducted a visible emission test within the last 6 months, a test need not be performed.

If you have any questions, please contact this office.

Sincerely,

J. H. Kerns, P.E.
Regional Engineer
West Central Region

JHK/JLT/pm

Joan P. Middlemas
BOARD MEMBER

Alice C. Wainwright
BOARD MEMBER

Mark D. Hollis
BOARD MEMBER

Y.E. Hall
BOARD MEMBER