

TO: Teco Gannon Unit No. 1 file  
THRU: W.C. Thomas *WCT*  
THRU: J.W. Estler  
FROM: T. John *TJ*  
DATE: January 26, 1987  
SUBJECT: Recommend permit No. AO29-125315 be issued to  
TECO, Gannon Unit No. 1.


Based on the information received and with comments from the local program, I recommend that permit No. AO29-125315 be issued to TECO, Gannon Unit No. 1.

The source, located at Port Sutton Road, Tampa, is a 1257 MMBTU coal fired steam generator. Particulate emissions are controlled by a Combustion Engineering, Inc. Electrostatic Precipitator.

HILLSBOROUGH COUNTY  
ENVIRONMENTAL PROTECTION

COMMISSION

RODNEY COLSON  
RON GLICKMAN  
PAM IORIO  
RUBIN E. PADGETT  
JAN KAMINIS PLATT  
JAMES D. SELVEY  
PICKENS C. TALLEY II



ROGER P. STEWART  
DIRECTOR

1900 - 9th AVE  
TAMPA, FLORIDA 33605

TELEPHONE (813) 272-5960

D. E. R.

JAN 13 1987

*Gannon*

MEMORANDUM

SOUTH WEST DISTRICT  
TAMPA

Date January 7, 1987

To Tom John thru Bill Thomas

From Victor San Agustin thru Jerry Campbell *VSA* *Jc*

Subject: Revision to My Draft of December 17, 1986

The purpose of this memo is to recommend that certain portions of my December 17 draft be revised. These revisions were requested by TECO and we do not have any objections to any of the comments. They are:

Specific Condition 4:

From - Two copies of test data shall be submitted to both the Hillsborough County Environmental Protection Commission and Florida Department of Environmental Regulation within 45 days of such testing.

To - One copy of test data shall be submitted to both the Hillsborough County Environmental Protection Commission and Florida Department of Environmental Regulation within 45 days of such testing.

Specific Condition 6:

This condition should be deleted. Although I feel the condition is useful for tracking purposes, TECO does not want it in the permit.

Specific Condition 8, Last Sentence:

From - Emission reports shall be submitted to.....

To - An Emission report shall be submitted to.....

Specific Condition 9.C. under Monthly:

From - Inspect insulator compartment heaters/blowers. Service as needed.  
Observe operation of all rappers and vibrators.  
Check rapper and transformer/rectifier controls.

To - Inspect insulator compartment heaters/blowers. Service as needed.  
Observation of operation of all rapper and transformer/rectifier controls.


If you have any questions, Please feel free to call me.

VSA/ch

HILLSBOROUGH COUNTY  
ENVIRONMENTAL PROTECTION

COMMISSION

RODNEY COLSON  
RON GLICKMAN  
PAM IORIO  
RUBIN E. PADGETT  
JAN KAMINIS PLATT  
JAMES D. SELVEY  
PICKENS C. TALLEY II



ROGER P. STEWART  
DIRECTOR

1900 - 9th AVE  
TAMPA, FLORIDA 33605

TELEPHONE (813) 272-5960

MEMORANDUM

Date January 7, -1987

To Tom John thru Bill Thomas

From Victor San Agustin<sup>VSA</sup> thru Jerry Campbell<sup>Jc</sup>

Subject: Revision to My Draft of December 17, 1986

The purpose of this memo is to recommend that certain portions of my December 17 draft be revised. These revisions were requested by TECO and we do not have any objections to any of the comments. They are:

Specific Condition 4:

From - Two copies of test data shall be submitted to both the Hillsborough County Environmental Protection Commission and Florida Department of Environmental Regulation within 45 days of such testing.

To - One copy of test data shall be submitted to both the Hillsborough County Environmental Protection Commission and Florida Department of Environmental Regulation within 45 days of such testing.

Specific Condition 6:

This condition should be deleted. Although I feel the condition is useful for tracking purposes, TECO does not want it in the permit.

Specific Condition 8, Last Sentence:

From - Emission reports shall be submitted to.....

To - An Emission report shall be submitted to.....

Specific Condition 9.C. under Monthly:

From - Inspect insulator compartment heaters/blowers. Service as needed.

Observe operation of all rappers and vibrators.  
Check rapper and transformer/rectifier controls.

To - Inspect insulator compartment heaters/blowers. Service as needed.

Observation of operation of all rapper and transformer/rectifier controls.

If you have any questions, Please feel free to call me.

VSA/ch