

Florida Department of  
Environmental Protection

Memorandum

---

To: Joe Kahn, Division Director  
Through: Trina Vielhauer, Bureau of Air Regulation  
From: Jeff Koerner, New Source Review Section  
Date: July 30, 2010  
Subject: Project No. 0570040-029-AV  
Final Title V Air Permit Revision  
Tampa Electric Company, H.L. Culbreath Bayside Power Station  
Miscellaneous Revisions, Excess Emissions

The H.L. Culbreath Bayside Power Plant is an existing electrical generating plant located in Hillsborough County at 3602 Port Sutton Road in Tampa, Florida. This project was processed concurrently with and incorporates final Permit No. 0570040-028-AC, which revises: Permit No. 0570040-019-AC for existing combined cycle Units 1 and 2 to clarify excess emissions during warm and cold steam turbine startups; and Permit No. 0570040-026-AC for the new simple cycle peaking Units 3 through 6 to address the exclusion of carbon monoxide emissions during combustion turbine tuning. There were no comments on the draft/proposed permit and no petitions were filed.

I recommend your approval of the attached Final Permit package.

Attachments

TLV/jfk

**NOTICE OF FINAL PERMIT**

*In the Matter of an  
Application for Permit by:*

Tampa Electric Company  
P.O. Box 111  
Tampa, Florida 33601-0111

Permit No. 0570040-029-AV  
Final Title V Air Permit Revision  
H.L. Culbreath Bayside Power Station  
Hillsborough County

*Authorized Representative:*  
Frank Busot, Director  
H.L. Culbreath Bayside Power Station

Enclosed is the final permit package to revise Title V air operation Permit No. 0570040-027-AV for the H.L. Culbreath Bayside Power Station. The existing facility is located in Hillsborough County at 3602 Port Sutton Road in Tampa, Florida. This permit is issued pursuant to Chapter 403, Florida Statutes.

Any party to this order has the right to seek judicial review of it under Section 120.68 of the Florida Statutes by filing a notice of appeal under Rule 9.110 of the Florida Rules of Appellate Procedure with the clerk of the Department of Environmental Protection in the Office of General Counsel (Mail Station #35, 3900 Commonwealth Boulevard, Tallahassee, Florida, 32399-3000) and by filing a copy of the notice of appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The notice must be filed within 30 days after this order is filed with the clerk of the Department.

Executed in Tallahassee, Florida.



Trina Vielhauer, Chief  
Bureau of Air Regulation

TLV/jfk


**CERTIFICATE OF SERVICE**

The undersigned duly designated deputy agency clerk hereby certifies that this Notice of Final Permit (including the Final Permit and Final Determination), or a link to these documents available electronically on a publicly accessible server, was sent by electronic mail with received receipt requested to the persons listed below:

- Mr. Frank Busot, TECO, Director, Bayside Power Station (flbusot@tecoenergy.com)
- Mr. Byron Burrows, TECO, Manager-Air Programs, P.E. (btburrows@tecoenergy.com)
- Ms. Laurie Pence, TECO, Environmental Specialist (lapence@tecoenergy.com)
- Ms. Cindy Zhang-Torres, DEP SWD Office (cindy.zhang-torres@dep.state.fl.us)
- Ms. Dianna Lee, Hillsborough County EPC (lee@epchc.org)
- Mr. Mike Halpin, DEP Siting Office (mike.halpin@dep.state.fl.us)
- Ms. Katy Forney, U.S. EPA Region 4 (forney.kathleen@epamail.epa.gov)
- Ms. Ana Oquendo, U.S. EPA Region 4 (oquendo.ana@epamail.epa.gov)
- Ms. Barbara Friday, DEP BAR for posting with U.S. EPA Region 4 (barbara.friday@dep.state.fl.us)
- Ms. Victoria Gibson, DEP BAR Reading File (victoria.gibson@dep.state.fl.us)

Clerk Stamp

**FILING AND ACKNOWLEDGMENT FILED**, on this date, pursuant to Section 120.52(7), Florida Statutes, with the designated agency clerk, receipt of which is hereby acknowledged.

 8/4/10  
(Clerk) (Date)

## FINAL DETERMINATION

---

### PERMITTEE

Tampa Electric Company  
P.O. Box 111  
Tampa, Florida 33601-0111

### PERMITTING AUTHORITY

Florida Department of Environmental Protection (Department)  
Division of Air Resource Management  
Bureau of Air Regulation  
2600 Blair Stone Road, MS #5505  
Tallahassee, Florida 32399-2400

### PROJECT

Permit No. 0570040-029-AV  
Final Title V Air Permit Revision  
H.L. Culbreath Bayside Power Station

This project was processed concurrently with and incorporates final Permit No. 0570040-028-AC, which revises: Permit No. 0570040-019-AC for existing combined cycle Units 1 and 2 to clarify excess emissions during warm and cold steam turbine startups; and Permit No. 0570040-026-AC for the new simple cycle peaking Units 3 through 6 to address the exclusion of carbon monoxide emissions during combustion turbine tuning.

### NOTICE AND PUBLICATION

The Department distributed a draft/proposed permit package on June 9, 2010. The applicant published the Public Notice in the South Shore News and Tribune (affiliated with The Tampa Tribune) on June 16, 2010. The Department received the proof of publication on June 18, 2010. No requests for administrative hearings or requests for extensions of time to file a petition for administrative hearing were received.

### COMMENTS

EPA's 45-day review period ended July 31, 2010. No comments on the proposed permit were received from the EPA Region 4 Office.

### CONCLUSION

The final action of the Department is to issue the permit with no changes.

## STATEMENT OF BASIS

---

### **Title V Air Operation Permit Revision Permit No. 0570040-029-AV (Revises Permit No. 0570040-027-AV)**

#### **APPLICANT**

The applicant for this project is Tampa Electric Company. The applicant's responsible official and mailing address are: Frank Busot, Director, Bayside Power Station, Tampa Electric Company, P.O. Box 111, Tampa, Florida 33601-0111.

#### **FACILITY DESCRIPTION**

The applicant operates the H.L. Culbreath Bayside Power Station, which is located at 3602 Port Sutton Road, Tampa, Florida, 33619. The existing facility is an electric power plant categorized as Standard Industrial Classification No. 4911. The existing plant consists of the following emissions units.

- Unit 1 (EU 020 – 022) is a “3-on-1” combined cycle combustion turbine system consisting of three General Electric Model PG7241(FA) combustion turbines (169 megawatt (MW) each) and one common steam-electrical generator (239 MW) with a combined nominal generating capacity of 746 MW. Unit 2 (EU 023 – 026) is a “4-on-1” combined cycle combustion turbine system consisting of four General Electric Model PG7241(FA) combustion turbines (169 MW each) and one common steam-electrical generator (414 MW) with a combined nominal generating capacity of 1090 MW. Each combustion turbine set includes an automated gas turbine control system, an inlet air filtration system, an evaporative inlet air cooling system, an unfired heat recovery steam generator (HRSG), a single exhaust stack, electric fuel heaters, cooling towers and associated support equipment. Each combustion turbine fires natural gas and is equipped with dry low-NO<sub>x</sub> (DLN) combustion technology and a selective catalytic reduction (SCR) system to reduce nitrogen oxides (NO<sub>x</sub>) emissions. Emissions of CO and NO<sub>x</sub> are monitored with continuous emissions monitoring systems (CEMS).
- Units 3 through 6 (EU 031 - 038) consist of four Pratt & Whitney Model No. FT8-3 SwiftPac® aero-derivative combustion turbine-electrical generator sets to operate in simple cycle mode. For each SwiftPac®, two combustion turbines are coupled to one common electrical generator set having a total nominal gross generation capacity of 62 MW. Each unit fires natural gas, controls NO<sub>x</sub> emissions with water injection and carbon monoxide (CO) emissions with catalytic oxidation. Emissions of CO and NO<sub>x</sub> are monitored with continuous emissions monitoring systems (CEMS).
- Diesel engines are used to power generators and a fire pump (EU-039).

Also included in this permit are miscellaneous unregulated and insignificant activities.

#### **PRIMARY REGULATORY REQUIREMENTS**

Title III: The facility is not identified as a major source of hazardous air pollutants (HAP).

Title IV: The combustion turbines (EU-020 - EU-026 and EU-031 - EU-038) are subject to Phase II of the acid rain provisions of the Clean Air Act.

Title V: The facility is a Title V major source of air pollution in accordance with Chapter 62-213, Florida Administrative Code (F.A.C.).

PSD: The facility is a major stationary source of air pollution in accordance with Rule 62-212.400, F.A.C. for the Prevention of Significant Deterioration (PSD) of Air Quality.

NSPS: The facility operates units subject to applicable provisions in the following New Source Performance Standards (NSPS) in Part 60 of Title 40, Code of Federal Regulations (CFR):

- Subpart A, General Provisions (EU-020 - EU-026 and EU-039);

## STATEMENT OF BASIS

---

- Subpart GG, Stationary Gas Turbines (EU-020 - EU-026);
- Subpart IIII, Stationary Compression Ignition Internal Combustion Engines (EU-039); and
- NSPS Subpart KKKK, Combustion Turbines (EU-031 - EU-038).

NESHAP: The facility operates units subject to applicable provisions in the following National Emissions Standards for Hazardous Air Pollutants (NESHAP) in 40 CFR 63:

- Subpart A, General Provisions (EU-039); and
- Subpart ZZZZ, Stationary Reciprocating Internal Combustion Engines (EU-039).

CAIR: The combustion turbines (EU-020 - EU-026 and EU-031 - EU-038) are subject to the applicable requirements of the Clean Air Interstate Rule (CAIR) in accordance with Rule 62-296.470, F.A.C.

CAM: Each combined cycle combustion turbine (EU-020 - EU-026) is equipped with an SCR system to control NO<sub>x</sub> emissions; however, compliance is continuously demonstrated by CEMS. Each simple cycle combustion turbine (EU-031 - EU-038) is equipped with an SCR system to control NO<sub>x</sub> emissions; however, compliance is continuously demonstrated by CEMS. There are no other add on control equipment. Therefore, a Compliance Assurance Monitoring (CAM) Plan is not required for any of the emissions units.

### PROJECT DESCRIPTION

The purpose of this permitting project is to revise Title V air operation Permit No. 0570040-027-AV to incorporate newly constructed Units 3 through 6 (EU-031 - 038), which are the four Pratt & Whitney Model No. FT8-3 SwiftPac® aeroderivative simple cycle combustion turbine-electrical generator sets. The project also incorporates concurrent air construction permit revision No. 0570040-028-AC (PSD-FL-301D), which revises Permit No. 0570040-019-AC (PSD-FL-301C) for the combined cycle units (EU-020 - 026) and Permit No. 0570040-026-AC for the simple cycle units (EU-031 - EU-038). The changes are primarily related to excess emissions conditions.

### PROCESSING SCHEDULE AND RELATED DOCUMENTS

|            |   |
|------------|---|
| 09/30/2009 | Received application to revise the Title V air operation permit;                    |
| 12/15/2009 | Received additional information related to excess emissions;                        |
| 01/21/2010 | Received revised application for a concurrent air construction permit revision; and |
| 03/30/2010 | Received updated and corrected Acid Rain and CAIR, complete.                        |

### CONCLUSION

This project revises Title V Air Operation Permit No. 0570040-027-AV, which was issued on December 07, 2009. This Title V air operation permit revision is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Chapters 62-4, 62-210, 62-213 and 62-214, F.A.C. In accordance with the terms and conditions of this permit, the above named permittee is hereby authorized to operate the facility as shown on the application and approved drawings, plans, and other documents, on file with the permitting authority.

Tampa Electric Company  
H.L. Culbreath Bayside Power Station  
Facility ID No. 0570040  
Hillsborough County

**Title V Air Operation Permit Revision**

**Permit No. 0570040-029-AV**

(Revision of Title V Air Operation Permit No. 0570040-027-AV)



**Permitting Authority:**

State of Florida  
Department of Environmental Protection  
Division of Air Resource Management  
Bureau of Air Regulation  
Title V Section  
2600 Blair Stone Road  
Mail Station #5505  
Tallahassee, Florida 32399-2400  
Telephone: (850) 488-0114  
Fax: (850) 921-9533

**Compliance Authority:**

Environmental Protection Commission of Hillsborough County  
Air Management  
3629 Queen Palm Drive  
Tampa, Florida 33619  
Telephone: 813/627-2600  
Fax: 813/627-2660

**Title V Air Operation Permit Revision  
Permit No. 0570040-029-AV**

**Table of Contents**

| <b><u>Section</u></b>  | <b><u>Page Number</u></b> |
|--|---------------------------|
| I. Facility Information  |                           |
| A. Facility Description .....  | 2                         |
| B. Summary of Emissions Units .....  | 2                         |
| C. Applicable Regulations .....  | 3                         |
| II. Facility-wide Conditions .....   | 5                         |
| III. Emissions Units and Conditions  |                           |
| A. Emission Units 020 through 026, Combined Cycle Units 1 and 2 .....                          | 8                         |
| B. Emission Unit 008, Fuel Yard .....  | 16                        |
| C. Emission Units 039, Diesel Generator and Fire Pump Engines .....                            | 19                        |
| D. Emission Units 031 through 038, Simple Cycle Units 3 through 6 .....                        | 20                        |
| IV. Acid Rain Part .....   | 27                        |
| V. Clean Air Interstate Rule Part .....  | 36                        |
| VI. Appendices   |                           |
| Appendix A. Abbreviations, Acronyms, Citations and Identification Numbers                      |                           |
| Appendix BD. Final BACT Determination and Emissions Standards (Units 1 and 2)                  |                           |
| Appendix CD. Consent Decree (U.S. EPA vs. TECO)  |                           |
| Appendix CFJ. Consent Final Judgment (DEP vs. TECO)  |                           |
| Appendix CM. Standard Continuous Monitoring Requirements                                       |                           |
| Appendix CR. Common Regulatory Requirements  |                           |
| Appendix GG: NSPS Subpart GG for Stationary Gas Turbines                                       |                           |
| Appendix I. Insignificant Activities   |                           |
| Appendix III. NSPS Subpart III for Stationary Compression Ignition Internal Combustion Engines |                           |
| Appendix KKKK. NSPS Subpart KKKK for Stationary Combustion Turbines after February 18, 2005    |                           |
| Appendix NE. NESHAP Subpart A for General Provisions   |                           |
| Appendix NS. NSPS Subpart A for General Provisions   |                           |
| Appendix RR. Facility-Wide Reporting Requirements  |                           |
| Appendix TR. Facility-Wide Testing Requirements  |                           |
| Appendix TV. Title V General Conditions  |                           |
| Appendix U. Unregulated Activities   |                           |
| Appendix ZZZZ. NESHAP Subpart ZZZZ for Reciprocating Internal Combustion Engines               |                           |
| Referenced Attachments .....   | At End                    |
| Table 1-1, Summary of Air Pollutant Standards and Terms  |                           |
| Table 2-1, Compliance Requirements   |                           |



# Florida Department of Environmental Protection

Bob Martinez Center  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

Charlie Crist  
Governor

Jeff Kottkamp  
Lt. Governor

Michael W. Sole  
Secretary

**PERMITTEE:**

Tampa Electric Company  
P.O. Box 111  
Tampa, Florida 33601-0111

Permit No. 0570040-029-AV  
H.L. Culbreath Bayside Power Station  
Facility ID No. 0570040  
Title V Air Operation Permit Revision

The purpose of this permit is to revise Title V Air Operation Permit No. 0570040-027-AV for the above referenced facility. The existing H.L. Culbreath Bayside Power Station is located at 3602 Port Sutton Road, Tampa, in Hillsborough County. UTM Coordinates are Zone 17, 360.1 km East and 3087.5 km North.

The Title V air operation permit is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, 62-213 and 62-214. The above named permittee is hereby authorized to operate the facility in accordance with the terms and conditions of this permit.

Effective Date: August 2, 2010  
Renewal Application Due Date: May 20, 2014  
Expiration Date: December 31, 2014



---

Joseph Kahn, Director  
Division of Air Resource Management

JK/tlv/jfk



**SECTION I. FACILITY INFORMATION.**

**Subsection A. Facility Description.**

The H. L. Culbreath Bayside Power Station is an electric power plant consisting of six primary electrical generating units. Unit 1 (EU 020 – 022) is a “3-on-1” combined cycle gas turbine system with a nominal generating capacity of 746 MW, which consists of three gas turbines (169 megawatt (MW) each) and one steam-electrical generator (239 MW). Unit 2 (EU 023 – 026) is a “4-on-1” combined cycle gas turbine system with a nominal generating capacity of 1090 MW, which consists of four gas turbines (169 MW each) and one steam-electrical generator (414 MW). These units fire natural gas as the exclusive fuel and employ selective catalytic reduction (SCR) to reduce emissions of nitrogen oxides (NO<sub>x</sub>). Emissions of carbon monoxide (CO) and NO<sub>x</sub> are monitored with continuous emissions monitoring systems (CEMS).

Units 3 through 6 (EU 031 - 038) consist of four Pratt & Whitney Model No. FT8-3 SwiftPac® aero-derivative simple cycle combustion turbine-electrical generator sets to operate in simple cycle mode. For each SwiftPac®, two combustion turbines are coupled to one common electrical generator set having a total nominal gross generation capacity of 62 MW. Each unit fires natural gas, controls NO<sub>x</sub> emissions with water injection and CO emissions with catalytic oxidation. Emissions of CO and NO<sub>x</sub> are monitored with continuous emissions monitoring systems (CEMS).

Based on the application to renew the Title V air operation permit received on May 20, 2009:

Title III: The facility is not identified as a major source of hazardous air pollutants (HAP).

Title IV: The gas turbines are subject to Phase II of the acid rain provisions of the Clean Air Act.

Title V: The facility is a Title V major source of air pollution in accordance with Chapter 62-213, Florida Administrative Code (F.A.C.).

PSD: The facility is a major stationary source of air pollution in accordance with Rule 62-212.400, F.A.C. for the Prevention of Significant Deterioration (PSD) of Air Quality.

NESHAP: The facility operates units subject to the National Emissions Standards for Hazardous Air Pollutants (NESHAP) in Part 63, Title 40, Code of Federal Regulations (CFR).

NSPS: The facility operates units subject to the New Source Performance Standards (NSPS) in Part 60, Title 40, CFR.

CAIR: The combustion turbines (EU-020 - EU-026 and EU-031 - EU-038) are subject to the applicable requirements of the Clean Air Interstate Rule (CAIR) in accordance with Rule 62-296.470, F.A.C.

**Subsection B. Summary of Emissions Units.**

| EU No.  | Brief Description                      |
|---|--|
| <i>Regulated Emissions Units</i>  |  |
| 008   | F. J. Gannon Station Fuel Yard         |
| 039   | Diesel Generator and Fire Pump Engines |
| Bayside Unit 1 - Combined Cycle Unit with Three Gas Turbines and One Steam-Electrical Generator (746 MW, total) |  |
| 020   | CT-1A – Combined Cycle Gas Turbine     |
| 021   | CT-1B – Combined Cycle Gas Turbine     |
| 022   | CT-1C – Combined Cycle Gas Turbine     |
| Bayside Unit 2 - Combined Cycle Unit with Four Gas Turbines and One Steam-Electrical Generator (1090 MW, total) |  |
| 023   | CT-2A – Combined Cycle Gas Turbine     |
| 024   | CT-2B – Combined Cycle Gas Turbine     |
| 025   | CT-2C – Combined Cycle Gas Turbine     |

**SECTION I. FACILITY INFORMATION.**

| <b>EU No.</b>  | <b>Brief Description</b>                  |
|--|---|
| 026  | CT-2D – Combined Cycle Gas Turbine        |
| Bayside Unit 3 – Simple Cycle Peaking Unit with Two Combustion Turbines and One Electrical Generator Set (62 MW) |   |
| 031  | Unit 3A - Simple Cycle Combustion Turbine |
| 032  | Unit 3B - Simple Cycle Combustion Turbine |
| Bayside Unit 4 – Simple Cycle Peaking Unit with Two Combustion Turbines and One Electrical Generator Set (62 MW) |   |
| 033  | Unit 4A - Simple Cycle Combustion Turbine |
| 034  | Unit 4B - Simple Cycle Combustion Turbine |
| Bayside Unit 5 – Simple Cycle Peaking Unit with Two Combustion Turbines and One Electrical Generator Set (62 MW) |   |
| 035  | Unit 5A - Simple Cycle Combustion Turbine |
| 036  | Unit 5B - Simple Cycle Combustion Turbine |
| Bayside Unit 6 – Simple Cycle Peaking Unit with Two Combustion Turbines and One Electrical Generator Set (62 MW) |   |
| 037  | Unit 6A - Simple Cycle Combustion Turbine |
| 038  | Unit 6B - Simple Cycle Combustion Turbine |

The terms “gas turbine” and “combustion turbine” are interchangeable. The combined cycle units are referred to as “gas turbines” pursuant to NSPS Subpart GG and the simple cycle peaking units are referred to as “combustion turbines” pursuant to NSPS Subpart KKKK. Other than the fuel yard identified above, the F. J. Gannon Units 1 - 6 and other emissions units associated with the coal-fired boilers have been permanently shut down, dismantled and removed from the site (EU-001 through EU-007 and EU-009 through EU-019). This facility also includes other miscellaneous insignificant emissions units and activities. Please reference the permit number, facility identification number, and the corresponding emissions unit identification numbers on all correspondence, test submittals, applications, etc.

**Subsection C. Applicable Regulations.**

Based on the Title V Air Operation Renewal application received May 20, 2009, this facility is not a major source of hazardous air pollutants (HAPs). A summary of applicable regulations is shown in the following table.

| <b>Regulation</b>   | <b>EU Nos.</b>        |
|---|-----------------------|
| <i>Federal Rule Citations</i>   |                       |
| 40 CFR 60, Subpart A: NSPS General Provisions   | 020-026, 031-038, 039 |
| 40 CFR 60, Subpart GG: Standards of Performance for Stationary Gas Turbines               | 020-026               |
| 40 CFR 60, Subpart IIII: NSPS Stationary Compression Ignition Internal Combustion Engines | 039                   |
| 40 CFR 60, Subpart KKKK: NSPS Stationary Combustion Turbines after February 18, 2005      | 031-038               |
| 40 CFR 63, Subpart A: NESHAP General Provisions   | 039                   |
| 40 CFR 63, Subpart ZZZZ: NESHAP Reciprocating Internal Combustion Engines                 | 039                   |
| 40 CFR 72: Acid Rain Program Permit Regulations   | 020-026               |
| 40 CFR 75: Acid Rain Program Continuous Emissions Monitoring                              | 020-026               |
| 40 CFR 77: Acid Rain Program Excess Emissions   | 020-026               |
| 40 CFR 78: Acid Rain Program Appeal Procedures  | 020-026               |
| 40 CFR 96: Clean Air Interstate Rule  | 020-026               |
| <i>State Rule Citations</i>   |                       |

**SECTION I. FACILITY INFORMATION.**

| <b>Regulation</b>  | <b>EU Nos.</b>        |
|--|-----------------------|
| Rule 62-204.800, F.A.C.: Federal Regulations Adopted by Reference                                | 020-026, 031-038, 039 |
| Rule 62-212.400, F.A.C.: Prevention of Significant Deterioration (PSD) of Air Quality            | 020-026               |
| Rule 62-213.413, F.A.C.: Fast-Track Revisions of Acid Rain Parts.                                | 020-026               |
| Chapter 62-214, F.A.C.: Requirements For Sources Subject To The Federal Acid Rain Program        | 020-026, 031-038      |
| Rule 62-296.470, F.A.C.: Implementation of Federal Clean Air Interstate Rule                     | 020-026, 031-038      |
| Rule 62-296.700, F.A.C.: Reasonably Available Control Technology (RACT) for PM                   | 008                   |
| Rule 62.296.711, F.A.C.: Materials Handling, Sizing, Screening, Crushing and Grinding Operations | 008                   |

## SECTION II. FACILITY-WIDE CONDITIONS.

---

**The following conditions apply facility-wide to all emission units and activities.**

**FW1. Appendices.** The permittee shall comply with all documents identified in Section VI, Appendices, listed in the Table of Contents. Each document is an enforceable part of this permit unless otherwise indicated. [Rule 62-213.440, F.A.C.]

### **Emissions and Controls**

**FW2. Not federally Enforceable. Objectionable Odor Prohibited.** No person shall cause, suffer, allow or permit the discharge of air pollutants, which cause or contribute to an objectionable odor. An "objectionable odor" means any odor present in the outdoor atmosphere which by itself or in combination with other odors, is or may be harmful or injurious to human health or welfare, which unreasonably interferes with the comfortable use and enjoyment of life or property, or which creates a nuisance. [Rule 62-296.320(2) and 62-210.200(Definitions), F.A.C.]

**FW3. General Volatile Organic Compounds (VOC) Emissions or Organic Solvents (OS) Emissions.** The permittee shall allow no person to store, pump, handle, process, load, unload or use in any process or installation, volatile organic compounds or organic solvents without applying known and existing vapor emission control devices or systems deemed-necessary and ordered by the Department. Nothing is deemed necessary and ordered at this time. [Rule 62-296.320(1), F.A.C.]

**FW4. General Visible Emissions.** No person shall cause, let, permit, suffer or allow to be discharged into the atmosphere the emissions of air pollutants from any activity equal to or greater than 20% opacity. EPA Method 9 is the method of compliance pursuant to Chapter 62-297, F.A.C. This regulation does not impose a specific testing requirement. [Rule 62-296.320(4)(b), F.A.C.]

**FW5. Unconfined Particulate Matter.** No person shall cause, let, permit, suffer or allow the emissions of unconfined particulate matter from any activity, including vehicular movement; transportation of materials; construction; alteration; demolition or wrecking; or industrially related activities such as loading, unloading, storing or handling; without taking reasonable precautions to prevent such emissions. Reasonable precautions to prevent emissions of unconfined particulate matter at this facility include:

- a. Chemical or water application to unpaved roads and unpaved yard areas.
- b. Paving and maintenance of roads, parking areas, and yards.
- c. Landscaping or planting of vegetation.
- d. Confining abrasive blasting where possible.
- e. Other techniques, as necessary.

[Rule 62-296.320(4)(c), F.A.C.; and, proposed by applicant in Title V air operation permit renewal application received May 20, 2009.]

### **Annual Reports and Fees**

See Appendix RR, Facility-wide Reporting Requirements for additional details.

**FW6. Annual Operating Report.** The permittee shall submit an annual report that summarizes the actual operating rates and emissions from this facility. Annual operating reports shall be submitted to the Compliance Authority by April 1<sup>st</sup> of each year. [Rule 62-210.370(3), F.A.C.]

**FW7. Annual Emissions Fee Form and Fee.** The annual Title V emissions fees are due (postmarked) by March 1<sup>st</sup> of each year. The completed form and calculated fee shall be submitted to: Major Air Pollution Source Annual Emissions Fee, P.O. Box 3070, Tallahassee, Florida 32315-3070. The forms are available for download by accessing the Title V Annual Emissions Fee On-line Information Center at the following Internet web site: <http://www.dep.state.fl.us/air/emission/tvfee.htm>. [Rule 62-213.205, F.A.C.]

## SECTION II. FACILITY-WIDE CONDITIONS.

---

**FW8. Annual Statement of Compliance.** The permittee shall submit an annual statement of compliance to the compliance authority at the address shown on the cover of this permit within 60 days after the end of each calendar year during which the Title V permit was effective. [Rules 62-213.440(3)(a)2. & 3. and (b), F.A.C.]

**FW9. Prevention of Accidental Releases (Section 112(r) of CAA).**

- a. As required by Section 112(r)(7)(B)(iii) of the CAA and 40 CFR 68, the owner or operator shall submit an updated Risk Management Plan (RMP) to the Chemical Emergency Preparedness and Prevention Office (CEPPO) RMP Reporting Center.
- b. As required under Section 252.941(1)(c), F.S., the owner or operator shall report to the appropriate representative of the Department of Community Affairs (DCA), as established by department rule, within one working day of discovery of an accidental release of a regulated substance from the stationary source, if the owner or operator is required to report the release to the United States Environmental Protection Agency under Section 112(r)(6) of the CAA.
- c. The owner or operator shall submit the required annual registration fee to the DCA on or before April 1, in accordance with Part IV, Chapter 252, F.S., and Rule 9G-21, F.A.C.
- d. Any required written reports, notifications, certifications, and data required to be sent to the DCA, should be sent to: Department of Community Affairs, Division of Emergency Management, 2555 Shumard Oak Boulevard, Tallahassee, FL 32399-2100, Telephone: 850/413-9921, Fax: 850/488-1739.
- e. Any Risk Management Plans, original submittals, revisions, or updates to submittals, should be sent to: RMP Reporting Center, Post Office Box 10162, Fairfax, VA 22038, Telephone: 703/227-7650.

Any required reports to be sent to the National Response Center, should be sent to: National Response Center, EPA Office of Solid Waste and Emergency Response, USEPA (5305 W), 401 M Street SW, Washington, D.C. 20460, Telephone: (800) 424-8802.

Send the required annual registration fee using approved forms made payable to: Cashier, Department of Community Affairs, State Emergency Response Commission, 2555 Shumard Oak Boulevard, Tallahassee, FL 32399-2149.

[Part IV, Chapter 252, F.S.; and, Rule 9G-21, F.A.C.]

**SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.**

**Subsection A. Combined Cycle Combustion Turbines (EU-020 to EU-026)**

**The specific conditions in this subsection apply to the following emissions units.**

| EU No. | Bayside Combustion Turbines (CT) |        |           | Steam Turbines (ST) |           | Total |
|--------|----------------------------------|--------|-----------|---------------------|-----------|-------|
|        | Unit No.                         | CT No. | MW, Shaft | ST Unit No.         | MW, Steam |       |
| 020    | Combined Cycle<br>Unit No. 1     | CT-1A  | 169 MW    | No. 5               | 239       | 746   |
| 021    |                                  | CT-1B  | 169 MW    |                     |           |       |
| 022    |                                  | CT-1C  | 169 MW    |                     |           |       |
| 023    | Combined Cycle<br>Unit No. 2     | CT-2A  | 169 MW    | No. 6               | 414       | 1090  |
| 024    |                                  | CT-2B  | 169 MW    |                     |           |       |
| 025    |                                  | CT-2C  | 169 MW    |                     |           |       |
| 026    |                                  | CT-2D  | 169 MW    |                     |           |       |
| Totals | 2 Combined Cycle Units           | 7 GTs  | 1183 MW   | 2 STs               | 653       | 1836  |

Bayside Unit 1 (EU 020 – 022) is a “3-on-1” combined cycle combustion turbine system consisting of three combustion turbines (169 megawatt (MW) each) and one common steam-electrical generator (239 MW) with a combined nominal generating capacity of 746 MW. Bayside Unit 2 (EU 023 – 026) is a “4-on-1” combined cycle combustion turbine system consisting of four combustion turbines (169 MW each) and one common steam-electrical generator (414 MW) with a combined nominal generating capacity of 1090 MW. The nameplate generating capacity is identified for the steam turbine-electrical generators. The final design may not fully utilize the nameplate generating capacity.

Each combustion turbine is General Electric Model PG7241(FA) combustion turbine-electrical generator set, which includes an automated gas turbine control system, an inlet air filtration system, an evaporative inlet air cooling system, an unfired heat recovery steam generator (HRSG), a single exhaust stack, electric fuel heaters, cooling towers and associated support equipment. At a compressor inlet air temperature of 59° F and firing 1,842 million British thermal units (MMBtu) per hour of natural gas, each unit produces a nominal 169 MW of shaft-driven electricity. Heat energy is recovered from each HRSG to produce steam, which is delivered to a common header to generate additional power from the steam-electrical generator set for each combined cycle unit. Each combustion turbine is equipped with dry low-NOx (DLN) combustion technology and a selective catalytic reduction (SCR) system to reduce nitrogen oxides (NOx) emissions. Each combustion turbine is equipped with continuous emissions monitoring systems (CEMS) to measure and record carbon monoxide (CO) and NOx emissions as well as flue gas carbon dioxide content. Each combustion turbine has a single exhaust stack that is 150 feet tall and 19.0 feet in diameter. Exhaust gases exit the stack with a volumetric flow rate of approximately 1,030,000 actual cubic feet per minute (acfm) at 220° F.

**CAM Plan:** Although an SCR system is required to achieve the NO<sub>x</sub> standard, a Compliance Assurance Monitoring (CAM) Plan is not required because compliance is continuously demonstrated by CEMS.

*{Permitting Notes: These emissions units are regulated under: NSPS Subpart GG for Stationary Gas Turbines in 40 CFR 60 adopted and incorporated by reference in Rule 62-204.800, F.A.C.; Rule 212.400, F.A.C. for the Prevention of Significant Deterioration (PSD), which required Best Available Control Technology (BACT) determinations as specified in Permit No. PSD-FL-301 (as modified) for carbon monoxide (CO), particulate matter (PM/PM<sub>10</sub>), and volatile organic compounds (VOC); Chapter 62-214, F.A.C., the Phase II Acid Rain Program as specified in Section IV of this permit; and Rule 62-296.470, F.A.C., the Clean Air Interstate Rule as specified in Section V of this permit.}*

## SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

### Subsection A. Combined Cycle Combustion Turbines (EU-020 to EU-026)

#### Essential Potential to Emit (PTE) Parameters

- A.1. Permitted Capacity.** The maximum heat input rate to each gas turbine shall not exceed 1842 MMBtu per hour while producing approximately 169 MW (shaft). The maximum heat input rate is based on operation at 100% load, a compressor inlet air temperature of 59° F, the higher heating value (HHV) of natural gas and expected performance levels. Heat input rates will vary depending upon gas turbine characteristics, ambient conditions, and evaporative cooling. The permittee shall maintain on site records of the manufacturer's performance curves for the gas turbines. Operating data may be adjusted for the appropriate site conditions in accordance with the performance curves and/or equations on file with the Department. [Permit No. PSD-FL-301A; Rules 62-4.160(2), 62-210.200(PTE), and 62-212.400(BACT), F.A.C.]
- A.2. Emissions Unit Operating Rate Limitation After Testing.** See the related testing provisions in Appendix TR, Facility-wide Testing Requirements. [Rule 62-297.310(2), F.A.C.]
- A.3. Methods of Operation.**
- Allowable Fuels.*** Each gas turbine shall fire only pipeline-quality natural gas. The fuel sulfur content shall not exceed 2 grains per 100 SCF of natural gas based on a 12-month rolling average. Compliance shall be demonstrated each month by compiling the daily fuel sulfur analyses provided by the pipeline vendor. Methods for determining the sulfur content of the natural gas shall be in accordance with applicable 40 CFR Part 75 procedures, as amended or ASTM methods D4084-82, D3246-81 or equivalent methods. No other fuels are allowed. [Permit No. PSD-FL-301A; Rules 62-210.200(PTE) and 62-213.410, F.A.C.; DEP/TEC Consent Final Judgment; EPA/TEC Consent Decree]
  - Operating Procedures.*** The Best Available Control Technology (BACT) determinations established by this permit rely on "good operating practices" to minimize emissions. Therefore, all operators and supervisors shall be properly trained to operate and maintain the gas turbines and pollution control systems in accordance with the guidelines and procedures established by the manufacturer. The training shall include good operating practices as well as methods to minimize emissions during startup and shutdown. [Permit No. PSD-FL-301A; Rules 62-4.070(3) and 62-212.400(BACT), F.A.C.]
- A.4. Hours of Operation.** These emissions units may operate continuously (8760 hours/year). [Rule 62-210.200(PTE), F.A.C., Permit No. PSD-FL-301A]

#### Control Technology

- A.5. DLN Combustion Technology.** The permittee shall tune, operate and maintain the General Electric dry low-NOx combustion system (DLN 2.6 or better) to provide efficient lean premix combustion. Each system shall be maintained and tuned in accordance with the manufacturer's recommendations. [Permit No. PSD-FL-301A; Rule 62-212.400(BACT), F.A.C.]
- A.6. SCR System.** The permittee shall tune, operate and maintain a selective catalytic reduction (SCR) system to reduce NOx emissions from each combined cycle gas turbine. The SCR system shall consist of an ammonia injection grid, catalyst, ammonia storage, a monitoring and control system, electrical system, piping, and other ancillary equipment. The SCR system shall be designed to reduce NOx emissions while minimizing ammonia slip within the permitted levels. *{Permitting Note: In general, the SCR system is placed in service once the exhaust gas temperature reaches 446° F.}* [Permit No. PSD-FL-301A; DEP/TEC Consent Final Judgment; EPA/TEC Consent Decree; Rule 62-4.070(3), F.A.C.]

#### Emission Limitations and Standards

*{Permitting Note: The attached Table 1, Summary of Air Pollutant Standards, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}*

- A.7. Emissions Standards Based on Performance Tests:** The following standards apply to each combined cycle gas turbine as determined by emissions performance tests conducted at permitted capacity. The mass

### SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

#### Subsection A. Combined Cycle Combustion Turbines (EU-020 to EU-026)

emission limits are based on a compressor inlet temperature of 59° F. The permittee shall maintain on site the manufacturer's performance curves (or equations) that correct for site conditions. Operating data shall be adjusted for the appropriate site conditions in accordance with the performance curves and/or equations on file with the Department. Unless otherwise specified, the averaging times are based on the specified averaging time of the applicable test method.

- a. *Ammonia Slip*. Subject to the requirements of Condition A.18 in this section, each SCR system shall be designed and operated for an ammonia slip target of less than 5 ppmvd corrected to 15% oxygen based on the average of three test runs. [Rule 62-4.070(3), F.A.C. and PSD-FL-301A]
  - b. *Carbon Monoxide (CO)*. CO emissions shall not exceed 28.7 pounds per hour and 7.8 ppmvd corrected to 15% oxygen based on the average of three test runs as determined by EPA Method 10. [Rule 62-212.400(BACT), F.A.C. and PSD-FL-301A]
  - c. *Nitrogen Oxides (NOx)*. NOx emissions shall not exceed 23.1 pounds per hour and 3.5 ppmvd corrected to 15% oxygen based on the average of three test runs as determined by EPA Method 7E. NOx emissions are defined as oxides of nitrogen reported as NO<sub>2</sub>. [DEP/TEC Consent Final Judgment; EPA/TEC Consent Decree; and PSD-FL-301A]
  - d. *Particulate Matter (PM/PM<sub>10</sub>)*. The exclusive firing of pipeline-quality natural gas combined with the efficient combustion design and operation of each gas turbine represent the Best Available Control Technology (BACT) requirements for particulate matter emissions. Compliance with carbon monoxide and visible emissions standards shall serve as continuous indicators of efficient combustion to minimize particulate matter emissions. No performance tests are required. [Rule 62-212.400(BACT), F.A.C. and PSD-FL-301A]
  - e. *Sulfuric Acid Mist (SAM) and Sulfur Dioxide (SO<sub>2</sub>)*. The exclusive firing of pipeline-quality natural gas effectively limits potential emissions of SO<sub>2</sub> and SAM. No performance tests are required. [Design; DEP/TEC Consent Final Judgment; EPA/TEC Consent Decree; and PSD-FL-301A]
  - f. *Visible Emissions*. Visible emissions shall not exceed 10% opacity, based on a 6-minute average as determined by EPA Method 9. Except as allowed by Condition A.10 of this section, this standard applies to all loads. [Rule 62-212.400(BACT), F.A.C. and PSD-FL-301A]
  - g. *Volatile Organic Compounds (VOC)*. The exclusive firing of pipeline-quality natural gas combined with the efficient combustion design and operation of each gas turbine represent the Best Available Control Technology (BACT) requirements for VOC emissions. Compliance with carbon monoxide standards shall serve as a continuous indicator of efficient combustion to minimize VOC emissions. No performance tests are required. [PSD-FL-301A and Rule 62-212.400(BACT), F.A.C.]
- A.8. Emissions Standards Based on CEMS Data:** The following standards apply to each gas turbine based on data collected from each required Continuous Emissions Monitoring System (CEMS).
- a. *Carbon Monoxide (CO)*: CO emissions shall not exceed 9.0 ppmvd corrected to 15% oxygen based on a 24-hour block average of CEMS data.
  - b. *Nitrogen Oxides (NOx)*: NOx emissions shall not exceed 3.5 ppmvd corrected to 15% oxygen based on a 24-hour block average of CEMS data.

Each 24-hour block average shall start at midnight each operating day and shall be calculated from 24 consecutive 1-hour averages. If a unit operates less than 24 hours during the block, the 24-hour block average shall be the average of the available valid 1-hour averages. [Permit No. PSD-FL-301A; Rules 62-212.400(BACT) and 62-4.070(3), F.A.C.]

#### **Excess Emissions**

Rule 62-210.700 (Excess Emissions), F.A.C. cannot vary any requirement of an NSPS, NESHAP or Acid Rain



### SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

#### Subsection A. Combined Cycle Combustion Turbines (EU-020 to EU-026)

program provision.

- A.9. Excess Emissions Prohibited:** Excess emissions caused entirely or in part by poor maintenance, poor operation or any other equipment or process failure that may reasonably be prevented during startup, shutdown or malfunction, shall be prohibited. All such preventable emissions shall be included in the compliance averages determined from the CO and NO<sub>x</sub> CEMS data. [Permit No. PSD-FL-301A and Rule 62-210.700(4), F.A.C.]
- A.10. Alternative Standards and CEMS Data Exclusion:** As provided by the authority in Rule 62-210.700(5), F.A.C., the above requirements are established in lieu of the provisions of Rule 62-210.700(1), F.A.C. The following permit conditions establish alternate standards or allow the exclusion of monitoring data for specifically defined periods of startup, shutdown, malfunction and other limited-use operations. These conditions apply only if operators employ the best operational practices to minimize the amount and duration of emissions during such incidents.
- a. *Definitions:* The following terms are defined in Rule 62-210.200, F.A.C. “Shutdown” means the cessation of the operation of an emissions unit for any purpose. “Malfunction” means any unavoidable mechanical and/or electrical failure of air pollution control equipment or process equipment or of a process resulting in operation in an abnormal or unusual manner. “Startup” means the commencement of operation of any emissions unit which has shut down or ceased operation for a period of time sufficient to cause temperature, pressure, chemical or pollution control device imbalances, which result in excess emissions.
  - b. *Alternative Opacity During Startup and Shutdown.* During startup and shutdown, the opacity of the exhaust gases shall not exceed 10%, except for up to ten 6-minute averaging periods in a calendar day during which the opacity shall not exceed 20%. Data for each 6-minute averaging period shall be exclusive from other 6-minute averaging periods.
  - c. *Low Load Operation.* Except for other authorized periods of low-load operation, each gas turbine may operate below 50% base load providing: the gas turbine is firing natural gas and operating in full dry low-NO<sub>x</sub> combustion mode; the CO and NO<sub>x</sub> CEMS are functioning properly during such periods and recording valid emissions data within the span range of the monitors; and the gas turbine remains in compliance with the CO and NO<sub>x</sub> emissions standards (24-hour block averages).
  - d. *CEMS Data Exclusion.* For the following specified operational periods, CO and NO<sub>x</sub> emissions data may be excluded from the 24-hour block compliance averages in accordance with the corresponding requirements.
    - (1) *Standard Gas Turbine/HRSG Startups, Shutdowns, and Malfunctions.* For each gas turbine, no more than four 1-hour CEMS emission averages shall be excluded from any 24-hour block compliance average due to standard startups, shutdowns, and malfunctions (total).
    - (2) *Cold Steam Turbine Startup.* “Cold steam turbine startup” means a startup after the steam turbine has been offline for 24 hours or more, or the first stage turbine metal temperature is 250° F or less. More than one gas turbine may be used to complete a cold steam turbine startup; however, to minimize emissions, no more than one gas turbine per Bayside Unit at a time shall be operated during a cold steam turbine startup. For a given cold steam turbine startup, no more than sixteen 1-hour CEMS emission averages for all participating gas turbines shall be excluded from the 24-hour block compliance averages. For a gas turbine used during a cold steam turbine startup, no more than a total of sixteen 1-hour CEMS emission averages shall be excluded from any 24-hour block compliance average due to any combination of cold steam turbine startups and gas turbine/HRSG startups, shutdowns and malfunctions. In the event of a cold steam turbine startup and-gas turbine/HRSG startups, shutdowns and/or malfunctions within the same 24-hour period, a total of sixteen 1-hour CEMS emissions averages may be excluded with no more than four of those sixteen 1-hour CEMS

### SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

#### Subsection A. Combined Cycle Combustion Turbines (EU-020 to EU-026)

emissions averages being excluded due to gas turbine/HRSG startups, shutdowns, and/or malfunctions (total).

- (3) *Warm Steam Turbine Startup*: “Warm steam turbine startup” means a startup after the steam turbine has been offline for less than 24 hours and the first stage turbine metal temperature is 250° F or more. More than one gas turbine may be used to complete a warm steam turbine startup; however, to minimize emissions, no more than one gas turbine per Bayside Unit at a time shall be operated during a warm steam turbine startup. For a given warm steam turbine startup, no more than eight 1-hour CEMS emission averages for all participating gas turbines shall be excluded from the compliance averages. For a gas turbine used during a warm steam turbine startup, no more than eight 1-hour CEMS emission averages shall be excluded from any compliance average in a 24-hour block period due to any combination of warm steam turbine startups and gas turbine/HRSG startups, shutdowns and malfunctions. In the event of a warm steam turbine startup and-gas turbine/HRSG startups, shutdowns and/or malfunctions within the same 24-hour period, a total of eight 1-hour CEMS emissions averages may be excluded with no more than four of those eight 1-hour CEMS emissions averages being excluded due to gas turbine/HRSG startups, shutdowns, and/or malfunctions (total).
- (4) *Other Limited-Use Operations*: CEMS data collected during any of the following limited use operational periods may be excluded from the compliance averages.
- (a) *DLN Tuning*. “DLN Tuning” means operating the gas turbine at intermittent loads throughout the full load range in order to adjust and tune the dry low-NO<sub>x</sub> (DLN) combustion system. DLN tuning shall be conducted in accordance with manufacturer’s recommendations (or industry standards). {*Permitting Note: For example, a major tuning session would occur after combustor change-out.*}
- (b) *Compressor Blade Drying*. Following a compressor blade wash in accordance with the manufacturer’s recommendations (or industry standards), the permittee may operate a gas turbine at very low loads to heat and dry the compressor blades. {*Permitting Note: A gas turbine would typically operate at approximately 10% of base load or less to perform compressor blade drying.*}
- (c) *Over Speed Trip Test*. As a periodic maintenance practice, the permittee may perform over speed trip tests in accordance with the manufacturer’s recommendations (or industry standards). {*Permitting Note: During this test, the gas turbine is operated at full speed, no load (FSNL) for approximately 5 to 6 hours. The unit is gradually accelerated to 110% speed (3960 rpm) to initiate a trip and then coasts down normally. Over speed trip tests are typically performed after a long outage or a major component overhaul.*}

To the extent practicable, the permittee shall minimize the amount and duration of emissions during periods of startup, shutdown, malfunction and other limited-use operations. If a CEMS reports emissions in excess of an emissions standard (24-hour block), the permittee shall notify the Compliance Authority within one working day with a preliminary report of: the nature, extent and duration of the excess emissions; the cause of the excess emissions; and the actions taken to correct the problem. In addition, the Compliance Authority may request a written summary report of the incident. All emissions data allowed for exclusion shall be summarized in the Semiannual CEMS Report required in Condition A.20 of this subsection.

- e. *Startup and Shutdown Plan*. The permittee shall maintain on site a “Startup and Shutdown Plan” that describes procedures for startup and shutdown of the Bayside Units.

As provided by the authority in Rule 62-210.700(5), F.A.C., the above requirements are established in lieu of the provisions of Rule 62-210.700(1), F.A.C.

## SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

### Subsection A. Combined Cycle Combustion Turbines (EU-020 to EU-026)

*{Permitting Note: The durations for warm and cold steam turbine startups are not typical for combined cycle units. The Bayside Units utilize the existing Gannon steam turbines. Operating procedures require one gas turbine to operate at low loads for extended periods to gradually warm the main and hot reheat steam lines to the steam turbine as well as the steam turbine. Some steam lines are in excess of 1700 feet. Such startups are expected to occur infrequently.}* [Design; Rules 62-4.130, 62-210.700(5), and 62-212.400 (BACT), F.A.C.; Permit No. PSD-FL-301B]

- A.11. Excess Emissions - Notification:** In case of excess emissions resulting from malfunctions, each owner or operator shall notify the Department or the appropriate Local Program in accordance with Rule 62-4.130, F.A.C. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department. [Rule 62-210.700(6), F.A.C.]

#### **Monitoring of Operations**

- A.12. Monitoring of Operations:** To demonstrate compliance with the gas turbine capacity requirements, the permittee shall monitor and record the operating rate of each gas turbine on a daily average basis, considering the number of hours of operation during each day (including the times of startup, shutdown and malfunction). Such monitoring shall be made using a monitoring component of the CEMS required above, or by monitoring daily rates of consumption and heat content of natural gas in accordance with the provisions of 40 CFR 75 Appendix D. [Permit No. PSD-FL-301A; Rules 62-4.070(3) and 62-212.400(BACT), F.A.C.]
- A.13. Ammonia Monitoring Requirements:** The permittee shall calibrate, maintain and operate, in accordance with the manufacturer's specifications, an ammonia flow meter to measure and record the ammonia injection rate through each SCR system. The permittee shall document the general range of ammonia flow rates required to meet emissions limitations over the range of gas turbine load conditions allowed in this permit by comparing NO<sub>x</sub> emissions recorded by the NO<sub>x</sub> monitor with ammonia flow rates recorded using the ammonia flow meter. During NO<sub>x</sub> monitor downtimes or malfunctions, the permittee shall operate at the ammonia flow rate that is consistent with the documented flow rate for the gas turbine load. [Permit No. PSD-FL-301A; Rules 62-4.070(3) and 62-212.400(BACT), F.A.C.]

#### **Continuous Monitoring Requirements**

- A.14. Continuous Emissions Monitoring Systems:** The permittee shall calibrate, maintain, and operate a continuous emission monitoring system (CEMS) in the exhaust stack of each emissions unit to measure and record emissions of CO and NO<sub>x</sub> in a manner sufficient to demonstrate compliance with the CEMS emission standards of this permit. The carbon dioxide (CO<sub>2</sub>) content of the flue gas shall also be monitored at the location where CO and NO<sub>x</sub> are monitored to correct the measured emissions rates to 15% oxygen. The oxygen content of the flue gas shall be calculated by the CEMS using the CO<sub>2</sub> content of the flue gas and an F-factor that is appropriate for natural gas.
- a. *Emission Averages.* Compliance with the 24-hour standards for CO and NO<sub>x</sub> emissions shall be based on data collected by the required CEMS. The 24-hour block shall start at midnight of each operating day and consist of 24 consecutive 1-hour blocks. If a unit operates continuously throughout the day, the 24-hour block average shall be the average of 24 consecutive 1-hour emission averages. If a unit operates less than 24 hours during the day, the 24-hour block average shall be the average of available valid 1-hour emission averages collected during operation. If monitoring data is authorized for exclusion (due to startup, shutdown, malfunction, or tuning), the 24-hour block average shall be the average of the remaining available valid 1-hour emission averages collected during operation. Upon a request from the Compliance Authority, the NO<sub>x</sub> emission rate shall be corrected to ISO conditions to demonstrate compliance with the applicable standards of 40 CFR 60.332.
- b. *Data Collection.* The CEMS shall be operated to sample, analyze, and record CO, CO<sub>2</sub>, and NO<sub>x</sub> data evenly spaced over the hour. Each 1-hour emission average shall be computed using at least one data point in each fifteen minute quadrant of the 1-hour block during which the unit combusted fuel.

### SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

#### Subsection A. Combined Cycle Combustion Turbines (EU-020 to EU-026)

Notwithstanding this requirement, each 1-hour emission average shall be computed from at least two data points separated by a minimum of 15 minutes. If the unit does not operate in more than one quadrant of a 1-hour block, the data is insufficient to determine a 1-hour emission average and shall be ignored.

(Example: Unit begins startup with only ten minutes remaining in the 1-hour block. Data is insufficient to determine a 1-hour average and is ignored.) All valid measurements or data points collected during a 1-hour block shall be used to calculate the 1-hour emission averages. If the CEMS measures concentration on a wet basis, the CEMS shall include provisions to determine the moisture content of the exhaust gas and an algorithm to enable correction of the monitoring results to a dry basis (0% moisture). Alternatively, a curve of the flue gas moisture content versus load may be developed through manual stack test measurements and used in an algorithm to enable correction of the monitoring results to a dry basis (0% moisture). The CO and NO<sub>x</sub> CEMS shall express the 1-hour emission averages and the 24-hour block averages in terms of “ppmv corrected to 15% oxygen”.

- c. *Data Exclusion.* CO, CO<sub>2</sub>, and NO<sub>x</sub> emissions data shall be recorded by the CEMS at all times including episodes of startup, shutdown, malfunction, and tuning. CO and NO<sub>x</sub> emissions data recorded during such episodes may be excluded from the 24-hour block compliance averages in accordance with the requirements of Condition A.10 of this section. All periods of data excluded due to startup, shutdown or malfunction shall be consecutive for each episode. The permittee shall minimize the duration of data excluded for startup, shutdown and malfunctions, to the extent practicable. Data recorded during startup, shutdown or malfunction shall not be excluded if the episode was caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure, which may reasonably be prevented. Best operational practices shall be used to minimize hourly emissions that occur during startup, shutdown and malfunction. Emissions of any quantity or duration that occur entirely or in part from poor maintenance, poor operation, or any other equipment or process failure, which may reasonably be prevented, shall be prohibited. Excluded emissions shall be summarized in the required semiannual report.
- d. *NO<sub>x</sub> Certification.* The NO<sub>x</sub> monitor shall be operated and maintained in accordance with the applicable requirements of 40 CFR Part 75, Subparts B and C. For purposes of determining compliance with the CEMS emission standards of this permit, missing data shall not be substituted. Instead the 24-hour block average shall be determined using the remaining hourly data in the 24-hour block. Record keeping and reporting shall be conducted pursuant to 40 CFR Part 75, Subparts F and G. The relative accuracy test assessments (RATA) required for the NO<sub>x</sub> monitor shall be performed using EPA Method 7E or 20 as defined in Appendix A of 40 CFR 60. The span for the NO<sub>x</sub> monitor shall not be greater than 10 ppmv corrected to 15% oxygen. A dual span monitor may be used.
- e. *CO and CO<sub>2</sub> Certification.* The CO<sub>2</sub> monitor shall meet Performance Specification 3 in Appendix B of 40 CFR 60. The CO monitor shall meet Performance Specification 4 in Appendix B of 40 CFR 60. Quality assurance procedures for each monitor shall conform to the requirements of 40 CFR 60, Appendix F; and the Data Assessment Report of Section 7 shall be made each calendar quarter and reported semi-annually to the Compliance Authority. The RATA required for the CO<sub>2</sub> monitor shall be performed using EPA Method 3A, of Appendix A in 40 CFR 60. The RATA required for the CO monitor shall be performed using EPA Method 10, of Appendix A in 40 CFR 60. The Method 10 analysis shall use a continuous sampling train. The span for the CO monitor shall not be greater than 25 ppm corrected to 15% oxygen. A dual span CO monitor may be used.
- f. *Monitor Availability.* Monitor availability shall not be less than 95% in any calendar quarter. The quarterly Data Assessment Report required in Condition A.14e above shall be used to demonstrate monitor availability and may be reported semiannually. In the event 95% availability is not achieved, the permittee shall provide the Compliance Authority with a report identifying the problems in achieving 95% availability and a plan of corrective actions that will be taken to achieve 95% availability. The permittee shall implement the reported corrective actions within the next calendar quarter. Failure to take

**SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.**

**Subsection A. Combined Cycle Combustion Turbines (EU-020 to EU-026)**

corrective actions or continued failure to achieve the minimum monitor availability shall be violations of this permit. The quarterly reports shall be submitted semiannually in conjunction with the Semiannual CEMS Report in Condition A.20.

*{Permitting Note: Compliance with these requirements will ensure compliance with the other applicable CEMS requirements such as: NSPS Subpart GG; Rule 62-297.520, F.A.C.; 40 CFR 60.7(a)(5) and 40 CFR 60.13; 40 CFR Part 51, Appendix P; 40 CFR 60, Appendix B - Performance Specifications; and 40 CFR 60, Appendix F - Quality Assurance Procedures.}*

[Permit No. PSD-FL-301A; Rules 62-4.070(3), 62-210.700(5), and 62-212.400(BACT), F.A.C.]

**Test Methods and Procedures**

**A.15. Test Methods.** Required tests shall be performed in accordance with the following reference methods:

| Method  | Description of Method and Comments   |
|---------|--|
| 320     | Measurement of Vapor Phase Organic and Inorganic Emissions by Extractive Fourier Transform Infrared (FTIR) Spectroscopy  |
| CTM-027 | Procedure for Collection and Analysis of Ammonia in Stationary Source: This is an EPA conditional test method. The minimum detection limit shall be 1 ppm.   |
| 5       | Determination of Particulate Matter Emissions from Stationary Sources: The minimum sampling time shall be two hours per run and the minimum sampling volume shall be 60 dscf per run.                          |
| 7E      | Determination of Nitrogen Oxide Emissions from Stationary Sources  |
| 9       | Visual Determination of the Opacity of Emissions from Stationary Sources   |
| 10      | Determination of Carbon Monoxide Emissions from Stationary Sources: The method shall use a continuous sampling train.  |
| 18      | Measurement of Gaseous Organic Compound Emissions by Gas Chromatography: EPA Method 18 may be used concurrently with EPA Method 25A to deduct emissions of methane and ethane from the measured VOC emissions. |
| 20      | Determination of Nitrogen Oxides, Sulfur Dioxide and Diluent Emissions from Stationary Gas Turbines  |
| 25A     | Determination of Volatile Organic Concentrations   |

Except for Method 320 and Method CTM-027, the above methods are described in Appendix A of 40 CFR 60, which is adopted by reference in Rule 62-204.800, F.A.C. Method 320 is described in Appendix A of 40 CFR 63, which is adopted by reference in Rule 62-204.800, F.A.C. Method CTM-027 is published on EPA's Technology Transfer Network Web Site at "<http://www.epa.gov/ttn/emc/ctm.html>". Although no specific tests are required for emissions of particulate matter and volatile organic compounds, the test methods are included for completeness. No other methods may be used for compliance testing unless prior written approval is received from the Department. [Permit No. PSD-FL-301A; Rules 62-204.800 and 62-297.100, F.A.C.; 40 CFR 60, Appendix A]

**A.16. Common Testing Requirements.** Unless otherwise specified, tests shall be conducted in accordance with the requirements and procedures specified in Appendix TR, Facility-Wide Testing Requirements, of this permit. [Rule 62-297.310, F.A.C.]

**A.17. Annual Compliance Tests.** During each federal fiscal year (October 1<sup>st</sup> to September 30<sup>th</sup>), each gas turbine shall be tested to demonstrate compliance with the emission standards for ammonia slip and visible emissions. The test results for ammonia slip shall also report the CO and NOx emissions recorded by the CEMS during each test run. *{Permitting Note: Continuous compliance with the CO and NOx standards will be demonstrated with certified CEMS data.}* [Permit No. PSD-FL-301A; Rules 62-212.400(BACT) and 62-297.310(7)(a)4, F.A.C.]

**A.18. Additional Ammonia Slip Testing:** If the tested ammonia slip rate for a gas turbine exceeds 5 ppmvd

### SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

#### Subsection A. Combined Cycle Combustion Turbines (EU-020 to EU-026)

corrected to 15% oxygen when firing natural gas during the annual test, the permittee shall:

- a. Begin testing and reporting the ammonia slip for each subsequent calendar quarter;
- b. Before the ammonia slip exceeds 7 ppmvd corrected to 15% oxygen, take corrective actions that result in lowering the ammonia slip to less than 5 ppmvd corrected to 15% oxygen; and
- c. Test and demonstrate that the ammonia slip is less than 5 ppmvd corrected to 15% oxygen within 15 days after completing the corrective actions.

Corrective actions may include, but are not limited to, adding catalyst, replacing catalyst, or other SCR system maintenance or repair. After demonstrating that the ammonia slip level is less than 5 ppmvd corrected to 15% oxygen, testing and reporting shall resume on an annual basis. [Permit No. PSD-FL-301A; Rules 62-4.070(3) and 62-297.310(7)(b), F.A.C.]

**A.19. Compliance Testing Requirements:** Appendix TR of this permit identifies other compliance testing requirements commonly applicable to the emissions units in this subsection. [Rule 62-297.310, F.A.C.]

#### **Recordkeeping and Reporting Requirements**

**A.20. Semiannual CEMS Report:** In addition to the reports required pursuant to 40 CFR 60.7, the permittee shall submit semiannual reports for each gas turbine summarizing the CEMS data and equipment. For each calendar quarter, the report shall include: the 24-hour block compliance averages for each day of operation; the number of 1-hour emission averages excluded from each 24-hour compliance average; the emissions rate of the excluded monitoring data; the reason for excluding monitoring data; the hours of missing data due to monitor downtime; the reason for any monitor downtime; unusual maintenance or repair of the CEMS; and a summary of any RATA tests performed. Based on operational data, the permittee shall also update the general range of ammonia flow rates required to meet NO<sub>x</sub> emissions limitations over the range of gas turbine load conditions. A report covering operations from January through June shall be submitted by July 30<sup>th</sup> of each year. A report covering operations from July through December shall be submitted by January 30<sup>th</sup> of each year. The data assessment report required by Condition A.14(f) shall be submitted in conjunction with the Semiannual CEMS Report. The report due dates may be modified by the Title V permit. [Permit No. PSD-FL-301A; Rules 62-4.070(3) and 62-212.400(BACT), F.A.C.]

**A.21. Reporting Schedule.** The following reports and notifications shall be submitted to the Compliance Authority:

| Report   | Reporting Deadline  | Related Conditions |
|--|---|--------------------|
| Data Assessment Report for Quality Assurance for each CO and CO <sub>2</sub> Monitor                       | Done each calendar quarter and reported semi-annually to the Compliance Authority   | A.14.              |
| Corrective Action Report for Monitor Availability for each CO, CO <sub>2</sub> and NO <sub>x</sub> Monitor | If monitor availability is less than 95% in any calendar quarter, provide report to Compliance Authority identifying the problems and a plan of corrective actions. | A.14.              |
| Semiannual CEMS Report for each CO and NO <sub>x</sub> Monitor   | July 30 <sup>th</sup> (for January through June), and January 30 <sup>th</sup> (July through December)  | A.20               |

{Permitting Note: See Appendix RR, Facility-Wide Reporting Requirements, for additional reporting requirements.}

#### **NSPS Provisions**

**A.22. NSPS Subparts A and GG Provisions:** The combined cycle gas turbines identified in this subsection are subject to applicable requirements in NSPS Subparts A (General Provisions) and GG (Stationary Gas Turbines) in 40 CFR 60. See Appendix NS and GG, respectively. Some separate reporting and monitoring may be required by the individual subparts. [Rule 62-204.800, F.A.C. and NSPS Subparts A and GG]

**SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.**

**Subsection B. Fuel Yard (EU-008)**

The specific conditions in this subsection apply to the following emissions unit.

| EU No. | Brief Description |
|--------|-------------------|
| 008    | Fuel Yard         |

Activities related to the existing fuel yard include: barge unloading of coal (clamshell and continuous); railcar unloading of coal; truck, barge, and train unloading of flux; and the transfer and storage of these materials. The following table identifies the emissions points and particulate matter control equipment information.

Table B-1. Emission Point Summary for Fuel Yard

| Emission Point Description            | ID No.           | Throughput TPH | Control Method | Efficiency |
|---------------------------------------|------------------|----------------|----------------|------------|
| Barge to clamshell                    | FH-001/002       | 2,300          | DS             | 95%        |
| Barge to continuous unloader          | FH-003           | 2,300          | DS             | 95%        |
| Clamshell to barge unloading hopper   | FH-004/005       | 2,300          | DS             | 95%        |
| Continuous unloader to conveyor A     | FH-006           | 2,300          | **DS           | 95%        |
| Barge unloading hoppers to conveyor B | FH-008/009       | 2,300          | **DS/E         | 95%        |
| Railcar to rail unloading hopper      | FH-013           | 2,300          | DS/E           | 95%        |
| Rail unloading hopper to conveyor L   | FH-014           | 2,300          | **DS/E         | 95%        |
| Fuel storage pile                     | FH-022/023 a & b | NA             | DS             | 50%        |
| Dozer operations of storage piles     | FH-044           | NA             | DS             | 50%        |
| Truck unloading - auxiliary           | AH-001           | 400            | DS             | 85%        |
| Storage pile                          | AH-002           | 400            | DS/E           | 90%        |
| Truck dump to flux storage pile       | OMH-001          | NA             | DS             | 85%        |
| Flux storage pile maintenance         | OMH-002          | NA             | DS             | 50%        |
| Flux storage pile                     | OMH-003          | NA             | DS             | 50%        |

Notes: "DS" means dust suppressant. "E" means enclosure. "NA" means not applicable. The double asterisk (\*\*) identifies the dust suppressant application point.

*{Permitting Note: The above activities are regulated under the following: Rule 62-296.711, F.A.C. (Materials Handling, Sizing, Screening, Crushing and Grinding Operation); and Rule 62-296.700, F.A.C. (Reasonably Available Control Technology (RACT) for Particulate Matter). The existing fuel yard equipment previously served F. J. Gannon Station Units 1 through 6; however, the coal-fired boilers are permanently shut down.}*

**Essential Potential to Emit (PTE) Parameters**

- B.1. Permitted Capacity:** Coal throughput for this facility shall not exceed 2.85 million tons in any 12 consecutive months. [Rules 62-4.160(2), 62-210.200 (PTE), and 62-212.400(2)(a)2, F.A.C.; Permit No. 0570040-006-AC]
- B.2. Hours of Operation.** This emissions unit is allowed to operate continuously (8760 hours per year). [Rules 62-4.160(2) and 62-210.200(PTE), F.A.C.]

**Control Technology**

- B.3. Control Techniques:** Water sprays or chemical wetting agents and stabilizers are acceptable methods to be used on coal storage piles as necessary to maintain an opacity of less than or equal to 5%. Other

### SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

#### Subsection B. Fuel Yard (EU-008)

appropriate methods may be applied to maintain this opacity, after they are approved by the Department. Facilities that cause frequent, valid complaints may be required by the Compliance Authority to take these or other reasonable precautions. In determining what constitutes reasonable precautions for a particular source, the Compliance Authority shall consider the cost of the control technique or work practice, the environmental impacts of the technique or practice, and the degree of reduction of emissions expected from a particular technique or practice. [Permit Nos. 0570040-006-AC and 0570040-010-AC]

- B.4. Application of Dust Suppressants:** Dust suppressants shall be applied to the fuel either prior to or at the time of delivery and at all emission points as specified in Table B-1 of this subsection to control fugitive particulate matter emissions and maintain an opacity of less than or equal to 5%. For the application of dust suppressants prior to delivery, the permittee shall keep monthly records of: 1) the amount of dust suppressant applied for each type and amount of coal delivered, and 2) the type of dust suppressant used (e.g., MSD sheets, product name). [Permit No. 0570040-006-AC]

#### **Emission Limitations and Standards**

- B.5. Visible Emissions.** Visible emissions generated by fugitive or unconfined particulate matter from fuel yard shall not exceed 5% opacity. *{Permitting note: The averaging time for this condition is based on the specified averaging time of the applicable test method, unless otherwise specified in this permit.}* [Rule 62-296.711(2)(a), F.A.C. and Permit No. AC29-152987]

#### **Monitoring of Operations**

- B.6. Proper Maintenance:** All controls associated with the transfer points shall be maintained to the extent that the capture efficiencies credited will be achieved. [Rule 62-4.070(3), F.A.C. and Permit No. AO29-216480]

**B.7. Operation and Maintenance Plan for Particulate Matter Control**

a. Process Parameters

(1) Operation Schedule: 8760 hours per year

(2) Equipment Data

Conveyor Hoods: Corrugated Aluminum

Transfer Point Enclosures: Carbon Steel

- b. Inspection and Maintenance Procedures: If operating, the fuel yard particulate matter control equipment shall receive regular preventative maintenance as follows:

(1) Conveyor Enclosures

(a) Daily random visual inspections of conveyor hoods.

(b) Daily random visual inspection of the transfer points chute work.

(2) Dust Suppression System

(a) Quarterly inspection of system for water leaks.

(b) Quarterly inspection of spray nozzles.

The pumps, tanks, etc., that make-up the dust suppression system undergo normal maintenance including lubrication, flushing, and draining.

[Rule 62-296.700, F.A.C.]

#### **Test Methods and Procedures**

- B.8. Visible Emissions:** A 30-minute visible emissions test shall be performed on the following material transfer operations during each federal fiscal year (October 1 - September 30) the fuel yard is operational:



### SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

#### Subsection B. Fuel Yard (EU-008)

- a. The clamshell to the hopper; and
- b. The railcar to the hopper.

The test method for visible emissions shall be determined using EPA Method 9, adopted and incorporated by reference in Rule 62-204.800, F.A.C., and referenced in Chapter 62-297, F.A.C. [Rules 62-204.800, 62-297.310(4)(a)2, 62-297.310(7)(a)4, F.A.C.; Permit No. 0570040-006-AC]

#### **Recordkeeping and Reporting Requirements**

- B.9. Testing Rates:** All compliance testing shall be conducted during normal operation and at the maximum material (including limestone or iron ore where applicable) transfer rate attainable during the test period. [Rule 62-4.070(3), F.A.C.; Permit No. AO29-216480]
- B.10. O&M Records:** Records of inspections, maintenance, and performance parameters shall be retained for a minimum of five years and shall be made available to the Compliance Authority upon request. [Rules 62-213.440(1)(b)2.b and 62-296.700(6)(e), F.A.C.]
- B.11. Common Compliance Testing Requirements:** Appendix TR of this permit identifies other compliance testing requirements commonly applicable to the emissions units in this subsection. These include the following requirements: Rule 297.310(7)(a)9, F.A.C. (Test Notification); Rule 62-297.310(5), F.A.C. (Determination of Process Variables); Rule 62-297.310(8), F.A.C. (Test Reports); and Rule 62-297.310(7), F.A.C. (Special Compliance Tests).

**SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.**

**Subsection C. Engines (EU-039)**

The specific conditions in this subsection apply to the following emissions unit.

| EU No. | Engine                                 | Qty. | In-Service Date | Engine Displacement       | Engine Model Year | Rating   | Rule Applicability                              |
|--------|--|------|-----------------|---------------------------|-------------------|----------|---|
| 039    | Standby Diesel Generator               | 1    | 02/1980         | 638 cu. in. (10.5 litre)  | 1979              | 227 bHP  | NESHAP Subparts A, ZZZZ                         |
|        | Diesel Emergency Fire Pump Engine      | 1    | 02/2007         | 358 cu. in. (5.9 litre)   | 2006              | 188 bHP  | NSPS Subparts A, IIII<br>NESHAP Subpart A, ZZZZ |
|        | Diesel Emergency Backup Generator      | 1    | 09/2008         | 912 cu. in. (14.9 litre)  | 2007              | 755 bHP  |   |
|        | Diesel Emergency Black Start Generator | 1    | 04/2009         | 1943 cu. in. (31.8 litre) | 2007              | 1495 bHP |   |

**New Source Performance Standards**

- C.1. NSPS Subpart A: As identified in the above table, five of the engines are subject to the applicable regulations in Subpart A (General Provisions) of 40 CFR 60. See Appendix NS.
- C.2. NSPS Subpart IIII: As identified in the above table, five of the engines are subject the applicable regulations in Subpart IIII (Stationary Compression Ignition Internal Combustion Engines) of 40 CFR 60. See Appendix IIII.

**National Emission Standards for Hazardous Air Pollutants**

- C.3. NESHAP Subpart A: All engines identified in the above table are subject to applicable requirements in Subpart A (General Provisions) of 40 CFR 63. See Appendix NE.
- C.4. NESHAP Subpart ZZZZ: All engines identified in the above table are subject to applicable requirements in Subpart ZZZZ (Reciprocating Internal Combustion Engines) of 40 CFR 63. See Appendix ZZZZ.
  - a. The Standby Diesel Generator (227 bHP) is an existing unit as defined by NESHAP Subpart ZZZZ; however, there are no unit-specific applicable requirements at this time.
  - b. The other engines are defined as new units by NESAHP Subpart ZZZZ. Pursuant to 40 CFR63.6590, these units comply with NESHAP Subpart ZZZZ by complying with NSPS Subpart IIII.

**SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.**

**Subsection D. Simple Cycle Combustion Turbines (EU-031 to EU-038)**

The specific conditions in this subsection apply to the following emissions units.

| EU No. | Unit No. | Generation | Emission Unit Description  |
|--------|----------|------------|--|
| 031    | Unit 3A  | 62 MW      | There are four Pratt & Whitney Model No. FT8-3 Swiftpac® aero-derivative simple cycle combustion turbine peaking units. Each Swiftpac® system includes two combustion turbines coupled with a single 62 MW electrical generator set. Each combustion turbine is considered an emissions unit and will fire only natural gas. NO <sub>x</sub> emissions are controlled with water injection and CO and VOC emissions are controlled with an oxidation catalyst system. Each combustion turbine has a separate stack that is approximately 9.5 feet in diameter and 60 feet tall. Exhaust gas exits each stack at a temperature of 893° F with a volumetric flow rate of 430,737 acfm. Each stack includes a CEMS for monitoring CO and NO <sub>x</sub> emissions. |
| 032    | Unit 3B  |            |  |
| 033    | Unit 4A  | 62 MW      |  |
| 034    | Unit 4B  |            |  |
| 035    | Unit 5A  | 62 MW      |  |
| 036    | Unit 5B  |            |  |
| 037    | Unit 6A  | 62 MW      |  |
| 038    | Unit 6B  |            |  |

**Essential Potential to Emit (PTE) Parameters**

- D.1. Permitted Capacity: The maximum heat input rate to each simple cycle combustion turbine is 342.7 MMBtu per hour when firing pipeline-quality natural gas based on 100% load, an ambient temperature of 59° F, evaporative cooling to a 52° F compressor inlet air temperature and the HHV of the fuel. Heat input rates will vary depending upon combustion turbine characteristics, ambient conditions and evaporative cooling. The permittee shall maintain on site manufacturer’s performance curves (or equations) that correct for site conditions. If these performance curves are updated, the permittee shall submit updated information to the Department. Operating data may be adjusted for the appropriate site conditions in accordance with the performance curves and/or equations on file with the Department. [Permit No. 0570040-026-AC and Rule 62-210.200(PTE), F.A.C.]
- D.2. Authorized Fuels: Each simple cycle combustion turbine shall fire only pipeline-quality natural gas, which shall contain no more than 2 grains of sulfur per 100 standard cubic feet of natural gas. [Rules 62-210.200(PTE) and 62-212.400(PSD), F.A.C.]
- D.3. Simple Cycle Mode: Each simple cycle combustion turbine shall operate only in simple cycle mode subject to the operational restrictions specified in this subsection. This requirement is based on the permittee’s initial request, which formed the basis of the PSD applicability and emission standards specified in this permit. For any request to convert these units to combined cycle operation by installing or connecting to heat recovery steam generators, including changes to the fuel or quantity related to combined cycle conversion that may cause an increase in short or long-term emissions, the permittee shall submit a full application for a PSD air construction permit modification complete with a proposed best available control technology (BACT) determination as if the simple cycle combustion turbine had never been built. [Rules 62-210.200(BACT and PTE), 62-212.400(12)(Source Obligation) and 62-212.400(PSD), F.A.C.]
- D.4. Hours of Operation: Each simple cycle combustion turbine is limited to a maximum of 3500 hours per year of operation. [Permit No. 0570040-026-AC; and Rules 62-210.200(PTE) and 62-212.400(12)(Source Obligation), F.A.C.]

**Equipment Description**

- D.5. Simple Cycle Combustion Turbine: The permittee is authorized to operate, tune and maintain four Pratt & Whitney Model No. FT8-3 SwiftPac® aeroderivative simple cycle combustion turbine-electrical generator sets to operate in simple cycle mode. For each SwiftPac®, two combustion turbines are coupled to one common electrical generator set having a total nominal gross generation capacity of 62 MW. [Permit No. 0570040-026-AC and Rules 62-210.200(PTE) and 62-212.400(12)(Source Obligation), F.A.C.]

**SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.**

**Subsection D. Simple Cycle Combustion Turbines (EU-031 to EU-038)**

**Control Technology**

D.6. Water Injection System: The permittee shall operate and maintain a water injection system to reduce NO<sub>x</sub> emissions from each simple cycle combustion turbine. The water injection system shall be maintained and tuned in accordance with the manufacturer’s recommendations or determined best practices to achieve the permitted NO<sub>x</sub> emissions standards. [Permit No. 0570040-026-AC and Rule 62-4.070(3), F.A.C.]

D.7. Oxidation Catalyst System: The permittee shall operate and maintain an oxidation catalyst system to reduce CO and VOC emissions from the simple cycle combustion turbines. The oxidation catalyst system shall be maintained and operated in accordance with the manufacturer’s recommendations or determined best practices. [Permit No. 0570040-026-AC and Rule 62-4.070(3), F.A.C.]

**Emission Limitations and Standards**

*{Permitting Note: The attached Table 1, Summary of Air Pollutant Standards, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}*

D.8. Emission Standards: Emissions from each simple cycle combustion turbine shall not exceed the following standards.

| <b>Pollutant</b>             | <b>Emission Standard<sup>e</sup></b>             | <b>Averaging Time</b>            | <b>Compliance Method</b>                 | <b>Basis</b>  |
|------------------------------|--|----------------------------------|--|---|
| NO <sub>x</sub> <sup>a</sup> | 25.0 ppmvd @ 15% oxygen                          | 4-hour rolling avg. <sup>f</sup> | CEMS                                     | NSPS Subpart KKKK   |
|                              | 32.0 lb/hour<br>56.0 tons/year                   | Average of three,<br>1-hour runs | Annual RATA                              | Rule 62-4.070(3), F.A.C.  |
| CO <sup>b</sup>              | 21.0 ppmvd @ 15% oxygen                          | 3-hour rolling avg.              | CEMS                                     | Rule 62-212.400(12), F.A.C.<br>Source Obligation                      |
|                              | 9.1 lb/hour<br>8.2 tons/year                     | Average of three,<br>1-hour runs | Annual RATA                              |   |
| VOC <sup>b</sup>             | 5.1 lb/hour                                      | Average of three,<br>1-hour runs | One-Time Initial Test<br>CO is Surrogate | Rule 62-212.400(12), F.A.C.<br>Source Obligation                      |
| Visible Emissions            | < 20% opacity                                    | 6-minute block                   | Annual Test                              | Rule 62-296.320(4)(b)1,<br>F.A.C.                                     |
| PM <sup>c</sup>              | 2 grains sulfur/100 scf of gas                   | N/A                              | Recordkeeping                            | Vendor Data   |
| SO <sub>2</sub> <sup>d</sup> | 2 grains sulfur/100 scf of gas<br>0.060 lb/MMBtu | N/A                              | Recordkeeping                            | Rule 62-212.400(12), F.A.C.<br>Source Obligation<br>NSPS Subpart KKKK |
| SAM <sup>d</sup>             | 2 grains sulfur/100 scf of gas                   | N/A                              | Recordkeeping                            | Rule 62-212.400(12), F.A.C.<br>Source Obligation                      |

- a. Continuous compliance with the 4-hour rolling average NO<sub>x</sub> standards shall be demonstrated based on data collected by the required Continuous Emissions Monitoring System (CEMS). During an annual Relative Accuracy Test Audit (RATA) on the NO<sub>x</sub> CEMS, the permittee shall demonstrate compliance with the individual mass-based (lb/hour) standards.
- b. An oxidation catalyst shall be installed on each simple cycle combustion turbine to minimize the emissions of CO and VOC. Continuous compliance with the 3-hour rolling average CO standards shall be demonstrated based on data collected by the required CEMS. During an annual RATA on the CO CEMS, the permittee shall demonstrate compliance with the individual mass-based (lb/hour) standards. CO will be used as a surrogate for VOC emissions as a demonstration of good combustion. *{Permitting Note: For an initial demonstration of compliance with the VOC mass-based limit, a one-time compliance*

### SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

#### Subsection D. Simple Cycle Combustion Turbines (EU-031 to EU-038)

*test was conducted using EPA Method 25A on one simple cycle combustion turbine with an option to perform EPA Method 18 concurrently to deduct emissions of methane and ethane.}*

- c. The sulfur fuel specification combined with the efficient combustion design and operation of each simple cycle combustion turbine will minimize PM emissions, which are a surrogate for PM<sub>10</sub> emissions, in addition to compliance with the visible emissions standard. Compliance with the fuel specifications, CO standards, and visible emissions standards shall serve as indicators of good combustion. Compliance with the fuel specification shall be demonstrated by keeping records of the fuel sulfur content. Compliance with the visible emissions standard shall be demonstrated by conducting tests in accordance with EPA Method 9.
- d. The fuel sulfur specification effectively limits the potential emissions of SO<sub>2</sub> and sulfuric acid mist (SAM) from each simple cycle combustion turbine. Compliance with the fuel sulfur specification shall be the use of pipeline-quality natural gas. *{Permitting Note: Based on the fuel sulfur specification, potential SO<sub>2</sub> emissions are 1.9 lb/hour (0.03 lb/MWhr), which is equivalent to 0.0055 lb/MMBtu and is less than the Subpart KKKK standard of 0.060 lb/MMBtu.}*
- e. The mass-based emission standards are based on a turbine compressor inlet temperature of 59° F, evaporative cooling on, and the HHV of natural gas. Mass-based emission standards may be adjusted to actual test conditions in accordance with the performance curves and/or equations on file with the Department.
- f. Compliance with the NO<sub>x</sub> standard shall be in accordance with the requirements of Subpart KKKK in 40 CFR 60, as described in 40 CFR 60.4350(g).

*{Permitting Note: In combination with the annual restriction on hours of operation, the above emissions standards effectively limit annual potential emissions from the simple cycle combustion turbine.}*

[Rules 62-4.070(3), 62-210.200(PTE) and 62-212.400(PSD), F.A.C.; and Subpart KKKK in 40 CFR 60]

#### **Excess Emissions**

*{Permitting Note: Rule 62-210.700, F.A.C. (Excess Emissions) cannot vary or supersede any federal provision of the NSPS, NESHAP or Acid Rain programs.}*

- D.9. **Excess Emissions Prohibited - SIP:** Excess emissions caused entirely or in part by poor maintenance, poor operation or any other equipment or process failure that may reasonably be prevented during startup, shutdown or malfunction shall be prohibited. All such preventable emissions shall be included in any compliance determinations based on CEMS data. [Rules 62-210.700(4), F.A.C.]
- D.10. **Excess CO Emissions Allowed - SIP:** If excess CO emissions occur due to startup, shutdown, malfunction or tuning, CEMS data collected during such periods may be excluded from the compliance averages in accordance with the following requirements provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions are minimized. All periods of excluded data shall be consecutive for each such episode and only data obtained during the described episodes (startup, shutdown, malfunction and tuning) may be excluded in accordance with the procedures described in the CEMS Data Requirements of Appendix CM of this permit.
  - a. *Startup:* No more than the first 10 minutes of CEMS data collected during startup shall be excluded for each simple cycle combustion turbine. For startups of less than 10 minutes in duration, only those minutes attributable to startup shall be excluded.
  - b. *Shutdown:* No more than the first 10 minutes of CEMS data collected during shutdown shall be excluded for each simple cycle combustion turbine. For shutdowns less than 10 minutes in duration, only those minutes attributable to shutdown shall be excluded.

### SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

#### Subsection D. Simple Cycle Combustion Turbines (EU-031 to EU-038)

- c. *Malfunction*: No more than 120 minutes of CEMS data in a 24-hour period shall be excluded due to malfunctions of each gas turbine or control system. Within one working day of occurrence, the owner or operator shall notify the Compliance Authority of any malfunction resulting in the exclusion of CEMS data.
- d. *Tuning*: "Tuning" means adjusting the combustors in accordance with the manufacturer's recommendations (or industry standards) or modifying the water-to-fuel ratio to affect a change in the post-combustion air emissions. Such tuning sessions are infrequent. Excess CEMS emissions data collected during tuning may be excluded from the compliance averages.

As provided by the authority in Rule 62-210.700(5), F.A.C., the above conditions replace the provisions in Rule 62-210.700(1), F.A.C. All valid emissions data (including data collected during startup, shutdown, malfunction and tuning) shall be used to report annual emissions for the Annual Operating Report. The permittee shall notify the Compliance Authority within one working day of discovering any emissions in excess of a CEMS standard subject to the specified averaging period. All such reasonably preventable emissions shall be included in any CEMS compliance determinations. All valid emissions data (including data collected during startup, shutdown and malfunction) shall be used to report annual emissions for the Annual Operating Report. [Rules 62-4.070(3), 62-210.200, 62-210.370(3) and 62-210.700(4), F.A.C.]

- D.11. Excess Emissions - NSPS: Excess NO<sub>x</sub> emissions shall be regulated in accordance with 40 CFR 60.4350 and 60.4380. Excess SO<sub>2</sub> emissions shall be regulated in accordance with 40 CFR 60.4385. See Appendix KKKK (NSPS Subpart KKKK Requirements for Stationary Combustion Turbines) of this permit. [NSPS Subpart KKKK in 40 CFR 60 and Rule 62-204.800, F.A.C.]
- D.12. Notification Requirements: The permittee shall notify the Compliance Authority within one working day of discovering any emissions in excess of a standard subject to the specified averaging period and authorized data exclusion. The notice may be by telephone, facsimile transmittal or electronic mail. [Rule 62-4.070(3), F.A.C.]

#### **Monitoring of Operations**

- D.13. Monitoring of Capacity: The permittee shall monitor and record the heat input rate of each simple cycle combustion turbine on a daily average basis, considering the number of hours of operation during each day (including the times of startup, shutdown and malfunction). Such monitoring shall be made by monitoring daily rates of fuel consumption and heating value of natural gas in accordance with the provisions of 40 CFR 75, Appendix D. [Rule 62-4.070(3), F.A.C.]

#### **Continuous Monitoring Requirements**

- D.14. CEMS for Continuous Compliance: In accordance with the requirements in Appendix CM (Standard Continuous Monitoring Requirements) of this permit, the permittee shall calibrate, operate and maintain a CEMS to measure and record the emissions of CO and NO<sub>x</sub> from each simple cycle combustion turbine in terms of the applicable standards. The permittee shall demonstrate continuous compliance with the 3-hour rolling average CO emissions standards and with the 4-hour rolling average NO<sub>x</sub> emission standards based on data collected from each certified CEMS. Results of each RATA shall be submitted with the semiannual report. As required in Appendix CM, monitor availability shall be demonstrated by the Data Assessment Report required by Section 7 in Appendix F of 40 CFR 60. [Permit No. 0570040-026-AC; Rules 62-4.070(3) and 62-204.800, F.A.C.; and NSPS Subpart KKKK in 40 CFR 60]

#### **Test Methods and Procedures**

- D.15. Common Testing Requirements: See Appendix TR (Facility-Wide Testing Requirements) of this permit for notification, testing, recordkeeping and reporting requirements regarding a performance test. [Rules 62-204.800 and 62-297.310, F.A.C. and 40 CFR 60, Appendix A]

### SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

#### Subsection D. Simple Cycle Combustion Turbines (EU-031 to EU-038)

D.16. Test Methods: Required tests shall be performed in *accordance* with the following reference methods.

| Method | Description of Method and Comments  |
|--------|---|
| 1-4    | Methods for Determining Traverse Points, Velocity and Flow Rate, Gas Analysis, and Moisture Content: These methods shall be performed as necessary to support other methods.  |
| 7E     | Determination of NO <sub>x</sub> Emissions from Stationary Sources (Instrumental)   |
| 9      | Visual Determination of Opacity of Emissions from Stationary Sources  |
| 10     | Determination of Carbon Monoxide Emissions from Stationary Sources  |
| 18     | Measurement of Gaseous Organic Compound Emissions by Gas Chromatography<br>{Note: EPA Method 18 may be used (optional) concurrently with EPA Method 25A to deduct emissions of methane and ethane from the measured VOC emissions.} |
| 20     | Determination of NO <sub>x</sub> , SO <sub>2</sub> , and Diluent Emissions from Stationary Combustion Turbines  |
| 25A    | Determination of Total Gaseous Organic Concentrations Using a Flame Ionization Analyzer   |

The methods are described in 40 CFR 60, Appendix A, and adopted by reference in Rule 62-204.800, F.A.C. No other methods may be used for compliance testing unless prior written approval is received from the administrator of the Department's Emissions Monitoring Section in accordance with an alternate sampling procedure pursuant to Rule 62-297.620, F.A.C. [Rule 62-204.800, F.A.C. and 40 CFR 60, Appendix A]

D.17. Annual Compliance Testing: Annual compliance tests for visible emissions shall be conducted during each federal fiscal year (*October 1<sup>st</sup>* to September 30<sup>th</sup>). Data collected from the required CEMS quality assurance RATA shall be used to demonstrate compliance with the mass-based emissions standards (lb/hour) for NO<sub>x</sub> and CO. [Rules 62-4.070(3) and 62-297.310(7)(a)4, F.A.C.]

D.18. Testing Requirements: Compliance tests shall be conducted between 90% and 100% of permitted capacity in accordance with the requirements of Rule 62-297.310(2), F.A.C. For each visible emissions test, CO emissions recorded by the CEMS shall also be reported. The mass emission rate standards are based on a turbine compressor inlet temperature 59°F and 100% load. Mass emission rates may be adjusted from actual test conditions in accordance with the performance curves and/or equations on file with the Department. [Rules 62-4.070 and 62-297.310, F.A.C.; 40 CFR 60.8; and Appendix TR]

D.19. NSPS Compliance Demonstration: See 40 CFR 60.4400, 60.4405 and 60.4415 in Appendix KKKK (NSPS Subpart KKKK Requirements for Stationary Combustion Turbines) of this permit. [40 CFR 60.4400 and 60.4405; and Appendix KKKK of this permit]

D.20. Special Compliance Tests: When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it shall require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department. [Rule 62-297.310(7)(b), F.A.C.]

#### Reporting and Recordkeeping Requirements

D.21. Test Reports: The permittee shall prepare and submit reports for all required tests in accordance with the requirements specified in Appendix TR (Facility-Wide Testing Requirements) of this permit. [Rule 62-297.310(8), F.A.C. and Appendix D of this permit]

D.22. Monthly Operations Summary: By the 15<sup>th</sup> calendar day of each month, the permittee shall record the following for each fuel in a written or electronic log for each combustion turbine for the previous month of operation: fuel consumption, hours of operation and the updated calendar year totals for each. Information

### SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

#### Subsection D. Simple Cycle Combustion Turbines (EU-031 to EU-038)

recorded and stored as an electronic file shall be available for inspection and printing within at least three days of a request by the Department. [Rule 62-4.070(3), F.A.C.]

- D.23. **Fuel Sulfur Records:** Compliance with the fuel sulfur limit for natural gas shall be demonstrated by keeping reports obtained from the vendor indicating the average sulfur content of the natural gas being supplied from the pipeline for each month of operation. A representative sample shall be collected using ASTM D5287. Methods for determining the sulfur content of the natural gas shall be ASTM Method D1072, or alternatively D3246, D4084, D4468, D4810, D6228, D6667, or Gaseous Processors Association Standard 2377, or more recent versions. Any method deemed satisfactory for purposes of NSPS Subpart KKKK may be used to demonstrate compliance with the fuel sulfur limit for natural gas. [Rules 62-4.070(3) and 62-4.160(15), F.A.C.; 40 CFR 60.4415; and Appendix KKKK of this permit]
- D.24. **Emissions Performance Test Reports:** A report indicating the results of any required emissions performance test shall be submitted to the Compliance Authority no later than 45 days after completion of the last test run. The test report shall provide sufficient detail on the tested emission unit and the procedures used to allow the Department to determine if the test was properly conducted and if the test results were properly computed. At a minimum, the test report shall provide the applicable information listed in Rule 62-297.310(8)(c), F.A.C., and in Appendix D (Standard Testing Requirements) of this permit. [Rule 62-297.310(8), F.A.C. and Appendix D of this permit]
- D.25. **Excess Emissions Reporting:**
- Malfunction Notification:** If emissions in excess of a standard (subject to the specified averaging period) occur due to malfunction, the permittee shall notify the Compliance Authority within one working day of: the nature, extent, and duration of the excess emissions; the cause of the excess emissions; and the actions taken to correct the problem. In addition, the Department may request a written summary report of the incident.
  - SIP Semiannual Report:** Within 30 days following the end of each calendar semiannual period, the permittee shall submit a report to the Compliance Authority summarizing periods of CO emissions in excess of the permit standards following the NSPS format in 40 CFR 60.7(c), Subpart A. A summary of data excluded from SIP compliance calculations should also be provided. In addition, the report shall summarize the CO CEMS system monitors availability for the previous semiannual period. Results of each RATA shall be submitted with the semiannual report.
  - NSPS Semiannual Report:** Within 30 days following the calendar semiannual period, the permittee shall submit the written reports required by 40 CFR 60, Subpart KKKK (Standards of Performance for Stationary Combustion Turbines) for the semiannual period to the Compliance Authority. Excess NO<sub>x</sub> emissions must be reported for all periods of unit operation, including startup, shutdown and malfunction. Results of each RATA shall be submitted with the semiannual report. {Permitting Note: NSPS monitoring of fuel sulfur for SO<sub>2</sub> emissions is exempt pursuant to 40 CFR 60.4365 because the units fire gas from a pipeline with a valid purchase contract, tariff sheet or transportation contract for the fuel specifying the maximum total sulfur content as 20 grains of sulfur or less per 100 standard cubic feet of gas and has potential sulfur emissions of less than less than 0.060 lb SO<sub>2</sub>/MMBtu of heat input.}
- {Permitting Note: If there are no periods of excess emissions as defined in Subpart KKKK of 40 CFR 60, a statement to that effect may be submitted with the SIP Semiannual Report to suffice for the NSPS Semiannual Report.}*
- [Rules 62-4.130, 62-204.800 and 62-210.700(6), F.A.C.; and 40 CFR 60.7 and 60.4375]
- D.26. **Reporting Schedule:** The following reports and notifications shall be submitted to the Compliance Authority:



**SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.**

**Subsection D. Simple Cycle Combustion Turbines (EU-031 to EU-038)**

| <b>Report</b>  | <b>Reporting Deadline</b>   | <b>Related Conditions</b>   |
|--|---|-----------------------------|
| Data Assessment Report for Quality Assurance for each CO and CO <sub>2</sub> Monitor                       | Done each calendar quarter and reported semi-annually to the Compliance Authority   | D.14                        |
| Semiannual SIP Excess Emissions Report for CO CEMS for Each Unit   | July 30 <sup>th</sup> (for January through June), and January 30 <sup>th</sup> (July through December)  | D.25                        |
| Semiannual NSPS Excess Emissions Report for NO <sub>x</sub> CEMS for Each Unit                             | July 30 <sup>th</sup> (for January through June), and January 30 <sup>th</sup> (July through December)  | D.25                        |
| Corrective Action Report for Monitor Availability for each CO, CO <sub>2</sub> and NO <sub>x</sub> Monitor | If monitor availability is less than 95% in any calendar quarter, provide report to Compliance Authority identifying the problems and a plan of corrective actions. | Condition 14 in Appendix CM |

*{Permitting Note: See Appendix RR, Facility-Wide Reporting Requirements, for additional reporting requirements.}*

**NSPS Provisions**

D.27. **NSPS Requirements:** Each simple cycle combustion turbine shall comply with the applicable requirements in NSPS Subparts A (General Provisions) and KKKK (Standards of Performance for Stationary Combustion Turbines for which Construction is Commenced after February 18, 2005) in 40 CFR 60. See Appendix F for the NSPS Subpart A provisions and Appendix NS and KKKK, respectively. Some separate reporting and monitoring may be required by the individual subparts. [Rule 62-204.800(7)(b), F.A.C. and Subparts A and KKKK in 40 CFR 60]

**SECTION IV. ACID RAIN PART.**

**Subsection A. Gas Turbines – Combined Cycle Units**

**Operated by:** Tampa Electric

**ORIS Code:** 7873

The emissions units listed below are regulated under Acid Rain, Phase II.

| EU No. | EPA Unit ID No. | Brief Description   |
|--------|-----------------|---|
| 020    | CT-1A           | Combined Cycle Gas Turbine CT-1A                                |
| 021    | CT-1B           | Combined Cycle Gas Turbine CT-1B                                |
| 022    | CT-1C           | Combined Cycle Gas Turbine CT-1C                                |
| 023    | CT-2A           | Combined Cycle Gas Turbine CT-2A                                |
| 024    | CT-2B           | Combined Cycle Gas Turbine CT-2B                                |
| 025    | CT-2C           | Combined Cycle Gas Turbine CT-2C                                |
| 026    | CT-2D           | Combined Cycle Gas Turbine CT-2D                                |
| 031    | Unit 3A         | Aero-derivative Simple Cycle Combustion Turbine Peaking Unit 3A |
| 032    | Unit 3B         | Aero-derivative Simple Cycle Combustion Turbine Peaking Unit 3B |
| 033    | Unit 4A         | Aero-derivative Simple Cycle Combustion Turbine Peaking Unit 4A |
| 034    | Unit 4B         | Aero-derivative Simple Cycle Combustion Turbine Peaking Unit 4B |
| 035    | Unit 5A         | Aero-derivative Simple Cycle Combustion Turbine Peaking Unit 5A |
| 036    | Unit 5B         | Aero-derivative Simple Cycle Combustion Turbine Peaking Unit 5B |
| 037    | Unit 6A         | Aero-derivative Simple Cycle Combustion Turbine Peaking Unit 6A |
| 038    | Unit 6B         | Aero-derivative Simple Cycle Combustion Turbine Peaking Unit 6B |

*{Permitting Note: In accordance with the Consent Final Judgment (DEP vs. TECO) dated December 6, 1999 and the Consent Decree (U.S. vs. TECO) dated February 29, 2000, coal-fired Emissions Units 001 through 006 are permanently shut down. As required by these agreements, Emission Units 001 through 006 are permanently shutdown, dismantled and removed from the site. Previously, the permittee submitted the appropriate Retired Emissions Units Acid Rain forms.}*

**A.1.** The Phase II Acid Rain Part application submitted for this facility, as approved by the Department, is a part of this permit. The owners and operators of these Phase II acid rain units must comply with the standard requirements and special provisions set forth in the application listed below:

- a. DEP Form No. 62-210.900(1)(a), dated 05/18/2009, received 05/20/2009.
- b. DEP Form No. 62-210.900(1)(a), dated 05/18/2009, received 05/20/2009.

[Chapter 62-213, F.A.C. and Rule 62-214.320, F.A.C.]

**A.2.** Sulfur dioxide (SO<sub>2</sub>) Emission Allowances. SO<sub>2</sub> emissions from sources subject to the Federal Acid Rain Program (Title IV) shall not exceed any allowances that the source lawfully holds under the Federal Acid Rain Program. Allowances shall not be used to demonstrate compliance with a non-Title IV applicable requirement of the Act.

- a. No permit revision shall be required for increases in emissions that are authorized by allowances acquired pursuant to the Federal Acid Rain Program, provided that such increases do not require a permit revision pursuant to Rule 62-213.400(3), F.A.C.
- b. No limit shall be placed on the number of allowances held by the source under the Federal Acid Rain Program.
- c. Allowances shall be accounted for under the Federal Acid Rain Program.

[Rule 62-213.440(1)(c)1, 2 and 3, F.A.C.]

**SECTION IV. ACID RAIN PART.**

**Subsection A. Gas Turbines – Combined Cycle Units**

## Acid Rain Part Application

For more information, see instructions and refer to 40 CFR 72.30, 72.31, and 74; and Chapter 62-214, F.A.C.

This submission is:  New     Revised     Renewal

**STEP 1**

Identify the source by plant name, state, and ORIS or plant code.

|                       |         |                 |
|-----------------------|---------|-----------------|
| Bayside Power Station | Florida | 7873            |
| Plant name            | State   | ORIS/Plant Code |

**STEP 2**

Enter the unit ID# for every Acid Rain unit at the Acid Rain source in column "a."

If unit a SO<sub>2</sub> Opt-in unit, enter "yes" in column "b".

For new units or SO<sub>2</sub> Opt-In units, enter the requested information in columns "d" and "e."

| a        | b   | c  | d  | e   |
|----------|---|--|--|---|
| Unit ID# | SO <sub>2</sub> Opt-in Unit?<br>(Yes or No) | Unit will hold allowances in accordance with 40 CFR 72.9(c)(1) | New or SO <sub>2</sub> Opt-In Units<br>Commence Operation Date | New or SO <sub>2</sub> Opt-In Units<br>Monitor Certification Deadline |
| CT1A     | No  | Yes  | N/A  | N/A   |
| CT1B     | No  | Yes  | N/A  | N/A   |
| CT1C     | No  | Yes  | N/A  | N/A   |
| CT2A     | No  | Yes  | N/A  | N/A   |
| CT2B     | No  | Yes  | N/A  | N/A   |
| CT2C     | No  | Yes  | N/A  | N/A   |
| CT2D     | No  | Yes  | N/A  | N/A   |
|          |   | Yes  |  |   |
|          |   | Yes  |  |   |
|          |   | Yes  |  |   |
|          |   | Yes  |  |   |
|          |   | Yes  |  |   |

## SECTION IV. ACID RAIN PART.

### Subsection A. Gas Turbines – Combined Cycle Units

#### Bayside Power Station

Name (from STEP 1)

#### STEP 3

Read the standard requirements.

#### Acid Rain Part Requirements.

- (1) The designated representative of each Acid Rain source and each Acid Rain unit at the source shall:
  - (i) Submit a complete Acid Rain Part application (including a compliance plan) under 40 CFR Part 72 and Rules 62-214.320 and 330, F.A.C., in accordance with the deadlines specified in Rule 62-214.320, F.A.C.; and
  - (ii) Submit in a timely manner any supplemental information that the DEP determines is necessary in order to review an Acid Rain Part application and issue or deny an Acid Rain Part;
- (2) The owners and operators of each Acid Rain source and each Acid Rain unit at the source shall:
  - (i) Operate the unit in compliance with a complete Acid Rain Part application or a superseding Acid Rain Part issued by the DEP; and
  - (ii) Have an Acid Rain Part.

#### Monitoring Requirements.

- (1) The owners and operators and, to the extent applicable, designated representative of each Acid Rain source and each Acid Rain unit at the source shall comply with the monitoring requirements as provided in 40 CFR Part 75, and Rule 62-214.420, F.A.C.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR Part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program.
- (3) The requirements of 40 CFR Part 75 shall not affect the responsibility of the owners and operators to monitor emissions of other pollutants or other emissions characteristics at the unit under other applicable requirements of the Act and other provisions of the operating permit for the source.
- (4) For applications including a SO<sub>2</sub> Opt-in unit, a monitoring plan for each SO<sub>2</sub> Opt-in unit must be submitted with this application pursuant to 40 CFR 74.14(a). For renewal applications for SO<sub>2</sub> Opt-in units include an updated monitoring plan if applicable under 40 CFR 75.53(b).

#### Sulfur Dioxide Requirements.

- (1) The owners and operators of each source and each Acid Rain unit at the source shall:
  - (i) Hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)), or in the compliance subaccount of another Acid Rain unit at the same source to the extent provided in 40 CFR 73.35(b)(3), not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and
  - (ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide.
- (2) Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act.
- (3) An Acid Rain unit shall be subject to the requirements under paragraph (1) of the sulfur dioxide requirements as follows:
  - (i) Starting January 1, 2000, an Acid Rain unit under 40 CFR 72.6(a)(2); or
  - (ii) Starting on the later of January 1, 2000, or the deadline for monitor certification under 40 CFR Part 75, an Acid Rain unit under 40 CFR 72.6(a)(3).
- (4) Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program.
- (5) An allowance shall not be deducted in order to comply with the requirements under paragraph (1) of the sulfur dioxide requirements prior to the calendar year for which the allowance was allocated.
- (6) An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain Part application, the Acid Rain Part, or an exemption under 40 CFR 72.7 or 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization.
- (7) An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right.

Nitrogen Oxides Requirements. The owners and operators of the source and each Acid Rain unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides.

#### Excess Emissions Requirements.

- (1) The designated representative of an Acid Rain unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR Part 77.
- (2) The owners and operators of an Acid Rain unit that has excess emissions in any calendar year shall:
  - (i) Pay without demand the penalty required, and pay upon demand the interest on that penalty, as required by 40 CFR Part 77; and
  - (ii) Comply with the terms of an approved offset plan, as required by 40 CFR Part 77.

#### Recordkeeping and Reporting Requirements.

- (1) Unless otherwise provided, the owners and operators of the source and each Acid Rain unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 5 years, in writing by the EPA or the DEP:
  - (i) The certificate of representation for the designated representative for the source and each Acid Rain unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with Rule 62-214.350, F.A.C.; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative;
  - (ii) All emissions monitoring information, in accordance with 40 CFR Part 75, provided that to the extent that 40 CFR Part 75 provides for a 3-year period for recordkeeping, the 3-year period shall apply;
  - (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the Acid Rain Program; and

**SECTION IV. ACID RAIN PART.**

**Subsection A. Gas Turbines – Combined Cycle Units**

|   |
|---|
| <p><b>Bayside Power Station</b></p> <p>Plant Name (from STEP 1)</p> |
|---|

**STEP 3,  
Continued.**

Recordkeeping and Reporting Requirements (cont)

(iv) Copies of all documents used to complete an Acid Rain Part application and any other submission under the Acid Rain Program or to demonstrate compliance with the requirements of the Acid Rain Program.

(2) The designated representative of an Acid Rain source and each Acid Rain unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR Part 72, Subpart I, and 40 CFR Part 75.

Liability.

(1) Any person who knowingly violates any requirement or prohibition of the Acid Rain Program, a complete Acid Rain Part application, an Acid Rain Part, or an exemption under 40 CFR 72.7 or 72.8, including any requirement for the payment of any penalty owed to the United States, shall be subject to enforcement pursuant to section 113(c) of the Act.

(2) Any person who knowingly makes a false, material statement in any record, submission, or report under the Acid Rain Program shall be subject to criminal enforcement pursuant to section 113(c) of the Act and 18 U.S.C. 1001.

(3) No permit revision shall excuse any violation of the requirements of the Acid Rain Program that occurs prior to the date that the revision takes effect.

(4) Each Acid Rain source and each Acid Rain unit shall meet the requirements of the Acid Rain Program.

(5) Any provision of the Acid Rain Program that applies to an Acid Rain source (including a provision applicable to the designated representative of an Acid Rain source) shall also apply to the owners and operators of such source and of the Acid Rain units at the source.

(8) Any provision of the Acid Rain Program that applies to an Acid Rain unit (including a provision applicable to the designated representative of an Acid Rain unit) shall also apply to the owners and operators of such unit. Except as provided under 40 CFR 72.44 (Phase II repowering extension plans) and 40 CFR 76.11 (NO<sub>x</sub> averaging plans), and except with regard to the requirements applicable to units with a common stack under 40 CFR Part 75 (including 40 CFR 75.16, 75.17, and 75.18), the owners and operators and the designated representative of one Acid Rain unit shall not be liable for any violation by any other Acid Rain unit of which they are not owners or operators or the designated representative and that is located at a source of which they are not owners or operators or the designated representative.

(7) Each violation of a provision of 40 CFR Parts 72, 73, 74, 75, 76, 77, and 78 by an Acid Rain source or Acid Rain unit, or by an owner or operator or designated representative of such source or unit, shall be a separate violation of the Act.

Effect on Other Authorities.

No provision of the Acid Rain Program, an Acid Rain Part application, an Acid Rain Part, or an exemption under 40 CFR 72.7 or 72.8 shall be construed as:

(1) Except as expressly provided in title IV of the Act, exempting or excluding the owners and operators and, to the extent applicable, the designated representative of an Acid Rain source or Acid Rain unit from compliance with any other provision of the Act, including the provisions of title I of the Act relating to applicable National Ambient Air Quality Standards or State Implementation Plans;

(2) Limiting the number of allowances a unit can hold; provided, that the number of allowances held by the unit shall not affect the source's obligation to comply with any other provisions of the Act;

(3) Requiring a change of any kind in any state law regulating electric utility rates and charges, affecting any state law regarding such state regulation, or limiting such state regulation, including any prudence review requirements under such state law;

(4) Modifying the Federal Power Act or affecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act; or

(5) Interfering with or impairing any program for competitive bidding for power supply in a state in which such program is established.

**STEP 4**

**For SO<sub>2</sub> Opt-In units only.**

**In column "f" enter the unit ID# for every SO<sub>2</sub> Opt-In unit identified in column "a" of STEP 2.**

**For column "g" describe the combustion unit and attach information and diagrams on the combustion unit's configuration.**

**In column "h" enter the hours.**

| f        | g                                  | h (not required for renewal application)                                      |
|----------|------------------------------------|---|
| Unit ID# | Description of the combustion unit | Number of hours unit operated in the six months preceding initial application |
|          |                                    |   |
|          |                                    |   |
|          |                                    |   |
|          |                                    |   |
|          |                                    |   |
|          |                                    |   |
|          |                                    |   |

**SECTION IV. ACID RAIN PART.**

**Subsection A. Gas Turbines – Combined Cycle Units**

|                              |
|------------------------------|
| <b>Bayside Power Station</b> |
| Plant Name (from STEP 1)     |

**STEP 5**

For SO<sub>2</sub> Opt-in units only.  
(Not required for SO<sub>2</sub> Opt-in renewal applications.)

In column "i" enter the unit ID# for every SO<sub>2</sub> Opt-in unit identified in column "a" (and in column "f").

For columns "j" through "n," enter the information required under 40 CFR 74.20-74.25 and attach all supporting documentation required by 40 CFR 74.20-74.25.

| i        | j  | k   | l   | m  | n  |
|----------|--|---|---|--|--|
| Unit ID# | Baseline or Alternative Baseline under 40 CFR 74.20<br>(mmBtu) | Actual SO <sub>2</sub> Emissions Rate under 40 CFR 74.22<br>(lbs/mmBtu) | Allowable 1985 SO <sub>2</sub> Emissions Rate under 40 CFR 74.23<br>(lbs/mmBtu) | Current Allowable SO <sub>2</sub> Emissions Rate under 40 CFR 74.24<br>(lbs/mmBtu) | Current Promulgated SO <sub>2</sub> Emissions Rate under 40 CFR 74.25<br>(lbs/mmBtu) |
|          |  |   |   |  |  |
|          |  |   |   |  |  |
|          |  |   |   |  |  |
|          |  |   |   |  |  |
|          |  |   |   |  |  |
|          |  |   |   |  |  |
|          |  |   |   |  |  |
|          |  |   |   |  |  |
|          |  |   |   |  |  |

**STEP 6**

For SO<sub>2</sub> Opt-in units only.

Attach additional requirements, certify and sign.

- A. If the combustion source seeks to qualify for a transfer of allowances from the replacement of thermal energy, a thermal energy plan as provided in 40 CFR 74.47 for combustion sources must be attached.
- B. A statement whether the combustion unit was previously an affected unit under 40 CFR 74.
- C. A statement that the combustion unit is not an affected unit under 40 CFR 72.6 and does not have an exemption under 40 CFR 72.7, 72.8, or 72.14.
- D. Attach a complete compliance plan for SO<sub>2</sub> under 40 CFR 72.40.
- E. The designated representative of the combustion unit shall submit a monitoring plan in accordance with 40 CFR 74.61. For renewal application, submit an updated monitoring plan if applicable under 40 CFR 75.53(b).
- F. The following statement must be signed by the designated representative or alternate designated representative of the combustion source: "I certify that the data submitted under 40 CFR Part 74, Subpart C, reflects actual operations of the combustion source and has not been adjusted in any way."


|           |      |
|-----------|------|
| Signature | Date |
|-----------|------|

**STEP 7**

Read the certification statement; provide name, title, owner company name, phone, and e-mail address; sign, and date.

**Certification (for designated representative or alternate designated representative only)**

I am authorized to make this submission on behalf of the owners and operators of the Acid Rain source or Acid Rain units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

|  |  |
|--|--|
| Byron T. Burrows<br>Name   | Manager – Air Programs, EHS<br>Title       |
| Tampa Electric Company<br>Owner Company Name   |  |
| (813) 228-4740<br>Phone  | btburrows@tecoenergy.com<br>E-mail address |
| <br>Signature | Date 5/18/09                               |

DEP Form No. 62-210.900(1)(a) – Form  
Effective: 3/16/08

**SECTION IV. ACID RAIN PART.**

**Subsection A. Gas Turbines – Simple Cycle Units**

# Acid Rain Part Application

For more information, see instructions and refer to 40 CFR 72.30, 72.31, and 74; and Chapter 62-214, F.A.C.

This submission is:  New     Revised     Renewal

**STEP 1**

Identify the source by plant name, state, and ORIS or plant code.

|                              |                |                 |
|------------------------------|----------------|-----------------|
| <b>Bayside Power Station</b> | <b>Florida</b> | <b>7873</b>     |
| Plant name                   | State          | ORIS/Plant Code |

**STEP 2**

Enter the unit ID# for every Acid Rain unit at the Acid Rain source in column "a."

If unit a SO<sub>2</sub> Opt-in unit, enter "yes" in column "b".

For new units or SO<sub>2</sub> Opt-in units, enter the requested information in columns "d" and "e."

| a           | b   | c  | d  | e   |
|-------------|---|--|--|---|
| Unit ID#    | SO <sub>2</sub> Opt-In Unit?<br>(Yes or No) | Unit will hold allowances in accordance with 40 CFR 72.9(c)(1) | New or SO <sub>2</sub> Opt-In Units<br><br>Commence Operation Date | New or SO <sub>2</sub> Opt-In Units<br><br>Monitor Certification Deadline |
| CT3A (#031) | No  | Yes  | N/A  | N/A   |
| CT3B (#032) | No  | Yes  | N/A  | N/A   |
| CT4A (#033) | No  | Yes  | N/A  | N/A   |
| CT4B (#034) | No  | Yes  | N/A  | N/A   |
| CT5A (#035) | No  | Yes  | N/A  | N/A   |
| CT5B (#036) | No  | Yes  | N/A  | N/A   |
| CT6A (#037) | No  | Yes  | N/A  | N/A   |
| CT6B (#038) | No  | Yes  | N/A  | N/A   |
|             |   | Yes  |  |   |
|             |   | Yes  |  |   |
|             |   | Yes  |  |   |
|             |   | Yes  |  |   |

**SECTION IV. ACID RAIN PART.**  
**Subsection A. Gas Turbines – Simple Cycle Units**

**Bayside Power Station**

Name (from STEP 1)

**STEP 3**

**Read the standard requirements.**

**Acid Rain Part Requirements.**

- (1) The designated representative of each Acid Rain source and each Acid Rain unit at the source shall:
  - (i) Submit a complete Acid Rain Part application (including a compliance plan) under 40 CFR Part 72 and Rules 62-214.320 and 330, F.A.C. in accordance with the deadlines specified in Rule 62-214.320, F.A.C.; and
  - (ii) Submit in a timely manner any supplemental information that the DEP determines is necessary in order to review an Acid Rain Part application and issue or deny an Acid Rain Part;
- (2) The owners and operators of each Acid Rain source and each Acid Rain unit at the source shall:
  - (i) Operate the unit in compliance with a complete Acid Rain Part application or a superseding Acid Rain Part issued by the DEP; and
  - (ii) Have an Acid Rain Part.

**Monitoring Requirements.**

- (1) The owners and operators and, to the extent applicable, designated representative of each Acid Rain source and each Acid Rain unit at the source shall comply with the monitoring requirements as provided in 40 CFR Part 75, and Rule 62-214.420, F.A.C.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR Part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program.
- (3) The requirements of 40 CFR Part 75 shall not affect the responsibility of the owners and operators to monitor emissions of other pollutants or other emissions characteristics at the unit under other applicable requirements of the Act and other provisions of the operating permit for the source.
- (4) For applications including a SO<sub>2</sub> Opt-in unit, a monitoring plan for each SO<sub>2</sub> Opt-in unit must be submitted with this application pursuant to 40 CFR 74.14(a). For renewal applications for SO<sub>2</sub> Opt-in units include an updated monitoring plan if applicable under 40 CFR 75.53(b).

**Sulfur Dioxide Requirements.**

- (1) The owners and operators of each source and each Acid Rain unit at the source shall:
  - (i) Hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)), or in the compliance subaccount of another Acid Rain unit at the same source to the extent provided in 40 CFR 73.35(b)(3), not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and
  - (ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide.
- (2) Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act.
- (3) An Acid Rain unit shall be subject to the requirements under paragraph (1) of the sulfur dioxide requirements as follows:
  - (i) Starting January 1, 2000, an Acid Rain unit under 40 CFR 72.6(a)(2); or
  - (ii) Starting on the later of January 1, 2000, or the deadline for monitor certification under 40 CFR Part 75, an Acid Rain unit under 40 CFR 72.6(a)(3).
- (4) Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program.
- (5) An allowance shall not be deducted in order to comply with the requirements under paragraph (1) of the sulfur dioxide requirements prior to the calendar year for which the allowance was allocated.
- (6) An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain Part application, the Acid Rain Part, or an exemption under 40 CFR 72.7 or 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization.
- (7) An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right.

**Nitrogen Oxides Requirements.** The owners and operators of the source and each Acid Rain unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides.

**Excess Emissions Requirements.**

- (1) The designated representative of an Acid Rain unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR Part 77.
- (2) The owners and operators of an Acid Rain unit that has excess emissions in any calendar year shall:
  - (i) Pay without demand the penalty required, and pay upon demand the interest on that penalty, as required by 40 CFR Part 77; and
  - (ii) Comply with the terms of an approved offset plan, as required by 40 CFR Part 77.

**Recordkeeping and Reporting Requirements.**

- (1) Unless otherwise provided, the owners and operators of the source and each Acid Rain unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 5 years, in writing by the EPA or the DEP:
  - (i) The certificate of representation for the designated representative for the source and each Acid Rain unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with Rule 62-214.350, F.A.C.; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative;
  - (ii) All emissions monitoring information, in accordance with 40 CFR Part 75, provided that to the extent that 40 CFR Part 75 provides for a 3-year period for recordkeeping, the 3-year period shall apply;
  - (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the Acid Rain Program; and,



**SECTION IV. ACID RAIN PART.**  
**Subsection A. Gas Turbines – Simple Cycle Units**

**Bayside Power Station**

Plant Name (from STEP 1)

**STEP 3,  
Continued.**

**Recordkeeping and Reporting Requirements (cont)**

(iv) Copies of all documents used to complete an Acid Rain Part application and any other submission under the Acid Rain Program or to demonstrate compliance with the requirements of the Acid Rain Program.

(2) The designated representative of an Acid Rain source and each Acid Rain unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR Part 72, Subpart I, and 40 CFR Part 75.

**Liability.**

(1) Any person who knowingly violates any requirement or prohibition of the Acid Rain Program, a complete Acid Rain Part application, an Acid Rain Part, or an exemption under 40 CFR 72.7 or 72.8, including any requirement for the payment of any penalty owed to the United States, shall be subject to enforcement pursuant to section 113(c) of the Act.

(2) Any person who knowingly makes a false, material statement in any record, submission, or report under the Acid Rain Program shall be subject to criminal enforcement pursuant to section 113(c) of the Act and 18 U.S.C. 1001.

(3) No permit revision shall excuse any violation of the requirements of the Acid Rain Program that occurs prior to the date that the revision takes effect.

(4) Each Acid Rain source and each Acid Rain unit shall meet the requirements of the Acid Rain Program.

(5) Any provision of the Acid Rain Program that applies to an Acid Rain source (including a provision applicable to the designated representative of an Acid Rain source) shall also apply to the owners and operators of such source and of the Acid Rain units at the source.

(6) Any provision of the Acid Rain Program that applies to an Acid Rain unit (including a provision applicable to the designated representative of an Acid Rain unit) shall also apply to the owners and operators of such unit. Except as provided under 40 CFR 72.44 (Phase II repowering extension plans) and 40 CFR 76.11 (NO<sub>x</sub> averaging plans), and except with regard to the requirements applicable to units with a common stack under 40 CFR Part 75 (including 40 CFR 75.16, 75.17, and 75.18), the owners and operators and the designated representative of one Acid Rain unit shall not be liable for any violation by any other Acid Rain unit of which they are not owners or operators or the designated representative and that is located at a source of which they are not owners or operators or the designated representative.

(7) Each violation of a provision of 40 CFR Parts 72, 73, 74, 75, 76, 77, and 78 by an Acid Rain source or Acid Rain unit, or by an owner or operator or designated representative of such source or unit, shall be a separate violation of the Act.

**Effect on Other Authorities.**

No provision of the Acid Rain Program, an Acid Rain Part application, an Acid Rain Part, or an exemption under 40 CFR 72.7 or 72.8 shall be construed as:

(1) Except as expressly provided in title IV of the Act, exempting or excluding the owners and operators and, to the extent applicable, the designated representative of an Acid Rain source or Acid Rain unit from compliance with any other provision of the Act, including the provisions of title I of the Act relating to applicable National Ambient Air Quality Standards or State Implementation Plans;

(2) Limiting the number of allowances a unit can hold; *provided*, that the number of allowances held by the unit shall not affect the source's obligation to comply with any other provisions of the Act;

(3) Requiring a change of any kind in any state law regulating electric utility rates and charges, affecting any state law regarding such state regulation, or limiting such state regulation, including any prudence review requirements under such state law;

(4) Modifying the Federal Power Act or affecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act; or

(5) Interfering with or impairing any program for competitive bidding for power supply in a state in which such program is established.

**STEP 4  
For SO<sub>2</sub> Opt-In  
units only.**

In column "f" enter the unit ID# for every SO<sub>2</sub> Opt-In unit identified in column "a" of STEP 2.

For column "g" describe the combustion unit and attach information and diagrams on the combustion unit's configuration.

In column "h" enter the hours.

| f        | g                                  | h (not required for renewal application)                                      |
|----------|------------------------------------|---|
| Unit ID# | Description of the combustion unit | Number of hours unit operated in the six months preceding initial application |
|          |                                    |   |
|          |                                    |   |
|          |                                    |   |
|          |                                    |   |
|          |                                    |   |
|          |                                    |   |
|          |                                    |   |

**SECTION IV. ACID RAIN PART.**

**Subsection A. Gas Turbines – Simple Cycle Units**

|                              |
|------------------------------|
| <b>Bayside Power Station</b> |
| Plant Name (from STEP 1)     |

**STEP 5**

For SO<sub>2</sub> Opt-in units only.  
(Not required for SO<sub>2</sub> Opt-in renewal applications.)

In column "l" enter the unit ID# for every SO<sub>2</sub> Opt-in unit identified in column "a" (and in column "p").

For columns "j" through "n," enter the information required under 40 CFR 74.20-74.25 and attach all supporting documentation required by 40 CFR 74.20-74.25.

| l        | j   | k  | i  | m   | n   |
|----------|---|--|--|---|---|
| Unit ID# | Baseline or Alternative Baseline under 40 CFR 74.20 (mmBtu) | Actual SO <sub>2</sub> Emissions Rate under 40 CFR 74.22 (lbs/mmBtu) | Allowable 1985 SO <sub>2</sub> Emissions Rate under 40 CFR 74.23 (lbs/mmBtu) | Current Allowable SO <sub>2</sub> Emissions Rate under 40 CFR 74.24 (lbs/mmBtu) | Current Promulgated SO <sub>2</sub> Emissions Rate under 40 CFR 74.25 (lbs/mmBtu) |
|          |   |  |  |   |   |
|          |   |  |  |   |   |
|          |   |  |  |   |   |
|          |   |  |  |   |   |
|          |   |  |  |   |   |
|          |   |  |  |   |   |
|          |   |  |  |   |   |
|          |   |  |  |   |   |
|          |   |  |  |   |   |

**STEP 6**

For SO<sub>2</sub> Opt-in units only.


Attach additional requirements, certify and sign.

- A. If the combustion source seeks to qualify for a transfer of allowances from the replacement of thermal energy, a thermal energy plan as provided in 40 CFR 74.47 for combustion sources must be attached.
- B. A statement whether the combustion unit was previously an affected unit under 40 CFR 74.
- C. A statement that the combustion unit is not an affected unit under 40 CFR 72.6 and does not have an exemption under 40 CFR 72.7, 72.8, or 72.14.
- D. Attach a complete compliance plan for SO<sub>2</sub> under 40 CFR 72.40.
- E. The designated representative of the combustion unit shall submit a monitoring plan in accordance with 40 CFR 74.61. For renewal application, submit an updated monitoring plan if applicable under 40 CFR 75.53(b).
- F. The following statement must be signed by the designated representative or alternate designated representative of the combustion source: "I certify that the data submitted under 40 CFR Part 74, Subpart C, reflects actual operations of the combustion source and has not been adjusted in any way."

|           |      |
|-----------|------|
| Signature | Date |
|-----------|------|

**STEP 7**

Read the certification statement; provide name, title, owner company name, phone, and e-mail address; sign, and date.

|  |  |
|--|--|
| <b>Certification (for designated representative or alternate designated representative only)</b>   |  |
| I am authorized to make this submission on behalf of the owners and operators of the Acid Rain source or Acid Rain units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment. |  |
| Byron T. Burrows<br>Name   | Manager – Air Programs, EHS<br>Title       |
| Tampa Electric Company<br>Owner Company Name   |  |
| (813) 228-4740<br>Phone  | btburrows@tecoenergy.com<br>E-mail address |
| <br>Signature   | 4/14/10<br>Date                            |

DEP Form No. 62-210.900(1)(a) – Form Effective: 3/16/08

**SECTION V. CAIR PART.**

**SUBSECTION A. Clean Air Interstate Rule Provisions**

**Clean Air Interstate Rule (CAIR).**

**Operated by:** Tampa Electric Company  
**Plant:** H.L. Culbreath Bayside Power Station  
**ORIS Code:** 7873

The emissions units below are regulated under the Clean Air Interstate Rule.

| <b>EU No.</b> | <b>EPA Unit ID No.</b> | <b>Brief Description</b>  |
|---------------|------------------------|---|
| 020           | CT-1A                  | Combined Cycle Gas Turbine CT-1A                                |
| 021           | CT-1B                  | Combined Cycle Gas Turbine CT-1B                                |
| 022           | CT-1C                  | Combined Cycle Gas Turbine CT-1C                                |
| 023           | CT-2A                  | Combined Cycle Gas Turbine CT-2A                                |
| 024           | CT-2B                  | Combined Cycle Gas Turbine CT-2B                                |
| 025           | CT-2C                  | Combined Cycle Gas Turbine CT-2C                                |
| 026           | CT-2D                  | Combined Cycle Gas Turbine CT-2D                                |
| 031           | Unit 3A                | Aero-derivative Simple Cycle Combustion Turbine Peaking Unit 3A |
| 032           | Unit 3B                | Aero-derivative Simple Cycle Combustion Turbine Peaking Unit 3B |
| 033           | Unit 4A                | Aero-derivative Simple Cycle Combustion Turbine Peaking Unit 4A |
| 034           | Unit 4B                | Aero-derivative Simple Cycle Combustion Turbine Peaking Unit 4B |
| 035           | Unit 5A                | Aero-derivative Simple Cycle Combustion Turbine Peaking Unit 5A |
| 036           | Unit 5B                | Aero-derivative Simple Cycle Combustion Turbine Peaking Unit 5B |
| 037           | Unit 6A                | Aero-derivative Simple Cycle Combustion Turbine Peaking Unit 6A |
| 038           | Unit 6B                | Aero-derivative Simple Cycle Combustion Turbine Peaking Unit 6B |

**A.1. Clean Air Interstate Rule Application.** The Clean Air Interstate Rule Part Form submitted for this facility is a part of this permit. The owners and operators of these CAIR units as identified in this form must comply with the standard requirements and special provisions set forth in the CAIR Part Form (DEP Form No. 62-210.900(1)(b)) dated March 16, 2008, which is attached at the end of this section. [Chapter 62-213, F.A.C. and Rule 62-210.200, F.A.C.]



SECTION V. CAIR PART.

SUBSECTION A. Clean Air Interstate Rule Provisions – Combined Cycle Units

|                          |
|--------------------------|
| Bayside Power Station    |
| Plant Name (from STEP 1) |

STEP 3

Read the standard requirements.

CAIR NO<sub>x</sub> ANNUAL TRADING PROGRAM

CAIR Part Requirements.

- (1) The CAIR designated representative of each CAIR NO<sub>x</sub> source and each CAIR NO<sub>x</sub> unit at the source shall:
  - (i) Submit to the DEP a complete and certified CAIR Part form under 40 CFR 90.122 and Rule 62-286.470, F.A.C., in accordance with the deadlines specified in Rule 62-213.420, F.A.C.; and
  - (ii) [Reserved];
- (2) The owners and operators of each CAIR NO<sub>x</sub> source and each CAIR NO<sub>x</sub> unit at the source shall have a CAIR Part included in the Title V operating permit issued by the DEP under 40 CFR Part 90, Subpart CC, and operate the source and the unit in compliance with such CAIR Part.

Monitoring, Reporting, and Recordkeeping Requirements.

- (1) The owners and operators, and the CAIR designated representative, of each CAIR NO<sub>x</sub> source and each CAIR NO<sub>x</sub> unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR Part 90, Subpart HH, and Rule 62-286.470, F.A.C.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR Part 90, Subpart HH, shall be used to determine compliance by each CAIR NO<sub>x</sub> source with the following CAIR NO<sub>x</sub> Emissions Requirements.

NO<sub>x</sub> Emission Requirements.

- (1) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR NO<sub>x</sub> source and each CAIR NO<sub>x</sub> unit at the source shall hold, in the source's compliance account, CAIR NO<sub>x</sub> allowances available for compliance deductions for the control period under 40 CFR 90.154(a) in an amount not less than the tons of total NO<sub>x</sub> emissions for the control period from all CAIR NO<sub>x</sub> units at the source, as determined in accordance with 40 CFR Part 90, Subpart HH.
- (2) A CAIR NO<sub>x</sub> unit shall be subject to the requirements under paragraph (1) of the NO<sub>x</sub> Requirements starting on the later of January 1, 2009, or the deadline for meeting the unit's monitor certification requirements under 40 CFR 90.170(b)(1) or (2) and for each control period thereafter.
- (3) A CAIR NO<sub>x</sub> allowance shall not be deducted, for compliance with the requirements under paragraph (1) of the NO<sub>x</sub> Requirements, for a control period in a calendar year before the year for which the CAIR NO<sub>x</sub> allowance was allocated.
- (4) CAIR NO<sub>x</sub> allowances shall be held in, deducted from, or transferred into or among CAIR NO<sub>x</sub> Allowance Tracking System accounts in accordance with 40 CFR Part 90, Subparts FF and GG.
- (5) A CAIR NO<sub>x</sub> allowance is a limited authorization to emit one ton of NO<sub>x</sub> in accordance with the CAIR NO<sub>x</sub> Annual Trading Program. No provision of the CAIR NO<sub>x</sub> Annual Trading Program, the CAIR Part, or an exemption under 40 CFR 90.105 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.
- (6) A CAIR NO<sub>x</sub> allowance does not constitute a property right.
- (7) Upon recordation by the Administrator under 40 CFR Part 96, Subpart EE, FF, or GG, every allocation, transfer, or deduction of a CAIR NO<sub>x</sub> allowance to or from a CAIR NO<sub>x</sub> unit's compliance account is incorporated automatically in any CAIR Part of the source that includes the CAIR NO<sub>x</sub> unit.

Excess Emissions Requirements.

- If a CAIR NO<sub>x</sub> source emits NO<sub>x</sub> during any control period in excess of the CAIR NO<sub>x</sub> emissions limitation, then:
- (1) The owners and operators of the source and each CAIR NO<sub>x</sub> unit at the source shall surrender the CAIR NO<sub>x</sub> allowances required for deduction under 40 CFR 90.154(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or applicable state law; and
  - (2) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 90, Subpart AA, the Clean Air Act, and applicable state law.

Recordkeeping and Reporting Requirements.

- (1) Unless otherwise provided, the owners and operators of the CAIR NO<sub>x</sub> source and each CAIR NO<sub>x</sub> unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the DEP or the Administrator.
  - (i) The certificate of representation under 40 CFR 90.113 for the CAIR designated representative for the source and each CAIR NO<sub>x</sub> unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation, provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation under 40 CFR 90.113 changing the CAIR designated representative.
  - (ii) All emissions monitoring information, in accordance with 40 CFR Part 90, Subpart HH, of this part, provided that to the extent that 40 CFR Part 96, Subpart HH, provides for a 3-year period for recordkeeping, the 3-year period shall apply.
  - (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NO<sub>x</sub> Annual Trading Program.
  - (iv) Copies of all documents used to complete a CAIR Part form and any other submission under the CAIR NO<sub>x</sub> Annual Trading Program or to demonstrate compliance with the requirements of the CAIR NO<sub>x</sub> Annual Trading Program.
- (2) The CAIR designated representative of a CAIR NO<sub>x</sub> source and each CAIR NO<sub>x</sub> unit at the source shall submit the reports required under the CAIR NO<sub>x</sub> Annual Trading Program, including those under 40 CFR Part 90, Subpart HH.

SECTION V. CAIR PART.

SUBSECTION A. Clean Air Interstate Rule Provisions – Combined Cycle Units

|                              |
|------------------------------|
| <b>Bayside Power Station</b> |
|                              |
| Plant Name (from STEP 1)     |
|                              |

STEP 3,  
Continued

Liability.

- (1) Each CAIR NO<sub>x</sub> source and each CAIR NO<sub>x</sub> unit shall meet the requirements of the CAIR NO<sub>x</sub> Annual Trading Program.
- (2) Any provision of the CAIR NO<sub>x</sub> Annual Trading Program that applies to a CAIR NO<sub>x</sub> source or the CAIR designated representative of a CAIR NO<sub>x</sub> source shall also apply to the owners and operators of such source and of the CAIR NO<sub>x</sub> units at the source.
- (3) Any provision of the CAIR NO<sub>x</sub> Annual Trading Program that applies to a CAIR NO<sub>x</sub> unit or the CAIR designated representative of a CAIR NO<sub>x</sub> unit shall also apply to the owners and operators of such unit.

Effect on Other Authorities.

No provision of the CAIR NO<sub>x</sub> Annual Trading Program, a CAIR Part, or an exemption under 40 CFR 96.105 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR NO<sub>x</sub> source or CAIR NO<sub>x</sub> unit from compliance with any other provision of the applicable, approved State Implementation Plan, a federally enforceable permit, or the Clean Air Act.

**CAIR SO<sub>2</sub> TRADING PROGRAM**

CAIR Part Requirements.

- (1) The CAIR designated representative of each CAIR SO<sub>2</sub> source and each CAIR SO<sub>2</sub> unit at the source shall:
  - (i) Submit to the DEP a complete and certified CAIR Part form under 40 CFR 96.222 and Rule 62-296.470, F.A.C., in accordance with the deadlines specified in Rule 62-213.420, F.A.C.; and
  - (ii) [Reserved].
- (2) The owners and operators of each CAIR SO<sub>2</sub> source and each CAIR SO<sub>2</sub> unit at the source shall have a CAIR Part included in the Title V operating permit issued by the DEP under 40 CFR Part 96, Subpart CCC, for the source and operate the source and each CAIR unit in compliance with such CAIR Part.

Monitoring, Reporting, and Recordkeeping Requirements.

- (1) The owners and operators, and the CAIR designated representative, of each CAIR SO<sub>2</sub> source and each SO<sub>2</sub> CAIR unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR Part 96, Subpart HHH, and Rule 62-296.470, F.A.C.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR Part 96, Subpart HHH, shall be used to determine compliance by each CAIR SO<sub>2</sub> source with the following CAIR SO<sub>2</sub> Emission Requirements.

SO<sub>2</sub> Emission Requirements.

- (1) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR SO<sub>2</sub> source and each CAIR SO<sub>2</sub> unit at the source shall hold, in the source's compliance account, a tonnage equivalent in CAIR SO<sub>2</sub> allowances available for compliance deductions for the control period, as determined in accordance with 40 CFR 96.254(a) and (b), not less than the tons of total sulfur dioxide emissions for the control period from all CAIR SO<sub>2</sub> units at the source, as determined in accordance with 40 CFR Part 96, Subpart HHH.
- (2) A CAIR SO<sub>2</sub> unit shall be subject to the requirements under paragraph (1) of the Sulfur Dioxide Emission Requirements starting on the later of January 1, 2010 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 96.270(b)(1) or (2) and for each control period thereafter.
- (3) A CAIR SO<sub>2</sub> allowance shall not be deducted, for compliance with the requirements under paragraph (1) of the SO<sub>2</sub> Emission Requirements, for a control period in a calendar year before the year for which the CAIR SO<sub>2</sub> allowance was allocated.
- (4) CAIR SO<sub>2</sub> allowances shall be held in, deducted from, or transferred into or among CAIR SO<sub>2</sub> Allowance Tracking System accounts in accordance with 40 CFR Part 96, Subparts FFF and GGG.
- (5) A CAIR SO<sub>2</sub> allowance is a limited authorization to emit sulfur dioxide in accordance with the CAIR SO<sub>2</sub> Trading Program. No provision of the CAIR SO<sub>2</sub> Trading Program, the CAIR Part, or an exemption under 40 CFR 96.205 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.
- (6) A CAIR SO<sub>2</sub> allowance does not constitute a property right.
- (7) Upon recordation by the Administrator under 40 CFR Part 96, Subpart FFF or GGG, every allocation, transfer, or deduction of a CAIR SO<sub>2</sub> allowance to or from a CAIR SO<sub>2</sub> unit's compliance account is incorporated automatically in any CAIR Part of the source that includes the CAIR SO<sub>2</sub> unit.

Excess Emissions Requirements.

If a CAIR SO<sub>2</sub> source emits SO<sub>2</sub> during any control period in excess of the CAIR SO<sub>2</sub> emissions limitation, then:

- (1) The owners and operators of the source and each CAIR SO<sub>2</sub> unit at the source shall surrender the CAIR SO<sub>2</sub> allowances required for deduction under 40 CFR 96.254(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or applicable state law; and
- (2) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 96, Subpart AAA, the Clean Air Act, and applicable state law.

SECTION V. CAIR PART.

SUBSECTION A. Clean Air Interstate Rule Provisions – Combined Cycle Units

|   |
|---|
| <p><b>Bayside Power Station</b></p> <p>Plant Name (from STEP 1)</p> |
|---|

STEP 3,  
Continued

Recordkeeping and Reporting Requirements.

- (1) Unless otherwise provided, the owners and operators of the CAIR SO<sub>2</sub> source and each CAIR SO<sub>2</sub> unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Department or the Administrator.
  - (i) The certificate of representation under 40 CFR 98.213 for the CAIR designated representative for the source and each CAIR SO<sub>2</sub> unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation under 40 CFR 98.213 changing the CAIR designated representative.
  - (ii) All emissions monitoring information, in accordance with 40 CFR Part 98, Subpart HHH, of this part, provided that to the extent that 40 CFR Part 98, Subpart HHH, provides for a 3-year period for recordkeeping, the 3-year period shall apply.
  - (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR SO<sub>2</sub> Trading Program.
  - (iv) Copies of all documents used to complete a CAIR Part form and any other submission under the CAIR SO<sub>2</sub> Trading Program or to demonstrate compliance with the requirements of the CAIR SO<sub>2</sub> Trading Program.
- (2) The CAIR designated representative of a CAIR SO<sub>2</sub> source and each CAIR SO<sub>2</sub> unit at the source shall submit the reports required under the CAIR SO<sub>2</sub> Trading Program, including those under 40 CFR Part 98, Subpart HHH.

Liability.

- (1) Each CAIR SO<sub>2</sub> source and each CAIR SO<sub>2</sub> unit shall meet the requirements of the CAIR SO<sub>2</sub> Trading Program.
- (2) Any provision of the CAIR SO<sub>2</sub> Trading Program that applies to a CAIR SO<sub>2</sub> source or the CAIR designated representative of a CAIR SO<sub>2</sub> source shall also apply to the owners and operators of such source and of the CAIR SO<sub>2</sub> units at the source.
- (3) Any provision of the CAIR SO<sub>2</sub> Trading Program that applies to a CAIR SO<sub>2</sub> unit or the CAIR designated representative of a CAIR SO<sub>2</sub> unit shall also apply to the owners and operators of such unit.

Effect on Other Authorities.

No provision of the CAIR SO<sub>2</sub> Trading Program, a CAIR Part, or an exemption under 40 CFR 98.205 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR SO<sub>2</sub> source or CAIR SO<sub>2</sub> unit from compliance with any other provision of the applicable, approved State Implementation Plan, a federally enforceable permit, or the Clean Air Act.

**CAIR NO<sub>x</sub> OZONE SEASON TRADING PROGRAM**

CAIR Part Requirements.

- (1) The CAIR designated representative of each CAIR NO<sub>x</sub> Ozone Season source and each CAIR NO<sub>x</sub> Ozone Season unit at the source shall:
  - (i) Submit to the DEP a complete and certified CAIR Part form under 40 CFR 98.322 and Rule 62-266.470, F.A.C., in accordance with the deadlines specified in Rule 62-213.420, F.A.C.; and
  - (ii) [Reserved];
- (2) The owners and operators of each CAIR NO<sub>x</sub> Ozone Season source required to have a Title V operating permit or air construction permit, and each CAIR NO<sub>x</sub> Ozone Season unit required to have a Title V operating permit or air construction permit at the source shall have a CAIR Part included in the Title V operating permit or air construction permit issued by the DEP under 40 CFR Part 98, Subpart CCCC, for the source and operate the source and the unit in compliance with such CAIR Part.

Monitoring, Reporting, and Recordkeeping Requirements.

- (1) The owners and operators, and the CAIR designated representative, of each CAIR NO<sub>x</sub> Ozone Season source and each CAIR NO<sub>x</sub> Ozone Season unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR Part 98, Subpart HHHH, and Rule 62-266.470, F.A.C.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR Part 98, Subpart HHHH, shall be used to determine compliance by each CAIR NO<sub>x</sub> Ozone Season source with the following CAIR NO<sub>x</sub> Ozone Season Emissions Requirements.

NO<sub>x</sub> Ozone Season Emission Requirements.

- (1) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR NO<sub>x</sub> Ozone Season source and each CAIR NO<sub>x</sub> Ozone Season unit at the source shall hold, in the source's compliance account, CAIR NO<sub>x</sub> Ozone Season allowances available for compliance deductions for the control period under 40 CFR 98.354(a) in an amount not less than the tons of total NO<sub>x</sub> emissions for the control period from all CAIR NO<sub>x</sub> Ozone Season units at the source, as determined in accordance with 40 CFR Part 98, Subpart HHHH.
- (2) A CAIR NO<sub>x</sub> Ozone Season unit shall be subject to the requirements under paragraph (1) of the NO<sub>x</sub> Ozone Season Emission Requirements starting on the later of May 1, 2008 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 98.370(b)(1),(2), or (3) and for each control period thereafter.
- (3) A CAIR NO<sub>x</sub> Ozone Season allowance shall not be deducted, for compliance with the requirements under paragraph (1) of the NO<sub>x</sub> Ozone Season Emission Requirements, for a control period in a calendar year before the year for which the CAIR NO<sub>x</sub> Ozone Season allowance was allocated.
- (4) CAIR NO<sub>x</sub> Ozone Season allowances shall be held in, deducted from, or transferred into or among CAIR NO<sub>x</sub> Ozone Season Allowance Tracking System accounts in accordance with 40 CFR Part 98, Subparts FFFF and GGGG.
- (5) A CAIR NO<sub>x</sub> Ozone Season allowance is a limited authorization to emit one ton of NO<sub>x</sub> in accordance with the CAIR NO<sub>x</sub> Ozone Season Trading Program. No provision of the CAIR NO<sub>x</sub> Ozone Season Trading Program, the CAIR Part, or an exemption under 40 CFR 98.305 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.
- (6) A CAIR NO<sub>x</sub> Ozone Season allowance does not constitute a property right.
- (7) Upon recordation by the Administrator under 40 CFR Part 98, Subpart EEEE, FFFF or GGGG, every allocation, transfer, or deduction of a CAIR NO<sub>x</sub> Ozone Season allowance to or from a CAIR NO<sub>x</sub> Ozone Season unit's compliance account is incorporated automatically in any CAIR Part of the source that includes the CAIR NO<sub>x</sub> Ozone Season unit.

**SECTION V. CAIR PART.**

**SUBSECTION A. Clean Air Interstate Rule Provisions – Combined Cycle Units**

**STEP 3,  
Continued**

|  |
|--|
| <b>Bayside Power Station</b><br><br>Plant Name (from STEP 1) |
|--|

**Excess Emissions Requirements.**

If a CAIR NO<sub>x</sub> Ozone Season source emits NO<sub>x</sub> during any control period in excess of the CAIR NO<sub>x</sub> Ozone Season emissions limitation, then:  
 (1) The owners and operators of the source and each CAIR NO<sub>x</sub> Ozone Season unit at the source shall surrender the CAIR NO<sub>x</sub> Ozone Season allowances required for deduction under 40 CFR 86.354(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or applicable state law; and  
 (2) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 86, Subpart AAAA, the Clean Air Act, and applicable state law.

**Recordkeeping and Reporting Requirements.**

(1) Unless otherwise provided, the owners and operators of the CAIR NO<sub>x</sub> Ozone Season source and each CAIR NO<sub>x</sub> Ozone Season unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the DEP or the Administrator.  
 (i) The certificate of representation under 40 CFR 86.313 for the CAIR designated representative for the source and each CAIR NO<sub>x</sub> Ozone Season unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation under 40 CFR 86.113 changing the CAIR designated representative.  
 (ii) All emissions monitoring information, in accordance with 40 CFR Part 86, Subpart HHHH, of this part, provided that to the extent that 40 CFR Part 86, Subpart HHHH, provides for a 3-year period for recordkeeping, the 3-year period shall apply.  
 (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NO<sub>x</sub> Ozone Season Trading Program.  
 (iv) Copies of all documents used to complete a CAIR Part form and any other submission under the CAIR NO<sub>x</sub> Ozone Season Trading Program or to demonstrate compliance with the requirements of the CAIR NO<sub>x</sub> Ozone Season Trading Program.  
 (2) The CAIR designated representative of a CAIR NO<sub>x</sub> Ozone Season source and each CAIR NO<sub>x</sub> Ozone Season unit at the source shall submit the reports required under the CAIR NO<sub>x</sub> Ozone Season Trading Program, including those under 40 CFR Part 86, Subpart HHHH.

**Liability.**

(1) Each CAIR NO<sub>x</sub> Ozone Season source and each CAIR NO<sub>x</sub> Ozone Season unit shall meet the requirements of the CAIR NO<sub>x</sub> Ozone Season Trading Program.  
 (2) Any provision of the CAIR NO<sub>x</sub> Ozone Season Trading Program that applies to a CAIR NO<sub>x</sub> Ozone Season source or the CAIR designated representative of a CAIR NO<sub>x</sub> Ozone Season source shall also apply to the owners and operators of such source and of the CAIR NO<sub>x</sub> Ozone Season units at the source.  
 (3) Any provision of the CAIR NO<sub>x</sub> Ozone Season Trading Program that applies to a CAIR NO<sub>x</sub> Ozone Season unit or the CAIR designated representative of a CAIR NO<sub>x</sub> Ozone Season unit shall also apply to the owners and operators of such unit.

**Effect on Other Authorities.**


No provision of the CAIR NO<sub>x</sub> Ozone Season Trading Program, a CAIR Part, or an exemption under 40 CFR 86.305 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR NO<sub>x</sub> Ozone Season source or CAIR NO<sub>x</sub> Ozone Season unit from compliance with any other provision of the applicable, approved State Implementation Plan, a federally enforceable permit, or the Clean Air Act.

**STEP 4**

**Certification (for designated representative or alternate designated representative only)**

**Read the certification statement; provide name, title, owner company name, phone, and e-mail address; sign, and date.**

I am authorized to make this submission on behalf of the owners and operators of the CAIR source or CAIR units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

|  |  |  |  |
|--|--|--|--|
| Byron T. Burrows<br>Name   |  | Manager – Air Programs, EHS<br>Title       |  |
| Tampa Electric Company<br>Owner Company Name   |  |  |  |
| (813) 228-4740<br>Phone  |  | btburrows@tecoenergy.com<br>E-mail address |  |
| <br>Signature |  | 5/18/09<br>Date                            |  |





## SECTION V. CAIR PART.

### SUBSECTION A. Clean Air Interstate Rule Provisions – Simple Cycle Units

H.L. Culbreath Bayside Power Station

Plant Name (from STEP 1)

#### STEP 3

Read the standard requirements.

#### CAIR NO<sub>x</sub> ANNUAL TRADING PROGRAM

##### CAIR Part Requirements.

- (1) The CAIR designated representative of each CAIR NO<sub>x</sub> source and each CAIR NO<sub>x</sub> unit at the source shall:
  - (i) Submit to the DEP a complete and certified CAIR Part form under 40 CFR 98.122 and Rule 62-296.470, F.A.C., in accordance with the deadlines specified in Rule 62-213.420, F.A.C.; and
  - (ii) [Reserved];
- (2) The owners and operators of each CAIR NO<sub>x</sub> source and each CAIR NO<sub>x</sub> unit at the source shall have a CAIR Part included in the Title V operating permit issued by the DEP under 40 CFR Part 98, Subpart CC, and operate the source and the unit in compliance with such CAIR Part.

##### Monitoring, Reporting, and Recordkeeping Requirements.

- (1) The owners and operators, and the CAIR designated representative, of each CAIR NO<sub>x</sub> source and each CAIR NO<sub>x</sub> unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR Part 98, Subpart HH, and Rule 62-296.470, F.A.C.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR Part 98, Subpart HH, shall be used to determine compliance by each CAIR NO<sub>x</sub> source with the following CAIR NO<sub>x</sub> Emissions Requirements.

##### NO<sub>x</sub> Emission Requirements.

- (1) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR NO<sub>x</sub> source and each CAIR NO<sub>x</sub> unit at the source shall hold, in the source's compliance account, CAIR NO<sub>x</sub> allowances available for compliance deductions for the control period under 40 CFR 98.154(a) in an amount not less than the tons of total NO<sub>x</sub> emissions for the control period from all CAIR NO<sub>x</sub> units at the source, as determined in accordance with 40 CFR Part 98, Subpart HH.
- (2) A CAIR NO<sub>x</sub> unit shall be subject to the requirements under paragraph (1) of the NO<sub>x</sub> Requirements starting on the later of January 1, 2009, or the deadline for meeting the unit's monitor certification requirements under 40 CFR 98.170(b)(1) or (2) and for each control period thereafter.
- (3) A CAIR NO<sub>x</sub> allowance shall not be deducted, for compliance with the requirements under paragraph (1) of the NO<sub>x</sub> Requirements, for a control period in a calendar year before the year for which the CAIR NO<sub>x</sub> allowance was allocated.
- (4) CAIR NO<sub>x</sub> allowances shall be held in, deducted from, or transferred into or among CAIR NO<sub>x</sub> Allowance Tracking System accounts in accordance with 40 CFR Part 98, Subparts FF and GG.
- (5) A CAIR NO<sub>x</sub> allowance is a limited authorization to emit one ton of NO<sub>x</sub> in accordance with the CAIR NO<sub>x</sub> Annual Trading Program. No provision of the CAIR NO<sub>x</sub> Annual Trading Program, the CAIR Part, or an exemption under 40 CFR 98.105 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.
- (6) A CAIR NO<sub>x</sub> allowance does not constitute a property right.
- (7) Upon recordation by the Administrator under 40 CFR Part 98, Subpart EE, FF, or GG, every allocation, transfer, or deduction of a CAIR NO<sub>x</sub> allowance to or from a CAIR NO<sub>x</sub> unit's compliance account is incorporated automatically in any CAIR Part of the source that includes the CAIR NO<sub>x</sub> unit.

##### Excess Emissions Requirements.

If a CAIR NO<sub>x</sub> source emits NO<sub>x</sub> during any control period in excess of the CAIR NO<sub>x</sub> emissions limitation, then:

- (1) The owners and operators of the source and each CAIR NO<sub>x</sub> unit at the source shall surrender the CAIR NO<sub>x</sub> allowances required for deduction under 40 CFR 98.154(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or applicable state law; and
- (2) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 98, Subpart AA, the Clean Air Act, and applicable state law.

##### Recordkeeping and Reporting Requirements.

- (1) Unless otherwise provided, the owners and operators of the CAIR NO<sub>x</sub> source and each CAIR NO<sub>x</sub> unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the DEP or the Administrator.
  - (i) The certificate of representation under 40 CFR 98.113 for the CAIR designated representative for the source and each CAIR NO<sub>x</sub> unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation under 40 CFR 98.113 changing the CAIR designated representative.
  - (ii) All emissions monitoring information, in accordance with 40 CFR Part 98, Subpart HH, of this part, provided that to the extent that 40 CFR Part 98, Subpart HH, provides for a 3-year period for recordkeeping, the 3-year period shall apply.
  - (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NO<sub>x</sub> Annual Trading Program.
  - (iv) Copies of all documents used to complete a CAIR Part form and any other submission under the CAIR NO<sub>x</sub> Annual Trading Program or to demonstrate compliance with the requirements of the CAIR NO<sub>x</sub> Annual Trading Program.
- (2) The CAIR designated representative of a CAIR NO<sub>x</sub> source and each CAIR NO<sub>x</sub> unit at the source shall submit the reports required under the CAIR NO<sub>x</sub> Annual Trading Program, including those under 40 CFR Part 98, Subpart HH.

## SECTION V. CAIR PART.

### SUBSECTION A. Clean Air Interstate Rule Provisions – Simple Cycle Units

H.L. Culbreath Bayside Power Station

Plant Name (from STEP 1)

#### STEP 3, Continued

#### Liability.

- (1) Each CAIR NO<sub>x</sub> source and each CAIR NO<sub>x</sub> unit shall meet the requirements of the CAIR NO<sub>x</sub> Annual Trading Program.
- (2) Any provision of the CAIR NO<sub>x</sub> Annual Trading Program that applies to a CAIR NO<sub>x</sub> source or the CAIR designated representative of a CAIR NO<sub>x</sub> source shall also apply to the owners and operators of such source and of the CAIR NO<sub>x</sub> units at the source.
- (3) Any provision of the CAIR NO<sub>x</sub> Annual Trading Program that applies to a CAIR NO<sub>x</sub> unit or the CAIR designated representative of a CAIR NO<sub>x</sub> unit shall also apply to the owners and operators of such unit.

#### Effect on Other Authorities.

No provision of the CAIR NO<sub>x</sub> Annual Trading Program, a CAIR Part, or an exemption under 40 CFR 98.105 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR NO<sub>x</sub> source or CAIR NO<sub>x</sub> unit from compliance with any other provision of the applicable, approved State Implementation Plan, a federally enforceable permit, or the Clean Air Act.

### CAIR SO<sub>2</sub> TRADING PROGRAM

#### CAIR Part Requirements.

- (1) The CAIR designated representative of each CAIR SO<sub>2</sub> source and each CAIR SO<sub>2</sub> unit at the source shall:
  - (i) Submit to the DEP a complete and certified CAIR Part form under 40 CFR 98.222 and Rule 62-298.470, F.A.C., in accordance with the deadlines specified in Rule 62-213.420, F.A.C.; and
  - (ii) [Reserved];
- (2) The owners and operators of each CAIR SO<sub>2</sub> source and each CAIR SO<sub>2</sub> unit at the source shall have a CAIR Part included in the Title V operating permit issued by the DEP under 40 CFR Part 98, Subpart CCC, for the source and operate the source and each CAIR unit in compliance with such CAIR Part.

#### Monitoring, Reporting, and Recordkeeping Requirements.

- (1) The owners and operators, and the CAIR designated representative, of each CAIR SO<sub>2</sub> source and each SO<sub>2</sub> CAIR unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR Part 98, Subpart HHH, and Rule 62-298.470, F.A.C.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR Part 98, Subpart HHH, shall be used to determine compliance by each CAIR SO<sub>2</sub> source with the following CAIR SO<sub>2</sub> Emission Requirements.

#### SO<sub>2</sub> Emission Requirements.

- (1) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR SO<sub>2</sub> source and each CAIR SO<sub>2</sub> unit at the source shall hold, in the source's compliance account, a tonnage equivalent in CAIR SO<sub>2</sub> allowances available for compliance deductions for the control period, as determined in accordance with 40 CFR 98.254(a) and (b), not less than the tons of total sulfur dioxide emissions for the control period from all CAIR SO<sub>2</sub> units at the source, as determined in accordance with 40 CFR Part 98, Subpart HHH.
- (2) A CAIR SO<sub>2</sub> unit shall be subject to the requirements under paragraph (1) of the Sulfur Dioxide Emission Requirements starting on the later of January 1, 2010 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 98.270(b)(1) or (2) and for each control period thereafter.
- (3) A CAIR SO<sub>2</sub> allowance shall not be deducted, for compliance with the requirements under paragraph (1) of the SO<sub>2</sub> Emission Requirements, for a control period in a calendar year before the year for which the CAIR SO<sub>2</sub> allowance was allocated.
- (4) CAIR SO<sub>2</sub> allowances shall be held in, deducted from, or transferred into or among CAIR SO<sub>2</sub> Allowance Tracking System accounts in accordance with 40 CFR Part 98, Subparts FFF and GGG.
- (5) A CAIR SO<sub>2</sub> allowance is a limited authorization to emit sulfur dioxide in accordance with the CAIR SO<sub>2</sub> Trading Program. No provision of the CAIR SO<sub>2</sub> Trading Program, the CAIR Part, or an exemption under 40 CFR 98.205 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.
- (6) A CAIR SO<sub>2</sub> allowance does not constitute a property right.
- (7) Upon recordation by the Administrator under 40 CFR Part 98, Subpart FFF or GGG, every allocation, transfer, or deduction of a CAIR SO<sub>2</sub> allowance to or from a CAIR SO<sub>2</sub> unit's compliance account is incorporated automatically in any CAIR Part of the source that includes the CAIR SO<sub>2</sub> unit.

#### Excess Emissions Requirements.

If a CAIR SO<sub>2</sub> source emits SO<sub>2</sub> during any control period in excess of the CAIR SO<sub>2</sub> emissions limitation, then:

- (1) The owners and operators of the source and each CAIR SO<sub>2</sub> unit at the source shall surrender the CAIR SO<sub>2</sub> allowances required for deduction under 40 CFR 98.254(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or applicable state law; and
- (2) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 98, Subpart AAA, the Clean Air Act, and applicable state law.

## SECTION V. CAIR PART.

### SUBSECTION A. Clean Air Interstate Rule Provisions – Simple Cycle Units

H.L. Culbreath Bayside Power Station

Plant Name (from STEP 1)

STEP 3,  
Continued

#### Recordkeeping and Reporting Requirements.

(1) Unless otherwise provided, the owners and operators of the CAIR SO<sub>2</sub> source and each CAIR SO<sub>2</sub> unit at the source shall keep on file at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Department or the Administrator.

(i) The certificate of representation under 40 CFR 98.213 for the CAIR designated representative for the source and each CAIR SO<sub>2</sub> unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on file at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation under 40 CFR 98.213 changing the CAIR designated representative.

(ii) All emissions monitoring information, in accordance with 40 CFR Part 98, Subpart HHH, of this part, provided that to the extent that 40 CFR Part 98, Subpart HHH, provides for a 3-year period for recordkeeping, the 3-year period shall apply.

(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR SO<sub>2</sub> Trading Program.

(iv) Copies of all documents used to complete a CAIR Part form and any other submission under the CAIR SO<sub>2</sub> Trading Program or to demonstrate compliance with the requirements of the CAIR SO<sub>2</sub> Trading Program.

(2) The CAIR designated representative of a CAIR SO<sub>2</sub> source and each CAIR SO<sub>2</sub> unit at the source shall submit the reports required under the CAIR SO<sub>2</sub> Trading Program, including those under 40 CFR Part 98, Subpart HHH.

#### Liability.

(1) Each CAIR SO<sub>2</sub> source and each CAIR SO<sub>2</sub> unit shall meet the requirements of the CAIR SO<sub>2</sub> Trading Program.

(2) Any provision of the CAIR SO<sub>2</sub> Trading Program that applies to a CAIR SO<sub>2</sub> source or the CAIR designated representative of a CAIR SO<sub>2</sub> source shall also apply to the owners and operators of such source and of the CAIR SO<sub>2</sub> units at the source.

(3) Any provision of the CAIR SO<sub>2</sub> Trading Program that applies to a CAIR SO<sub>2</sub> unit or the CAIR designated representative of a CAIR SO<sub>2</sub> unit shall also apply to the owners and operators of such unit.

#### Effect on Other Authorities.

No provision of the CAIR SO<sub>2</sub> Trading Program, a CAIR Part, or an exemption under 40 CFR 98.205 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR SO<sub>2</sub> source or CAIR SO<sub>2</sub> unit from compliance with any other provision of the applicable, approved State Implementation Plan, a federally enforceable permit, or the Clean Air Act.

### CAIR NO<sub>x</sub> OZONE SEASON TRADING PROGRAM

#### CAIR Part Requirements.

(1) The CAIR designated representative of each CAIR NO<sub>x</sub> Ozone Season source and each CAIR NO<sub>x</sub> Ozone Season unit at the source shall:

(i) Submit to the DEP a complete and certified CAIR Part form under 40 CFR 98.322 and Rule 62-296.470, F.A.C., in accordance with the deadlines specified in Rule 62-213.420, F.A.C.; and

(ii) [Reserved];

(2) The owners and operators of each CAIR NO<sub>x</sub> Ozone Season source required to have a Title V operating permit or air construction permit, and each CAIR NO<sub>x</sub> Ozone Season unit required to have a Title V operating permit or air construction permit at the source shall have a CAIR Part included in the Title V operating permit or air construction permit issued by the DEP under 40 CFR Part 98, Subpart CCCC, for the source and operate the source and the unit in compliance with such CAIR Part.

#### Monitoring, Reporting, and Recordkeeping Requirements.

(1) The owners and operators, and the CAIR designated representative, of each CAIR NO<sub>x</sub> Ozone Season source and each CAIR NO<sub>x</sub> Ozone Season unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR Part 98, Subpart HHHH, and Rule 62-296.470, F.A.C.

(2) The emissions measurements recorded and reported in accordance with 40 CFR Part 98, Subpart HHHH, shall be used to determine compliance by each CAIR NO<sub>x</sub> Ozone Season source with the following CAIR NO<sub>x</sub> Ozone Season Emissions Requirements.

#### NO<sub>x</sub> Ozone Season Emission Requirements.

(1) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR NO<sub>x</sub> Ozone Season source and each CAIR NO<sub>x</sub> Ozone Season unit at the source shall hold, in the source's compliance account, CAIR NO<sub>x</sub> Ozone Season allowances available for compliance deductions for the control period under 40 CFR 98.354(a) in an amount not less than the tons of total NO<sub>x</sub> emissions for the control period from all CAIR NO<sub>x</sub> Ozone Season units at the source, as determined in accordance with 40 CFR Part 98, Subpart HHHH.

(2) A CAIR NO<sub>x</sub> Ozone Season unit shall be subject to the requirements under paragraph (1) of the NO<sub>x</sub> Ozone Season Emission Requirements starting on the later of May 1, 2009 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 98.370(b)(1),(2), or (3) and for each control period thereafter.

(3) A CAIR NO<sub>x</sub> Ozone Season allowance shall not be deducted, for compliance with the requirements under paragraph (1) of the NO<sub>x</sub> Ozone Season Emission Requirements, for a control period in a calendar year before the year for which the CAIR NO<sub>x</sub> Ozone Season allowance was allocated.

(4) CAIR NO<sub>x</sub> Ozone Season allowances shall be held in, deducted from, or transferred into or among CAIR NO<sub>x</sub> Ozone Season Allowance Tracking System accounts in accordance with 40 CFR Part 98, Subparts FFFF and GGGG.

(5) A CAIR NO<sub>x</sub> Ozone Season allowance is a limited authorization to emit one ton of NO<sub>x</sub> in accordance with the CAIR NO<sub>x</sub> Ozone Season Trading Program. No provision of the CAIR NO<sub>x</sub> Ozone Season Trading Program, the CAIR Part, or an exemption under 40 CFR 98.305 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.

(6) A CAIR NO<sub>x</sub> Ozone Season allowance does not constitute a property right.

(7) Upon recordation by the Administrator under 40 CFR Part 98, Subpart EEEE, FFFF or GGGG, every allocation, transfer, or deduction of a CAIR NO<sub>x</sub> Ozone Season allowance to or from a CAIR NO<sub>x</sub> Ozone Season unit's compliance account is incorporated automatically in any CAIR Part of the source that includes the CAIR NO<sub>x</sub> Ozone Season unit.

**SECTION V. CAIR PART.**

**SUBSECTION A. Clean Air Interstate Rule Provisions – Simple Cycle Units**

|  |
|--|
| H.L. Culbreath Bayside Power Station<br>Plant Name (from STEP 1) |
|--|

**STEP 3,  
Continued**

Excess Emissions Requirements.

If a CAIR NO<sub>x</sub> Ozone Season source emits NO<sub>x</sub> during any control period in excess of the CAIR NO<sub>x</sub> Ozone Season emissions limitation, then:

(1) The owners and operators of the source and each CAIR NO<sub>x</sub> Ozone Season unit at the source shall surrender the CAIR NO<sub>x</sub> Ozone Season allowances required for deduction under 40 CFR 98.354(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or applicable state law; and

(2) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 98, Subpart AAAA, the Clean Air Act, and applicable state law.

Recordkeeping and Reporting Requirements.

(1) Unless otherwise provided, the owners and operators of the CAIR NO<sub>x</sub> Ozone Season source and each CAIR NO<sub>x</sub> Ozone Season unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the DEP or the Administrator.

(i) The certificate of representation under 40 CFR 98.313 for the CAIR designated representative for the source and each CAIR NO<sub>x</sub> Ozone Season unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation under 40 CFR 98.113 changing the CAIR designated representative.

(ii) All emissions monitoring information, in accordance with 40 CFR Part 98, Subpart HHHH, of this part, provided that to the extent that 40 CFR Part 98, Subpart HHHH, provides for a 3-year period for recordkeeping, the 3-year period shall apply.

(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NO<sub>x</sub> Ozone Season Trading Program.

(iv) Copies of all documents used to complete a CAIR Part form and any other submission under the CAIR NO<sub>x</sub> Ozone Season Trading Program or to demonstrate compliance with the requirements of the CAIR NO<sub>x</sub> Ozone Season Trading Program.

(2) The CAIR designated representative of a CAIR NO<sub>x</sub> Ozone Season source and each CAIR NO<sub>x</sub> Ozone Season unit at the source shall submit the reports required under the CAIR NO<sub>x</sub> Ozone Season Trading Program, including those under 40 CFR Part 98, Subpart HHHH.

Liability.

(1) Each CAIR NO<sub>x</sub> Ozone Season source and each CAIR NO<sub>x</sub> Ozone Season unit shall meet the requirements of the CAIR NO<sub>x</sub> Ozone Season Trading Program.

(2) Any provision of the CAIR NO<sub>x</sub> Ozone Season Trading Program that applies to a CAIR NO<sub>x</sub> Ozone Season source or the CAIR designated representative of a CAIR NO<sub>x</sub> Ozone Season source shall also apply to the owners and operators of such source and of the CAIR NO<sub>x</sub> Ozone Season units at the source.

(3) Any provision of the CAIR NO<sub>x</sub> Ozone Season Trading Program that applies to a CAIR NO<sub>x</sub> Ozone Season unit or the CAIR designated representative of a CAIR NO<sub>x</sub> Ozone Season unit shall also apply to the owners and operators of such unit.

Effect on Other Authorities.

No provision of the CAIR NO<sub>x</sub> Ozone Season Trading Program, a CAIR Part, or an exemption under 40 CFR 98.305 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR NO<sub>x</sub> Ozone Season source or CAIR NO<sub>x</sub> Ozone Season unit from compliance with any other provision of the applicable, approved State Implementation Plan, a federally enforceable permit, or the Clean Air Act.

**STEP 4**

**Certification (for designated representative or alternate designated representative only)**

**Read the certification statement; provide name, title, owner company name, phone, and e-mail address; sign, and date.**

I am authorized to make this submission on behalf of the owners and operators of the CAIR source or CAIR units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

|                                    |                                     |
|------------------------------------|-------------------------------------|
| Paul L. Carpinone                  | Acid Rain Designated Representative |
| Name                               | Title                               |
| Tampa Electric Company             |                                     |
| Company Owner Name                 |                                     |
| (813) 228-4858                     | plcarpinone@tecoenergy.com          |
| Phone                              | E-mail Address                      |
| Signature <i>Paul L. Carpinone</i> | Date 4-14-2010                      |

## SECTION VI. APPENDICES.

---

**The following Appendices are enforceable parts of the Title V air operation permit.**

- Appendix A. Abbreviations, Acronyms, Citations and Identification Numbers
- Appendix BD. Final BACT Determination and Emissions Standards (Units 1 and 2)
- Appendix CD. Consent Decree (U.S. EPA vs. TECO)
- Appendix CFJ. Consent Final Judgment (DEP vs. TECO)
- Appendix CM. Standard Continuous Monitoring Requirements
- Appendix CR. Common Regulatory Requirements
- Appendix GG. NSPS Subpart GG for Stationary Gas Turbines (Units 1 and 2)
- Appendix I. Insignificant Activities
- Appendix IIII. NSPS Subpart IIII for Stationary Compression Ignition Internal Combustion Engines
- Appendix KKKK. NSPS Subpart KKKK for Stationary Combustion Turbines (Units 3 – 6)
- Appendix NE. NESHAP Subpart A for General Provisions
- Appendix NS. NSPS Subpart A for General Provisions
- Appendix RR. Facility-Wide Reporting Requirements
- Appendix TR. Facility-Wide Testing Requirements
- Appendix TV. Title V General Conditions
- Appendix U. Unregulated Activities
- Appendix ZZZZ. NESHAP Subpart ZZZZ for Reciprocating Internal Combustion Engines

## APPENDIX A

### Abbreviations, Acronyms, Citations and Identification Numbers

#### Abbreviations and Acronyms:

|  |  |
|--|--|
| <b>° F:</b> degrees Fahrenheit   | <b>lb/hr:</b> pounds per hour  |
| <b>acfm:</b> actual cubic feet per minute  | <b>LONG:</b> longitude   |
| <b>AOR:</b> Annual Operating Report  | <b>MACT:</b> maximum achievable technology   |
| <b>ARMS:</b> Air Resource Management System<br>(Department's database)   | <b>mm:</b> millimeter  |
| <b>BACT:</b> Best Available Control Technology   | <b>MMBtu:</b> million British thermal units  |
| <b>Btu:</b> British thermal units  | <b>MSDS:</b> material safety data sheets   |
| <b>CAM:</b> compliance assurance monitoring  | <b>MW:</b> megawatt  |
| <b>CEMS:</b> continuous emissions monitoring system  | <b>NESHAP:</b> National Emissions Standards for Hazardous<br>Air Pollutants                          |
| <b>cfm:</b> cubic feet per minute  | <b>NO<sub>x</sub>:</b> nitrogen oxides   |
| <b>CFR:</b> Code of Federal Regulations  | <b>NSPS:</b> New Source Performance Standards  |
| <b>CO:</b> carbon monoxide   | <b>O&amp;M:</b> operation and maintenance  |
| <b>COMS:</b> continuous opacity monitoring system  | <b>O<sub>2</sub>:</b> oxygen   |
| <b>DARM:</b> Division of Air Resource Management   | <b>ORIS:</b> Office of Regulatory Information Systems  |
| <b>DCA:</b> Department of Community Affairs  | <b>OS:</b> organic solvent   |
| <b>DEP:</b> Department of Environmental Protection   | <b>Pb:</b> lead  |
| <b>Department:</b> Department of Environmental Protection  | <b>PM:</b> particulate matter  |
| <b>dscfm:</b> dry standard cubic feet per minute   | <b>PM<sub>10</sub>:</b> particulate matter with a mean aerodynamic<br>diameter of 10 microns or less |
| <b>EPA:</b> Environmental Protection Agency  | <b>PSD:</b> prevention of significant deterioration  |
| <b>ESP:</b> electrostatic precipitator   | <b>psi:</b> pounds per square inch   |
| <b>EU:</b> emissions unit  | <b>PTE:</b> potential to emit  |
| <b>F.A.C.:</b> Florida Administrative Code   | <b>RACT:</b> reasonably available control technology   |
| <b>F.D.:</b> forced draft  | <b>RATA:</b> relative accuracy test audit  |
| <b>F.S.:</b> Florida Statutes  | <b>RMP:</b> Risk Management Plan   |
| <b>FGR:</b> flue gas recirculation   | <b>RO:</b> responsible official  |
| <b>Fl:</b> fluoride  | <b>SAM:</b> sulfuric acid mist   |
| <b>ft<sup>2</sup>:</b> square feet   | <b>scf:</b> standard cubic feet  |
| <b>ft<sup>3</sup>:</b> cubic feet  | <b>scfm:</b> standard cubic feet per minute  |
| <b>gpm:</b> gallons per minute   | <b>SIC:</b> standard industrial classification code  |
| <b>gr:</b> grains  | <b>SNCR:</b> selective non-catalytic reduction   |
| <b>HAP:</b> hazardous air pollutant  | <b>SOA:</b> Specific Operating Agreement   |
| <b>Hg:</b> mercury   | <b>SO<sub>2</sub>:</b> sulfur dioxide  |
| <b>I.D.:</b> induced draft   | <b>TPH:</b> tons per hour  |
| <b>ID:</b> identification  | <b>TPY:</b> tons per year  |
| <b>ISO:</b> International Standards Organization (refers to<br>those conditions at 288 Kelvin, 60% relative humidity and<br>101.3 kilopascals pressure.) | <b>UTM:</b> Universal Transverse Mercator coordinate system  |
| <b>kPa:</b> kilopascals  | <b>VE:</b> visible emissions   |
| <b>LAT:</b> latitude   | <b>VOC:</b> volatile organic compounds   |
| <b>lb:</b> pound   | <b>x:</b> by or times  |

## APPENDIX A

### Abbreviations, Acronyms, Citations and Identification Numbers

---

#### Citations:

The following examples illustrate the methods used in this permit to abbreviate and cite the references of rules, regulations, guidance memorandums, permit numbers and ID numbers.

#### Code of Federal Regulations:

*Example:* [40 CFR 60.334]

*Where:* 40 refers to Title 40  
CFR refers to Code of Federal Regulations  
60 refers to Part 60  
60.334 refers to Section 60.334

#### Florida Administrative Code (F.A.C.) Rules:

*Example:* [Rule 62-213.205, F.A.C.]

*Where:* 62 refers to Title 62  
62-213 refers to Chapter 62-213  
62-213.205 refers to Rule 62-213.205, F.A.C.

---

#### Identification Numbers:

##### Facility Identification (ID) Number:

*Example:* Facility ID No.: 1050221

*Where:* 105 is the 3-digit number code identifying that the facility is located in Polk County  
0221 is the 4-digit number assigned by state database

##### Permit Numbers:

*Example:* 1050221-002-AV or 1050221-001-AC

*Where:* AC means Air Construction Permit  
AV means Air Operation Permit (Title V Source)  
105 is the 3-digit number code identifying that the facility is located in Polk County  
0221 is the 4-digit number assigned by permit tracking database  
001 or 002 is the 3-digit sequential project number assigned by permit tracking database

*Example:* PSD-FL-185  
PA 95-01  
AC53-208321

*Where:* PSD means Prevention of Significant Deterioration of Air Quality Permit  
PA refers to the certification under the Power Plant Siting Act  
AC53 is an Air Construction Permit for a facility is located in Polk County (old style of numbering)



**APPENDIX BD**

**Final BACT Determination and Emission Standards (Units 1 and 2)**

**Emissions Standards for Bayside Units 1 and 2 (Emissions Units 020 through 026)**

Each emissions unit consists of a General Electric Model PG7241(FA) gas turbine-electrical generator set, an automated gas turbine control system, an inlet air filtration system, an evaporative inlet air cooling system, an unfired heat recovery steam generator (HRSG), a single exhaust stack that is 150 feet tall and 19.0 feet in diameter, and associated support equipment. Each unit Natural gas is the exclusive fuel. At a compressor inlet air temperature of 59° F and firing 1842 MMBtu (HHV) per hour of natural gas, each unit produces a nominal 169 MW of shaft-driven electricity. Exhaust gases exit the stack with a volumetric flow rate of approximately 1,030,000 acfm at 220° F.

| <b>Pollutant</b>   | <b>Controls and Standards<sup>a</sup></b>   |
|--|---|
| <i>Standards based on emissions performance tests at permitted capacity and an inlet temperature of 59° F:</i> |   |
| Ammonia  | <i>Standard: 5 ppmvd @ 15% O<sub>2</sub><sup>b</sup></i>  |
| CO<br>(BACT)   | <i>Control: DLN combustion technology and exclusive firing of natural gas<br/>Standard: 7.8 ppmvd @ 15% O<sub>2</sub><br/>Standard: 28.7 lb/hour</i>  |
| NOx  | <i>Controls: SCR with DLN combustion technology and exclusive firing of natural gas<br/>Standard: 3.5 ppmvd @ 15% O<sub>2</sub><br/>Standard: 23.1 lb/hour</i>  |
| PM/PM <sub>10</sub><br>(BACT)  | <i>Controls: DLN combustion technology and exclusive firing of natural gas<br/>Standard: 10% opacity, 6-minute average<br/>Comments: The CO CEMS standard serves as a continuous indicator of efficient combustion. The estimated maximum emissions are 12 lb/hour (front-half catch only).</i> |
| SAM/SO <sub>2</sub>  | <i>Standard: Exclusive firing of natural gas (&lt; 2 grains per 100 SCF, 12 month rolling average)</i>  |
| VOC<br>(BACT)  | <i>Controls: DLN combustion technology and exclusive firing of natural gas<br/>Comments: The CO CEMS standard serves as a continuous indicator of efficient combustion. The estimated maximum emissions are 3 lb/hour (1.3 ppmvd @ 15% O<sub>2</sub>).</i>                                      |
| <i>Standards based on CEMS data:</i>   |   |
| CO<br>(BACT)   | <i>Control: DLN combustion technology and exclusive firing of natural gas<br/>Standard: 9.0 ppmvd @ 15% O<sub>2</sub>, 24-hour block average</i>  |
| NOx  | <i>Controls: SCR with DLN combustion technology and exclusive firing of natural gas<br/>Standard: 3.5 ppmvd @ 15% O<sub>2</sub>, 24-hour block average</i>  |

**Notes:**

- a. "BACT" means Best Available Control Technology. "SCR" means selective catalytic reduction system. "DLN" means dry low-NOx combustion technology.
- b. If the tested ammonia slip rate exceeds 5 ppmvd corrected to 15% oxygen during the required annual test, the permittee shall begin testing and reporting the ammonia slip for each subsequent calendar quarter. Before the ammonia slip exceeds 7 ppmvd corrected to 15% oxygen, the permittee shall take corrective actions that result in lowering the ammonia slip to less than 5 ppmvd corrected to 15% oxygen. The permittee shall test and demonstrate that the ammonia slip is less than 5 ppmvd corrected to 15% oxygen within 15 days after completing the corrective actions.

A detailed description of each BACT evaluation is presented in the Technical Evaluation and Preliminary Determination. Any changes are noted in the Department's Final Determination issued simultaneously with the final permit.

**Final BACT Determinations**

Actual emissions of NOx and SO<sub>2</sub> from the re-powered plant will decrease due to the shutdown of existing coal-fired units. Therefore, the project nets out of PSD for NOx and SO<sub>2</sub> emissions. However, each gas turbine is required to fire natural gas as the primary fuel and to incorporate an SCR system as a result of the DEP/TEC Consent Final Judgment and the EPA/TEC Consent Decree. The gas turbines are subject to the acid rain requirements, which require a continuous emissions monitoring system (CEMS) for NOx emissions. The NOx CEMS will also be used to demonstrate compliance with the specified permit standards.

**APPENDIX BD**

**Final BACT Determination and Emission Standards (Units 1 and 2)**

The project did result in significant net actual emissions increases of carbon monoxide (CO) and volatile organic compounds (VOC). Based on an interpretation by EPA Region 4, emissions of particulate matter (PM/PM10) would also be significant if BACT-level controls had previously been installed on the existing Gannon Units. For CO, PM/PM10, and VOC emissions, the Department determines that the efficient combustion of pipeline-quality natural gas and good operating practices represent BACT for the combined cycle units. In addition to the control requirements, the CO, PM/PM10, and VOC emissions standards specified in the permit and summarized in the above table represent the determination of Best Available Control Technology (BACT). A continuous emission monitoring system (CEMS) is required to demonstrate continuous compliance with the CO standards. The CO CEMS will also serve as a continuous indicator of efficient combustion to minimize PM and VOC emissions. The Department's detailed technical review and rationale for the determinations of Best Available Control Technology (BACT) are presented in Technical Evaluation and Preliminary Determination issued with the draft PSD permit package.

**Mass Emission Rate Summary**

The following table summarizes the hourly mass emission rates (lb/hour) at various the compressor inlet temperatures.

| Pollutant | Compressor Inlet Temperature | Mass Emission Rate lb/hour |
|-----------|------------------------------|----------------------------|
| CO        | 18° F                        | 31.1                       |
|           | 35° F                        | 30.0                       |
|           | 59° F                        | 28.7                       |
|           | 72° F                        | 27.8                       |
|           | 93° F                        | 26.9                       |
| NOx       | 18° F                        | 24.7                       |
|           | 35° F                        | 23.8                       |
|           | 59° F                        | 23.1                       |
|           | 72° F                        | 22.6                       |
|           | 93° F                        | 21.9                       |
| PM/PM10   | 18° F                        | 11.5                       |
|           | 35° F                        | 11.4                       |
|           | 59° F                        | 11.3                       |
|           | 72° F                        | 11.3                       |
|           | 93° F                        | 11.2                       |
| VOC       | 18° F                        | 3.0                        |
|           | 35° F                        | 3.0                        |
|           | 59° F                        | 2.8                        |
|           | 72° F                        | 2.7                        |
|           | 93° F                        | 2.7                        |

*Notes:*

- This table represents the mass emission rates for the General Electric Model PG7241(FA) gas turbine (combined cycle) firing natural gas with a selective catalytic reduction system to reduce NOx emissions.
- NOx emission rates are reported as NO2 and are based on control with DLN combustion and an SCR system.
- PM emission rates are based on EPA Method 5 (front-half catch only).
- VOC emission rates are measure as methane.

**APPENDIX CD**

**Consent Decree (U.S. EPA vs. TECO)**

---

On October 4, 2000, the United States and Tampa Electric Company entered into a settlement agreement (Consent Decree, Civil Action No. 99-2524). In May of 2001, this agreement was amended. The requirements of these agreements have been incorporated into the Title V air operation permit. Copies of these documents may be requested from the Department.

**APPENDIX CFJ**

**Consent Final Judgment (DEP vs. TECO)**

On December 7, 1999, the Florida Department of Environmental Protection and the Tampa Electric Company entered into a settlement agreement (Consent Final Judgment, Case No. 99-009737). The requirements of this agreement have been incorporated into the Title V air operation permit. Copies of this document may be requested from the Department.

## Standard Continuous Monitoring Requirements

The new simple cycle combustion turbine (EU 031 - 038) are subject to the following requirements for the new continuous emissions monitoring systems (CEMS) required for CO and NO<sub>x</sub> emissions.

**CEMS OPERATION PLAN**

1. CEMS Operation Plan: The permittee shall implement the CEMS Operation Plan submitted to the Emissions Monitoring Section of the Bureau of Air Monitoring and Mobile Sources for the proper installation, calibration, maintenance and operation of each CEMS required by this permit. The permittee shall submit any updates for approval to the Emissions Monitoring Section. [Rule 62-4.070(3), F.A.C.]

**MONITORS, PERFORMANCE SPECIFICATIONS AND QUALITY ASSURANCE**

2. Span Values and Dual Range Monitors: The permittee shall set appropriate span values for the CEMS based on the emissions standards and range of operation. If necessary, the permittee shall install dual range monitors in accordance with the CEMS Operation Plan. [Rule 62-4.070(3), F.A.C.]
3. Diluent Monitor: If required by permit to correct the CEMS output to the oxygen concentrations specified in the applicable emissions standard, the permittee shall either install an oxygen monitor or install a carbon dioxide (CO<sub>2</sub>) monitor and use an appropriate F-Factor computational approach. The oxygen or CO<sub>2</sub> content of the flue gas shall be monitored at the location where CO and NO<sub>x</sub> are monitored to correct the measured emissions rates to 15% oxygen. Each diluents monitor shall comply with the performance and quality assurance requirements of 40 CFR 75. [Rule 62-4.070(3), F.A.C.]
4. Moisture Correction: If necessary, the permittee shall install a system to determine the moisture content of the exhaust gas and develop an algorithm to enable correction of the monitoring results to a dry basis (0% moisture). [Rule 62-4.070(3), F.A.C.]
5. Continuous Flow Monitor: For compliance with mass emission flow rate standards, the permittee shall install a continuous flow monitor to determine the stack exhaust flow rate. The flow monitor shall be certified pursuant to Performance Specification 6 in Appendix B of 40 CFR Part 60. Alternatively, the permittee may install a fuel flow monitor and use an appropriate F-Factor computational approach to calculate stack exhaust flow rate. *{Permitting Note: The CEMS Operation Plan will contain additional details and procedures for CEMS installation.}* [Rule 62-4.070(3), F.A.C.]
6. Performance Specifications: The permittee shall evaluate the “acceptability” of each CEMS by conducting the appropriate performance specification. CEMS determined to be “unacceptable” shall not be considered “installed” for purposes of meeting the timelines of this permit.
  - a. For CO monitors, the permittee shall conduct Performance Specification 4 in Appendix B of 40 CFR Part 60.
  - b. For NO<sub>x</sub> monitors, the permittee shall conduct Performance Specification 2 in Appendix B of 40 CFR Part 60.
7. Quality Assurance: The permittee shall follow the quality assurance procedures in Appendix F of 40 CFR Part 60.
  - a. For CO, the required relative accuracy test audit (RATA) tests shall be performed using EPA Method 10 in Appendix A of 40 CFR Part 60. Quality assurance procedures shall conform to the requirements in Appendix F of 40 CFR 60 and the Data Assessment Report of Section 7 shall be made each calendar quarter and reported semiannually to the Compliance Authority.
  - b. For NO<sub>x</sub>, the RATA tests shall be performed using EPA Method 7E in Appendix A of 40 CFR Part 60. Each NO<sub>x</sub> monitor shall be certified pursuant to the specifications of 40 CFR 75 and meet the applicable requirements in 40 CFR 60.4345. Quality assurance procedures shall conform to the requirements of 40 CFR 75.

[Rule 62-4.070(3), F.A.C. and NSPS Subpart KKKK in 40 CFR 60]

**CALCULATION APPROACH FOR SIP COMPLIANCE**

8. CEMS for Compliance: Once adherence to the applicable performance specification for each CEMS is demonstrated, the permittee shall use the CEMS to demonstrate compliance with the applicable emission standards as specified by this permit. [Rule 62-4.070(3), F.A.C.]
9. CEMS Data: Each CEMS shall monitor and record emissions during all operations and whenever emissions are being generated, including during episodes of startups, shutdowns, and malfunctions. All data shall be used, except for invalid measurements taken during monitor system breakdowns, repairs, calibration checks, zero adjustments, and span

## Standard Continuous Monitoring Requirements

adjustments. If the CEMS measures concentration on a wet basis, the CEM system shall include provisions to determine the moisture content of the exhaust gas and an algorithm to enable correction of the monitoring results to a dry basis (0% moisture). Alternatively, the owner or operator may develop through manual stack test measurements a curve of moisture contents in the exhaust gas versus load, and use these typical values in an algorithm to enable correction of the monitoring results to a dry basis (0% moisture). Final results of the CEMS shall be expressed as ppmvd corrected to 15% oxygen. The CEMS shall be used to demonstrate compliance with the CEMS emission standards for CO and NO<sub>x</sub> as specified in this permit. For purposes of determining compliance with the CEMS emissions standards of this permit, missing (or excluded) data shall not be substituted. [Rule 62-4.070(3), F.A.C.]

10. Operating Hours and Operating Days: For purposes of this Appendix, the following definitions shall apply. An hour is the 60-minute period beginning at the top of each hour. Any hour during which an emissions unit is in operation for more than 15 minutes is an operating hour for that emission unit. A day is the 24-hour period from midnight to midnight. Any day with at least one operating hour for an emissions unit is an operating day for that emission unit. [Rule 62-4.070(3), F.A.C.]
11. Valid Hourly Averages: Each CEMS shall be designed and operated to sample, analyze, and record data evenly spaced over the hour at a minimum of one measurement per minute. Each hourly average value shall be computed using at least one data point in each fifteen-minute quadrant of an hour, where the unit combusted fuel during that quadrant of an hour. All valid measurements collected during an hour shall be used to calculate a 1-hour block average that begins at the top of each hour.
  - a. Hours that are not operating hours are not valid hours.
  - b. For each operating hour, the 1-hour block average shall be computed from at least two data points separated by a minimum of 15 minutes. If less than two such data points are available, there is insufficient data, the 1-hour block average is not valid, and the hour is considered as "monitor unavailable."[Rule 62-4.070(3), F.A.C.]
12. Calculation Approaches: The permittee shall implement the calculation approach specified by this permit for each CEMS, as follows:
  - a. *3-Hour Rolling Average (CO)*: Compliance with the 3-hour rolling average shall be determined after each operating hour by calculating and recording the arithmetic average of all valid hourly averages for the previous 3 operating hours (compliance period).
  - b. *4-Hour Rolling Average (NO<sub>x</sub>)*: Compliance with the 4-hour rolling average shall be determined after each operating hour by calculating and recording the arithmetic average of all valid hourly averages for the previous 4 operating hours (compliance period).[Rule 62-4.070(3), F.A.C.]
13. Minimum Valid Hours: At least one valid hourly average shall be used to calculate the emissions over any averaging period specified by this permit. One valid hourly average shall be sufficient to calculate the emissions over any averaging period. [Rule 62-4.070(3), F.A.C.]

**MONITOR AVAILABILITY**

14. Monitor Availability: Monitor availability shall be calculated on a quarterly basis for each emission unit as the number of valid hourly averages obtained by the CEMS, divided by the number of operating hours, times 100%. The monitor availability calculation shall not include periods of time where the monitor was functioning properly, but was unable to collect data while conducting a mandated quality assurance/quality control activity such as calibration error tests, RATA, calibration gas audit, or relative accuracy audits (RAA). Monitor availability for each CEMS shall be 95% or greater in any calendar quarter. Monitor availability shall be reported in the quarterly excess emissions report. In the event 95% availability is not achieved, the permittee shall provide the Department with a report identifying the problems in achieving 95% availability and a plan of corrective actions that will be taken to achieve 95% availability. The permittee shall implement the reported corrective actions within the next calendar quarter. Failure to take corrective actions or continued failure to achieve the minimum monitor availability shall be violations of this permit. [Rule 62-4.070(3), F.A.C.]

## Standard Continuous Monitoring Requirements

**EXCESS EMISSIONS**15. Definitions:

- a. *Excess Emissions* (under the Florida SIP) are defined as emissions of pollutants in excess of those allowed by any applicable air pollution rule of the Department, or by a permit issued pursuant to any such rule or Chapter 62-4, F.A.C. The term applies only to conditions which occur during startup, shutdown, or malfunction.
- b. *Startup* is defined as the commencement of operation of any emissions unit which has shut down or ceased operation for a period of time sufficient to cause temperature, pressure, chemical or pollution control device imbalances, which result in excess emissions.
- c. *Shutdown* means the cessation of the operation of an emissions unit for any purpose.
- d. *Malfunction* means any unavoidable mechanical and/or electrical failure of air pollution control equipment or process equipment or of a process resulting in operation in an abnormal or unusual manner.

[Rule 62-210.200(Definitions), F.A.C.]

16. Excess Emissions Prohibited: Excess emissions caused entirely or in part by poor maintenance, poor operation or any other equipment or process failure that may reasonably be prevented during startup, shutdown or malfunction shall be prohibited. All such preventable emissions shall be included in any compliance determinations based on CEMS data. [Rules 62-210.700(4), F.A.C.]

17. Data Exclusion Procedures for SIP Compliance: In accordance with the procedures of this condition and Condition D.10 in Subsection III.D of the permit, limited amounts of CEMS CO emissions data may be excluded from the corresponding compliance demonstration, provided that best operational practices to minimize emissions are adhered to and the duration of data excluded is minimized. The data exclusion procedures of this condition apply only to SIP-based emission limits.

- a. *Excess Emissions.* Data in excess of the applicable emission standard may be excluded from compliance calculations if the data are collected during periods of permitted excess emissions (for example, during startup, shutdown or malfunction).
- b. *Limited Data Exclusion.* If the compliance calculation using all valid CEMS emission data, as defined in this appendix, indicates that the emission unit is in compliance, then no CEMS data shall be excluded from the compliance demonstration.
- c. *Event Driven Exclusion.* The underlying event (for example, the startup, shutdown or malfunction event) must precede the data exclusion. If there is no underlying event, then no data may be excluded. Only data collected during the event may be excluded.
- d. *Reporting Excluded Data.* The data exclusion procedures of this condition are not necessarily the same procedures used for excess emissions as defined by federal rules. Quarterly or semi-annual reports required by this permit shall indicate not only the duration of data excluded from SIP compliance calculations but also the number of excess emissions as defined by federal rules.

[Rule 62-4.070(3), F.A.C.]

18. Notification Requirements: The permittee shall notify the Compliance Authority within one working day of discovering any emissions that demonstrate non-compliance for a given averaging period. [Rule 62-4.070(3), F.A.C.]

**CALCULATING AND REPORTING ANNUAL EMISSIONS**

19. CEMS for Calculating Annual Emissions: As defined by this Appendix, all valid data shall be used when calculating annual emissions.
  - a. Annual emissions shall include data collected during startup, shutdown, and malfunction periods.
  - b. Annual emissions shall include data collected during periods when the emission unit is not operating, but emissions are being generated (for example, firing fuel to warm up a process for some period of time prior to the emission unit's "official" startup).
  - c. Annual emissions shall not include data from periods of time where the monitor was functioning properly but was unable to collect data while conducting a mandated quality assurance/quality control activity such as calibration error tests, RATA, calibration gas audit, or RAA. These periods of time shall be considered "missing

---

**Standard Continuous Monitoring Requirements**

---

data” for purposes of calculating annual emissions.

- d. Annual emissions shall not include data from periods of time when emissions are in excess of the calibrated span of the CEMS. These periods of time shall be considered “missing data” for purposes of calculating annual emissions.

[Rule 62-210.370, F.A.C.]

20. Accounting for Missing Data: All valid measurements collected during each hour shall be used to calculate a 1-hour block average that begins at the top of each hour. For each hour, the 1-hour block average shall be computed from at least two data points separated by a minimum of 15 minutes. If less than two such data points are available, the permittee shall account for emissions during that hour using site-specific data to generate a reasonable estimate of the 1-hour block average.
21. Emissions Calculation: Annual emissions shall be calculated as the sum of all valid emissions occurring during the year.
22. Reporting Annual Emissions: The permittee shall use data from each required CEMS when calculating annual emissions for purposes of computing actual emissions, baseline actual emissions, and net emissions increase, as defined at Rule 62-210.200, F.A.C., and for purposes of computing emissions pursuant to the reporting requirements of Rules 62-210.370(3) and 62-212.300(1)(e), F.A.C. [Rule 62-4.070(3), F.A.C.]



## Common Regulatory Requirements

Unless otherwise specified in the permit, the following conditions apply to all emissions units and activities at the facility.

**Emissions and Controls.**

1. **Plant Operation - Problems:** If temporarily unable to comply with any of the conditions of the permit due to breakdown of equipment or destruction by fire, wind or other cause, the permittee shall notify each Compliance Authority as soon as possible, but at least within one working day, excluding weekends and holidays. The notification shall include: pertinent information as to the cause of the problem; steps being taken to correct the problem and prevent future recurrence; and, where applicable, the owner's intent toward reconstruction of destroyed facilities. Such notification does not release the permittee from any liability for failure to comply with the conditions of this permit or the regulations.  
[Rule 62-4.130, F.A.C.]
2. **Circumvention:** The permittee shall not circumvent the air pollution control equipment or allow the emission of air pollutants without this equipment operating properly.  
[Rule 62-210.650, F.A.C.]
3. **Excess Emissions Allowed:** Excess emissions resulting from startup, shutdown or malfunction of any emissions unit shall be permitted providing (1) best operational practices to minimize emissions are adhered to and (2) the duration of excess emissions shall be minimized but in no case exceed 2 hours in any 24-hour period unless specifically authorized by the Department for longer duration. Pursuant to Rule 62-210.700(5), F.A.C., the permit subsection may specify more or less stringent requirements for periods of excess emissions. Rule 62-210-700(Excess Emissions), F.A.C., cannot vary or supersede any federal NSPS or NESHAP provision.  
[Rule 62-210.700(1), F.A.C.]
4. **Excess Emissions Prohibited:** Excess emissions caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure that may reasonably be prevented during startup, shutdown or malfunction shall be prohibited.  
[Rule 62-210.700(4), F.A.C.]
5. **Excess Emissions - Notification:** In case of excess emissions resulting from malfunctions, the permittee shall notify the Compliance Authority in accordance with Rule 62-4.130, F.A.C. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department.  
[Rule 62-210.700(6), F.A.C.]
6. **VOC or OS Emissions:** No person shall store, pump, handle, process, load, unload or use in any process or installation, volatile organic compounds (VOC) or organic solvents (OS) without applying known and existing vapor emission control devices or systems deemed necessary and ordered by the Department.  
[Rule 62-296.320(1), F.A.C.]
7. **Objectionable Odor Prohibited:** No person shall cause, suffer, allow or permit the discharge of air pollutants, which cause or contribute to an objectionable odor. An "objectionable odor" means any odor present in the outdoor atmosphere which by itself or in combination with other odors, is or may be harmful or injurious to human health or welfare, which unreasonably interferes with the comfortable use and enjoyment of life or property, or which creates a nuisance.  
[Rules 62-296.320(2) and 62-210.200(Definitions), F.A.C.]
8. **General Visible Emissions:** No person shall cause, let, permit, suffer or allow to be discharged into the atmosphere the emissions of air pollutants from any activity equal to or greater than 20% opacity. This regulation does not impose a specific testing requirement.  
[Rule 62-296.320(4)(b)1, F.A.C.]
9. **Unconfined Particulate Emissions:** During the construction period, unconfined particulate matter emissions shall be minimized by dust suppressing techniques such as covering and/or application of water or chemicals to the affected areas, as necessary.  
[Rule 62-296.320(4)(c), F.A.C.]

**Records and Reports.**

10. **Records Retention:** All measurements, records, and other data required by this permit shall be documented in a permanent, legible format and retained for at least 5 years following the date on which such measurements, records, or data are recorded. Records shall be made available to the Department upon request.  
[Rule 62-213.440(1)(b)2, F.A.C.]

## Common Regulatory Requirements

11. Emissions Computation and Reporting:

- a. *Applicability.* This rule sets forth required methodologies to be used by the owner or operator of a facility for computing actual emissions, baseline actual emissions, and net emissions increase, as defined at Rule 62-210.200, F.A.C., and for computing emissions for purposes of the reporting requirements of subsection 62-210.370(3) and paragraph 62-212.300(1)(e), F.A.C., or of any permit condition that requires emissions be computed in accordance with this rule. This rule is not intended to establish methodologies for determining compliance with the emission limitations of any air permit.
- b. *Computation of Emissions.* For any of the purposes set forth in subsection 62-210.370(1), F.A.C., the owner or operator of a facility shall compute emissions in accordance with the requirements set forth in this subsection.
- (1) **Basic Approach.** The owner or operator shall employ, on a pollutant-specific basis, the most accurate of the approaches set forth below to compute the emissions of a pollutant from an emissions unit; provided, however, that nothing in this rule shall be construed to require installation and operation of any continuous emissions monitoring system (CEMS), continuous parameter monitoring system (CPMS), or predictive emissions monitoring system (PEMS) not otherwise required by rule or permit, nor shall anything in this rule be construed to require performance of any stack testing not otherwise required by rule or permit.
- (a) If the emissions unit is equipped with a CEMS meeting the requirements of paragraph 62-210.370(2)(b), F.A.C., the owner or operator shall use such CEMS to compute the emissions of the pollutant, unless the owner or operator demonstrates to the department that an alternative approach is more accurate because the CEMS represents still-emerging technology.
- (b) If a CEMS is not available or does not meet the requirements of paragraph 62-210.370(2)(b), F.A.C., but emissions of the pollutant can be computed pursuant to the mass balance methodology of paragraph 62-210.370(2)(c), F.A.C., the owner or operator shall use such methodology, unless the owner or operator demonstrates to the department that an alternative approach is more accurate.
- (c) If a CEMS is not available or does not meet the requirements of paragraph 62-210.370(2)(b), F.A.C., and emissions cannot be computed pursuant to the mass balance methodology, the owner or operator shall use an emission factor meeting the requirements of paragraph 62-210.370(2)(d), F.A.C., unless the owner or operator demonstrates to the department that an alternative approach is more accurate.
- (2) **Continuous Emissions Monitoring System (CEMS).**
- (a) An owner or operator may use a CEMS to compute emissions of a pollutant for purposes of this rule provided:
- 1) The CEMS complies with the applicable certification and quality assurance requirements of 40 CFR Part 60, Appendices B and F, or, for an acid rain unit, the certification and quality assurance requirements of 40 CFR Part 75, all adopted by reference at Rule 62-204.800, F.A.C.; or
- 2) The owner or operator demonstrates that the CEMS otherwise represents the most accurate means of computing emissions for purposes of this rule.
- (b) Stack gas volumetric flow rates used with the CEMS to compute emissions shall be obtained by the most accurate of the following methods as demonstrated by the owner or operator:
- 1) A calibrated flow meter that records data on a continuous basis, if available; or
- 2) The average flow rate of all valid stack tests conducted during a five-year period encompassing the period over which the emissions are being computed, provided all stack tests used shall represent the same operational and physical configuration of the unit.
- (c) The owner or operator may use CEMS data in combination with an appropriate f-factor, heat input data, and any other necessary parameters to compute emissions if such method is demonstrated by the owner or operator to be more accurate than using a stack gas volumetric flow rate as set forth at subparagraph 62-210.370(2)(b)2., F.A.C., above.
- (3) **Mass Balance Calculations.**
- (a) An owner or operator may use mass balance calculations to compute emissions of a pollutant for purposes of this rule provided the owner or operator:

## Common Regulatory Requirements

- 1) Demonstrates a means of validating the content of the pollutant that is contained in or created by all materials or fuels used in or at the emissions unit; and
  - 2) Assumes that the emissions unit emits all of the pollutant that is contained in or created by any material or fuel used in or at the emissions unit if it cannot otherwise be accounted for in the process or in the capture and destruction of the pollutant by the unit's air pollution control equipment.
- (b) Where the vendor of a raw material or fuel which is used in or at the emissions unit publishes a range of pollutant content from such material or fuel, the owner or operator shall use the highest value of the range to compute the emissions, unless the owner or operator demonstrates using site-specific data that another content within the range is more accurate.
- (c) In the case of an emissions unit using coatings or solvents, the owner or operator shall document, through purchase receipts, records and sales receipts, the beginning and ending VOC inventories, the amount of VOC purchased during the computational period, and the amount of VOC disposed of in the liquid phase during such period.
- (4) Emission Factors.
- a. An owner or operator may use an emission factor to compute emissions of a pollutant for purposes of this rule provided the emission factor is based on site-specific data such as stack test data, where available, unless the owner or operator demonstrates to the department that an alternative emission factor is more accurate. An owner or operator using site-specific data to derive an emission factor, or set of factors, shall meet the following requirements.
    - 1) If stack test data are used, the emission factor shall be based on the average emissions per unit of input, output, or gas volume, whichever is appropriate, of all valid stack tests conducted during at least a five-year period encompassing the period over which the emissions are being computed, provided all stack tests used shall represent the same operational and physical configuration of the unit.
    - 2) Multiple emission factors shall be used as necessary to account for variations in emission rate associated with variations in the emissions unit's operating rate or operating conditions during the period over which emissions are computed.
    - 3) The owner or operator shall compute emissions by multiplying the appropriate emission factor by the appropriate input, output or gas volume value for the period over which the emissions are computed. The owner or operator shall not compute emissions by converting an emission factor to pounds per hour and then multiplying by hours of operation, unless the owner or operator demonstrates that such computation is the most accurate method available.
  - b. If site-specific data are not available to derive an emission factor, the owner or operator may use a published emission factor directly applicable to the process for which emissions are computed. If no directly-applicable emission factor is available, the owner or operator may use a factor based on a similar, but different, process.
- (5) Accounting for Emissions During Periods of Missing Data from CEMS, PEMS, or CPMS. In computing the emissions of a pollutant, the owner or operator shall account for the emissions during periods of missing data from CEMS, PEMS, or CPMS using other site-specific data to generate a reasonable estimate of such emissions.
- (6) Accounting for Emissions During Periods of Startup and Shutdown. In computing the emissions of a pollutant, the owner or operator shall account for the emissions during periods of startup and shutdown of the emissions unit.
- (7) Fugitive Emissions. In computing the emissions of a pollutant from a facility or emissions unit, the owner or operator shall account for the fugitive emissions of the pollutant, to the extent quantifiable, associated with such facility or emissions unit.
- (8) Recordkeeping. The owner or operator shall retain a copy of all records used to compute emissions pursuant to this rule for a period of five years from the date on which such emissions information is submitted to the department for any regulatory purpose.

## Common Regulatory Requirements

c. *Annual Operating Report for Air Pollutant Emitting Facility*

- (1) The Annual Operating Report for Air Pollutant Emitting Facility (DEP Form No. 62-210.900(5)) shall be completed each year for the following facilities:
  - a. All Title V sources.
  - b. All synthetic non-Title V sources.
  - c. All facilities with the potential to emit ten (10) tons per year or more of volatile organic compounds or twenty-five (25) tons per year or more of nitrogen oxides and located in an ozone nonattainment area or ozone air quality maintenance area.
  - d. All facilities for which an annual operating report is required by rule or permit.
- (2) Notwithstanding paragraph 62-210.370(3)(a), F.A.C., no annual operating report shall be required for any facility operating under an air general permit.
- (3) The annual operating report shall be submitted to the appropriate Department of Environmental Protection (DEP) division, district or DEP-approved local air pollution control program office by April 1<sup>st</sup> of the following year. If the report is submitted using the Department's electronic annual operating report software, there is no requirement to submit a copy to any DEP or local air program office.
- (4) Emissions shall be computed in accordance with the provisions of subsection 62-210.370(2), F.A.C., for purposes of the annual operating report.
- (5) Facility Relocation. Unless otherwise provided by rule or more stringent permit condition, the owner or operator of a relocatable facility must submit a Facility Relocation Notification Form (DEP Form No. 62-210.900(6)) to the Department at least 30 days prior to the relocation. A separate form shall be submitted for each facility in the case of the relocation of multiple facilities which are jointly owned or operated.

[Rule 62-210.370, F.A.C.]

**Federal Regulations Adopted by Reference**

In accordance with Rule 62-204.800, F.A.C., the following federal regulation in Title 40 of the Code of Federal Regulations (CFR) was adopted by reference. The original federal rule numbering has been retained.

*Federal Revision Date: February 24, 2006*

*State Rule Effective Date: July 1, 2006*

*Standardized Conditions Revision Date: August 6, 2009*

**40 CFR Part 60, Subpart GG - Standards of Performance for Stationary Gas Turbines****§ 60.330 Applicability and designation of affected facility.**

- (a) The provisions of this subpart are applicable to the following affected facilities: All stationary gas turbines with a heat input at peak load equal to or greater than 10.7 gigajoules (10 million Btu) per hour, based on the lower heating value of the fuel fired.
- (b) Any facility under paragraph (a) of this section which commences construction, modification, or reconstruction after October 3, 1977, is subject to the requirements of this part except as provided in paragraphs (e) and (j) of §60.332.

[44 FR 52798, Sept. 10, 1979, as amended at 52 FR 42434, Nov. 5, 1987; 65 FR 61759, Oct. 17, 2000]

**§ 60.331 Definitions.**

As used in this subpart, all terms not defined herein shall have the meaning given them in the Act and in subpart A of this part.

- (a) *Stationary gas turbine* means any simple cycle gas turbine, regenerative cycle gas turbine or any gas turbine portion of a combined cycle steam/electric generating system that is not self propelled. It may, however, be mounted on a vehicle for portability.
- (b) *Simple cycle gas turbine* means any stationary gas turbine which does not recover heat from the gas turbine exhaust gases to preheat the inlet combustion air to the gas turbine, or which does not recover heat from the gas turbine exhaust gases to heat water or generate steam.
- (c) *Regenerative cycle gas turbine* means any stationary gas turbine which recovers heat from the gas turbine exhaust gases to preheat the inlet combustion air to the gas turbine.
- (d) *Combined cycle gas turbine* means any stationary gas turbine which recovers heat from the gas turbine exhaust gases to heat water or generate steam.
- (e) *Emergency gas turbine* means any stationary gas turbine which operates as a mechanical or electrical power source only when the primary power source for a facility has been rendered inoperable by an emergency situation.
- (f) *Ice fog* means an atmospheric suspension of highly reflective ice crystals.
- (g) *ISO standard day conditions* means 288 degrees Kelvin, 60 percent relative humidity and 101.3 kilopascals pressure.
- (h) *Efficiency* means the gas turbine manufacturer's rated heat rate at peak load in terms of heat input per unit of power output based on the lower heating value of the fuel.
- (i) *Peak load* means 100 percent of the manufacturer's design capacity of the gas turbine at ISO standard day conditions.
- (j) *Base load* means the load level at which a gas turbine is normally operated.
- (k) *Fire-fighting turbine* means any stationary gas turbine that is used solely to pump water for extinguishing fires.
- (l) *Turbines employed in oil/gas production or oil/gas transportation* means any stationary gas turbine used to provide power to extract crude oil/natural gas from the earth or to move crude oil/natural gas, or products refined from these substances through pipelines.
- (m) A *Metropolitan Statistical Area* or *MSA* as defined by the Department of Commerce.
- (n) *Offshore platform gas turbines* means any stationary gas turbine located on a platform in an ocean.
- (o) *Garrison facility* means any permanent military installation.

## NSPS Subpart GG for Stationary Gas Turbines

- (p) *Gas turbine model* means a group of gas turbines having the same nominal air flow, combustor inlet pressure, combustor inlet temperature, firing temperature, turbine inlet temperature and turbine inlet pressure.
- (q) *Electric utility stationary gas turbine* means any stationary gas turbine constructed for the purpose of supplying more than one-third of its potential electric output capacity to any utility power distribution system for sale.
- (r) *Emergency fuel* is a fuel fired by a gas turbine only during circumstances, such as natural gas supply curtailment or breakdown of delivery system, that make it impossible to fire natural gas in the gas turbine.
- (s) *Unit operating hour* means a clock hour during which any fuel is combusted in the affected unit. If the unit combusts fuel for the entire clock hour, it is considered to be a full unit operating hour. If the unit combusts fuel for only part of the clock hour, it is considered to be a partial unit operating hour.
- (t) *Excess emissions* means a specified averaging period over which either:
- (1) The NO<sub>x</sub> emissions are higher than the applicable emission limit in §60.332;
  - (2) The total sulfur content of the fuel being combusted in the affected facility exceeds the limit specified in §60.333; or
  - (3) The recorded value of a particular monitored parameter is outside the acceptable range specified in the parameter monitoring plan for the affected unit.
- (u) *Natural gas* means a naturally occurring fluid mixture of hydrocarbons ( e.g. , methane, ethane, or propane) produced in geological formations beneath the Earth's surface that maintains a gaseous state at standard atmospheric temperature and pressure under ordinary conditions. Natural gas contains 20.0 grains or less of total sulfur per 100 standard cubic feet. Equivalents of this in other units are as follows: 0.068 weight percent total sulfur, 680 parts per million by weight (ppmw) total sulfur, and 338 parts per million by volume (ppmv) at 20 degrees Celsius total sulfur. Additionally, natural gas must either be composed of at least 70 percent methane by volume or have a gross calorific value between 950 and 1100 British thermal units (Btu) per standard cubic foot. Natural gas does not include the following gaseous fuels: landfill gas, digester gas, refinery gas, sour gas, blast furnace gas, coal-derived gas, producer gas, coke oven gas, or any gaseous fuel produced in a process which might result in highly variable sulfur content or heating value.
- (v) *Duct burner* means a device that combusts fuel and that is placed in the exhaust duct from another source, such as a stationary gas turbine, internal combustion engine, kiln, etc., to allow the firing of additional fuel to heat the exhaust gases before the exhaust gases enter a heat recovery steam generating unit.
- (w) *Lean premix stationary combustion turbine* means any stationary combustion turbine where the air and fuel are thoroughly mixed to form a lean mixture for combustion in the combustor. Mixing may occur before or in the combustion chamber. A unit which is capable of operating in both lean premix and diffusion flame modes is considered a lean premix stationary combustion turbine when it is in the lean premix mode, and it is considered a diffusion flame stationary combustion turbine when it is in the diffusion flame mode.
- (x) *Diffusion flame stationary combustion turbine* means any stationary combustion turbine where fuel and air are injected at the combustor and are mixed only by diffusion prior to ignition. A unit which is capable of operating in both lean premix and diffusion flame modes is considered a lean premix stationary combustion turbine when it is in the lean premix mode, and it is considered a diffusion flame stationary combustion turbine when it is in the diffusion flame mode.
- (y) *Unit operating day* means a 24-hour period between 12:00 midnight and the following midnight during which any fuel is combusted at any time in the unit. It is not necessary for fuel to be combusted continuously for the entire 24-hour period.

[44 FR 52798, Sept. 10, 1979, as amended at 47 FR 3770, Jan. 27, 1982; 65 FR 61759, Oct. 17, 2000; 69 FR 41359, July 8, 2004]

### § 60.332 Standard for nitrogen oxides.

- (a) On and after the date on which the performance test required by §60.8 is completed, every owner or operator subject to the provisions of this subpart as specified in paragraphs (b), (c), and (d) of this section shall comply with one of the following, except as provided in paragraphs (e), (f), (g), (h), (i), (j), (k), and (l) of this section.
- (1) No owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any stationary gas turbine, any gases which contain nitrogen oxides in excess of:

**APPENDIX GG**

**NSPS Subpart GG for Stationary Gas Turbines**

$$STD = 0.0075 \frac{(14.4)}{Y} + F$$

where:

STD = allowable ISO corrected (if required as given in §60.335(b)(1)) NO<sub>x</sub> emission concentration (percent by volume at 15 percent oxygen and on a dry basis),

Y = manufacturer's rated heat rate at manufacturer's rated load (kilojoules per watt hour) or, actual measured heat rate based on lower heating value of fuel as measured at actual peak load for the facility. The value of Y shall not exceed 14.4 kilojoules per watt hour, and

F = NO<sub>x</sub> emission allowance for fuel-bound nitrogen as defined in paragraph (a)(4) of this section.

(2) No owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any stationary gas turbine, any gases which contain nitrogen oxides in excess of:

$$STD = 0.0150 \frac{(14.4)}{Y} + F$$

where:

STD = allowable ISO corrected (if required as given in §60.335(b)(1)) NO<sub>x</sub> emission concentration (percent by volume at 15 percent oxygen and on a dry basis),

Y = manufacturer's rated heat rate at manufacturer's rated peak load (kilojoules per watt hour), or actual measured heat rate based on lower heating value of fuel as measured at actual peak load for the facility. The value of Y shall not exceed 14.4 kilojoules per watt hour, and

F = NO<sub>x</sub> emission allowance for fuel-bound nitrogen as defined in paragraph (a)(4) of this section.

(3) The use of F in paragraphs (a)(1) and (2) of this section is optional. That is, the owner or operator may choose to apply a NO<sub>x</sub> allowance for fuel-bound nitrogen and determine the appropriate F-value in accordance with paragraph (a)(4) of this section or may accept an F-value of zero.

(4) If the owner or operator elects to apply a NO<sub>x</sub> emission allowance for fuel-bound nitrogen, F shall be defined according to the nitrogen content of the fuel during the most recent performance test required under §60.8 as follows:

| Fuel-bound nitrogen (percent by weight) | F (NO <sub>x</sub> percent by volume) |
|---|---------------------------------------|
| N ≤ 0.015                               | 0                                     |
| 0.015 < N ≤ 0.1                         | 0.04(N)                               |
| 0.1 < N ≤ 0.25                          | 0.004+0.0067(N-0.1)                   |
| N > 0.25                                | 0.005                                 |

Where:

N = the nitrogen content of the fuel (percent by weight).

or:

Manufacturers may develop and submit to EPA custom fuel-bound nitrogen allowances for each gas turbine model they manufacture. These fuel-bound nitrogen allowances shall be substantiated with data and must be approved for use by the Administrator before the initial performance test required by §60.8. Notices of approval of custom fuel-bound nitrogen allowances will be published in the Federal Register.

(b) Electric utility stationary gas turbines with a heat input at peak load greater than 107.2 gigajoules per hour (100 million Btu/hour) based on the lower heating value of the fuel fired shall comply with the provisions of paragraph (a)(1) of this section.

## NSPS Subpart GG for Stationary Gas Turbines

- (c) Stationary gas turbines with a heat input at peak load equal to or greater than 10.7 gigajoules per hour (10 million Btu/hour) but less than or equal to 107.2 gigajoules per hour (100 million Btu/hour) based on the lower heating value of the fuel fired, shall comply with the provisions of paragraph (a)(2) of this section.
- (d) Stationary gas turbines with a manufacturer's rated base load at ISO conditions of 30 megawatts or less except as provided in §60.332(b) shall comply with paragraph (a)(2) of this section.
- (e) Stationary gas turbines with a heat input at peak load equal to or greater than 10.7 gigajoules per hour (10 million Btu/hour) but less than or equal to 107.2 gigajoules per hour (100 million Btu/hour) based on the lower heating value of the fuel fired and that have commenced construction prior to October 3, 1982 are exempt from paragraph (a) of this section.
- (f) Stationary gas turbines using water or steam injection for control of NO<sub>x</sub> emissions are exempt from paragraph (a) when ice fog is deemed a traffic hazard by the owner or operator of the gas turbine.
- (g) Emergency gas turbines, military gas turbines for use in other than a garrison facility, military gas turbines installed for use as military training facilities, and fire fighting gas turbines are exempt from paragraph (a) of this section.
- (h) Stationary gas turbines engaged by manufacturers in research and development of equipment for both gas turbine emission control techniques and gas turbine efficiency improvements are exempt from paragraph (a) on a case-by-case basis as determined by the Administrator.
- (i) Exemptions from the requirements of paragraph (a) of this section will be granted on a case-by-case basis as determined by the Administrator in specific geographical areas where mandatory water restrictions are required by governmental agencies because of drought conditions. These exemptions will be allowed only while the mandatory water restrictions are in effect.
- (j) Stationary gas turbines with a heat input at peak load greater than 107.2 gigajoules per hour that commenced construction, modification, or reconstruction between the dates of October 3, 1977, and January 27, 1982, and were required in the September 10, 1979, Federal Register(44 FR 52792) to comply with paragraph (a)(1) of this section, except electric utility stationary gas turbines, are exempt from paragraph (a) of this section.
- (k) Stationary gas turbines with a heat input greater than or equal to 10.7 gigajoules per hour (10 million Btu/hour) when fired with natural gas are exempt from paragraph (a)(2) of this section when being fired with an emergency fuel.
- (l) Regenerative cycle gas turbines with a heat input less than or equal to 107.2 gigajoules per hour (100 million Btu/hour) are exempt from paragraph (a) of this section.

[44 FR 52798, Sept. 10, 1979, as amended at 47 FR 3770, Jan. 27, 1982; 65 FR 61759, Oct. 17, 2000; 69 FR 41359, July 8, 2004]

#### § 60.333 Standard for sulfur dioxide.

On and after the date on which the performance test required to be conducted by §60.8 is completed, every owner or operator subject to the provision of this subpart shall comply with one or the other of the following conditions:

- (a) No owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any stationary gas turbine any gases which contains sulfur dioxide in excess of 0.015 percent by volume at 15 percent oxygen and on a dry basis.
- (b) No owner or operator subject to the provisions of this subpart shall burn in any stationary gas turbine any fuel which contains total sulfur in excess of 0.8 percent by weight (8000 ppmw).

[44 FR 52798, Sept. 10, 1979, as amended at 69 FR 41360, July 8, 2004]

#### § 60.334 Monitoring of operations.

- (a) Except as provided in paragraph (b) of this section, the owner or operator of any stationary gas turbine subject to the provisions of this subpart and using water or steam injection to control NO<sub>x</sub> emissions shall install, calibrate, maintain and operate a continuous monitoring system to monitor and record the fuel consumption and the ratio of water or steam to fuel being fired in the turbine.
- (b) The owner or operator of any stationary gas turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and which uses water or steam injection to control NO<sub>x</sub> emissions may, as an alternative to operating the continuous monitoring system described in paragraph (a) of this section, install, certify, maintain, operate, and quality-assure a continuous emission monitoring system (CEMS) consisting of NO<sub>x</sub> and O<sub>2</sub>



monitors. As an alternative, a CO<sub>2</sub> monitor may be used to adjust the measured NO<sub>x</sub> concentrations to 15 percent O<sub>2</sub> by either converting the CO<sub>2</sub> hourly averages to equivalent O<sub>2</sub> concentrations using Equation F-14a or F-14b in appendix F to part 75 of this chapter and making the adjustments to 15 percent O<sub>2</sub>, or by using the CO<sub>2</sub> readings directly to make the adjustments, as described in Method 20. If the option to use a CEMS is chosen, the CEMS shall be installed, certified, maintained and operated as follows:

- (1) Each CEMS must be installed and certified according to PS 2 and 3 (for diluent) of 40 CFR part 60, appendix B, except the 7-day calibration drift is based on unit operating days, not calendar days. Appendix F, Procedure 1 is not required. The relative accuracy test audit (RATA) of the NO<sub>x</sub> and diluent monitors may be performed individually or on a combined basis, *i.e.*, the relative accuracy tests of the CEMS may be performed either:
  - (i) On a ppm basis (for NO<sub>x</sub>) and a percent O<sub>2</sub> basis for oxygen; or
  - (ii) On a ppm at 15 percent O<sub>2</sub> basis; or
  - (iii) On a ppm basis (for NO<sub>x</sub>) and a percent CO<sub>2</sub> basis (for a CO<sub>2</sub> monitor that uses the procedures in Method 20 to correct the NO<sub>x</sub> data to 15 percent O<sub>2</sub>).
- (2) As specified in §60.13(e)(2), during each full unit operating hour, each monitor must complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each 15-minute quadrant of the hour, to validate the hour. For partial unit operating hours, at least one valid data point must be obtained for each quadrant of the hour in which the unit operates. For unit operating hours in which required quality assurance and maintenance activities are performed on the CEMS, a minimum of two valid data points (one in each of two quadrants) are required to validate the hour.
- (3) For purposes of identifying excess emissions, CEMS data must be reduced to hourly averages as specified in §60.13(h).
  - (i) For each unit operating hour in which a valid hourly average, as described in paragraph (b)(2) of this section, is obtained for both NO<sub>x</sub> and diluent, the data acquisition and handling system must calculate and record the hourly NO<sub>x</sub> emissions in the units of the applicable NO<sub>x</sub> emission standard under §60.332(a), *i.e.*, percent NO<sub>x</sub> by volume, dry basis, corrected to 15 percent O<sub>2</sub> and International Organization for Standardization (ISO) standard conditions (if required as given in §60.335(b)(1)). For any hour in which the hourly average O<sub>2</sub> concentration exceeds 19.0 percent O<sub>2</sub>, a diluent cap value of 19.0 percent O<sub>2</sub> may be used in the emission calculations.
  - (ii) A worst case ISO correction factor may be calculated and applied using historical ambient data. For the purpose of this calculation, substitute the maximum humidity of ambient air (H<sub>o</sub>), minimum ambient temperature (T<sub>a</sub>), and minimum combustor inlet absolute pressure (P<sub>o</sub>) into the ISO correction equation.
  - (iii) If the owner or operator has installed a NO<sub>x</sub> CEMS to meet the requirements of part 75 of this chapter, and is continuing to meet the ongoing requirements of part 75 of this chapter, the CEMS may be used to meet the requirements of this section, except that the missing data substitution methodology provided for at 40 CFR part 75, subpart D, is not required for purposes of identifying excess emissions. Instead, periods of missing CEMS data are to be reported as monitor downtime in the excess emissions and monitoring performance report required in §60.7(c).
- (c) For any turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and which does not use steam or water injection to control NO<sub>x</sub> emissions, the owner or operator may, but is not required to, for purposes of determining excess emissions, use a CEMS that meets the requirements of paragraph (b) of this section. Also, if the owner or operator has previously submitted and received EPA, State, or local permitting authority approval of a procedure for monitoring compliance with the applicable NO<sub>x</sub> emission limit under §60.332, that approved procedure may continue to be used.
- (d) The owner or operator of any new turbine constructed after July 8, 2004, and which uses water or steam injection to control NO<sub>x</sub> emissions may elect to use either the requirements in paragraph (a) of this section for continuous water or steam to fuel ratio monitoring or may use a NO<sub>x</sub> CEMS installed, certified, operated, maintained, and quality-assured as described in paragraph (b) of this section.
- (e) The owner or operator of any new turbine that commences construction after July 8, 2004, and which does not use water or steam injection to control NO<sub>x</sub> emissions, may, but is not required to, elect to use a NO<sub>x</sub> CEMS installed, certified, operated, maintained, and quality-assured as described in paragraph (b) of this section. Other acceptable

monitoring approaches include periodic testing approved by EPA or the State or local permitting authority or continuous parameter monitoring as described in paragraph (f) of this section.

- (f) The owner or operator of a new turbine that commences construction after July 8, 2004, which does not use water or steam injection to control NO<sub>x</sub> emissions may, but is not required to, perform continuous parameter monitoring as follows:
- (1) For a diffusion flame turbine without add-on selective catalytic reduction controls (SCR), the owner or operator shall define at least four parameters indicative of the unit's NO<sub>x</sub> formation characteristics and shall monitor these parameters continuously.
  - (2) For any lean premix stationary combustion turbine, the owner or operator shall continuously monitor the appropriate parameters to determine whether the unit is operating in low-NO<sub>x</sub> mode.
  - (3) For any turbine that uses SCR to reduce NO<sub>x</sub> emissions, the owner or operator shall continuously monitor appropriate parameters to verify the proper operation of the emission controls.
  - (4) For affected units that are also regulated under part 75 of this chapter, if the owner or operator elects to monitor NO<sub>x</sub> emission rate using the methodology in appendix E to part 75 of this chapter, or the low mass emissions methodology in §75.19 of this chapter, the requirements of this paragraph (f) may be met by performing the parametric monitoring described in section 2.3 of appendix E or in §75.19(c)(1)(iv)(H) of this chapter.
- (g) The steam or water to fuel ratio or other parameters that are continuously monitored as described in paragraphs (a), (d) or (f) of this section shall be monitored during the performance test required under §60.8, to establish acceptable values and ranges. The owner or operator may supplement the performance test data with engineering analyses, design specifications, manufacturer's recommendations and other relevant information to define the acceptable parametric ranges more precisely. The owner or operator shall develop and keep on-site a parameter monitoring plan which explains the procedures used to document proper operation of the NO<sub>x</sub> emission controls. The plan shall include the parameter(s) monitored and the acceptable range(s) of the parameter(s) as well as the basis for designating the parameter(s) and acceptable range(s). Any supplemental data such as engineering analyses, design specifications, manufacturer's recommendations and other relevant information shall be included in the monitoring plan. For affected units that are also subject to part 75 of this chapter and that use the low mass emissions methodology in §75.19 of this chapter or the NO<sub>x</sub> emission measurement methodology in appendix E to part 75, the owner or operator may meet the requirements of this paragraph by developing and keeping on-site (or at a central location for unmanned facilities) a quality-assurance plan, as described in §75.19 (e)(5) or in section 2.3 of appendix E and section 1.3.6 of appendix B to part 75 of this chapter.
- (h) The owner or operator of any stationary gas turbine subject to the provisions of this subpart:
- (1) Shall monitor the total sulfur content of the fuel being fired in the turbine, except as provided in paragraph (h)(3) of this section. The sulfur content of the fuel must be determined using total sulfur methods described in §60.335(b)(10). Alternatively, if the total sulfur content of the gaseous fuel during the most recent performance test was less than 0.4 weight percent (4000 ppmw), ASTM D4084–82, 94, D5504–01, D6228–98, or Gas Processors Association Standard 2377–86 (all of which are incorporated by reference-see §60.17), which measure the major sulfur compounds may be used; and
  - (2) Shall monitor the nitrogen content of the fuel combusted in the turbine, if the owner or operator claims an allowance for fuel bound nitrogen (*i.e.*, if an F-value greater than zero is being or will be used by the owner or operator to calculate STD in §60.332). The nitrogen content of the fuel shall be determined using methods described in §60.335(b)(9) or an approved alternative.
  - (3) Notwithstanding the provisions of paragraph (h)(1) of this section, the owner or operator may elect not to monitor the total sulfur content of the gaseous fuel combusted in the turbine, if the gaseous fuel is demonstrated to meet the definition of natural gas in §60.331(u), regardless of whether an existing custom schedule approved by the administrator for subpart GG requires such monitoring. The owner or operator shall use one of the following sources of information to make the required demonstration:
    - (i) The gas quality characteristics in a current, valid purchase contract, tariff sheet or transportation contract for the gaseous fuel, specifying that the maximum total sulfur content of the fuel is 20.0 grains/100 scf or less; or
    - (ii) Representative fuel sampling data which show that the sulfur content of the gaseous fuel does not exceed 20 grains/100 scf. At a minimum, the amount of fuel sampling data specified in section 2.3.1.4 or 2.3.2.4 of appendix D to part 75 of this chapter is required.

## NSPS Subpart GG for Stationary Gas Turbines

- (4) For any turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and for which a custom fuel monitoring schedule has previously been approved, the owner or operator may, without submitting a special petition to the Administrator, continue monitoring on this schedule.
- (i) The frequency of determining the sulfur and nitrogen content of the fuel shall be as follows:
- (1) *Fuel oil.* For fuel oil, use one of the total sulfur sampling options and the associated sampling frequency described in sections 2.2.3, 2.2.4.1, 2.2.4.2, and 2.2.4.3 of appendix D to part 75 of this chapter ( *i.e.* , flow proportional sampling, daily sampling, sampling from the unit's storage tank after each addition of fuel to the tank, or sampling each delivery prior to combining it with fuel oil already in the intended storage tank). If an emission allowance is being claimed for fuel-bound nitrogen, the nitrogen content of the oil shall be determined and recorded once per unit operating day.
  - (2) *Gaseous fuel.* Any applicable nitrogen content value of the gaseous fuel shall be determined and recorded once per unit operating day. For owners and operators that elect not to demonstrate sulfur content using options in paragraph (h)(3) of this section, and for which the fuel is supplied without intermediate bulk storage, the sulfur content value of the gaseous fuel shall be determined and recorded once per unit operating day.
  - (3) *Custom schedules.* Notwithstanding the requirements of paragraph (i)(2) of this section, operators or fuel vendors may develop custom schedules for determination of the total sulfur content of gaseous fuels, based on the design and operation of the affected facility and the characteristics of the fuel supply. Except as provided in paragraphs (i)(3)(i) and (i)(3)(ii) of this section, custom schedules shall be substantiated with data and shall be approved by the Administrator before they can be used to comply with the standard in §60.333.
    - (i) The two custom sulfur monitoring schedules set forth in paragraphs (i)(3)(i)(A) through (D) and in paragraph (i)(3)(ii) of this section are acceptable, without prior Administrative approval:
      - (A) The owner or operator shall obtain daily total sulfur content measurements for 30 consecutive unit operating days, using the applicable methods specified in this subpart. Based on the results of the 30 daily samples, the required frequency for subsequent monitoring of the fuel's total sulfur content shall be as specified in paragraph (i)(3)(i)(B), (C), or (D) of this section, as applicable.
      - (B) If none of the 30 daily measurements of the fuel's total sulfur content exceeds 0.4 weight percent (4000 ppmw), subsequent sulfur content monitoring may be performed at 12 month intervals. If any of the samples taken at 12-month intervals has a total sulfur content between 0.4 and 0.8 weight percent (4000 and 8000 ppmw), follow the procedures in paragraph (i)(3)(i)(C) of this section. If any measurement exceeds 0.8 weight percent (8000 ppmw), follow the procedures in paragraph (i)(3)(i)(D) of this section.
      - (C) If at least one of the 30 daily measurements of the fuel's total sulfur content is between 0.4 and 0.8 weight percent (4000 and 8000 ppmw), but none exceeds 0.8 weight percent (8000 ppmw), then:
        - ( 1 ) Collect and analyze a sample every 30 days for three months. If any sulfur content measurement exceeds 0.8 weight percent (8000 ppmw), follow the procedures in paragraph (i)(3)(i)(D) of this section. Otherwise, follow the procedures in paragraph (i)(3)(i)(C)( 2 ) of this section.
        - ( 2 ) Begin monitoring at 6-month intervals for 12 months. If any sulfur content measurement exceeds 0.8 weight percent (8000 ppmw), follow the procedures in paragraph (i)(3)(i)(D) of this section. Otherwise, follow the procedures in paragraph (i)(3)(i)(C)( 3 ) of this section.
        - ( 3 ) Begin monitoring at 12-month intervals. If any sulfur content measurement exceeds 0.8 weight percent (8000 ppmw), follow the procedures in paragraph (i)(3)(i)(D) of this section. Otherwise, continue to monitor at this frequency.
      - (D) If a sulfur content measurement exceeds 0.8 weight percent (8000 ppmw), immediately begin daily monitoring according to paragraph (i)(3)(i)(A) of this section. Daily monitoring shall continue until 30 consecutive daily samples, each having a sulfur content no greater than 0.8 weight percent (8000 ppmw), are obtained. At that point, the applicable procedures of paragraph (i)(3)(i)(B) or (C) of this section shall be followed.
    - (ii) The owner or operator may use the data collected from the 720-hour sulfur sampling demonstration described in section 2.3.6 of appendix D to part 75 of this chapter to determine a custom sulfur sampling schedule, as follows:

- (A) If the maximum fuel sulfur content obtained from the 720 hourly samples does not exceed 20 grains/100 scf ( *i.e.* , the maximum total sulfur content of natural gas as defined in §60.331(u)), no additional monitoring of the sulfur content of the gas is required, for the purposes of this subpart.
  - (B) If the maximum fuel sulfur content obtained from any of the 720 hourly samples exceeds 20 grains/100 scf, but none of the sulfur content values (when converted to weight percent sulfur) exceeds 0.4 weight percent (4000 ppmw), then the minimum required sampling frequency shall be one sample at 12 month intervals.
  - (C) If any sample result exceeds 0.4 weight percent sulfur (4000 ppmw), but none exceeds 0.8 weight percent sulfur (8000 ppmw), follow the provisions of paragraph (i)(3)(i)(C) of this section.
  - (D) If the sulfur content of any of the 720 hourly samples exceeds 0.8 weight percent (8000 ppmw), follow the provisions of paragraph (i)(3)(i)(D) of this section.
- (j) For each affected unit that elects to continuously monitor parameters or emissions, or to periodically determine the fuel sulfur content or fuel nitrogen content under this subpart, the owner or operator shall submit reports of excess emissions and monitor downtime, in accordance with §60.7(c). Excess emissions shall be reported for all periods of unit operation, including startup, shutdown and malfunction. For the purpose of reports required under §60.7(c), periods of excess emissions and monitor downtime that shall be reported are defined as follows:
- (1) Nitrogen oxides.
    - (i) For turbines using water or steam to fuel ratio monitoring:
      - (A) An excess emission shall be any unit operating hour for which the average steam or water to fuel ratio, as measured by the continuous monitoring system, falls below the acceptable steam or water to fuel ratio needed to demonstrate compliance with §60.332, as established during the performance test required in §60.8. Any unit operating hour in which no water or steam is injected into the turbine shall also be considered an excess emission.
      - (B) A period of monitor downtime shall be any unit operating hour in which water or steam is injected into the turbine, but the essential parametric data needed to determine the steam or water to fuel ratio are unavailable or invalid.
      - (C) Each report shall include the average steam or water to fuel ratio, average fuel consumption, ambient conditions (temperature, pressure, and humidity), gas turbine load, and (if applicable) the nitrogen content of the fuel during each excess emission. You do not have to report ambient conditions if you opt to use the worst case ISO correction factor as specified in §60.334(b)(3)(ii), or if you are not using the ISO correction equation under the provisions of §60.335(b)(1).
    - (ii) If the owner or operator elects to take an emission allowance for fuel bound nitrogen, then excess emissions and periods of monitor downtime are as described in paragraphs (j)(1)(ii)(A) and (B) of this section.
      - (A) An excess emission shall be the period of time during which the fuel-bound nitrogen (N) is greater than the value measured during the performance test required in §60.8 and used to determine the allowance. The excess emission begins on the date and hour of the sample which shows that N is greater than the performance test value, and ends with the date and hour of a subsequent sample which shows a fuel nitrogen content less than or equal to the performance test value.
      - (B) A period of monitor downtime begins when a required sample is not taken by its due date. A period of monitor downtime also begins on the date and hour that a required sample is taken, if invalid results are obtained. The period of monitor downtime ends on the date and hour of the next valid sample.
    - (iii) For turbines using NO<sub>x</sub> and diluent CEMS:
      - (A) An hour of excess emissions shall be any unit operating hour in which the 4-hour rolling average NO<sub>x</sub> concentration exceeds the applicable emission limit in §60.332(a)(1) or (2). For the purposes of this subpart, a "4-hour rolling average NO<sub>x</sub> concentration" is the arithmetic average of the average NO<sub>x</sub> concentration measured by the CEMS for a given hour (corrected to 15 percent O<sub>2</sub> and, if required under §60.335(b)(1), to ISO standard conditions) and the three unit operating hour average NO<sub>x</sub> concentrations immediately preceding that unit operating hour.

## NSPS Subpart GG for Stationary Gas Turbines

- (B) A period of monitor downtime shall be any unit operating hour in which sufficient data are not obtained to validate the hour, for either NO<sub>x</sub> concentration or diluent (or both).
- (C) Each report shall include the ambient conditions (temperature, pressure, and humidity) at the time of the excess emission period and (if the owner or operator has claimed an emission allowance for fuel bound nitrogen) the nitrogen content of the fuel during the period of excess emissions. You do not have to report ambient conditions if you opt to use the worst case ISO correction factor as specified in §60.334(b)(3)(ii), or if you are not using the ISO correction equation under the provisions of §60.335(b)(1).
- (iv) For owners or operators that elect, under paragraph (f) of this section, to monitor combustion parameters or parameters that document proper operation of the NO<sub>x</sub> emission controls:
  - (A) An excess emission shall be a 4-hour rolling unit operating hour average in which any monitored parameter does not achieve the target value or is outside the acceptable range defined in the parameter monitoring plan for the unit.
  - (B) A period of monitor downtime shall be a unit operating hour in which any of the required parametric data are either not recorded or are invalid.
- (2) Sulfur dioxide. If the owner or operator is required to monitor the sulfur content of the fuel under paragraph (h) of this section:
  - (i) For samples of gaseous fuel and for oil samples obtained using daily sampling, flow proportional sampling, or sampling from the unit's storage tank, an excess emission occurs each unit operating hour included in the period beginning on the date and hour of any sample for which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8 weight percent and ending on the date and hour that a subsequent sample is taken that demonstrates compliance with the sulfur limit.
  - (ii) If the option to sample each delivery of fuel oil has been selected, the owner or operator shall immediately switch to one of the other oil sampling options ( *i.e.* , daily sampling, flow proportional sampling, or sampling from the unit's storage tank) if the sulfur content of a delivery exceeds 0.8 weight percent. The owner or operator shall continue to use one of the other sampling options until all of the oil from the delivery has been combusted, and shall evaluate excess emissions according to paragraph (j)(2)(i) of this section. When all of the fuel from the delivery has been burned, the owner or operator may resume using the as-delivered sampling option.
  - (iii) A period of monitor downtime begins when a required sample is not taken by its due date. A period of monitor downtime also begins on the date and hour of a required sample, if invalid results are obtained. The period of monitor downtime shall include only unit operating hours, and ends on the date and hour of the next valid sample.
- (3) *Ice fog*. Each period during which an exemption provided in §60.332(f) is in effect shall be reported in writing to the Administrator quarterly. For each period the ambient conditions existing during the period, the date and time the air pollution control system was deactivated, and the date and time the air pollution control system was reactivated shall be reported. All quarterly reports shall be postmarked by the 30th day following the end of each calendar quarter.
- (4) *Emergency fuel*. Each period during which an exemption provided in §60.332(k) is in effect shall be included in the report required in §60.7(c). For each period, the type, reasons, and duration of the firing of the emergency fuel shall be reported.
- (5) All reports required under §60.7(c) shall be postmarked by the 30th day following the end of each 6-month period.

[44 FR 52798, Sept. 10, 1979, as amended at 47 FR 3770, Jan. 27, 1982; 65 FR 61759, Oct. 17, 2000; 69 FR 41360, July 8, 2004; 71 FR 9457, Feb. 24, 2006]

#### § 60.335 Test methods and procedures.

- (a) The owner or operator shall conduct the performance tests required in §60.8, using either
  - (1) EPA Method 20,
  - (2) ASTM D6522-00 (incorporated by reference, see §60.17), or

NSPS Subpart GG for Stationary Gas Turbines

- (3) EPA Method 7E and either EPA Method 3 or 3A in appendix A to this part, to determine NO<sub>x</sub> and diluent concentration.
- (4) Sampling traverse points are to be selected following Method 20 or Method 1, (non-particulate procedures) and sampled for equal time intervals. The sampling shall be performed with a traversing single-hole probe or, if feasible, with a stationary multi-hole probe that samples each of the points sequentially. Alternatively, a multi-hole probe designed and documented to sample equal volumes from each hole may be used to sample simultaneously at the required points.
- (5) Notwithstanding paragraph (a)(4) of this section, the owner or operator may test at few points than are specified in Method 1 or Method 20 if the following conditions are met:
  - (i) You may perform a stratification test for NO<sub>x</sub> and diluent pursuant to
    - (A) [Reserved]
    - (B) The procedures specified in section 6.5.6.1(a) through (e) appendix A to part 75 of this chapter.
  - (ii) Once the stratification sampling is completed, the owner or operator may use the following alternative sample point selection criteria for the performance test:
    - (A) If each of the individual traverse point NO<sub>x</sub> concentrations, normalized to 15 percent O<sub>2</sub>, is within ±10 percent of the mean normalized concentration for all traverse points, then you may use 3 points (located either 16.7, 50.0, and 83.3 percent of the way across the stack or duct, or, for circular stacks or ducts greater than 2.4 meters (7.8 feet) in diameter, at 0.4, 1.2, and 2.0 meters from the wall). The 3 points shall be located along the measurement line that exhibited the highest average normalized NO<sub>x</sub> concentration during the stratification test; or
    - (B) If each of the individual traverse point NO<sub>x</sub> concentrations, normalized to 15 percent O<sub>2</sub>, is within ±5 percent of the mean normalized concentration for all traverse points, then you may sample at a single point, located at least 1 meter from the stack wall or at the stack centroid.
- (6) Other acceptable alternative reference methods and procedures are given in paragraph (c) of this section.
- (b) The owner or operator shall determine compliance with the applicable nitrogen oxides emission limitation in §60.332 and shall meet the performance test requirements of §60.8 as follows:
  - (1) For each run of the performance test, the mean nitrogen oxides emission concentration (NO<sub>xo</sub>) corrected to 15 percent O<sub>2</sub> shall be corrected to ISO standard conditions using the following equation. Notwithstanding this requirement, use of the ISO correction equation is optional for: Lean premix stationary combustion turbines; units used in association with heat recovery steam generators (HRSG) equipped with duct burners; and units equipped with add-on emission control devices:

$$NO_x = (NO_{x_o})(P_r/P_o)^{0.5} e^{19 (H_o - 0.00633)(288^\circ K/T_a)^{1.53}}$$

Where:

NO<sub>x</sub> = emission concentration of NO<sub>x</sub> at 15 percent O<sub>2</sub> and ISO standard ambient conditions, ppm by volume, dry basis,

NO<sub>xo</sub> = mean observed NO<sub>x</sub> concentration, ppm by volume, dry basis, at 15 percent O<sub>2</sub>,

P<sub>r</sub> = reference combustor inlet absolute pressure at 101.3 kilopascals ambient pressure, mm Hg,

P<sub>o</sub> = observed combustor inlet absolute pressure at test, mm Hg,

H<sub>o</sub> = observed humidity of ambient air, g H<sub>2</sub>O/g air,

e = transcendental constant, 2.718, and

T<sub>a</sub> = ambient temperature, °K.

- (2) The 3-run performance test required by §60.8 must be performed within ±5 percent at 30, 50, 75, and 90-to-100 percent of peak load or at four evenly-spaced load points in the normal operating range of the gas turbine, including the minimum point in the operating range and 90-to-100 percent of peak load, or at the highest achievable load point if 90-to-100 percent of peak load cannot be physically achieved in practice. If the turbine combusts both oil and gas as primary or backup fuels, separate performance testing is required for each fuel.

Notwithstanding these requirements, performance testing is not required for any emergency fuel (as defined in §60.331).

- (3) For a combined cycle turbine system with supplemental heat (duct burner), the owner or operator may elect to measure the turbine NO<sub>x</sub> emissions after the duct burner rather than directly after the turbine. If the owner or operator elects to use this alternative sampling location, the applicable NO<sub>x</sub> emission limit in §60.332 for the combustion turbine must still be met.
- (4) If water or steam injection is used to control NO<sub>x</sub> with no additional post-combustion NO<sub>x</sub> control and the owner or operator chooses to monitor the steam or water to fuel ratio in accordance with §60.334(a), then that monitoring system must be operated concurrently with each EPA Method 20, ASTM D6522-00 (incorporated by reference, see §60.17), or EPA Method 7E run and shall be used to determine the fuel consumption and the steam or water to fuel ratio necessary to comply with the applicable §60.332 NO<sub>x</sub> emission limit.
- (5) If the owner operator elects to claim an emission allowance for fuel bound nitrogen as described in §60.332, then concurrently with each reference method run, a representative sample of the fuel used shall be collected and analyzed, following the applicable procedures described in §60.335(b)(9). These data shall be used to determine the maximum fuel nitrogen content for which the established water (or steam) to fuel ratio will be valid.
- (6) If the owner or operator elects to install a CEMS, the performance evaluation of the CEMS may either be conducted separately (as described in paragraph (b)(7) of this section) or as part of the initial performance test of the affected unit.
- (7) If the owner or operator elects to install and certify a NO<sub>x</sub> CEMS under §60.334(e), then the initial performance test required under §60.8 may be done in the following alternative manner:
  - (i) Perform a minimum of 9 reference method runs, with a minimum time per run of 21 minutes, at a single load level, between 90 and 100 percent of peak (or the highest physically achievable) load.
  - (ii) Use the test data both to demonstrate compliance with the applicable NO<sub>x</sub> emission limit under §60.332 and to provide the required reference method data for the RATA of the CEMS described under §60.334(b).
  - (iii) The requirement to test at three additional load levels is waived.
- (8) If the owner or operator elects under §60.334(f) to monitor combustion parameters or parameters indicative of proper operation of NO<sub>x</sub> emission controls, the appropriate parameters shall be continuously monitored and recorded during each run of the initial performance test, to establish acceptable operating ranges, for purposes of the parameter monitoring plan for the affected unit, as specified in §60.334(g).
- (9) To determine the fuel bound nitrogen content of fuel being fired (if an emission allowance is claimed for fuel bound nitrogen), the owner or operator may use equipment and procedures meeting the requirements of:
  - (i) For liquid fuels, ASTM D2597-94 (Reapproved 1999), D6366-99, D4629-02, D5762-02 (all of which are incorporated by reference, *see* §60.17); or
  - (ii) For gaseous fuels, shall use analytical methods and procedures that are accurate to within 5 percent of the instrument range and are approved by the Administrator.
- (10) If the owner or operator is required under §60.334(i)(1) or (3) to periodically determine the sulfur content of the fuel combusted in the turbine, a minimum of three fuel samples shall be collected during the performance test. Analyze the samples for the total sulfur content of the fuel using:
  - (i) For liquid fuels, ASTM D129-00, D2622-98, D4294-02, D1266-98, D5453-00 or D1552-01 (all of which are incorporated by reference, *see* §60.17); or
  - (ii) For gaseous fuels, ASTM D1072-80, 90 (Reapproved 1994); D3246-81, 92, 96; D4468-85 (Reapproved 2000); or D6667-01 (all of which are incorporated by reference, *see* §60.17). The applicable ranges of some ASTM methods mentioned above are not adequate to measure the levels of sulfur in some fuel gases. Dilution of samples before analysis (with verification of the dilution ratio) may be used, subject to the prior approval of the Administrator.
- (11) The fuel analyses required under paragraphs (b)(9) and (b)(10) of this section may be performed by the owner or operator, a service contractor retained by the owner or operator, the fuel vendor, or any other qualified agency.

**APPENDIX GG**

**NSPS Subpart GG for Stationary Gas Turbines**

---

- (c) The owner or operator may use the following as alternatives to the reference methods and procedures specified in this section:
- (1) Instead of using the equation in paragraph (b)(1) of this section, manufacturers may develop ambient condition correction factors to adjust the nitrogen oxides emission level measured by the performance test as provided in §60.8 to ISO standard day conditions.

[69 FR 41363, July 8, 2004, as amended at 71 FR 9458, Feb. 24, 2006]



**APPENDIX I**  
**Insignificant Activities**

---

The facilities, emissions units, or pollutant-emitting activities listed in Rule 62-210.300(3)(a), F.A.C., Categorical Exemptions, or that meet the criteria specified in Rule 62-210.300(3)(b)1., F.A.C., Generic Emissions Unit Exemption, are exempt from the permitting requirements of Chapters 62-210, 62-212 and 62-4, F.A.C.; provided, however, that exempt emissions units shall be subject to any applicable emission limiting standards and the emissions from exempt emissions units or activities shall be considered in determining the potential emissions of the facility containing such emissions units. Emissions units and pollutant-emitting activities exempt from permitting under Rules 62-210.300(3)(a) and (b)1., F.A.C., shall not be exempt from the permitting requirements of Chapter 62-213, F.A.C., if they are contained within a Title V source; however, such emissions units and activities shall be considered insignificant for Title V purposes provided they also meet the criteria of Rule 62-213.430(6)(b), F.A.C. No emissions unit shall be entitled to an exemption from permitting under Rules 62-210.300(3)(a) and (b)1., F.A.C., if its emissions, in combination with the emissions of other units and activities at the facility, would cause the facility to emit or have the potential to emit any pollutant in such amount as to make the facility a Title V source.

The following emissions units and activities are considered insignificant pursuant to Rule 62-213.430(6), F.A.C.

1. Freshwater cooling tower;
2. Brazing, soldering or welding equipment;
3. Comfort heating units with a gross minimum heat output of less than 1 MMBtu/hour;
4. No. 2 fuel oil storage tanks;
5. No. 2 fuel oil truck unloading operations;
6. Lube oil processing and treating equipment;
7. Laboratory equipment used exclusively for chemical or physical analyses;
8. Turbine vapor extractors;
9. Equipment used for steam cleaning; and
10. Petroleum lubrication systems.

**FEDERAL REGULATIONS ADOPTED BY REFERENCE**

In accordance with rule 62-204.800, F.A.C., the following federal regulation in Title 40 of the Code Of Federal Regulations (CFR) was adopted by reference. The original federal rule numbering has been retained.

*Federal Revision Date: July 11, 2006*

*Rule Effective Date: January 8, 2007*

*Standardized Conditions Revision Date: August 4, 2009*

**40 CFR Part 60, Subpart IIII - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines**

**Source:** 71 FR 39172, July 11, 2006, unless otherwise noted.

**What This Subpart Covers****§ 60.4200 Am I subject to this subpart?**

- (a) The provisions of this subpart are applicable to manufacturers, owners, and operators of stationary compression ignition (CI) internal combustion engines (ICE) as specified in paragraphs (a)(1) through (3) of this section. For the purposes of this subpart, the date that construction commences is the date the engine is ordered by the owner or operator.
  - (1) Manufacturers of stationary CI ICE with a displacement of less than 30 liters per cylinder where the model year is:
    - (i) 2007 or later, for engines that are not fire pump engines,
    - (ii) The model year listed in table 3 to this subpart or later model year, for fire pump engines.
  - (2) Owners and operators of stationary CI ICE that commence construction after July 11, 2005 where the stationary CI ICE are:
    - (i) Manufactured after April 1, 2006 and are not fire pump engines, or
    - (ii) Manufactured as a certified National Fire Protection Association (NFPA) fire pump engine after July 1, 2006.
  - (3) Owners and operators of stationary CI ICE that modify or reconstruct their stationary CI ICE after July 11, 2005.
- (b) The provisions of this subpart are not applicable to stationary CI ICE being tested at a stationary CI ICE test cell/stand.
- (c) If you are an owner or operator of an area source subject to this subpart, you are exempt from the obligation to obtain a permit under 40 CFR part 70 or 40 CFR part 71, provided you are not required to obtain a permit under 40 CFR 70.3(a) or 40 CFR 71.3(a) for a reason other than your status as an area source under this subpart. Notwithstanding the previous sentence, you must continue to comply with the provisions of this subpart applicable to area sources.
- (d) Stationary CI ICE may be eligible for exemption from the requirements of this subpart as described in 40 CFR part 1068, subpart C (or the exemptions described in 40 CFR part 89, subpart J and 40 CFR part 94, subpart J, for engines that would need to be certified to standards in those parts), except that owners and operators, as well as manufacturers, may be eligible to request an exemption for national security.

**EMISSION STANDARDS FOR MANUFACTURERS****§ 60.4201 What emission standards must I meet for non-emergency engines if I am a stationary CI internal combustion engine manufacturer?**

- (a) Stationary CI internal combustion engine manufacturers must certify their 2007 model year and later non-emergency stationary CI ICE with a maximum engine power less than or equal to 2,237 kilowatt (KW) (3,000 horsepower (HP)) and a displacement of less than 10 liters per cylinder to the certification emission standards for new nonroad CI engines in 40 CFR 89.112, 40 CFR 89.113, 40 CFR 1039.101, 40 CFR 1039.102, 40 CFR 1039.104, 40 CFR 1039.105, 40 CFR 1039.107, and 40 CFR 1039.115, as applicable, for all pollutants, for the same model year and maximum engine power.
- (b) Stationary CI internal combustion engine manufacturers must certify their 2007 through 2010 model year non-emergency stationary CI ICE with a maximum engine power greater than 2,237 KW (3,000 HP) and a displacement of less than 10 liters per cylinder to the emission standards in table 1 to this subpart, for all pollutants, for the same maximum engine power.

---

**NSPS Subpart IIII for Stationary Compression Ignition Internal Combustion Engines**


---

- (c) Stationary CI internal combustion engine manufacturers must certify their 2011 model year and later non-emergency stationary CI ICE with a maximum engine power greater than 2,237 KW (3,000 HP) and a displacement of less than 10 liters per cylinder to the certification emission standards for new nonroad CI engines in 40 CFR 1039.101, 40 CFR 1039.102, 40 CFR 1039.104, 40 CFR 1039.105, 40 CFR 1039.107, and 40 CFR 1039.115, as applicable, for all pollutants, for the same maximum engine power.
- (d) Stationary CI internal combustion engine manufacturers must certify their 2007 model year and later non-emergency stationary CI ICE with a displacement of greater than or equal to 10 liters per cylinder and less than 30 liters per cylinder to the certification emission standards for new marine CI engines in 40 CFR 94.8, as applicable, for all pollutants, for the same displacement and maximum engine power.

**§ 60.4202 What emission standards must I meet for emergency engines if I am a stationary CI internal combustion engine manufacturer?**

- (a) Stationary CI internal combustion engine manufacturers must certify their 2007 model year and later emergency stationary CI ICE with a maximum engine power less than or equal to 2,237 KW (3,000 HP) and a displacement of less than 10 liters per cylinder that are not fire pump engines to the emission standards specified in paragraphs (a)(1) through (2) of this section.
  - (1) For engines with a maximum engine power less than 37 KW (50 HP):
    - (i) The certification emission standards for new nonroad CI engines for the same model year and maximum engine power in 40 CFR 89.112 and 40 CFR 89.113 for all pollutants for model year 2007 engines, and
    - (ii) The certification emission standards for new nonroad CI engines in 40 CFR 1039.104, 40 CFR 1039.105, 40 CFR 1039.107, 40 CFR 1039.115, and table 2 to this subpart, for 2008 model year and later engines.
  - (2) For engines with a maximum engine power greater than or equal to 37 KW (50 HP), the certification emission standards for new nonroad CI engines for the same model year and maximum engine power in 40 CFR 89.112 and 40 CFR 89.113 for all pollutants beginning in model year 2007.
- (b) Stationary CI internal combustion engine manufacturers must certify their 2007 model year and later emergency stationary CI ICE with a maximum engine power greater than 2,237 KW (3,000 HP) and a displacement of less than 10 liters per cylinder that are not fire pump engines to the emission standards specified in paragraphs (b)(1) through (2) of this section.
  - (1) For 2007 through 2010 model years, the emission standards in table 1 to this subpart, for all pollutants, for the same maximum engine power.
  - (2) For 2011 model year and later, the certification emission standards for new nonroad CI engines for engines of the same model year and maximum engine power in 40 CFR 89.112 and 40 CFR 89.113 for all pollutants.
- (c) Stationary CI internal combustion engine manufacturers must certify their 2007 model year and later emergency stationary CI ICE with a displacement of greater than or equal to 10 liters per cylinder and less than 30 liters per cylinder that are not fire pump engines to the certification emission standards for new marine CI engines in 40 CFR 94.8, as applicable, for all pollutants, for the same displacement and maximum engine power.
- (d) Beginning with the model years in table 3 to this subpart, stationary CI internal combustion engine manufacturers must certify their fire pump stationary CI ICE to the emission standards in table 4 to this subpart, for all pollutants, for the same model year and NFPA nameplate power.

**§ 60.4203 How long must my engines meet the emission standards if I am a stationary CI internal combustion engine manufacturer?**

Engines manufactured by stationary CI internal combustion engine manufacturers must meet the emission standards as required in §§60.4201 and 60.4202 during the useful life of the engines.

**EMISSION STANDARDS FOR OWNERS AND OPERATORS**

**§ 60.4204 What emission standards must I meet for non-emergency engines if I am an owner or operator of a stationary CI internal combustion engine?**

- (a) Owners and operators of pre-2007 model year non-emergency stationary CI ICE with a displacement of less than 10 liters per cylinder must comply with the emission standards in table 1 to this subpart. Owners and operators of pre-

---

**NSPS Subpart IIII for Stationary Compression Ignition Internal Combustion Engines**


---

2007 model year non-emergency stationary CI ICE with a displacement of greater than or equal to 10 liters per cylinder and less than 30 liters per cylinder must comply with the emission standards in 40 CFR 94.8(a)(1).

- (b) Owners and operators of 2007 model year and later non-emergency stationary CI ICE with a displacement of less than 30 liters per cylinder must comply with the emission standards for new CI engines in §60.4201 for their 2007 model year and later stationary CI ICE, as applicable.
- (c) Owners and operators of non-emergency stationary CI ICE with a displacement of greater than or equal to 30 liters per cylinder must meet the requirements in paragraphs (c)(1) and (2) of this section.
  - (1) Reduce nitrogen oxides (NO<sub>x</sub>) emissions by 90 percent or more, or limit the emissions of NO<sub>x</sub> in the stationary CI internal combustion engine exhaust to 1.6 grams per KW-hour (g/KW-hr) (1.2 grams per HP-hour (g/HP-hr)).
  - (2) Reduce particulate matter (PM) emissions by 60 percent or more, or limit the emissions of PM in the stationary CI internal combustion engine exhaust to 0.15 g/KW-hr (0.11 g/HP-hr).

**§ 60.4205 What emission standards must I meet for emergency engines if I am an owner or operator of a stationary CI internal combustion engine?**

- (a) Owners and operators of pre-2007 model year emergency stationary CI ICE with a displacement of less than 10 liters per cylinder that are not fire pump engines must comply with the emission standards in table 1 to this subpart. Owners and operators of pre-2007 model year non-emergency stationary CI ICE with a displacement of greater than or equal to 10 liters per cylinder and less than 30 liters per cylinder that are not fire pump engines must comply with the emission standards in 40 CFR 94.8(a)(1).
- (b) Owners and operators of 2007 model year and later emergency stationary CI ICE with a displacement of less than 30 liters per cylinder that are not fire pump engines must comply with the emission standards for new nonroad CI engines in §60.4202, for all pollutants, for the same model year and maximum engine power for their 2007 model year and later emergency stationary CI ICE.
- (c) Owners and operators of fire pump engines with a displacement of less than 30 liters per cylinder must comply with the emission standards in table 4 to this subpart, for all pollutants.
- (d) Owners and operators of emergency stationary CI ICE with a displacement of greater than or equal to 30 liters per cylinder must meet the requirements in paragraphs (d)(1) and (2) of this section.
  - (1) Reduce NO<sub>x</sub> emissions by 90 percent or more, or limit the emissions of NO<sub>x</sub> in the stationary CI internal combustion engine exhaust to 1.6 grams per KW-hour (1.2 grams per HP-hour).
  - (2) Reduce PM emissions by 60 percent or more, or limit the emissions of PM in the stationary CI internal combustion engine exhaust to 0.15 g/KW-hr (0.11 g/HP-hr).

**§ 60.4206 How long must I meet the emission standards if I am an owner or operator of a stationary CI internal combustion engine?**

Owners and operators of stationary CI ICE must operate and maintain stationary CI ICE that achieve the emission standards as required in §§60.4204 and 60.4205 according to the manufacturer's written instructions or procedures developed by the owner or operator that are approved by the engine manufacturer, over the entire life of the engine.

**FUEL REQUIREMENTS FOR OWNERS AND OPERATORS**

**§ 60.4207 What fuel requirements must I meet if I am an owner or operator of a stationary CI internal combustion engine subject to this subpart?**

- (a) Beginning October 1, 2007, owners and operators of stationary CI ICE subject to this subpart that use diesel fuel must use diesel fuel that meets the requirements of 40 CFR 80.510(a).
- (b) Beginning October 1, 2010, owners and operators of stationary CI ICE subject to this subpart with a displacement of less than 30 liters per cylinder that use diesel fuel must use diesel fuel that meets the requirements of 40 CFR 80.510(b) for nonroad diesel fuel.
- (c) Owners and operators of pre-2011 model year stationary CI ICE subject to this subpart may petition the Administrator for approval to use remaining non-compliant fuel that does not meet the fuel requirements of paragraphs (a) and (b) of this section beyond the dates required for the purpose of using up existing fuel inventories. If approved, the petition will be valid for a period of up to 6 months. If additional time is needed, the owner or operator is required to submit a new petition to the Administrator.

---

**NSPS Subpart IIII for Stationary Compression Ignition Internal Combustion Engines**


---

- (d) Owners and operators of pre-2011 model year stationary CI ICE subject to this subpart that are located in areas of Alaska not accessible by the Federal Aid Highway System may petition the Administrator for approval to use any fuels mixed with used lubricating oil that do not meet the fuel requirements of paragraphs (a) and (b) of this section. Owners and operators must demonstrate in their petition to the Administrator that there is no other place to use the lubricating oil. If approved, the petition will be valid for a period of up to 6 months. If additional time is needed, the owner or operator is required to submit a new petition to the Administrator.
- (e) Stationary CI ICE that have a national security exemption under §60.4200(d) are also exempt from the fuel requirements in this section.

**OTHER REQUIREMENTS FOR OWNERS AND OPERATORS****§ 60.4208 What is the deadline for importing or installing stationary CI ICE produced in the previous model year?**

- (a) After December 31, 2008, owners and operators may not install stationary CI ICE (excluding fire pump engines) that do not meet the applicable requirements for 2007 model year engines.
- (b) After December 31, 2009, owners and operators may not install stationary CI ICE with a maximum engine power of less than 19 KW (25 HP) (excluding fire pump engines) that do not meet the applicable requirements for 2008 model year engines.
- (c) After December 31, 2014, owners and operators may not install non-emergency stationary CI ICE with a maximum engine power of greater than or equal to 19 KW (25 HP) and less than 56 KW (75 HP) that do not meet the applicable requirements for 2013 model year non-emergency engines.
- (d) After December 31, 2013, owners and operators may not install non-emergency stationary CI ICE with a maximum engine power of greater than or equal to 56 KW (75 HP) and less than 130 KW (175 HP) that do not meet the applicable requirements for 2012 model year non-emergency engines.
- (e) After December 31, 2012, owners and operators may not install non-emergency stationary CI ICE with a maximum engine power of greater than or equal to 130 KW (175 HP), including those above 560 KW (750 HP), that do not meet the applicable requirements for 2011 model year non-emergency engines.
- (f) After December 31, 2016, owners and operators may not install non-emergency stationary CI ICE with a maximum engine power of greater than or equal to 560 KW (750 HP) that do not meet the applicable requirements for 2015 model year non-emergency engines.
- (g) In addition to the requirements specified in §§60.4201, 60.4202, 60.4204, and 60.4205, it is prohibited to import stationary CI ICE with a displacement of less than 30 liters per cylinder that do not meet the applicable requirements specified in paragraphs (a) through (f) of this section after the dates specified in paragraphs (a) through (f) of this section.
- (h) The requirements of this section do not apply to owners or operators of stationary CI ICE that have been modified, reconstructed, and do not apply to engines that were removed from one existing location and reinstalled at a new location.

**§ 60.4209 What are the monitoring requirements if I am an owner or operator of a stationary CI internal combustion engine?**

If you are an owner or operator, you must meet the monitoring requirements of this section. In addition, you must also meet the monitoring requirements specified in §60.4211.

- (a) If you are an owner or operator of an emergency stationary CI internal combustion engine, you must install a non-resettable hour meter prior to startup of the engine.
- (b) If you are an owner or operator of a stationary CI internal combustion engine equipped with a diesel particulate filter to comply with the emission standards in §60.4204, the diesel particulate filter must be installed with a backpressure monitor that notifies the owner or operator when the high backpressure limit of the engine is approached.

**COMPLIANCE REQUIREMENTS****§ 60.4210 What are my compliance requirements if I am a stationary CI internal combustion engine manufacturer?**

- (a) Stationary CI internal combustion engine manufacturers must certify their stationary CI ICE with a displacement of less than 10 liters per cylinder to the emission standards specified in §60.4201(a) through (c) and §60.4202(a), (b) and

## NSPS Subpart IIII for Stationary Compression Ignition Internal Combustion Engines

(d) using the certification procedures required in 40 CFR part 89, subpart B, or 40 CFR part 1039, subpart C, as applicable, and must test their engines as specified in those parts. For the purposes of this subpart, engines certified to the standards in table 1 to this subpart shall be subject to the same requirements as engines certified to the standards in 40 CFR part 89. For the purposes of this subpart, engines certified to the standards in table 4 to this subpart shall be subject to the same requirements as engines certified to the standards in 40 CFR part 89, except that engines with NFPA nameplate power of less than 37 KW (50 HP) certified to model year 2011 or later standards shall be subject to the same requirements as engines certified to the standards in 40 CFR part 1039.

- (b) Stationary CI internal combustion engine manufacturers must certify their stationary CI ICE with a displacement of greater than or equal to 10 liters per cylinder and less than 30 liters per cylinder to the emission standards specified in §60.4201(d) and §60.4202(c) using the certification procedures required in 40 CFR part 94 subpart C, and must test their engines as specified in 40 CFR part 94.
- (c) Stationary CI internal combustion engine manufacturers must meet the requirements of 40 CFR 1039.120, 40 CFR 1039.125, 40 CFR 1039.130, 40 CFR 1039.135, and 40 CFR part 1068 for engines that are certified to the emission standards in 40 CFR part 1039. Stationary CI internal combustion engine manufacturers must meet the corresponding provisions of 40 CFR part 89 or 40 CFR part 94 for engines that would be covered by that part if they were nonroad (including marine) engines. Labels on such engines must refer to stationary engines, rather than or in addition to nonroad or marine engines, as appropriate. Stationary CI internal combustion engine manufacturers must label their engines according to paragraphs (c)(1) through (3) of this section.
- (1) Stationary CI internal combustion engines manufactured from January 1, 2006 to March 31, 2006 (January 1, 2006 to June 30, 2006 for fire pump engines), other than those that are part of certified engine families under the nonroad CI engine regulations, must be labeled according to 40 CFR 1039.20.
- (2) Stationary CI internal combustion engines manufactured from April 1, 2006 to December 31, 2006 (or, for fire pump engines, July 1, 2006 to December 31 of the year preceding the year listed in table 3 to this subpart) must be labeled according to paragraphs (c)(2)(i) through (iii) of this section:
- (i) Stationary CI internal combustion engines that are part of certified engine families under the nonroad regulations must meet the labeling requirements for nonroad CI engines, but do not have to meet the labeling requirements in 40 CFR 1039.20.
- (ii) Stationary CI internal combustion engines that meet Tier 1 requirements (or requirements for fire pumps) under this subpart, but do not meet the requirements applicable to nonroad CI engines must be labeled according to 40 CFR 1039.20. The engine manufacturer may add language to the label clarifying that the engine meets Tier 1 requirements (or requirements for fire pumps) of this subpart.
- (iii) Stationary CI internal combustion engines manufactured after April 1, 2006 that do not meet Tier 1 requirements of this subpart, or fire pumps engines manufactured after July 1, 2006 that do not meet the requirements for fire pumps under this subpart, may not be used in the U.S. If any such engines are manufactured in the U.S. after April 1, 2006 (July 1, 2006 for fire pump engines), they must be exported or must be brought into compliance with the appropriate standards prior to initial operation. The export provisions of 40 CFR 1068.230 would apply to engines for export and the manufacturers must label such engines according to 40 CFR 1068.230.
- (3) Stationary CI internal combustion engines manufactured after January 1, 2007 (for fire pump engines, after January 1 of the year listed in table 3 to this subpart, as applicable) must be labeled according to paragraphs (c)(3)(i) through (iii) of this section.
- (i) Stationary CI internal combustion engines that meet the requirements of this subpart and the corresponding requirements for nonroad (including marine) engines of the same model year and HP must be labeled according to the provisions in part 89, 94 or 1039, as appropriate.
- (ii) Stationary CI internal combustion engines that meet the requirements of this subpart, but are not certified to the standards applicable to nonroad (including marine) engines of the same model year and HP must be labeled according to the provisions in part 89, 94 or 1039, as appropriate, but the words "stationary" must be included instead of "nonroad" or "marine" on the label. In addition, such engines must be labeled according to 40 CFR 1039.20.
- (iii) Stationary CI internal combustion engines that do not meet the requirements of this subpart must be labeled according to 40 CFR 1068.230 and must be exported under the provisions of 40 CFR 1068.230.

---

 NSPS Subpart IIII for Stationary Compression Ignition Internal Combustion Engines
 

---

- (d) An engine manufacturer certifying an engine family or families to standards under this subpart that are identical to standards applicable under parts 89, 94, or 1039 for that model year may certify any such family that contains both nonroad (including marine) and stationary engines as a single engine family and/or may include any such family containing stationary engines in the averaging, banking and trading provisions applicable for such engines under those parts.
- (e) Manufacturers of engine families discussed in paragraph (d) of this section may meet the labeling requirements referred to in paragraph (c) of this section for stationary CI ICE by either adding a separate label containing the information required in paragraph (c) of this section or by adding the words “and stationary” after the word “nonroad” or “marine,” as appropriate, to the label.
- (f) Starting with the model years shown in table 5 to this subpart, stationary CI internal combustion engine manufacturers must add a permanent label stating that the engine is for stationary emergency use only to each new emergency stationary CI internal combustion engine greater than or equal to 19 KW (25 HP) that meets all the emission standards for emergency engines in §60.4202 but does not meet all the emission standards for non-emergency engines in §60.4201. The label must be added according to the labeling requirements specified in 40 CFR 1039.135(b). Engine manufacturers must specify in the owner's manual that operation of emergency engines is limited to emergency operations and required maintenance and testing.
- (g) Manufacturers of fire pump engines may use the test cycle in table 6 to this subpart for testing fire pump engines and may test at the NFPA certified nameplate HP, provided that the engine is labeled as “Fire Pump Applications Only”.
- (h) Engine manufacturers, including importers, may introduce into commerce uncertified engines or engines certified to earlier standards that were manufactured before the new or changed standards took effect until inventories are depleted, as long as such engines are part of normal inventory. For example, if the engine manufacturers' normal industry practice is to keep on hand a one-month supply of engines based on its projected sales, and a new tier of standards starts to apply for the 2009 model year, the engine manufacturer may manufacture engines based on the normal inventory requirements late in the 2008 model year, and sell those engines for installation. The engine manufacturer may not circumvent the provisions of §§60.4201 or 60.4202 by stockpiling engines that are built before new or changed standards take effect. Stockpiling of such engines beyond normal industry practice is a violation of this subpart.
- (i) The replacement engine provisions of 40 CFR 89.1003(b)(7), 40 CFR 94.1103(b)(3), 40 CFR 94.1103(b)(4) and 40 CFR 1068.240 are applicable to stationary CI engines replacing existing equipment that is less than 15 years old.

**§ 60.4211 What are my compliance requirements if I am an owner or operator of a stationary CI internal combustion engine?**

- (a) If you are an owner or operator and must comply with the emission standards specified in this subpart, you must operate and maintain the stationary CI internal combustion engine and control device according to the manufacturer's written instructions or procedures developed by the owner or operator that are approved by the engine manufacturer. In addition, owners and operators may only change those settings that are permitted by the manufacturer. You must also meet the requirements of 40 CFR parts 89, 94 and/or 1068, as they apply to you.
- (b) If you are an owner or operator of a pre-2007 model year stationary CI internal combustion engine and must comply with the emission standards specified in §§60.4204(a) or 60.4205(a), or if you are an owner or operator of a CI fire pump engine that is manufactured prior to the model years in table 3 to this subpart and must comply with the emission standards specified in §60.4205(c), you must demonstrate compliance according to one of the methods specified in paragraphs (b)(1) through (5) of this section.
  - (1) Purchasing an engine certified according to 40 CFR part 89 or 40 CFR part 94, as applicable, for the same model year and maximum engine power. The engine must be installed and configured according to the manufacturer's specifications.
  - (2) Keeping records of performance test results for each pollutant for a test conducted on a similar engine. The test must have been conducted using the same methods specified in this subpart and these methods must have been followed correctly.
  - (3) Keeping records of engine manufacturer data indicating compliance with the standards.
  - (4) Keeping records of control device vendor data indicating compliance with the standards.

## NSPS Subpart IIII for Stationary Compression Ignition Internal Combustion Engines

- (5) Conducting an initial performance test to demonstrate compliance with the emission standards according to the requirements specified in §60.4212, as applicable.
- (c) If you are an owner or operator of a 2007 model year and later stationary CI internal combustion engine and must comply with the emission standards specified in §60.4204(b) or §60.4205(b), or if you are an owner or operator of a CI fire pump engine that is manufactured during or after the model year that applies to your fire pump engine power rating in table 3 to this subpart and must comply with the emission standards specified in §60.4205(c), you must comply by purchasing an engine certified to the emission standards in §60.4204(b), or §60.4205(b) or (c), as applicable, for the same model year and maximum (or in the case of fire pumps, NFPA nameplate) engine power. The engine must be installed and configured according to the manufacturer's specifications.
- (d) If you are an owner or operator and must comply with the emission standards specified in §60.4204(c) or §60.4205(d), you must demonstrate compliance according to the requirements specified in paragraphs (d)(1) through (3) of this section.
- (1) Conducting an initial performance test to demonstrate initial compliance with the emission standards as specified in §60.4213.
- (2) Establishing operating parameters to be monitored continuously to ensure the stationary internal combustion engine continues to meet the emission standards. The owner or operator must petition the Administrator for approval of operating parameters to be monitored continuously. The petition must include the information described in paragraphs (d)(2)(i) through (v) of this section.
- (i) Identification of the specific parameters you propose to monitor continuously;
- (ii) A discussion of the relationship between these parameters and NO<sub>x</sub> and PM emissions, identifying how the emissions of these pollutants change with changes in these parameters, and how limitations on these parameters will serve to limit NO<sub>x</sub> and PM emissions;
- (iii) A discussion of how you will establish the upper and/or lower values for these parameters which will establish the limits on these parameters in the operating limitations;
- (iv) A discussion identifying the methods and the instruments you will use to monitor these parameters, as well as the relative accuracy and precision of these methods and instruments; and
- (v) A discussion identifying the frequency and methods for recalibrating the instruments you will use for monitoring these parameters.
- (3) For non-emergency engines with a displacement of greater than or equal to 30 liters per cylinder, conducting annual performance tests to demonstrate continuous compliance with the emission standards as specified in §60.4213.
- (e) Emergency stationary ICE may be operated for the purpose of maintenance checks and readiness testing, provided that the tests are recommended by Federal, State, or local government, the manufacturer, the vendor, or the insurance company associated with the engine. Maintenance checks and readiness testing of such units is limited to 100 hours per year. There is no time limit on the use of emergency stationary ICE in emergency situations. Anyone may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that Federal, State, or local standards require maintenance and testing of emergency ICE beyond 100 hours per year. For owners and operators of emergency engines meeting standards under §60.4205 but not §60.4204, any operation other than emergency operation, and maintenance and testing as permitted in this section, is prohibited.

**TESTING REQUIREMENTS FOR OWNERS AND OPERATORS****§ 60.4212 What test methods and other procedures must I use if I am an owner or operator of a stationary CI internal combustion engine with a displacement of less than 30 liters per cylinder?**

Owners and operators of stationary CI ICE with a displacement of less than 30 liters per cylinder who conduct performance tests pursuant to this subpart must do so according to paragraphs (a) through (d) of this section.

- (a) The performance test must be conducted according to the in-use testing procedures in 40 CFR part 1039, subpart F.
- (b) Exhaust emissions from stationary CI ICE that are complying with the emission standards for new CI engines in 40 CFR part 1039 must not exceed the not-to-exceed (NTE) standards for the same model year and maximum engine



NSPS Subpart IIII for Stationary Compression Ignition Internal Combustion Engines

power as required in 40 CFR 1039.101(e) and 40 CFR 1039.102(g)(1), except as specified in 40 CFR 1039.104(d). This requirement starts when NTE requirements take effect for nonroad diesel engines under 40 CFR part 1039.

- (c) Exhaust emissions from stationary CI ICE that are complying with the emission standards for new CI engines in 40 CFR 89.112 or 40 CFR 94.8, as applicable, must not exceed the NTE numerical requirements, rounded to the same number of decimal places as the applicable standard in 40 CFR 89.112 or 40 CFR 94.8, as applicable, determined from the following equation:

$$\text{NTE requirement for each pollutant} = (1.25) \times (\text{STD}) \quad (\text{Eq. 1})$$

Where:

STD = The standard specified for that pollutant in 40 CFR 89.112 or 40 CFR 94.8, as applicable.

Alternatively, stationary CI ICE that are complying with the emission standards for new CI engines in 40 CFR 89.112 or 40 CFR 94.8 may follow the testing procedures specified in §60.4213 of this subpart, as appropriate.

- (d) Exhaust emissions from stationary CI ICE that are complying with the emission standards for pre-2007 model year engines in §60.4204(a), §60.4205(a), or §60.4205(c) must not exceed the NTE numerical requirements, rounded to the same number of decimal places as the applicable standard in §60.4204(a), §60.4205(a), or §60.4205(c), determined from the equation in paragraph (c) of this section.

Where:

STD = The standard specified for that pollutant in §60.4204(a), §60.4205(a), or §60.4205(c).

Alternatively, stationary CI ICE that are complying with the emission standards for pre-2007 model year engines in §60.4204(a), §60.4205(a), or §60.4205(c) may follow the testing procedures specified in §60.4213, as appropriate.

**§ 60.4213 What test methods and other procedures must I use if I am an owner or operator of a stationary CI internal combustion engine with a displacement of greater than or equal to 30 liters per cylinder?**

Owners and operators of stationary CI ICE with a displacement of greater than or equal to 30 liters per cylinder must conduct performance tests according to paragraphs (a) through (d) of this section.

- (a) Each performance test must be conducted according to the requirements in §60.8 and under the specific conditions that this subpart specifies in table 7. The test must be conducted within 10 percent of 100 percent peak (or the highest achievable) load.
- (b) You may not conduct performance tests during periods of startup, shutdown, or malfunction, as specified in §60.8(c).
- (c) You must conduct three separate test runs for each performance test required in this section, as specified in §60.8(f). Each test run must last at least 1 hour.
- (d) To determine compliance with the percent reduction requirement, you must follow the requirements as specified in paragraphs (d)(1) through (3) of this section.

- (1) You must use Equation 2 of this section to determine compliance with the percent reduction requirement:

$$\frac{C_i - C_o}{C_i} \times 100 = R \quad (\text{Eq. 2})$$

Where:

- C<sub>i</sub> = concentration of NO<sub>x</sub> or PM at the control device inlet,
- C<sub>o</sub> = concentration of NO<sub>x</sub> or PM at the control device outlet, and
- R = percent reduction of NO<sub>x</sub> or PM emissions.

- (2) You must normalize the NO<sub>x</sub> or PM concentrations at the inlet and outlet of the control device to a dry basis and to 15 percent oxygen (O<sub>2</sub>) using Equation 3 of this section, or an equivalent percent carbon dioxide (CO<sub>2</sub>) using the procedures described in paragraph (d)(3) of this section.

$$C_{adj} = C_i \frac{5.9}{20.9 - \% O_2} \quad (\text{Eq. 3})$$

## NSPS Subpart IIII for Stationary Compression Ignition Internal Combustion Engines

Where:

$C_{adj}$  = Calculated  $NO_x$  or PM concentration adjusted to 15 percent  $O_2$ .

$C_d$  = Measured concentration of  $NO_x$  or PM, uncorrected.

5.9 = 20.9 percent  $O_2$ –15 percent  $O_2$ , the defined  $O_2$  correction value, percent.

% $O_2$  = Measured  $O_2$  concentration, dry basis, percent.

(3) If pollutant concentrations are to be corrected to 15 percent  $O_2$  and  $CO_2$  concentration is measured in lieu of  $O_2$  concentration measurement, a  $CO_2$  correction factor is needed. Calculate the  $CO_2$  correction factor as described in paragraphs (d)(3)(i) through (iii) of this section.

(i) Calculate the fuel-specific  $F_o$  value for the fuel burned during the test using values obtained from Method 19, Section 5.2, and the following equation:

$$F_o = \frac{0.209 \times}{F_d} \quad (\text{Eq. 4})$$

Where:

$F_o$  = Fuel factor based on the ratio of  $O_2$  volume to the ultimate  $CO_2$  volume produced by the fuel at zero percent excess air.

0.209 = Fraction of air that is  $O_2$ , percent/100.

$F_d$  = Ratio of the volume of dry effluent gas to the gross calorific value of the fuel from Method 19,  $ds\text{m}^3 / J$  ( $dscf/10^6$  Btu).

$F_c$  = Ratio of the volume of  $CO_2$  produced to the gross calorific value of the fuel from Method 19,  $ds\text{m}^3 / J$  ( $dscf/10^6$  Btu).

(ii) Calculate the  $CO_2$  correction factor for correcting measurement data to 15 percent  $O_2$ , as follows:

$$X_{CO_2} = \frac{5.9}{F_c} \quad (\text{Eq. 5})$$

Where:

$X_{CO_2}$  =  $CO_2$  correction factor, percent.

5.9 = 20.9 percent  $O_2$ –15 percent  $O_2$ , the defined  $O_2$  correction value, percent.

(iii) Calculate the  $NO_x$  and PM gas concentrations adjusted to 15 percent  $O_2$  using  $CO_2$  as follows:

$$C_{adj} = C_d \frac{X_{CO_2}}{\%CO_2} \quad (\text{Eq. 6})$$

Where:

$C_{adj}$  = Calculated  $NO_x$  or PM concentration adjusted to 15 percent  $O_2$ .

$C_d$  = Measured concentration of  $NO_x$  or PM, uncorrected.

% $CO_2$  = Measured  $CO_2$  concentration, dry basis, percent.

(e) To determine compliance with the  $NO_x$  mass per unit output emission limitation, convert the concentration of  $NO_x$  in the engine exhaust using Equation 7 of this section:

$$ER = \frac{C_d \times 1.912 \times 10^{-3} \times Q \times T}{KW\text{-hour}} \quad (\text{Eq. 7})$$

Where:

ER = Emission rate in grams per KW-hour.

$C_d$  = Measured  $NO_x$  concentration in ppm.

## NSPS Subpart IIII for Stationary Compression Ignition Internal Combustion Engines

$1.912 \times 10^{-3}$  = Conversion constant for ppm NO<sub>x</sub> to grams per standard cubic meter at 25 degrees Celsius.

Q = Stack gas volumetric flow rate, in standard cubic meter per hour.

T = Time of test run, in hours.

KW-hour = Brake work of the engine, in KW-hour.

- (f) To determine compliance with the PM mass per unit output emission limitation, convert the concentration of PM in the engine exhaust using Equation 8 of this section:

$$ER = \frac{C_{adj} \times Q \times T}{KW\text{-hour}} \quad (\text{Eq. 8})$$

Where:

ER = Emission rate in grams per KW-hour.

C<sub>adj</sub> = Calculated PM concentration in grams per standard cubic meter.

Q = Stack gas volumetric flow rate, in standard cubic meter per hour.

T = Time of test run, in hours.

KW-hour = Energy output of the engine, in KW.

### NOTIFICATION, REPORTS, AND RECORDS FOR OWNERS AND OPERATORS

#### § 60.4214 What are my notification, reporting, and recordkeeping requirements if I am an owner or operator of a stationary CI internal combustion engine?

- (a) Owners and operators of non-emergency stationary CI ICE that are greater than 2,237 KW (3,000 HP), or have a displacement of greater than or equal to 10 liters per cylinder, or are pre-2007 model year engines that are greater than 130 KW (175 HP) and not certified, must meet the requirements of paragraphs (a)(1) and (2) of this section.
- (1) Submit an initial notification as required in §60.7(a)(1). The notification must include the information in paragraphs (a)(1)(i) through (v) of this section.
- (i) Name and address of the owner or operator;
  - (ii) The address of the affected source;
  - (iii) Engine information including make, model, engine family, serial number, model year, maximum engine power, and engine displacement;
  - (iv) Emission control equipment; and
  - (v) Fuel used.
- (2) Keep records of the information in paragraphs (a)(2)(i) through (iv) of this section.
- (i) All notifications submitted to comply with this subpart and all documentation supporting any notification.
  - (ii) Maintenance conducted on the engine.
  - (iii) If the stationary CI internal combustion is a certified engine, documentation from the manufacturer that the engine is certified to meet the emission standards.
  - (iv) If the stationary CI internal combustion is not a certified engine, documentation that the engine meets the emission standards.
- (b) If the stationary CI internal combustion engine is an emergency stationary internal combustion engine, the owner or operator is not required to submit an initial notification. Starting with the model years in table 5 to this subpart, if the emergency engine does not meet the standards applicable to non-emergency engines in the applicable model year, the owner or operator must keep records of the operation of the engine in emergency and non-emergency service that are recorded through the non-resettable hour meter. The owner must record the time of operation of the engine and the reason the engine was in operation during that time.

## NSPS Subpart IIII for Stationary Compression Ignition Internal Combustion Engines

- (c) If the stationary CI internal combustion engine is equipped with a diesel particulate filter, the owner or operator must keep records of any corrective action taken after the backpressure monitor has notified the owner or operator that the high backpressure limit of the engine is approached.

**SPECIAL REQUIREMENTS****§ 60.4215 What requirements must I meet for engines used in Guam, American Samoa, or the Commonwealth of the Northern Mariana Islands?**

- (a) Stationary CI ICE that are used in Guam, American Samoa, or the Commonwealth of the Northern Mariana Islands are required to meet the applicable emission standards in §60.4205. Non-emergency stationary CI ICE with a displacement of greater than or equal to 30 liters per cylinder, must meet the applicable emission standards in §60.4204(c).
- (b) Stationary CI ICE that are used in Guam, American Samoa, or the Commonwealth of the Northern Mariana Islands are not required to meet the fuel requirements in §60.4207.

**§ 60.4216 What requirements must I meet for engines used in Alaska?**

- (a) Prior to December 1, 2010, owners and operators of stationary CI engines located in areas of Alaska not accessible by the Federal Aid Highway System should refer to 40 CFR part 69 to determine the diesel fuel requirements applicable to such engines.
- (b) The Governor of Alaska may submit for EPA approval, by no later than January 11, 2008, an alternative plan for implementing the requirements of 40 CFR part 60, subpart IIII, for public-sector electrical utilities located in rural areas of Alaska not accessible by the Federal Aid Highway System. This alternative plan must be based on the requirements of section 111 of the Clean Air Act including any increased risks to human health and the environment and must also be based on the unique circumstances related to remote power generation, climatic conditions, and serious economic impacts resulting from implementation of 40 CFR part 60, subpart IIII. If EPA approves by rulemaking process an alternative plan, the provisions as approved by EPA under that plan shall apply to the diesel engines used in new stationary internal combustion engines subject to this paragraph.

**§ 60.4217 What emission standards must I meet if I am an owner or operator of a stationary internal combustion engine using special fuels?**

- (a) Owners and operators of stationary CI ICE that do not use diesel fuel, or who have been given authority by the Administrator under §60.4207(d) of this subpart to use fuels that do not meet the fuel requirements of paragraphs (a) and (b) of §60.4207, may petition the Administrator for approval of alternative emission standards, if they can demonstrate that they use a fuel that is not the fuel on which the manufacturer of the engine certified the engine and that the engine cannot meet the applicable standards required in §60.4202 or §60.4203 using such fuels.
- (b) [Reserved]

**GENERAL PROVISIONS****§ 60.4218 What parts of the General Provisions apply to me?**

Table 8 to this subpart shows which parts of the General Provisions in §§60.1 through 60.19 apply to you.

## Definitions

**§ 60.4219 What definitions apply to this subpart?**

As used in this subpart, all terms not defined herein shall have the meaning given them in the CAA and in subpart A of this part.

*Combustion turbine* means all equipment, including but not limited to the turbine, the fuel, air, lubrication and exhaust gas systems, control systems (except emissions control equipment), and any ancillary components and sub-components comprising any simple cycle combustion turbine, any regenerative/recuperative cycle combustion turbine, the combustion turbine portion of any cogeneration cycle combustion system, or the combustion turbine portion of any combined cycle steam/electric generating system.

*Compression ignition* means relating to a type of stationary internal combustion engine that is not a spark ignition engine.

*Diesel fuel* means any liquid obtained from the distillation of petroleum with a boiling point of approximately 150 to 360 degrees Celsius. One commonly used form is number 2 distillate oil.

## NSPS Subpart IIII for Stationary Compression Ignition Internal Combustion Engines

*Diesel particulate filter* means an emission control technology that reduces PM emissions by trapping the particles in a flow filter substrate and periodically removes the collected particles by either physical action or by oxidizing (burning off) the particles in a process called regeneration.

*Emergency stationary internal combustion engine* means any stationary internal combustion engine whose operation is limited to emergency situations and required testing and maintenance. Examples include stationary ICE used to produce power for critical networks or equipment (including power supplied to portions of a facility) when electric power from the local utility (or the normal power source, if the facility runs on its own power production) is interrupted, or stationary ICE used to pump water in the case of fire or flood, etc. Stationary CI ICE used to supply power to an electric grid or that supply power as part of a financial arrangement with another entity are not considered to be emergency engines.

*Engine manufacturer* means the manufacturer of the engine. See the definition of “manufacturer” in this section.

*Fire pump engine* means an emergency stationary internal combustion engine certified to NFPA requirements that is used to provide power to pump water for fire suppression or protection.

*Manufacturer* has the meaning given in section 216(1) of the Act. In general, this term includes any person who manufactures a stationary engine for sale in the United States or otherwise introduces a new stationary engine into commerce in the United States. This includes importers who import stationary engines for sale or resale.

*Maximum engine power* means maximum engine power as defined in 40 CFR 1039.801.

*Model year* means either:

- (1) The calendar year in which the engine was originally produced, or
- (2) The annual new model production period of the engine manufacturer if it is different than the calendar year. This must include January 1 of the calendar year for which the model year is named. It may not begin before January 2 of the previous calendar year and it must end by December 31 of the named calendar year. For an engine that is converted to a stationary engine after being placed into service as a nonroad or other non-stationary engine, model year means the calendar year or new model production period in which the engine was originally produced.

*Other internal combustion engine* means any internal combustion engine, except combustion turbines, which is not a reciprocating internal combustion engine or rotary internal combustion engine.

*Reciprocating internal combustion engine* means any internal combustion engine which uses reciprocating motion to convert heat energy into mechanical work.

*Rotary internal combustion engine* means any internal combustion engine which uses rotary motion to convert heat energy into mechanical work.

*Spark ignition* means relating to a gasoline, natural gas, or liquefied petroleum gas fueled engine or any other type of engine with a spark plug (or other sparking device) and with operating characteristics significantly similar to the theoretical Otto combustion cycle. Spark ignition engines usually use a throttle to regulate intake air flow to control power during normal operation. Dual-fuel engines in which a liquid fuel (typically diesel fuel) is used for CI and gaseous fuel (typically natural gas) is used as the primary fuel at an annual average ratio of less than 2 parts diesel fuel to 100 parts total fuel on an energy equivalent basis are spark ignition engines.

*Stationary internal combustion engine* means any internal combustion engine, except combustion turbines, that converts heat energy into mechanical work and is not mobile. Stationary ICE differ from mobile ICE in that a stationary internal combustion engine is not a nonroad engine as defined at 40 CFR 1068.30 (excluding paragraph (2)(ii) of that definition), and is not used to propel a motor vehicle or a vehicle used solely for competition. Stationary ICE include reciprocating ICE, rotary ICE, and other ICE, except combustion turbines.

*Subpart* means 40 CFR part 60, subpart IIII.

*Useful life* means the period during which the engine is designed to properly function in terms of reliability and fuel consumption, without being remanufactured, specified as a number of hours of operation or calendar years, whichever comes first. The values for useful life for stationary CI ICE with a displacement of less than 10 liters per cylinder are given in 40 CFR 1039.101(g). The values for useful life for stationary CI ICE with a displacement of greater than or equal to 10 liters per cylinder and less than 30 liters per cylinder are given in 40 CFR 94.9(a).

**APPENDIX III**

**NSPS Subpart IIII for Stationary Compression Ignition Internal Combustion Engines**

**Table 1 to Subpart IIII of Part 60—Emission Standards for Stationary Pre-2007 Model Year Engines With a Displacement of <10 Liters per Cylinder and 2007–2010 Model Year Engines >2,237 KW (3,000 HP) and With a Displacement of <10 Liters per Cylinder**

[As stated in §§60.4201(b), 60.4202(b), 60.4204(a), and 60.4205(a), you must comply with the following emission standards]

| Maximum engine power    | Emission standards for stationary pre-2007 model year engines with a displacement of <10 liters per cylinder and 2007–2010 model year engines >2,237 KW (3,000 HP) and with a displacement of <10 liters per cylinder in g/KW-hr (g/HP-hr) |           |                 |            |             |
|-------------------------|--|-----------|-----------------|------------|-------------|
|                         | NMHC + NO <sub>x</sub>   | HC        | NO <sub>x</sub> | CO         | PM          |
| KW<8 (HP<11)            | 10.5 (7.8)   |           |                 | 8.0 (6.0)  | 1.0 (0.75)  |
| 8≤KW<19 (11≤HP<25)      | 9.5 (7.1)  |           |                 | 6.6 (4.9)  | 0.80 (0.60) |
| 19≤KW<37 (25≤HP<50)     | 9.5 (7.1)  |           |                 | 5.5 (4.1)  | 0.80 (0.60) |
| 37≤KW<56 (50≤HP<75)     |  |           | 9.2 (6.9)       |            |             |
| 56≤KW<75 (75≤HP<100)    |  |           | 9.2 (6.9)       |            |             |
| 75≤KW<130 (100≤HP<175)  |  |           | 9.2 (6.9)       |            |             |
| 130≤KW<225 (175≤HP<300) |  | 1.3 (1.0) | 9.2 (6.9)       | 11.4 (8.5) | 0.54 (0.40) |
| 225≤KW<450 (300≤HP<600) |  | 1.3 (1.0) | 9.2 (6.9)       | 11.4 (8.5) | 0.54 (0.40) |
| 450≤KW≤560 (600≤HP≤750) |  | 1.3 (1.0) | 9.2 (6.9)       | 11.4 (8.5) | 0.54 (0.40) |
| KW>560 (HP>750)         |  | 1.3 (1.0) | 9.2 (6.9)       | 11.4 (8.5) | 0.54 (0.40) |

**Table 2 to Subpart IIII of Part 60—Emission Standards for 2008 Model Year and Later Emergency Stationary CI ICE <37 KW (50 HP) With a Displacement of <10 Liters per Cylinder**

[As stated in §60.4202(a)(1), you must comply with the following emission standards]

| Engine power        | Emission standards for 2008 model year and later emergency stationary CI ICE <37 KW (50 HP) with a displacement of <10 liters per cylinder in g/KW-hr (g/HP-hr) |                        |           |             |
|---------------------|---|------------------------|-----------|-------------|
|                     | Model year(s)   | NO <sub>x</sub> + NMHC | CO        | PM          |
| KW<8 (HP<11)        | 2008+   | 7.5 (5.6)              | 8.0 (6.0) | 0.40 (0.30) |
| 8≤KW<19 (11≤HP<25)  | 2008+   | 7.5 (5.6)              | 6.6 (4.9) | 0.40 (0.30) |
| 19≤KW<37 (25≤HP<50) | 2008+   | 7.5 (5.6)              | 5.5 (4.1) | 0.30 (0.22) |

**APPENDIX III**

**NSPS Subpart IIII for Stationary Compression Ignition Internal Combustion Engines**

**Table 3 to Subpart IIII of Part 60—Certification Requirements for Stationary Fire Pump Engines**

[As stated in §60.4202(d), you must certify new stationary fire pump engines beginning with the following model years:]

| <b>Engine power</b>        | <b>Starting model year engine manufacturers must certify new stationary fire pump engines according to §60.4202(d)</b> |
|----------------------------|--|
| KW<75 (HP<100)             | 2011   |
| 75≤KW<130<br>(100≤HP<175)  | 2010   |
| 130≤KW≤560<br>(175≤HP≤750) | 2009   |
| KW>560 (HP>750)            | 2008   |

**Table 4 to Subpart IIII of Part 60—Emission Standards for Stationary Fire Pump Engines**

[As stated in §§60.4202(d) and 60.4205(c), you must comply with the following emission standards for stationary fire pump engines]

| <b>Maximum engine power</b> | <b>Model year(s)</b> | <b>NMHC + NO<sub>x</sub></b> | <b>CO</b> | <b>PM</b>   |
|-----------------------------|----------------------|------------------------------|-----------|-------------|
| KW<8 (HP<11)                | 2010 and earlier     | 10.5 (7.8)                   | 8.0 (6.0) | 1.0 (0.75)  |
|                             | 2011+                | 7.5 (5.6)                    |           | 0.40 (0.30) |
| 8≤KW<19 (11≤HP<25)          | 2010 and earlier     | 9.5 (7.1)                    | 6.6 (4.9) | 0.80 (0.60) |
|                             | 2011+                | 7.5 (5.6)                    |           | 0.40 (0.30) |
| 19≤KW<37 (25≤HP<50)         | 2010 and earlier     | 9.5 (7.1)                    | 5.5 (4.1) | 0.80 (0.60) |
|                             | 2011+                | 7.5 (5.6)                    |           | 0.30 (0.22) |
| 37≤KW<56 (50≤HP<75)         | 2010 and earlier     | 10.5 (7.8)                   | 5.0 (3.7) | 0.80 (0.60) |
|                             | 2011+ <sup>1</sup>   | 4.7 (3.5)                    |           | 0.40 (0.30) |
| 56≤KW<75 (75≤HP<100)        | 2010 and earlier     | 10.5 (7.8)                   | 5.0 (3.7) | 0.80 (0.60) |
|                             | 2011+ <sup>1</sup>   | 4.7 (3.5)                    |           | 0.40 (0.30) |
| 75≤KW<130 (100≤HP<175)      | 2009 and earlier     | 10.5 (7.8)                   | 5.0 (3.7) | 0.80 (0.60) |
|                             | 2010+ <sup>2</sup>   | 4.0 (3.0)                    |           | 0.30 (0.22) |
| 130≤KW<225 (175≤HP<300)     | 2008 and earlier     | 10.5 (7.8)                   | 3.5 (2.6) | 0.54 (0.40) |
|                             | 2009+ <sup>3</sup>   | 4.0 (3.0)                    |           | 0.20 (0.15) |
| 225≤KW<450 (300≤HP<600)     | 2008 and earlier     | 10.5 (7.8)                   | 3.5 (2.6) | 0.54 (0.40) |
|                             | 2009+ <sup>3</sup>   | 4.0 (3.0)                    |           | 0.20 (0.15) |
| 450≤KW≤560 (600≤HP≤750)     | 2008 and earlier     | 10.5 (7.8)                   | 3.5 (2.6) | 0.54 (0.40) |
|                             | 2009+                | 4.0 (3.0)                    |           | 0.20 (0.15) |
| KW>560 (HP>750)             | 2007 and earlier     | 10.5 (7.8)                   | 3.5 (2.6) | 0.54 (0.40) |
|                             | 2008+                | 6.4 (4.8)                    |           | 0.20 (0.15) |

<sup>1</sup>For model years 2011–2013, manufacturers, owners and operators of fire pump stationary CI ICE in this engine power category with a rated speed of greater than 2,650 revolutions per minute (rpm) may comply with the emission limitations for 2010 model year engines.

**APPENDIX III**

**NSPS Subpart IIII for Stationary Compression Ignition Internal Combustion Engines**

<sup>2</sup>For model years 2010–2012, manufacturers, owners and operators of fire pump stationary CI ICE in this engine power category with a rated speed of greater than 2,650 rpm may comply with the emission limitations for 2009 model year engines.

<sup>3</sup>In model years 2009–2011, manufacturers of fire pump stationary CI ICE in this engine power category with a rated speed of greater than 2,650 rpm may comply with the emission limitations for 2008 model year engines.

**Table 5 to Subpart IIII of Part 60—Labeling and Recordkeeping Requirements for New Stationary Emergency Engines**

[You must comply with the labeling requirements in §60.4210(f) and the recordkeeping requirements in §60.4214(b) for new emergency stationary CI ICE beginning in the following model years:]

| Engine power          | Starting model year |
|-----------------------|---------------------|
| 19≤KW<56 (25≤HP<75)   | 2013                |
| 56≤KW<130 (75≤HP<175) | 2012                |
| KW≥130 (HP≥175)       | 2011                |

**Table 6 to Subpart IIII of Part 60—Optional 3-Mode Test Cycle for Stationary Fire Pump Engines**

[As stated in §60.4210(g), manufacturers of fire pump engines may use the following test cycle for testing fire pump engines:]

| Mode No. | Engine speed <sup>1</sup> | Torque (percent) <sup>2</sup> | Weighting factors |
|----------|---------------------------|-------------------------------|-------------------|
| 1        | Rated                     | 100                           | 0.30              |
| 2        | Rated                     | 75                            | 0.50              |
| 3        | Rated                     | 50                            | 0.20              |

<sup>1</sup>Engine speed: ±2 percent of point.

<sup>2</sup>Torque: NFPA certified nameplate HP for 100 percent point. All points should be ±2 percent of engine percent load value.

**Table 7 to Subpart IIII of Part 60—Requirements for Performance Tests for Stationary CI ICE With a Displacement of ≥30 Liters per Cylinder**

[As stated in §60.4213, you must comply with the following requirements for performance tests for stationary CI ICE with a displacement of ≥30 liters per cylinder:]

| For each   | Complying with the requirement to                         | You must  | Using  | According to the following requirements   |
|--|---|---|--|---|
| 1. Stationary CI internal combustion engine with a displacement of ≥30 liters per cylinder | a. Reduce NO <sub>x</sub> emissions by 90 percent or more | i. Select the sampling port location and the number of traverse points; | (1) Method 1 or 1A of 40 CFR part 60, appendix A | (a) Sampling sites must be located at the inlet and outlet of the control device. |



**APPENDIX III**

**NSPS Subpart IIII for Stationary Compression Ignition Internal Combustion Engines**

|  |  |   |  |   |
|--|--|---|--|---|
|  |  | ii. Measure O <sub>2</sub> at the inlet and outlet of the control device;   | (2) Method 3, 3A, or 3B of 40 CFR part 60, appendix A  | (b) Measurements to determine O <sub>2</sub> concentration must be made at the same time as the measurements for NO <sub>x</sub> concentration.                     |
|  |  | iii. If necessary, measure moisture content at the inlet and outlet of the control device; and,   | (3) Method 4 of 40 CFR part 60, appendix A, Method 320 of 40 CFR part 63, appendix A, or ASTM D 6348-03 (incorporated by reference, see §60.17)  | (c) Measurements to determine moisture content must be made at the same time as the measurements for NO <sub>x</sub> concentration.                                 |
|  |  | iv. Measure NO <sub>x</sub> at the inlet and outlet of the control device   | (4) Method 7E of 40 CFR part 60, appendix A, Method 320 of 40 CFR part 63, appendix A, or ASTM D 6348-03 (incorporated by reference, see §60.17) | (d) NO <sub>x</sub> concentration must be at 15 percent O <sub>2</sub> , dry basis. Results of this test consist of the average of the three 1-hour or longer runs. |
|  | b. Limit the concentration of NO <sub>x</sub> in the stationary CI internal combustion engine exhaust. | i. Select the sampling port location and the number of traverse points;   | (1) Method 1 or 1A of 40 CFR part 60, Appendix A   | (a) If using a control device, the sampling site must be located at the outlet of the control device.   |
|  |  | ii. Determine the O <sub>2</sub> concentration of the stationary internal combustion engine exhaust at the sampling port location; and, | (2) Method 3, 3A, or 3B of 40 CFR part 60, appendix A  | (b) Measurements to determine O <sub>2</sub> concentration must be made at the same time as the measurement for NO <sub>x</sub> concentration.                      |
|  |  | iii. If necessary, measure moisture content of the stationary internal combustion engine exhaust at the sampling port location; and,    | (3) Method 4 of 40 CFR part 60, appendix A, Method 320 of 40 CFR part 63, appendix A, or ASTM D 6348-03 (incorporated by reference, see §60.17)  | (c) Measurements to determine moisture content must be made at the same time as the measurement for NO <sub>x</sub> concentration.                                  |
|  |  | iv. Measure NO <sub>x</sub> at the exhaust of the stationary internal combustion engine   | (4) Method 7E of 40 CFR part 60, appendix A, Method 320 of 40 CFR part 63, appendix A, or ASTM D 6348-03 (incorporated by reference, see §60.17) | (d) NO <sub>x</sub> concentration must be at 15 percent O <sub>2</sub> , dry basis. Results of this test consist of the average of the three 1-hour or longer runs. |
|  | c. Reduce PM emissions by 60 percent or more   | i. Select the sampling port location and the number of traverse points;   | (1) Method 1 or 1A of 40 CFR part 60, appendix A   | (a) Sampling sites must be located at the inlet and outlet of the control device.   |

**APPENDIX III**

**NSPS Subpart IIII for Stationary Compression Ignition Internal Combustion Engines**

|  |  |  |   |  |
|--|--|--|---|--|
|  |  | ii. Measure O <sub>2</sub> at the inlet and outlet of the control device;  | (2) Method 3, 3A, or 3B of 40 CFR part 60, appendix A | (b) Measurements to determine O <sub>2</sub> concentration must be made at the same time as the measurements for PM concentration.                     |
|  |  | iii. If necessary, measure moisture content at the inlet and outlet of the control device; and   | (3) Method 4 of 40 CFR part 60, appendix A            | (c) Measurements to determine and moisture content must be made at the same time as the measurements for PM concentration.                             |
|  |  | iv. Measure PM at the inlet and outlet of the control device   | (4) Method 5 of 40 CFR part 60, appendix A            | (d) PM concentration must be at 15 percent O <sub>2</sub> , dry basis. Results of this test consist of the average of the three 1-hour or longer runs. |
|  | d. Limit the concentration of PM in the stationary CI internal combustion engine exhaust | i. Select the sampling port location and the number of traverse points;  | (1) Method 1 or 1A of 40 CFR part 60, Appendix A      | (a) If using a control device, the sampling site must be located at the outlet of the control device.  |
|  |  | ii. Determine the O <sub>2</sub> concentration of the stationary internal combustion engine exhaust at the sampling port location; and | (2) Method 3, 3A, or 3B of 40 CFR part 60, appendix A | (b) Measurements to determine O <sub>2</sub> concentration must be made at the same time as the measurements for PM concentration.                     |
|  |  | iii. If necessary, measure moisture content of the stationary internal combustion engine exhaust at the sampling port location; and    | (3) Method 4 of 40 CFR part 60, appendix A            | (c) Measurements to determine moisture content must be made at the same time as the measurements for PM concentration.                                 |
|  |  | iv. Measure PM at the exhaust of the stationary internal combustion engine   | (4) Method 5 of 40 CFR part 60, appendix A            | (d) PM concentration must be at 15 percent O <sub>2</sub> , dry basis. Results of this test consist of the average of the three 1-hour or longer runs. |

**Table 8 to Subpart IIII of Part 60—Applicability of General Provisions to Subpart IIII**

[As stated in §60.4218, you must comply with the following applicable General Provisions:]

| <b>General Provisions citation</b> | <b>Subject of citation</b>                      | <b>Applies to subpart</b> | <b>Explanation</b> |
|------------------------------------|---|---------------------------|--------------------|
| §60.1                              | General applicability of the General Provisions | Yes                       |                    |

**APPENDIX IIII**

**NSPS Subpart IIII for Stationary Compression Ignition Internal Combustion Engines**

|        |  |     |   |
|--------|--|-----|---|
| §60.2  | Definitions  | Yes | Additional terms defined in §60.4219.   |
| §60.3  | Units and abbreviations                                | Yes |   |
| §60.4  | Address  | Yes |   |
| §60.5  | Determination of construction or modification          | Yes |   |
| §60.6  | Review of plans  | Yes |   |
| §60.7  | Notification and Recordkeeping                         | Yes | Except that §60.7 only applies as specified in §60.4214(a).   |
| §60.8  | Performance tests                                      | Yes | Except that §60.8 only applies to stationary CI ICE with a displacement of (≥30 liters per cylinder and engines that are not certified. |
| §60.9  | Availability of information                            | Yes |   |
| §60.10 | State Authority  | Yes |   |
| §60.11 | Compliance with standards and maintenance requirements | No  | Requirements are specified in subpart IIII.   |
| §60.12 | Circumvention  | Yes |   |
| §60.13 | Monitoring requirements                                | Yes | Except that §60.13 only applies to stationary CI ICE with a displacement of (≥30 liters per cylinder.                                   |
| §60.14 | Modification   | Yes |   |
| §60.15 | Reconstruction   | Yes |   |
| §60.16 | Priority list  | Yes |   |
| §60.17 | Incorporations by reference                            | Yes |   |
| §60.18 | General control device requirements                    | No  |   |
| §60.19 | General notification and reporting requirements        | Yes |   |

This subpart establishes emission standards and compliance schedules for the control of emissions from stationary combustion turbines that commenced construction, modification or reconstruction after February 18, 2005. This Appendix has been edited specifically for the simple cycle combustion turbines (EU 031 – 038).

### Applicability

#### § 60.4305 Does this subpart apply to my stationary combustion turbine?

(a) If you are the owner or operator of a stationary combustion turbine with a heat input at peak load equal to or greater than 10.7 gigajoules (10 MMBtu) per hour, based on the higher heating value of the fuel, which commenced construction, modification, or reconstruction after February 18, 2005, your turbine is subject to this subpart. Only heat input to the combustion turbine should be included when determining whether or not this subpart is applicable to your turbine.

(b) Stationary combustion turbines regulated under this subpart are exempt from the requirements of subpart GG of this part.

#### § 60.4310 What types of operations are exempt from these standards of performance?

(a) Emergency combustion turbines, as defined in §60.4420(i), are exempt from the nitrogen oxides (NOx) emission limits in §60.4320.

(b) NA

(c) NA

(d) NA

### Emission Limits

#### § 60.4315 What pollutants are regulated by this subpart?

The pollutants regulated by this subpart are nitrogen oxide (NOx) and sulfur dioxide (SO<sub>2</sub>).

#### § 60.4320 What emission limits must I meet for nitrogen oxides (NOx)?

(a) You must meet the emission limits for NOx specified in Table 1 to this subpart.

(b) If you have two or more turbines that are connected to a single generator, each turbine must meet the emission limits for NOx.

#### § 60.4325 What emission limits must I meet for NOx if my turbine burns both natural gas and distillate oil (or some other combination of fuels)?

Not applicable (NA).

#### § 60.4330 What emission limits must I meet for sulfur dioxide (SO<sub>2</sub>)?

(a) If your turbine is located in a continental area, you must comply with either paragraph (a)(1) or (a)(2) of this section. If your turbine is located in Alaska, you do not have to comply with the requirements in paragraph (a) of this section until January 1, 2008.

(1) NA

(2) You must not burn in the subject stationary combustion turbine any fuel which contains total potential sulfur emissions in excess of 26 ng SO<sub>2</sub>/J (0.060 lb SO<sub>2</sub>/MMBtu) heat input. If your turbine simultaneously fires multiple fuels, each fuel must meet this requirement.

(b) NA.

### General Compliance Requirements

#### § 60.4333 What are my general requirements for complying with this subpart?

(a) You must operate and maintain your stationary combustion turbine, air pollution control equipment, and monitoring equipment in a manner consistent with good air pollution control practices for minimizing emissions at all times including during startup, shutdown, and malfunction.

(b) NA.

### Monitoring

**§ 60.4335 How do I demonstrate compliance for NO<sub>x</sub> if I use water or steam injection?**

- (a) If you are using water or steam injection to control NO<sub>x</sub> emissions, you must install, calibrate, maintain and operate a continuous monitoring system to monitor and record the fuel consumption and the ratio of water or steam to fuel being fired in the turbine when burning a fuel that requires water or steam injection for compliance.
- (b) Alternatively, you may use continuous emission monitoring, as follows:
- (1) Install, certify, maintain, and operate a continuous emission monitoring system (CEMS) consisting of a NO<sub>x</sub> monitor and a diluent gas (oxygen (O<sub>2</sub>) or carbon dioxide (CO<sub>2</sub>)) monitor, to determine the hourly NO<sub>x</sub> emission rate in parts per million (ppm) or pounds per million British thermal units (lb/MMBtu).
  - (2) NA.
  - (3) NA.
  - (4) NA.

**§ 60.4340 How do I demonstrate continuous compliance for NO<sub>x</sub> if I do not use water or steam injection?**

- (a) NA.
- (b) NA.

**§ 60.4345 What are the requirements for the continuous emission monitoring system equipment, if I choose to use this option?**

If the option to use a NO<sub>x</sub> CEMS is chosen:

- (a) Each NO<sub>x</sub> diluent CEMS must be installed and certified according to Performance Specification 2 (PS 2) in appendix B to this part, except the 7-day calibration drift is based on unit operating days, not calendar days. With state approval, Procedure 1 in appendix F to this part is not required. Alternatively, a NO<sub>x</sub> diluent CEMS that is installed and certified according to appendix A of part 75 of this chapter is acceptable for use under this subpart. The relative accuracy test audit (RATA) of the CEMS shall be performed on a lb/MMBtu basis.
- (b) As specified in §60.13(e)(2), during each full unit operating hour, both the NO<sub>x</sub> monitor and the diluent monitor must complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each 15-minute quadrant of the hour, to validate the hour. For partial unit operating hours, at least one valid data point must be obtained with each monitor for each quadrant of the hour in which the unit operates. For unit operating hours in which required quality assurance and maintenance activities are performed on the CEMS, a minimum of two valid data points (one in each of two quadrants) are required for each monitor to validate the NO<sub>x</sub> emission rate for the hour.
- (c) Each fuel flow meter shall be installed, calibrated, maintained, and operated according to the manufacturer's instructions. Alternatively, with state approval, fuel flow meters that meet the installation, certification, and quality assurance requirements of appendix D to part 75 of this chapter are acceptable for use under this subpart.
- (d) Each watt meter, steam flow meter, and each pressure or temperature measurement device shall be installed, calibrated, maintained, and operated according to manufacturer's instructions.
- (e) The owner or operator shall develop and keep on-site a quality assurance (QA) plan for all of the continuous monitoring equipment described in paragraphs (a), (c), and (d) of this section. For the CEMS and fuel flow meters, the owner or operator may, with state approval, satisfy the requirements of this paragraph by implementing the QA program and plan described in section 1 of appendix B to part 75 of this chapter.

**§ 60.4350 How do I use data from the continuous emission monitoring equipment to identify excess emissions?**

For purposes of identifying excess emissions:

- (a) All CEMS data must be reduced to hourly averages as specified in §60.13(h).
- (b) For each unit operating hour in which a valid hourly average, as described in §60.4345(b), is obtained for both NO<sub>x</sub> and diluent monitors, the data acquisition and handling system must calculate and record the hourly NO<sub>x</sub> emission rate in units of ppm or lb/MMBtu, using the appropriate equation from method 19 in appendix A of this part. For any hour in which the hourly average O<sub>2</sub> concentration exceeds 19.0 percent O<sub>2</sub> (or the hourly average CO<sub>2</sub> concentration is less than 1.0 percent CO<sub>2</sub>), a diluent cap value of 19.0 percent O<sub>2</sub> or 1.0 percent CO<sub>2</sub> (as applicable) may be used in the emission calculations.

- (c) Correction of measured NO<sub>x</sub> concentrations to 15 percent O<sub>2</sub> is not allowed.
- (d) If you have installed and certified a NO<sub>x</sub> diluent CEMS to meet the requirements of part 75 of this chapter, states can approve that only quality assured data from the CEMS shall be used to identify excess emissions under this subpart. Periods where the missing data substitution procedures in subpart D of part 75 are applied are to be reported as monitor downtime in the excess emissions and monitoring performance report required under §60.7(c).
- (e) All required fuel flow rate, steam flow rate, temperature, pressure, and megawatt data must be reduced to hourly averages.
- (f) Calculate the hourly average NO<sub>x</sub> emission rates, in units of the emission standards under §60.4320, using either ppm for units complying with the concentration limit.
- (g) For simple cycle units without heat recovery, use the calculated hourly average emission rates from paragraph (f) of this section to assess excess emissions on a 4-hour rolling average basis, as described in §60.4380(b)(1).
- (h) NA.

**§ 60.4355 How do I establish and document a proper parameter monitoring plan?**

- (a) NA.  
(b) NA.

**§ 60.4360 How do I determine the total sulfur content of the turbine's combustion fuel? NA.**

**§ 60.4365 How can I be exempted from monitoring the total sulfur content of the fuel?**

You may elect not to monitor the total sulfur content of the fuel combusted in the turbine, if the fuel is demonstrated not to exceed potential sulfur emissions of 26 ng SO<sub>2</sub>/J (0.060 lb SO<sub>2</sub>/MMBtu) heat input for units located in continental areas and 180 ng SO<sub>2</sub>/J (0.42 lb SO<sub>2</sub>/MMBtu) heat input for units located in noncontinental areas or a continental area that the Administrator determines does not have access to natural gas and that the removal of sulfur compounds would cause more environmental harm than benefit. You must use one of the following sources of information to make the required demonstration:

- (a) The fuel quality characteristics in a current, valid purchase contract, tariff sheet or transportation contract for the fuel, specifying that the maximum total sulfur content for oil use in continental areas is 0.05 weight percent (500 ppmw) or less, the total sulfur content for natural gas use in continental areas is 20 grains of sulfur or less per 100 standard cubic feet, has potential sulfur emissions of less than less than 26 ng SO<sub>2</sub>/J (0.060 lb SO<sub>2</sub>/MMBtu) heat input for continental areas; or
- (b) Representative fuel sampling data which show that the sulfur content of the fuel does not exceed 26 ng SO<sub>2</sub>/J (0.060 lb SO<sub>2</sub>/MMBtu) heat input for continental areas. At a minimum, the amount of fuel sampling data specified in section 2.3.1.4 or 2.3.2.4 of appendix D to part 75 of this chapter is required.

**§ 60.4370 How often must I determine the sulfur content of the fuel? NA.**

**Reporting**

**§ 60.4375 What reports must I submit?**

- (a) For each affected unit required to continuously monitor parameters or emissions, or to periodically determine the fuel sulfur content under this subpart, you must submit reports of excess emissions and monitor downtime, in accordance with §60.7(c). Excess emissions must be reported for all periods of unit operation, including start-up, shutdown, and malfunction.
- (b) NA.

**§ 60.4380 How are excess emissions and monitor downtime defined for NO<sub>x</sub>?**

For the purpose of reports required under §60.7(c), periods of excess emissions and monitor downtime that must be reported are defined as follows:

- (a) NA.
- (b) For turbines using continuous emission monitoring, as described in §§60.4335(b) and 60.4345:
- (1) An excess emissions is any unit operating period in which the 4-hour rolling average NO<sub>x</sub> emission rate exceeds the applicable emission limit in §60.4320. For the purposes of this subpart, a "4- hour rolling average NO<sub>x</sub> emission

rate” is the arithmetic average of the average NOx emission rate in ppm or ng/J (lb/MWh) measured by the continuous emission monitoring equipment for a given hour and the three unit operating hour average NOx emission rates immediately preceding that unit operating hour. Calculate the rolling average if a valid NOx emission rate is obtained for at least 3 of the 4 hours.

(2) A period of monitor downtime is any unit operating hour in which the data for any of the following parameters are either missing or invalid: NOx concentration, CO<sub>2</sub> or O<sub>2</sub> concentration, fuel flow rate, steam flow rate, steam temperature, steam pressure, or megawatts. The steam flow rate, steam temperature, and steam pressure are only required if you will use this information for compliance purposes.

(3) For operating periods during which multiple emissions standards apply, the applicable standard is the average of the applicable standards during each hour. For hours with multiple emissions standards, the applicable limit for that hour is determined based on the condition that corresponded to the highest emissions standard.

(c) NA.

**§ 60.4385 How are excess emissions and monitoring downtime defined for SO<sub>2</sub>?**

If you choose the option to monitor the sulfur content of the fuel, excess emissions and monitoring downtime are defined as follows:

(a) For samples of gaseous fuel obtained using daily sampling, an excess emission occurs each unit operating hour included in the period beginning on the date and hour of any sample for which the sulfur content of the fuel being fired in the combustion turbine exceeds the applicable limit and ending on the date and hour that a subsequent sample is taken that demonstrates compliance with the sulfur limit.

(b) NA.

(c) A period of monitor downtime begins when a required sample is not taken by its due date. A period of monitor downtime also begins on the date and hour of a required sample, if invalid results are obtained. The period of monitor downtime ends on the date and hour of the next valid sample.

**§ 60.4390 What are my reporting requirements if I operate an emergency combustion turbine or a research and development turbine? NA.**

**§ 60.4395 When must I submit my reports?**

All reports required under §60.7(c) must be postmarked by the 30th day following the end of each 6-month period.

**Performance Tests**

**§ 60.4400 How do I conduct the initial and subsequent performance tests, regarding NO<sub>x</sub>?**

(a) You must conduct an initial performance test, as required in §60.8. Subsequent NO<sub>x</sub> performance tests shall be conducted on an annual basis (no more than 14 calendar months following the previous performance test).

(1) There are two general methodologies that you may use to conduct the performance tests. For each test run:

(i) Measure the NO<sub>x</sub> concentration (in parts per million (ppm)), using EPA Method 7E or EPA Method 20 in appendix A of this part. For units complying with the output based standard, concurrently measure the stack gas flow rate, using EPA Methods 1 and 2 in appendix A of this part, and measure and record the electrical and thermal output from the unit. Then, use the following equation to calculate the NO<sub>x</sub> emission rate:

$$E = \frac{1.194 \times 10^{-7} * (NO_x)_c * Q_{std}}{P} \quad (\text{Eq. 5})$$

Where:

E = NO<sub>x</sub> emission rate, in lb/MWh

1.194 × 10<sup>-7</sup> = conversion constant, in lb/dscf-ppm

(NO<sub>x</sub>)<sub>c</sub> = average NO<sub>x</sub> concentration for the run, in ppm

Q<sub>std</sub> = stack gas volumetric flow rate, in dscf/hr

P = gross electrical and mechanical energy output of the combustion turbine, in MW (for simple-cycle operation), for combined-cycle operation, the sum of all electrical and mechanical output from the combustion

and steam turbines, or, for combined heat and power operation, the sum of all electrical and mechanical output from the combustion and steam turbines plus all useful recovered thermal output not used for additional electric or mechanical generation, in MW, calculated according to §60.4350(f)(2); or

(ii) Measure the NO<sub>x</sub> and diluent gas concentrations, using either EPA Methods 7E and 3A, or EPA Method 20 in appendix A of this part. Concurrently measure the heat input to the unit, using a fuel flow meter (or flow meters), and measure the electrical and thermal output of the unit. Use EPA Method 19 in appendix A of this part to calculate the NO<sub>x</sub> emission rate in lb/MMBtu. Then, use Equations 1 and, if necessary, 2 and 3 in §60.4350(f) to calculate the NO<sub>x</sub> emission rate in lb/MWh.

(2) Sampling traverse points for NO<sub>x</sub> and (if applicable) diluent gas are to be selected following EPA Method 20 or EPA Method 1 (non-particulate procedures), and sampled for equal time intervals. The sampling must be performed with a traversing single-hole probe, or, if feasible, with a stationary multihole probe that samples each of the points sequentially. Alternatively, a multi-hole probe designed and documented to sample equal volumes from each hole may be used to sample simultaneously at the required points.

(3) Notwithstanding paragraph (a)(2) of this section, you may test at fewer points than are specified in EPA Method 1 or EPA Method 20 in appendix A of this part if the following conditions are met:

(i) You may perform a stratification test for NO<sub>x</sub> and diluent pursuant to

(A) [Reserved], or

(B) The procedures specified in section 6.5.6.1(a) through (e) of appendix A of part 75 of this chapter.

(ii) Once the stratification sampling is completed, you may use the following alternative sample point selection criteria for the performance test:

(A) If each of the individual traverse point NO<sub>x</sub> concentrations is within ±10 percent of the mean concentration for all traverse points, or the individual traverse point diluent concentrations differs by no more than ±5ppm or ±0.5 percent CO<sub>2</sub> (or O<sub>2</sub>) from the mean for all traverse points, then you may use three points (located either 16.7, 50.0 and 83.3 percent of the way across the stack or duct, or, for circular stacks or ducts greater than 2.4 meters (7.8 feet) in diameter, at 0.4, 1.2, and 2.0 meters from the wall). The three points must be located along the measurement line that exhibited the highest average NO<sub>x</sub> concentration during the stratification test; or

(B) For turbines with a NO<sub>x</sub> standard greater than 15 ppm @ 15% O<sub>2</sub>, you may sample at a single point, located at least 1 meter from the stack wall or at the stack centroid if each of the individual traverse point NO<sub>x</sub> concentrations is within ±5 percent of the mean concentration for all traverse points, or the individual traverse point diluent concentrations differs by no more than ±3 ppm or ±0.3 percent CO<sub>2</sub> (or O<sub>2</sub>) from the mean for all traverse points; or

(C) NA.

(b) The performance test must be done at any load condition within plus or minus 25 percent of 100 percent of peak load. You may perform testing at the highest achievable load point, if at least 75 percent of peak load cannot be achieved in practice. You must conduct three separate test runs for each performance test. The minimum time per run is 20 minutes.

(1) If the stationary combustion turbine combusts both oil and gas as primary or backup fuels, separate performance testing is required for each fuel.

(2) NA.

(3) NA.

(4) Compliance with the applicable emission limit in §60.4320 must be demonstrated at each tested load level. Compliance is achieved if the three-run arithmetic average NO<sub>x</sub> emission rate at each tested level meets the applicable emission limit in §60.4320.

(5) If you elect to install a CEMS, the performance evaluation of the CEMS may either be conducted separately or (as described in §60.4405) as part of the initial performance test of the affected unit.

(6) The ambient temperature must be greater than 0 °F during the performance test.

**§ 60.4405 How do I perform the initial performance test if I have chosen to install a NO<sub>x</sub>-diluent CEMS?**



If you elect to install and certify a NO<sub>x</sub>-diluent CEMS under §60.4345, then the initial performance test required under §60.8 may be performed in the following alternative manner:

- (a) Perform a minimum of nine RATA reference method runs, with a minimum time per run of 21 minutes, at a single load level, within plus or minus 25 percent of 100 percent of peak load. The ambient temperature must be greater than 0 °F during the RATA runs.
- (b) For each RATA run, concurrently measure the heat input to the unit using a fuel flow meter (or flow meters) and measure the electrical and thermal output from the unit.
- (c) Use the test data both to demonstrate compliance with the applicable NO<sub>x</sub> emission limit under §60.4320 and to provide the required reference method data for the RATA of the CEMS described under §60.4335.
- (d) Compliance with the applicable emission limit in §60.4320 is achieved if the arithmetic average of all of the NO<sub>x</sub> emission rates for the RATA runs, expressed in units of ppm or lb/MWh, does not exceed the emission limit.

**§ 60.4410 How do I establish a valid parameter range if I have chosen to continuously monitor parameters? NA.**

**§ 60.4415 How do I conduct the initial and subsequent performance tests for sulfur?**

(a) You must conduct an initial performance test, as required in §60.8. Subsequent SO<sub>2</sub> performance tests shall be conducted on an annual basis (no more than 14 calendar months following the previous performance test). There are three methodologies that you may use to conduct the performance tests.

(1) If you choose to periodically determine the sulfur content of the fuel combusted in the turbine, a representative fuel sample would be collected following ASTM D5287 (incorporated by reference, see §60.17) for natural gas. The fuel analyses of this section may be performed either by you, a service contractor retained by you, the fuel vendor, or any other qualified agency. Analyze the samples for the total sulfur content of the fuel using:

(i) NA.

(ii) For gaseous fuels, ASTM D1072, or alternatively D3246, D4084, D4468, D4810, D6228, D6667, or Gas Processors Association Standard 2377 (all of which are incorporated by reference, see §60.17).

(2) Measure the SO<sub>2</sub> concentration (in parts per million (ppm)), using EPA Methods 6, 6C, 8, or 20 in appendix A of this part. In addition, the American Society of Mechanical Engineers (ASME) standard, ASME PTC 19-10-1981-Part 10, "Flue and Exhaust Gas Analyses," manual methods for sulfur dioxide (incorporated by reference, see §60.17) can be used instead of EPA Methods 6 or 20. For units complying with the output based standard, concurrently measure the stack gas flow rate, using EPA Methods 1 and 2 in appendix A of this part, and measure and record the electrical and thermal output from the unit. Then use the following equation to calculate the SO<sub>2</sub> emission rate:

$$E = \frac{1.664 \times 10^{-7} * (SO_2)_c * Q_{std}}{P} \quad (\text{Eq. 6})$$

Where:

E = SO<sub>2</sub> emission rate, in lb/MWh

1.664 × 10<sup>-7</sup> = conversion constant, in lb/dscf-ppm

(SO<sub>2</sub>)<sub>c</sub> = average SO<sub>2</sub> concentration for the run, in ppm

Q<sub>std</sub> = stack gas volumetric flow rate, in dscf/hr

P = gross electrical and mechanical energy output of the combustion turbine, in MW (for simple-cycle operation), for combined-cycle operation, the sum of all electrical and mechanical output from the combustion and steam turbines, or, for combined heat and power operation, the sum of all electrical and mechanical output from the combustion and steam turbines plus all useful recovered thermal output not used for additional electric or mechanical generation, in MW, calculated according to §60.4350(f)(2); or

(3) Measure the SO<sub>2</sub> and diluent gas concentrations, using either EPA Methods 6, 6C, or 8 and 3A, or 20 in appendix A of this part. In addition, you may use the manual methods for sulfur dioxide ASME PTC 19-10-1981-Part 10 (incorporated by reference, see §60.17). Concurrently measure the heat input to the unit, using a fuel flow meter (or flow meters), and measure the electrical and thermal output of the unit. Use EPA Method 19 in appendix A of this part to calculate the SO<sub>2</sub> emission rate in lb/MMBtu. Then, use Equations 1 and, if necessary, 2 and 3 in §60.4350(f) to calculate the SO<sub>2</sub> emission rate in lb/MWh.

(b) [Reserved]

## Definitions

### § 60.4420 What definitions apply to this subpart?

As used in this subpart, all terms not defined herein will have the meaning given them in the Clean Air Act and in subpart A (General Provisions) of this part.

*Combined cycle combustion turbine* means any stationary combustion turbine which recovers heat from the combustion turbine exhaust gases to generate steam that is only used to create additional power output in a steam turbine.

*Combined heat and power combustion turbine* means any stationary combustion turbine which recovers heat from the exhaust gases to heat water or another medium, generate steam for useful purposes other than additional electric generation, or directly uses the heat in the exhaust gases for a useful purpose.

*Combustion turbine model* means a group of combustion turbines having the same nominal air flow, combustor inlet pressure, combustor inlet temperature, firing temperature, turbine inlet temperature and turbine inlet pressure.

*Combustion turbine test cell/stand* means any apparatus used for testing uninstalled stationary or uninstalled mobile (motive) combustion turbines.

*Diffusion flame stationary combustion turbine* means any stationary combustion turbine where fuel and air are injected at the combustor and are mixed only by diffusion prior to ignition.

*Duct burner* means a device that combusts fuel and that is placed in the exhaust duct from another source, such as a stationary combustion turbine, internal combustion engine, kiln, etc., to allow the firing of additional fuel to heat the exhaust gases before the exhaust gases enter a heat recovery steam generating unit.

*Efficiency* means the combustion turbine manufacturer's rated heat rate at peak load in terms of heat input per unit of power output—based on the higher heating value of the fuel.

*Emergency combustion turbine* means any stationary combustion turbine which operates in an emergency situation. Examples include stationary combustion turbines used to produce power for critical networks or equipment, including power supplied to portions of a facility, when electric power from the local utility is interrupted, or stationary combustion turbines used to pump water in the case of fire or flood, etc. Emergency stationary combustion turbines do not include stationary combustion turbines used as peaking units at electric utilities or stationary combustion turbines at industrial facilities that typically operate at low capacity factors. Emergency combustion turbines may be operated for the purpose of maintenance checks and readiness testing, provided that the tests are required by the manufacturer, the vendor, or the insurance company associated with the turbine. Required testing of such units should be minimized, but there is no time limit on the use of emergency combustion turbines.

*Excess emissions* means a specified averaging period over which either (1) the NOX emissions are higher than the applicable emission limit in §60.4320; (2) the total sulfur content of the fuel being combusted in the affected facility exceeds the limit specified in §60.4330; or (3) the recorded value of a particular monitored parameter is outside the acceptable range specified in the parameter monitoring plan for the affected unit.

*Gross useful output* means the gross useful work performed by the stationary combustion turbine system. For units using the mechanical energy directly or generating only electricity, the gross useful work performed is the gross electrical or mechanical output from the turbine/generator set. For combined heat and power units, the gross useful work performed is the gross electrical or mechanical output plus the useful thermal output (i.e., thermal energy delivered to a process).

*Heat recovery steam generating unit* means a unit where the hot exhaust gases from the combustion turbine are routed in order to extract heat from the gases and generate steam, for use in a steam turbine or other device that utilizes steam. Heat recovery steam generating units can be used with or without duct burners.

*Integrated gasification combined cycle electric utility steam generating unit* means a coal-fired electric utility steam generating unit that burns a synthetic gas derived from coal in a combined-cycle gas turbine. No solid coal is directly burned in the unit during operation. *ISO conditions* means 288 Kelvin, 60 percent relative humidity and 101.3 kilopascals pressure.

*Lean premix stationary combustion turbine* means any stationary combustion turbine where the air and fuel are thoroughly mixed to form a lean mixture before delivery to the combustor. Mixing may occur before or in the combustion chamber. A lean premixed turbine may operate in diffusion flame mode during operating conditions such as startup and shutdown, extreme ambient temperature, or low or transient load.

**APPENDIX KKKK**

NSPS Subpart KKKK for Stationary Combustion Turbines

*Natural gas* means a naturally occurring fluid mixture of hydrocarbons (e.g., methane, ethane, or propane) produced in geological formations beneath the Earth's surface that maintains a gaseous state at standard atmospheric temperature and pressure under ordinary conditions. Additionally, natural gas must either be composed of at least 70 percent methane by volume or have a gross calorific value between 950 and 1,100 British thermal units (Btu) per standard cubic foot. Natural gas does not include the following gaseous fuels: landfill gas, digester gas, refinery gas, sour gas, blast furnace gas, coal derived gas, producer gas, coke oven gas, or any gaseous fuel produced in a process which might result in highly variable sulfur content or heating value.

*Noncontinental area* means the State of Hawaii, the Virgin Islands, Guam, American Samoa, the Commonwealth of Puerto Rico, the Northern Mariana Islands, or offshore platforms.

*Peak load* means 100 percent of the manufacturer's design capacity of the combustion turbine at ISO conditions.

*Regenerative cycle combustion turbine* means any stationary combustion turbine which recovers heat from the combustion turbine exhaust gases to preheat the inlet combustion air to the combustion turbine.

*Simple cycle combustion turbine* means any stationary combustion turbine which does not recover heat from the combustion turbine exhaust gases to preheat the inlet combustion air to the combustion turbine, or which does not recover heat from the combustion turbine exhaust gases for purposes other than enhancing the performance of the combustion turbine itself.

*Stationary combustion turbine* means all equipment, including but not limited to the turbine, the fuel, air, lubrication and exhaust gas systems, control systems (except emissions control equipment), heat recovery system, and any ancillary components and sub-components comprising any simple cycle stationary combustion turbine, any regenerative/recuperative cycle stationary combustion turbine, any combined cycle combustion turbine, and any combined heat and power combustion turbine based system. Stationary means that the combustion turbine is not self propelled or intended to be propelled while performing its function. It may, however, be mounted on a vehicle for portability.

*Unit operating day* means a 24-hour period between 12 midnight and the following midnight during which any fuel is combusted at any time in the unit. It is not necessary for fuel to be combusted continuously for the entire 24-hour period.

*Unit operating hour* means a clock hour during which any fuel is combusted in the affected unit. If the unit combusts fuel for the entire clock hour, it is considered to be a full unit operating hour. If the unit combusts fuel for only part of the clock hour, it is considered to be a partial unit operating hour.

*Useful thermal output* means the thermal energy made available for use in any industrial or commercial process, or used in any heating or cooling application, i.e., total thermal energy made available for processes and applications other than electrical or mechanical generation. Thermal output for this subpart means the energy in recovered thermal output measured against the energy in the thermal output at 15 degrees Celsius and 101.325 kilopascals of pressure.

**Table 1 to Subpart KKKK of Part 60-Nitrogen Oxide Emission Limits for New Stationary Combustion Turbines**

| Combustion turbine type         | Combustion turbine heat input at peak load (HHV) | NOX emission standard   |
|---------------------------------|--|---|
| New turbine firing natural gas. | > 50 MMBtu/h and [le] 850 MMBtu/h                | 25 ppm at 15 percent O <sub>2</sub> or 150 ng/J of useful output (1.2 lb/ MWh). |

## NESHAP Subpart A for General Provisions

In accordance with Rule 62-204.800, F.A.C., the following federal regulations in Part 63 of Title 40 of the Code of Federal Regulations were adopted by reference. The original federal rule numbering has been retained.

#### 40 CFR 63 Subpart A – NESHAP General Provisions

##### § 63.1 Applicability.

###### (a) *General.*

(1) Terms used throughout this part are defined in § 63.2 or in the Clean Air Act (Act) as amended in 1990, except that individual subparts of this part may include specific definitions in addition to or that supersede definitions in § 63.2.

(2) This part contains national emission standards for hazardous air pollutants (NESHAP) established pursuant to section 112 of the Act as amended November 15, 1990. These standards regulate specific categories of stationary sources that emit (or have the potential to emit) one or more hazardous air pollutants listed in this part pursuant to section 112(b) of the Act. This section explains the applicability of such standards to sources affected by them. The standards in this part are independent of NESHAP contained in 40 CFR part 61. The NESHAP in part 61 promulgated by signature of the Administrator before November 15, 1990 (i.e., the date of enactment of the Clean Air Act Amendments of 1990) remain in effect until they are amended, if appropriate, and added to this part.

(3) No emission standard or other requirement established under this part shall be interpreted, construed, or applied to diminish or replace the requirements of a more stringent emission limitation or other applicable requirement established by the Administrator pursuant to other authority of the Act (section 111, part C or D or any other authority of this Act), or a standard issued under State authority. The Administrator may specify in a specific standard under this part that facilities subject to other provisions under the Act need only comply with the provisions of that standard.

(4) (i) Each relevant standard in this part 63 must identify explicitly whether each provision in this subpart A is or is not included in such relevant standard.

(ii) If a relevant part 63 standard incorporates the requirements of 40 CFR part 60, part 61, or other part 63 standards, the relevant part 63 standard must identify explicitly the applicability of each corresponding part 60, part 61, or other part 63 subpart A (General) Provision.

(iii) The General Provisions in this Subpart A do not apply to regulations developed pursuant to section 112(r) of the amended Act., unless otherwise specified in those regulations.

(5) [Reserved]

(6) To obtain the most current list of categories of sources to be regulated under section 112 of the Act, or to obtain the most recent regulation promulgation schedule established pursuant to section 112(e) of the Act, contact the Office of the Director, Emission Standards Division, Office of Air Quality Planning and Standards, U.S. EPA (MD-13), Research Triangle Park, North Carolina 27711.

(7) [Reserved]

(8) [Reserved]

(9) [Reserved]

(10) For the purposes of this part, time periods specified in days shall be measured in calendar days, even if the word “calendar” is absent, unless otherwise specified in an applicable requirement.

(11) For the purposes of this part, if an explicit postmark deadline is not specified in an applicable requirement for the submittal of a notification, application, test plan, report, or other written communication to the Administrator, the owner or operator shall postmark the submittal on or before the number of days specified in the applicable requirement. For example, if a notification must be submitted 15 days before a particular event is scheduled to take place, the notification shall be postmarked on or before 15 days preceding the event; likewise, if a notification must be submitted 15 days after a particular event takes place, the notification shall be postmarked on or before 15 days following the end of the event. The use of reliable non-Government mail carriers that provide indications of verifiable delivery of information required to be submitted to the Administrator, similar to the postmark provided by the U.S. Postal Service, or alternative means of delivery agreed to by the permitting authority, is acceptable.

(12) Notwithstanding time periods or postmark deadlines specified in this part for the submittal of information to the Administrator by an owner or operator, or the review of such information by the Administrator, such time periods or deadlines may be changed by mutual agreement between the owner or operator and the Administrator. Procedures governing the implementation of this provision are specified in § 63.9(i).

(13) [Reserved]

(14) [Reserved]

###### (b) *Initial applicability determination for this part.*

## NESHAP Subpart A for General Provisions

(1) The provisions of this part apply to the owner or operator of any stationary source that - (i) Emits or has the potential to emit any hazardous air pollutant listed in or pursuant to section 112(b) of the Act; and  
 (ii) Is subject to any standard, limitation, prohibition, or other federally enforceable requirement established pursuant to this part.

(2) [Reserved]

(3) An owner or operator of a stationary source who is in the relevant source category and who determines that the source is not subject to a relevant standard or other requirement established under this part, must keep a record as specified in § 63.10(b)(3).

(c) *Applicability of this part after a relevant standard has been set under this part.*

(1) If a relevant standard has been established under this part, the owner or operator of an affected source must comply with the provisions of that standard and of this subpart as provided in paragraph (a)(4) of this section.

(2) Except as provided in § 63.10(b)(3), if a relevant standard has been established under this part, the owner or operator of an affected source may be required to obtain a title V permit from a permitting authority in the State in which the source is located. Emission standards promulgated in this part for area sources pursuant to section 112(c)(3) of the Act will specify whether –

(i) States will have the option to exclude area sources affected by that standard from the requirement to obtain a title V permit (i.e., the standard will exempt the category of area sources altogether from the permitting requirement);

(ii) States will have the option to defer permitting of area sources in that category until the Administrator takes rulemaking action to determine applicability of the permitting requirements; or

(iii) If a standard fails to specify what the permitting requirements will be for area sources affected by such a standard, then area sources that are subject to the standard will be subject to the requirement to obtain a title V permit without any deferral.

(3) [Reserved]

(4) [Reserved]

(5) If an area source that otherwise would be subject to an emission standard or other requirement established under this part if it were a major source subsequently increases its emissions of hazardous air pollutants (or its potential to emit hazardous air pollutants) such that the source is a major source that is subject to the emission standard or other requirement, such source also shall be subject to the notification requirements of this subpart.

(d) [Reserved]

(e) If the Administrator promulgates an emission standard under section 112(d) or (h) of the Act that is applicable to a source subject to an emission limitation by permit established under section 112(j) of the Act, and the requirements under the section 112(j) emission limitation are substantially as effective as the promulgated emission standard, the owner or operator may request the permitting authority to revise the source's title V permit to reflect that the emission limitation in the permit satisfies the requirements of the promulgated emission standard. The process by which the permitting authority determines whether the section 112(j) emission limitation is substantially as effective as the promulgated emission standard must include, consistent with part 70 or 71 of this chapter, the opportunity for full public, EPA, and affected State review (including the opportunity for EPA's objection) prior to the permit revision being finalized. A negative determination by the permitting authority constitutes final action for purposes of review and appeal under the applicable title V operating permit program.

### § 63.2 Definitions.

The terms used in this part are defined in the Act or in this section as follows:

*Act* means the Clean Air Act (42 U.S.C. 7401 et seq., as amended by Pub. L. 101–549, 104 Stat. 2399).

*Actual emissions* is defined in subpart D of this part for the purpose of granting a compliance extension for an early reduction of hazardous air pollutants.

*Administrator* means the Administrator of the United States Environmental Protection Agency or his or her authorized representative (e.g., a State that has been delegated the authority to implement the provisions of this part).

*Affected source*, for the purposes of this part, means the collection of equipment, activities, or both within a single contiguous area and under common control that is included in a section 112(c) source category or subcategory for which a section 112(d) standard or other relevant standard is established pursuant to section 112 of the Act. Each relevant standard will define the "affected source," as defined in this paragraph unless a different definition is warranted based on a published justification as to why this definition would result in significant administrative, practical, or implementation problems and

why the different definition would resolve those problems. The term "affected source," as used in this part, is separate and distinct from any other use of that term in EPA regulations such as those implementing title IV of the Act. Affected source may be defined differently for part 63 than affected facility and stationary source in parts 60 and 61, respectively. This definition of "affected source," and the procedures for adopting an alternative definition of "affected source," shall apply to each section 112(d) standard for which the initial proposed rule is signed by the Administrator after June 30, 2002.

*Alternative emission limitation* means conditions established pursuant to sections 112(i)(5) or 112(i)(6) of the Act by the Administrator or by a State with an approved permit program.

*Alternative emission standard* means an alternative means of emission limitation that, after notice and opportunity for public comment, has been demonstrated by an owner or operator to the Administrator's satisfaction to achieve a reduction in emissions of any air pollutant at least equivalent to the reduction in emissions of such pollutant achieved under a relevant design, equipment, work practice, or operational emission standard, or combination thereof, established under this part pursuant to section 112(h) of the Act.

*Alternative test method* means any method of sampling and analyzing for an air pollutant that is not a test method in this chapter and that has been demonstrated to the Administrator's satisfaction, using Method 301 in Appendix A of this part, to produce results adequate for the Administrator's determination that it may be used in place of a test method specified in this part.

*Approved permit program* means a State permit program approved by the Administrator as meeting the requirements of part 70 of this chapter or a Federal permit program established in this chapter pursuant to title V of the Act (42 U.S.C. 7661).

*Area source* means any stationary source of hazardous air pollutants that is not a major source as defined in this part.

*Commenced* means, with respect to construction or reconstruction of an affected source, that an owner or operator has undertaken a continuous program of construction or reconstruction or that an owner or operator has entered into a contractual obligation to undertake and complete, within a reasonable time, a continuous program of construction or reconstruction.

*Compliance date* means the date by which an affected source is required to be in compliance with a relevant standard, limitation, prohibition, or any federally enforceable requirement established by the Administrator (or a State with an approved permit program) pursuant to section 112 of the Act.

*Compliance schedule* means:

(1) In the case of an affected source that is in compliance with all applicable requirements established under this part, a statement that the source will continue to comply with such requirements; or

(2) In the case of an affected source that is required to comply with applicable requirements by a future date, a statement that the source will meet such requirements on a timely basis and, if required by an applicable requirement, a detailed schedule of the dates by which each step toward compliance will be reached; or

(3) In the case of an affected source not in compliance with all applicable requirements established under this part, a schedule of remedial measures, including an enforceable sequence of actions or operations with milestones and a schedule for the submission of certified progress reports, where applicable, leading to compliance with a relevant standard, limitation, prohibition, or any federally enforceable requirement established pursuant to section 112 of the Act for which the affected source is not in compliance. This compliance schedule shall resemble and be at least as stringent as that contained in any judicial consent decree or administrative order to which the source is subject. Any such schedule of compliance shall be supplemental to, and shall not sanction non-compliance with, the applicable requirements on which it is based.

*Construction* means the on-site fabrication, erection, or installation of an affected source. Construction does not include the removal of all equipment comprising an affected source from an existing location and reinstallation of such equipment at a new location. The owner or operator of an existing affected source that is relocated may elect not to reinstall minor ancillary equipment including, but not limited to, piping, ductwork, and valves. However, removal and reinstallation of an affected source will be construed as reconstruction if it satisfies the criteria for reconstruction as defined in this section. The costs of replacing minor ancillary equipment must be considered in determining whether the existing affected source is reconstructed.

*Continuous emission monitoring system (CEMS)* means the total equipment that may be required to meet the data acquisition and availability requirements of this part, used to sample, condition (if applicable), analyze, and provide a record of emissions.

*Continuous monitoring system (CMS)* is a comprehensive term that may include, but is not limited to, continuous emission monitoring systems, continuous opacity monitoring systems, continuous parameter monitoring systems, or other manual or automatic monitoring that is used for demonstrating compliance with an applicable regulation on a continuous basis as defined by the regulation.

*Continuous opacity monitoring system (COMS)* means a continuous monitoring system that measures the opacity of emissions.

## NESHAP Subpart A for General Provisions

*Continuous parameter monitoring system* means the total equipment that may be required to meet the data acquisition and availability requirements of this part, used to sample, condition (if applicable), analyze, and provide a record of process or control system parameters.

*Effective date* means:

- (1) With regard to an emission standard established under this part, the date of promulgation in the FEDERAL REGISTER of such standard; or
- (2) With regard to an alternative emission limitation or equivalent emission limitation determined by the Administrator (or a State with an approved permit program), the date that the alternative emission limitation or equivalent emission limitation becomes effective according to the provisions of this part.

*Emission standard* means a national standard, limitation, prohibition, or other regulation promulgated in a subpart of this part pursuant to sections 112(d), 112(h), or 112(f) of the Act.

*Emissions averaging* is a way to comply with the emission limitations specified in a relevant standard, whereby an affected source, if allowed under a subpart of this part, may create emission credits by reducing emissions from specific points to a level below that required by the relevant standard, and those credits are used to offset emissions from points that are not controlled to the level required by the relevant standard.

*EPA* means the United States Environmental Protection Agency.

*Equivalent emission limitation* means any maximum achievable control technology emission limitation or requirements which are applicable to a major source of hazardous air pollutants and are adopted by the Administrator (or a State with an approved permit program) on a case-by-case basis, pursuant to section 112(g) or (j) of the Act.

*Excess emissions and continuous monitoring system performance report* is a report that must be submitted periodically by an affected source in order to provide data on its compliance with relevant emission limits, operating parameters, and the performance of its continuous parameter monitoring systems.

*Existing source* means any affected source that is not a new source.

*Federally enforceable* means all limitations and conditions that are enforceable by the Administrator and citizens under the Act or that are enforceable under other statutes administered by the Administrator. Examples of federally enforceable limitations and conditions include, but are not limited to:

- (1) Emission standards, alternative emission standards, alternative emission limitations, and equivalent emission limitations established pursuant to section 112 of the Act as amended in 1990;
- (2) New source performance standards established pursuant to section 111 of the Act, and emission standards established pursuant to section 112 of the Act before it was amended in 1990;
- (3) All terms and conditions in a title V permit, including any provisions that limit a source's potential to emit, unless expressly designated as not federally enforceable;
- (4) Limitations and conditions that are part of an approved State Implementation Plan (SIP) or a Federal Implementation Plan (FIP);
- (5) Limitations and conditions that are part of a Federal construction permit issued under 40 CFR 52.21 or any construction permit issued under regulations approved by the EPA in accordance with 40 CFR part 51;
- (6) Limitations and conditions that are part of an operating permit where the permit and the permitting program pursuant to which it was issued meet all of the following criteria:
  - (i) The operating permit program has been submitted to and approved by EPA into a State implementation plan (SIP) under section 110 of the CAA;
  - (ii) The SIP imposes a legal obligation that operating permit holders adhere to the terms and limitations of such permits and provides that permits which do not conform to the operating permit program requirements and the requirements of EPA's underlying regulations may be deemed not "federally enforceable" by EPA;
  - (iii) The operating permit program requires that all emission limitations, controls, and other requirements imposed by such permits will be at least as stringent as any other applicable limitations and requirements contained in the SIP or enforceable under the SIP, and that the program may not issue permits that waive, or make less stringent, any limitations or requirements contained in or issued pursuant to the SIP, or that are otherwise "federally enforceable";
  - (iv) The limitations, controls, and requirements in the permit in question are permanent, quantifiable, and otherwise enforceable as a practical matter; and
  - (v) The permit in question was issued only after adequate and timely notice and opportunity for comment for EPA and the public.
- (7) Limitations and conditions in a State rule or program that has been approved by the EPA under subpart E of this part for the purposes of implementing and enforcing section 112; and
- (8) Individual consent agreements that the EPA has legal authority to create.

*Fixed capital cost* means the capital needed to provide all the depreciable components of an existing source.

## NESHAP Subpart A for General Provisions

*Fugitive emissions* means those emissions from a stationary source that could not reasonably pass through a stack, chimney, vent, or other functionally equivalent opening. Under section 112 of the Act, all fugitive emissions are to be considered in determining whether a stationary source is a major source.

*Hazardous air pollutant* means any air pollutant listed in or pursuant to section 112(b) of the Act.

*Issuance* of a part 70 permit will occur, if the State is the permitting authority, in accordance with the requirements of part 70 of this chapter and the applicable, approved State permit program. When the EPA is the permitting authority, issuance of a title V permit occurs immediately after the EPA takes final action on the final permit.

*Major source* means any stationary source or group of stationary sources located within a contiguous area and under common control that emits or has the potential to emit considering controls, in the aggregate, 10 tons per year or more of any hazardous air pollutant or 25 tons per year or more of any combination of hazardous air pollutants, unless the Administrator establishes a lesser quantity, or in the case of radionuclides, different criteria from those specified in this sentence.

*Malfunction* means any sudden, infrequent, and not reasonably preventable failure of air pollution control and monitoring equipment, process equipment, or a process to operate in a normal or usual manner which causes, or has the potential to cause, the emission limitations in an applicable standard to be exceeded. Failures that are caused in part by poor maintenance or careless operation are not malfunctions.

*Monitoring* means the collection and use of measurement data or other information to control the operation of a process or pollution control device or to verify a work practice standard relative to assuring compliance with applicable requirements. Monitoring is composed of four elements:

- (1) Indicator(s) of performance -- the parameter or parameters you measure or observe for demonstrating proper operation of the pollution control measures or compliance with the applicable emissions limitation or standard. Indicators of performance may include direct or predicted emissions measurements (including opacity), operational parametric values that correspond to process or control device (and capture system) efficiencies or emissions rates, and recorded findings of inspection of work practice activities, materials tracking, or design characteristics. Indicators may be expressed as a single maximum or minimum value, a function of process variables (for example, within a range of pressure drops), a particular operational or work practice status (for example, a damper position, completion of a waste recovery task, materials tracking), or an interdependency between two or among more than two variables.
- (2) Measurement techniques -- the means by which you gather and record information of or about the indicators of performance. The components of the measurement technique include the detector type, location and installation specifications, inspection procedures, and quality assurance and quality control measures. Examples of measurement techniques include continuous emission monitoring systems, continuous opacity monitoring systems, continuous parametric monitoring systems, and manual inspections that include making records of process conditions or work practices.
- (3) Monitoring frequency -- the number of times you obtain and record monitoring data over a specified time interval. Examples of monitoring frequencies include at least four points equally spaced for each hour for continuous emissions or parametric monitoring systems, at least every 10 seconds for continuous opacity monitoring systems, and at least once per operating day (or week, month, etc.) for work practice or design inspections.
- (4) Averaging time -- the period over which you average and use data to verify proper operation of the pollution control approach or compliance with the emissions limitation or standard. Examples of averaging time include a 3-hour average in units of the emissions limitation, a 30-day rolling average emissions value, a daily average of a control device operational parametric range, and an instantaneous alarm.

*New affected source* means the collection of equipment, activities, or both within a single contiguous area and under common control that is included in a section 112(c) source category or subcategory that is subject to a section 112(d) or other relevant standard for new sources. This definition of "new affected source," and the criteria to be utilized in implementing it, shall apply to each section 112(d) standard for which the initial proposed rule is signed by the Administrator after June 30, 2002. Each relevant standard will define the term "new affected source," which will be the same as the "affected source" unless a different collection is warranted based on consideration of factors including:

- (1) Emission reduction impacts of controlling individual sources versus groups of sources;
- (2) Cost effectiveness of controlling individual equipment;
- (3) Flexibility to accommodate common control strategies;
- (4) Cost/benefits of emissions averaging;
- (5) Incentives for pollution prevention;
- (6) Feasibility and cost of controlling processes that share common equipment (e.g., product recovery devices);
- (7) Feasibility and cost of monitoring; and
- (8) Other relevant factors.

*New source* means any affected source the construction or reconstruction of which is commenced after the Administrator first proposes a relevant emission standard under this part establishing an emission standard applicable to such source.



## NESHAP Subpart A for General Provisions

*Opacity* means the degree to which emissions reduce the transmission of light and obscure the view of an object in the background. For continuous opacity monitoring systems, opacity means the fraction of incident light that is attenuated by an optical medium.

*Owner or operator* means any person who owns, leases, operates, controls, or supervises a stationary source..

*Performance audit* means a procedure to analyze blind samples, the content of which is known by the Administrator, simultaneously with the analysis of performance test samples in order to provide a measure of test data quality.

*Performance evaluation* means the conduct of relative accuracy testing, calibration error testing, and other measurements used in validating the continuous monitoring system data.

*Performance test* means the collection of data resulting from the execution of a test method (usually three emission test runs) used to demonstrate compliance with a relevant emission standard as specified in the performance test section of the relevant standard.

*Permit modification* means a change to a title V permit as defined in regulations codified in this chapter to implement title V of the Act (42 U.S.C. 7661).

*Permit program* means a comprehensive State operating permit system established pursuant to title V of the Act (42 U.S.C. 7661) and regulations codified in part 70 of this chapter and applicable State regulations, or a comprehensive Federal operating permit system established pursuant to title V of the Act and regulations codified in this chapter.

*Permit revision* means any permit modification or administrative permit amendment to a title V permit as defined in regulations codified in this chapter to implement title V of the Act (42 U.S.C. 7661).

*Permitting authority* means:

(1) The State air pollution control agency, local agency, other State agency, or other agency authorized by the Administrator to carry out a permit program under part 70 of this chapter; or

(2) The Administrator, in the case of EPA-implemented permit programs under title V of the Act (42 U.S.C. 7661).

*Potential to emit* means the maximum capacity of a stationary source to emit a pollutant under its physical and operational design. Any physical or operational limitation on the capacity of the stationary source to emit a pollutant, including air pollution control equipment and restrictions on hours of operation or on the type or amount of material combusted, stored, or processed, shall be treated as part of its design if the limitation or the effect it would have on emissions is federally enforceable.

*Reconstruction* means the replacement of components of an affected or a previously unaffected stationary source to such an extent that:

(1) The fixed capital cost of the new components exceeds 50 percent of the fixed capital cost that would be required to construct a comparable new source; and

(2) It is technologically and economically feasible for the reconstructed source to meet the relevant standard(s) established by the Administrator (or a State) pursuant to section 112 of the Act. Upon reconstruction, an affected source, or a stationary source that becomes an affected source, is subject to relevant standards for new sources, including compliance dates, irrespective of any change in emissions of hazardous air pollutants from that source.

*Regulation promulgation schedule* means the schedule for the promulgation of emission standards under this part, established by the Administrator pursuant to section 112(e) of the Act and published in the FEDERAL REGISTER.

*Relevant standard* means:

(1) An emission standard;

(2) An alternative emission standard;

(3) An alternative emission limitation; or

(4) An equivalent emission limitation established pursuant to section 112 of the Act that applies to the collection of equipment, activities, or both regulated by such standard or limitation. A relevant standard may include or consist of a design, equipment, work practice, or operational requirement, or other measure, process, method, system, or technique (including prohibition of emissions) that the Administrator (or a State) establishes for new or existing sources to which such standard or limitation applies. Every relevant standard established pursuant to section 112 of the Act includes subpart A of this part, as provided by § 63.1(a)(4), and all applicable appendices of this part or of other parts of this chapter that are referenced in that standard.

*Responsible official* means one of the following:

(1) For a corporation: A president, secretary, treasurer, or vice president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision-making functions for the corporation, or a duly authorized representative of such person if the representative is responsible for the overall operation of one or more manufacturing, production, or operating facilities and either:

(i) The facilities employ more than 250 persons or have gross annual sales or expenditures exceeding \$25 million (in second quarter 1980 dollars); or

(ii) The delegation of authority to such representative is approved in advance by the Administrator.

(2) For a partnership or sole proprietorship: a general partner or the proprietor, respectively.

(3) For a municipality, State, Federal, or other public agency: either a principal executive officer or ranking elected official. For the purposes of this part, a principal executive officer of a Federal agency includes the chief executive officer having responsibility for the overall operations of a principal geographic unit of the agency (e.g., a Regional Administrator of the EPA).

(4) For affected sources (as defined in this part) applying for or subject to a title V permit: "responsible official" shall have the same meaning as defined in part 70 or Federal title V regulations in this chapter (42 U.S.C. 7661), whichever is applicable.

*Run* means one of a series of emission or other measurements needed to determine emissions for a representative operating period or cycle as specified in this part.

*Shutdown* means the cessation of operation of an affected source or portion of an affected source for any purpose.

*Six-minute period* means, with respect to opacity determinations, any one of the 10 equal parts of a 1-hour period.

*Standard conditions* means a temperature of 293 °K (68° F) and a pressure of 101.3 kilopascals (29.92 in. Hg).

*Startup* means the setting in operation of an affected source for any purpose.

*State* means all non-Federal authorities, including local agencies, interstate associations, and State-wide programs, that have delegated authority to implement:

(1) The provisions of this part and/or

(2) the permit program established under part 70 of this chapter. The term State shall have its conventional meaning where clear from the context.

*Stationary source* means any building, structure, facility, or installation which emits or may emit any air pollutant.

*Test method* means the validated procedure for sampling, preparing, and analyzing for an air pollutant specified in a relevant standard as the performance test procedure. The test method may include methods described in an appendix of this chapter, test methods incorporated by reference in this part, or methods validated for an application through procedures in Method 301 of appendix A of this part.

*Title V permit* means any permit issued, renewed, or revised pursuant to Federal or State regulations established to implement title V of the Act (42 U.S.C. 7661). A title V permit issued by a State permitting authority is called a part 70 permit in this part.

*Visible emission* means the observation of an emission of opacity or optical density above the threshold of vision.

*Working day* means any day on which Federal Government offices (or State government offices for a State that has obtained delegation under section 112(l)) are open for normal business. Saturdays, Sundays, and official Federal (or where delegated, State) holidays are not working days.

### § 63.3 Units and abbreviations.

Used in this part are abbreviations and symbols of units of measure. These are defined as follows:

(a) System International (SI) units of measure:

A = ampere

g = gram

Hz = hertz

J = joule

°K = degree Kelvin

kg = kilogram

l = liter

m = meter

m<sup>3</sup> = cubic meter

mg = milligram = 10<sup>-3</sup> gram

ml = milliliter = 10<sup>-3</sup> liter

mm = millimeter = 10<sup>-3</sup> meter

Mg = megagram = 10<sup>6</sup> gram = metric ton

MJ = megajoule

mol = mole

N = newton

ng = nanogram = 10<sup>-9</sup> gram

nm = nanometer = 10<sup>-9</sup> meter

Pa = pascal

s = second

V = volt

W = watt

Ω = ohm

μg = microgram = 10<sup>-6</sup> gram

μl = microliter = 10<sup>-6</sup> liter

(b) Other units of measure:

Btu = British thermal unit

°C = degree Celsius (centigrade)

cal = calorie

cfm = cubic feet per minute

cc = cubic centimeter

cu ft = cubic feet

d = day

dcf = dry cubic feet

dcm = dry cubic meter

dscf = dry cubic feet at standard conditions

dscm = dry cubic meter at standard conditions

eq = equivalent

°F = degree Fahrenheit  
 ft = feet  
 ft<sup>2</sup> = square feet  
 ft<sup>3</sup> = cubic feet  
 gal = gallon  
 gr = grain  
 g-eq = gram equivalent  
 g-mole = gram mole  
 hr = hour  
 in. = inch  
 in. H<sub>2</sub>O = inches of water  
 K = 1,000  
 kcal = kilocalorie  
 lb = pound  
 lpm = liter per minute  
 meq = milliequivalent  
 min = minute  
 MW = molecular weight  
 oz = ounces

ppb = parts per billion  
 ppbw = parts per billion by weight  
 ppbv = parts per billion by volume  
 ppm = parts per million  
 ppmw = parts per million by weight  
 ppmv = parts per million by volume  
 psia = pounds per square inch absolute  
 psig = pounds per square inch gage  
 °R = degree Rankine  
 scf = cubic feet at standard conditions  
 scfh = cubic feet at standard conditions per hour  
 scm = cubic meter at standard conditions  
 scmm = cubic meter at standard conditions per min.  
 sec = second  
 sq ft = square feet  
 std = at standard conditions  
 v/v = volume per volume  
 yd<sup>2</sup> = square yards  
 yr = year

## (c) Miscellaneous:

act = actual  
 avg = average  
 I.D. = inside diameter  
 M = molar  
 N = normal  
 O.D. = outside diameter  
 % = percent

**§ 63.4 Prohibited activities and circumvention.**(a) *Prohibited activities.*

(1) No owner or operator subject to the provisions of this part must operate any affected source in violation of the requirements of this part. Affected sources subject to and in compliance with either an extension of compliance or an exemption from compliance are not in violation of the requirements of this part. An extension of compliance can be granted by the Administrator under this part; by a State with an approved permit program; or by the President under section 112(i)(4) of the Act.

(2) No owner or operator subject to the provisions of this part shall fail to keep records, notify, report, or revise reports as required under this part.

- (3) [Reserved]  
 (4) [Reserved]  
 (5) [Reserved]

(b) *Circumvention.* No owner or operator subject to the provisions of this part shall build, erect, install, or use any article, machine, equipment, or process to conceal an emission that would otherwise constitute noncompliance with a relevant standard. Such concealment includes, but is not limited to

- (1) The use of diluents to achieve compliance with a relevant standard based on the concentration of a pollutant in the effluent discharged to the atmosphere;  
 (2) The use of gaseous diluents to achieve compliance with a relevant standard for visible emissions; and  
 (3) [Reserved]

(c) *Severability.* Notwithstanding any requirement incorporated into a title V permit obtained by an owner or operator subject to the provisions of this part, the provisions of this part are federally enforceable.

**§ 63.5 Preconstruction review and notification requirements.**(a) *Applicability.*

## NESHAP Subpart A for General Provisions

(1) This section implements the preconstruction review requirements of section 112(i)(1) for sources subject to a relevant emission standard that has been promulgated in this part. In addition, this section includes other requirements for constructed and reconstructed stationary sources that are or become subject to a relevant promulgated emission standard.

(2) After the effective date of a relevant standard promulgated under this part, the requirements in this section apply to owners or operators who construct a new source or reconstruct a source after the proposal date of that standard. New or reconstructed sources that start up before the standard's effective date are not subject to the preconstruction review requirements specified in paragraphs (b)(3), (d), and (e) of this section.

(b) *Requirements for existing, newly constructed, and reconstructed sources.*

(1) A new affected source for which construction commences after proposal of a relevant standard is subject to relevant standards for new affected sources, including compliance dates. An affected source for which reconstruction commences after proposal of a relevant standard is subject to relevant standards for new sources, including compliance dates, irrespective of any change in emissions of hazardous air pollutants from that source.

(2) [Reserved]

(3) After the effective date of any relevant standard promulgated by the Administrator under this part, no person may, without obtaining written approval in advance from the Administrator in accordance with the procedures specified in paragraphs (d) and (e) of this section, do any of the following:

(i) Construct a new affected source that is major-emitting and subject to such standard;

(ii) Reconstruct an affected source that is major-emitting and subject to such standard; or

(iii) Reconstruct a major source such that the source becomes an affected source that is major-emitting and subject to the standard.

(4) After the effective date of any relevant standard promulgated by the Administrator under this part, an owner or operator who constructs a new affected source that is not major-emitting or reconstructs an affected source that is not major-emitting that is subject to such standard, or reconstructs a source such that the source becomes an affected source subject to the standard, must notify the Administrator of the intended construction or reconstruction. The notification must be submitted in accordance with the procedures in § 63.9(b).

(5) [Reserved]

(6) After the effective date of any relevant standard promulgated by the Administrator under this part, equipment added (or a process change) to an affected source that is within the scope of the definition of affected source under the relevant standard must be considered part of the affected source and subject to all provisions of the relevant standard established for that affected source.

(c) [Reserved]

(d) *Application for approval of construction or reconstruction.* The provisions of this paragraph implement section 112(i)(1) of the Act.

(1) *General application requirements.*

(i) An owner or operator who is subject to the requirements of paragraph (b)(3) of this section must submit to the Administrator an application for approval of the construction or reconstruction. The application must be submitted as soon as practicable before actual construction or reconstruction begins. The application for approval of construction or reconstruction may be used to fulfill the initial notification requirements of § 63.9(b)(5). The owner or operator may submit the application for approval well in advance of the date actual construction or reconstruction begins in order to ensure a timely review by the Administrator and that the planned date to begin will not be delayed.

(ii) A separate application shall be submitted for each construction or reconstruction. Each application for approval of construction or reconstruction shall include at a minimum:

(A) The applicant's name and address;

(B) A notification of intention to construct a new major affected source or make any physical or operational change to a major affected source that may meet or has been determined to meet the criteria for a reconstruction, as defined in § 63.2 or in the relevant standard;

(C) The address (i.e., physical location) or proposed address of the source;

(D) An identification of the relevant standard that is the basis of the application;

(E) The expected date of the beginning of actual construction or reconstruction;

(F) The expected completion date of the construction or reconstruction;

## NESHAP Subpart A for General Provisions

(G) [Reserved]

(H) The type and quantity of hazardous air pollutants emitted by the source, reported in units and averaging times and in accordance with the test methods specified in the relevant standard, or if actual emissions data are not yet available, an estimate of the type and quantity of hazardous air pollutants expected to be emitted by the source reported in units and averaging times specified in the relevant standard. The owner or operator may submit percent reduction information if a relevant standard is established in terms of percent reduction.

However, operating parameters, such as flow rate, shall be included in the submission to the extent that they demonstrate performance and compliance; and

(I) [Reserved]

(J) Other information as specified in paragraphs (d)(2) and (d)(3) of this section.

(iii) An owner or operator who submits estimates or preliminary information in place of the actual emissions data and analysis required in paragraphs (d)(1)(ii)(H) and (d)(2) of this section shall submit the actual, measured emissions data and other correct information as soon as available but no later than with the notification of compliance status required in § 63.9(h) (see § 63.9(h)(5)).

(2) *Application for approval of construction.* Each application for approval of construction must include, in addition to the information required in paragraph (d)(1)(ii) of this section, technical information describing the proposed nature, size, design, operating design capacity, and method of operation of the source, including an identification of each type of emission point for each type of hazardous air pollutant that is emitted (or could reasonably be anticipated to be emitted) and a description of the planned air pollution control system (equipment or method) for each emission point. The description of the equipment to be used for the control of emissions must include each control device for each hazardous air pollutant and the estimated control efficiency (percent) for each control device. The description of the method to be used for the control of emissions must include an estimated control efficiency (percent) for that method. Such technical information must include calculations of emission estimates in sufficient detail to permit assessment of the validity of the calculations.

(3) *Application for approval of reconstruction.* Each application for approval of reconstruction shall include, in addition to the information required in paragraph (d)(1)(ii) of this section - (i) A brief description of the affected source and the components that are to be replaced;

(ii) A description of present and proposed emission control systems (i.e., equipment or methods). The description of the equipment to be used for the control of emissions shall include each control device for each hazardous air pollutant and the estimated control efficiency (percent) for each control device. The description of the method to be used for the control of emissions shall include an estimated control efficiency (percent) for that method. Such technical information shall include calculations of emission estimates in sufficient detail to permit assessment of the validity of the calculations;

(iii) An estimate of the fixed capital cost of the replacements and of constructing a comparable entirely new source;

(iv) The estimated life of the affected source after the replacements; and

(v) A discussion of any economic or technical limitations the source may have in complying with relevant standards or other requirements after the proposed replacements. The discussion shall be sufficiently detailed to demonstrate to the Administrator's satisfaction that the technical or economic limitations affect the source's ability to comply with the relevant standard and how they do so.

(vi) If in the application for approval of reconstruction the owner or operator designates the affected source as a reconstructed source and declares that there are no economic or technical limitations to prevent the source from complying with all relevant standards or other requirements, the owner or operator need not submit the information required in paragraphs (d)(3)(iii) through (d)(3)(v) of this section.

(4) *Additional information.* The Administrator may request additional relevant information after the submittal of an application for approval of construction or reconstruction.

(e) *Approval of construction or reconstruction.*

(1) (i) If the Administrator determines that, if properly constructed, or reconstructed, and operated, a new or existing source for which an application under paragraph (d) of this section was submitted will not cause emissions in violation of the relevant standard(s) and any other federally enforceable requirements, the Administrator will approve the construction or reconstruction.

(ii) In addition, in the case of reconstruction, the Administrator's determination under this paragraph will be based on:

(A) The fixed capital cost of the replacements in comparison to the fixed capital cost that would be required to construct a comparable entirely new source;

(B) The estimated life of the source after the re-placements compared to the life of a comparable entirely new source;

(C) The extent to which the components being replaced cause or contribute to the emissions from the source; and

(D) Any economic or technical limitations on compliance with relevant standards that are inherent in the proposed replacements.

(2) (i) The Administrator will notify the owner or operator in writing of approval or intention to deny approval of construction or reconstruction within 60 calendar days after receipt of sufficient information to evaluate an application submitted under paragraph (d) of this section. The 60-day approval or denial period will begin after the owner or operator has been notified in writing that his/her application is complete. The Administrator will notify the owner or operator in writing of the status of his/her application, that is, whether the application contains sufficient information to make a determination, within 30 calendar days after receipt of the original application and within 30 calendar days after receipt of any supplementary information that is submitted.

(ii) When notifying the owner or operator that his/her application is not complete, the Administrator will specify the information needed to complete the application and provide notice of opportunity for the applicant to present, in writing, within 30 calendar days after he/she is notified of the incomplete application, additional information or arguments to the Administrator to enable further action on the application.

(3) Before denying any application for approval of construction or reconstruction, the Administrator will notify the applicant of the Administrator's intention to issue the denial together with - (i) Notice of the information and findings on which the intended denial is based; and

(ii) Notice of opportunity for the applicant to present, in writing, within 30 calendar days after he/she is notified of the intended denial, additional information or arguments to the Administrator to enable further action on the application.

(4) A final determination to deny any application for approval will be in writing and will specify the grounds on which the denial is based. The final determination will be made within 60 calendar days of presentation of additional information or arguments (if the application is complete), or within 60 calendar days after the final date specified for presentation if no presentation is made.

(5) Neither the submission of an application for approval nor the Administrator's approval of construction or reconstruction shall -

(i) Relieve an owner or operator of legal responsibility for compliance with any applicable provisions of this part or with any other applicable Federal, State, or local requirement; or (ii) Prevent the Administrator from implementing or enforcing this part or taking any other action under the Act.

(f) *Approval of construction or reconstruction based on prior State preconstruction review.*

(1) Preconstruction review procedures that a State utilizes for other purposes may also be utilized for purposes of this section if the procedures are substantially equivalent to those specified in this section. The Administrator will approve an application for construction or reconstruction specified in paragraphs (b)(3) and (d) of this section if the owner or operator of a new affected source or reconstructed affected source, who is subject to such requirement meets the following conditions:

(i) The owner or operator of the new affected source or reconstructed affected source has undergone a preconstruction review and approval process in the State in which the source is (or would be) located and has received a federally enforceable construction permit that contains a finding that the source will meet the relevant promulgated emission standard, if the source is properly built and operated.

(ii) Provide a statement from the State or other evidence (such as State regulations) that it considered the factors specified in paragraph (e)(1) of this section.

(2) The owner or operator must submit to the Administrator the request for approval of construction or reconstruction under this paragraph (f)(2) no later than the application deadline specified in paragraph (d)(1) of this section (see also § 63.9(b)(2)). The owner or operator must include in the request information sufficient for the Administrator's determination. The Administrator will evaluate the owner or operator's request in accordance with the procedures specified in paragraph (e) of this section. The Administrator may request additional relevant information after the submittal of a request for approval of construction or reconstruction under this paragraph (f)(2).

### § 63.6 Compliance with standards and maintenance requirements.

(a) *Applicability.*

(1) The requirements in this section apply to the owner or operator of affected sources for which any relevant standard has been established pursuant to section 112 of the Act and the applicability of such requirements is set out in accordance with § 63.1(a)(4) unless --

(i) The Administrator (or a State with an approved permit program) has granted an extension of compliance consistent with paragraph (i) of this section; or

## NESHAP Subpart A for General Provisions

(ii) The President has granted an exemption from compliance with any relevant standard in accordance with section 112(i)(4) of the Act.

(2) If an area source that otherwise would be subject to an emission standard or other requirement established under this part if it were a major source subsequently increases its emissions of hazardous air pollutants (or its potential to emit hazardous air pollutants) such that the source is a major source, such source shall be subject to the relevant emission standard or other requirement.

*(b) Compliance dates for new and reconstructed sources.*

(1) Except as specified in paragraphs (b)(3) and (4) of this section, the owner or operator of a new or reconstructed affected source for which construction or reconstruction commences after proposal of a relevant standard that has an initial startup before the effective date of a relevant standard established under this part pursuant to section 112(d), (f), or (h) of the Act must comply with such standard not later than the standard's effective date.

(2) Except as specified in paragraphs (b)(3) and (4) of this section, the owner or operator of a new or reconstructed affected source that has an initial startup after the effective date of a relevant standard established under this part pursuant to section 112(d), (f), or (h) of the Act must comply with such standard upon startup of the source.

(3) The owner or operator of an affected source for which construction or reconstruction is commenced after the proposal date of a relevant standard established under this part pursuant to section 112(d), 112(f), or 112(h) of the Act but before the effective date (that is, promulgation) of such standard shall comply with the relevant emission standard not later than the date 3 years after the effective date if:

(i) The promulgated standard (that is, the relevant standard) is more stringent than the proposed standard; for purposes of this paragraph, a finding that controls or compliance methods are "more stringent" must include control technologies or performance criteria and compliance or compliance assurance methods that are different but are substantially equivalent to those required by the promulgated rule, as determined by the Administrator (or his or her authorized representative); and

(ii) The owner or operator complies with the standard as proposed during the 3-year period immediately after the effective date.

(4) The owner or operator of an affected source for which construction or reconstruction is commenced after the proposal date of a relevant standard established pursuant to section 112(d) of the Act but before the proposal date of a relevant standard established pursuant to section 112(f) shall not be required to comply with the section 112(f) emission standard until the date 10 years after the date construction or reconstruction is commenced, except that, if the section 112(f) standard is promulgated more than 10 years after construction or reconstruction is commenced, the owner or operator must comply with the standard as provided in paragraphs (b)(1) and (2) of this section.

(5) The owner or operator of a new source that is subject to the compliance requirements of paragraph (b)(3) or (4) of this section must notify the Administrator in accordance with § 63.9(d).

(6) [Reserved]

(7) When an area source becomes a major source by the addition of equipment or operations that meet the definition of new affected source in the relevant standard, the portion of the existing facility that is a new affected source must comply with all requirements of that standard applicable to new sources. The source owner or operator must comply with the relevant standard upon startup.

*(c) Compliance dates for existing sources.*

(1) After the effective date of a relevant standard established under this part pursuant to section 112(d) or 112(h) of the Act, the owner or operator of an existing source shall comply with such standard by the compliance date established by the Administrator in the applicable subpart(s) of this part. Except as otherwise provided for in section 112 of the Act, in no case will the compliance date established for an existing source in an applicable subpart of this part exceed 3 years after the effective date of such standard.

(2) If an existing source is subject to a standard established under this part pursuant to section 112(f) of the Act, the owner or operator must comply with the standard by the date 90 days after the standard's effective date, or by the date specified in an extension granted to the source by the Administrator under paragraph (i)(4)(ii) of this section, whichever is later.

(3)–(4) [Reserved]

(5) Except as provided in paragraph (b)(7) of this section, the owner or operator of an area source that increases its emissions of (or its potential to emit) hazardous air pollutants such that the source becomes a major source shall be subject to relevant standards for existing sources. Such sources must comply by the date specified in the standards for existing area sources that become major sources. If no such compliance date is specified in the standards, the source shall have a period of time to comply with the relevant emission standard that is equivalent to the compliance period specified in the relevant standard for existing sources in existence at the time the standard becomes effective.

(d) [Reserved]

(e) *Operation and maintenance requirements.*

(1) (i) At all times, including periods of startup, shutdown, and malfunction, the owner or operator must operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. During a period of startup, shutdown, or malfunction, this general duty to minimize emissions requires that the owner or operator reduce emissions from the affected source to the greatest extent which is consistent with safety and good air pollution control practices. The general duty to minimize emissions during a period of startup, shutdown, or malfunction does not require the owner or operator to achieve emission levels that would be required by the applicable standard at other times if this is not consistent with safety and good air pollution control practices, nor does it require the owner or operator to make any further efforts to reduce emissions if levels required by the applicable standard have been achieved. Determination of whether such operation and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, review of operation and maintenance procedures (including the startup, shutdown, and malfunction plan required in paragraph (e)(3) of this section), review of operation and maintenance records, and inspection of the source.

(ii) Malfunctions must be corrected as soon as practicable after their occurrence in accordance with the startup, shutdown, and malfunction plan required in paragraph (e)(3) of this section. To the extent that an unexpected event arises during a startup, shutdown, or malfunction, an owner or operator must comply by minimizing emissions during such a startup, shutdown, and malfunction event consistent with safety and good air pollution control practices.

(iii) Operation and maintenance requirements established pursuant to section 112 of the Act are enforceable independent of emissions limitations or other requirements in relevant standards.

(2) [Reserved]

(3) Startup, shutdown, and malfunction plan.

(i) The owner or operator of an affected source must develop and implement a written startup, shutdown, and malfunction plan that describes, in detail, procedures for operating and maintaining the source during periods of startup, shutdown, and malfunction, and a program of corrective action for malfunctioning process and air pollution control and monitoring equipment used to comply with the relevant standard.

(A) Ensure that, at all times, the owner or operator operates and maintains each affected source, including associated air pollution control and monitoring equipment, in a manner which satisfies the general duty to minimize emissions established by paragraph (e)(1)(i) of this section;

(B) Ensure that owners or operators are prepared to correct malfunctions as soon as practicable after their occurrence in order to minimize excess emissions of hazardous air pollutants; and

(C) Reduce the reporting burden associated with periods of startup, shutdown, and malfunction (including corrective action taken to restore malfunctioning process and air pollution control equipment to its normal or usual manner of operation).

(ii) During periods of startup, shutdown, and malfunction, the owner or operator of an affected source must operate and maintain such source (including associated air pollution control and monitoring equipment) in accordance with the procedures specified in the startup, shutdown, and malfunction plan developed under paragraph (e)(3)(i) of this section.

(iii) When actions taken by the owner or operator during a startup, shutdown, or malfunction (including actions taken to correct a malfunction) are consistent with the procedures specified in the affected source's startup, shutdown, and malfunction plan, the owner or operator must keep records for that event which demonstrate that the procedures specified in the plan were followed. These records may take the form of a "checklist," or other effective form of recordkeeping that confirms conformance with the startup, shutdown, and malfunction plan for that event. In addition, the owner or operator must keep records of these events as specified in § 63.10(b), including records of the occurrence and duration of each startup, shutdown, or malfunction of operation and each malfunction of the air pollution control and monitoring equipment. Furthermore, the owner or operator shall confirm that actions taken during the relevant reporting period during periods of startup, shutdown, and malfunction were consistent with the affected source's startup, shutdown and malfunction plan in the semiannual (or more frequent) startup, shutdown, and malfunction report required in § 63.10(d)(5).

(iv) If an action taken by the owner or operator during a startup, shutdown, or malfunction (including an action taken to correct a malfunction) is not consistent with the procedures specified in the affected source's startup, shutdown, and malfunction plan, and the source exceeds any applicable emission limitation in the relevant emission standard, then the owner or operator must record the actions taken for that event and must report such actions within 2 working days after commencing actions inconsistent with the plan, followed by a letter within 7 working days after the end of the event, in



accordance with Sec. 63.10(d)(5) (unless the owner or operator makes alternative reporting arrangements, in advance, with the Administrator).

(v) The owner or operator must maintain at the affected source a current startup, shutdown, and malfunction plan and must make the plan available upon request for inspection and copying by the Administrator. In addition, if the startup, shutdown, and malfunction plan is subsequently revised as provided in paragraph (e)(3)(viii) of this section, the owner or operator must maintain at the affected source each previous (i.e., superseded) version of the startup, shutdown, and malfunction plan, and must make each such previous version available for inspection and copying by the Administrator for a period of 5 years after revision of the plan. If at any time after adoption of a startup, shutdown, and malfunction plan the affected source ceases operation or is otherwise no longer subject to the provisions of this part, the owner or operator must retain a copy of the most recent plan for 5 years from the date the source ceases operation or is no longer subject to this part and must make the plan available upon request for inspection and copying by the Administrator. The Administrator may at any time request in writing that the owner or operator submit a copy of any startup, shutdown, and malfunction plan (or a portion thereof) which is maintained at the affected source or in the possession of the owner or operator. Upon receipt of such a request, the owner or operator must promptly submit a copy of the requested plan (or a portion thereof) to the Administrator. The Administrator must request that the owner or operator submit a particular startup, shutdown, or malfunction plan (or a portion thereof) whenever a member of the public submits a specific and reasonable request to examine or to receive a copy of that plan or portion of a plan. The owner or operator may elect to submit the required copy of any startup, shutdown, and malfunction plan to the Administrator in an electronic format. If the owner or operator claims that any portion of such a startup, shutdown, and malfunction plan is confidential business information entitled to protection from disclosure under section 114(c) of the Act or 40 CFR 2.301, the material which is claimed as confidential must be clearly designated in the submission.

(vi) To satisfy the requirements of this section to develop a startup, shutdown, and malfunction plan, the owner or operator may use the affected source's standard operating procedures (SOP) manual, or an Occupational Safety and Health Administration (OSHA) or other plan, provided the alternative plans meet all the requirements of this section and are made available for inspection or submitted when requested by the Administrator.

(vii) Based on the results of a determination made under paragraph (e)(1)(i) of this section, the Administrator may require that an owner or operator of an affected source make changes to the startup, shutdown, and malfunction plan for that source. The Administrator must require appropriate revisions to a startup, shutdown, and malfunction plan, if the Administrator finds that the plan:

(A) Does not address a startup, shutdown, or malfunction event that has occurred;

(B) Fails to provide for the operation of the source (including associated air pollution control and monitoring equipment) during a startup, shutdown, or malfunction event in a manner consistent with the general duty to minimize emissions established by paragraph (e)(1)(i) of this section;

(C) Does not provide adequate procedures for correcting malfunctioning process and/or air pollution control and monitoring equipment as quickly as practicable; or

(D) Includes an event that does not meet the definition of startup, shutdown, or malfunction listed in § 63.2.

(viii) The owner or operator may periodically revise the startup, shutdown, and malfunction plan for the affected source as necessary to satisfy the requirements of this part or to reflect changes in equipment or procedures at the affected source. Unless the permitting authority provides otherwise, the owner or operator may make such revisions to the startup, shutdown, and malfunction plan without prior approval by the Administrator or the permitting authority. However, each such revision to a startup, shutdown, and malfunction plan must be reported in the semiannual report required by § 63.10(d)(5). If the startup, shutdown, and malfunction plan fails to address or inadequately addresses an event that meets the characteristics of a malfunction but was not included in the startup, shutdown, and malfunction plan at the time the owner or operator developed the plan, the owner or operator must revise the startup, shutdown, and malfunction plan within 45 days after the event to include detailed procedures for operating and maintaining the source during similar malfunction events and a program of corrective action for similar malfunctions of process or air pollution control and monitoring equipment. In the event that the owner or operator makes any revision to the startup, shutdown, and malfunction plan which alters the scope of the activities at the source which are deemed to be a startup, shutdown, or malfunction, or otherwise modifies the applicability of any emission limit, work practice requirement, or other requirement in a standard established under this part, the revised plan shall not take effect until after the owner or operator has provided a written notice describing the revision to the permitting authority.

(ix) The title V permit for an affected source must require that the owner or operator adopt a startup, shutdown, and malfunction plan which conforms to the provisions of this part, and that the owner or operator operate and maintain the source in accordance with the procedures specified in the current startup, shutdown, and malfunction plan. However, any revisions made to the startup, shutdown, and malfunction plan in accordance with the procedures established by this part shall not be deemed to constitute permit revisions under part 70 or part 71 of this chapter. Moreover, none of the procedures

## NESHAP Subpart A for General Provisions

specified by the startup, shutdown, and malfunction plan for an affected source shall be deemed to fall within the permit shield provision in section 504(f) of the Act.

(f) *Compliance with nonopacity emission standards -*

(1) *Applicability.* The non-opacity emission standards set forth in this part shall apply at all times except during periods of startup, shutdown, and malfunction, and as otherwise specified in an applicable subpart. If a startup, shutdown, or malfunction of one portion of an affected source does not affect the ability of particular emission points within other portions of the affected source to comply with the non-opacity emission standards set forth in this part, then that emission point must still be required to comply with the non-opacity emission standards and other applicable requirements.

(2) *Methods for determining compliance.*

(i) The Administrator will determine compliance with nonopacity emission standards in this part based on the results of performance tests conducted according to the procedures in § 63.7, unless otherwise specified in an applicable subpart of this part.

(ii) The Administrator will determine compliance with nonopacity emission standards in this part by evaluation of an owner or operator's conformance with operation and maintenance requirements, including the evaluation of monitoring data, as specified in § 63.6(e) and applicable subparts of this part.

(iii) If an affected source conducts performance testing at startup to obtain an operating permit in the State in which the source is located, the results of such testing may be used to demonstrate compliance with a relevant standard if -

(A) The performance test was conducted within a reasonable amount of time before an initial performance test is required to be conducted under the relevant standard;

(B) The performance test was conducted under representative operating conditions for the source;

(C) The performance test was conducted and the resulting data were reduced using EPA-approved test methods and procedures, as specified in § 63.7(e) of this subpart; and

(D) The performance test was appropriately quality-assured, as specified in § 63.7(c).

(iv) The Administrator will determine compliance with design, equipment, work practice, or operational emission standards in this part by review of records, inspection of the source, and other procedures specified in applicable subparts of this part.

(v) The Administrator will determine compliance with design, equipment, work practice, or operational emission standards in this part by evaluation of an owner or operator's conformance with operation and maintenance requirements, as specified in paragraph (e) of this section and applicable subparts of this part.

(3) *Finding of compliance.* The Administrator will make a finding concerning an affected source's compliance with a non-opacity emission standard, as specified in paragraphs (f)(1) and (2) of this section, upon obtaining all the compliance information required by the relevant standard (including the written reports of performance test results, monitoring results, and other information, if applicable), and information available to the Administrator pursuant to paragraph (e)(1)(i) of this section.

(g) *Use of an alternative nonopacity emission standard.*

(1) If, in the Administrator's judgment, an owner or operator of an affected source has established that an alternative means of emission limitation will achieve a reduction in emissions of a hazardous air pollutant from an affected source at least equivalent to the reduction in emissions of that pollutant from that source achieved under any design, equipment, work practice, or operational emission standard, or combination thereof, established under this part pursuant to section 112(h) of the Act, the Administrator will publish in the FEDERAL REGISTER a notice permitting the use of the alternative emission standard for purposes of compliance with the promulgated standard. Any FEDERAL REGISTER notice under this paragraph shall be published only after the public is notified and given the opportunity to comment. Such notice will restrict the permission to the stationary source(s) or category(ies) of sources from which the alternative emission standard will achieve equivalent emission reductions. The Administrator will condition permission in such notice on requirements to assure the proper operation and maintenance of equipment and practices required for compliance with the alternative emission standard and other requirements, including appropriate quality assurance and quality control requirements, that are deemed necessary.

(2) An owner or operator requesting permission under this paragraph shall, unless otherwise specified in an applicable subpart, submit a proposed test plan or the results of testing and monitoring in accordance with § 63.7 and § 63.8, a description of the procedures followed in testing or monitoring, and a description of pertinent conditions during testing or monitoring. Any testing or monitoring conducted to request permission to use an alternative nonopacity emission standard shall be appropriately quality assured and quality controlled, as specified in § 63.7 and § 63.8.

(3) The Administrator may establish general procedures in an applicable subpart that accomplish the requirements of paragraphs (g)(1) and (g)(2) of this section.

## NESHAP Subpart A for General Provisions

(h) *Compliance with opacity and visible emission standards -*

(1) *Applicability.* The opacity and visible emission standards set forth in this part must apply at all times except during periods of startup, shutdown, and malfunction, and as otherwise specified in an applicable subpart. If a startup, shutdown, or malfunction of one portion of an affected source does not affect the ability of particular emission points within other portions of the affected source to comply with the opacity and visible emission standards set forth in this part, then that emission point shall still be required to comply with the opacity and visible emission standards and other applicable requirements.

## (2) Methods for determining compliance.

(i) The Administrator will determine compliance with opacity and visible emission standards in this part based on the results of the test method specified in an applicable subpart. Whenever a continuous opacity monitoring system (COMS) is required to be installed to determine compliance with numerical opacity emission standards in this part, compliance with opacity emission standards in this part shall be determined by using the results from the COMS. Whenever an opacity emission test method is not specified, compliance with opacity emission standards in this part shall be determined by conducting observations in accordance with Test Method 9 in appendix A of part 60 of this chapter or the method specified in paragraph (h)(7)(ii) of this section. Whenever a visible emission test method is not specified, compliance with visible emission standards in this part shall be determined by conducting observations in accordance with Test Method 22 in appendix A of part 60 of this chapter.

## (ii) [Reserved]

(iii) If an affected source undergoes opacity or visible emission testing at startup to obtain an operating permit in the State in which the source is located, the results of such testing may be used to demonstrate compliance with a relevant standard if -

(A) The opacity or visible emission test was conducted within a reasonable amount of time before a performance test is required to be conducted under the relevant standard;

(B) The opacity or visible emission test was conducted under representative operating conditions for the source;

(C) The opacity or visible emission test was conducted and the resulting data were reduced using EPA-approved test methods and procedures, as specified in § 63.7(e); and

(D) The opacity or visible emission test was appropriately quality-assured, as specified in § 63.7(c) of this section.

## (3) [Reserved]

(4) *Notification of opacity or visible emission observations.* The owner or operator of an affected source shall notify the Administrator in writing of the anticipated date for conducting opacity or visible emission observations in accordance with § 63.9(f), if such observations are required for the source by a relevant standard.

(5) *Conduct of opacity or visible emission observations.* When a relevant standard under this part includes an opacity or visible emission standard, the owner or operator of an affected source shall comply with the following:

(i) For the purpose of demonstrating initial compliance, opacity or visible emission observations shall be conducted concurrently with the initial performance test required in § 63.7 unless one of the following conditions applies:

(A) If no performance test under § 63.7 is required, opacity or visible emission observations shall be conducted within 60 days after achieving the maximum production rate at which a new or reconstructed source will be operated, but not later than 120 days after initial startup of the source, or within 120 days after the effective date of the relevant standard in the case of new sources that start up before the standard's effective date. If no performance test under § 63.7 is required, opacity or visible emission observations shall be conducted within 120 days after the compliance date for an existing or modified source; or

(B) If visibility or other conditions prevent the opacity or visible emission observations from being conducted concurrently with the initial performance test required under § 63.7, or within the time period specified in paragraph (h)(5)(i)(A) of this section, the source's owner or operator shall reschedule the opacity or visible emission observations as soon after the initial performance test, or time period, as possible, but not later than 30 days thereafter, and shall advise the Administrator of the rescheduled date. The rescheduled opacity or visible emission observations shall be conducted (to the extent possible) under the same operating conditions that existed during the initial performance test conducted under § 63.7. The visible emissions observer shall determine whether visibility or other conditions prevent the opacity or visible emission observations from being made concurrently with the initial performance test in accordance with procedures contained in Test Method 9 or Test Method 22 in appendix A of part 60 of this chapter.

(ii) For the purpose of demonstrating initial compliance, the minimum total time of opacity observations shall be 3 hours (30 6-minute averages) for the performance test or other required set of observations (e.g., for fugitive-type emission sources subject only to an opacity emission standard).

(iii) The owner or operator of an affected source to which an opacity or visible emission standard in this part applies shall conduct opacity or visible emission observations in accordance with the provisions of this section, record the

results of the evaluation of emissions, and report to the Administrator the opacity or visible emission results in accordance with the provisions of § 63.10(d).

(iv) [Reserved]

(v) Opacity readings of portions of plumes that contain condensed, uncombined water vapor shall not be used for purposes of determining compliance with opacity emission standards.

(6) *Availability of records.* The owner or operator of an affected source shall make available, upon request by the Administrator, such records that the Administrator deems necessary to determine the conditions under which the visual observations were made and shall provide evidence indicating proof of current visible observer emission certification.

(7) *Use of a continuous opacity monitoring system.*

(i) The owner or operator of an affected source required to use a continuous opacity monitoring system (COMS) shall record the monitoring data produced during a performance test required under § 63.7 and shall furnish the Administrator a written report of the monitoring results in accordance with the provisions of § 63.10(e)(4).

(ii) Whenever an opacity emission test method has not been specified in an applicable subpart, or an owner or operator of an affected source is required to conduct Test Method 9 observations (see appendix A of part 60 of this chapter), the owner or operator may submit, for compliance purposes, COMS data results produced during any performance test required under § 63.7 in lieu of Method 9 data. If the owner or operator elects to submit COMS data for compliance with the opacity emission standard, he or she shall notify the Administrator of that decision, in writing, simultaneously with the notification under § 63.7(b) of the date the performance test is scheduled to begin. Once the owner or operator of an affected source has notified the Administrator to that effect, the COMS data results will be used to determine opacity compliance during subsequent performance tests required under § 63.7, unless the owner or operator notifies the Administrator in writing to the contrary not later than with the notification under § 63.7(b) of the date the subsequent performance test is scheduled to begin.

(iii) For the purposes of determining compliance with the opacity emission standard during a performance test required under § 63.7 using COMS data, the COMS data shall be reduced to 6-minute averages over the duration of the mass emission performance test.

(iv) The owner or operator of an affected source using a COMS for compliance purposes is responsible for demonstrating that he/she has complied with the performance evaluation requirements of § 63.8(e), that the COMS has been properly maintained, operated, and data quality-assured, as specified in § 63.8(c) and § 63.8(d), and that the resulting data have not been altered in any way.

(v) Except as provided in paragraph (h)(7)(ii) of this section, the results of continuous monitoring by a COMS that indicate that the opacity at the time visual observations were made was not in excess of the emission standard are probative but not conclusive evidence of the actual opacity of an emission, provided that the affected source proves that, at the time of the alleged violation, the instrument used was properly maintained, as specified in § 63.8(c), and met Performance Specification 1 in appendix B of part 60 of this chapter, and that the resulting data have not been altered in any way.

(8) *Finding of compliance.* The Administrator will make a finding concerning an affected source's compliance with an opacity or visible emission standard upon obtaining all the compliance information required by the relevant standard (including the written reports of the results of the performance tests required by § 63.7, the results of Test Method 9 or another required opacity or visible emission test method, the observer certification required by paragraph (h)(6) of this section, and the continuous opacity monitoring system results, whichever is/are applicable) and any information available to the Administrator needed to determine whether proper operation and maintenance practices are being used.

(9) *Adjustment to an opacity emission standard.*

(i) If the Administrator finds under paragraph (h)(8) of this section that an affected source is in compliance with all relevant standards for which initial performance tests were conducted under § 63.7, but during the time such performance tests were conducted fails to meet any relevant opacity emission standard, the owner or operator of such source may petition the Administrator to make appropriate adjustment to the opacity emission standard for the affected source. Until the Administrator notifies the owner or operator of the appropriate adjustment, the relevant opacity emission standard remains applicable.

(ii) The Administrator may grant such a petition upon a demonstration by the owner or operator that -

(A) The affected source and its associated air pollution control equipment were operated and maintained in a manner to minimize the opacity of emissions during the performance tests;

(B) The performance tests were performed under the conditions established by the Administrator; and

(C) The affected source and its associated air pollution control equipment were incapable of being adjusted or operated to meet the relevant opacity emission standard.

(iii) The Administrator will establish an adjusted opacity emission standard for the affected source meeting the above requirements at a level at which the source will be able, as indicated by the performance and opacity tests, to meet

the opacity emission standard at all times during which the source is meeting the mass or concentration emission standard. The Administrator will promulgate the new opacity emission standard in the FEDERAL REGISTER.

(iv) After the Administrator promulgates an adjusted opacity emission standard for an affected source, the owner or operator of such source shall be subject to the new opacity emission standard, and the new opacity emission standard shall apply to such source during any subsequent performance tests.

(i) *Extension of compliance with emission standards.*

(1) Until an extension of compliance has been granted by the Administrator (or a State with an approved permit program) under this paragraph, the owner or operator of an affected source subject to the requirements of this section shall comply with all applicable requirements of this part.

(2) *Extension of compliance for early reductions and other reductions*

(i) *Early reductions.* Pursuant to section 112(i)(5) of the Act, if the owner or operator of an existing source demonstrates that the source has achieved a reduction in emissions of hazardous air pollutants in accordance with the provisions of subpart D of this part, the Administrator (or the State with an approved permit program) will grant the owner or operator an extension of compliance with specific requirements of this part, as specified in subpart D.

(ii) *Other reductions.* Pursuant to section 112(i)(6) of the Act, if the owner or operator of an existing source has installed best available control technology (BACT) (as defined in section 169(3) of the Act) or technology required to meet a lowest achievable emission rate (LAER) (as defined in section 171 of the Act) prior to the promulgation of an emission standard in this part applicable to such source and the same pollutant (or stream of pollutants) controlled pursuant to the BACT or LAER installation, the Administrator will grant the owner or operator an extension of compliance with such emission standard that will apply until the date 5 years after the date on which such installation was achieved, as determined by the Administrator.

(3) *Request for extension of compliance.* Paragraphs (i)(4) through (i)(7) of this section concern requests for an extension of compliance with a relevant standard under this part (except requests for an extension of compliance under paragraph (i)(2)(i) of this section will be handled through procedures specified in subpart D of this part).

(4) (i) (A) The owner or operator of an existing source who is unable to comply with a relevant standard established under this part pursuant to section 112(d) of the Act may request that the Administrator (or a State, when the State has an approved part 70 permit program and the source is required to obtain a part 70 permit under that program, or a State, when the State has been delegated the authority to implement and enforce the emission standard for that source) grant an extension allowing the source up to 1 additional year to comply with the standard, if such additional period is necessary for the installation of controls. An additional extension of up to 3 years may be added for mining waste operations, if the 1-year extension of compliance is insufficient to dry and cover mining waste in order to reduce emissions of any hazardous air pollutant. The owner or operator of an affected source who has requested an extension of compliance under this paragraph and who is otherwise required to obtain a title V permit shall apply for such permit or apply to have the source's title V permit revised to incorporate the conditions of the extension of compliance. The conditions of an extension of compliance granted under this paragraph will be incorporated into the affected source's title V permit according to the provisions of part 70 or Federal title V regulations in this chapter (42 U.S.C. 7661), whichever are applicable.

(B) Any request under this paragraph for an extension of compliance with a relevant standard must be submitted in writing to the appropriate authority no later than 120 days prior to the affected source's compliance date (as specified in paragraphs (b) and (c) of this section), except as provided for in paragraph (i)(4)(i)(C) of this section. Nonfrivolous requests submitted under this paragraph will stay the applicability of the rule as to the emission points in question until such time as the request is granted or denied. A denial will be effective as of the date of denial. Emission standards established under this part may specify alternative dates for the submittal of requests for an extension of compliance if alternatives are appropriate for the source categories affected by those standards.

(C) An owner or operator may submit a compliance extension request after the date specified in paragraph (i)(4)(i)(B) of this section provided the need for the compliance extension arose after that date, and before the otherwise applicable compliance date and the need arose due to circumstances beyond reasonable control of the owner or operator. This request must include, in addition to the information required in paragraph (i)(6)(i) of this section, a statement of the reasons additional time is needed and the date when the owner or operator first learned of the problems. Nonfrivolous requests submitted under this paragraph will stay the applicability of the rule as to the emission points in question until such time as the request is granted or denied. A denial will be effective as of the original compliance date.

(ii) The owner or operator of an existing source unable to comply with a relevant standard established under this part pursuant to section 112(f) of the Act may request that the Administrator grant an extension allowing the source up to 2 years after the standard's effective date to comply with the standard. The Administrator may grant such an extension if he/she finds that such additional period is necessary for the installation of controls and that steps will be taken during the period of the extension to assure that the health of persons will be protected from imminent endangerment. Any request for

an extension of compliance with a relevant standard under this paragraph must be submitted in writing to the Administrator not later than 90 calendar days after the effective date of the relevant standard.

(5) The owner or operator of an existing source that has installed BACT or technology required to meet LAER [as specified in paragraph (i)(2)(ii) of this section] prior to the promulgation of a relevant emission standard in this part may request that the Administrator grant an extension allowing the source 5 years from the date on which such installation was achieved, as determined by the Administrator, to comply with the standard. Any request for an extension of compliance with a relevant standard under this paragraph shall be submitted in writing to the Administrator not later than 120 days after the promulgation date of the standard. The Administrator may grant such an extension if he or she finds that the installation of BACT or technology to meet LAER controls the same pollutant (or stream of pollutants) that would be controlled at that source by the relevant emission standard.

(6) (i) The request for a compliance extension under paragraph (i)(4) of this section shall include the following information:

(A) A description of the controls to be installed to comply with the standard;

(B) A compliance schedule, including the date by which each step toward compliance will be reached. At a minimum, the list of dates shall include:

(1) The date by which on-site construction, installation of emission control equipment, or a process change is planned to be initiated; and

(2) The date by which final compliance is to be achieved;

(C) [Reserved]

(D) [Reserved]

(ii) The request for a compliance extension under paragraph (i)(5) of this section shall include all information needed to demonstrate to the Administrator's satisfaction that the installation of BACT or technology to meet LAER controls the same pollutant (or stream of pollutants) that would be controlled at that source by the relevant emission standard.

(7) Advice on requesting an extension of compliance may be obtained from the Administrator (or the State with an approved permit program).

(8) *Approval of request for extension of compliance.* Paragraphs (i)(9) through (i)(14) of this section concern approval of an extension of compliance requested under paragraphs (i)(4) through (i)(6) of this section.

(9) Based on the information provided in any request made under paragraphs (i)(4) through (i)(6) of this section, or other information, the Administrator (or the State with an approved permit program) may grant an extension of compliance with an emission standard, as specified in paragraphs (i)(4) and (i)(5) of this section.

(10) The extension will be in writing and will -

(i) Identify each affected source covered by the extension;

(ii) Specify the termination date of the extension;

(iii) Specify the dates by which steps toward compliance are to be taken, if appropriate;

(iv) Specify other applicable requirements to which the compliance extension applies (e.g., performance tests);

and

(v) (A) Under paragraph (i)(4), specify any additional conditions that the Administrator (or the State) deems necessary to assure installation of the necessary controls and protection of the health of persons during the extension period; or

(B) Under paragraph (i)(5), specify any additional conditions that the Administrator deems necessary to assure the proper operation and maintenance of the installed controls during the extension period.

(11) The owner or operator of an existing source that has been granted an extension of compliance under paragraph (i)(10) of this section may be required to submit to the Administrator (or the State with an approved permit program) progress reports indicating whether the steps toward compliance outlined in the compliance schedule have been reached. The contents of the progress reports and the dates by which they shall be submitted will be specified in the written extension of compliance granted under paragraph (i)(10) of this section.

(12) (i) The Administrator (or the State with an approved permit program) will notify the owner or operator in writing of approval or intention to deny approval of a request for an extension of compliance within 30 calendar days after receipt of sufficient information to evaluate a request submitted under paragraph (i)(4)(i) or (i)(5) of this section. The Administrator (or the State) will notify the owner or operator in writing of the status of his/her application, that is, whether the application contains sufficient information to make a determination, within 30 calendar days after receipt of the original application and within 30 calendar days after receipt of any supplementary information that is submitted. The 30-day approval or denial period will begin after the owner or operator has been notified in writing that his/her application is complete.

(ii) When notifying the owner or operator that his/her application is not complete, the Administrator will specify the information needed to complete the application and provide notice of opportunity for the applicant to present, in

## NESHAP Subpart A for General Provisions

writing, within 30 calendar days after he/she is notified of the incomplete application, additional information or arguments to the Administrator to enable further action on the application.

(iii) Before denying any request for an extension of compliance, the Administrator (or the State with an approved permit program) will notify the owner or operator in writing of the Administrator's (or the State's) intention to issue the denial, together with -

(A) Notice of the information and findings on which the intended denial is based; and

(B) Notice of opportunity for the owner or operator to present in writing, within 15 calendar days after he/she is notified of the intended denial, additional information or arguments to the Administrator (or the State) before further action on the request.

(iv) The Administrator's final determination to deny any request for an extension will be in writing and will set forth the specific grounds on which the denial is based. The final determination will be made within 30 calendar days after presentation of additional information or argument (if the application is complete), or within 30 calendar days after the final date specified for the presentation if no presentation is made.

(13) (i) The Administrator will notify the owner or operator in writing of approval or intention to deny approval of a request for an extension of compliance within 30 calendar days after receipt of sufficient information to evaluate a request submitted under paragraph (i)(4)(ii) of this section. The 30-day approval or denial period will begin after the owner or operator has been notified in writing that his/her application is complete. The Administrator (or the State) will notify the owner or operator in writing of the status of his/her application, that is, whether the application contains sufficient information to make a determination, within 15 calendar days after receipt of the original application and within 15 calendar days after receipt of any supplementary information that is submitted.

(ii) When notifying the owner or operator that his/her application is not complete, the Administrator will specify the information needed to complete the application and provide notice of opportunity for the applicant to present, in writing, within 15 calendar days after he/she is notified of the incomplete application, additional information or arguments to the Administrator to enable further action on the application.

(iii) Before denying any request for an extension of compliance, the Administrator will notify the owner or operator in writing of the Administrator's intention to issue the denial, together with -

(A) Notice of the information and findings on which the intended denial is based; and

(B) Notice of opportunity for the owner or operator to present in writing, within 15 calendar days after he/she is notified of the intended denial, additional information or arguments to the Administrator before further action on the request.

(iv) A final determination to deny any request for an extension will be in writing and will set forth the specific grounds on which the denial is based. The final determination will be made within 30 calendar days after presentation of additional information or argument (if the application is complete), or within 30 calendar days after the final date specified for the presentation if no presentation is made.

(14) The Administrator (or the State with an approved permit program) may terminate an extension of compliance at an earlier date than specified if any specification under paragraph (i)(10)(iii) or (iv) of this section is not met. Upon a determination to terminate, the Administrator will notify, in writing, the owner or operator of the Administrator's determination to terminate, together with:

(i) Notice of the reason for termination; and

(ii) Notice of opportunity for the owner or operator to present in writing, within 15 calendar days after he/she is notified of the determination to terminate, additional information or arguments to the Administrator before further action on the termination.

(iii) A final determination to terminate an extension of compliance will be in writing and will set forth the specific grounds on which the termination is based. The final determination will be made within 30 calendar days after presentation of additional information or arguments, or within 30 calendar days after the final date specified for the presentation if no presentation is made.

(15) [Reserved]

(16) The granting of an extension under this section shall not abrogate the Administrator's authority under section 114 of the Act.

(j) *Exemption from compliance with emission standards.* The President may exempt any stationary source from compliance with any relevant standard established pursuant to section 112 of the Act for a period of not more than 2 years if the President determines that the technology to implement such standard is not available and that it is in the national security interests of the United States to do so. An exemption under this paragraph may be extended for 1 or more additional periods, each period not to exceed 2 years.

### § 63.7 Performance testing requirements.

(a) *Applicability and performance test dates.*

(1) The applicability of this section is set out in § 63.1(a)(4).

(2) If required to do performance testing by a relevant standard, and unless a waiver of performance testing is obtained under this section or the conditions of paragraph (c)(3)(ii)(B) of this section apply, the owner or operator of the affected source must perform such tests within 180 days of the compliance date for such source.

(i)-(viii) [Reserved]

(ix) When an emission standard promulgated under this part is more stringent than the standard proposed (see § 63.6(b)(3)), the owner or operator of a new or reconstructed source subject to that standard for which construction or reconstruction is commenced between the proposal and promulgation dates of the standard shall comply with performance testing requirements within 180 days after the standard's effective date, or within 180 days after startup of the source, whichever is later. If the promulgated standard is more stringent than the proposed standard, the owner or operator may choose to demonstrate compliance with either the proposed or the promulgated standard. If the owner or operator chooses to comply with the proposed standard initially, the owner or operator shall conduct a second performance test within 3 years and 180 days after the effective date of the standard, or after startup of the source, whichever is later, to demonstrate compliance with the promulgated standard.

(3) The Administrator may require an owner or operator to conduct performance tests at the affected source at any other time when the action is authorized by section 114 of the Act.

(b) *Notification of performance test.*

(1) The owner or operator of an affected source must notify the Administrator in writing of his or her intention to conduct a performance test at least 60 calendar days before the performance test is initially scheduled to begin to allow the Administrator, upon request, to review an approve the site-specific test plan required under paragraph (c) of this section and to have an observer present during the test.

(2) In the event the owner or operator is unable to conduct the performance test on the date specified in the notification requirement specified in paragraph (b)(1) of this section due to unforeseeable circumstances beyond his or her control, the owner or operator must notify the Administrator as soon as practicable and without delay prior to the scheduled performance test date and specify the date when the performance test is rescheduled. This notification of delay in conducting the performance test shall not relieve the owner or operator of legal responsibility for compliance with any other applicable provisions of this part or with any other applicable Federal, State, or local requirement, nor will it prevent the Administrator from implementing or enforcing this part or taking any other action under the Act.

(c) *Quality assurance program.*

(1) The results of the quality assurance program required in this paragraph will be considered by the Administrator when he/she determines the validity of a performance test.

(2) (i) *Submission of site-specific test plan.* Before conducting a required performance test, the owner or operator of an affected source shall develop and, if requested by the Administrator, shall submit a site-specific test plan to the Administrator for approval. The test plan shall include a test program summary, the test schedule, data quality objectives, and both an internal and external quality assurance (QA) program. Data quality objectives are the pretest expectations of precision, accuracy, and completeness of data.

(ii) The internal QA program shall include, at a minimum, the activities planned by routine operators and analysts to provide an assessment of test data precision; an example of internal QA is the sampling and analysis of replicate samples.

(iii) The external QA program shall include, at a minimum, application of plans for a test method performance audit (PA) during the performance test. The PA's consist of blind audit samples provided by the Administrator and analyzed during the performance test in order to provide a measure of test data bias. The external QA program may also include systems audits that include the opportunity for on-site evaluation by the Administrator of instrument calibration, data validation, sample logging, and documentation of quality control data and field maintenance activities.

(iv) The owner or operator of an affected source shall submit the site-specific test plan to the Administrator upon the Administrator's request at least 60 calendar days before the performance test is scheduled to take place, that is, simultaneously with the notification of intention to conduct a performance test required under paragraph (b) of this section, or on a mutually agreed upon date.

(v) The Administrator may request additional relevant information after the submittal of a site-specific test plan.

(3) *Approval of site-specific test plan.*

(i) The Administrator will notify the owner or operator of approval or intention to deny approval of the site-specific test plan (if review of the site-specific test plan is requested) within 30 calendar days after receipt of the original



plan and within 30 calendar days after receipt of any supplementary information that is submitted under paragraph (c)(3)(i)(B) of this section. Before disapproving any site-specific test plan, the Administrator will notify the applicant of the Administrator's intention to disapprove the plan together with -

(A) Notice of the information and findings on which the intended disapproval is based; and

(B) Notice of opportunity for the owner or operator to present, within 30 calendar days after he/she is notified of the intended disapproval, additional information to the Administrator before final action on the plan.

(ii) In the event that the Administrator fails to approve or disapprove the site-specific test plan within the time period specified in paragraph (c)(3)(i) of this section, the following conditions shall apply:

(A) If the owner or operator intends to demonstrate compliance using the test method(s) specified in the relevant standard or with only minor changes to those tests methods (see paragraph (e)(2)(i) of this section), the owner or operator must conduct the performance test within the time specified in this section using the specified method(s);

(B) If the owner or operator intends to demonstrate compliance by using an alternative to any test method specified in the relevant standard, the owner or operator is authorized to conduct the performance test using an alternative test method after the Administrator approves the use of the alternative method when the Administrator approves the site-specific test plan (if review of the site-specific test plan is requested) or after the alternative method is approved (see paragraph (f) of this section). However, the owner or operator is authorized to conduct the performance test using an alternative method in the absence of notification of approval 45 days after submission of the site-specific test plan or request to use an alternative method. The owner or operator is authorized to conduct the performance test within 60 calendar days after he/she is authorized to demonstrate compliance using an alternative test method. Notwithstanding the requirements in the preceding three sentences, the owner or operator may proceed to conduct the performance test as required in this section (without the Administrator's prior approval of the site-specific test plan) if he/she subsequently chooses to use the specified testing and monitoring methods instead of an alternative.

(iii) Neither the submission of a site-specific test plan for approval, nor the Administrator's approval or disapproval of a plan, nor the Administrator's failure to approve or disapprove a plan in a timely manner shall -

(A) Relieve an owner or operator of legal responsibility for compliance with any applicable provisions of this part or with any other applicable Federal, State, or local requirement; or

(B) Prevent the Administrator from implementing or enforcing this part or taking any other action under the Act.

(4) (i) *Performance test method audit program.* The owner or operator must analyze performance audit (PA) samples during each performance test. The owner or operator must request performance audit materials 30 days prior to the test date. Audit materials including cylinder audit gases may be obtained by contacting the appropriate EPA Regional Office or the responsible enforcement authority.

(ii) The Administrator will have sole discretion to require any subsequent remedial actions of the owner or operator based on the PA results.

(iii) If the Administrator fails to provide required PA materials to an owner or operator of an affected source in time to analyze the PA samples during a performance test, the requirement to conduct a PA under this paragraph shall be waived for such source for that performance test. Waiver under this paragraph of the requirement to conduct a PA for a particular performance test does not constitute a waiver of the requirement to conduct a PA for future required performance tests.

(d) *Performance testing facilities.* If required to do performance testing, the owner or operator of each new source and, at the request of the Administrator, the owner or operator of each existing source, shall provide performance testing facilities as follows:

(1) Sampling ports adequate for test methods applicable to such source. This includes:

(i) Constructing the air pollution control system such that volumetric flow rates and pollutant emission rates can be accurately determined by applicable test methods and procedures; and

(ii) Providing a stack or duct free of cyclonic flow during performance tests, as demonstrated by applicable test methods and procedures;

(2) Safe sampling platform(s);

(3) Safe access to sampling platform(s);

(4) Utilities for sampling and testing equipment; and

(5) Any other facilities that the Administrator deems necessary for safe and adequate testing of a source.

(e) *Conduct of performance tests.*

(1) Performance tests shall be conducted under such conditions as the Administrator specifies to the owner or operator based on representative performance (i.e., performance based on normal operating conditions) of the affected source. Operations during periods of startup, shutdown, and malfunction shall not constitute representative conditions for the

purpose of a performance test, nor shall emissions in excess of the level of the relevant standard during periods of startup, shutdown, and malfunction be considered a violation of the relevant standard unless otherwise specified in the relevant standard or a determination of noncompliance is made under

§ 63.6(e). Upon request, the owner or operator shall make available to the Administrator such records as may be necessary to determine the conditions of performance tests.

(2) Performance tests shall be conducted and data shall be reduced in accordance with the test methods and procedures set forth in this section, in each relevant standard, and, if required, in applicable appendices of parts 51, 60, 61, and 63 of this chapter unless the Administrator -

(i) Specifies or approves, in specific cases, the use of a test method with minor changes in methodology (see definition in § 63.90(a)). Such changes may be approved in conjunction with approval of the site-specific test plan (see paragraph (c) of this section); or

(ii) Approves the use of an intermediate or major change or alternative to a test method (see definitions in § 63.90(a)), the results of which the Administrator has determined to be adequate for indicating whether a specific affected source is in compliance; or

(iii) Approves shorter sampling times or smaller sample volumes when necessitated by process variables or other factors; or

(iv) Waives the requirement for performance tests because the owner or operator of an affected source has demonstrated by other means to the Administrator's satisfaction that the affected source is in compliance with the relevant standard.

(3) Unless otherwise specified in a relevant standard or test method, each performance test shall consist of three separate runs using the applicable test method. Each run shall be conducted for the time and under the conditions specified in the relevant standard. For the purpose of determining compliance with a relevant standard, the arithmetic mean of the results of the three runs shall apply. Upon receiving approval from the Administrator, results of a test run may be replaced with results of an additional test run in the event that

(i) A sample is accidentally lost after the testing team leaves the site; or

(ii) Conditions occur in which one of the three runs must be discontinued because of forced shutdown; or

(iii) Extreme meteorological conditions occur; or

(iv) Other circumstances occur that are beyond the owner or operator's control.

(4) Nothing in paragraphs (e)(1) through (e)(3) of this section shall be construed to abrogate the Administrator's authority to require testing under section 114 of the Act.

(f) *Use of an alternative test method -*

(1) *General.* Until authorized to use an intermediate or major change or alternative to a test method, the owner or operator of an affected source remains subject to the requirements of this section and the relevant standard.

(2) The owner or operator of an affected source required to do performance testing by a relevant standard may use an alternative test method from that specified in the standard provided that the owner or operator -

(i) Notifies the Administrator of his or her intention to use an alternative test method at least 60 days before the performance test is scheduled to begin;

(ii) Uses Method 301 in appendix A of this part to validate the alternative test method. This may include the use of specific procedures of Method 301 if use of such procedures are sufficient to validate the alternative test method; and

(iii) Submits the results of the Method 301 validation process along with the notification of intention and the justification for not using the specified test method. The owner or operator may submit the information required in this paragraph well in advance of the deadline specified in paragraph (f)(2)(i) of this section to ensure a timely review by the Administrator in order to meet the performance test date specified in this section or the relevant standard.

(3) The Administrator will determine whether the owner or operator's validation of the proposed alternative test method is adequate and issue an approval or disapproval of the alternative test method. If the owner or operator intends to demonstrate compliance by using an alternative to any test method specified in the relevant standard, the owner or operator is authorized to conduct the performance test using an alternative test method after the Administrator approves the use of the alternative method. However, the owner or operator is authorized to conduct the performance test using an alternative method in the absence of notification of approval/disapproval 45 days after submission of the request to use an alternative method and the request satisfies the requirements in paragraph (f)(2) of this section. The owner or operator is authorized to conduct the performance test within 60 calendar days after he/she is authorized to demonstrate compliance using an alternative test method. Notwithstanding the requirements in the preceding three sentences, the owner or operator may proceed to conduct the performance test as required in this section (without the Administrator's prior approval of the site-specific test plan) if he/she subsequently chooses to use the specified testing and monitoring methods instead of an alternative.

## NESHAP Subpart A for General Provisions

(4) If the Administrator finds reasonable grounds to dispute the results obtained by an alternative test method for the purposes of demonstrating compliance with a relevant standard, the Administrator may require the use of a test method specified in a relevant standard.

(5) If the owner or operator uses an alternative test method for an affected source during a required performance test, the owner or operator of such source shall continue to use the alternative test method for subsequent performance tests at that affected source until he or she receives approval from the Administrator to use another test method as allowed under § 63.7(f).

(6) Neither the validation and approval process nor the failure to validate an alternative test method shall abrogate the owner or operator's responsibility to comply with the requirements of this part.

(g) *Data analysis, recordkeeping, and reporting.*

(1) Unless otherwise specified in a relevant standard or test method, or as otherwise approved by the Administrator in writing, results of a performance test shall include the analysis of samples, determination of emissions, and raw data. A performance test is "completed" when field sample collection is terminated. The owner or operator of an affected source shall report the results of the performance test to the Administrator before the close of business on the 60th day following the completion of the performance test, unless specified otherwise in a relevant standard or as approved otherwise in writing by the Administrator (see § 63.9(i)). The results of the performance test shall be submitted as part of the notification of compliance status required under § 63.9(h). Before a title V permit has been issued to the owner or operator of an affected source, the owner or operator shall send the results of the performance test to the Administrator. After a title V permit has been issued to the owner or operator of an affected source, the owner or operator shall send the results of the performance test to the appropriate permitting authority.

(2) [Reserved]

(3) For a minimum of 5 years after a performance test is conducted, the owner or operator shall retain and make available, upon request, for inspection by the Administrator the records or results of such performance test and other data needed to determine emissions from an affected source.

(h) *Waiver of performance tests.*

(1) Until a waiver of a performance testing requirement has been granted by the Administrator under this paragraph, the owner or operator of an affected source remains subject to the requirements of this section.

(2) Individual performance tests may be waived upon written application to the Administrator if, in the Administrator's judgment, the source is meeting the relevant standard(s) on a continuous basis, or the source is being operated under an extension of compliance, or the owner or operator has requested an extension of compliance and the Administrator is still considering that request.

(3) Request to waive a performance test.

(i) If a request is made for an extension of compliance under § 63.6(i), the application for a waiver of an initial performance test shall accompany the information required for the request for an extension of compliance. If no extension of compliance is requested or if the owner or operator has requested an extension of compliance and the Administrator is still considering that request, the application for a waiver of an initial performance test shall be submitted at least 60 days before the performance test if the site-specific test plan under paragraph (c) of this section is not submitted.

(ii) If an application for a waiver of a subsequent performance test is made, the application may accompany any required compliance progress report, compliance status report, or excess emissions and continuous monitoring system performance report [such as those required under § 63.6(I), § 63.9(h), and § 63.10(e) or specified in a relevant standard or in the source's title V permit], but it shall be submitted at least 60 days before the performance test if the site-specific test plan required under paragraph (c) of this section is not submitted.

(iii) Any application for a waiver of a performance test shall include information justifying the owner or operator's request for a waiver, such as the technical or economic infeasibility, or the impracticality, of the affected source performing the required test.

(4) Approval of request to waive performance test. The Administrator will approve or deny a request for a waiver of a performance test made under paragraph (h)(3) of this section when he/she:

(i) Approves or denies an extension of compliance under § 63.6(i)(8); or

(ii) Approves or disapproves a site-specific test plan under § 63.7(c)(3); or

(iii) Makes a determination of compliance following the submission of a required compliance status report or excess emissions and continuous monitoring systems performance report; or

(iv) Makes a determination of suitable progress towards compliance following the submission of a compliance progress report, whichever is applicable.

(5) Approval of any waiver granted under this section shall not abrogate the Administrator's authority under the Act or in any way prohibit the Administrator from later canceling the waiver. The cancellation will be made only after notice is given to the owner or operator of the affected source.

### § 63.8 Monitoring requirements.

#### (a) *Applicability.*

(1) The applicability of this section is set out in § 63.1(a)(4).

(2) For the purposes of this part, all CMS required under relevant standards shall be subject to the provisions of this section upon promulgation of performance specifications for CMS as specified in the relevant standard or otherwise by the Administrator.

(3) [Reserved]

(4) Additional monitoring requirements for control devices used to comply with provisions in relevant standards of this part are specified in § 63.11.

#### (b) *Conduct of monitoring.*

(1) Monitoring shall be conducted as set forth in this section and the relevant standard(s) unless the Administrator -

(i) Specifies or approves the use of minor changes in methodology for the specified monitoring requirements and procedures (see § 63.90(a) for definition); or (ii) Approves the use of an intermediate or major change or alternative to any monitoring requirements or procedures (see § 63.90(a) for definition).

(iii) Owners or operators with flares subject to § 63.11(b) are not subject to the requirements of this section unless otherwise specified in the relevant standard.

(2) (i) When the emissions from two or more affected sources are combined before being released to the atmosphere, the owner or operator may install an applicable CMS for each emission stream or for the combined emissions streams, provided the monitoring is sufficient to demonstrate compliance with the relevant standard.

(ii) If the relevant standard is a mass emission standard and the emissions from one affected source are released to the atmosphere through more than one point, the owner or operator must install an applicable CMS at each emission point unless the installation of fewer systems is -

(A) Approved by the Administrator; or

(B) Provided for in a relevant standard (e.g., instead of requiring that a CMS be installed at each emission point before the effluents from those points are channeled to a common control device, the standard specifies that only one CMS is required to be installed at the vent of the control device).

(3) When more than one CMS is used to measure the emissions from one affected source (e.g., multiple breechings, multiple outlets), the owner or operator shall report the results as required for each CMS. However, when one CMS is used as a backup to another CMS, the owner or operator shall report the results from the CMS used to meet the monitoring requirements of this part. If both such CMS are used during a particular reporting period to meet the monitoring requirements of this part, then the owner or operator shall report the results from each CMS for the relevant compliance period.

#### (c) *Operation and maintenance of continuous monitoring systems.*

(1) The owner or operator of an affected source shall maintain and operate each CMS as specified in this section, or in a relevant standard, and in a manner consistent with good air pollution control practices.

(i) The owner or operator of an affected source must maintain and operate each CMS as specified in § 63.6(e)(1).

(ii) The owner or operator must keep the necessary parts for routine repairs of the affected CMS equipment readily available.

(iii) The owner or operator of an affected source must develop and implement a written startup, shutdown, and malfunction plan for CMS as specified in § 63.6(e)(3).

(2) (i) All CMS must be installed such that representative measures of emissions or process parameters from the affected source are obtained. In addition, CEMS must be located according to procedures contained in the applicable performance specification(s).

(ii) Unless the individual subpart states otherwise, the owner or operator must ensure the read out (that portion of the CMS that provides a visual display or record), or other indication of operation, from any CMS required for compliance with the emission standard is readily accessible on site for operational control or inspection by the operator of the equipment.

(3) All CMS shall be installed, operational, and the data verified as specified in the relevant standard either prior to or in conjunction with conducting performance tests under § 63.7. Verification of operational status shall, at a minimum,

## NESHAP Subpart A for General Provisions

include completion of the manufacturer's written specifications or recommendations for installation, operation, and calibration of the system.

(4) Except for system breakdowns, out-of-control periods, repairs, maintenance periods, calibration checks, and zero (low-level) and high-level calibration drift adjustments, all CMS, including COMS and CEMS, shall be in continuous operation and shall meet minimum frequency of operation requirements as follows:

(i) All COMS shall complete a minimum of one cycle of sampling and analyzing for each successive 10-second period and one cycle of data recording for each successive 6-minute period.

(ii) All CEMS for measuring emissions other than opacity shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period.

(5) Unless otherwise approved by the Administrator, minimum procedures for COMS shall include a method for producing a simulated zero opacity condition and an upscale (high-level) opacity condition using a certified neutral density filter or other related technique to produce a known obscuration of the light beam. Such procedures shall provide a system check of all the analyzer's internal optical surfaces and all electronic circuitry, including the lamp and photodetector assembly normally used in the measurement of opacity.

(6) The owner or operator of a CMS that is not a CPMS, which is installed in accordance with the provisions of this part and the applicable CMS performance specification(s), must check the zero (low-level) and high-level calibration drifts at least once daily in accordance with the written procedure specified in the performance evaluation plan developed under paragraphs (e)(3)(i) and (ii) of this section. The zero (low-level) and high-level calibration drifts must be adjusted, at a minimum, whenever the 24-hour zero (low-level) drift exceeds two times the limits of the applicable performance specification(s) specified in the relevant standard. The system shall allow the amount of excess zero (low-level) and high-level drift measured at the 24-hour interval checks to be recorded and quantified whenever specified. For COMS, all optical and instrumental surfaces exposed to the effluent gases must be cleaned prior to performing the zero (low-level) and high-level drift adjustments; the optical surfaces and instrumental surfaces must be cleaned when the cumulative automatic zero compensation, if applicable, exceeds 4 percent opacity. The CPMS must be calibrated prior to use for the purposes of complying with this section. The CPMS must be checked daily for indication that the system is responding. If the CPMS system includes an internal system check, results must be recorded and checked daily for proper operation.

(7) (i) A CMS is out of control if -

(A) The zero (low-level), mid-level (if applicable), or high-level calibration drift (CD) exceeds two times the applicable CD specification in the applicable performance specification or in the relevant standard; or

(B) The CMS fails a performance test audit (e.g., cylinder gas audit), relative accuracy audit, relative accuracy test audit, or linearity test audit; or

(C) The COMS CD exceeds two times the limit in the applicable performance specification in the relevant standard.

(ii) When the CMS is out of control, the owner or operator of the affected source shall take the necessary corrective action and shall repeat all necessary tests which indicate that the system is out of control. The owner or operator shall take corrective action and conduct retesting until the performance requirements are below the applicable limits. The beginning of the out-of-control period is the hour the owner or operator conducts a performance check (e.g., calibration drift) that indicates an exceedance of the performance requirements established under this part. The end of the out-of-control period is the hour following the completion of corrective action and successful demonstration that the system is within the allowable limits. During the period the CMS is out of control, recorded data shall not be used in data averages and calculations, or to meet any data availability requirement established under this part.

(8) The owner or operator of a CMS that is out of control as defined in paragraph (c)(7) of this section shall submit all information concerning out-of-control periods, including start and end dates and hours and descriptions of corrective actions taken, in the excess emissions and continuous monitoring system performance report required in § 63.10(e)(3).

(d) *Quality control program.*

(1) The results of the quality control program required in this paragraph will be considered by the Administrator when he/she determines the validity of monitoring data.

(2) The owner or operator of an affected source that is required to use a CMS and is subject to the monitoring requirements of this section and a relevant standard shall develop and implement a CMS quality control program. As part of the quality control program, the owner or operator shall develop and submit to the Administrator for approval upon request a site-specific performance evaluation test plan for the CMS performance evaluation required in paragraph (e)(3)(i) of this section, according to the procedures specified in paragraph (e). In addition, each quality control program shall include, at a minimum, a written protocol that describes procedures for each of the following operations:

(i) Initial and any subsequent calibration of the CMS;

(ii) Determination and adjustment of the calibration drift of the CMS;

(iii) Preventive maintenance of the CMS, including spare parts inventory;

(B) Prevent the Administrator from implementing or enforcing this part or taking any other action under the Act.

(4) *Conduct of performance evaluation and performance evaluation dates.* The owner or operator of an affected source shall conduct a performance evaluation of a required CMS during any performance test required under § 63.7 in accordance with the applicable performance specification as specified in the relevant standard. Notwithstanding the requirement in the previous sentence, if the owner or operator of an affected source elects to submit COMS data for compliance with a relevant opacity emission standard as provided under § 63.6(h)(7), he/she shall conduct a performance evaluation of the COMS as specified in the relevant standard, before the performance test required under § 63.7 is conducted in time to submit the results of the performance evaluation as specified in paragraph (e)(5)(ii) of this section. If a performance test is not required, or the requirement for a performance test has been waived under § 63.7(h), the owner or operator of an affected source shall conduct the performance evaluation not later than 180 days after the appropriate compliance date for the affected source, as specified in § 63.7(a), or as otherwise specified in the relevant standard.

(5) *Reporting performance evaluation results.*

(i) The owner or operator shall furnish the Administrator a copy of a written report of the results of the performance evaluation simultaneously with the results of the performance test required under § 63.7 or within 60 days of completion of the performance evaluation if no test is required, unless otherwise specified in a relevant standard. The Administrator may request that the owner or operator submit the raw data from a performance evaluation in the report of the performance evaluation results.

(ii) The owner or operator of an affected source using a COMS to determine opacity compliance during any performance test required under § 63.7 and described in § 63.6(d)(6) shall furnish the Administrator two or, upon request, three copies of a written report of the results of the COMS performance evaluation under this paragraph. The copies shall be provided at least 15 calendar days before the performance test required under § 63.7 is conducted.

(f) *Use of an alternative monitoring method -*

(1) *General.* Until permission to use an alternative monitoring procedure (minor, intermediate, or major changes; see definition in § 63.90(a)) has been granted by the Administrator under this paragraph (f)(1), the owner or operator of an affected source remains subject to the requirements of this section and the relevant standard.

(2) After receipt and consideration of written application, the Administrator may approve alternatives to any monitoring methods or procedures of this part including, but not limited to, the following:

(i) Alternative monitoring requirements when installation of a CMS specified by a relevant standard would not provide accurate measurements due to liquid water or other interferences caused by substances within the effluent gases;

(ii) Alternative monitoring requirements when the affected source is infrequently operated;

(iii) Alternative monitoring requirements to accommodate CEMS that require additional measurements to correct for stack moisture conditions;

(iv) Alternative locations for installing CMS when the owner or operator can demonstrate that installation at alternate locations will enable accurate and representative measurements;

(v) Alternate methods for converting pollutant concentration measurements to units of the relevant standard;

(vi) Alternate procedures for performing daily checks of zero (low-level) and high-level drift that do not involve use of high-level gases or test cells;

(vii) Alternatives to the American Society for Testing and Materials (ASTM) test methods or sampling procedures specified by any relevant standard;

(viii) Alternative CMS that do not meet the design or performance requirements in this part, but adequately demonstrate a definite and consistent relationship between their measurements and the measurements of opacity by a system complying with the requirements as specified in the relevant standard. The Administrator may require that such demonstration be performed for each affected source; or

(ix) Alternative monitoring requirements when the effluent from a single affected source or the combined effluent from two or more affected sources is released to the atmosphere through more than one point.

(3) If the Administrator finds reasonable grounds to dispute the results obtained by an alternative monitoring method, requirement, or procedure, the Administrator may require the use of a method, requirement, or procedure specified in this section or in the relevant standard. If the results of the specified and alternative method, requirement, or procedure do not agree, the results obtained by the specified method, requirement, or procedure shall prevail.

(4) (i) *Request to use alternative monitoring procedure.* An owner or operator who wishes to use an alternative monitoring procedure must submit an application to the Administrator as described in paragraph (f)(4)(ii) of this section. The application may be submitted at any time provided that the monitoring procedure is not the performance test method used to demonstrate compliance with a relevant standard or other requirement. If the alternative monitoring procedure will serve as the performance test method that is to be used to demonstrate compliance with a relevant standard, the application

must be submitted at least 60 days before the performance evaluation is scheduled to begin and must meet the requirements for an alternative test method under § 63.7(f).

(ii) The application must contain a description of the proposed alternative monitoring system which addresses the four elements contained in the definition of monitoring in § 63.2 and a performance evaluation test plan, if required, as specified in paragraph (e)(3) of this section. In addition, the application must include information justifying the owner or operator's request for an alternative monitoring method, such as the technical or economic infeasibility, or the impracticality, of the affected source using the required method.

(iii) The owner or operator may submit the information required in this paragraph well in advance of the submittal dates specified in paragraph (f)(4)(i) above to ensure a timely review by the Administrator in order to meet the compliance demonstration date specified in this section or the relevant standard.

(iv) Application for minor changes to monitoring procedures, as specified in paragraph (b)(1) of this section, may be made in the site-specific performance evaluation plan.

(5) *Approval of request to use alternative monitoring procedure.*

(i) The Administrator will notify the owner or operator of approval or intention to deny approval of the request to use an alternative monitoring method within 30 calendar days after receipt of the original request and within 30 calendar days after receipt of any supplementary information that is submitted. If a request for a minor change is made in conjunction with site-specific performance evaluation plan, then approval of the plan will constitute approval of the minor change. Before disapproving any request to use an alternative monitoring method, the Administrator will notify the applicant of the Administrator's intention to disapprove the request together with --

(A) Notice of the information and findings on which the intended disapproval is based; and

(B) Notice of opportunity for the owner or operator to present additional information to the Administrator before final action on the request. At the time the Administrator notifies the applicant of his or her intention to disapprove the request, the Administrator will specify how much time the owner or operator will have after being notified of the intended disapproval to submit the additional information.

(ii) The Administrator may establish general procedures and criteria in a relevant standard to accomplish the requirements of paragraph (f)(5)(i) of this section.

(iii) If the Administrator approves the use of an alternative monitoring method for an affected source under paragraph (f)(5)(i) of this section, the owner or operator of such source shall continue to use the alternative monitoring method until he or she receives approval from the Administrator to use another monitoring method as allowed by § 63.8(f).

(6) Alternative to the relative accuracy test. An alternative to the relative accuracy test for CEMS specified in a relevant standard may be requested as follows:

(i) *Criteria for approval of alternative procedures.* An alternative to the test method for determining relative accuracy is available for affected sources with emission rates demonstrated to be less than 50 percent of the relevant standard. The owner or operator of an affected source may petition the Administrator under paragraph (f)(6)(ii) of this section to substitute the relative accuracy test in section 7 of Performance Specification 2 with the procedures in section 10 if the results of a performance test conducted according to the requirements in § 63.7, or other tests performed following the criteria in § 63.7, demonstrate that the emission rate of the pollutant of interest in the units of the relevant standard is less than 50 percent of the relevant standard. For affected sources subject to emission limitations expressed as control efficiency levels, the owner or operator may petition the Administrator to substitute the relative accuracy test with the procedures in section 10 of Performance Specification 2 if the control device exhaust emission rate is less than 50 percent of the level needed to meet the control efficiency requirement. The alternative procedures do not apply if the CEMS is used continuously to determine compliance with the relevant standard.

(ii) *Petition to use alternative to relative accuracy test.* The petition to use an alternative to the relative accuracy test shall include a detailed description of the procedures to be applied, the location and the procedure for conducting the alternative, the concentration or response levels of the alternative relative accuracy materials, and the other equipment checks included in the alternative procedure(s). The Administrator will review the petition for completeness and applicability. The Administrator's determination to approve an alternative will depend on the intended use of the CEMS data and may require specifications more stringent than in Performance Specification 2.

(iii) *Rescission of approval to use alternative to relative accuracy test.* The Administrator will review the permission to use an alternative to the CEMS relative accuracy test and may rescind such permission if the CEMS data from a successful completion of the alternative relative accuracy procedure indicate that the affected source's emissions are approaching the level of the relevant standard. The criterion for reviewing the permission is that the collection of CEMS data shows that emissions have exceeded 70 percent of the relevant standard for any averaging period, as specified in the relevant standard. For affected sources subject to emission limitations expressed as control efficiency levels, the criterion for reviewing the permission is that the collection of CEMS data shows that exhaust emissions have exceeded 70 percent of the level needed to meet the control efficiency requirement for any averaging period, as specified in the relevant standard. The owner or operator of the affected source shall maintain records and determine the level of emissions relative to the

criterion for permission to use an alternative for relative accuracy testing. If this criterion is exceeded, the owner or operator shall notify the Administrator within 10 days of such occurrence and include a description of the nature and cause of the increased emissions. The Administrator will review the notification and may rescind permission to use an alternative and require the owner or operator to conduct a relative accuracy test of the CEMS as specified in section 7 of Performance Specification 2.

*(g) Reduction of monitoring data.*

(1) The owner or operator of each CMS must reduce the monitoring data as specified in paragraphs (g)(1) through (5) of this section.

(2) The owner or operator of each COMS shall reduce all data to 6-minute averages calculated from 36 or more data points equally spaced over each 6-minute period. Data from CEMS for measurement other than opacity, unless otherwise specified in the relevant standard, shall be reduced to 1-hour averages computed from four or more data points equally spaced over each 1-hour period, except during periods when calibration, quality assurance, or maintenance activities pursuant to provisions of this part are being performed. During these periods, a valid hourly average shall consist of at least two data points with each representing a 15-minute period. Alternatively, an arithmetic or integrated 1-hour average of CEMS data may be used. Time periods for averaging are defined in § 63.2.

(3) The data may be recorded in reduced or nonreduced form (e.g., ppm pollutant and percent O<sub>2</sub> or ng/J of pollutant).

(4) All emission data shall be converted into units of the relevant standard for reporting purposes using the conversion procedures specified in that standard. After conversion into units of the relevant standard, the data may be rounded to the same number of significant digits as used in that standard to specify the emission limit (e.g., rounded to the nearest 1 percent opacity).

(5) Monitoring data recorded during periods of unavoidable CMS breakdowns, out-of-control periods, repairs, maintenance periods, calibration checks, and zero (low-level) and high-level adjustments must not be included in any data average computed under this part. For the owner or operator complying with the requirements of § 63.10(b)(2)(vii)(A) or (B), data averages must include any data recorded during periods of monitor breakdown or malfunction.

**§ 63.9 Notification requirements.**

*(a) Applicability and general information.*

(1) The applicability of this section is set out in § 63.1(a)(4).

(2) For affected sources that have been granted an extension of compliance under subpart D of this part, the requirements of this section do not apply to those sources while they are operating under such compliance extensions.

(3) If any State requires a notice that contains all the information required in a notification listed in this section, the owner or operator may send the Administrator a copy of the notice sent to the State to satisfy the requirements of this section for that notification.

(4) (i) Before a State has been delegated the authority to implement and enforce notification requirements established under this part, the owner or operator of an affected source in such State subject to such requirements shall submit notifications to the appropriate Regional Office of the EPA (to the attention of the Director of the Division indicated in the list of the EPA Regional Offices in § 63.13).

(ii) After a State has been delegated the authority to implement and enforce notification requirements established under this part, the owner or operator of an affected source in such State subject to such requirements shall submit notifications to the delegated State authority (which may be the same as the permitting authority). In addition, if the delegated (permitting) authority is the State, the owner or operator shall send a copy of each notification submitted to the State to the appropriate Regional Office of the EPA, as specified in paragraph (a)(4)(i) of this section. The Regional Office may waive this requirement for any notifications at its discretion.

*(b) Initial notifications.*

(1) (i) The requirements of this paragraph apply to the owner or operator of an affected source when such source becomes subject to a relevant standard.

(ii) If an area source that otherwise would be subject to an emission standard or other requirement established under this part if it were a major source subsequently increases its emissions of hazardous air pollutants (or its potential to emit hazardous air pollutants) such that the source is a major source that is subject to the emission standard or other requirement, such source shall be subject to the notification requirements of this section.

(iii) Affected sources that are required under this paragraph to submit an initial notification may use the application for approval of construction or reconstruction under § 63.5(d) of this subpart, if relevant, to fulfill the initial notification requirements of this paragraph.



## NESHAP Subpart A for General Provisions

(2) The owner or operator of an affected source that has an initial startup before the effective date of a relevant standard under this part shall notify the Administrator in writing that the source is subject to the relevant standard. The notification, which shall be submitted not later than 120 calendar days after the effective date of the relevant standard (or within 120 calendar days after the source becomes subject to the relevant standard), shall provide the following information:

- (i) The name and address of the owner or operator;
- (ii) The address (i.e., physical location) of the affected source;
- (iii) An identification of the relevant standard, or other requirement, that is the basis of the notification and the source's compliance date;

(iv) A brief description of the nature, size, design, and method of operation of the source and an identification of the types of emission points within the affected source subject to the relevant standard and types of hazardous air pollutants emitted; and

(v) A statement of whether the affected source is a major source or an area source.

(3) [Reserved]

(4) The owner or operator of a new or reconstructed major affected source for which an application for approval of construction or reconstruction is required under § 63.5(d) must provide the following information in writing to the Administrator:

(i) A notification of intention to construct a new major-emitting affected source, reconstruct a major-emitting affected source, or reconstruct a major source such that the source becomes a major-emitting affected source with the application for approval of construction or reconstruction as specified in § 63.5(d)(1)(i); and

(ii) [Reserved]

(iii) [Reserved]

(iv) [Reserved]; and

(v) A notification of the actual date of startup of the source, delivered or postmarked within 15 calendar days after that date.

(5) The owner or operator of a new or reconstructed affected source for which an application for approval of construction or reconstruction is not required under § 63.5(d) must provide the following information in writing to the Administrator:

(i) A notification of intention to construct a new affected source, reconstruct an affected source, or reconstruct a source such that the source becomes an affected source, and

(ii) A notification of the actual date of startup of the source, delivered or postmarked within 15 calendar days after that date.

(iii) Unless the owner or operator has requested and received prior permission from the Administrator to submit less than the information in § 63.5(d), the notification must include the information required on the application for approval of construction or reconstruction as specified in § 63.5(d)(1)(i).

(c) *Request for extension of compliance.* If the owner or operator of an affected source cannot comply with a relevant standard by the applicable compliance date for that source, or if the owner or operator has installed BACT or technology to meet LAER consistent with § 63.6(i)(5) of this subpart, he/she may submit to the Administrator (or the State with an approved permit program) a request for an extension of compliance as specified in § 63.6(i)(4) through § 63.6(i)(6).

(d) *Notification that source is subject to special compliance requirements.* An owner or operator of a new source that is subject to special compliance requirements as specified in § 63.6(b)(3) and § 63.6(b)(4) shall notify the Administrator of his/her compliance obligations not later than the notification dates established in paragraph (b) of this section for new sources that are not subject to the special provisions.

(e) *Notification of performance test.* The owner or operator of an affected source shall notify the Administrator in writing of his or her intention to conduct a performance test at least 60 calendar days before the performance test is scheduled to begin to allow the Administrator to review and approve the site-specific test plan required under § 63.7(c), if requested by the Administrator, and to have an observer present during the test.

(f) *Notification of opacity and visible emission observations.* The owner or operator of an affected source shall notify the Administrator in writing of the anticipated date for conducting the opacity or visible emission observations specified in § 63.6(h)(5), if such observations are required for the source by a relevant standard. The notification shall be submitted with the notification of the performance test date, as specified in paragraph (e) of this section, or if no performance test is required or visibility or other conditions prevent the opacity or visible emission observations from being conducted

## NESHAP Subpart A for General Provisions

concurrently with the initial performance test required under § 63.7, the owner or operator shall deliver or postmark the notification not less than 30 days before the opacity or visible emission observations are scheduled to take place.

(g) *Additional notification requirements for sources with continuous monitoring systems.* The owner or operator of an affected source required to use a CMS by a relevant standard shall furnish the Administrator written notification as follows:

(1) A notification of the date the CMS performance evaluation under § 63.8(e) is scheduled to begin, submitted simultaneously with the notification of the performance test date required under § 63.7(b). If no performance test is required, or if the requirement to conduct a performance test has been waived for an affected source under § 63.7(h), the owner or operator shall notify the Administrator in writing of the date of the performance evaluation at least 60 calendar days before the evaluation is scheduled to begin;

(2) A notification that COMS data results will be used to determine compliance with the applicable opacity emission standard during a performance test required by § 63.7 in lieu of Method 9 or other opacity emissions test method data, as allowed by § 63.6(h)(7)(ii), if compliance with an opacity emission standard is required for the source by a relevant standard. The notification shall be submitted at least 60 calendar days before the performance test is scheduled to begin; and

(3) A notification that the criterion necessary to continue use of an alternative to relative accuracy testing, as provided by § 63.8(f)(6), has been exceeded. The notification shall be delivered or postmarked not later than 10 days after the occurrence of such exceedance, and it shall include a description of the nature and cause of the increased emissions.

(h) *Notification of compliance status.*

(1) The requirements of paragraphs (h)(2) through (h)(4) of this section apply when an affected source becomes subject to a relevant standard.

(2) (i) Before a title V permit has been issued to the owner or operator of an affected source, and each time a notification of compliance status is required under this part, the owner or operator of such source shall submit to the Administrator a notification of compliance status, signed by the responsible official who shall certify its accuracy, attesting to whether the source has complied with the relevant standard. The notification shall list -

(A) The methods that were used to determine compliance;

(B) The results of any performance tests, opacity or visible emission observations, continuous monitoring system (CMS) performance evaluations, and/or other monitoring procedures or methods that were conducted;

(C) The methods that will be used for determining continuing compliance, including a description of monitoring and reporting requirements and test methods;

(D) The type and quantity of hazardous air pollutants emitted by the source (or surrogate pollutants if specified in the relevant standard), reported in units and averaging times and in accordance with the test methods specified in the relevant standard;

(E) If the relevant standard applies to both major and area sources, an analysis demonstrating whether the affected source is a major source (using the emissions data generated for this notification);

(F) A description of the air pollution control equipment (or method) for each emission point, including each control device (or method) for each hazardous air pollutant and the control efficiency (percent) for each control device (or method); and

(G) A statement by the owner or operator of the affected existing, new, or reconstructed source as to whether the source has complied with the relevant standard or other requirements.

(ii) The notification must be sent before the close of business on the 60<sup>th</sup> day following the completion of the relevant compliance demonstration activity specified in the relevant standard (unless a different reporting period is specified in the standard, in which case the letter must be sent before the close of business on the day the report of the relevant testing or monitoring results is required to be delivered or postmarked). For example, the notification shall be sent before close of business on the 60th (or other required) day following completion of the initial performance test and again before the close of business on the 60th (or other required) day following the completion of any subsequent required performance test. If no performance test is required but opacity or visible emission observations are required to demonstrate compliance with an opacity or visible emission standard under this part, the notification of compliance status shall be sent before close of business on the 30th day following the completion of opacity or visible emission observations. Notifications may be combined as long as the due date requirement for each notification is met.

(3) After a title V permit has been issued to the owner or operator of an affected source, the owner or operator of such source shall comply with all requirements for compliance status reports contained in the source's title V permit, including reports required under this part. After a title V permit has been issued to the owner or operator of an affected source, and each time a notification of compliance status is required under this part, the owner or operator of such source shall submit

## NESHAP Subpart A for General Provisions

the notification of compliance status to the appropriate permitting authority following completion of the relevant compliance demonstration activity specified in the relevant standard.

(4) [Reserved]

(5) If an owner or operator of an affected source submits estimates or preliminary information in the application for approval of construction or reconstruction required in § 63.5(d) in place of the actual emissions data or control efficiencies required in paragraphs (d)(1)(ii)(H) and (d)(2) of § 63.5, the owner or operator shall submit the actual emissions data and other correct information as soon as available but no later than with the initial notification of compliance status required in this section.

(6) Advice on a notification of compliance status may be obtained from the Administrator.

(i) *Adjustment to time periods or postmark deadlines for submittal and review of required communications.*

(1) (i) Until an adjustment of a time period or postmark deadline has been approved by the Administrator under paragraphs (i)(2) and (i)(3) of this section, the owner or operator of an affected source remains strictly subject to the requirements of this part.

(ii) An owner or operator shall request the adjustment provided for in paragraphs (i)(2) and (i)(3) of this section each time he or she wishes to change an applicable time period or postmark deadline specified in this part.

(2) Notwithstanding time periods or postmark deadlines specified in this part for the submittal of information to the Administrator by an owner or operator, or the review of such information by the Administrator, such time periods or deadlines may be changed by mutual agreement between the owner or operator and the Administrator. An owner or operator who wishes to request a change in a time period or postmark deadline for a particular requirement shall request the adjustment in writing as soon as practicable before the subject activity is required to take place. The owner or operator shall include in the request whatever information he or she considers useful to convince the Administrator that an adjustment is warranted.

(3) If, in the Administrator's judgment, an owner or operator's request for an adjustment to a particular time period or postmark deadline is warranted, the Administrator will approve the adjustment. The Administrator will notify the owner or operator in writing of approval or disapproval of the request for an adjustment within 15 calendar days of receiving sufficient information to evaluate the request.

(4) If the Administrator is unable to meet a specified deadline, he or she will notify the owner or operator of any significant delay and inform the owner or operator of the amended schedule.

(j) *Change in information already provided.* Any change in the information already provided under this section shall be provided to the Administrator in writing within 15 calendar days after the change.

### § 63.10 Recordkeeping and reporting requirements.

(a) *Applicability and general information.*

(1) The applicability of this section is set out in § 63.1(a)(4).

(2) For affected sources that have been granted an extension of compliance under subpart D of this part, the requirements of this section do not apply to those sources while they are operating under such compliance extensions.

(3) If any State requires a report that contains all the information required in a report listed in this section, an owner or operator may send the Administrator a copy of the report sent to the State to satisfy the requirements of this section for that report.

(4) (i) Before a State has been delegated the authority to implement and enforce recordkeeping and reporting requirements established under this part, the owner or operator of an affected source in such State subject to such requirements shall submit reports to the appropriate Regional Office of the EPA (to the attention of the Director of the Division indicated in the list of the EPA Regional Offices in § 63.13).

(ii) After a State has been delegated the authority to implement and enforce recordkeeping and reporting requirements established under this part, the owner or operator of an affected source in such State subject to such requirements shall submit reports to the delegated State authority (which may be the same as the permitting authority). In addition, if the delegated (permitting) authority is the State, the owner or operator shall send a copy of each report submitted to the State to the appropriate Regional Office of the EPA, as specified in paragraph (a)(4)(i) of this section. The Regional Office may waive this requirement for any reports at its discretion.

(5) If an owner or operator of an affected source in a State with delegated authority is required to submit periodic reports under this part to the State, and if the State has an established timeline for the submission of periodic reports that is consistent with the reporting frequency(ies) specified for such source under this part, the owner or operator may change the dates by which

## NESHAP Subpart A for General Provisions

periodic reports under this part shall be submitted (without changing the frequency of reporting) to be consistent with the State's schedule by mutual agreement between the owner or operator and the State. For each relevant standard established pursuant to section 112 of the Act, the allowance in the previous sentence applies in each State beginning 1 year after the affected source's compliance date for that standard. Procedures governing the implementation of this provision are specified in § 63.9(i).

(6) If an owner or operator supervises one or more stationary sources affected by more than one standard established pursuant to section 112 of the Act, he/she may arrange by mutual agreement between the owner or operator and the Administrator (or the State permitting authority) a common schedule on which periodic reports required for each source shall be submitted throughout the year. The allowance in the previous sentence applies in each State beginning 1 year after the latest compliance date for any relevant standard established pursuant to section 112 of the Act for any such affected source(s). Procedures governing the implementation of this provision are specified in § 63.9(i).

(7) If an owner or operator supervises one or more stationary sources affected by standards established pursuant to section 112 of the Act (as amended November 15, 1990) and standards set under part 60, part 61, or both such parts of this chapter, he/she may arrange by mutual agreement between the owner or operator and the Administrator (or the State permitting authority) a common schedule on which periodic reports required by each relevant (i.e., applicable) standard shall be submitted throughout the year. The allowance in the previous sentence applies in each State beginning 1 year after the stationary source is required to be in compliance with the relevant section 112 standard, or 1 year after the stationary source is required to be in compliance with the applicable part 60 or part 61 standard, whichever is latest. Procedures governing the implementation of this provision are specified in § 63.9(i).

(b) *General recordkeeping requirements.*

(1) The owner or operator of an affected source subject to the provisions of this part shall maintain files of all information (including all reports and notifications) required by this part recorded in a form suitable and readily available for expeditious inspection and review. The files shall be retained for at least 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record. At a minimum, the most recent 2 years of data shall be retained on site. The remaining 3 years of data may be retained off site. Such files may be maintained on microfilm, on a computer, on computer floppy disks, on magnetic tape disks, or on microfiche.

(2) The owner or operator of an affected source subject to the provisions of this part shall maintain relevant records for such source of -

(i) The occurrence and duration of each startup, shutdown, or malfunction of operation (i.e., process equipment);  
 (ii) The occurrence and duration of each malfunction of the required air pollution control and monitoring equipment;

(iii) All required maintenance performed on the air pollution control and monitoring equipment;

(iv) Actions taken during periods of startup, shutdown, and malfunction (including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation) when such actions are different from the procedures specified in the affected source's startup, shutdown, and malfunction plan (see § 63.6(e)(3));

(v) All information necessary to demonstrate conformance with the affected source's startup, shutdown, and malfunction plan (see § 63.6(e)(3)) when all actions taken during periods of startup, shutdown, and malfunction (including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation) are consistent with the procedures specified in such plan. (The information needed to demonstrate conformance with the startup, shutdown, and malfunction plan may be recorded using a "checklist," or some other effective form of recordkeeping, in order to minimize the recordkeeping burden for conforming events);

(vi) Each period during which a CMS is malfunctioning or inoperative (including out-of-control periods);

(vii) All required measurements needed to demonstrate compliance with a relevant standard (including, but not limited to, 15-minute averages of CMS data, raw performance testing measurements, and raw performance evaluation measurements, that support data that the source is required to report);

(A) This paragraph applies to owners or operators required to install a continuous emissions monitoring system (CEMS) where the CEMS installed is automated, and where the calculated data averages do not exclude periods of CEMS breakdown or malfunction. An automated CEMS records and reduces the measured data to the form of the pollutant emission standard through the use of a computerized data acquisition system. In lieu of maintaining a file of all CEMS subhourly measurements as required under paragraph (b)(2)(vii) of this section, the owner or operator shall retain the most recent consecutive three averaging periods of subhourly measurements and a file that contains a hard copy of the data acquisition system algorithm used to reduce the measured data into the reportable form of the standard.

(B) This paragraph applies to owners or operators required to install a

## NESHAP Subpart A for General Provisions

CEMS where the measured data is manually reduced to obtain the reportable form of the standard, and where the calculated data averages do not exclude periods of CEMS breakdown or malfunction. In lieu of maintaining a file of all CEMS subhourly measurements as required under paragraph (b)(2)(vii) of this section, the owner or operator shall retain all subhourly measurements for the most recent reporting period. The subhourly measurements shall be retained for 120 days from the date of the most recent summary or excess emission report submitted to the Administrator.

(C) The Administrator or delegated authority, upon notification to the source, may require the owner or operator to maintain all measurements as required by paragraph (b)(2)(vii), if the administrator or the delegated authority determines these records are required to more accurately assess the compliance status of the affected source.

(viii) All results of performance tests, CMS performance evaluations, and opacity and visible emission observations;

(ix) All measurements as may be necessary to determine the conditions of performance tests and performance evaluations;

(x) All CMS calibration checks;

(xi) All adjustments and maintenance performed on CMS;

(xii) Any information demonstrating whether a source is meeting the requirements for a waiver of recordkeeping or reporting requirements under this part, if the source has been granted a waiver under paragraph (f) of this section;

(xiii) All emission levels relative to the criterion for obtaining permission to use an alternative to the relative accuracy test, if the source has been granted such permission under § 63.8(f)(6); and

(xiv) All documentation supporting initial notifications and notifications of compliance status under § 63.9.

(3) *Recordkeeping requirement for applicability determinations.* If an owner or operator determines that his or her stationary source that emits (or has the potential to emit, without considering controls) one or more hazardous air pollutants regulated by any standard established pursuant to section 112(d) or (f), and that stationary source is in the source category regulated by the relevant standard, but that source is not subject to the relevant standard (or other requirement established under this part) because of limitations on the source's potential to emit or an exclusion, the owner or operator must keep a record of the applicability determination on site at the source for a period of 5 years after the determination, or until the source changes its operations to become an affected source, whichever comes first. The record of the applicability determination must be signed by the person making the determination and include an analysis (or other information) that demonstrates why the owner or operator believes the source is unaffected (e.g., because the source is an area source). The analysis (or other information) must be sufficiently detailed to allow the Administrator to make a finding about the source's applicability status with regard to the relevant standard or other requirement. If relevant, the analysis must be performed in accordance with requirements established in relevant subparts of this part for this purpose for particular categories of stationary sources. If relevant, the analysis should be performed in accordance with EPA guidance materials published to assist sources in making applicability determinations under section 112, if any. The requirements to determine applicability of a standard under § 63.1(b)(3) and to record the results of that determination under paragraph (b)(3) of this section shall not by themselves create an obligation for the owner or operator to obtain a title V permit.

(c) *Additional recordkeeping requirements for sources with continuous monitoring systems.* In addition to complying with the requirements specified in paragraphs (b)(1) and (b)(2) of this section, the owner or operator of an affected source required to install a CMS by a relevant standard shall maintain records for such source of -

(1) All required CMS measurements (including monitoring data recorded during unavoidable CMS breakdowns and out-of-control periods);

(2)-(4) [Reserved]

(5) The date and time identifying each period during which the CMS was inoperative except for zero (low-level) and high-level checks;

(6) The date and time identifying each period during which the CMS was out of control, as defined in § 63.8(c)(7);

(7) The specific identification (i.e., the date and time of commencement and completion) of each period of excess emissions and parameter monitoring exceedances, as defined in the relevant standard(s), that occurs during startups, shutdowns, and malfunctions of the affected source;

(8) The specific identification (i.e., the date and time of commencement and completion) of each time period of excess emissions and parameter monitoring exceedances, as defined in the relevant standard(s), that occurs during periods other than startups, shutdowns, and malfunctions of the affected source;

(9) [Reserved]

(10) The nature and cause of any malfunction (if known);

(11) The corrective action taken or preventive measures adopted;

(12) The nature of the repairs or adjustments to the CMS that was inoperative or out of control;

(13) The total process operating time during the reporting period; and

(14) All procedures that are part of a quality control program developed and implemented for CMS under § 63.8(d).

(15) In order to satisfy the requirements of paragraphs (c)(10) through (c)(12) of this section and to avoid duplicative recordkeeping efforts, the owner or operator may use the affected source's startup, shutdown, and malfunction plan or records kept to satisfy the recordkeeping requirements of the startup, shutdown, and malfunction plan specified in § 63.6(e), provided that such plan and records adequately address the requirements of paragraphs (c)(10) through (c)(12).

(d) *General reporting requirements.*

(1) Notwithstanding the requirements in this paragraph or paragraph (e) of this section, the owner or operator of an affected source subject to reporting requirements under this part shall submit reports to the Administrator in accordance with the reporting requirements in the relevant standard(s).

(2) *Reporting results of performance tests.* Before a title V permit has been issued to the owner or operator of an affected source, the owner or operator shall report the results of any performance test under § 63.7 to the Administrator. After a title V permit has been issued to the owner or operator of an affected source, the owner or operator shall report the results of a required performance test to the appropriate permitting authority. The owner or operator of an affected source shall report the results of the performance test to the Administrator (or the State with an approved permit program) before the close of business on the 60th day following the completion of the performance test, unless specified otherwise in a relevant standard or as approved otherwise in writing by the Administrator. The results of the performance test shall be submitted as part of the notification of compliance status required under § 63.9(h).

(3) *Reporting results of opacity or visible emission observations.* The owner or operator of an affected source required to conduct opacity or visible emission observations by a relevant standard shall report the opacity or visible emission results (produced using Test Method 9 or Test Method 22, or an alternative to these test methods) along with the results of the performance test required under § 63.7. If no performance test is required, or if visibility or other conditions prevent the opacity or visible emission observations from being conducted concurrently with the performance test required under § 63.7, the owner or operator shall report the opacity or visible emission results before the close of business on the 30th day following the completion of the opacity or visible emission observations.

(4) *Progress reports.* The owner or operator of an affected source who is required to submit progress reports as a condition of receiving an extension of compliance under § 63.6(i) shall submit such reports to the Administrator (or the State with an approved permit program) by the dates specified in the written extension of compliance.

(5) (i) *Periodic startup, shutdown, and malfunction reports.* If actions taken by an owner or operator during a startup, shutdown, or malfunction of an affected source (including actions taken to correct a malfunction) are consistent with the procedures specified in the source's startup, shutdown, and malfunction plan (see Sec. 63.6(e)(3)), the owner or operator shall state such information in a startup, shutdown, and malfunction report. Such a report shall identify any instance where any action taken by an owner or operator during a startup, shutdown, or malfunction (including actions taken to correct a malfunction) is not consistent with the affected source's startup, shutdown, and malfunction plan, but the source does not exceed any applicable emission limitation in the relevant emission standard. Such a report shall also include the number, duration, and a brief description for each type of malfunction which occurred during the reporting period and which caused or may have caused any applicable emission limitation to be exceeded. Reports shall only be required if a startup, shutdown, or malfunction occurred during the reporting period. The startup, shutdown, and malfunction report shall consist of a letter, containing the name, title, and signature of the owner or operator or other responsible official who is certifying its accuracy, that shall be submitted to the Administrator semiannually (or on a more frequent basis if specified otherwise in a relevant standard or as established otherwise by the permitting authority in the source's title V permit). The startup, shutdown, and malfunction report shall be delivered or postmarked by the 30th day following the end of each calendar half (or other calendar reporting period, as appropriate). If the owner or operator is required to submit excess emissions and continuous monitoring system performance (or other periodic) reports under this part, the startup, shutdown, and malfunction reports required under this paragraph may be submitted simultaneously with the excess emissions and continuous monitoring system performance (or other) reports. If startup, shutdown, and malfunction reports are submitted with excess emissions and continuous monitoring system performance (or other periodic) reports, and the owner or operator receives approval to reduce the frequency of reporting for the latter under paragraph (e) of this section, the frequency of reporting for the startup, shutdown, and malfunction reports also may be reduced if the Administrator does not object to the intended change. The procedures to implement the allowance in the preceding sentence shall be the same as the procedures specified in paragraph (e)(3) of this section.

(ii) *Immediate startup, shutdown, and malfunction reports.* Notwithstanding the allowance to reduce the frequency of reporting for periodic startup, shutdown, and malfunction reports under paragraph (d)(5)(i) of this section, any time an action taken by an owner or operator during a startup, shutdown, or malfunction (including actions taken to correct a malfunction) is not consistent with the procedures specified in the affected source's startup, shutdown, and malfunction plan, and the source exceeds any applicable emission limitation in the relevant emission standard, the owner or

## NESHAP Subpart A for General Provisions

operator shall report the actions taken for that event within 2 working days after commencing actions inconsistent with the plan followed by a letter within 7 working days after the end of the event. The immediate report required under this paragraph (d)(5)(ii) shall consist of a telephone call (or facsimile (FAX) transmission) to the Administrator within 2 working days after commencing actions inconsistent with the plan, and it shall be followed by a letter, delivered or postmarked within 7 working days after the end of the event, that contains the name, title, and signature of the owner or operator or other responsible official who is certifying its accuracy, explaining the circumstances of the event, the reasons for not following the startup, shutdown, and malfunction plan, and describing all excess emissions and/or parameter monitoring exceedances which are believed to have occurred. Notwithstanding the requirements of the previous sentence, after the effective date of an approved permit program in the State in which an affected source is located, the owner or operator may make alternative reporting arrangements, in advance, with the permitting authority in that State. Procedures governing the arrangement of alternative reporting requirements under this paragraph (d)(5)(ii) are specified in Sec. 63.9(i).

(e) *Additional reporting requirements for sources with continuous monitoring systems -*

(1) *General.* When more than one CEMS is used to measure the emissions from one affected source (e.g., multiple breechings, multiple outlets), the owner or operator shall report the results as required for each CEMS.

(2) Reporting results of continuous monitoring system performance evaluations.

(i) The owner or operator of an affected source required to install a CMS by a relevant standard shall furnish the Administrator a copy of a written report of the results of the CMS performance evaluation, as required under § 63.8(e), simultaneously with the results of the performance test required under § 63.7, unless otherwise specified in the relevant standard.

(ii) The owner or operator of an affected source using a COMS to determine opacity compliance during any performance test required under § 63.7 and described in § 63.6(d)(6) shall furnish the Administrator two or, upon request, three copies of a written report of the results of the COMS performance evaluation conducted under § 63.8(e). The copies shall be furnished at least 15 calendar days before the performance test required under § 63.7 is conducted.

(3) *Excess emissions and continuous monitoring system performance report and summary report.*

(i) Excess emissions and parameter monitoring exceedances are defined in relevant standards. The owner or operator of an affected source required to install a CMS by a relevant standard shall submit an excess emissions and continuous monitoring system performance report and/or a summary report to the Administrator semiannually, except when

(A) More frequent reporting is specifically required by a relevant standard;

(B) The Administrator determines on a case-by-case basis that more frequent reporting is necessary to accurately assess the compliance status of the source; or

(C) [Reserved].

(ii) Request to reduce frequency of excess emissions and continuous monitoring system performance reports. Notwithstanding the frequency of reporting requirements specified in paragraph (e)(3)(i) of this section, an owner or operator who is required by a relevant standard to submit excess emissions and continuous monitoring system performance (and summary) reports on a quarterly (or more frequent) basis may reduce the frequency of reporting for that standard to semiannual if the following conditions are met:

(A) For 1 full year (e.g., 4 quarterly or 12 monthly reporting periods) the affected source's excess emissions and continuous monitoring system performance reports continually demonstrate that the source is in compliance with the relevant standard;

(B) The owner or operator continues to comply with all recordkeeping and monitoring requirements specified in this subpart and the relevant standard; and

(C) The Administrator does not object to a reduced frequency of reporting for the affected source, as provided in paragraph (e)(3)(iii) of this section.

(iii) The frequency of reporting of excess emissions and continuous monitoring system performance (and summary) reports required to comply with a relevant standard may be reduced only after the owner or operator notifies the Administrator in writing of his or her intention to make such a change and the Administrator does not object to the intended change. In deciding whether to approve a reduced frequency of reporting, the Administrator may review information concerning the source's entire previous performance history during the 5-year recordkeeping period prior to the intended change, including performance test results, monitoring data, and evaluations of an owner or operator's conformance with operation and maintenance requirements. Such information may be used by the Administrator to make a judgment about the source's potential for noncompliance in the future. If the Administrator disapproves the owner or operator's request to reduce the frequency of reporting, the Administrator will notify the owner or operator in writing within 45 days after receiving notice of the owner or operator's intention. The notification from the Administrator to the owner or operator will specify the grounds on which the disapproval is based. In the absence of a notice of disapproval within 45 days, approval is automatically granted.

## NESHAP Subpart A for General Provisions

(iv) As soon as CMS data indicate that the source is not in compliance with any emission limitation or operating parameter specified in the relevant standard, the frequency of reporting shall revert to the frequency specified in the relevant standard, and the owner or operator shall submit an excess emissions and continuous monitoring system performance (and summary) report for the noncomplying emission points at the next appropriate reporting period following the noncomplying event. After demonstrating ongoing compliance with the relevant standard for another full year, the owner or operator may again request approval from the Administrator to reduce the frequency of reporting for that standard, as provided for in paragraphs (e)(3)(ii) and (e)(3)(iii) of this section.

(v) *Content and submittal dates for excess emissions and monitoring system performance reports.* All excess emissions and monitoring system performance reports and all summary reports, if required, shall be delivered or postmarked by the 30th day following the end of each calendar half or quarter, as appropriate. Written reports of excess emissions or exceedances of process or control system parameters shall include all the information required in paragraphs (c)(5) through (c)(13) of this section, in § 63.8(c)(7) and § 63.8(c)(8), and in the relevant standard, and they shall contain the name, title, and signature of the responsible official who is certifying the accuracy of the report. When no excess emissions or exceedances of a parameter have occurred, or a CMS has not been inoperative, out of control, repaired, or adjusted, such information shall be stated in the report.

(vi) *Summary report.* As required under paragraphs (e)(3)(vii) and (e)(3)(viii) of this section, one summary report shall be submitted for the hazardous air pollutants monitored at each affected source (unless the relevant standard specifies that more than one summary report is required, e.g., one summary report for each hazardous air pollutant monitored). The summary report shall be entitled "Summary Report - Gaseous and Opacity Excess Emission and Continuous Monitoring System Performance" and shall contain the following information:

(A) The company name and address of the affected source;

(B) An identification of each hazardous air pollutant monitored at the affected source;

(C) The beginning and ending dates of the reporting period;

(D) A brief description of the process units;

(E) The emission and operating parameter limitations specified in the relevant standard(s);

(F) The monitoring equipment manufacturer(s) and model number(s);

(G) The date of the latest CMS certification or audit;

(H) The total operating time of the affected source during the reporting period;

(I) An emission data summary (or similar summary if the owner or operator monitors control system parameters), including the total duration of excess emissions during the reporting period (recorded in minutes for opacity and hours for gases), the total duration of excess emissions expressed as a percent of the total source operating time during that reporting period, and a breakdown of the total duration of excess emissions during the reporting period into those that are due to startup/shutdown, control equipment problems, process problems, other known causes, and other unknown causes;

(J) A CMS performance summary (or similar summary if the owner or operator monitors control system parameters), including the total CMS downtime during the reporting period (recorded in minutes for opacity and hours for gases), the total duration of CMS downtime expressed as a percent of the total source operating time during that reporting period, and a breakdown of the total CMS downtime during the reporting period into periods that are due to monitoring equipment malfunctions, nonmonitoring equipment malfunctions, quality assurance/quality control calibrations, other known causes, and other unknown causes;

(K) A description of any changes in CMS, processes, or controls since the last reporting period;

(L) The name, title, and signature of the responsible official who is certifying the accuracy of the report;

and

(M) The date of the report.

(vii) If the total duration of excess emissions or process or control system parameter exceedances for the reporting period is less than 1 percent of the total operating time for the reporting period, and CMS downtime for the reporting period is less than 5 percent of the total operating time for the reporting period, only the summary report shall be submitted, and the full excess emissions and continuous monitoring system performance report need not be submitted unless required by the Administrator.

(viii) If the total duration of excess emissions or process or control system parameter exceedances for the reporting period is 1 percent or greater of the total operating time for the reporting period, or the total CMS downtime for the reporting period is 5 percent or greater of the total operating time for the reporting period, both the summary report and the excess emissions and continuous monitoring system performance report shall be submitted.

(4) Reporting continuous opacity monitoring system data produced during a performance test. The owner or operator of an affected source required to use a COMS shall record the monitoring data produced during a performance test required under § 63.7 and shall furnish the Administrator a written report of the monitoring results. The report of COMS data shall be submitted simultaneously with the report of the performance test results required in paragraph (d)(2) of this section.



## NESHAP Subpart A for General Provisions

- (iv) Data recording, calculations, and reporting;
- (v) Accuracy audit procedures, including sampling and analysis methods; and
- (vi) Program of corrective action for a malfunctioning CMS.

(3) The owner or operator shall keep these written procedures on record for the life of the affected source or until the affected source is no longer subject to the provisions of this part, to be made available for inspection, upon request, by the Administrator. If the performance evaluation plan is revised, the owner or operator shall keep previous (i.e., superseded) versions of the performance evaluation plan on record to be made available for inspection, upon request, by the Administrator, for a period of 5 years after each revision to the plan. Where relevant, e.g., program of corrective action for a malfunctioning CMS, these written procedures may be incorporated as part of the affected source's startup, shutdown, and malfunction plan to avoid duplication of planning and recordkeeping efforts.

(e) *Performance evaluation of continuous monitoring systems -*

(1) *General.* When required by a relevant standard, and at any other time the Administrator may require under section 114 of the Act, the owner or operator of an affected source being monitored shall conduct a performance evaluation of the CMS. Such performance evaluation shall be conducted according to the applicable specifications and procedures described in this section or in the relevant standard.

(2) *Notification of performance evaluation.* The owner or operator shall notify the Administrator in writing of the date of the performance evaluation simultaneously with the notification of the performance test date required under § 63.7(b) or at least 60 days prior to the date the performance evaluation is scheduled to begin if no performance test is required.

(3) (i) *Submission of site-specific performance evaluation test plan.* Before conducting a required CMS performance evaluation, the owner or operator of an affected source shall develop and submit a site-specific performance evaluation test plan to the Administrator for approval upon request. The performance evaluation test plan shall include the evaluation program objectives, an evaluation program summary, the performance evaluation schedule, data quality objectives, and both an internal and external QA program. Data quality objectives are the pre-evaluation expectations of precision, accuracy, and completeness of data.

(ii) The internal QA program shall include, at a minimum, the activities planned by routine operators and analysts to provide an assessment of CMS performance. The external QA program shall include, at a minimum, systems audits that include the opportunity for on-site evaluation by the Administrator of instrument calibration, data validation, sample logging, and documentation of quality control data and field maintenance activities.

(iii) The owner or operator of an affected source shall submit the site-specific performance evaluation test plan to the Administrator (if requested) at least 60 days before the performance test or performance evaluation is scheduled to begin, or on a mutually agreed upon date, and review and approval of the performance evaluation test plan by the Administrator will occur with the review and approval of the site-specific test plan (if review of the site-specific test plan is requested).

(iv) The Administrator may request additional relevant information after the submittal of a site-specific performance evaluation test plan.

(v) In the event that the Administrator fails to approve or disapprove the site-specific performance evaluation test plan within the time period specified in § 63.7(c)(3), the following conditions shall apply:

(A) If the owner or operator intends to demonstrate compliance using the monitoring method(s) specified in the relevant standard, the owner or operator shall conduct the performance evaluation within the time specified in this subpart using the specified method(s);

(B) If the owner or operator intends to demonstrate compliance by using an alternative to a monitoring method specified in the relevant standard, the owner or operator shall refrain from conducting the performance evaluation until the Administrator approves the use of the alternative method. If the Administrator does not approve the use of the alternative method within 30 days before the performance evaluation is scheduled to begin, the performance evaluation deadlines specified in paragraph (e)(4) of this section may be extended such that the owner or operator shall conduct the performance evaluation within 60 calendar days after the Administrator approves the use of the alternative method. Notwithstanding the requirements in the preceding two sentences, the owner or operator may proceed to conduct the performance evaluation as required in this section (without the Administrator's prior approval of the site-specific performance evaluation test plan) if he/she subsequently chooses to use the specified monitoring method(s) instead of an alternative.

(vi) Neither the submission of a site-specific performance evaluation test plan for approval, nor the Administrator's approval or disapproval of a plan, nor the Administrator's failure to approve or disapprove a plan in a timely manner shall -

(A) Relieve an owner or operator of legal responsibility for compliance with any applicable provisions of this part or with any other applicable Federal, State, or local requirement; or

*(f) Waiver of recordkeeping or reporting requirements.*

(1) Until a waiver of a recordkeeping or reporting requirement has been granted by the Administrator under this paragraph, the owner or operator of an affected source remains subject to the requirements of this section.

(2) Recordkeeping or reporting requirements may be waived upon written application to the Administrator if, in the Administrator's judgment, the affected source is achieving the relevant standard(s), or the source is operating under an extension of compliance, or the owner or operator has requested an extension of compliance and the Administrator is still considering that request.

(3) If an application for a waiver of record-keeping or reporting is made, the application shall accompany the request for an extension of compliance under § 63.6(i), any required compliance progress report or compliance status report required under this part (such as under § 63.6(i) and § 63.9(h)) or in the source's title V permit, or an excess emissions and continuous monitoring system performance report required under paragraph (e) of this section, whichever is applicable. The application shall include whatever information the owner or operator considers useful to convince the Administrator that a waiver of recordkeeping or reporting is warranted.

(4) The Administrator will approve or deny a request for a waiver of recordkeeping or reporting requirements under this paragraph when he/she -

(i) Approves or denies an extension of compliance; or

(ii) Makes a determination of compliance following the submission of a required compliance status report or excess emissions and continuous monitoring systems performance report; or

(iii) Makes a determination of suitable progress towards compliance following the submission of a compliance progress report, whichever is applicable.

(5) A waiver of any recordkeeping or reporting requirement granted under this paragraph may be conditioned on other recordkeeping or reporting requirements deemed necessary by the Administrator.

(6) Approval of any waiver granted under this section shall not abrogate the Administrator's authority under the Act or in any way prohibit the Administrator from later canceling the waiver. The cancellation will be made only after notice is given to the owner or operator of the affected source.

**§ 63.11 Control device requirements.**

(a) *Applicability.* The applicability of this section is set out in Sec. 63.1(a)(4).

*(b) Flares.*

(1) Owners or operators using flares to comply with the provisions of this part shall monitor these control devices to assure that they are operated and maintained in conformance with their designs. Applicable subparts will provide provisions stating how owners or operators using flares shall monitor these control devices.

(2) Flares shall be steam-assisted, air-assisted, or non-assisted.

(3) Flares shall be operated at all times when emissions may be vented to them.

(4) Flares shall be designed for and operated with no visible emissions, except for periods not to exceed a total of 5 minutes during any 2 consecutive hours. Test Method 22 in appendix A of part 60 of this chapter shall be used to determine the compliance of flares with the visible emission provisions of this part. The observation period is 2 hours and shall be used according to Method 22.

(5) Flares shall be operated with a flame present at all times. The presence of a flare pilot flame shall be monitored using a thermocouple or any other equivalent device to detect the presence of a flame.

(6) An owner/operator has the choice of adhering to the heat content specifications in paragraph (b)(6)(ii) of this section, and the maximum tip velocity specifications in paragraph (b)(7) or (b)(8) of this section, or adhering to the requirements in paragraph (b)(6)(i) of this section.

(i) (A) Flares shall be used that have a diameter of 3 inches or greater, are nonassisted, have a hydrogen content of 8.0 percent (by volume) or greater, and are designed for and operated with an exit velocity less than 37.2 m/sec (122 ft/sec) and less than the velocity  $V_{max}$ , as determined by the following equation:

$$V_{max} = (X_{H2} - K_1) * K_2$$

Where:

$V_{max}$  = Maximum permitted velocity, m/sec.

$K_1$  = Constant, 6.0 volume-percent hydrogen.

$K_2$  = Constant, 3.9 (m/sec)/volume-percent hydrogen.

## NESHAP Subpart A for General Provisions

$X_{H_2}$  = The volume-percent of hydrogen, on a wet basis, as calculated by using the American Society for Testing and Materials (ASTM) Method D1946-77. (Incorporated by reference as specified in § 63.14).

(B) The actual exit velocity of a flare shall be determined by the method specified in paragraph (b)(7)(i) of this section.

(ii) Flares shall be used only with the net heating value of the gas being combusted at 11.2 MJ/scm (300 Btu/scf) or greater if the flare is steam-assisted or air-assisted; or with the net heating value of the gas being combusted at 7.45 MJ/scm (200 Btu/scf) or greater if the flare is non-assisted. The net heating value of the gas being combusted in a flare shall be calculated using the following equation:

$$H_T = \sum_{i=1}^n K_i C_i H_i$$

Where:

$H_T$  = Net heating value of the sample, MJ/scm; where the net enthalpy per mole of offgas is based on combustion at 25 °C and 760 mm Hg, but the standard temperature for determining the volume corresponding to one mole is 20 °C.

$K$  = Constant =  $1.740 \times 10^{-7}$  (1/ppmv)(g-mole/scm)(MJ/kcal); where the standard temperature for (g-mole/scm) is 20 °C.

$C_i$  = Concentration of sample component  $i$  in ppmv on a wet basis, as measured for organics by Test Method 18 and measured for hydrogen and carbon monoxide by American Society for Testing and Materials (ASTM) D1946-77 or 90 (Reapproved 1994) (incorporated by reference as specified in § 63.14).

$H_i$  = Net heat of combustion of sample component  $i$ , kcal/g-mole at 25 °C and 760 mm Hg. The heats of combustion may be determined using ASTM D2382-76 or 88 or D4809-95. (incorporated by reference as specified in § 63.14) if published values are not available or cannot be calculated.

$n$  = Number of sample components.

(7) (i) Steam-assisted and nonassisted flares shall be designed for and operated with an exit velocity less than 18.3 m/sec (60 ft/sec), except as provided in paragraphs (b)(7)(ii) and (b)(7)(iii) of this section. The actual exit velocity of a flare shall be determined by dividing by the volumetric flow rate of gas being combusted (in units of emission standard temperature and pressure), as determined by Test Method 2, 2A, 2C, or 2D in appendix A to 40 CFR part 60 of this chapter, as appropriate, by the unobstructed (free) cross-sectional area of the flare tip.

(ii) Steam-assisted and nonassisted flares designed for and operated with an exit velocity, as determined by the method specified in paragraph (b)(7)(i) of this section, equal to or greater than 18.3 m/sec (60 ft/sec) but less than 122 m/sec (400 ft/sec), are allowed if the net heating value of the gas being combusted is greater than 37.3 MJ/scm (1,000 Btu/scf).

(iii) Steam-assisted and nonassisted flares designed for and operated with an exit velocity, as determined by the method specified in paragraph (b)(7)(i) of this section, less than the velocity  $V_{max}$ , as determined by the method specified in this paragraph, but less than 122 m/sec (400 ft/sec) are allowed. The maximum permitted velocity,  $V_{max}$ , for flares complying with this paragraph shall be determined by the following equation:

$$\text{Log}_{10}(V_{max}) = (H_T + 28.8) / 31.7$$

Where:

$V_{max}$  = Maximum permitted velocity, m/sec.

28.8 = Constant.

31.7 = Constant.

$H_T$  = The net heating value as determined in paragraph (b)(6) of this section.

(8) Air-assisted flares shall be designed and operated with an exit velocity less than the velocity  $V_{max}$ . The maximum permitted velocity,  $V_{max}$ , for air-assisted flares shall be determined by the following equation:

$$V_{max} = 8.71 + 0.708(H_T)$$

Where:

$V_{max}$  = Maximum permitted velocity, m/sec.

8.71 = Constant.

0.708 = Constant.

$H_T$  = The net heating value as determined in paragraph (b)(6)(ii) of this section.

### § 63.12 State authority and delegations.

(a) The provisions of this part shall not be construed in any manner to preclude any State or political subdivision thereof from -

(1) Adopting and enforcing any standard, limitation, prohibition, or other regulation applicable to an affected source subject to the requirements of this part, provided that such standard, limitation, prohibition, or regulation is not less stringent than any requirement applicable to such source established under this part;

(2) Requiring the owner or operator of an affected source to obtain permits, licenses, or approvals prior to initiating construction, reconstruction, modification, or operation of such source; or

(3) Requiring emission reductions in excess of those specified in subpart D of this part as a condition for granting the extension of compliance authorized by section 112(i)(5) of the Act.

(b) (1) Section 112(l) of the Act directs the Administrator to delegate to each State, when appropriate, the authority to implement and enforce standards and other requirements pursuant to section 112 for stationary sources located in that State. Because of the unique nature of radioactive material, delegation of authority to implement and enforce standards that control radionuclides may require separate approval.

(2) Subpart E of this part establishes procedures consistent with section 112(l) for the approval of State rules or programs to implement and enforce applicable Federal rules promulgated under the authority of section 112. Subpart E also establishes procedures for the review and withdrawal of section 112 implementation and enforcement authorities granted through a section 112(l) approval.

(c) All information required to be submitted to the EPA under this part also shall be submitted to the appropriate State agency of any State to which authority has been delegated under section 112(l) of the Act, provided that each specific delegation may exempt sources from a certain Federal or State reporting requirement. The Administrator may permit all or some of the information to be submitted to the appropriate State agency only, instead of to the EPA and the State agency.

### § 63.13 Addresses of State air pollution control agencies and EPA Regional Offices.

(a) All requests, reports, applications, submittals, and other communications to the Administrator pursuant to this part shall be submitted to the appropriate Regional Office of the U.S. Environmental Protection Agency indicated as follows:

EPA Region IV (Alabama, Florida, Georgia, Kentucky, Mississippi, North Carolina, South Carolina, Tennessee). Director; Air, Pesticides and Toxics Management Division; Atlanta Federal Center, 61 Forsyth Street; Atlanta, GA 30303-3104.

(b) All information required to be submitted to the Administrator under this part also shall be submitted to the appropriate State agency of any State to which authority has been delegated under section 112(l) of the Act. The owner or operator of an affected source may contact the appropriate EPA Regional Office for the mailing addresses for those States whose delegation requests have been approved.

(c) If any State requires a submittal that contains all the information required in an application, notification, request, report, statement, or other communication required in this part, an owner or operator may send the appropriate Regional Office of the EPA a copy of that submittal to satisfy the requirements of this part for that communication.

### § 63.14 Incorporations by reference.

(a) The materials listed in this section are incorporated by reference in the corresponding sections noted. These incorporations by reference were approved by the Director of the Federal Register in accordance with 5 U.S.C. 552(a) and 1 CFR part 51. These materials are incorporated as they exist on the date of the approval, and notice of any change in these materials will be published in the Federal Register. The materials are available for purchase at the corresponding addresses noted below, and all are available for inspection at the Office of the Federal Register, 800 North Capitol Street, NW., suite

700, Washington, DC, at the Air and Radiation Docket and Information Center, U.S. EPA, 401 M St., SW., Washington, DC, and at the EPA Library (MD-35), U.S. EPA, Research Triangle Park, North Carolina.

- (b) The following materials are available for purchase from at least one of the following addresses: American Society for Testing and Materials (ASTM), 100 Barr Harbor Drive, Post Office Box C700, West Conshohocken, PA 19428-2959; or ProQuest, 300 North Zeeb Road, Ann Arbor, MI 48106.
- (1) ASTM D523-89, Standard Test Method for Specular Gloss, IBR approved for § 63.782.
  - (2) ASTM D1193-77, 91, Standard Specification for Reagent Water, IBR approved for Appendix A: Method 306, Sections 7.1.1 and 7.4.2.
  - (3) ASTM D1331-89, Standard Test Methods for Surface and Interfacial Tension of Solutions of Surface Active Agents, IBR approved for Appendix A: Method 306B, Sections 6.2, 11.1, and 12.2.2.
  - (4) ASTM D1475-90, Standard Test Method for Density of Paint, Varnish Lacquer, and Related Products, IBR approved for § 63.788, Appendix A.
  - (5) ASTM D1946-77, 90, 94, Standard Method for Analysis of Reformed Gas by Gas Chromatography, IBR approved for § 63.11(b)(6).
  - (6) ASTM D2369-93, 95, Standard Test Method for Volatile Content of Coatings, IBR approved for § 63.788, Appendix A.
  - (7) ASTM D2382-76, 88, Heat of Combustion of Hydrocarbon Fuels by Bomb Calorimeter (High-Precision Method), IBR approved for § 63.11(b)(6).
  - (8) ASTM D2879-83, 96, Test Method for Vapor Pressure-Temperature Relationship and Initial Decomposition Temperature of Liquids by Isotenoscope, IBR approved for § 63.111 of Subpart G.
  - (9) ASTM D3257-93, Standard Test Methods for Aromatics in Mineral Spirits by Gas Chromatography, IBR approved for § 63.786(b).
  - (10) ASTM 3695-88, Standard Test Method for Volatile Alcohols in Water by Direct Aqueous-Injection Gas Chromatography, IBR approved for § 63.365(e)(1) of Subpart O.
  - (11) ASTM D3792-91, Standard Method for Water Content of Water-Reducible Paints by Direct Injection into a Gas Chromatograph, IBR approved for § 63.788, Appendix A.
  - (12) ASTM D3912-80, Standard Test Method for Chemical Resistance of Coatings Used in Light-Water Nuclear Power Plants, IBR approved for § 63.782.
  - (13) ASTM D4017-90, 96a, Standard Test Method for Water in Paints and Paint Materials by the Karl Fischer Titration Method, IBR approved for § 63.788, Appendix A.
  - (14) ASTM D4082-89, Standard Test Method for Effects of Gamma Radiation on Coatings for Use in Light-Water Nuclear Power Plants, IBR approved for § 63.782.
  - (15) ASTM D4256-89, 94, Standard Test Method for Determination of the Decontaminability of Coatings Used in Light-Water Nuclear Power Plants, IBR approved for § 63.782.
  - (16) ASTM D4809-95, Standard Test Method for Heat of Combustion of Liquid Hydrocarbon Fuels by Bomb Calorimeter (Precision Method), IBR approved for § 63.11(b)(6).
  - (17) ASTM E180-93, Standard Practice for Determining the Precision of ASTM Methods for Analysis and Testing of Industrial Chemicals, IBR approved for § 63.786(b).
  - (18) ASTM E260-91, 96, General Practice for Packed Column Gas Chromatography, IBR approved for §§ 63.750(b)(2) and 63.786(b)(5).
  - (19) Reserved
  - (20) Reserved
  - (21) ASTM D2099-00, Standard Test Method for Dynamic Water Resistance of Shoe Upper Leather by the Maeser Water Penetration Tester, IBR approved for § 63.5350.
  - (24) ASTM D2697-86 (Reapproved 1998), "Standard Test Method for Volume Nonvolatile Matter in Clear or Pigmented Coatings," IBR approved for Sec. Sec. 63.3161(f)(1), 63.3521(b)(1), 63.3941(b)(1), 63.4141(b)(1), 63.4741(b)(1), 63.4941(b)(1), and 63.5160(c).
  - (25) ASTM D6093-97 (Reapproved 2003), "Standard Test Method for Percent Volume Nonvolatile Matter in Clear or Pigmented Coatings Using a Helium Gas Pycnometer," IBR approved for Sec. Sec. 63.3161(f)(1), 63.3521(b)(1), 63.3941(b)(1), 63.4141(b)(1), 63.4741(b)(1), 63.4941(b)(1), and 63.5160(c).
  - (26) ASTM D1475-98 (Reapproved 2003), "Standard Test Method for Density of Liquid Coatings, Inks, and Related Products," IBR approved for Sec. Sec. 63.3151(b), 63.3941(b)(4), 63.3941(c), 63.3951(c), 63.4141(b)(3), 63.4141(c), and 63.4551(c).
  - (27) ASTM D 6522-00, Standard Test Method for Determination of Nitrogen Oxides, Carbon Monoxide and Oxygen concentrations in Emissions from Natural Gas Fired Reciprocating Engines, Combustion Turbines, Boilers, and Process heaters Using Portable Analyzers, IBR approved for Sec. 63.9307(c)(2).

- (28) [Reserved]
- (29) ASTM D6420-99, Standard Test Method for Determination of Gaseous Organic Compounds by Direct Interface Gas Chromatography-Mass Spectrometry, IBR approved for §§ 63.5799 and 63.5850.
- (30) ASTM E 515-95 (Reapproved 2000), Standard Test Method for Leaks Using Bubble Emission Techniques, IBR approved for Sec. 63.425(i)(2).
- (31) ASTM D5291-02, Standard Test Methods for Instrumental Determination of Carbon, Hydrogen, and Nitrogen in Petroleum Products and Lubricants, IBR approved for Sec. 63.3981, appendix A.
- (32) ASTM D5965-02, "Standard Test Methods for Specific Gravity of Coating Powders," IBR approved for Sec. 63.3151(b) and 63.3951(c).
- (33) ASTM D6053-00, Standard Test Method for Determination of Volatile Organic Compound (VOC) Content of Electrical Insulating Varnishes, IBR approved for Sec. 63.3981, appendix A.
- (34) E145-94 (Reapproved 2001), Standard Specification for Gravity-Convection and Forced-Ventilation Ovens, IBR approved for Sec. 63.4581, Appendix A.
- (35) [Reserved]
- (36) ASTM D5066-91 (Reapproved 2001), "Standard Test Method for Determination of the Transfer Efficiency Under Production Conditions for Spray Application of Automotive Paints-Weight Basis," IBR approved for Sec. 63.3161(g).
- (37) ASTM D5087-02, "Standard Test Method for Determining Amount of Volatile Organic Compound (VOC) Released from Solventborne Automotive Coatings and Available for Removal in a VOC Control Device (Abatement)," IBR approved for Sec. 63.3165(e) and 63.3176, appendix A.
- (38) ASTM D6266-00a, "Test Method for Determining the Amount of Volatile Organic Compound (VOC) Released from Waterborne Automotive Coatings and Available for Removal in a VOC Control Device (Abatement)," IBR approved for Sec. 63.3165(e).

(c) The materials listed below are available for purchase from the American Petroleum Institute (API), 1220 L Street, NW., Washington, DC 20005.

- (1) API Publication 2517, Evaporative Loss from External Floating-Roof Tanks, Third Edition, February 1989, IBR approved for § 63.111 of subpart G of this part.
- (2) API Publication 2518, Evaporative Loss from Fixed-roof Tanks, Second Edition, October 1991, IBR approved for § 63.150(g)(3)(i)(C) of subpart G of this part.
- (3) API Manual of Petroleum Measurement Specifications (MPMS) Chapter 19.2, Evaporative Loss From Floating-Roof Tanks (formerly API Publications 2517 and 2519), First Edition, April 1997, IBR approved for § 63.1251 of subpart GGG of this part.

(d) *State and Local Requirements.* The materials listed below are available at the Air and Radiation Docket and Information Center, U.S. EPA, 401 M St., SW., Washington, DC.

- (1) *California Regulatory Requirements Applicable to the Air Toxics Program*, January 5, 1999, IBR approved for § 63.99(a)(5)(ii) of subpart E of this part.
- (2) *New Jersey's Toxic Catastrophe Prevention Act Program*, (July 20, 1998), Incorporation By Reference approved for § 63.99(a)(30)(i) of subpart E of this part.
- (3) (i) Letter of June 7, 1999 to the U.S. Environmental Protection Agency Region 3 from the Delaware Department of Natural Resources and Environmental Control requesting formal full delegation to take over primary responsibility for implementation and enforcement of the Chemical Accident Prevention Program under Section 112(r) of the Clean Air Act Amendments of 1990.
- (ii) Delaware Department of Natural Resources and Environmental Control, Division of Air and Waste Management, Accidental Release Prevention Regulation, sections 1 through 5 and sections 7 through 14, effective January 11, 1999, IBR approved for § 63.99(a)(8)(i) of subpart E of this part.
- (iii) State of Delaware Regulations Governing the Control of Air Pollution (October 2000), IBR approved for § 63.99(a)(8)(ii)-(v) of subpart E of this part.

(e) The materials listed below are available for purchase from the National Institute of Standards and Technology, Springfield, VA 22161, (800) 553-6847.

- (1) Handbook 44, Specifications, Tolerances, and Other Technical Requirements for Weighing and Measuring Devices 1998, IBR approved for § 63.1303(e)(3).
- (2) [Reserved]

(f) The following material is available from the National Council of the Paper Industry for Air and Stream Improvement, Inc. (NCASI), P. O. Box 133318, Research Triangle Park, NC 27709-3318 or at <http://www.ncasi.org>: NCASI Method DI/MEOH-94.02, Methanol in Process Liquids GC/FID (Gas Chromatography/Flame Ionization Detection), August 1998, Methods Manual, NCASI, Research Triangle Park, NC, IBR approved for § 63.457(c)(3)(ii) of subpart S of this part.

(g) The materials listed below are available for purchase from AOAC International, Customer Services, Suite 400, 2200 Wilson Boulevard, Arlington, Virginia, 22201-3301, Telephone (703) 522-3032, Fax (703) 522-5468.

- (1) AOAC Official Method 978.01 Phosphorus (Total) in Fertilizers, Automated Method, Sixteenth edition, 1995, IBR approved for § 63.626(d)(3)(vi).
- (2) AOAC Official Method 969.02 Phosphorus (Total) in Fertilizers, Alkalimetric Quinolinium Molybdophosphate Method, Sixteenth edition, 1995, IBR approved for § 63.626(d)(3)(vi).
- (3) AOAC Official Method 962.02 Phosphorus (Total) in Fertilizers, Gravimetric Quinolinium Molybdophosphate Method, Sixteenth edition, 1995, IBR approved for § 63.626(d)(3)(vi).
- (4) AOAC Official Method 957.02 Phosphorus (Total) in Fertilizers, Preparation of Sample Solution, Sixteenth edition, 1995, IBR approved for § 63.626(d)(3)(vi).
- (5) AOAC Official Method 929.01 Sampling of Solid Fertilizers, Sixteenth edition, 1995, IBR approved for § 63.626(d)(3)(vi).
- (6) AOAC Official Method 929.02 Preparation of Fertilizer Sample, Sixteenth edition, 1995, IBR approved for § 63.626(d)(3)(vi).
- (7) AOAC Official Method 958.01 Phosphorus (Total) in Fertilizers, Spectrophotometric Molybdovanadophosphate Method, Sixteenth edition, 1995, IBR approved for § 63.626(d)(3)(vi).

(h) The materials listed below are available for purchase from The Association of Florida Phosphate Chemists, P.O. Box 1645, Bartow, Florida, 33830, Book of Methods Used and Adopted By The Association of Florida Phosphate Chemists, Seventh Edition 1991, IBR.

- (1) Section IX, Methods of Analysis for Phosphate Rock, No. 1 Preparation of Sample, IBR approved for § 63.606(c)(3)(ii) and § 63.626(c)(3)(ii).
- (2) Section IX, Methods of Analysis for Phosphate Rock, No. 3 Phosphorus -- P<sub>2</sub>O<sub>5</sub> or Ca<sub>3</sub>(PO<sub>4</sub>)<sub>2</sub>, Method A-Volumetric Method, IBR approved for § 63.606(c)(3)(ii) and § 63.626(c)(3)(ii).
- (3) Section IX, Methods of Analysis for Phosphate Rock, No. 3 Phosphorus-P<sub>2</sub>O<sub>5</sub> or Ca<sub>3</sub>(PO<sub>4</sub>)<sub>2</sub>, Method B -- Gravimetric Quimociac Method, IBR approved for § 63.606(c)(3)(ii) and § 63.626(c)(3)(ii).
- (4) Section IX, Methods of Analysis For Phosphate Rock, No. 3 Phosphorus-P<sub>2</sub>O<sub>5</sub> or Ca<sub>3</sub>(PO<sub>4</sub>)<sub>2</sub>, Method C -- Spectrophotometric Method, IBR approved for § 63.606(c)(3)(ii) and § 63.626(c)(3)(ii).
- (5) Section XI, Methods of Analysis for Phosphoric Acid, Superphosphate, Triple Superphosphate, and Ammonium Phosphates; No. 3 Total Phosphorus-P<sub>2</sub>O<sub>5</sub>, Method A -- Volumetric Method, IBR approved for § 63.606(c)(3)(ii), § 63.626(c)(3)(ii), and § 63.626(d)(3)(v).
- (6) Section XI, Methods of Analysis for Phosphoric Acid, Superphosphate, Triple Superphosphate, and Ammonium Phosphates, No. 3 Total Phosphorus-P<sub>2</sub>O<sub>5</sub>, Method B -- Gravimetric Quimociac Method, IBR approved for § 63.606(c)(3)(ii), § 63.626(c)(3)(ii), and § 63.626(d)(3)(v).
- (7) Section XI, Methods of Analysis for Phosphoric Acid, Superphosphate, Triple Superphosphate, and Ammonium Phosphates, No. 3 Total Phosphorus-P<sub>2</sub>O<sub>5</sub>, Method C -- Spectrophotometric Method, IBR approved for § 63.606(c)(3)(ii), § 63.626(c)(3)(ii), and § 63.626(d)(3)(v).

(i) The following materials are available for purchase from at least one of the following addresses: ASME International, Orders/Inquiries, P.O. Box 2900, Fairfield, NJ 07007-2900; or Global Engineering Documents, Sales Department, 15 Inverness Way East, Englewood, CO 80112.

- (1) ASME standard number QHO-1-1994, "Standard for the Qualification and Certification of Hazardous Waste Incinerator Operators," IBR approved for Sec. 63.1206(c)(6)(iii).
- (2) ASME standard number QHO-1a-1996 Addenda to QHO-1-1994, "Standard for the Qualification and Certification of Hazardous Waste Incinerator Operators," IBR approved for Sec. 63.1206(c)(6)(iii).
- (3) ANSI/ASME PTC 19.10-1981, "Flue and Exhaust Gas Analyses [Part 10, Instruments and Apparatus]," IBR approved for Sec. Sec. 63.865(b), 63.3166(a)(3), 63.3360(e)(1)(iii), 63.3545(a)(3), 63.3555(a)(3), 63.4166(a)(3), 63.4362(a)(3), 63.4766(a)(3), 63.4965(a)(3), 63.5160(d)(1)(iii), 63.9307(c)(2), and 63.9323(a)(3).

(j) The following material is available for purchase from: British Standards Institute, 389 Chiswick High Road, London W4 4AL, United Kingdom.

## NESHAP Subpart A for General Provisions

(1) BS EN 1593:1999, Non-destructive Testing: Leak Testing--Bubble Emission Techniques, IBR approved for Sec. 63.425(i)(2).

(2) [Reserved]

(k) The following material may be obtained from U.S. EPA, Office of Solid Waste (5305W), 1200 Pennsylvania Avenue, NW., Washington, DC 20460:

(1) Method 9071B, "n-Hexane Extractable Material (HEM) for Sludge, Sediment, and Solid Samples," (Revision 2, April 1998) as published in EPA Publication SW-846: "Test Methods for Evaluating Solid Waste, Physical/Chemical Methods." The incorporation by reference of Method 9071B is approved for Section 63.7824(e) of Subpart FFFFF of this part.

**§ 63.15 Availability of information and confidentiality.**

*(a) Availability of information.*

(1) With the exception of information protected through part 2 of this chapter, all reports, records, and other information collected by the Administrator under this part are available to the public. In addition, a copy of each permit application, compliance plan (including the schedule of compliance), notification of compliance status, excess emissions and continuous monitoring systems performance report, and title V permit is available to the public, consistent with protections recognized in section 503(e) of the Act.

(2) The availability to the public of information provided to or otherwise obtained by the Administrator under this part shall be governed by part 2 of this chapter.

*(b) Confidentiality.*

(1) If an owner or operator is required to submit information entitled to protection from disclosure under section 114(c) of the Act, the owner or operator may submit such information separately. The requirements of section 114(c) shall apply to such information.

(2) The contents of a title V permit shall not be entitled to protection under section 114(c) of the Act; however, information submitted as part of an application for a title V permit may be entitled to protection from disclosure.



**SECTION 4. APPENDIX NS**  
**NSPS Subpart A for General Provisions**

---

In accordance with Rule 62-204.800, F.A.C., the following federal regulations in Part 60 of Title 40 of the Code of Federal Regulations were adopted by reference. The original federal rule numbering has been retained.

**40 CFR 60 NSPS SUBPART A, GENERAL PROVISIONS**

**§ 60.1 Applicability.**

- (a) Except as provided in subparts B and C, the provisions of this part apply to the owner or operator of any stationary source which contains an affected facility, the construction or modification of which is commenced after the date of publication in this part of any standard (or, if earlier, the date of publication of any proposed standard) applicable to that facility.
- (b) Any new or revised standard of performance promulgated pursuant to section 111(b) of the Act shall apply to the owner or operator of any stationary source which contains an affected facility, the construction or modification of which is commenced after the date of publication in this part of such new or revised standard (or, if earlier, the date of publication of any proposed standard) applicable to that facility.
- (c) In addition to complying with the provisions of this part, the owner or operator of an affected facility may be required to obtain an operating permit issued to stationary sources by an authorized State air pollution control agency or by the Administrator of the U.S. Environmental Protection Agency (EPA) pursuant to Title V of the Clean Air Act (Act) as amended November 15, 1990 (42 U.S.C. 7661). For more information about obtaining an operating permit see part 70 of this chapter.
- (d) Site-specific standard for Merck & Co., Inc.'s Stonewall Plant in Elkton, Virginia. {Not Applicable}

**§ 60.2 Definitions.**

The terms used in this part are defined in the Act or in this section as follows:

Act means the Clean Air Act (42 U.S.C. 7401 et seq. )

Administrator means the Administrator of the Environmental Protection Agency or his authorized representative.

Affected facility means, with reference to a stationary source, any apparatus to which a standard is applicable.

Alternative method means any method of sampling and analyzing for an air pollutant which is not a reference or equivalent method but which has been demonstrated to the Administrator's satisfaction to, in specific cases, produce results adequate for his determination of compliance.

Approved permit program means a State permit program approved by the Administrator as meeting the requirements of part 70 of this chapter or a Federal permit program established in this chapter pursuant to Title V of the Act (42 U.S.C. 7661).

Capital expenditure means an expenditure for a physical or operational change to an existing facility which exceeds the product of the applicable "annual asset guideline repair allowance percentage" specified in the latest edition of Internal Revenue Service (IRS) Publication 534 and the existing facility's basis, as defined by section 1012 of the Internal Revenue Code. However, the total expenditure for a physical or operational change to an existing facility must not be reduced by any "excluded additions" as defined in IRS Publication 534, as would be done for tax purposes.

Clean coal technology demonstration project means a project using funds appropriated under the heading 'Department of Energy-Clean Coal Technology', up to a total amount of \$2,500,000,000 for commercial demonstrations of clean coal technology, or similar projects funded through appropriations for the Environmental Protection Agency.

Commenced means, with respect to the definition of new source in section 111(a)(2) of the Act, that an owner or operator has undertaken a continuous program of construction or modification or that an owner or operator has entered into a contractual obligation to undertake and complete, within a reasonable time, a continuous program of construction or modification.

Construction means fabrication, erection, or installation of an affected facility.

Continuous monitoring system means the total equipment, required under the emission monitoring sections in applicable subparts, used to sample and condition (if applicable), to analyze, and to provide a permanent record of emissions or process parameters.

**SECTION 4. APPENDIX NS**  
**NSPS Subpart A for General Provisions**

---

Electric utility steam generating unit means any steam electric generating unit that is constructed for the purpose of supplying more than one-third of its potential electric output capacity and more than 25 MW electrical output to any utility power distribution system for sale. Any steam supplied to a steam distribution system for the purpose of providing steam to a steam-electric generator that would produce electrical energy for sale is also considered in determining the electrical energy output capacity of the affected facility.

Equivalent method means any method of sampling and analyzing for an air pollutant which has been demonstrated to the Administrator's satisfaction to have a consistent and quantitatively known relationship to the reference method, under specified conditions.

Excess Emissions and Monitoring Systems Performance Report is a report that must be submitted periodically by a source in order to provide data on its compliance with stated emission limits and operating parameters, and on the performance of its monitoring systems.

Existing facility means, with reference to a stationary source, any apparatus of the type for which a standard is promulgated in this part, and the construction or modification of which was commenced before the date of proposal of that standard; or any apparatus which could be altered in such a way as to be of that type.

Force majeure means, for purposes of §60.8, an event that will be or has been caused by circumstances beyond the control of the affected facility, its contractors, or any entity controlled by the affected facility that prevents the owner or operator from complying with the regulatory requirement to conduct performance tests within the specified timeframe despite the affected facility's best efforts to fulfill the obligation. Examples of such events are acts of nature, acts of war or terrorism, or equipment failure or safety hazard beyond the control of the affected facility.

Isokinetic sampling means sampling in which the linear velocity of the gas entering the sampling nozzle is equal to that of the undisturbed gas stream at the sample point.

Issuance of a part 70 permit will occur, if the State is the permitting authority, in accordance with the requirements of part 70 of this chapter and the applicable, approved State permit program. When the EPA is the permitting authority, issuance of a Title V permit occurs immediately after the EPA takes final action on the final permit.

Malfunction means any sudden, infrequent, and not reasonably preventable failure of air pollution control equipment, process equipment, or a process to operate in a normal or usual manner. Failures that are caused in part by poor maintenance or careless operation are not malfunctions.

Modification means any physical change in, or change in the method of operation of, an existing facility which increases the amount of any air pollutant (to which a standard applies) emitted into the atmosphere by that facility or which results in the emission of any air pollutant (to which a standard applies) into the atmosphere not previously emitted.

Monitoring device means the total equipment, required under the monitoring of operations sections in applicable subparts, used to measure and record (if applicable) process parameters.

Nitrogen oxides means all oxides of nitrogen except nitrous oxide, as measured by test methods set forth in this part.

One-hour period means any 60-minute period commencing on the hour.

Opacity means the degree to which emissions reduce the transmission of light and obscure the view of an object in the background.

Owner or operator means any person who owns, leases, operates, controls, or supervises an affected facility or a stationary source of which an affected facility is a part.

Part 70 permit means any permit issued, renewed, or revised pursuant to part 70 of this chapter.

Particulate matter means any finely divided solid or liquid material, other than uncombined water, as measured by the reference methods specified under each applicable subpart, or an equivalent or alternative method.

Permit program means a comprehensive State operating permit system established pursuant to title V of the Act (42 U.S.C. 7661) and regulations codified in part 70 of this chapter and applicable State regulations, or a comprehensive Federal operating permit system established pursuant to title V of the Act and regulations codified in this chapter.

Permitting authority means:

**SECTION 4. APPENDIX NS**  
**NSPS Subpart A for General Provisions**

---

- (1) The State air pollution control agency, local agency, other State agency, or other agency authorized by the Administrator to carry out a permit program under part 70 of this chapter; or
- (2) The Administrator, in the case of EPA-implemented permit programs under title V of the Act (42 U.S.C. 7661).

Proportional sampling means sampling at a rate that produces a constant ratio of sampling rate to stack gas flow rate.

Reactivation of a very clean coal-fired electric utility steam generating unit means any physical change or change in the method of operation associated with the commencement of commercial operations by a coal-fired utility unit after a period of discontinued operation where the unit:

- (1) Has not been in operation for the two-year period prior to the enactment of the Clean Air Act Amendments of 1990, and the emissions from such unit continue to be carried in the permitting authority's emissions inventory at the time of enactment;
- (2) Was equipped prior to shut-down with a continuous system of emissions control that achieves a removal efficiency for sulfur dioxide of no less than 85 percent and a removal efficiency for particulates of no less than 98 percent;
- (3) Is equipped with low-NOX burners prior to the time of commencement of operations following reactivation; and
- (4) Is otherwise in compliance with the requirements of the Clean Air Act.

Reference method means any method of sampling and analyzing for an air pollutant as specified in the applicable subpart.

Repowering means replacement of an existing coal-fired boiler with one of the following clean coal technologies: atmospheric or pressurized fluidized bed combustion, integrated gasification combined cycle, magnetohydrodynamics, direct and indirect coal-fired turbines, integrated gasification fuel cells, or as determined by the Administrator, in consultation with the Secretary of Energy, a derivative of one or more of these technologies, and any other technology capable of controlling multiple combustion emissions simultaneously with improved boiler or generation efficiency and with significantly greater waste reduction relative to the performance of technology in widespread commercial use as of November 15, 1990. Repowering shall also include any oil and/or gas-fired unit which has been awarded clean coal technology demonstration funding as of January 1, 1991, by the Department of Energy.

Run means the net period of time during which an emission sample is collected. Unless otherwise specified, a run may be either intermittent or continuous within the limits of good engineering practice.

Shutdown means the cessation of operation of an affected facility for any purpose.

Six-minute period means any one of the 10 equal parts of a one-hour period.

Standard means a standard of performance proposed or promulgated under this part.

Standard conditions means a temperature of 293 K (68F) and a pressure of 101.3 kilopascals (29.92 in Hg).

Startup means the setting in operation of an affected facility for any purpose.

State means all non-Federal authorities, including local agencies, interstate associations, and State-wide programs, that have delegated authority to implement: (1) The provisions of this part; and/or (2) the permit program established under part 70 of this chapter. The term State shall have its conventional meaning where clear from the context.

Stationary source means any building, structure, facility, or installation which emits or may emit any air pollutant.

Title V permit means any permit issued, renewed, or revised pursuant to Federal or State regulations established to implement title V of the Act (42 U.S.C. 7661). A title V permit issued by a State permitting authority is called a part 70 permit in this part.

Volatile Organic Compound means any organic compound which participates in atmospheric photochemical reactions; or which is measured by a reference method, an equivalent method, an alternative method, or which is determined by procedures specified under any subpart.

[44 FR 55173, Sept. 25, 1979, as amended at 45 FR 5617, Jan. 23, 1980; 45 FR 85415, Dec. 24, 1980; 54 FR 6662, Feb. 14, 1989; 55 FR 51382, Dec. 13, 1990; 57 FR 32338, July 21, 1992; 59 FR 12427, Mar. 16, 1994; 72 FR 27442, May 16, 2007]

**§ 60.3 Units and abbreviations.**

**SECTION 4. APPENDIX NS**  
**NSPS Subpart A for General Provisions**

Used in this part are abbreviations and symbols of units of measure. These are defined as follows:

(a) System International (SI) units of measure:

|                                |  |
|--------------------------------|--|
| A—ampere                       | mol—mole                                 |
| g—gram                         | N—newton                                 |
| Hz—hertz                       | ng—nanogram— $10^{-9}$ gram              |
| J—joule                        | nm—nanometer— $10^{-9}$ meter            |
| K—degree Kelvin                | Pa—pascal                                |
| kg—kilogram                    | s—second                                 |
| m—meter                        | V—volt                                   |
| $m^3$ —cubic meter             | W—watt                                   |
| mg—milligram— $10^{-3}$ gram   | $\Omega$ —ohm                            |
| mm—millimeter— $10^{-3}$ meter | $\mu\text{g}$ —microgram— $10^{-6}$ gram |
| Mg—megagram— $10^6$ gram       |  |

(b) Other units of measure:

|   |   |
|---|---|
| Btu—British thermal unit                        | l—liter   |
| $^{\circ}\text{C}$ —degree Celsius (centigrade) | lpm—liter per minute                            |
| cal—calorie                                     | lb—pound  |
| cfm—cubic feet per minute                       | meq—milliequivalent                             |
| cu ft—cubic feet                                | min—minute                                      |
| dcf—dry cubic feet                              | ml—milliliter                                   |
| dcm—dry cubic meter                             | mol. wt.—molecular weight                       |
| dscf—dry cubic feet at standard conditions      | ppb—parts per billion                           |
| dscm—dry cubic meter at standard conditions     | ppm—parts per million                           |
| eq—equivalent                                   | psia—pounds per square inch absolute            |
| $^{\circ}\text{F}$ —degree Fahrenheit           | psig—pounds per square inch gage                |
| ft—feet   | $^{\circ}\text{R}$ —degree Rankine              |
| gal—gallon                                      | scf—cubic feet at standard conditions           |
| gr—grain  | scfh—cubic feet per hour at standard conditions |
| g-eq—gram equivalent                            | scm—cubic meter at standard conditions          |
| hr—hour   | sec—second                                      |
| in—inch   | sq ft—square feet                               |
| k—1,000   | std—at standard conditions                      |

(c) Chemical nomenclature:

|  |                                 |
|--|---------------------------------|
| CdS—cadmium sulfide                    | $\text{NO}_2$ —nitrogen dioxide |
| CO—carbon monoxide                     | $\text{NO}_x$ —nitrogen oxides  |
| $\text{CO}_2$ —carbon dioxide          | $\text{O}_2$ —oxygen            |
| HCl—hydrochloric acid                  | $\text{SO}_2$ —sulfur dioxide   |
| Hg—mercury                             | $\text{SO}_3$ —sulfur trioxide  |
| $\text{H}_2\text{O}$ —water            | $\text{SO}_x$ —sulfur oxides    |
| $\text{H}_2\text{S}$ —hydrogen sulfide |                                 |
| $\text{H}_2\text{SO}_4$ —sulfuric acid |                                 |
| $\text{N}_2$ —nitrogen                 |                                 |
| NO—nitric oxide                        |                                 |

## (d) Miscellaneous:

A.S.T.M.—American Society for Testing and Materials

[42 FR 37000, July 19, 1977; 42 FR 38178, July 27, 1977]

**§ 60.4 Address.**

All addresses that pertain to Florida have been incorporated. To see the complete list of addresses please go to <http://ecfr.gpoaccess.gov/cgi/t/text/text-idx?c=ecfr&rgn=div6&view=text&node=40:6.0.1.1.1.1&idno=40>.

Link to an amendment published at 73 FR 18164, Apr. 3, 2008.

- (a) All requests, reports, applications, submittals, and other communications to the Administrator pursuant to this part shall be submitted in duplicate to the appropriate Regional Office of the U.S. Environmental Protection Agency to the attention of the Director of the Division indicated in the following list of EPA Regional Offices.

Region IV (Alabama, Florida, Georgia, Kentucky, Mississippi, North Carolina, South Carolina, Tennessee), Director, Air and Waste Management Division, U.S. Environmental Protection Agency, 345 Courtland Street, NE., Atlanta, GA 30365.

- (b) Section 111(c) directs the Administrator to delegate to each State, when appropriate, the authority to implement and enforce standards of performance for new stationary sources located in such State. All information required to be submitted to EPA under paragraph (a) of this section, must also be submitted to the appropriate State Agency of any State to which this authority has been delegated (provided, that each specific delegation may except sources from a certain Federal or State reporting requirement). The appropriate mailing address for those States whose delegation request has been approved is as follows:

(K) Bureau of Air Quality Management, Department of Environmental Regulation, Twin Towers Office Building, 2600 Blair Stone Road, Tallahassee, FL 32301.

[40 FR 18169, Apr. 25, 1975]

Editorial Note: For Federal Register citations affecting §60.4 see the List of CFR Sections Affected which appears in the Finding Aids section of the printed volume and on GPO Access.

**§ 60.5 Determination of construction or modification.**

- (a) When requested to do so by an owner or operator, the Administrator will make a determination of whether action taken or intended to be taken by such owner or operator constitutes construction (including reconstruction) or modification or the commencement thereof within the meaning of this part.
- (b) The Administrator will respond to any request for a determination under paragraph (a) of this section within 30 days of receipt of such request.

[40 FR 58418, Dec. 16, 1975]

**§ 60.6 Review of plans.**

- (a) When requested to do so by an owner or operator, the Administrator will review plans for construction or modification for the purpose of providing technical advice to the owner or operator.
- (b)
- (1) A separate request shall be submitted for each construction or modification project.
  - (2) Each request shall identify the location of such project, and be accompanied by technical information describing the proposed nature, size, design, and method of operation of each affected facility involved in such project, including information on any equipment to be used for measurement or control of emissions.
- (c) Neither a request for plans review nor advice furnished by the Administrator in response to such request shall (1) relieve an owner or operator of legal responsibility for compliance with any provision of this part or of any applicable State or local requirement, or (2) prevent the Administrator from implementing or enforcing any provision of this part or taking any other action authorized by the Act.

[36 FR 24877, Dec. 23, 1971, as amended at 39 FR 9314, Mar. 8, 1974]

**§ 60.7 Notification and record keeping.**

- (a) Any owner or operator subject to the provisions of this part shall furnish the Administrator written notification or, if acceptable to both the Administrator and the owner or operator of a source, electronic notification, as follows:
- (1) A notification of the date construction (or reconstruction as defined under §60.15) of an affected facility is commenced postmarked no later than 30 days after such date. This requirement shall not apply in the case of mass-produced facilities which are purchased in completed form.
  - (2) [Reserved]
  - (3) A notification of the actual date of initial startup of an affected facility postmarked within 15 days after such date.
  - (4) A notification of any physical or operational change to an existing facility which may increase the emission rate of any air pollutant to which a standard applies, unless that change is specifically exempted under an applicable subpart or in §60.14(e). This notice shall be postmarked 60 days or as soon as practicable before the change is commenced and shall include information describing the precise nature of the change, present and proposed emission control systems, productive capacity of the facility before and after the change, and the expected completion date of the change. The Administrator may request additional relevant information subsequent to this notice.
  - (5) A notification of the date upon which demonstration of the continuous monitoring system performance commences in accordance with §60.13(c). Notification shall be postmarked not less than 30 days prior to such date.
  - (6) A notification of the anticipated date for conducting the opacity observations required by §60.11(e)(1) of this part. The notification shall also include, if appropriate, a request for the Administrator to provide a visible emissions reader during a performance test. The notification shall be postmarked not less than 30 days prior to such date.
  - (7) A notification that continuous opacity monitoring system data results will be used to determine compliance with the applicable opacity standard during a performance test required by §60.8 in lieu of Method 9 observation data as allowed by §60.11(e)(5) of this part. This notification shall be postmarked not less than 30 days prior to the date of the performance test.
- (b) Any owner or operator subject to the provisions of this part shall maintain records of the occurrence and duration of any startup, shutdown, or malfunction in the operation of an affected facility; any malfunction of the air pollution control equipment; or any periods during which a continuous monitoring system or monitoring device is inoperative.
- (c) Each owner or operator required to install a continuous monitoring device shall submit excess emissions and monitoring systems performance report (excess emissions are defined in applicable subparts) and-or summary report form (see paragraph (d) of this section) to the Administrator semiannually, except when: more frequent reporting is specifically required by an applicable subpart; or the Administrator, on a case-by-case basis, determines that more frequent reporting is necessary to accurately assess the compliance status of the source. All reports shall be postmarked by the 30th day following the end of each six-month period. Written reports of excess emissions shall include the following information:
- (1) The magnitude of excess emissions computed in accordance with §60.13(h), any conversion factor(s) used, and the date and time of commencement and completion of each time period of excess emissions. The process operating time during the reporting period.
  - (2) Specific identification of each period of excess emissions that occurs during startups, shutdowns, and malfunctions of the affected facility. The nature and cause of any malfunction (if known), the corrective action taken or preventative measures adopted.
  - (3) The date and time identifying each period during which the continuous monitoring system was inoperative except for zero and span checks and the nature of the system repairs or adjustments.
  - (4) When no excess emissions have occurred or the continuous monitoring system(s) have not been inoperative, repaired, or adjusted, such information shall be stated in the report.
- (d) The summary report form shall contain the information and be in the format shown in figure 1 unless otherwise specified by the Administrator. One summary report form shall be submitted for each pollutant monitored at each affected facility.
- (1) If the total duration of excess emissions for the reporting period is less than 1 percent of the total operating time for the reporting period and CMS downtime for the reporting period is less than 5 percent of the total operating

**NSPS Subpart A for General Provisions**

time for the reporting period, only the summary report form shall be submitted and the excess emission report described in §60.7(c) need not be submitted unless requested by the Administrator.

- (2) If the total duration of excess emissions for the reporting period is 1 percent or greater of the total operating time for the reporting period or the total CMS downtime for the reporting period is 5 percent or greater of the total operating time for the reporting period, the summary report form and the excess emission report described in §60.7(c) shall both be submitted.

**Figure 1. Summary Report - Gaseous and Opacity Excess Emission and Monitoring System Performance**

Pollutant (Circle One): SO<sub>2</sub> / NO<sub>x</sub> / TRS / H<sub>2</sub>S / CO / Opacity)

Reporting period dates: From \_\_\_\_\_ to \_\_\_\_\_

Company: \_\_\_\_\_

Emission Limitation: \_\_\_\_\_

Address: \_\_\_\_\_

Monitor Manufacturer and Model No. \_\_\_\_\_

Date of Latest CMS Certification or Audit: \_\_\_\_\_

Process Units Description: \_\_\_\_\_

Total Source Operating Time in Reporting Period<sup>1</sup> \_\_\_\_\_

| Emission Data Summary <sup>1</sup>   |                | CMS Performance Summary <sup>1</sup>   |                |
|--|----------------|--|----------------|
| 1. Duration of excess emissions in reporting period due to:  |                | 1. CMS downtime in reporting period due to:  |                |
| a. Startup/shutdown  |                | a. Monitor equipment malfunctions  |                |
| b. Control equipment problems  |                | b. Non-Monitor equipment malfunctions  |                |
| c. Process problems  |                | c. Quality assurance calibration   |                |
| d. Other known causes  |                | d. Other known causes  |                |
| e. Unknown causes  |                | e. Unknown causes  |                |
| 2. Total duration of excess emission   |                | 2. Total CMS Downtime  |                |
| 3. $\frac{\text{Total duration of excess emissions} \times (100\%)}{\text{[Total source operating time]}}$ | % <sup>2</sup> | 3. $\frac{\text{[Total CMS Downtime]} \times (100\%)}{\text{[Total source operating time]}}$ | % <sup>2</sup> |

<sup>1</sup> For opacity, record all times in minutes. For gases, record all times in hours.

<sup>2</sup> For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in §60.7(c) shall be submitted.

On a separate page, describe any changes since last quarter in CMS, process or controls. I certify that the information contained in this report is true, accurate, and complete.

\_\_\_\_\_  
Name

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Title

\_\_\_\_\_  
Date

- (e)
- (1) Notwithstanding the frequency of reporting requirements specified in paragraph (c) of this section, an owner or operator who is required by an applicable subpart to submit excess emissions and monitoring systems performance reports (and summary reports) on a quarterly (or more frequent) basis may reduce the frequency of reporting for that standard to semiannual if the following conditions are met:
    - (i) For 1 full year (e.g., 4 quarterly or 12 monthly reporting periods) the affected facility's excess emissions and monitoring systems reports submitted to comply with a standard under this part continually demonstrate that the facility is in compliance with the applicable standard;
    - (ii) The owner or operator continues to comply with all recordkeeping and monitoring requirements specified in this subpart and the applicable standard; and
    - (iii) The Administrator does not object to a reduced frequency of reporting for the affected facility, as provided in paragraph (e)(2) of this section.
  - (2) The frequency of reporting of excess emissions and monitoring systems performance (and summary) reports may be reduced only after the owner or operator notifies the Administrator in writing of his or her intention to make such a change and the Administrator does not object to the intended change. In deciding whether to approve a reduced frequency of reporting, the Administrator may review information concerning the source's entire previous performance history during the required recordkeeping period prior to the intended change, including performance test results, monitoring data, and evaluations of an owner or operator's conformance with operation and maintenance requirements. Such information may be used by the Administrator to make a judgment about the source's potential for noncompliance in the future. If the Administrator disapproves the owner or operator's request to reduce the frequency of reporting, the Administrator will notify the owner or operator in writing within 45 days after receiving notice of the owner or operator's intention. The notification from the Administrator to the owner or operator will specify the grounds on which the disapproval is based. In the absence of a notice of disapproval within 45 days, approval is automatically granted.
  - (3) As soon as monitoring data indicate that the affected facility is not in compliance with any emission limitation or operating parameter specified in the applicable standard, the frequency of reporting shall revert to the frequency specified in the applicable standard, and the owner or operator shall submit an excess emissions and monitoring systems performance report (and summary report, if required) at the next appropriate reporting period following the noncomplying event. After demonstrating compliance with the applicable standard for another full year, the owner or operator may again request approval from the Administrator to reduce the frequency of reporting for that standard as provided for in paragraphs (e)(1) and (e)(2) of this section.
- (f) Any owner or operator subject to the provisions of this part shall maintain a file of all measurements, including continuous monitoring system, monitoring device, and performance testing measurements; all continuous monitoring system performance evaluations; all continuous monitoring system or monitoring device calibration checks; adjustments and maintenance performed on these systems or devices; and all other information required by this part recorded in a permanent form suitable for inspection. The file shall be retained for at least two years following the date of such measurements, maintenance, reports, and records, except as follows:
- (1) This paragraph applies to owners or operators required to install a continuous emissions monitoring system (CEMS) where the CEMS installed is automated, and where the calculated data averages do not exclude periods of CEMS breakdown or malfunction. An automated CEMS records and reduces the measured data to the form of the pollutant emission standard through the use of a computerized data acquisition system. In lieu of maintaining a file of all CEMS subhourly measurements as required under paragraph (f) of this section, the owner or operator shall retain the most recent consecutive three averaging periods of subhourly measurements and a file that contains a hard copy of the data acquisition system algorithm used to reduce the measured data into the reportable form of the standard.
  - (2) This paragraph applies to owners or operators required to install a CEMS where the measured data is manually reduced to obtain the reportable form of the standard, and where the calculated data averages do not exclude periods of CEMS breakdown or malfunction. In lieu of maintaining a file of all CEMS subhourly measurements as required under paragraph (f) of this section, the owner or operator shall retain all subhourly measurements for the most recent reporting period. The subhourly measurements shall be retained for 120 days from the date of the most recent summary or excess emission report submitted to the Administrator.
  - (3) The Administrator or delegated authority, upon notification to the source, may require the owner or operator to



## NSPS Subpart A for General Provisions

maintain all measurements as required by paragraph (f) of this section, if the Administrator or the delegated authority determines these records are required to more accurately assess the compliance status of the affected source.

- (g) If notification substantially similar to that in paragraph (a) of this section is required by any other State or local agency, sending the Administrator a copy of that notification will satisfy the requirements of paragraph (a) of this section.
- (h) Individual subparts of this part may include specific provisions which clarify or make inapplicable the provisions set forth in this section.

[36 FR 24877, Dec. 28, 1971, as amended at 40 FR 46254, Oct. 6, 1975; 40 FR 58418, Dec. 16, 1975; 45 FR 5617, Jan. 23, 1980; 48 FR 48335, Oct. 18, 1983; 50 FR 53113, Dec. 27, 1985; 52 FR 9781, Mar. 26, 1987; 55 FR 51382, Dec. 13, 1990; 59 FR 12428, Mar. 16, 1994; 59 FR 47265, Sep. 15, 1994; 64 FR 7463, Feb. 12, 1999]

#### § 60.8 Performance tests.

- (a) Except as specified in paragraphs (a)(1), (a)(2), (a)(3), and (a)(4) of this section, within 60 days after achieving the maximum production rate at which the affected facility will be operated, but not later than 180 days after initial startup of such facility, or at such other times specified by this part, and at such other times as may be required by the Administrator under section 114 of the Act, the owner or operator of such facility shall conduct performance test(s) and furnish the Administrator a written report of the results of such performance test(s).
  - (1) If a force majeure is about to occur, occurs, or has occurred for which the affected owner or operator intends to assert a claim of force majeure, the owner or operator shall notify the Administrator, in writing as soon as practicable following the date the owner or operator first knew, or through due diligence should have known that the event may cause or caused a delay in testing beyond the regulatory deadline, but the notification must occur before the performance test deadline unless the initial force majeure or a subsequent force majeure event delays the notice, and in such cases, the notification shall occur as soon as practicable.
  - (2) The owner or operator shall provide to the Administrator a written description of the force majeure event and a rationale for attributing the delay in testing beyond the regulatory deadline to the force majeure; describe the measures taken or to be taken to minimize the delay; and identify a date by which the owner or operator proposes to conduct the performance test. The performance test shall be conducted as soon as practicable after the force majeure occurs.
  - (3) The decision as to whether or not to grant an extension to the performance test deadline is solely within the discretion of the Administrator. The Administrator will notify the owner or operator in writing of approval or disapproval of the request for an extension as soon as practicable.
  - (4) Until an extension of the performance test deadline has been approved by the Administrator under paragraphs (a)(1), (2), and (3) of this section, the owner or operator of the affected facility remains strictly subject to the requirements of this part.
- (b) Performance tests shall be conducted and data reduced in accordance with the test methods and procedures contained in each applicable subpart unless the Administrator (1) specifies or approves, in specific cases, the use of a reference method with minor changes in methodology, (2) approves the use of an equivalent method, (3) approves the use of an alternative method the results of which he has determined to be adequate for indicating whether a specific source is in compliance, (4) waives the requirement for performance tests because the owner or operator of a source has demonstrated by other means to the Administrator's satisfaction that the affected facility is in compliance with the standard, or (5) approves shorter sampling times and smaller sample volumes when necessitated by process variables or other factors. Nothing in this paragraph shall be construed to abrogate the Administrator's authority to require testing under section 114 of the Act.
- (c) Performance tests shall be conducted under such conditions as the Administrator shall specify to the plant operator based on representative performance of the affected facility. The owner or operator shall make available to the Administrator such records as may be necessary to determine the conditions of the performance tests. Operations during periods of startup, shutdown, and malfunction shall not constitute representative conditions for the purpose of a performance test nor shall emissions in excess of the level of the applicable emission limit during periods of startup, shutdown, and malfunction be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard.
- (d) The owner or operator of an affected facility shall provide the Administrator at least 30 days prior notice of any performance test, except as specified under other subparts, to afford the Administrator the opportunity to have an

observer present. If after 30 days notice for an initially scheduled performance test, there is a delay (due to operational problems, etc.) in conducting the scheduled performance test, the owner or operator of an affected facility shall notify the Administrator (or delegated State or local agency) as soon as possible of any delay in the original test date, either by providing at least 7 days prior notice of the rescheduled date of the performance test, or by arranging a rescheduled date with the Administrator (or delegated State or local agency) by mutual agreement.

- (e) The owner or operator of an affected facility shall provide, or cause to be provided, performance testing facilities as follows:
- (1) Sampling ports adequate for test methods applicable to such facility. This includes (i) constructing the air pollution control system such that volumetric flow rates and pollutant emission rates can be accurately determined by applicable test methods and procedures and (ii) providing a stack or duct free of cyclonic flow during performance tests, as demonstrated by applicable test methods and procedures.
  - (2) Safe sampling platform(s).
  - (3) Safe access to sampling platform(s).
  - (4) Utilities for sampling and testing equipment.
- (f) Unless otherwise specified in the applicable subpart, each performance test shall consist of three separate runs using the applicable test method. Each run shall be conducted for the time and under the conditions specified in the applicable standard. For the purpose of determining compliance with an applicable standard, the arithmetic means of results of the three runs shall apply. In the event that a sample is accidentally lost or conditions occur in which one of the three runs must be discontinued because of forced shutdown, failure of an irreplaceable portion of the sample train, extreme meteorological conditions, or other circumstances, beyond the owner or operator's control, compliance may, upon the Administrator's approval, be determined using the arithmetic mean of the results of the two other runs.

[36 FR 24877, Dec. 23, 1971, as amended at 39 FR 9314, Mar. 8, 1974; 42 FR 57126, Nov. 1, 1977; 44 FR 33612, June 11, 1979; 54 FR 6662, Feb. 14, 1989; 54 FR 21344, May 17, 1989; 64 FR 7463, Feb. 12, 1999; 72 FR 27442, May 16, 2007]

#### § 60.9 Availability of information.

The availability to the public of information provided to, or otherwise obtained by, the Administrator under this part shall be governed by part 2 of this chapter. (Information submitted voluntarily to the Administrator for the purposes of §§60.5 and 60.6 is governed by §§2.201 through 2.213 of this chapter and not by §2.301 of this chapter.)

#### § 60.10 State authority.

The provisions of this part shall not be construed in any manner to preclude any State or political subdivision thereof from:

- (a) Adopting and enforcing any emission standard or limitation applicable to an affected facility, provided that such emission standard or limitation is not less stringent than the standard applicable to such facility.
- (b) Requiring the owner or operator of an affected facility to obtain permits, licenses, or approvals prior to initiating construction, modification, or operation of such facility.

#### § 60.11 Compliance with standards and maintenance requirements.

- (a) Compliance with standards in this part, other than opacity standards, shall be determined in accordance with performance tests established by §60.8, unless otherwise specified in the applicable standard.
- (b) Compliance with opacity standards in this part shall be determined by conducting observations in accordance with Method 9 in appendix A of this part, any alternative method that is approved by the Administrator, or as provided in paragraph (e)(5) of this section. For purposes of determining initial compliance, the minimum total time of observations shall be 3 hours (30 6-minute averages) for the performance test or other set of observations (meaning those fugitive-type emission sources subject only to an opacity standard).
- (c) The opacity standards set forth in this part shall apply at all times except during periods of startup, shutdown, malfunction, and as otherwise provided in the applicable standard.
- (d) At all times, including periods of startup, shutdown, and malfunction, owners and operators shall, to the extent practicable, maintain and operate any affected facility including associated air pollution control equipment in a manner consistent with good air pollution control practice for minimizing emissions. Determination of whether acceptable operating and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, opacity observations, review of operating and maintenance

procedures, and inspection of the source.

(e)

- (1) For the purpose of demonstrating initial compliance, opacity observations shall be conducted concurrently with the initial performance test required in §60.8 unless one of the following conditions apply. If no performance test under §60.8 is required, then opacity observations shall be conducted within 60 days after achieving the maximum production rate at which the affected facility will be operated but no later than 180 days after initial startup of the facility. If visibility or other conditions prevent the opacity observations from being conducted concurrently with the initial performance test required under §60.8, the source owner or operator shall reschedule the opacity observations as soon after the initial performance test as possible, but not later than 30 days thereafter, and shall advise the Administrator of the rescheduled date. In these cases, the 30-day prior notification to the Administrator required in §60.7(a)(6) shall be waived. The rescheduled opacity observations shall be conducted (to the extent possible) under the same operating conditions that existed during the initial performance test conducted under §60.8. The visible emissions observer shall determine whether visibility or other conditions prevent the opacity observations from being made concurrently with the initial performance test in accordance with procedures contained in Method 9 of appendix B of this part. Opacity readings of portions of plumes which contain condensed, uncombined water vapor shall not be used for purposes of determining compliance with opacity standards. The owner or operator of an affected facility shall make available, upon request by the Administrator, such records as may be necessary to determine the conditions under which the visual observations were made and shall provide evidence indicating proof of current visible observer emission certification. Except as provided in paragraph (e)(5) of this section, the results of continuous monitoring by transmissometer which indicate that the opacity at the time visual observations were made was not in excess of the standard are probative but not conclusive evidence of the actual opacity of an emission, provided that the source shall meet the burden of proving that the instrument used meets (at the time of the alleged violation) Performance Specification 1 in appendix B of this part, has been properly maintained and (at the time of the alleged violation) that the resulting data have not been altered in any way.
- (2) Except as provided in paragraph (e)(3) of this section, the owner or operator of an affected facility to which an opacity standard in this part applies shall conduct opacity observations in accordance with paragraph (b) of this section, shall record the opacity of emissions, and shall report to the Administrator the opacity results along with the results of the initial performance test required under §60.8. The inability of an owner or operator to secure a visible emissions observer shall not be considered a reason for not conducting the opacity observations concurrent with the initial performance test.
- (3) The owner or operator of an affected facility to which an opacity standard in this part applies may request the Administrator to determine and to record the opacity of emissions from the affected facility during the initial performance test and at such times as may be required. The owner or operator of the affected facility shall report the opacity results. Any request to the Administrator to determine and to record the opacity of emissions from an affected facility shall be included in the notification required in §60.7(a)(6). If, for some reason, the Administrator cannot determine and record the opacity of emissions from the affected facility during the performance test, then the provisions of paragraph (e)(1) of this section shall apply.
- (4) An owner or operator of an affected facility using a continuous opacity monitor (transmissometer) shall record the monitoring data produced during the initial performance test required by §60.8 and shall furnish the Administrator a written report of the monitoring results along with Method 9 and §60.8 performance test results.
- (5) An owner or operator of an affected facility subject to an opacity standard may submit, for compliance purposes, continuous opacity monitoring system (COMS) data results produced during any performance test required under §60.8 in lieu of Method 9 observation data. If an owner or operator elects to submit COMS data for compliance with the opacity standard, he shall notify the Administrator of that decision, in writing, at least 30 days before any performance test required under §60.8 is conducted. Once the owner or operator of an affected facility has notified the Administrator to that effect, the COMS data results will be used to determine opacity compliance during subsequent tests required under §60.8 until the owner or operator notifies the Administrator, in writing, to the contrary. For the purpose of determining compliance with the opacity standard during a performance test required under §60.8 using COMS data, the minimum total time of COMS data collection shall be averages of all 6-minute continuous periods within the duration of the mass emission performance test. Results of the COMS opacity determinations shall be submitted along with the results of the performance test required under §60.8. The owner or operator of an affected facility using a COMS for compliance purposes is responsible for demonstrating that the COMS meets the requirements specified in §60.13(c) of this part, that the COMS has been properly maintained

## NSPS Subpart A for General Provisions

and operated, and that the resulting data have not been altered in any way. If COMS data results are submitted for compliance with the opacity standard for a period of time during which Method 9 data indicates noncompliance, the Method 9 data will be used to determine compliance with the opacity standard.

- (6) Upon receipt from an owner or operator of the written reports of the results of the performance tests required by §60.8, the opacity observation results and observer certification required by §60.11(e)(1), and the COMS results, if applicable, the Administrator will make a finding concerning compliance with opacity and other applicable standards. If COMS data results are used to comply with an opacity standard, only those results are required to be submitted along with the performance test results required by §60.8. If the Administrator finds that an affected facility is in compliance with all applicable standards for which performance tests are conducted in accordance with §60.8 of this part but during the time such performance tests are being conducted fails to meet any applicable opacity standard, he shall notify the owner or operator and advise him that he may petition the Administrator within 10 days of receipt of notification to make appropriate adjustment to the opacity standard for the affected facility.
  - (7) The Administrator will grant such a petition upon a demonstration by the owner or operator that the affected facility and associated air pollution control equipment was operated and maintained in a manner to minimize the opacity of emissions during the performance tests; that the performance tests were performed under the conditions established by the Administrator; and that the affected facility and associated air pollution control equipment were incapable of being adjusted or operated to meet the applicable opacity standard.
  - (8) The Administrator will establish an opacity standard for the affected facility meeting the above requirements at a level at which the source will be able, as indicated by the performance and opacity tests, to meet the opacity standard at all times during which the source is meeting the mass or concentration emission standard. The Administrator will promulgate the new opacity standard in the Federal Register.
- (f) Special provisions set forth under an applicable subpart shall supersede any conflicting provisions in paragraphs (a) through (e) of this section.
- (g) For the purpose of submitting compliance certifications or establishing whether or not a person has violated or is in violation of any standard in this part, nothing in this part shall preclude the use, including the exclusive use, of any credible evidence or information, relevant to whether a source would have been in compliance with applicable requirements if the appropriate performance or compliance test or procedure had been performed.

[38 FR 28565, Oct. 15, 1973, as amended at 39 FR 39873, Nov. 12, 1974; 43 FR 8800, Mar. 3, 1978; 45 FR 23379, Apr. 4, 1980; 48 FR 48335, Oct. 18, 1983; 50 FR 53113, Dec. 27, 1985; 51 FR 1790, Jan. 15, 1986; 52 FR 9781, Mar. 26, 1987; 62 FR 8328, Feb. 24, 1997; 65 FR 61749, Oct. 17, 2000]

#### § 60.12 Circumvention.

No owner or operator subject to the provisions of this part shall build, erect, install, or use any article, machine, equipment or process, the use of which conceals an emission which would otherwise constitute a violation of an applicable standard. Such concealment includes, but is not limited to, the use of gaseous diluents to achieve compliance with an opacity standard or with a standard which is based on the concentration of a pollutant in the gases discharged to the atmosphere.

[39 FR 9314, Mar. 8, 1974]

#### § 60.13 Monitoring requirements.

- (a) For the purposes of this section, all continuous monitoring systems required under applicable subparts shall be subject to the provisions of this section upon promulgation of performance specifications for continuous monitoring systems under appendix B to this part and, if the continuous monitoring system is used to demonstrate compliance with emission limits on a continuous basis, appendix F to this part, unless otherwise specified in an applicable subpart or by the Administrator. Appendix F is applicable December 4, 1987.
- (b) All continuous monitoring systems and monitoring devices shall be installed and operational prior to conducting performance tests under §60.8. Verification of operational status shall, as a minimum, include completion of the manufacturer's written requirements or recommendations for installation, operation, and calibration of the device.
- (c) If the owner or operator of an affected facility elects to submit continuous opacity monitoring system (COMS) data for compliance with the opacity standard as provided under §60.11(e)(5), he shall conduct a performance evaluation of the COMS as specified in Performance Specification 1, appendix B, of this part before the performance test required under §60.8 is conducted. Otherwise, the owner or operator of an affected facility shall conduct a performance evaluation of

the COMS or continuous emission monitoring system (CEMS) during any performance test required under §60.8 or within 30 days thereafter in accordance with the applicable performance specification in appendix B of this part. The owner or operator of an affected facility shall conduct COMS or CEMS performance evaluations at such other times as may be required by the Administrator under section 114 of the Act.

- (1) The owner or operator of an affected facility using a COMS to determine opacity compliance during any performance test required under §60.8 and as described in §60.11(e)(5) shall furnish the Administrator two or, upon request, more copies of a written report of the results of the COMS performance evaluation described in paragraph (c) of this section at least 10 days before the performance test required under §60.8 is conducted.
  - (2) Except as provided in paragraph (c)(1) of this section, the owner or operator of an affected facility shall furnish the Administrator within 60 days of completion two or, upon request, more copies of a written report of the results of the performance evaluation.
- (d)
- (1) Owners and operators of a CEMS installed in accordance with the provisions of this part, must check the zero (or low level value between 0 and 20 percent of span value) and span (50 to 100 percent of span value) calibration drifts at least once daily in accordance with a written procedure. The zero and span must, as a minimum, be adjusted whenever either the 24-hour zero drift or the 24-hour span drift exceeds two times the limit of the applicable performance specification in appendix B of this part. The system must allow the amount of the excess zero and span drift to be recorded and quantified whenever specified. Owners and operators of a COMS installed in accordance with the provisions of this part, must automatically, intrinsic to the opacity monitor, check the zero and upscale (span) calibration drifts at least once daily. For a particular COMS, the acceptable range of zero and upscale calibration materials is as defined in the applicable version of PS-1 in appendix B of this part. For a COMS, the optical surfaces, exposed to the effluent gases, must be cleaned before performing the zero and upscale drift adjustments, except for systems using automatic zero adjustments. The optical surfaces must be cleaned when the cumulative automatic zero compensation exceeds 4 percent opacity.
  - (2) Unless otherwise approved by the Administrator, the following procedures must be followed for a COMS. Minimum procedures must include an automated method for producing a simulated zero opacity condition and an upscale opacity condition using a certified neutral density filter or other related technique to produce a known obstruction of the light beam. Such procedures must provide a system check of all active analyzer internal optics with power or curvature, all active electronic circuitry including the light source and photodetector assembly, and electronic or electro-mechanical systems and hardware and or software used during normal measurement operation.
- (e) Except for system breakdowns, repairs, calibration checks, and zero and span adjustments required under paragraph (d) of this section, all continuous monitoring systems shall be in continuous operation and shall meet minimum frequency of operation requirements as follows:
- (1) All continuous monitoring systems referenced by paragraph (c) of this section for measuring opacity of emissions shall complete a minimum of one cycle of sampling and analyzing for each successive 10-second period and one cycle of data recording for each successive 6-minute period.
  - (2) All continuous monitoring systems referenced by paragraph (c) of this section for measuring emissions, except opacity, shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period.
- (f) All continuous monitoring systems or monitoring devices shall be installed such that representative measurements of emissions or process parameters from the affected facility are obtained. Additional procedures for location of continuous monitoring systems contained in the applicable Performance Specifications of appendix B of this part shall be used.
- (g) When the effluents from a single affected facility or two or more affected facilities subject to the same emission standards are combined before being released to the atmosphere, the owner or operator may install applicable continuous monitoring systems on each effluent or on the combined effluent. When the affected facilities are not subject to the same emission standards, separate continuous monitoring systems shall be installed on each effluent. When the effluent from one affected facility is released to the atmosphere through more than one point, the owner or operator shall install an applicable continuous monitoring system on each separate effluent unless the installation of fewer systems is approved by the Administrator. When more than one continuous monitoring system is used to measure the emissions from one affected facility (e.g., multiple breechings, multiple outlets), the owner or operator

shall report the results as required from each continuous monitoring system.

(h)

- (1) Owners or operators of all continuous monitoring systems for measurement of opacity shall reduce all data to 6-minute averages and for continuous monitoring systems other than opacity to 1-hour averages for time periods as defined in §60.2. Six-minute opacity averages shall be calculated from 36 or more data points equally spaced over each 6-minute period.
  - (2) For continuous monitoring systems other than opacity, 1-hour averages shall be computed as follows, except that the provisions pertaining to the validation of partial operating hours are only applicable for affected facilities that are required by the applicable subpart to include partial hours in the emission calculations:
    - (i) Except as provided under paragraph (h)(2)(iii) of this section, for a full operating hour (any clock hour with 60 minutes of unit operation), at least four valid data points are required to calculate the hourly average, i.e., one data point in each of the 15-minute quadrants of the hour.
    - (ii) Except as provided under paragraph (h)(2)(iii) of this section, for a partial operating hour (any clock hour with less than 60 minutes of unit operation), at least one valid data point in each 15-minute quadrant of the hour in which the unit operates is required to calculate the hourly average.
    - (iii) For any operating hour in which required maintenance or quality-assurance activities are performed:
      - (A) If the unit operates in two or more quadrants of the hour, a minimum of two valid data points, separated by at least 15 minutes, is required to calculate the hourly average; or
      - (B) If the unit operates in only one quadrant of the hour, at least one valid data point is required to calculate the hourly average.
    - (iv) If a daily calibration error check is failed during any operating hour, all data for that hour shall be invalidated, unless a subsequent calibration error test is passed in the same hour and the requirements of paragraph (h)(2)(iii) of this section are met, based solely on valid data recorded after the successful calibration.
    - (v) For each full or partial operating hour, all valid data points shall be used to calculate the hourly average.
    - (vi) Except as provided under paragraph (h)(2)(vii) of this section, data recorded during periods of continuous monitoring system breakdown, repair, calibration checks, and zero and span adjustments shall not be included in the data averages computed under this paragraph.
    - (vii) Owners and operators complying with the requirements of §60.7(f)(1) or (2) must include any data recorded during periods of monitor breakdown or malfunction in the data averages.
    - (viii) When specified in an applicable subpart, hourly averages for certain partial operating hours shall not be computed or included in the emission averages (e.g. hours with < 30 minutes of unit operation under §60.47b(d)).
    - (ix) Either arithmetic or integrated averaging of all data may be used to calculate the hourly averages. The data may be recorded in reduced or nonreduced form (e.g., ppm pollutant and percent O<sub>2</sub> or ng/J of pollutant).
  - (3) All excess emissions shall be converted into units of the standard using the applicable conversion procedures specified in the applicable subpart. After conversion into units of the standard, the data may be rounded to the same number of significant digits used in the applicable subpart to specify the emission limit.
- (i) After receipt and consideration of written application, the Administrator may approve alternatives to any monitoring procedures or requirements of this part including, but not limited to the following:
- (1) Alternative monitoring requirements when installation of a continuous monitoring system or monitoring device specified by this part would not provide accurate measurements due to liquid water or other interferences caused by substances in the effluent gases.
  - (2) Alternative monitoring requirements when the affected facility is infrequently operated.
  - (3) Alternative monitoring requirements to accommodate continuous monitoring systems that require additional measurements to correct for stack moisture conditions.
  - (4) Alternative locations for installing continuous monitoring systems or monitoring devices when the owner or operator can demonstrate that installation at alternate locations will enable accurate and representative

measurements.

- (5) Alternative methods of converting pollutant concentration measurements to units of the standards.
  - (6) Alternative procedures for performing daily checks of zero and span drift that do not involve use of span gases or test cells.
  - (7) Alternatives to the A.S.T.M. test methods or sampling procedures specified by any subpart.
  - (8) Alternative continuous monitoring systems that do not meet the design or performance requirements in Performance Specification 1, appendix B, but adequately demonstrate a definite and consistent relationship between its measurements and the measurements of opacity by a system complying with the requirements in Performance Specification 1. The Administrator may require that such demonstration be performed for each affected facility.
  - (9) Alternative monitoring requirements when the effluent from a single affected facility or the combined effluent from two or more affected facilities is released to the atmosphere through more than one point.
- (j) An alternative to the relative accuracy (RA) test specified in Performance Specification 2 of appendix B may be requested as follows:
- (1) An alternative to the reference method tests for determining RA is available for sources with emission rates demonstrated to be less than 50 percent of the applicable standard. A source owner or operator may petition the Administrator to waive the RA test in Section 8.4 of Performance Specification 2 and substitute the procedures in Section 16.0 if the results of a performance test conducted according to the requirements in §60.8 of this subpart or other tests performed following the criteria in §60.8 demonstrate that the emission rate of the pollutant of interest in the units of the applicable standard is less than 50 percent of the applicable standard. For sources subject to standards expressed as control efficiency levels, a source owner or operator may petition the Administrator to waive the RA test and substitute the procedures in Section 16.0 of Performance Specification 2 if the control device exhaust emission rate is less than 50 percent of the level needed to meet the control efficiency requirement. The alternative procedures do not apply if the continuous emission monitoring system is used to determine compliance continuously with the applicable standard. The petition to waive the RA test shall include a detailed description of the procedures to be applied. Included shall be location and procedure for conducting the alternative, the concentration or response levels of the alternative RA materials, and the other equipment checks included in the alternative procedure. The Administrator will review the petition for completeness and applicability. The determination to grant a waiver will depend on the intended use of the CEMS data (e.g., data collection purposes other than NSPS) and may require specifications more stringent than in Performance Specification 2 (e.g., the applicable emission limit is more stringent than NSPS).
  - (2) The waiver of a CEMS RA test will be reviewed and may be rescinded at such time, following successful completion of the alternative RA procedure, that the CEMS data indicate that the source emissions are approaching the level. The criterion for reviewing the waiver is the collection of CEMS data showing that emissions have exceeded 70 percent of the applicable standard for seven, consecutive, averaging periods as specified by the applicable regulation(s). For sources subject to standards expressed as control efficiency levels, the criterion for reviewing the waiver is the collection of CEMS data showing that exhaust emissions have exceeded 70 percent of the level needed to meet the control efficiency requirement for seven, consecutive, averaging periods as specified by the applicable regulation(s) [e.g., §60.45(g) (2) and (3), §60.73(e), and §60.84(e)]. It is the responsibility of the source operator to maintain records and determine the level of emissions relative to the criterion on the waiver of RA testing. If this criterion is exceeded, the owner or operator must notify the Administrator within 10 days of such occurrence and include a description of the nature and cause of the increasing emissions. The Administrator will review the notification and may rescind the waiver and require the owner or operator to conduct a RA test of the CEMS as specified in Section 8.4 of Performance Specification 2.

[40 FR 46255, Oct. 6, 1975; 40 FR 59205, Dec. 22, 1975, as amended at 41 FR 35185, Aug. 20, 1976; 48 FR 13326, Mar. 30, 1983; 48 FR 23610, May 25, 1983; 48 FR 32986, July 20, 1983; 52 FR 9782, Mar. 26, 1987; 52 FR 17555, May 11, 1987; 52 FR 21007, June 4, 1987; 64 FR 7463, Feb. 12, 1999; 65 FR 48920, Aug. 10, 2000; 65 FR 61749, Oct. 17, 2000; 66 FR 44980, Aug. 27, 2001; 71 FR 31102, June 1, 2006; 72 FR 32714, June 13, 2007]

Editorial Note: At 65 FR 61749, Oct. 17, 2000, §60.13 was amended by revising the words “ng/J of pollutant” to read “ng of pollutant per J of heat input” in the sixth sentence of paragraph (h). However, the amendment could not be incorporated because the words “ng/J of pollutant” do not exist in the sixth sentence of paragraph (h).

**§ 60.14 Modification.**

- (a) Except as provided under paragraphs (e) and (f) of this section, any physical or operational change to an existing facility which results in an increase in the emission rate to the atmosphere of any pollutant to which a standard applies shall be considered a modification within the meaning of section 111 of the Act. Upon modification, an existing facility shall become an affected facility for each pollutant to which a standard applies and for which there is an increase in the emission rate to the atmosphere.
- (b) Emission rate shall be expressed as kg/hr of any pollutant discharged into the atmosphere for which a standard is applicable. The Administrator shall use the following to determine emission rate:
- (1) Emission factors as specified in the latest issue of "Compilation of Air Pollutant Emission Factors," EPA Publication No. AP-42, or other emission factors determined by the Administrator to be superior to AP-42 emission factors, in cases where utilization of emission factors demonstrates that the emission level resulting from the physical or operational change will either clearly increase or clearly not increase.
  - (2) Material balances, continuous monitor data, or manual emission tests in cases where utilization of emission factors as referenced in paragraph (b)(1) of this section does not demonstrate to the Administrator's satisfaction whether the emission level resulting from the physical or operational change will either clearly increase or clearly not increase, or where an owner or operator demonstrates to the Administrator's satisfaction that there are reasonable grounds to dispute the result obtained by the Administrator utilizing emission factors as referenced in paragraph (b)(1) of this section. When the emission rate is based on results from manual emission tests or continuous monitoring systems, the procedures specified in appendix C of this part shall be used to determine whether an increase in emission rate has occurred. Tests shall be conducted under such conditions as the Administrator shall specify to the owner or operator based on representative performance of the facility. At least three valid test runs must be conducted before and at least three after the physical or operational change. All operating parameters which may affect emissions must be held constant to the maximum feasible degree for all test runs.
- (c) The addition of an affected facility to a stationary source as an expansion to that source or as a replacement for an existing facility shall not by itself bring within the applicability of this part any other facility within that source.
- (d) [Reserved]
- (e) The following shall not, by themselves, be considered modifications under this part:
- (1) Maintenance, repair, and replacement which the Administrator determines to be routine for a source category, subject to the provisions of paragraph (c) of this section and §60.15.
  - (2) An increase in production rate of an existing facility, if that increase can be accomplished without a capital expenditure on that facility.
  - (3) An increase in the hours of operation.
  - (4) Use of an alternative fuel or raw material if, prior to the date any standard under this part becomes applicable to that source type, as provided by §60.1, the existing facility was designed to accommodate that alternative use. A facility shall be considered to be designed to accommodate an alternative fuel or raw material if that use could be accomplished under the facility's construction specifications as amended prior to the change. Conversion to coal required for energy considerations, as specified in section 111(a)(8) of the Act, shall not be considered a modification.
  - (5) The addition or use of any system or device whose primary function is the reduction of air pollutants, except when an emission control system is removed or is replaced by a system which the Administrator determines to be less environmentally beneficial.
  - (6) The relocation or change in ownership of an existing facility.
- (f) Special provisions set forth under an applicable subpart of this part shall supersede any conflicting provisions of this section.
- (g) Within 180 days of the completion of any physical or operational change subject to the control measures specified in paragraph (a) of this section, compliance with all applicable standards must be achieved.
- (h) No physical change, or change in the method of operation, at an existing electric utility steam generating unit shall be treated as a modification for the purposes of this section provided that such change does not increase the maximum hourly emissions of any pollutant regulated under this section above the maximum hourly emissions achievable at that



unit during the 5 years prior to the change.

- (i) Repowering projects that are awarded funding from the Department of Energy as permanent clean coal technology demonstration projects (or similar projects funded by EPA) are exempt from the requirements of this section provided that such change does not increase the maximum hourly emissions of any pollutant regulated under this section above the maximum hourly emissions achievable at that unit during the five years prior to the change.
- (j)
  - (1) Repowering projects that qualify for an extension under section 409(b) of the Clean Air Act are exempt from the requirements of this section, provided that such change does not increase the actual hourly emissions of any pollutant regulated under this section above the actual hourly emissions achievable at that unit during the 5 years prior to the change.
  - (2) This exemption shall not apply to any new unit that:
    - (i) Is designated as a replacement for an existing unit;
    - (ii) Qualifies under section 409(b) of the Clean Air Act for an extension of an emission limitation compliance date under section 405 of the Clean Air Act; and
    - (iii) Is located at a different site than the existing unit.
- (k) The installation, operation, cessation, or removal of a temporary clean coal technology demonstration project is exempt from the requirements of this section. A temporary clean coal control technology demonstration project, for the purposes of this section is a clean coal technology demonstration project that is operated for a period of 5 years or less, and which complies with the State implementation plan for the State in which the project is located and other requirements necessary to attain and maintain the national ambient air quality standards during the project and after it is terminated.
- (l) The reactivation of a very clean coal-fired electric utility steam generating unit is exempt from the requirements of this section.

[40 FR 58419, Dec. 16, 1975, as amended at 43 FR 34347, Aug. 3, 1978; 45 FR 5617, Jan. 23, 1980; 57 FR 32339, July 21, 1992; 65 FR 61750, Oct. 17, 2000]

#### § 60.15 Reconstruction.

- (a) An existing facility, upon reconstruction, becomes an affected facility, irrespective of any change in emission rate.
- (b) "Reconstruction" means the replacement of components of an existing facility to such an extent that:
  - (1) The fixed capital cost of the new components exceeds 50 percent of the fixed capital cost that would be required to construct a comparable entirely new facility, and
  - (2) It is technologically and economically feasible to meet the applicable standards set forth in this part.
- (c) "Fixed capital cost" means the capital needed to provide all the depreciable components.
- (d) If an owner or operator of an existing facility proposes to replace components, and the fixed capital cost of the new components exceeds 50 percent of the fixed capital cost that would be required to construct a comparable entirely new facility, he shall notify the Administrator of the proposed replacements. The notice must be postmarked 60 days (or as soon as practicable) before construction of the replacements is commenced and must include the following information:
  - (1) Name and address of the owner or operator.
  - (2) The location of the existing facility.
  - (3) A brief description of the existing facility and the components which are to be replaced.
  - (4) A description of the existing air pollution control equipment and the proposed air pollution control equipment.
  - (5) An estimate of the fixed capital cost of the replacements and of constructing a comparable entirely new facility.
  - (6) The estimated life of the existing facility after the replacements.
  - (7) A discussion of any economic or technical limitations the facility may have in complying with the applicable standards of performance after the proposed replacements.

## NSPS Subpart A for General Provisions

- (e) The Administrator will determine, within 30 days of the receipt of the notice required by paragraph (d) of this section and any additional information he may reasonably require, whether the proposed replacement constitutes reconstruction.
- (f) The Administrator's determination under paragraph (e) shall be based on:
- (1) The fixed capital cost of the replacements in comparison to the fixed capital cost that would be required to construct a comparable entirely new facility;
  - (2) The estimated life of the facility after the replacements compared to the life of a comparable entirely new facility;
  - (3) The extent to which the components being replaced cause or contribute to the emissions from the facility; and
  - (4) Any economic or technical limitations on compliance with applicable standards of performance which are inherent in the proposed replacements.
- (g) Individual subparts of this part may include specific provisions which refine and delimit the concept of reconstruction set forth in this section.

[40 FR 58420, Dec. 16, 1975]

**§ 60.16 Priority list.**

A list of prioritized major source categories may be found at the following EPA web site:

<http://ecfr.gpoaccess.gov/cgi/t/text/text-idx?c=ecfr&rgn=div6&view=text&node=40:6.0.1.1.1.1&idno=40>

**§ 60.17 Incorporations by reference.**

The materials listed below are incorporated by reference in the corresponding sections noted. These incorporations by reference were approved by the Director of the Federal Register on the date listed. These materials are incorporated as they exist on the date of the approval, and a notice of any change in these materials will be published in the Federal Register. The materials are available for purchase at the corresponding address noted below, and all are available for inspection at the Library (C267-01), U.S. EPA, Research Triangle Park, NC or at the National Archives and Records Administration (NARA). For information on the availability of this material at NARA, call 202-741-6030, or go to: [http://www.archives.gov/federal\\_register/code\\_of\\_federal\\_regulations/ibr\\_locations.html](http://www.archives.gov/federal_register/code_of_federal_regulations/ibr_locations.html).

- (a) The following materials are available for purchase from at least one of the following addresses: American Society for Testing and Materials (ASTM), 100 Barr Harbor Drive, Post Office Box C700, West Conshohocken, PA 19428-2959; or ProQuest, 300 North Zeeb Road, Ann Arbor, MI 48106.
- (1) ASTM A99-76, 82 (Reapproved 1987), Standard Specification for Ferromanganese, incorporation by reference (IBR) approved for §60.261.
  - (2) ASTM A100-69, 74, 93, Standard Specification for Ferrosilicon, IBR approved for §60.261.
  - (3) ASTM A101-73, 93, Standard Specification for Ferrochromium, IBR approved for §60.261.
  - (4) ASTM A482-76, 93, Standard Specification for Ferrochromesilicon, IBR approved for §60.261.
  - (5) ASTM A483-64, 74 (Reapproved 1988), Standard Specification for Silicomanganese, IBR approved for §60.261.
  - (6) ASTM A495-76, 94, Standard Specification for Calcium-Silicon and Calcium Manganese-Silicon, IBR approved for §60.261.
  - (7) ASTM D86-78, 82, 90, 93, 95, 96, Distillation of Petroleum Products, IBR approved for §§60.562-2(d), 60.593(d), 60.593a(d), and 60.633(h).
  - (8) ASTM D129-64, 78, 95, 00, Standard Test Method for Sulfur in Petroleum Products (General Bomb Method), IBR approved for §§60.106(j)(2), 60.335(b)(10)(i), and Appendix A: Method 19, 12.5.2.2.3.
  - (9) ASTM D129-00 (Reapproved 2005), Standard Test Method for Sulfur in Petroleum Products (General Bomb Method), IBR approved for §60.4415(a)(1)(i).
  - (10) ASTM D240-76, 92, Standard Test Method for Heat of Combustion of Liquid Hydrocarbon Fuels by Bomb Calorimeter, IBR approved for §§60.46(c), 60.296(b), and Appendix A: Method 19, Section 12.5.2.2.3.
  - (11) ASTM D270-65, 75, Standard Method of Sampling Petroleum and Petroleum Products, IBR approved for Appendix A: Method 19, Section 12.5.2.2.1.

## NSPS Subpart A for General Provisions

- (12) ASTM D323–82, 94, Test Method for Vapor Pressure of Petroleum Products (Reid Method), IBR approved for §§60.111(l), 60.111a(g), 60.111b(g), and 60.116b(f)(2)(ii).
- (13) ASTM D388–77, 90, 91, 95, 98a, 99 (Reapproved 2004)e1, Standard Specification for Classification of Coals by Rank, IBR approved for §§60.24(h)(8), 60.41 of subpart D of this part, 60.45(f)(4)(i), 60.45(f)(4)(ii), 60.45(f)(4)(vi), 60.41Da of subpart Da of this part, 60.41b of subpart Db of this part, 60.41c of subpart Dc of this part, and 60.4102.
- (14) ASTM D388–77, 90, 91, 95, 98a, Standard Specification for Classification of Coals by Rank, IBR approved for §§60.251(b) and (c) of subpart Y of this part.
- (15) ASTM D396–78, 89, 90, 92, 96, 98, Standard Specification for Fuel Oils, IBR approved for §§60.41b of subpart Db of this part, 60.41c of subpart Dc of this part, 60.111(b) of subpart K of this part, and 60.111a(b) of subpart Ka of this part.
- (16) ASTM D975–78, 96, 98a, Standard Specification for Diesel Fuel Oils, IBR approved for §§60.111(b) of subpart K of this part and 60.111a(b) of subpart Ka of this part.
- (17) ASTM D1072–80, 90 (Reapproved 1994), Standard Test Method for Total Sulfur in Fuel Gases, IBR approved for §60.335(b)(10)(ii).
- (18) ASTM D1072–90 (Reapproved 1999), Standard Test Method for Total Sulfur in Fuel Gases, IBR approved for §60.4415(a)(1)(ii).
- (19) ASTM D1137–53, 75, Standard Method for Analysis of Natural Gases and Related Types of Gaseous Mixtures by the Mass Spectrometer, IBR approved for §60.45(f)(5)(i).
- (20) ASTM D1193–77, 91, Standard Specification for Reagent Water, IBR approved for Appendix A: Method 5, Section 7.1.3; Method 5E, Section 7.2.1; Method 5F, Section 7.2.1; Method 6, Section 7.1.1; Method 7, Section 7.1.1; Method 7C, Section 7.1.1; Method 7D, Section 7.1.1; Method 10A, Section 7.1.1; Method 11, Section 7.1.3; Method 12, Section 7.1.3; Method 13A, Section 7.1.2; Method 26, Section 7.1.2; Method 26A, Section 7.1.2; and Method 29, Section 7.2.2.
- (21) ASTM D1266–87, 91, 98, Standard Test Method for Sulfur in Petroleum Products (Lamp Method), IBR approved for §§60.106(j)(2) and 60.335(b)(10)(i).
- (22) ASTM D1266–98 (Reapproved 2003)e1, Standard Test Method for Sulfur in Petroleum Products (Lamp Method), IBR approved for §60.4415(a)(1)(i).
- (23) ASTM D1475–60 (Reapproved 1980), 90, Standard Test Method for Density of Paint, Varnish Lacquer, and Related Products, IBR approved for §60.435(d)(1), Appendix A: Method 24, Section 6.1; and Method 24A, Sections 6.5 and 7.1.
- (24) ASTM D1552–83, 95, 01, Standard Test Method for Sulfur in Petroleum Products (High-Temperature Method), IBR approved for §§60.106(j)(2), 60.335(b)(10)(i), and Appendix A: Method 19, Section 12.5.2.2.3.
- (25) ASTM D1552–03, Standard Test Method for Sulfur in Petroleum Products (High-Temperature Method), IBR approved for §60.4415(a)(1)(i).
- (26) ASTM D1826–77, 94, Standard Test Method for Calorific Value of Gases in Natural Gas Range by Continuous Recording Calorimeter, IBR approved for §§60.45(f)(5)(ii), 60.46(c)(2), 60.296(b)(3), and Appendix A: Method 19, Section 12.3.2.4.
- (27) ASTM D1835–87, 91, 97, 03a, Standard Specification for Liquefied Petroleum (LP) Gases, IBR approved for §§60.41Da of subpart Da of this part, 60.41b of subpart Db of this part, and 60.41c of subpart Dc of this part.
- (28) ASTM D1945–64, 76, 91, 96, Standard Method for Analysis of Natural Gas by Gas Chromatography, IBR approved for §60.45(f)(5)(i).
- (29) ASTM D1946–77, 90 (Reapproved 1994), Standard Method for Analysis of Reformed Gas by Gas Chromatography, IBR approved for §§60.18(f)(3), 60.45(f)(5)(i), 60.564(f)(1), 60.614(e)(2)(ii), 60.614(e)(4), 60.664(e)(2)(ii), 60.664(e)(4), 60.704(d)(2)(ii), and 60.704(d)(4).
- (30) ASTM D2013–72, 86, Standard Method of Preparing Coal Samples for Analysis, IBR approved for Appendix A: Method 19, Section 12.5.2.1.3.

APPENDIX NS

NSPS Subpart A for General Provisions

- (31) ASTM D2015–77 (Reapproved 1978), 96, Standard Test Method for Gross Calorific Value of Solid Fuel by the Adiabatic Bomb Calorimeter, IBR approved for §60.45(f)(5)(ii), 60.46(c)(2), and Appendix A: Method 19, Section 12.5.2.1.3.
- (32) ASTM D2016–74, 83, Standard Test Methods for Moisture Content of Wood, IBR approved for Appendix A: Method 28, Section 16.1.1.
- (33) ASTM D2234–76, 96, 97b, 98, Standard Methods for Collection of a Gross Sample of Coal, IBR approved for Appendix A: Method 19, Section 12.5.2.1.1.
- (34) ASTM D2369–81, 87, 90, 92, 93, 95, Standard Test Method for Volatile Content of Coatings, IBR approved for Appendix A: Method 24, Section 6.2.
- (35) ASTM D2382–76, 88, Heat of Combustion of Hydrocarbon Fuels by Bomb Calorimeter (High-Precision Method), IBR approved for §§60.18(f)(3), 60.485(g)(6), 60.485a(g)(6), 60.564(f)(3), 60.614(e)(4), 60.664(e)(4), and 60.704(d)(4).
- (36) ASTM D2504–67, 77, 88 (Reapproved 1993), Noncondensable Gases in C3 and Lighter Hydrocarbon Products by Gas Chromatography, IBR approved for §§60.485(g)(5) and 60.485a(g)(5).
- (37) ASTM D2584–68 (Reapproved 1985), 94, Standard Test Method for Ignition Loss of Cured Reinforced Resins, IBR approved for §60.685(c)(3)(i).
- (38) ASTM D2597–94 (Reapproved 1999), Standard Test Method for Analysis of Demethanized Hydrocarbon Liquid Mixtures Containing Nitrogen and Carbon Dioxide by Gas Chromatography, IBR approved for §60.335(b)(9)(i).
- (39) ASTM D2622–87, 94, 98, Standard Test Method for Sulfur in Petroleum Products by Wavelength Dispersive X-Ray Fluorescence Spectrometry, IBR approved for §§60.106(j)(2) and 60.335(b)(10)(i).
- (40) ASTM D2622–05, Standard Test Method for Sulfur in Petroleum Products by Wavelength Dispersive X-Ray Fluorescence Spectrometry, IBR approved for §60.4415(a)(1)(i).
- (41) ASTM D2879–83, 96, 97, Test Method for Vapor Pressure–Temperature Relationship and Initial Decomposition Temperature of Liquids by Iscteniscope, IBR approved for §§60.111b(f)(3), 60.116b(e)(3)(ii), 60.116b(f)(2)(i), 60.485(e)(1), and 60.485a(e)(1).
- (42) ASTM D2880–78, 96, Standard Specification for Gas Turbine Fuel Oils, IBR approved for §§60.111(b), 60.111a(b), and 60.335(d).
- (43) ASTM D2908–74, 91, Standard Practice for Measuring Volatile Organic Matter in Water by Aqueous-Injection Gas Chromatography, IBR approved for §60.564(j).
- (44) ASTM D2986–71, 78, 95a, Standard Method for Evaluation of Air, Assay Media by the Monodisperse DOP (Dioctyl Phthalate) Smoke Test, IBR approved for Appendix A: Method 5, Section 7.1.1; Method 12, Section 7.1.1; and Method 13A, Section 7.1.1.2.
- (45) ASTM D3173–73, 87, Standard Test Method for Moisture in the Analysis Sample of Coal and Coke, IBR approved for Appendix A: Method 19, Section 12.5.2.1.3.
- (46) ASTM D3176–74, 89, Standard Method for Ultimate Analysis of Coal and Coke, IBR approved for §60.45(f)(5)(i) and Appendix A: Method 19, Section 12.3.2.3.
- (47) ASTM D3177–75, 89, Standard Test Method for Total Sulfur in the Analysis Sample of Coal and Coke, IBR approved for Appendix A: Method 19, Section 12.5.2.1.3.
- (48) ASTM D3178–73 (Reapproved 1979), 89, Standard Test Methods for Carbon and Hydrogen in the Analysis Sample of Coal and Coke, IBR approved for §60.45(f)(5)(i).
- (49) ASTM D3246–81, 92, 96, Standard Test Method for Sulfur in Petroleum Gas by Oxidative Microcoulometry, IBR approved for §60.335(b)(10)(ii).
- (50) ASTM D3246–05, Standard Test Method for Sulfur in Petroleum Gas by Oxidative Microcoulometry, IBR approved for §60.4415(a)(1)(ii).
- (51) ASTM D3270–73T, 80, 91, 95, Standard Test Methods for Analysis for Fluoride Content of the Atmosphere and Plant Tissues (Semiautomated Method), IBR approved for Appendix A: Method 13A, Section 16.1.

APPENDIX NS

NSPS Subpart A for General Provisions

- (52) ASTM D3286–85, 96, Standard Test Method for Gross Calorific Value of Coal and Coke by the Isoperibol Bomb Calorimeter, IBR approved for Appendix A: Method 19, Section 12.5.2.1.3.
- (53) ASTM D3370–76, 95a, Standard Practices for Sampling Water, IBR approved for §60.564(j).
- (54) ASTM D3792–79, 91, Standard Test Method for Water Content of Water-Reducible Paints by Direct Injection into a Gas Chromatograph, IBR approved for Appendix A: Method 24, Section 6.3.
- (55) ASTM D4017–81, 90, 96a, Standard Test Method for Water in Paints and Paint Materials by the Karl Fischer Titration Method, IBR approved for Appendix A: Method 24, Section 6.4.
- (56) ASTM D4057–81, 95, Standard Practice for Manual Sampling of Petroleum and Petroleum Products, IBR approved for Appendix A: Method 19, Section 12.5.2.2.3.
- (57) ASTM D4057–95 (Reapproved 2000), Standard Practice for Manual Sampling of Petroleum and Petroleum Products, IBR approved for §60.4415(a)(1).
- (58) ASTM D4084–82, 94, Standard Test Method for Analysis of Hydrogen Sulfide in Gaseous Fuels (Lead Acetate Reaction Rate Method), IBR approved for §60.334(h)(1).
- (59) ASTM D4084–05, Standard Test Method for Analysis of Hydrogen Sulfide in Gaseous Fuels (Lead Acetate Reaction Rate Method), IBR approved for §§60.4360 and 60.4415(a)(1)(ii).
- (60) ASTM D4177–95, Standard Practice for Automatic Sampling of Petroleum and Petroleum Products, IBR approved for Appendix A: Method 19, Section 12.5.2.2.1.
- (61) ASTM D4177–95 (Reapproved 2000), Standard Practice for Automatic Sampling of Petroleum and Petroleum Products, IBR approved for §60.4415(a)(1).
- (62) ASTM D4239–85, 94, 97, Standard Test Methods for Sulfur in the Analysis Sample of Coal and Coke Using High Temperature Tube Furnace Combustion Methods, IBR approved for Appendix A: Method 19, Section 12.5.2.1.3.
- (63) ASTM D4294–02, Standard Test Method for Sulfur in Petroleum and Petroleum Products by Energy-Dispersive X-Ray Fluorescence Spectrometry, IBR approved for §60.335(b)(10)(i).
- (64) ASTM D4294–03, Standard Test Method for Sulfur in Petroleum and Petroleum Products by Energy-Dispersive X-Ray Fluorescence Spectrometry, IBR approved for §60.4415(a)(1)(i).
- (65) ASTM D4442–84, 92, Standard Test Methods for Direct Moisture Content Measurement in Wood and Wood-base Materials, IBR approved for Appendix A: Method 28, Section 16.1.1.
- (66) ASTM D4444–92, Standard Test Methods for Use and Calibration of Hand-Held Moisture Meters, IBR approved for Appendix A: Method 28, Section 16.1.1.
- (67) ASTM D4457–85 (Reapproved 1991), Test Method for Determination of Dichloromethane and 1, 1, 1-Trichloroethane in Paints and Coatings by Direct Injection into a Gas Chromatograph, IBR approved for Appendix A: Method 24, Section 6.5.
- (68) ASTM D4468–85 (Reapproved 2000), Standard Test Method for Total Sulfur in Gaseous Fuels by Hydrogenolysis and Rateometric Colorimetry, IBR approved for §§60.335(b)(10)(ii) and 60.4415(a)(1)(ii).
- (69) ASTM D4629–02, Standard Test Method for Trace Nitrogen in Liquid Petroleum Hydrocarbons by Syringe/Inlet Oxidative Combustion and Chemiluminescence Detection, IBR approved for §§60.49b(e) and 60.335(b)(9)(i).
- (70) ASTM D4809–95, Standard Test Method for Heat of Combustion of Liquid Hydrocarbon Fuels by Bomb Calorimeter (Precision Method), IBR approved for §§60.18(f)(3), 60.485(g)(6), 60.485a(g)(6), 60.564(f)(3), 60.614(d)(4), 60.664(e)(4), and 60.704(d)(4).
- (71) ASTM D4810–88 (Reapproved 1999), Standard Test Method for Hydrogen Sulfide in Natural Gas Using Length of Stain Detector Tubes, IBR approved for §§60.4360 and 60.4415(a)(1)(ii).
- (72) ASTM D5287–97 (Reapproved 2002), Standard Practice for Automatic Sampling of Gaseous Fuels, IBR approved for §60.4415(a)(1).
- (73) ASTM D5403–93, Standard Test Methods for Volatile Content of Radiation Curable Materials, IBR approved for Appendix A: Method 24, Section 6.6.
- (74) ASTM D5453–00, Standard Test Method for Determination of Total Sulfur in Light Hydrocarbons, Motor Fuels

- and Oils by Ultraviolet Fluorescence, IBR approved for §60.335(b)(10)(i).
- (75) ASTM D5453–05, Standard Test Method for Determination of Total Sulfur in Light Hydrocarbons, Motor Fuels and Oils by Ultraviolet Fluorescence, IBR approved for §60.4415(a)(1)(i).
- (76) ASTM D5504–01, Standard Test Method for Determination of Sulfur Compounds in Natural Gas and Gaseous Fuels by Gas Chromatography and Chemiluminescence, IBR approved for §§60.334(h)(1) and 60.4360.
- (77) ASTM D5762–02, Standard Test Method for Nitrogen in Petroleum and Petroleum Products by Boat-Inlet Chemiluminescence, IBR approved for §60.335(b)(9)(i).
- (78) ASTM D5865–98, Standard Test Method for Gross Calorific Value of Coal and Coke, IBR approved for §60.45(f)(5)(ii), 60.46(c)(2), and Appendix A: Method 19, Section 12.5.2.1.3.
- (79) ASTM D6216–98, Standard Practice for Opacity Monitor Manufacturers to Certify Conformance with Design and Performance Specifications, IBR approved for Appendix B, Performance Specification 1.
- (80) ASTM D6228–98, Standard Test Method for Determination of Sulfur Compounds in Natural Gas and Gaseous Fuels by Gas Chromatography and Flame Photometric Detection, IBR approved for §60.334(h)(1).
- (81) ASTM D6228–98 (Reapproved 2003), Standard Test Method for Determination of Sulfur Compounds in Natural Gas and Gaseous Fuels by Gas Chromatography and Flame Photometric Detection, IBR approved for §§60.4360 and 60.4415.
- (82) ASTM D6348–03, Standard Test Method for Determination of Gaseous Compounds by Extractive Direct Interface Fourier Transform Infrared (FTIR) Spectroscopy, IBR approved for table 7 of Subpart IIII of this part and table 2 of subpart JJJJ of this part.
- (83) ASTM D6366–99, Standard Test Method for Total Trace Nitrogen and Its Derivatives in Liquid Aromatic Hydrocarbons by Oxidative Combustion and Electrochemical Detection, IBR approved for §60.335(b)(9)(i).
- (84) ASTM D6420–99 (Reapproved 2004) Standard Test Method for Determination of Gaseous Organic Compounds by Direct Interface Gas Chromatography-Mass Spectrometry, IBR approved for table 2 of subpart JJJJ of this part.
- (85) ASTM D6522–00, Standard Test Method for Determination of Nitrogen Oxides, Carbon Monoxide, and Oxygen Concentrations in Emissions from Natural Gas-Fired Reciprocating Engines, Combustion Turbines, Boilers, and Process Heaters Using Portable Analyzers, IBR approved for §60.335(a).
- (86) ASTM D6522–00 (Reapproved 2005), Standard Test Method for Determination of Nitrogen Oxides, Carbon Monoxide, and Oxygen Concentrations in Emissions from Natural Gas-Fired Reciprocating Engines, Combustion Turbines, Boilers, and Process Heaters Using Portable Analyzers, IBR approved for table 2 of subpart JJJJ of this part.
- (87) ASTM D6667–01, Standard Test Method for Determination of Total Volatile Sulfur in Gaseous Hydrocarbons and Liquefied Petroleum Gases by Ultraviolet Fluorescence, IBR approved for §60.335(b)(10)(ii).
- (88) ASTM D6667–04, Standard Test Method for Determination of Total Volatile Sulfur in Gaseous Hydrocarbons and Liquefied Petroleum Gases by Ultraviolet Fluorescence, IBR approved for §60.4415(a)(1)(ii).
- (89) ASTM D6784–02, Standard Test Method for Elemental, Oxidized, Particle-Bound and Total Mercury in Flue Gas Generated from Coal-Fired Stationary Sources (Ontario Hydro Method), IBR approved for Appendix B to part 60, Performance Specification 12A, Section 8.6.2.
- (90) ASTM E168–67, 77, 92, General Techniques of Infrared Quantitative Analysis, IBR approved for §§60.485a(d)(1), 60.593(b)(2), 60.593a(b)(2), and 60.632(f).
- (91) ASTM E169–63, 77, 93, General Techniques of Ultraviolet Quantitative Analysis, IBR approved for §§60.485a(d)(1), 60.593(b)(2), 60.593a(b)(2), and 60.632(f).
- (92) ASTM E260–73, 91, 96, General Gas Chromatography Procedures, IBR approved for §§60.485a(d)(1), 60.593(b)(2), 60.593a(b)(2), and 60.632(f).
- (b) The following material is available for purchase from the Association of Official Analytical Chemists, 1111 North 19th Street, Suite 210, Arlington, VA 22209.
- (1) AOAC Method 9, Official Methods of Analysis of the Association of Official Analytical Chemists, 11th edition, 1970, pp. 11–12, IBR approved January 27, 1983 for §§60.204(b)(3), 60.214(b)(3), 60.224(b)(3), 60.234(b)(3).

APPENDIX NS

NSPS Subpart A for General Provisions

- (c) The following material is available for purchase from the American Petroleum Institute, 1220 L Street NW., Washington, DC 20005.
- (1) API Publication 2517, Evaporation Loss from External Floating Roof Tanks, Second Edition, February 1980, IBR approved January 27, 1983, for §§60.111(i), 60.111a(f), 60.111a(f)(1) and 60.116b(e)(2)(i).
- (d) The following material is available for purchase from the Technical Association of the Pulp and Paper Industry (TAPPI), Dunwoody Park, Atlanta, GA 30341.
- (1) TAPPI Method T624 os-68, IBR approved January 27, 1983 for §60.285(d)(3).
- (e) The following material is available for purchase from the Water Pollution Control Federation (WPCF), 2626 Pennsylvania Avenue NW., Washington, DC 20037.
- (1) Method 209A, Total Residue Dried at 103–105 °C, in Standard Methods for the Examination of Water and Wastewater, 15th Edition, 1980, IBR approved February 25, 1985 for §60.683(b).
- (f) The following material is available for purchase from the following address: Underwriter's Laboratories, Inc. (UL), 333 Pfingsten Road, Northbrook, IL 60062.
- (1) UL 103, Sixth Edition revised as of September 3, 1986, Standard for Chimneys, Factory-built, Residential Type and Building Heating Appliance.
- (g) The following material is available for purchase from the following address: West Coast Lumber Inspection Bureau, 6980 SW. Barnes Road, Portland, OR 97223.
- (1) West Coast Lumber Standard Grading Rules No. 16, pages 5–21 and 90 and 91, September 3, 1970, revised 1984.
- (h) The following material is available for purchase from the American Society of Mechanical Engineers (ASME), Three Park Avenue, New York, NY 10016–5990.
- (1) ASME QRO–1–1994, Standard for the Qualification and Certification of Resource Recovery Facility Operators, IBR approved for §§60.56a, 60.54b(a), 60.54b(b), 60.1185(a), 60.1185(c)(2), 60.1675(a), and 60.1675(c)(2).
  - (2) ASME PTC 4.1–1964 (Reaffirmed 1991), Power Test Codes: Test Code for Steam Generating Units (with 1968 and 1969 Addenda), IBR approved for §§60.46b of subpart Db of this part, 60.58a(h)(6)(ii), 60.58b(i)(6)(ii), 60.1320(a)(3) and 60.1810(a)(3).
  - (3) ASME Interim Supplement 19.5 on Instruments and Apparatus: Application, Part II of Fluid Meters, 6th Edition (1971), IBR approved for §§60.58a(h)(6)(ii), 60.58b(i)(6)(ii), 60.1320(a)(4), and 60.1810(a)(4).
  - (4) ANSI/ASME PTC 19.10–1981, Flue and Exhaust Gas Analyses [Part 10, Instruments and Apparatus], IBR approved for Tables 1 and 3 of subpart EEEE, Tables 2 and 4 of subpart FFFF, Table 2 of subpart JJJJ, and §§60.4415(a)(2) and 60.4415(a)(3) of subpart KKKK of this part.
- (i) Test Methods for Evaluating Solid Waste, Physical/Chemical Methods,” EPA Publication SW–846 Third Edition (November 1986), as amended by Updates I (July 1992), II (September 1994), IIA (August, 1993), IIB (January 1995), and III (December 1996). This document may be obtained from the U.S. EPA, Office of Solid Waste and Emergency Response, Waste Characterization Branch, Washington, DC 20460, and is incorporated by reference for appendix A to part 60, Method 29, Sections 7.5.34; 9.2.1; 9.2.3; 10.2; 10.3; 11.1.1; 11.1.3; 13.2.1; 13.2.2; 13.3.1; and Table 29–3.
- (j) “Standard Methods for the Examination of Water and Wastewater,” 16th edition, 1985. Method 303F: “Determination of Mercury by the Cold Vapor Technique.” This document may be obtained from the American Public Health Association, 1015 18th Street, NW., Washington, DC 20036, and is incorporated by reference for appendix A to part 60, Method 29, Sections 9.2.3; 10.3; and 11.1.3.
- (k) This material is available for purchase from the American Hospital Association (AHA) Service, Inc., Post Office Box 92683, Chicago, Illinois 60675–2683. You may inspect a copy at EPA's Air and Radiation Docket and Information Center (Docket A–91–61, Item IV–J–124), Room M–1500, 1200 Pennsylvania Ave., NW., Washington, DC.
- (1) An Ounce of Prevention: Waste Reduction Strategies for Health Care Facilities. American Society for Health Care Environmental Services of the American Hospital Association. Chicago, Illinois. 1993. AHA Catalog No. 057007. ISBN 0–87258–673–5. IBR approved for §60.35e and §60.55c.
- (l) This material is available for purchase from the National Technical Information Services, 5285 Port Royal Road, Springfield, Virginia 22161. You may inspect a copy at EPA's Air and Radiation Docket and Information Center

(Docket A-91-61, Item IV-J-125), Room M-1500, 1200 Pennsylvania Ave., NW., Washington, DC.

- (1) OMB Bulletin No. 93-17: Revised Statistical Definitions for Metropolitan Areas. Office of Management and Budget, June 30, 1993. NTIS No. PB 93-192-664. IBR approved for §60.31e.
- (m) This material is available for purchase from at least one of the following addresses: The Gas Processors Association, 6526 East 60th Street, Tulsa, OK, 74145; or Information Handling Services, 15 Inverness Way East, PO Box 1154, Englewood, CO 80150-1154. You may inspect a copy at EPA's Air and Radiation Docket and Information Center, Room B108, 1301 Constitution Ave., NW., Washington, DC 20460.
- (1) Gas Processors Association Method 2377-86, Test for Hydrogen Sulfide and Carbon Dioxide in Natural Gas Using Length of Stain Tubes, IBR approved for §§60.334(h)(1), 60.4360, and 60.4415(a)(1)(ii).
- (2) [Reserved]
- (n) This material is available for purchase from IHS Inc., 15 Inverness Way East, Englewood, CO 80112.
- (1) International Organization for Standards 8178-4: 1996(E), Reciprocating Internal Combustion Engines—Exhaust Emission Measurement—Part 4: Test Cycles for Different Engine Applications, IBR approved for §60.4241(b).
- (2) [Reserved]

[48 FR 3735, Jan. 27, 1983]

Editorial Note: For Federal Register citations affecting §60.17, see the List of CFR Sections Affected, which appears in the Finding Aids section of the printed volume and on GPO Access.

#### § 60.18 General control device requirements.

- (a) Introduction. This section contains requirements for control devices used to comply with applicable subparts of parts 60 and 61. The requirements are placed here for administrative convenience and only apply to facilities covered by subparts referring to this section.
- (b) Flares. Paragraphs (c) through (f) apply to flares.
- (c)
- (1) Flares shall be designed for and operated with no visible emissions as determined by the methods specified in paragraph (f), except for periods not to exceed a total of 5 minutes during any 2 consecutive hours.
- (2) Flares shall be operated with a flame present at all times, as determined by the methods specified in paragraph (f).
- (3) An owner/operator has the choice of adhering to either the heat content specifications in paragraph (c)(3)(ii) of this section and the maximum tip velocity specifications in paragraph (c)(4) of this section, or adhering to the requirements in paragraph (c)(3)(i) of this section.
- (i)
- (A) Flares shall be used that have a diameter of 3 inches or greater, are nonassisted, have a hydrogen content of 8.0 percent (by volume), or greater, and are designed for and operated with an exit velocity less than 37.2 m/sec (122 ft/sec) and less than the velocity,  $V_{max}$ , as determined by the following equation:
- $$V_{max} = (XH_2 - K_1) * K_2$$
- Where:
- $V_{max}$  = Maximum permitted velocity, m/sec.
- $K_1$  = Constant, 6.0 volume-percent hydrogen.
- $K_2$  = Constant, 3.9(m/sec)/volume-percent hydrogen.
- $XH_2$  = The volume-percent of hydrogen, on a wet basis, as calculated by using the American Society for Testing and Materials (ASTM) Method D1946-77. (Incorporated by reference as specified in §60.17).
- (B) The actual exit velocity of a flare shall be determined by the method specified in paragraph (f)(4) of this section.
- (ii) Flares shall be used only with the net heating value of the gas being combusted being 11.2 MJ/scm (300 Btu/scf) or greater if the flare is steam-assisted or air-assisted; or with the net heating value of the gas being



## NSPS Subpart A for General Provisions

combusted being 7.45 MJ/scm (200 Btu/scf) or greater if the flare is nonassisted. The net heating value of the gas being combusted shall be determined by the methods specified in paragraph (f)(3) of this section.

(4)

- (i) Steam-assisted and nonassisted flares shall be designed for and operated with an exit velocity, as determined by the methods specified in paragraph (f)(4) of this section, less than 18.3 m/sec (60 ft/sec), except as provided in paragraphs (c)(4) (ii) and (iii) of this section.
- (ii) Steam-assisted and nonassisted flares designed for and operated with an exit velocity, as determined by the methods specified in paragraph (f)(4), equal to or greater than 18.3 m/sec (60 ft/sec) but less than 122 m/sec (400 ft/sec) are allowed if the net heating value of the gas being combusted is greater than 37.3 MJ/scm (1,000 Btu/scf).
- (iii) Steam-assisted and nonassisted flares designed for and operated with an exit velocity, as determined by the methods specified in paragraph (f)(4), less than the velocity,  $V_{max}$ , as determined by the method specified in paragraph (f)(5), and less than 122 m/sec (400 ft/sec) are allowed.

(5) Air-assisted flares shall be designed and operated with an exit velocity less than the velocity,  $V_{max}$ , as determined by the method specified in paragraph (f)(6).

(6) Flares used to comply with this section shall be steam-assisted, air-assisted, or nonassisted.

(d) Owners or operators of flares used to comply with the provisions of this subpart shall monitor these control devices to ensure that they are operated and maintained in conformance with their designs. Applicable subparts will provide provisions stating how owners or operators of flares shall monitor these control devices.

(e) Flares used to comply with provisions of this subpart shall be operated at all times when emissions may be vented to them.

(f)

(1) Method 22 of appendix A to this part shall be used to determine the compliance of flares with the visible emission provisions of this subpart. The observation period is 2 hours and shall be used according to Method 22.

(2) The presence of a flare pilot flame shall be monitored using a thermocouple or any other equivalent device to detect the presence of a flame.

(3) The net heating value of the gas being combusted in a flare shall be calculated using the following equation:

$$H_T = K \sum_{i=1}^n C_i H_i$$

where:

$H_T$  = Net heating value of the sample, MJ/scm; where the net enthalpy per mole of off gas is based on combustion at 25 °C and 760 mm Hg, but the standard temperature for determining the volume corresponding to one mole is 20 °C;

$$K = \text{Constant} \cdot 1.740 \times 10^{-7} \left( \frac{1}{\text{ppm}} \right) \left( \frac{\text{g mole}}{\text{scm}} \right) \left( \frac{\text{MJ}}{\text{kcal}} \right)$$

where the standard temperature for  $\left( \frac{\text{g mole}}{\text{scm}} \right)$  is 20°C;

$C_i$  = Concentration of sample component  $i$  in ppm on a wet basis, as measured for organics by Reference Method 18 and measured for hydrogen and carbon monoxide by ASTM D1946-77 or 90 (Reapproved 1994) (Incorporated by reference as specified in §60.17); and

$H_i$  = Net heat of combustion of sample component  $i$ , kcal/g mole at 25 °C and 760 mm Hg. The heats of combustion may be determined using ASTM D2382-76 or 88 or D4809-95 (incorporated by reference as specified in §60.17) if published values are not available or cannot be calculated.

(4) The actual exit velocity of a flare shall be determined by dividing the volumetric flowrate (in units of standard temperature and pressure), as determined by Reference Methods 2, 2A, 2C, or 2D as appropriate; by the unobstructed (free) cross sectional area of the flare tip.

(5) The maximum permitted velocity,  $V_{max}$ , for flares complying with paragraph (c)(4)(iii) shall be determined by

the following equation.

$$\text{Log}_{10}(\text{Vmax}) = (\text{HT}+28.8)/31.7$$

Vmax = Maximum permitted velocity, M/sec

28.8 = Constant

31.7 = Constant

H<sub>T</sub> = The net heating value as determined in paragraph (f)(3).

- (6) The maximum permitted velocity, Vmax, for air-assisted flares shall be determined by the following equation.

$$\text{Vmax} = 8.706+0.7084 (\text{HT})$$

Vmax = Maximum permitted velocity, m/sec

8.706 = Constant

0.7084 = Constant

H<sub>T</sub> = The net heating value as determined in paragraph (f)(3).

[51 FR 2701, Jan. 21, 1986, as amended at 63 FR 24444, May 4, 1998; 65 FR 61752, Oct. 17, 2000]

**§ 60.19 General notification and reporting requirements.**

- (a) For the purposes of this part, time periods specified in days shall be measured in calendar days, even if the word "calendar" is absent, unless otherwise specified in an applicable requirement.
- (b) For the purposes of this part, if an explicit postmark deadline is not specified in an applicable requirement for the submittal of a notification, application, report, or other written communication to the Administrator, the owner or operator shall postmark the submittal on or before the number of days specified in the applicable requirement. For example, if a notification must be submitted 15 days before a particular event is scheduled to take place, the notification shall be postmarked on or before 15 days preceding the event; likewise, if a notification must be submitted 15 days after a particular event takes place, the notification shall be delivered or postmarked on or before 15 days following the end of the event. The use of reliable non-Government mail carriers that provide indications of verifiable delivery of information required to be submitted to the Administrator, similar to the postmark provided by the U.S. Postal Service, or alternative means of delivery, including the use of electronic media, agreed to by the permitting authority, is acceptable.
- (c) Notwithstanding time periods or postmark deadlines specified in this part for the submittal of information to the Administrator by an owner or operator, or the review of such information by the Administrator, such time periods or deadlines may be changed by mutual agreement between the owner or operator and the Administrator. Procedures governing the implementation of this provision are specified in paragraph (f) of this section.
- (d) If an owner or operator of an affected facility in a State with delegated authority is required to submit periodic reports under this part to the State, and if the State has an established timeline for the submission of periodic reports that is consistent with the reporting frequency(ies) specified for such facility under this part, the owner or operator may change the dates by which periodic reports under this part shall be submitted (without changing the frequency of reporting) to be consistent with the State's schedule by mutual agreement between the owner or operator and the State. The allowance in the previous sentence applies in each State beginning 1 year after the affected facility is required to be in compliance with the applicable subpart in this part. Procedures governing the implementation of this provision are specified in paragraph (f) of this section.
- (e) If an owner or operator supervises one or more stationary sources affected by standards set under this part and standards set under part 61, part 63, or both such parts of this chapter, he/she may arrange by mutual agreement between the owner or operator and the Administrator (or the State with an approved permit program) a common schedule on which periodic reports required by each applicable standard shall be submitted throughout the year. The allowance in the previous sentence applies in each State beginning 1 year after the stationary source is required to be in compliance with the applicable subpart in this part, or 1 year after the stationary source is required to be in compliance with the applicable 40 CFR part 61 or part 63 of this chapter standard, whichever is latest. Procedures governing the implementation of this provision are specified in paragraph (f) of this section.
- (f)

- (1)
  - (i) Until an adjustment of a time period or postmark deadline has been approved by the Administrator under paragraphs (f)(2) and (f)(3) of this section, the owner or operator of an affected facility remains strictly subject to the requirements of this part.
  - (ii) An owner or operator shall request the adjustment provided for in paragraphs (f)(2) and (f)(3) of this section each time he or she wishes to change an applicable time period or postmark deadline specified in this part.
- (2) Notwithstanding time periods or postmark deadlines specified in this part for the submittal of information to the Administrator by an owner or operator, or the review of such information by the Administrator, such time periods or deadlines may be changed by mutual agreement between the owner or operator and the Administrator. An owner or operator who wishes to request a change in a time period or postmark deadline for a particular requirement shall request the adjustment in writing as soon as practicable before the subject activity is required to take place. The owner or operator shall include in the request whatever information he or she considers useful to convince the Administrator that an adjustment is warranted.
- (3) If, in the Administrator's judgment, an owner or operator's request for an adjustment to a particular time period or postmark deadline is warranted, the Administrator will approve the adjustment. The Administrator will notify the owner or operator in writing of approval or disapproval of the request for an adjustment within 15 calendar days of receiving sufficient information to evaluate the request.
- (4) If the Administrator is unable to meet a specified deadline, he or she will notify the owner or operator of any significant delay and inform the owner or operator of the amended schedule.

[59 FR 12428, Mar. 16, 1994, as amended at 64 FR 7463, Feb. 12, 1998]

**APPENDIX RR**

**Facility-Wide Reporting Requirements**

**RR1. Reporting Schedule.** This table summarizes information for convenience purposes only. It does not supersede any of the terms or conditions of this permit.

| <b>Report</b>   | <b>Reporting Deadlines</b>  | <b>Related Conditions</b> |
|---|---|---------------------------|
| Plant Problems/Permit Deviations                              | Immediately upon occurrence (See RR2.d.)  | RR2, RR3                  |
| Malfunction Excess Emissions Report                           | Quarterly (if requested)  | RR3                       |
| Semi-Annual Monitoring Report                                 | Every 6 months  | RR4                       |
| Annual Operating Report                                       | April 1   | RR5                       |
| Annual Emissions Fee Form and Fee                             | March 1   | RR6                       |
| Annual Statement of Compliance                                | Within 60 days after the end of each calendar year (or more frequently if specified by Rule 62-213.440(2), F.A.C., or by any other applicable requirement); and<br>Within 60 days after submittal of a written agreement for transfer of responsibility, or<br>Within 60 days after permanent shutdown. | RR7                       |
| Notification of Administrative Permit Corrections             | As needed   | RR8                       |
| Notification of Startup after Shutdown for More than One Year | Minimum of 60 days prior to the intended startup date or, if emergency startup, as soon as possible after the startup date is ascertained   | RR9                       |
| Permit Renewal Application                                    | 225 days prior to the expiration date of permit   | TV17                      |
| Test Reports  | Maximum 45 days following compliance tests  | TR8                       |

{Permitting Note: See permit Section III, Emissions Units and Specific Conditions, for any additional emission unit-specific reporting requirements.}

**RR2. Reports of Problems.**

- a. **Plant Operation-Problems.** If the permittee is temporarily unable to comply with any of the conditions of the permit due to breakdown of equipment or destruction by hazard of fire, wind or by other cause, the permittee shall immediately notify the Department. Notification shall include pertinent information as to the cause of the problem, and what steps are being taken to correct the problem and to prevent its recurrence, and where applicable, the owner's intent toward reconstruction of destroyed facilities. Such notification does not release the permittee from any liability for failure to comply with Department rules.
  - b. If, for any reason, the permittee does not comply with or will be unable to comply with any condition or limitation specified in this permit, the permittee shall immediately provide the Department with the following information:
    - (1) A description of and cause of noncompliance; and
    - (2) The period of noncompliance, including dates and times; or, if not corrected, the anticipated time the noncompliance is expected to continue, and steps being taken to reduce, eliminate, and prevent recurrence of the noncompliance. The permittee shall be responsible for any and all damages which may result and may be subject to enforcement action by the Department for penalties or for revocation of this permit.
  - c. When requested by the Department, the permittee shall within a reasonable time furnish any information required by law which is needed to determine compliance with the permit. If the permittee becomes aware the relevant facts were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be corrected promptly.
  - d. "Immediately" shall mean the same day, if during a workday (i.e., 8:00 a.m. - 5:00 p.m.), or the first business day after the incident, excluding weekends and holidays; and, for purposes of Rule 62-4.160(15) and 40 CFR 70.6(a)(3)(iii)(B), "promptly" or "prompt" shall have the same meaning as "immediately".
- [Rule 62-4.130, Rule 62-4.160(8), Rule 62-4.160(15), and Rule 62-213.440(1)(b), F.A.C.; 40 CFR 70.6(a)(3)(iii)(B)]

## Facility-Wide Reporting Requirements

- RR3. Reports of Deviations from Permit Requirements.** The permittee shall report in accordance with the requirements of Rule 62-210.700(6), F.A.C. (below), and Rule 62-4.130, F.A.C. (condition RR2.), deviations from permit requirements, including those attributable to upset conditions as defined in the permit. Reports shall include the probable cause of such deviations, and any corrective actions or preventive measures taken.  
*Rule 62-210.700(6):* In case of excess emissions resulting from malfunctions, each owner or operator shall notify the Department or the appropriate Local Program in accordance with Rule 62-4.130, F.A.C. (See condition RR2.). A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department.  
[Rules 62-213.440(1)(b)3.b., and 62-210.700(6)F.A.C.]
- RR4. Semi-Annual Monitoring Reports.** The permittee shall submit reports of any required monitoring at least every six (6) months. All instances of deviations from permit requirements must be clearly identified in such reports. [Rule 62-213.440(1)(b)3.a., F.A.C.]
- RR5. Annual Operating Report.**
- The permittee shall submit to the Compliance Authority, each calendar year, on or before April 1, a completed DEP Form No 62-210.900(5), "Annual Operating Report for Air Pollutant Emitting Facility", for the preceding calendar year.
  - Emissions shall be computed in accordance with the provisions of Rule 62-210.370(2), F.A.C.  
[Rules 62-210.370(2) & (3), and 62-213.440(3)2., F.A.C.]
- RR6. Annual Emissions Fee Form and Fee.** Each Title V source permitted to operate in Florida must pay between January 15 and March 1 of each year, an annual emissions fee in an amount determined as set forth in Rule 62-213.205(1), F.A.C.
- If the Department has not received the fee by February 15 of the year following the calendar year for which the fee is calculated, the Department will send the primary responsible official of the Title V source a written warning of the consequences for failing to pay the fee by March 1. If the fee is not postmarked by March 1 of the year due, the Department shall impose, in addition to the fee, a penalty of 50 percent of the amount of the fee unpaid plus interest on such amount computed in accordance with Section 220.807, F.S. If the Department determines that a submitted fee was inaccurately calculated, the Department shall either refund to the permittee any amount overpaid or notify the permittee of any amount underpaid. The Department shall not impose a penalty or interest on any amount underpaid, provided that the permittee has timely remitted payment of at least 90 percent of the amount determined to be due and remits full payment within 60 days after receipt of notice of the amount underpaid. The Department shall waive the collection of underpayment and shall not refund overpayment of the fee, if the amount is less than 1 percent of the fee due, up to \$50.00. The Department shall make every effort to provide a timely assessment of the adequacy of the submitted fee. Failure to pay timely any required annual emissions fee, penalty, or interest constitutes grounds for permit revocation pursuant to Rule 62-4.100, F.A.C.
  - Any documentation of actual hours of operation, actual material or heat input, actual production amount, or actual emissions used to calculate the annual emissions fee shall be retained by the owner for a minimum of five (5) years and shall be made available to the Department upon request.
  - A completed DEP Form 62-213.900(1), "Major Air Pollution Source Annual Emissions Fee Form", must be submitted by a responsible official with the annual emissions fee.  
[Rules 62-213.205(1), (1)(g), (1)(i) & (1)(j), F.A.C.]
- RR7. Annual Statement of Compliance.**
- The permittee shall submit a Statement of Compliance with all terms and conditions of the permit that includes all the provisions of 40 CFR 70.6(c)(5)(iii), incorporated by reference at Rule 62-204.800, F.A.C., using DEP Form No. 62-213.900(7). Such statement shall be accompanied by a certification in accordance with Rule 62-213.420(4), F.A.C., for Title V requirements and with Rule 62-214.350, F.A.C., for Acid Rain requirements. Such statements shall be submitted (postmarked) to the Department and EPA:
    - Annually, within 60 days after the end of each calendar year during which the Title V permit was effective, or more frequently if specified by Rule 62-213.440(2), F.A.C., or by any other applicable requirement; and
    - Within 60 days after submittal of a written agreement for transfer of responsibility as required pursuant to 40 CFR 70.7(d)(1)(iv), adopted and incorporated by reference at Rule 62-204.800, F.A.C., or within 60 days after permanent shutdown of a facility permitted under Chapter 62-213, F.A.C.; provided that, in either such case, the reporting period shall be the portion of the calendar year the permit was effective up to the date of transfer of responsibility or permanent facility shutdown, as applicable.

APPENDIX RR

Facility-Wide Reporting Requirements

- b. In lieu of individually identifying all applicable requirements and specifying times of compliance with, non-compliance with, and deviation from each, the responsible official may use DEP Form No. 62-213.900(7) as such statement of compliance so long as the responsible official identifies all reportable deviations from and all instances of non-compliance with any applicable requirements and includes all information required by the federal regulation relating to each reportable deviation and instance of non-compliance.
- c. The responsible official may treat compliance with all other applicable requirements as a surrogate for compliance with Rule 62-296.320(2), Objectionable Odor Prohibited.

[Rules 62-213.440(3)(a)2. & 3. and (b), F.A.C.]

**RR8. Notification of Administrative Permit Corrections.**

- a. A facility owner shall notify the Department by letter of minor corrections to information contained in a permit. Such notifications shall include:
  - (1) Typographical errors noted in the permit;
  - (2) Name, address or phone number change from that in the permit;
  - (3) A change requiring more frequent monitoring or reporting by the permittee;
  - (4) A change in ownership or operational control of a facility, subject to the following provisions:
    - (a) The Department determines that no other change in the permit is necessary;
    - (b) The permittee and proposed new permittee have submitted an Application for Transfer of Air Permit, and the Department has approved the transfer pursuant to Rule 62-210.300(7), F.A.C.; and
    - (c) The new permittee has notified the Department of the effective date of sale or legal transfer.
  - (5) Changes listed at 40 CFR 72.83(a)(1), (2), (6), (9) and (10), adopted and incorporated by reference at Rule 62-204.800, F.A.C., and changes made pursuant to Rules 62-214.340(1) and (2), F.A.C., to Title V sources subject to emissions limitations or reductions pursuant to 42 USC ss. 7651-7651o;
  - (6) Changes listed at 40 CFR 72.83(a)(11) and (12), adopted and incorporated by reference at Rule 62-204.800, F.A.C., to Title V sources subject to emissions limitations or reductions pursuant to 42 USC ss. 7651-7651o, provided the notification is accompanied by a copy of any EPA determination concerning the similarity of the change to those listed at Rule 62-210.360(1)(e), F.A.C.; and
  - (7) Any other similar minor administrative change at the source.
- b. Upon receipt of any such notification, the Department shall within 60 days correct the permit and provide a corrected copy to the owner.
- c. After first notifying the owner, the Department shall correct any permit in which it discovers errors of the types listed at Rules 62-210.360(1)(a) and (b), F.A.C., and provide a corrected copy to the owner.
- d. For Title V source permits, other than general permits, a copy of the corrected permit shall be provided to EPA and any approved local air program in the county where the facility or any part of the facility is located.

[Rule 62-210.360, F.A.C.]

**RR9. Notification of Startup.** The owners or operator of any emissions unit or facility which has a valid air operation permit which has been shut down more than one year, shall notify the Department in writing of the intent to start up such emissions unit or facility, a minimum of 60 days prior to the intended startup date.

- a. The notification shall include information as to the startup date, anticipated emission rates or pollutants released, changes to processes or control devices which will result in changes to emission rates, and any other conditions which may differ from the valid outstanding operation permit.
- b. If, due to an emergency, a startup date is not known 60 days prior thereto, the owner shall notify the Department as soon as possible after the date of such startup is ascertained.

[Rule 62-210.300(5), F.A.C.]

**RR10. Report Submission.** The permittee shall submit all compliance related notifications and reports required of this permit to the Compliance Authority. {See front of permit for address and phone number.}

**RR11. EPA Report Submission.** Any reports, data, notifications, certifications, and requests required to be sent to the United States Environmental Protection Agency, Region 4, should be sent to: Air, Pesticides & Toxics Management Division, United States Environmental Protection Agency, Region 4, Sam Nunn Atlanta Federal Center, 61 Forsyth Street SW, Atlanta, GA 30303-8960. Phone: 404/562-9077.

**RR12. Acid Rain Report Submission.** Acid Rain Program Information shall be submitted, as necessary, to: Department of Environmental Protection, 2600 Blair Stone Road, Mail Station #5510, Tallahassee, Florida 32399-2400. Phone: 850/488-6140. Fax: 850/922-6979.

**RR13. Report Certification.** All reports shall be accompanied by a certification by a responsible official, pursuant to Rule 62-213.420(4), F.A.C. [Rule 62-213.440(1)(b)3.c, F.A.C.]

## Facility-Wide Reporting Requirements

**RR14. Certification by Responsible Official (RO).** In addition to the professional engineering certification required for applications by Rule 62-4.050(3), F.A.C., any application form, report, compliance statement, compliance plan and compliance schedule submitted pursuant to Chapter 62-213, F.A.C., shall contain a certification signed by a responsible official that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete. Any responsible official who fails to submit any required information or who has submitted incorrect information shall, upon becoming aware of such failure or incorrect submittal, promptly submit such supplementary information or correct information. [Rule 62-213.420(4), F.A.C.]

**RR15. Confidential Information.** Whenever an applicant submits information under a claim of confidentiality pursuant to Section 403.111, F.S., the applicant shall also submit a copy of all such information and claim directly to EPA. Any permittee may claim confidentiality of any data or other information by complying with this procedure. [Rules 62-213.420(2), and 62-213.440(1)(d)6., F.A.C.]

**RR16. Forms and Instructions.** The forms used by the Department in the Title V source operation program are adopted and incorporated by reference in Rule 62-213.900, F.A.C. The forms are listed by rule number, which is also the form number, and with the subject, title, and effective date. Copies of forms may be obtained by writing to the Department of Environmental Protection, Division of Air Resource Management, 2600 Blair Stone Road, Tallahassee, Florida 32399-2400, by contacting the appropriate permitting authority or by accessing the Department's web site at: <http://www.dep.state.fl.us/air/rules/forms.htm>.

- a. Major Air Pollution Source Annual Emissions Fee Form (Effective 01/03/2001).
- b. Statement of Compliance Form (Effective 06/02/2002).
- c. Responsible Official Notification Form (Effective 06/02/2002).

[Rule 62-213.900, F.A.C.: Forms (1), (7) and (8)]

## Facility-Wide Testing Requirements

Unless otherwise specified in the permit, the following testing requirements apply to each emissions unit for which testing is required. The terms "stack" and "duct" are used interchangeably in this appendix.

- TR1. Required Number of Test Runs.** For mass emission limitations, a compliance test shall consist of three complete and separate determinations of the total air pollutant emission rate through the test section of the stack or duct and three complete and separate determinations of any applicable process variables corresponding to the three distinct time periods during which the stack emission rate was measured; provided, however, that three complete and separate determinations shall not be required if the process variables are not subject to variation during a compliance test, or if three determinations are not necessary in order to calculate the unit's emission rate. The three required test runs shall be completed within one consecutive five-day period. In the event that a sample is lost or one of the three runs must be discontinued because of circumstances beyond the control of the owner or operator, and a valid third run cannot be obtained within the five-day period allowed for the test, the Secretary or his or her designee may accept the results of two complete runs as proof of compliance, provided that the arithmetic mean of the two complete runs is at least 20% below the allowable emission limiting standard. [Rule 62-297.310(1), F.A.C.]
- TR2. Operating Rate During Testing.** Testing of emissions shall be conducted with the emissions unit operating at permitted capacity. If it is impractical to test at permitted capacity, an emissions unit may be tested at less than the maximum permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test rate until a new test is conducted. Once the unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity. Permitted capacity is defined as 90 to 100 percent of the maximum operation rate allowed by the permit. [Rule 62-297.310(2), F.A.C.]
- TR3. Calculation of Emission Rate.** For each emissions performance test, the indicated emission rate or concentration shall be the arithmetic average of the emission rate or concentration determined by each of the three separate test runs unless otherwise specified in a particular test method or applicable rule. [Rule 62-297.310(3), F.A.C.]
- TR4. Applicable Test Procedures.**
- a. Required Sampling Time.
    - (1) Unless otherwise specified in the applicable rule, the required sampling time for each test run shall be no less than one hour and no greater than four hours, and the sampling time at each sampling point shall be of equal intervals of at least two minutes.
    - (2) Opacity Compliance Tests. When either EPA Method 9 or DEP Method 9 is specified as the applicable opacity test method, the required minimum period of observation for a compliance test shall be sixty (60) minutes for emissions units which emit or have the potential to emit 100 tons per year or more of particulate matter, and thirty (30) minutes for emissions units which have potential emissions less than 100 tons per year of particulate matter and are not subject to a multiple-valued opacity standard. The opacity test observation period shall include the period during which the highest opacity emissions can reasonably be expected to occur. Exceptions to these requirements are as follows:
      - (a) For batch, cyclical processes, or other operations which are normally completed within less than the minimum observation period and do not recur within that time, the period of observation shall be equal to the duration of the batch cycle or operation completion time.
      - (b) The observation period for special opacity tests that are conducted to provide data to establish a surrogate standard pursuant to Rule 62-297.310(5)(k), F.A.C., Waiver of Compliance Test Requirements, shall be established as necessary to properly establish the relationship between a proposed surrogate standard and an existing mass emission limiting standard.
      - (c) The minimum observation period for opacity tests conducted by employees or agents of the Department to verify the day-to-day continuing compliance of a unit or activity with an applicable opacity standard shall be twelve minutes.
  - b. Minimum Sample Volume. Unless otherwise specified in the applicable rule or test method, the minimum sample volume per run shall be 25 dry standard cubic feet.
  - c. Required Flow Rate Range. For EPA Method 5 particulate sampling, acid mist/sulfur dioxide, and fluoride sampling which uses Greenburg Smith type impingers, the sampling nozzle and sampling time shall be selected such that the average sampling rate will be between 0.5 and 1.0 actual cubic feet per minute, and the required minimum sampling volume will be obtained.
  - d. Calibration of Sampling Equipment. Calibration of the sampling train equipment shall be conducted in accordance with the schedule shown in Table 297.310-1, F.A.C.



## Facility-Wide Testing Requirements

| TABLE 297.310-1 CALIBRATION SCHEDULE |   |   |   |
|--------------------------------------|---|---|---|
| Item                                 | Minimum Calibration Frequency                                   | Reference Instrument  | Tolerance   |
| Liquid in glass thermometer          | Annually  | ASTM Hg in glass ref. thermometer or equivalent or thermometric points                    | +/- 2%  |
| Bimetallic thermometer               | Quarterly   | Calibration liquid in glass   | 5° F  |
| Thermocouple                         | Annually  | ASTM Hg in glass ref. thermometer, NBS calibrated reference and potentiometer             | 5° F  |
| Barometer                            | Monthly   | Hg barometer or NOAA station  | +/- 1% scale  |
| Pitot Tube                           | When required or when damaged                                   | By construction or measurements in wind tunnel D greater than 16" and standard pitot tube | See EPA Method 2, Fig. 2-2 and 2-3  |
| Probe Nozzles                        | Before each test or when nicked, dented, or corroded            | Micrometer  | +/- 0.001" mean of at least three readings; Max. deviation between readings, 0.004" |
| Dry Gas Meter and Orifice Meter      | 1. Full Scale: When received, when 5% change observed, annually | Spirometer or calibrated wet test or dry gas test meter                                   | 2%  |
|                                      | 2. One Point: Semiannually                                      |   |   |
|                                      | 3. Check after each test series                                 | Comparison check  | 5%  |

- e. *Allowed Modification to EPA Method 5.* When EPA Method 5 is required, the following modification is allowed: the heated filter may be separated from the impingers by a flexible tube.

[Rule 62-297.310(4), F.A.C.]

**TR5.** Determination of Process Variables.

- a. *Required Equipment.* The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.
- b. *Accuracy of Equipment.* Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value.

[Rule 62-297.310(5), F.A.C.]

**TR6.** Sampling Facilities. Permittees that are required to sample mass emissions from point sources shall install stack sampling ports and provide sampling facilities that meet the requirements of this condition. Sampling facilities include sampling ports, work platforms, access to work platforms, electrical power, and sampling equipment support. All stack sampling facilities must also comply with all applicable Occupational Safety and Health Administration (OSHA) Safety and Health Standards described in 29 CFR Part 1910, Subparts D and E.

- a. *Permanent Test Facilities.* The owner or operator of an emissions unit for which a compliance test, other than a visible emissions test, is required on at least an annual basis, shall install and maintain permanent stack sampling facilities.
- b. *Temporary Test Facilities.* The owner or operator of an emissions unit that is not required to conduct a

## Facility-Wide Testing Requirements

compliance test on at least an annual basis may use permanent or temporary stack sampling facilities. If the owner chooses to use temporary sampling facilities on an emissions unit, and the Department elects to test the unit, such temporary facilities shall be installed on the emissions unit within 5 days of a request by the Department and remain on the emissions unit until the test is completed.

c. *Sampling Ports.*

- (1) All sampling ports shall have a minimum inside diameter of 3 inches.
- (2) The ports shall be capable of being sealed when not in use.
- (3) The sampling ports shall be located in the stack at least 2 stack diameters or equivalent diameters downstream and at least 0.5 stack diameter or equivalent diameter upstream from any fan, bend, constriction or other flow disturbance.
- (4) For emissions units for which a complete application to construct has been filed prior to December 1, 1980, at least two sampling ports, 90 degrees apart, shall be installed at each sampling location on all circular stacks that have an outside diameter of 15 feet or less. For stacks with a larger diameter, four sampling ports, each 90 degrees apart, shall be installed. For emissions units for which a complete application to construct is filed on or after December 1, 1980, at least two sampling ports, 90 degrees apart, shall be installed at each sampling location on all circular stacks that have an outside diameter of 10 feet or less. For stacks with larger diameters, four sampling ports, each 90 degrees apart, shall be installed. On horizontal circular ducts, the ports shall be located so that the probe can enter the stack vertically, horizontally or at a 45 degree angle.
- (5) On rectangular ducts, the cross sectional area shall be divided into the number of equal areas in accordance with EPA Method 1. Sampling ports shall be provided which allow access to each sampling point. The ports shall be located so that the probe can be inserted perpendicular to the gas flow.

d. *Work Platforms.*

- (1) Minimum size of the working platform shall be 24 square feet in area. Platforms shall be at least 3 feet wide.
- (2) On circular stacks with 2 sampling ports, the platform shall extend at least 110 degrees around the stack.
- (3) On circular stacks with more than two sampling ports, the work platform shall extend 360 degrees around the stack.
- (4) All platforms shall be equipped with an adequate safety rail (ropes are not acceptable), toe board, and hinged floor-opening cover if ladder access is used to reach the platform. The safety rail directly in line with the sampling ports shall be removable so that no obstruction exists in an area 14 inches below each sample port and 6 inches on either side of the sampling port.

e. *Access to Work Platform.*

- (1) Ladders to the work platform exceeding 15 feet in length shall have safety cages or fall arresters with a minimum of 3 compatible safety belts available for use by sampling personnel.
- (2) Walkways over free-fall areas shall be equipped with safety rails and toe boards.

f. *Electrical Power.*

- (1) A minimum of two 120-volt AC, 20-amp outlets shall be provided at the sampling platform within 20 feet of each sampling port.
- (2) If extension cords are used to provide the electrical power, they shall be kept on the plant's property and be available immediately upon request by sampling personnel.

g. *Sampling Equipment Support.*

- (1) A three-quarter inch eyebolt and an angle bracket shall be attached directly above each port on vertical stacks and above each row of sampling ports on the sides of horizontal ducts.
  - (a) The bracket shall be a standard 3 inch x 3 inch x one-quarter inch equal-legs bracket which is 1 and one-half inches wide. A hole that is one-half inch in diameter shall be drilled through the exact center of the horizontal portion of the bracket. The horizontal portion of the bracket shall be located 14 inches above the centerline of the sampling port.
  - (b) A three-eighth inch bolt which protrudes 2 inches from the stack may be substituted for the required bracket. The bolt shall be located 15 and one-half inches above the centerline of the sampling port.
  - (c) The three-quarter inch eyebolt shall be capable of supporting a 500 pound working load. For stacks that are less than 12 feet in diameter, the eyebolt shall be located 48 inches above the horizontal portion of the angle bracket. For stacks that are greater than or equal to 12 feet in diameter, the eyebolt shall be located 60 inches above the horizontal portion of the angle bracket. If the eyebolt is more than 120 inches above the platform, a length of chain shall be attached to it to bring the free end of the chain to within safe reach from the platform.
- (2) A complete monorail or dual rail arrangement may be substituted for the eyebolt and bracket.
- (3) When the sample ports are located in the top of a horizontal duct, a frame shall be provided above the port to allow the sample probe to be secured during the test.

## Facility-Wide Testing Requirements

[Rule 62-297.310(6), F.A.C.]

- TR7. Frequency of Compliance Tests.** The following provisions apply only to those emissions units that are subject to an emissions limiting standard for which compliance testing is required.
- a. *General Compliance Testing.*
- (1) The owner or operator of a new or modified emissions unit that is subject to an emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining an operation permit for such emissions unit.
  - (2) For excess emission limitations for particulate matter specified in Rule 62-210.700, F.A.C., a compliance test shall be conducted annually while the emissions unit is operating under soot blowing conditions in each federal fiscal year during which soot blowing is part of normal emissions unit operation, except that such test shall not be required in any federal fiscal year in which a fossil fuel steam generator does not burn liquid and/or solid fuel for more than 400 hours other than during startup.
  - (3) The owner or operator of an emissions unit that is subject to any emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining a renewed operation permit. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy the requirements of this provision. In renewing an air operation permit pursuant to sub-subparagraph 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of emission compliance test results for any emissions unit that, during the year prior to renewal:
    - (a) Did not operate; or
    - (b) In the case of a fuel burning emissions unit, burned liquid and/or solid fuel for a total of no more than 400 hours.
  - (4) During each federal fiscal year (October 1 – September 30), unless otherwise specified by rule, order, or permit, the owner or operator of each emissions unit shall have a formal compliance test conducted for:
    - (a) Visible emissions, if there is an applicable standard;
    - (b) Each of the following pollutants, if there is an applicable standard, and if the emissions unit emits or has the potential to emit: 5 tons per year or more of lead or lead compounds measured as elemental lead; 30 tons per year or more of acrylonitrile; or 100 tons per year or more of any other regulated air pollutant; and
    - (c) Each NESHAP pollutant, if there is an applicable emission standard.
  - (5) An annual compliance test for particulate matter emissions shall not be required for any fuel burning emissions unit that, in a federal fiscal year, does not burn liquid and/or solid fuel, other than during startup, for a total of more than 400 hours.
  - (6) For fossil fuel steam generators on a semi-annual particulate matter emission compliance testing schedule, a compliance test shall not be required for any six-month period in which liquid and/or solid fuel is not burned for more than 200 hours other than during startup.
  - (7) For emissions units electing to conduct particulate matter emission compliance testing quarterly pursuant to paragraph 62-296.405(2)(a), F.A.C., a compliance test shall not be required for any quarter in which liquid and/or solid fuel is not burned for more than 100 hours other than during startup.
  - (8) Any combustion turbine that does not operate for more than 400 hours per year shall conduct a visible emissions compliance test once per each five-year period, coinciding with the term of its air operation permit.
  - (9) The owner or operator shall notify the Department, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator.
  - (10) An annual compliance test conducted for visible emissions shall not be required for units exempted from air permitting pursuant to subsection 62-210.300(3), F.A.C.; units determined to be insignificant pursuant to subparagraph 62-213.300(2)(a)1., A.C., or paragraph 62-213.430(6)(b), F.A.C.; or units permitted under the General Permit provisions in paragraph 62-210.300(4)(a) or Rule 62-213.300, F.A.C., unless the general permit specifically requires such testing.
- b. *Special Compliance Tests.* When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained Department rule or in a permit issued pursuant to those rules is being violated, it shall require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department.
- c. *Waiver of Compliance Test Requirements.* If the owner or operator of an emissions unit that is subject to a compliance test requirement demonstrates to the Department, pursuant to the procedure established in Rule 62-

## Facility-Wide Testing Requirements

297.620, F.A.C., that the compliance the emissions unit with an applicable weight emission limiting standard can be adequately determined by means other than the designated test procedure, such as specifying a surrogate standard of no visible emissions for particulate matter sources equipped with a bag house or specifying a fuel analysis for sulfur dioxide emissions, the Department shall waive the compliance test requirements for such emissions units and order that the alternate means of determining compliance be used, provided, however, the provisions of paragraph 62-297.310(7)(b), F.A.C., shall apply.

[Rule 62-297.310(7), F.A.C.]

**TR8. Test Reports.**

- a. The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Department on the results of each such test.
- b. The required test report shall be filed with the Department as soon as practical but no later than 45 days after the last sampling run of each test is completed.
- c. The test report shall provide sufficient detail on the emissions unit tested and the test procedures used to allow the Department to determine if the test was properly conducted and the test results properly computed. As a minimum, the test report, other than for an EPA or DEP Method 9 test, shall provide the following information.
  - (1) The type, location, and designation of the emissions unit tested.
  - (2) The facility at which the emissions unit is located.
  - (3) The owner or operator of the emissions unit.
  - (4) The normal type and amount of fuels used and materials processed, and the types and amounts of fuels used and material processed during each test run.
  - (5) The means, raw data and computations used to determine the amount of fuels used and materials processed, if necessary to determine compliance with an applicable emission limiting standard.
  - (6) The type of air pollution control devices installed on the emissions unit, their general condition, their normal operating parameters (pressure drops, total operating current and GPM scrubber water), and their operating parameters during each test run.
  - (7) A sketch of the duct within 8 stack diameters upstream and 2 stack diameters downstream of the sampling ports, including the distance to any upstream and downstream bends or other flow disturbances.
  - (8) The date, starting time and duration of each sampling run.
  - (9) The test procedures used, including any alternative procedures authorized pursuant to Rule 62-297.620, F.A.C. Where optional procedures are authorized in this chapter, indicate which option was used.
  - (10) The number of points sampled and configuration and location of the sampling plane.
  - (11) For each sampling point for each run, the dry gas meter reading, velocity head, pressure drop across the stack, temperatures, average meter temperatures and sample time per point.
  - (12) The type, manufacturer and configuration of the sampling equipment used.
  - (13) Data related to the required calibration of the test equipment.
  - (14) Data on the identification, processing and weights of all filters used.
  - (15) Data on the types and amounts of any chemical solutions used.
  - (16) Data on the amount of pollutant collected from each sampling probe, the filters, and the impingers, are reported separately for the compliance test.
  - (17) The names of individuals who furnished the process variable data, conducted the test, analyzed the samples and prepared the report.
  - (18) All measured and calculated data required to be determined by each applicable test procedure for each run.
  - (19) The detailed calculations for one run that relate the collected data to the calculated emission rate.
  - (20) The applicable emission standard and the resulting maximum allowable emission rate for the emissions unit plus the test result in the same form and unit of measure.
  - (21) A certification that, to the knowledge of the owner or his authorized agent, all data submitted are true and correct. When a compliance test is conducted for the Department or its agent, the person who conducts the test shall provide the certification with respect to the test procedures used. The owner or his authorized agent shall certify that all data required and provided to the person conducting the test are true and correct to his knowledge.

[Rule 62-297.310(8), F.A.C.]

**Operation**

- TV1. General Prohibition.** A permitted installation may only be operated, maintained, constructed, expanded or modified in a manner that is consistent with the terms of the permit. [Rule 62-4.030, Florida Administrative Code (F.A.C.)]
- TV2. Validity.** This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviation from the approved drawings, exhibits, specifications, or conditions of this permit may constitute grounds for revocation and enforcement action by the Department. [Rule 62-4.160(2), F.A.C.]
- TV3. Proper Operation and Maintenance.** The permittee shall properly operate and maintain the facility and systems of treatment and control (and related appurtenances) that are installed and used by the permittee to achieve compliance with the conditions of this permit, as required by Department rules. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to achieve compliance with the conditions of the permit and when required by Department rules. [Rule 62-4.160(6), F.A.C.]
- TV4. Not Federally Enforceable. Health, Safety and Welfare.** To ensure protection of public health, safety, and welfare, any construction, modification, or operation of an installation which may be a source of pollution, shall be in accordance with sound professional engineering practices pursuant to Chapter 471, F.S. [Rule 62-4.050(3), F.A.C.]
- TV5. Continued Operation.** An applicant making timely and complete application for permit, or for permit renewal, shall continue to operate the source under the authority and provisions of any existing valid permit or Florida Electrical Power Plant Siting Certification, and in accordance with applicable requirements of the Acid Rain Program, applicable requirements of the CAIR Program, and applicable requirements of the Hg Budget Trading Program, until the conclusion of proceedings associated with its permit application or until the new permit becomes effective, whichever is later, provided the applicant complies with all the provisions of subparagraphs 62-213.420(1)(b)3., F.A.C. [Rules 62-213.420(1)(b)2., F.A.C.]
- TV6. Changes without Permit Revision.** Title V sources having a valid permit issued pursuant to Chapter 62-213, F.A.C., may make the following changes without permit revision, provided that sources shall maintain source logs or records to verify periods of operation:
- a. Permitted sources may change among those alternative methods of operation;
  - b. A permitted source may implement operating changes, as defined in Rule 62-210.200, F.A.C., after the source submits any forms required by any applicable requirement and provides the Department and EPA with at least 7 days written notice prior to implementation. The source and the Department shall attach each notice to the relevant permit;
    - (1) The written notice shall include the date on which the change will occur, and a description of the change within the permitted source, the pollutants emitted and any change in emissions, and any term or condition becoming applicable or no longer applicable as a result of the change;
    - (2) The permit shield described in Rule 62-213.460, F.A.C., shall not apply to such changes;
  - c. Permitted sources may implement changes involving modes of operation only in accordance with Rule 62-213.415, F.A.C.  
[Rule 62-213.410, F.A.C.]
- TV7. Circumvention.** No person shall circumvent any air pollution control device, or allow the emission of air pollutants without the applicable air pollution control device operating properly. [Rule 62-210.650, F.A.C.]

**Compliance**

- TV8. Compliance with Chapter 403, F.S., and Department Rules.** Except as provided at Rule 62-213.460, Permit Shield, F.A.C., the issuance of a permit does not relieve any person from complying with the requirements of Chapter 403, F.S., or Department rules. [Rule 62-4.070(7), F.A.C.]
- TV9. Compliance with Federal, State and Local Rules.** Except as provided at Rule 62-213.460, F.A.C., issuance of a permit does not relieve the owner or operator of a facility or an emissions unit from complying with any applicable requirements, any emission limiting standards or other requirements of the air pollution rules of the Department or any other such requirements under federal, state, or local law. [Rule 62-210.300, F.A.C.]

## Title V General Conditions

- TV10. Binding and Enforceable.** The terms, conditions, requirements, limitations and restrictions set forth in this permit, are "permit conditions" and are binding and enforceable pursuant to Sections 403.141, 403.727, or 403.859 through 403.861, F.S. The permittee is placed on notice that the Department will review this permit periodically and may initiate enforcement action for any violation of these conditions. [Rule 62-4.160(1), F.A.C.]
- TV11. Timely Information.** When requested by the Department, the permittee shall within a reasonable time furnish any information required by law which is needed to determine compliance with the permit. If the permittee becomes aware the relevant facts were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be corrected promptly. [Rule 62-4.160(15), F.A.C.]
- TV12. Halting or Reduction of Source Activity.** It shall not be a defense for a permittee in an enforcement action that maintaining compliance with any permit condition would necessitate halting of or reduction of the source activity. [Rule 62-213.440(1)(d)3., F.A.C.]
- TV13. Final Permit Action.** Any Title V source shall comply with all the terms and conditions of the existing permit until the Department has taken final action on any permit renewal or any requested permit revision, except as provided at Rule 62-213.412(2), F.A.C. [Rule 62-213.440(1)(d)4., F.A.C.]
- TV14. Sudden and Unforeseeable Events Beyond the Control of the Source.** A situation arising from sudden and unforeseeable events beyond the control of the source which causes an exceedance of a technology-based emissions limitation because of unavoidable increases in emissions attributable to the situation and which requires immediate corrective action to restore normal operation, shall be an affirmative defense to an enforcement action in accordance with the provisions and requirements of 40 CFR 70.6(g)(2) and (3), hereby adopted and incorporated by reference. [Rule 62-213.440(1)(d)5., F.A.C.]
- TV15. Permit Shield.** Except as provided in Chapter 62-213, F.A.C., compliance with the terms and conditions of a permit issued pursuant to Chapter 62-213, F.A.C., shall, as of the effective date of the permit, be deemed compliance with any applicable requirements in effect, provided that the source included such applicable requirements in the permit application. Nothing in this condition or in any permit shall alter or affect the ability of EPA or the Department to deal with an emergency, the liability of an owner or operator of a source for any violation of applicable requirements prior to or at the time of permit issuance, or the requirements of the Federal Acid Rain Program, the CAIR Program. [Rule 62-213.460, F.A.C.]
- TV16. Compliance with Federal Rules.** A facility or emissions unit subject to any standard or requirement of 40 CFR, Part 60, 61, 63 or 65, adopted and incorporated by reference at Rule 62-204.800, F.A.C., shall comply with such standard or requirement. Nothing in this chapter shall relieve a facility or emissions unit from complying with such standard or requirement, provided, however, that where a facility or emissions unit is subject to a standard established in Rule 62-296, F.A.C., such standard shall also apply. [Rule 62-296.100(3), F.A.C.]

**Permit Procedures**

- TV17. Permit Revision Procedures.** The permittee shall revise its permit as required by Rules 62-213.400, 62-213.412, 62-213.420, 62-213.430 & 62-4.080, F.A.C.; and, in addition, the Department shall revise permits as provided in Rule 62-4.080, F.A.C. & 40 CFR 70.7(f).
- TV18. Permit Renewal.** The permittee shall renew its permit as required by Rules 62-4.090, 62.213.420(1) and 62-213.430(3), F.A.C. Permits being renewed are subject to the same requirements that apply to permit issuance at the time of application for renewal. Permit renewal applications shall contain that information identified in Rules 62-210.900(1) [Application for Air Permit - Long Form], 62-213.420(3) [Required Information], 62-213.420(6) [CAIR Part Form], F.A.C. Unless a Title V source submits a timely and complete application for permit renewal in accordance with the requirements this rule, the existing permit shall expire and the source's right to operate shall terminate. For purposes of a permit renewal, a timely application is one that is submitted 225 days before the expiration of a permit that expires on or after June 1, 2009. No Title V permit will be issued for a new term except through the renewal process. [Rules 62-213.420 & 62-213.430, F.A.C.]
- TV19. Insignificant Emissions Units or Pollutant-Emitting Activities.** The permittee shall identify and evaluate insignificant emissions units and activities as set forth in Rule 62-213.430(6), F.A.C.
- TV20. Savings Clause.** If any portion of the final permit is invalidated, the remainder of the permit shall remain in effect. [Rule 62-213.440(1)(d)1., F.A.C.]

**APPENDIX TV**  
**Title V General Conditions**

---

**TV21. Suspension and Revocation.**

- a. Permits shall be effective until suspended, revoked, surrendered, or expired and shall be subject to the provisions of Chapter 403, F.S., and rules of the Department.
- b. Failure to comply with pollution control laws and rules shall be grounds for suspension or revocation.
- c. A permit issued pursuant to Chapter 62-4, F.A.C., shall not become a vested property right in the permittee. The Department may revoke any permit issued by it if it finds that the permit holder or his agent:
  - (1) Submitted false or inaccurate information in his application or operational reports.
  - (2) Has violated law, Department orders, rules or permit conditions.
  - (3) Has failed to submit operational reports or other information required by Department rules.
  - (4) Has refused lawful inspection under Section 403.091, F.S.
- d. No revocation shall become effective except after notice is served by personal services, certified mail, or newspaper notice pursuant to Section 120.60(7), F.S., upon the person or persons named therein and a hearing held if requested within the time specified in the notice. The notice shall specify the provision of the law, or rule alleged to be violated, or the permit condition or Department order alleged to be violated, and the facts alleged to constitute a violation thereof.

[Rule 62-4.100, F.A.C.]

**TV22. Not federally enforceable. Financial Responsibility.** The Department may require an applicant to submit proof of financial responsibility and may require the applicant to post an appropriate bond to guarantee compliance with the law and Department rules. [Rule 62-4.110, F.A.C.]

**TV23. Emissions Unit Reclassification.**

- a. Any emissions unit whose operation permit has been revoked as provided for in Chapter 62-4, F.A.C., shall be deemed permanently shut down for purposes of Rule 62-212.500, F.A.C. Any emissions unit whose permit to operate has expired without timely renewal or transfer may be deemed permanently shut down, provided, however, that no such emissions unit shall be deemed permanently shut down if, within 20 days after receipt of written notice from the Department, the emissions unit owner or operator demonstrates that the permit expiration resulted from inadvertent failure to comply with the requirements of Rule 62-4.090, F.A.C., and that the owner or operator intends to continue the emissions unit in operation, and either submits an application for an air operation permit or complies with permit transfer requirements, if applicable.
- b. If the owner or operator of an emissions unit which is so permanently shut down, applies to the Department for a permit to reactivate or operate such emissions unit, the emissions unit will be reviewed and permitted as a new emissions unit.

[Rule 62-210.300(6), F.A.C.]

**TV24. Transfer of Permits.** Per Rule 62-4.160(11), F.A.C., this permit is transferable only upon Department approval in accordance with Rule 62-4.120, F.A.C., as applicable. The permittee shall be liable for any non-compliance of the permitted activity until the transfer is approved by the Department. The permittee transferring the permit shall remain liable for corrective actions that may be required as a result of any violations occurring prior to the sale or legal transfer of the facility. The permittee shall also comply with the requirements of Rule 62-210.300(7), F.A.C., and use DEP Form No. 62-210.900(7). [Rules 62-4.160(11), 62-4.120, and 62-210.300(7), F.A.C.]

**Rights, Title, Liability, and Agreements**

**TV25. Rights.** As provided in Subsections 403.987(6) and 403.722(5), F.S., the issuance of this permit does not convey any vested rights or any exclusive privileges. Neither does it authorize any injury to public or private property or any invasion of personal rights, nor any infringement of federal, state, or local laws or regulations. This permit is not a waiver of or approval of any other Department permit that may be required for other aspects of the total project which are not addressed in this permit. [Rule 62-4.160(3), F.A.C.]

**TV26. Title.** This permit conveys no title to land or water, does not constitute State recognition or acknowledgment of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the State. Only the Trustees of the Internal Improvement Trust Fund may express State opinion as to title. [Rule 62-4.160(4), (F.A.C.)]

**TV27. Liability.** This permit does not relieve the permittee from liability for harm or injury to human health or welfare, animal, or plant life, or property caused by the construction or operation of this permitted source, or from penalties

## Title V General Conditions

therefore; nor does it allow the permittee to cause pollution in contravention of F.S. and Department rules, unless specifically authorized by an order from the Department. [Rule 62-4.160(5), F.A.C.]

**TV28. Agreements.**

- a. The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, upon presentation of credentials or other documents as may be required by law and at reasonable times, access to the premises where the permitted activity is located or conducted to:
  - (1) Have access to and copy any records that must be kept under conditions of the permit;
  - (2) Inspect the facility, equipment, practices, or operations regulated or required under this permit; and,
  - (3) Sample or monitor any substances or parameters at any location reasonably necessary to assure compliance with this permit or Department rules. Reasonable time may depend on the nature of the concern being investigated.
- b. In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the Florida Statutes or Department rules, except where such use is prescribed by Sections 403.111 and 403.73, F.S. Such evidence shall only be used to the extent it is consistent with the Florida Rules of Civil Procedure and appropriate evidentiary rules.
- c. The permittee agrees to comply with changes in Department rules and Florida Statutes after a reasonable time for compliance; provided, however, the permittee does not waive any other rights granted by Florida Statutes or Department rules.

[Rules 62-4.160(7), (9) and (10), F.A.C.]

**Recordkeeping and Emissions Computation**

**TV29. Permit.** The permittee shall keep this permit or a copy thereof at the work site of the permitted activity. [Rule 62-4.160(12), F.A.C.]

**TV30. Recordkeeping.**

- a. Upon request, the permittee shall furnish all records and plans required under Department rules. During enforcement actions, the retention period for all records will be extended automatically unless otherwise stipulated by the Department.
- b. The permittee shall hold at the facility or other location designated by this permit records of all monitoring information (including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation) required by the permit, copies of all reports required by this permit, and records of all data used to complete the application for this permit. These materials shall be retained at least five (5) years from the date of the sample, measurement, report, or application unless otherwise specified by Department rule.
- c. Records of monitoring information shall include:
  - (1) The date, exact place, and time of sampling or measurements, and the operating conditions at the time of sampling or measurement;
  - (2) The person responsible for performing the sampling or measurements;
  - (3) The dates analyses were performed;
  - (4) The person and company that performed the analyses;
  - (5) The analytical techniques or methods used;
  - (6) The results of such analyses.

[Rules 62-4.160(14) and 62-213.440(1)(b)2., F.A.C.]

**TV31. Emissions Computation.** Pursuant to Rule 62-210.370, F.A.C., the following required methodologies are to be used by the owner or operator of a facility for computing actual emissions, baseline actual emissions, and net emissions increase, as defined at Rule 62-210.200, F.A.C., and for computing emissions for purposes of the reporting requirements of subsection 62-210.370(3) and paragraph 62-212.300(1)(e), F.A.C., or of any permit condition that requires emissions be computed in accordance with Rule 62-210.370, F.A.C. Rule 62-210.370, F.A.C., is not intended to establish methodologies for determining compliance with the emission limitations of any air permit.

For any of the purposes specified above, the owner or operator of a facility shall compute emissions in accordance with the requirements set forth in this subsection.



## Title V General Conditions

- a. *Basic Approach.* The owner or operator shall employ, on a pollutant-specific basis, the most accurate of the approaches set forth below to compute the emissions of a pollutant from an emissions unit; provided, however, that nothing in this rule shall be construed to require installation and operation of any continuous emissions monitoring system (CEMS), continuous parameter monitoring system (CPMS), or predictive emissions monitoring system (PEMS) not otherwise required by rule or permit, nor shall anything in this rule be construed to require performance of any stack testing not otherwise required by rule or permit.
- (1) If the emissions unit is equipped with a CEMS meeting the requirements of paragraph 62-210.370(2)(b), F.A.C., the owner or operator shall use such CEMS to compute the emissions of the pollutant, unless the owner or operator demonstrates to the department that an alternative approach is more accurate because the CEMS represents still-emerging technology.
  - (2) If a CEMS is not available or does not meet the requirements of paragraph 62-210.370(2)(b), F.A.C., but emissions of the pollutant can be computed pursuant to the mass balance methodology of paragraph 62-210.370(2)(c), F.A.C., the owner or operator shall use such methodology, unless the owner or operator demonstrates to the department that an alternative approach is more accurate.
  - (3) If a CEMS is not available or does not meet the requirements of paragraph 62-210.370(2)(b), F.A.C., and emissions cannot be computed pursuant to the mass balance methodology, the owner or operator shall use an emission factor meeting the requirements of paragraph 62-210.370(2)(d), F.A.C., unless the owner or operator demonstrates to the department that an alternative approach is more accurate.
- b. *Continuous Emissions Monitoring System (CEMS).*
- (1) An owner or operator may use a CEMS to compute emissions of a pollutant for purposes of this rule provided:
    - (a) The CEMS complies with the applicable certification and quality assurance requirements of 40 CFR Part 60, Appendices B and F, or, for an acid rain unit, the certification and quality assurance requirements of 40 CFR Part 75, all adopted by reference at Rule 62-204.800, F.A.C.; or,
    - (b) The owner or operator demonstrates that the CEMS otherwise represents the most accurate means of computing emissions for purposes of this rule.
  - (2) Stack gas volumetric flow rates used with the CEMS to compute emissions shall be obtained by the most accurate of the following methods as demonstrated by the owner or operator:
    - (a) A calibrated flow meter that records data on a continuous basis, if available; or
    - (b) The average flow rate of all valid stack tests conducted during a five-year period encompassing the period over which the emissions are being computed, provided all stack tests used shall represent the same operational and physical configuration of the unit.
  - (3) The owner or operator may use CEMS data in combination with an appropriate f-factor, heat input data, and any other necessary parameters to compute emissions if such method is demonstrated by the owner or operator to be more accurate than using a stack gas volumetric flow rate as set forth at subparagraph 62-210.370(2)(b)2., F.A.C., above.
- c. *Mass Balance Calculations.*
- (1) An owner or operator may use mass balance calculations to compute emissions of a pollutant for purposes of this rule provided the owner or operator:
    - (a) Demonstrates a means of validating the content of the pollutant that is contained in or created by all materials or fuels used in or at the emissions unit; and,
    - (b) Assumes that the emissions unit emits all of the pollutant that is contained in or created by any material or fuel used in or at the emissions unit if it cannot otherwise be accounted for in the process or in the capture and destruction of the pollutant by the unit's air pollution control equipment.
  - (2) Where the vendor of a raw material or fuel which is used in or at the emissions unit publishes a range of pollutant content from such material or fuel, the owner or operator shall use the highest value of the range to compute the emissions, unless the owner or operator demonstrates using site-specific data that another content within the range is more accurate.
  - (3) In the case of an emissions unit using coatings or solvents, the owner or operator shall document, through purchase receipts, records and sales receipts, the beginning and ending VOC inventories, the amount of VOC purchased during the computational period, and the amount of VOC disposed of in the liquid phase during such period.
- d. *Emission Factors.*
- (1) An owner or operator may use an emission factor to compute emissions of a pollutant for purposes of this rule provided the emission factor is based on site-specific data such as stack test data, where available, unless the owner or operator demonstrates to the department that an alternative emission factor is more accurate. An owner or operator using site-specific data to derive an emission factor, or set of factors, shall meet the following requirements.

## Title V General Conditions

- (a) If stack test data are used, the emission factor shall be based on the average emissions per unit of input, output, or gas volume, whichever is appropriate, of all valid stack tests conducted during at least a five-year period encompassing the period over which the emissions are being computed, provided all stack tests used shall represent the same operational and physical configuration of the unit.
  - (b) Multiple emission factors shall be used as necessary to account for variations in emission rate associated with variations in the emissions unit's operating rate or operating conditions during the period over which emissions are computed.
  - (c) The owner or operator shall compute emissions by multiplying the appropriate emission factor by the appropriate input, output or gas volume value for the period over which the emissions are computed. The owner or operator shall not compute emissions by converting an emission factor to pounds per hour and then multiplying by hours of operation, unless the owner or operator demonstrates that such computation is the most accurate method available.
- (2) If site-specific data are not available to derive an emission factor, the owner or operator may use a published emission factor directly applicable to the process for which emissions are computed. If no directly-applicable emission factor is available, the owner or operator may use a factor based on a similar, but different, process.
- e. *Accounting for Emissions During Periods of Missing Data from CEMS, PEMS, or CPMS.* In computing the emissions of a pollutant, the owner or operator shall account for the emissions during periods of missing data from CEMS, PEMS, or CPMS using other site-specific data to generate a reasonable estimate of such emissions.
  - f. *Accounting for Emissions During Periods of Startup and Shutdown.* In computing the emissions of a pollutant, the owner or operator shall account for the emissions during periods of startup and shutdown of the emissions unit.
  - g. *Fugitive Emissions.* In computing the emissions of a pollutant from a facility or emissions unit, the owner or operator shall account for the fugitive emissions of the pollutant, to the extent quantifiable, associated with such facility or emissions unit.
  - h. *Recordkeeping.* The owner or operator shall retain a copy of all records used to compute emissions pursuant to this rule for a period of five years from the date on which such emissions information is submitted to the department for any regulatory purpose.
- [Rule 62-210.370(1) & (2), F.A.C.]

**Responsible Official**

**TV32. Designation and Update.** The permittee shall designate and update a responsible official as required by Rule 62-213.202, F.A.C.

**Prohibitions and Restrictions**

**TV33. Asbestos.** This permit does not authorize any demolition or renovation of the facility or its parts or components which involves asbestos removal. This permit does not constitute a waiver of any of the requirements of Chapter 62-257, F.A.C., and 40 CFR 61, Subpart M, National Emission Standard for Asbestos, adopted and incorporated by reference in Rule 62-204.800, F.A.C. Compliance with Chapter 62-257, F.A.C., and 40 CFR 61, Subpart M, Section 61.145, is required for any asbestos demolition or renovation at the source. [40 CFR 61; Rule 62-204.800, F.A.C.; and, Chapter 62-257, F.A.C.]

**TV34. Refrigerant Requirements.** Any facility having refrigeration equipment, including air conditioning equipment, which uses a Class I or II substance (listed at 40 CFR 82, Subpart A, Appendices A and B), and any facility which maintains, services, or repairs motor vehicles using a Class I or Class II substance as refrigerant must comply with all requirements of 40 CFR 82, Subparts B and F, and with Chapter 62-281, F.A.C.

**TV35. Open Burning Prohibited.** Unless otherwise authorized by Rule 62-296.320(3) or Chapter 62-256, F.A.C., open burning is prohibited.

**APPENDIX U**  
**Unregulated Activities**

---

Unregulated Emissions Units and Activities. An emissions unit which emits no “emissions-limited pollutant” and which is subject to no unit-specific work practice standard, though it may be subject to regulations applied on a facility-wide basis (e.g., unconfined emissions, odor, general opacity) or to regulations that require only that it be able to prove exemption from unit-specific emissions or work practice standards.

The following emissions units and activities are neither “regulated emissions units” nor “insignificant emissions units”.

1. Surface coating operations less than 6.0 gallons per day;
2. Surface coating operations utilizing only coatings containing 5.0 percent or less VOC, by volume;
3. Fire and safety equipment;
4. Non-halogenated solvent storage and cleaning operations;
5. Architectural and equipment maintenance painting; and
6. Degreasing units using heavier-than-air vapors exclusively, except any such unit using or emitting any substance classified as a hazardous air pollutant

## NESHAP Subpart ZZZZ for Stationary Reciprocating Internal Combustion Engines

In accordance with Rule 62-204.800, F.A.C., the following federal regulations in Part 63 of Title 40 of the Code of Federal Regulations were adopted by reference. The original federal rule numbering has been retained.

{Permitting Note: The engines covered by this permit in EU-039 are regulated as shown in the following table. Only the Section §63.6590 of Subpart ZZZZ is included because of the limited applicability and requirements.}

| Engine   | Rule Applicability   |
|--|--|
| One 227 bHP Standby Diesel Generator<br>1979 Model Year                | Subject to NESHAP Subparts A and ZZZZ. Defined in Subpart ZZZZ as an "existing unit" that does not have to meet the requirements of Subpart ZZZZ and of Subpart A (General Provisions). No initial notification is necessary.                            |
| One 188 BHP Diesel Emergency Fire Pump Engine<br>2006 Model Year       | Subject to NSPS Subparts A and IIII. Defined as "new units".   |
| One 755 bHP Diesel Emergency Backup Generator<br>2007 Model Year       | NESHAP Subpart A and ZZZZ. Defined as "new units" that must meet the requirements of NESHAP Subpart ZZZZ by meeting the requirements NSPS Subpart IIII for compression ignition engines. No further requirements apply for such engines under this part. |
| One 1495 bHP Diesel Emergency Black-Start Generator<br>2007 Model Year |  |

### § 63.6590 What parts of my plant does this subpart cover?

This subpart applies to each affected source.

(a) *Affected source.* An affected source is any existing, new, or reconstructed stationary RICE located at a major or area source of HAP emissions, excluding stationary RICE being tested at a stationary RICE test cell/stand.

(1) *Existing stationary RICE.*

- (i) For stationary RICE with a site rating of more than 500 brake horsepower (HP) located at a major source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before December 19, 2002.
- (ii) For stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before June 12, 2006.
- (iii) For stationary RICE located at an area source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before June 12, 2006.
- (iv) A change in ownership of an existing stationary RICE does not make that stationary RICE a new or reconstructed stationary RICE.

(2) *New stationary RICE.*

- (i) A stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions is new if you commenced construction of the stationary RICE on or after December 19, 2002.
- (ii) A stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions is new if you commenced construction of the stationary RICE on or after June 12, 2006.
- (iii) A stationary RICE located at an area source of HAP emissions is new if you commenced construction of the stationary RICE on or after June 12, 2006.

(3) *Reconstructed stationary RICE.*

- (i) A stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions is reconstructed if you meet the definition of reconstruction in §63.2 and reconstruction is commenced on or after December 19, 2002.
- (ii) A stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions is reconstructed if you meet the definition of reconstruction in §63.2 and reconstruction is commenced on or after June 12, 2006.

## NESHAP Subpart ZZZZ for Stationary Reciprocating Internal Combustion Engines

(iii) A stationary RICE located at an area source of HAP emissions is reconstructed if you meet the definition of reconstruction in §63.2 and reconstruction is commenced on or after June 12, 2006.

(b) *Stationary RICE subject to limited requirements.*

- (1) An affected source which meets either of the criteria in paragraph (b)(1)(i) through (ii) of this section does not have to meet the requirements of this subpart and of subpart A of this part except for the initial notification requirements of §63.6645(h).
  - (i) The stationary RICE is a new or reconstructed emergency stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions; or
  - (ii) The stationary RICE is a new or reconstructed limited use stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions.
- (2) A new or reconstructed stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis must meet the initial notification requirements of §63.6645(h) and the requirements of §§63.6625(c), 63.6650(g), and 63.6655(c). These stationary RICE do not have to meet the emission limitations and operating limitations of this subpart.
- (3) A stationary RICE which is an existing spark ignition 4 stroke rich burn (4SRB) stationary RICE located at an area source, an existing spark ignition 4SRB stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source, an existing spark ignition 2 stroke lean burn (2SLB) stationary RICE, an existing spark ignition 4 stroke lean burn (4SLB) stationary RICE, an existing compression ignition (CI) stationary RICE, an existing emergency stationary RICE, an existing limited use stationary RICE, or an existing stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, ***does not have to meet the requirements of this subpart and of subpart A of this part. No initial notification is necessary.***

- (c) *Stationary RICE subject to Regulations under 40 CFR Part 60.* An affected source that is a new or reconstructed stationary RICE located at an area source, or is a new or reconstructed stationary RICE located at a major source of HAP emissions and is a spark ignition 2 stroke lean burn (2SLB) stationary RICE with a site rating of less than 500 brake HP, a spark ignition 4 stroke lean burn (4SLB) stationary RICE with a site rating of less than 250 brake HP, or a 4 stroke rich burn (4SRB) stationary RICE with a site rating of less than or equal to 500 brake HP, a stationary RICE with a site rating of less than or equal to 500 brake HP which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, an emergency or limited use stationary RICE with a site rating of less than or equal to 500 brake HP, or a compression ignition (CI) stationary RICE with a site rating of less than or equal to 500 brake HP, ***must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines. No further requirements apply for such engines under this part.***

[69 FR 33506, June 15, 2004, as amended at 73 FR 3604, Jan. 18, 2008]

**ATTACHMENTS**

---

Table 1. Summary of Air Pollutant Standards and Terms

Table 2. Summary of Compliance Requirements

**ATTACHMENTS**

**Table 1-1. Summary of Air Pollutant Standard and Terms**

For convenience purposes only, this table summarizes information related to the electric generating units. It does not supersede any of the terms or conditions of the permit.

| Facility ID No. 0570040, H.L. Culbreath Bayside Power Station |   |      |            |                 |   |                     |      |                      |       |  |  |  |                                |
|---|---|------|------------|-----------------|---|---------------------|------|----------------------|-------|--|--|--|--------------------------------|
| Emissions Unit Information                                    |   |      |            |                 |   | Allowable Emissions |      | Equivalent Emissions |       | Regulatory Citations                             |  |  |                                |
| EU ID   | EU Description  | Fuel | Hours/Year | Pollutant       | Standards   | lb/hour             | TPY  | lb/hour              | TPY   |  |  |  |                                |
| 020<br>To<br>026  | Bayside Units<br>Combined Cycle<br>1A to 1C<br>2A to 2D                             | Gas  | 8760       | CO              | 7.8 ppmvd @ 15% O <sub>2</sub> (Test)   | N/A                 | N/A  | 28.7                 | 125.7 | Rule 62-212.400(BACT), F.A.C.                    |  |  |                                |
|   |   |      |            | CO              | 9 ppmvd @ 15% O <sub>2</sub> (CEMS)   | N/A                 | N/A  | 33.1                 | 145   | Rule 62-212.400(BACT), F.A.C.                    |  |  |                                |
|   |   |      |            | NO <sub>x</sub> | 3.5 ppmvd @ 15% O <sub>2</sub> (Test)   | N/A                 | N/A  | 23.1                 | 101.2 | Permit No. PSD-FL-301                            |  |  |                                |
|   |   |      |            | NO <sub>x</sub> | 3.5 ppmvd @ 15% O <sub>2</sub> (CEMS)   | N/A                 | N/A  | 23.1                 | 101.2 | Permit No. PSD-FL-301                            |  |  |                                |
|   |   |      |            | VE 10           | Visible Emissions ≤ 10% Opacity, Normal Operations  |                     |      |                      |       |  |  |  | Rule 62-212.400(BACT), F.A.C.  |
|   |   |      |            | VE 20           | Visible Emissions ≤ 20% Opacity, conditional during startup and shutdown<br>Limited to ten, 6-minute periods per day. |                     |      |                      |       |  |  |  | Rule 62-212.400(BACT), F.A.C.  |
| 031<br>to<br>038  | Bayside Units<br>Simple Cycle<br>3A/3B<br>4A/4B<br>5A/5B<br>6A/6B<br>7A/7B<br>8A/8B | Gas  | 3500       | CO              | 25 ppmvd @ 15% O <sub>2</sub> (CEMS)<br>(Test)  | 32.0                | 56.0 | 32.0                 | 56.0  | NSPS Subpart KKKK<br>Rule 62-4.070(3), F.A.C.    |  |  |                                |
|   |   |      |            | NO <sub>x</sub> | 21.0 ppmvd @ 15% O <sub>2</sub> (CEMS)  | 9.1                 | 8.2  | 9.1                  | 8.2   | Rule 62-212.400(12), F.A.C.                      |  |  |                                |
|   |   |      |            | PM              | 2 grains sulfur/100 scf of gas  | NA                  | NA   | 2.5                  | 4.4   |  |  |  |                                |
|   |   |      |            | SAM             | 2 grains sulfur/100 scf of gas  | NA                  | NA   | 0.15                 | 0.26  | Rule 62-212.400(12), F.A.C.                      |  |  |                                |
|   |   |      |            | SO <sub>2</sub> | 2 grains sulfur/100 scf of gas<br>0.06 lb/MMBtu   | NA                  | NA   | 1.9                  | 3.3   | Rule 62-212.400(12), F.A.C.<br>NSPS Subpart KKKK |  |  |                                |
|   |   |      |            | VOC             | 5.1 lb/hour (Initial Test)  | 5.1                 | NA   | 5.1                  | 8.9   | Rule 62-212.400(12), F.A.C.                      |  |  |                                |
|   |   |      |            | VE 10           | Visible Emissions < 20% Opacity, Normal Operations (Test)   |                     |      |                      |       |  |  |  | Rule 62-296.320(4)(b)1, F.A.C. |

Notes:

- The "Equivalent Emissions" listed are for informational purposes only.
- Permit PSD-FL-301 was also based on the U.S. EPA vs. TECO Consent Decree and the DEP vs. TECO Consent Final Judgment.
- Rule 62-212.400(12), F.A.C. is the "source obligation" provision.
- SO<sub>2</sub> mass emission rates are based on a fuel sulfur content of 2 grains per 100 scf of natural gas.

**ATTACHMENTS**

**Table 2-1. Summary of Compliance Requirements**

For convenience purposes only, this table summarizes information related to the electric generating units. It does not supersede any of the terms or conditions of the permit.

| Facility ID No. 0570040, H.L. Culbreath Bayside Power Station |   |      |            |                 |                               |                     |                      |                          |     |                   |
|---|---|------|------------|-----------------|-------------------------------|---------------------|----------------------|--------------------------|-----|-------------------|
| Emissions Unit Information                                    |   |      |            |                 |                               | Allowable Emissions | Equivalent Emissions |                          |     | Permit Conditions |
| EU ID   | EU Description  | Fuel | Hours/Year | Pollutant       | Compliance Method             | Test Frequency      | Frequency Base Date  | Compliance Test Duration | CMS |                   |
| 020<br>To<br>026  | Bayside Units<br>Combined Cycle<br>1A to 1C<br>2A to 2D                             | Gas  | 8760       | CO              | Method 10 test                | Initial Only        | ---                  | 3-hour test avg.         | Yes | A.7, A.14         |
|   |   |      |            | CO              | CEMS                          | CEMS                | ---                  | 24-hour block avg.       | Yes | A.7, A.14         |
|   |   |      |            | NO <sub>x</sub> | Method 7E or 20               | Initial Only        | ---                  | 3-hour test avg.         | Yes | A.7, A.14         |
|   |   |      |            | NO <sub>x</sub> | CEMS                          | CEMS                | ---                  | 24-hour block avg.       | Yes | A.7, A.14         |
|   |   |      |            | VE 10           | Method 9                      | Annual              | 12/1/2003            | 30 minutes               | No  | A.7, A.17         |
|   |   |      |            | VE 20<br>SU/SD  | Method 9                      | N/A                 | ---                  | 30 minutes               | No  | A.10              |
| 031<br>to<br>038  | Bayside Units<br>Simple Cycle<br>3A/3B<br>4A/4B<br>5A/5B<br>6A/6B<br>7A/7B<br>8A/8B | Gas  | 3500       | CO              | CEMS                          | CEMS                | ---                  | 3-hour, rolling avg.     | Yes | D.8, D.14         |
|   |   |      |            | CO              | Test/RATA                     | Annual              | FFY                  | 3 hours                  | Yes | D.8               |
|   |   |      |            | NO <sub>x</sub> | CEMS                          | CEMS                | ---                  | 4-hour, rolling avg.     | Yes | D.8, D.14         |
|   |   |      |            | NO <sub>x</sub> | Test/RATA                     | Annual              | FFY                  | 3 hours                  | Yes | D.8, D.14         |
|   |   |      |            | Fuel<br>Sulfur  | Analysis<br>NSPS Subpart KKKK | Monthly             | ---                  | NA                       | No  | D.8, D.23         |
|   |   |      |            | VOC             | CO is surrogate               | CEMS                | ---                  | 3-hour, rolling avg.     | Yes | D.8               |
|   |   |      |            | VE 10           | Method 9                      | Annual              | 07/22/2009           | 30 minutes               | No  | D.8, D.17         |

Notes:

1. The frequency base date is established for planning purposes only. See Rule 62-297.310, F.A.C.
2. CMS means continuous monitoring system.
3. "SU" means startup and "SD" means shutdown. "FFY" means federal fiscal year.



## Friday, Barbara

---

**To:** flbusot@tecoenergy.com  
**Cc:** 'Byron Burrows'; lapence@tecoenergy.com; Zhang-Torres; 'lee@epchc.org'; Halpin, Mike; 'Forney.Kathleen@epamail.epa.gov'; Oquendo.Ana@epamail.epa.gov; Gibson, Victoria; Koerner, Jeff; Holtom, Jonathan  
**Subject:** TAMPA ELECTRIC COMPANY - H. L. CULBREATH BAYSIDE POWER STATION; 0570040-029-AV  
**Attachments:** 0570040-0290-AVSignedFinalNotice.pdf

Dear Sir/ Madam:

Attached is the official **Notice of Final Permit** for the project referenced below. Click on the link displayed below to access the permit project documents and send a "reply" message verifying receipt of the document(s) provided in the link; this may be done by selecting "Reply" on the menu bar of your e-mail software, noting that you can view the documents, and then selecting "Send".

*Note: We must receive verification that you are able to access the documents. Your immediate reply will preclude subsequent e-mail transmissions to verify accessibility of the document*

Attention: Jeff Koerner

Owner/Company Name: TAMPA ELECTRIC COMPANY  
Facility Name: H. L. CULBREATH BAYSIDE POWER STATION  
Project Number: 0570040-029-AV  
Permit Status: FINAL  
Permit Activity: PERMIT REVISION  
Facility County: HILLSBOROUGH

Click on the following link to access the permit project documents:

[http://ARM-PERMIT2K.dep.state.fl.us/adh/prod/pdf\\_permit\\_zip\\_files/0570040.029.AV.F\\_pdf.zip](http://ARM-PERMIT2K.dep.state.fl.us/adh/prod/pdf_permit_zip_files/0570040.029.AV.F_pdf.zip)

The Bureau of Air Regulation is issuing electronic documents for permits, notices and other correspondence in lieu of hard copies through the United States Postal System, to provide greater service to the applicant and the engineering community. Access these documents by clicking on the link provided above, or search for other project documents using the "Air Permit Documents Search" website at <http://www.dep.state.fl.us/air/emission/apds/default.asp> . "

Permit project documents that are addressed in this email may require immediate action within a specified time frame. Please open and review the document(s) as soon as possible, and verify that they are accessible. Please advise this office of any changes to your e-mail address or that of the Engineer-of-Record. If you have any problems opening the documents or would like further information, please contact the Florida Department of Environmental Protection, Bureau of Air Regulation.

Barbara Friday  
Bureau of Air Regulation  
Division of Air Resource Management (DARM)  
(850)921-9524

## Friday, Barbara

---

**From:** Busot, Frank L. [FLBusot@tecoenergy.com]  
**To:** Friday, Barbara  
**Sent:** Wednesday, August 04, 2010 3:25 PM  
**Subject:** Read: TAMPA ELECTRIC COMPANY - H. L. CULBREATH BAYSIDE POWER STATION;  
0570040-029-AV


Your message was read on Wednesday, August 04, 2010 3:25:10 PM (GMT-05:00) Eastern Time (US & Canada).

## Friday, Barbara

---

**From:** Busot, Frank L. [FLBusot@tecoenergy.com]  
**Sent:** Wednesday, August 04, 2010 3:27 PM  
**To:** Friday, Barbara  
**Cc:** Burrows, Byron T.; Pence, Laurie A.; Willoughby, Ben P.  
**Subject:** RE: TAMPA ELECTRIC COMPANY - H. L. CULBREATH BAYSIDE POWER STATION;  
0570040-029-AV  
**Attachments:** Busot Frank.vcf

I can view the document.



---

**From:** Friday, Barbara [mailto:Barbara.Friday@dep.state.fl.us]  
**Sent:** Wednesday, August 04, 2010 3:15 PM  
**To:** Busot, Frank L.  
**Cc:** Burrows, Byron T.; Pence, Laurie A.; Zhang-Torres; lee@epchc.org; Halpin, Mike; Forney.Kathleen@epamail.epa.gov; Oquendo.Ana@epamail.epa.gov; Gibson, Victoria; Koerner, Jeff; Holtom, Jonathan  
**Subject:** TAMPA ELECTRIC COMPANY - H. L. CULBREATH BAYSIDE POWER STATION; 0570040-029-AV

Dear Sir/ Madam:

Attached is the official **Notice of Final Permit** for the project referenced below. Click on the link displayed below to access the permit project documents and send a "reply" message verifying receipt of the document(s) provided in the link; this may be done by selecting "Reply" on the menu bar of your e-mail software, noting that you can view the documents, and then selecting "Send".

*Note: We must receive verification that you are able to access the documents. Your immediate reply will preclude subsequent e-mail transmissions to verify accessibility of the document*

Attention: Jeff Koerner

Owner/Company Name: TAMPA ELECTRIC COMPANY  
Facility Name: H. L. CULBREATH BAYSIDE POWER STATION  
Project Number: 0570040-029-AV  
Permit Status: FINAL  
Permit Activity: PERMIT REVISION  
Facility County: HILLSBOROUGH

Click on the following link to access the permit project documents:

[http://ARM-PERMIT2K.dep.state.fl.us/adh/prod/pdf\\_permit\\_zip\\_files/0570040.029.AV.F\\_pdf.zip](http://ARM-PERMIT2K.dep.state.fl.us/adh/prod/pdf_permit_zip_files/0570040.029.AV.F_pdf.zip)

The Bureau of Air Regulation is issuing electronic documents for permits, notices and other correspondence in lieu of hard copies through the United States Postal System, to provide greater service to the applicant and the engineering community. Access these documents by clicking on the link provided above, or search for other project documents using the “*Air Permit Documents Search*” website at <http://www.dep.state.fl.us/air/emission/apds/default.asp> . “

Permit project documents that are addressed in this email may require immediate action within a specified time frame. Please open and review the document(s) as soon as possible, and verify that they are accessible. Please advise this office of any changes to your e-mail address or that of the Engineer-of-Record. If you have any problems opening the documents or would like further information, please contact the Florida Department of Environmental Protection, Bureau of Air Regulation.

Barbara Friday  
Bureau of Air Regulation  
Division of Air Resource Management (DARM)  
(850)921-9524

*The Department of Environmental Protection values your feedback as a customer. DEP Secretary Michael W. Sole is committed to continuously assessing and improving the level and quality of services provided to you. Please take a few minutes to comment on the quality of service you received. Simply click on [this link to the DEP Customer Survey](#). Thank you in advance for completing the survey.*

---

NOTICE: This email is intended only for the individual(s) to whom it is addressed and may contain confidential information. If you have received this email by mistake, please notify the sender immediately, delete this email from your system and do not copy or disclose it to anyone else. Although we take precautions to protect against viruses, we advise you to take your own precautions to protect against viruses as we accept no liability for any which remain.

## Friday, Barbara

---

**From:** Burrows, Byron T. [BTBurrows@tecoenergy.com]  
**To:** Friday, Barbara  
**Sent:** Wednesday, August 04, 2010 4:16 PM  
**Subject:** Read: TAMPA ELECTRIC COMPANY - H. L. CULBREATH BAYSIDE POWER STATION;  
0570040-029-AV

Your message was read on Wednesday, August 04, 2010 4:15:44 PM (GMT-05:00) Eastern Time (US & Canada).

## Friday, Barbara

---

**From:** Pence, Laurie A. [lapence@tecoenergy.com]  
**To:** Friday, Barbara  
**Sent:** Wednesday, August 04, 2010 3:27 PM  
**Subject:** Read: TAMPA ELECTRIC COMPANY - H. L. CULBREATH BAYSIDE POWER STATION;  
0570040-029-AV

Your message was read on Wednesday, August 04, 2010 3:26:32 PM (GMT-05:00) Eastern Time (US & Canada).

**Friday, Barbara**

---

**From:** Microsoft Exchange  
**To:** lee@epchc.org  
**Sent:** Wednesday, August 04, 2010 3:15 PM  
**Subject:** Relayed: TAMPA ELECTRIC COMPANY - H. L. CULBREATH BAYSIDE POWER STATION;  
0570040-029-AV

**Delivery to these recipients or distribution lists is complete, but delivery notification was not sent by the destination:**

[lee@epchc.org](mailto:lee@epchc.org)

Subject: TAMPA ELECTRIC COMPANY - H. L. CULBREATH BAYSIDE POWER STATION; 0570040-029-AV

---

Sent by Microsoft Exchange Server 2007

## Friday, Barbara

---

**From:** Lee, Diana [Lee@epchc.org]  
**To:** Friday, Barbara  
**Sent:** Thursday, August 05, 2010 9:18 AM  
**Subject:** Read: TAMPA ELECTRIC COMPANY - H. L. CULBREATH BAYSIDE POWER STATION;  
0570040-029-AV

Your message was read on Thursday, August 05, 2010 9:18:01 AM (GMT-05:00) Eastern Time (US & Canada).



## Friday, Barbara

---

**From:** Microsoft Exchange  
**To:** Zhang-Torres; Halpin, Mike; Holtom, Jonathan; Gibson, Victoria  
**Sent:** Wednesday, August 04, 2010 3:15 PM  
**Subject:** Delivered: TAMPA ELECTRIC COMPANY - H. L. CULBREATH BAYSIDE POWER STATION;  
0570040-029-AV

**Your message has been delivered to the following recipients:**

Zhang-Torres

Halpin, Mike

Holtom, Jonathan

Gibson, Victoria

Subject: TAMPA ELECTRIC COMPANY - H. L. CULBREATH BAYSIDE POWER STATION; 0570040-029-AV

---

Sent by Microsoft Exchange Server 2007

## Friday, Barbara

---

**From:** Zhang-Torres  
**To:** Friday, Barbara  
**Sent:** Wednesday, August 04, 2010 3:23 PM  
**Subject:** Read: TAMPA ELECTRIC COMPANY - H. L. CULBREATH BAYSIDE POWER STATION;  
0570040-029-AV

Your message was read on Wednesday, August 04, 2010 3:23:19 PM (GMT-05:00) Eastern Time (US & Canada).

## Friday, Barbara

---

**From:** Holtom, Jonathan  
**To:** Friday, Barbara  
**Sent:** Wednesday, August 04, 2010 3:44 PM  
**Subject:** Read: TAMPA ELECTRIC COMPANY - H. L. CULBREATH BAYSIDE POWER STATION;  
0570040-029-AV

Your message was read on Wednesday, August 04, 2010 3:44:11 PM (GMT-05:00) Eastern Time (US & Canada).

## Friday, Barbara

---

**From:** Gibson, Victoria  
**To:** Friday, Barbara  
**Sent:** Wednesday, August 04, 2010 3:16 PM  
**Subject:** Read: TAMPA ELECTRIC COMPANY - H. L. CULBREATH BAYSIDE POWER STATION;  
0570040-029-AV

Your message was read on Wednesday, August 04, 2010 3:16:10 PM (GMT-05:00) Eastern Time (US & Canada).

**Friday, Barbara**

---

**From:** Mail Delivery System [MAILER-DAEMON@mseive02.rtp.epa.gov]  
**To:** Forney.Kathleen@epamail.epa.gov; Oquendo.Ana@epamail.epa.gov  
**Sent:** Wednesday, August 04, 2010 3:16 PM  
**Subject:** Relayed: TAMPA ELECTRIC COMPANY - H. L. CULBREATH BAYSIDE POWER STATION;  
0570040-029-AV

**Delivery to these recipients or distribution lists is complete, but delivery notification was not sent by the destination:**

[Forney.Kathleen@epamail.epa.gov](mailto:Forney.Kathleen@epamail.epa.gov)

[Oquendo.Ana@epamail.epa.gov](mailto:Oquendo.Ana@epamail.epa.gov)

Subject: TAMPA ELECTRIC COMPANY - H. L. CULBREATH BAYSIDE POWER STATION; 0570040-029-AV

**Friday, Barbara**

---

**From:** Microsoft Exchange  
**To:** Koerner, Jeff  
**Sent:** Wednesday, August 04, 2010 3:15 PM  
**Subject:** Delivered: TAMPA ELECTRIC COMPANY - H. L. CULBREATH BAYSIDE POWER STATION;  
0570040-029-AV

**Your message has been delivered to the following recipients:**

Koerner, Jeff

**Subject:** TAMPA ELECTRIC COMPANY - H. L. CULBREATH BAYSIDE POWER STATION; 0570040-029-AV

---

Sent by Microsoft Exchange Server 2007

## Friday, Barbara

---

**From:** Koerner, Jeff  
**To:** Friday, Barbara  
**Sent:** Wednesday, August 04, 2010 3:40 PM  
**Subject:** Read: TAMPA ELECTRIC COMPANY - H. L. CULBREATH BAYSIDE POWER STATION;  
0570040-029-AV

Your message was read on Wednesday, August 04, 2010 3:39:32 PM (GMT-05:00) Eastern Time (US & Canada).