



RECEIVED

DEC 21 2001

BUREAU OF AIR REGULATION

December 20, 2001

Mr. Scott M. Sheplak, P.E.  
Florida Department of Environmental Protection  
Division of Air Resource Management  
111 South Magnolia Drive, Suite 4  
Tallahassee, Florida 32301

Via FedEx  
Airbill No. 7902 5390 1188

**RE: Tampa Electric Company –  
F.J. Gannon Station  
Byproduct Beneficiation and Re-use  
DEP File No. 0570040-016-AC**

Dear Mr. Sheplak:

Tampa Electric Company (TEC) has received your letter of incompleteness dated October 26, 2001 addressing the proposed request to burn unmarketable byproduct materials in F.J. Gannon Station Units 1-6. This correspondence is intended to provide the responses to each question raised by the Department.

**FDEP Question 1**

**Please describe the beneficiation process in detail and include process flow diagram(s).**

**TEC Response 1**

The byproduct beneficiation process is a wet process and therefore will also minimize fugitive particulate matter (PM) emissions.

TEC expects to reuse a maximum amount of 36,500 tons per year (tpy) of the byproduct materials. The unmarketable conditioned fly ash and slag from the silos, precipitator hoppers, ash storage area, and slag bins will be transported via truck to the coalfield, where the byproduct materials will be screened. Spray water will be added at the screen and to the miscellaneous pile at the coalfield as needed to keep the materials wet, thus minimizing fugitive PM emissions. Water application as needed during material movement, screening, and loading operations shall insure that these activities are handled as a wet process. A rubber-tired front-end loader will place the screened byproduct materials on a portable conveyor, which will then be transported to the bunkers, mixed with raw fuel, and returned in Units 1 through 6.

A simplified process flow diagram of the proposed beneficiation project is shown in Attachment 1, of the permit application package.

**FDEP Question 2**

- a. **What effect will the combustion of unmarketable byproduct material in Units 1-6 have on air pollutant emissions?**
- b. **What are the potential air pollutant emission increases that will result from the combustion of these materials for air pollutants listed in Chapter 62-212, F.A.C., Table 212.400-2?**

**TEC Response 2**

- a. Tampa Electric does not anticipate a measurable impact on air emissions due to the combustion of the byproduct material. Gannon Units 1-6 are currently permitted to re-inject fly ash into each boiler. As stated in the non-PSD permit application, when the beneficiated byproduct material is reintroduced back into the system, the plant will not use the existing closed loop fly ash re-injection system. The proposed rate in which the beneficiated byproduct materials will be reintroduced back into the boilers is less than the current re-injection rate of 100% re-injection. Therefore the combustion of the beneficiated byproduct materials will not cause any air emission increases from the currently permitted operations at Gannon Station. A comparison of the current maximum re-injection rate of 100% re-injection as well as a comparison of stack test reports on Unit 6 with and without fly ash re-injection has been included in Attachment 2.
- b. Tampa Electric does not anticipate a measurable impact on air emissions due to the combustion of the byproduct material for the air pollutants listed in Chapter 62-212, F.A.C., Table 212.400-2. As stated in the TEC Response 2a , Gannon Units 1-6 are currently permitted to re-inject fly ash into each boiler. As indicated in the non-PSD permit application, when the beneficiated byproduct material is reintroduced back into the system, the plant will not use the existing closed loop fly ash re-injection system. The proposed rate in which the beneficiated byproduct materials will be reintroduced back into the boilers is less than the current re-injection rate corresponding to 100% re-injection. Therefore the combustion of the beneficiated byproduct materials will not cause any air emission increases from the currently permitted operations at Gannon Station. A comparison of the current maximum re-injection rate of 100% re-injection as well as a comparison of stack test reports on Unit 6 with and without fly ash re-injection has been included in Attachment 2.

**FDEP Question 3**

- a. **Will any physical changes need to be made to the boilers?**
- b. **You indicated in your application that you plan to add the byproducts to the raw fuel (coal) in the bunkers. Do you plan to add this material as a percentage (%) of the heat input or % of the mass, tons per hour? If so, at what rate?**

**TEC Response 3**

- a. No, there will not be any physical changes made to the boilers to accommodate this process.
- b. When combusting the beneficiated byproduct material, TEC will combust a weight percent blend of the byproduct material with coal. As shown in Table 1 of the permit application, the maximum amount of the byproduct material fired is expected to be no more than 100 tons per day (and thus, no more than 50 tons per hour). The estimated maximum fly ash weight percentage for the station from the total fuel consumption rate would be 0.85 %.

**FDEP Question 4**

- a. **Why are the byproduct materials “unmarketable”?**
- b. **Is the fly ash and/or slag a hazardous waste?**

**TEC Response 4**

- a. Tampa Electric has contracts in place for the sale of the byproduct materials that meet the terms and conditions specified. However, portions of the byproducts do not meet the vendor specifications and cannot be sold under current contracts. The reason that the referenced byproduct materials may be considered “unmarketable” is that they are often high in carbon content, therefore making them recyclable in terms of energy and byproduct recovery.
- b. No, fly ash and slag are not considered hazardous wastes.

**FDEP Question 5**

**Please describe the “slag”. Is this material the same as bottom ash?**

**TEC Response 5**

Slag is not considered to be the same as bottom ash. Bottom Ash is the ash that settles in a dry-bottom furnace, or is dislodged from the furnace walls, and usually collected in a hopper formed by the frontwall and rearwall tube panels at the bottom of the furnace. It is a glassy material with a high mineral content that results from the burning of coal in dry-bottom furnace. TEC only has one dry-bottom furnace that produces bottom ash, Big Bend Unit 4.

Slag is the consolidated material that settles to the bottom of wet-bottom furnaces. Slag, unlike bottom ash, forms when operating temperatures exceed the ash fusion temperature and remain in a molten state as it is drained from the furnace bottom. This molten ash that is collected on the wet-bottom furnace walls and other surfaces in the lower furnace, melted and quenched in the bottom hoppers then becomes hard and glassy. The material is similar in mineral content to fly ash. Three of Big Bend's units and all six of Gannon Station's current units produce slag.

**FDEP Question 6**

**Please provide a full elemental speciation analysis of the fly ash and slag constituents. Be sure to include heavy metals, i.e., mercury, lead, nickel, etc. on a percentage (%) by weight basis. Will there be any increases in mercury and/or lead air pollutant emissions from combustion?**

**TEC Response 6**

The requested full elemental speciation analysis of the fly ash and slag constituents is enclosed in Attachment 3. Tampa Electric does not anticipate that there will be any increases in heavy metals from the combustion of the beneficiated byproduct material.

**FDEP Question 7**

**Is the “closed loop fly ash re-injection system” mentioned on page 1-2 of your application a permitted activity? Please describe this activity.**

TEC Response 7

Yes, the "closed loop fly ash re-injection system" is a permitted activity. Each unit has its own fly ash system that can collect fly ash from the electrostatic precipitator hoppers to be conveyed to a storage silo or re-injection ports on the furnace. Fly ash that is collected in the hoppers of the electrostatic precipitators serving Units 5 and 6 is either re-injected into each individual boiler system or pneumatically conveyed to a 25 foot diameter, 50 foot high silo, Fly ash Silo (No.1). Fly ash that is collected in the hoppers of the electrostatic precipitators of Units 1-4 is either re-injected into each individual boiler system or pneumatically conveyed to a 30 foot diameter, 45.5 foot high silo, Fly ash Silo (No.2). Interlocks prevent any subsystem from conveying fly ash to the silo and the re-injection ports simultaneously. A copy of the process flow diagram, Figure II.D.3.6 (Volume II), that was provided with Tampa Electric's original Title V permit application, dated June 1996, is provided in Attachment 4.

FDEP Question 8

The following questions relate to the material handling operations:

- A. The PM/PM10 emissions calculations were based on AP-42 Chapter 13.2. The silt content and moisture content were not in the range of the allowable source conditions for the equation(s). As such, the quality rating should be lowered at least one quality rating and the emissions estimates should be adjusted accordingly (Reference "Using the AP-42 Data Base for Making Exclusionary Rule Applicability Determinations" by Eric Noble 3/2/95).
- B. In the emissions calculations, you used a control efficiency of 99% for water spray. As noted in AP-42 Appendix B-2, the maximum control efficiency for dust suppression by water sprays for particle sizes 6-10 $\mu$ m is 90%. In addition, the U.S. Department of Energy, "Technical Guide to Estimating Fugitive Dust Impacts from Coal Handling Operations", Table 4-3 list a maximum control efficiency of 90% for micron droplet water spray systems. It is more appropriate to use the 90% control efficiency listed in AP-42 and the DOE document, since the equation used to estimate emissions is from AP-42. In addition, the 99% control efficiency used in the application is not appropriate. Its use would imply that the control efficiency of a water spray system is equivalent to that of a high efficiency wet scrubber (Reference AP-42 Appendix B-2). If the emissions are adjusted using the 90% control efficiency, then PM emissions from the project would exceed 200 tpy and PM10 emissions would exceed of 100 tpy, and the project would be subject to PSD New Source Review Requirements pursuant to Rule 62-212.400(5), F.A.C. If PSD NSR is triggered, please revise your application accordingly.
- C. Per the process description on page 1-2 of your application, it states that a "front-end loader will place the screened byproduct materials on the portable conveyor". After screening, if the material is placed on a "new" pile prior to conveyor, then this transfer point needs to be included in Table 1 and 2 for emissions estimates.
- D. In your application, you state that the material will be sufficiently wet.
  - a. What measures will be employed by TECO to keep the material wet during handling and storage?
  - b. Is the 5% moisture content used in the emission estimate before or after the application of water?

- c. **If the 5% moisture content is after the application of water, then the 90% control efficiency estimate used in the application is not appropriate since it is double counting the water spray controls.**
- E. **On page 1-3 of your application, you state that emissions from the slag loading/unloading operations were negligible. Similar to the fly ash handling, there are emissions associated with the slag handling. What are the emissions estimates and assumptions taken for the slag handling?**

TEC Response 8

- A. Table 13.2.4-1 of AP-42 states that silt content of fly ash is between 87 and 81%, with a mean of 80%. TEC used 80% in the emissions calculations. The moisture content of the conditioned fly ash (based on test data) is 10 +/- 3%. TEC conservatively used 5% in the emissions calculations. AP-42 indicates that fly ash moisture content ranges between 26 and 29%, with mean of 27%. Since the test data is not only more representative of the project, but is also more conservative, the emission estimates are also conservative.
- B. Included as an attachment to the permit application is an excerpt from a EPRI document, "Fugitive Emissions From Coal-fired Power Plants," stating that close to 100% control can be achieved during most handling operations, if the fly ash is kept sufficiently wet. The control efficiency, in this context, is used as a preventative measure rather than as an emissions control. In other words, if the fly ash is sufficiently wet, it generates little or no fugitive PM emissions since the particles would be adhered to one another, causing a dust suppression effect. Therefore, it is not analogous to a piece of control equipment such as a wet scrubber. Currently the fly ash is routed from the Silo to the pugmill, where it is conditioned by wetting with water and thus causing it to be adequately wet.
- C. At the time the permit application was submitted, TEC did not take in account a new pile being formed after screening the byproduct material. There is a possibility that the screened materials will be placed in a new pile prior to the conveyor. Therefore, a new transfer point has been added to Table 1 and 2 for emission estimates. These updated tables are provided in Attachment 5.
- D. Additional control efficiency for watering as used in the emissions calculations is not double counting. First, the moisture content is an inherent property of the "conditioned" material. Any additional watering would increase the moisture content of the material. Secondly, TEC used an "uncontrolled" PM emission factor of 110 lb/ton, which is the highest of the available emission factors in AP-42 as well as other documents researched for the proposed screening operation. This emission factor does not allow for any adjustment due to variables such as moisture content or silt content. Therefore, TEC believes that the use of additional control efficiency is justified in the emissions estimates. A comparison of AP-42 emission factors derived from available data has been compiled to support the emission factor and control efficiency selected for this project, Attachment 6.
  - a. Fly ash transported by dump truck to the coalfield shall be adequately wetted and processed through the pugmill. Spray water will be added to the screen and to the miscellaneous pile at the coalfield as needed to keep the materials wet, thus minimizing fugitive PM emissions. In addition, the dump trucks used to transport fly ash shall utilize tarps at all times except when loading/unloading.
  - b. The 5% moisture content used in the emission estimate is before the application of water.

- c. As stated above, since the 5% moisture content is before the application of water, the 99% control efficiency used in the application is not double counting the water spray controls.
- E. It was conservatively assumed (for PM emissions calculation purposes) that all of the byproduct materials are fly ash. Since slag (glassy material) is much heavier and coarser than fly ash and the total process rate is capped, the use of slag would only decrease the potential PM emissions.

**FDEP Question 9**


**Given that the Gannon Station is undergoing a repowering and the station is operating under EPA and DEP settlements, what is the duration of these activities (combustion of unmarketable byproduct materials in Units 1-6 and beneficiation of fly ash/slag)?**

**TEC Response 9**

The duration of the beneficiation and combustion of unmarketable byproduct material in Units 1-6 will extend until the last unit is repowered to natural gas in 2004.

The Professional Engineer and Responsible Official Certifications are included in Attachments 7 and 8, respectively, of this submittal. TEC appreciates the opportunity to provide the additional information contained in this correspondence. If you have any questions, please call me at (813) 641-5261.

Sincerely,



Raiza Calderon  
Engineer  
Environmental Affairs

Enclosure

c/enc: Mr. Jerry Campbell, EPCHC  
Ms. Alice Harman, EPCHC  
Mr. Jerry Kissel - FDEP SW  
Mr. Scott Sheplak, FDEP

Enclosure

**ATTACHEMENT 1**

FIGURE 2. PROCESS LAYOUT

FIGURE 3. PROCESS FLOW DIAGRAM




FIGURE 2.  
PROCESS LAYOUT.

Source: TECO, 2001.








FIGURE 3.  
PROCESS FLOW DIAGRAM

Source: ECT, 2001.




**ATTACHEMENT 2**

COMPARISON OF FJ GANNON STATION UNIT 6 FLYASH  
REINJECTION

## Comparison of FJ Gannon Station Unit 6 Emissions from Flyash Reinjection

| Date                        | Flyash Reinjection | Particulate Matter |               | SO <sub>2</sub> | Visible Emissions |              |
|-----------------------------|--------------------|--------------------|---------------|-----------------|-------------------|--------------|
|                             |                    | Non-Soot Blowing   | Soot Blowing  |                 | Non-Soot Blowing  | Soot Blowing |
|                             | (%)                | (lbs / MMBtu)      | (lbs / MMBtu) | (lbs / MMBtu)   | (%)               | (%)          |
| <b>Title V Permit Limit</b> | <b>100</b>         | <b>0.1</b>         | <b>0.3</b>    | <b>2.4</b>      | <b>20</b>         | <b>20</b>    |
| April 9, 1997               | 100                | -                  | 0.07          | 1.600           | -                 | 5            |
| May 5, 1998                 | 100                | -                  | 0.08          | 2.100           | -                 | 6            |
| July 21, 1999               | 100                | -                  | 0.09          | 2.350           | -                 | 10           |
| March 8, 2000               | 100                | -                  | 0.05          | 2.114           | -                 | 5            |
| August 14-15, 2001          | 0                  | 0.07               | 0.10          | <b>1.865</b>    | 11                | 14           |

\* RATA was done on March 13, 2001



**EMISSIONS TEST REPORT  
PARTICULATE MATTER, SULFUR DIOXIDE, and  
VISIBLE EMISSIONS EVALUATION  
AUGUST 14 – 15, 2001  
F.J. GANNON STATION  
FACILITY ID NUMBER: 0570040  
EMISSION UNIT ID NO: -006  
UNIT 6**

Prepared For:  
Tampa Electric Company  
F.J. Gannon Station  
P.O. Box 111  
Tampa, Florida 33601-0111

Prepared By:  
Tampa Electric Company  
Environmental Affairs Department  
Environmental Services, Air Services Group



Environmental Services  
Air Services Group  
5010 Causeway Boulevard  
Tampa, Florida 33619- 6130

## 1.0 SUMMARY OF RESULTS

---

On August 14 – 15, 2001, the Environmental Services group of Tampa Electric Company, performed particulate matter source emissions tests at the F.J. Gannon Station, boiler number 6 (emissions unit ID number 0570040-006). Testing was conducted according to procedures stipulated by the Florida Department of Environmental Protection (FDEP) for fossil fuel fired steam generators, and requirements in Title V Permit No.: 0570040-002-AV.

The particulate matter emission rate under soot blowing conditions was derived from 3 USEPA Reference Method 17-test runs. The average of the 3 test runs was 0.10 lbs./MMBtu's. The FDEP allowable emission rate under soot-blowing conditions is 0.3 lbs./MMBtu's.

The particulate matter emission rate under non-soot blowing conditions was derived from 3 USEPA Reference Method 17-test runs. The average of the 3 test runs was 0.07 lbs./MMBtu's. The FDEP allowable emission rate under non soot-blowing conditions is 0.1 lbs./MMBtu's.

A 40CFR75 Relative Accuracy Test Audit (RATA) was conducted on March 16, 2001 for sulfur dioxide (SO<sub>2</sub>) emissions, and this data was used to demonstrate compliance with the FDEP SO<sub>2</sub> emission rate of 2.4 lbs./MMBtu's. The average of the 9, 21-minute USEPA Reference Method 6C/3A runs was 1.865 lbs./MMBtu's.

Visible emissions were evaluated using a Thermo Environmental Instruments, Model 400 transmissometer (S/N 400B-29003-233/B32), during both soot blowing and non soot-blowing testing. The 1-hour average opacity under soot blowing conditions was 14%. The 1-hour average opacity under non-soot blowing conditions was 11%. The FDEP allowable emission rate is 20 percent opacity.

During the tests, the boiler was operated at an average heat input rate of 3980 MMBtu's/hr. and an average load of 372 Mwe. The average quantity of fuel burned was 172 tons per hour. Details of boiler operations are presented in Appendix C.



TEST SUMMARY  
PARTICULATE EMISSIONS  
TEST RESULTS

| SOURCE INFORMATION               |  |  |  |  |
|----------------------------------|--|--|--|--|
| PLANT: F.J. Gannon               |  |  |  |  |
| DATE: 08/14&15/2001              |  |  |  |  |
| SAMPLING LOCATION: Unit #6       |  |  |  |  |
| OPERATING CONDITION: Sootblowing |  |  |  |  |

| RESULTS               | RUN NO<br>1-S | RUN NO<br>2-S | RUN NO<br>3-S | TEST<br>AVERAGE |
|-----------------------|---------------|---------------|---------------|-----------------|
| GAS FLOW RATE         |               |               |               |                 |
| (dscf/min)            | 810654        | 803948        | 805465        | 806689          |
| (acf/min)             | 1318529       | 1303960       | 1309787       | 1310759         |
| STACK TEMP.           |               |               |               |                 |
| (DEG. F)              | 309.3         | 306.3         | 304.9         | 306.8           |
| ISOKINETIC            |               |               |               |                 |
| (%)                   | 102.6         | 102.5         | 102.9         | 102.7           |
| MOISTURE              |               |               |               |                 |
| (% H2O)               | 9.30          | 9.40          | 9.80          | 9.50            |
| SAMPLE VOLUME         |               |               |               |                 |
| (dscf)                | 35.311        | 35.011        | 35.181        | 35.168          |
| CONDENSATE VOL.       |               |               |               |                 |
| (ml)                  | 76.4          | 76.7          | 81.4          | 78.2            |
| METER TEMP.           |               |               |               |                 |
| (DEG. F)              | 96            | 97            | 92            | 95              |
| PART. EMISSIONS       |               |               |               |                 |
| (lbs / MM Btu)        |               |               |               |                 |
| Emissions by F-factor | 0.08999       | 0.09838       | 0.09936       | 0.09591         |



TEST SUMMARY  
PARTICULATE EMISSIONS  
TEST RESULTS

| SOURCE INFORMATION                   |  |  |  |  |
|--------------------------------------|--|--|--|--|
| PLANT: F.J. GANNON STATION           |  |  |  |  |
| DATE: 08/14/01                       |  |  |  |  |
| SAMPLING LOCATION: UNIT NO.6         |  |  |  |  |
| OPERATING CONDITION: NON-SOOTBLOWING |  |  |  |  |

| RESULTS               | RUN NO<br>1 | RUN NO<br>2 | RUN NO<br>3 | TEST<br>AVERAGE |
|-----------------------|-------------|-------------|-------------|-----------------|
| GAS FLOW RATE         |             |             |             |                 |
| (dscf/min)            | 798955      | 804279      | 807387      | 803540          |
| (acf/min)             | 1295218     | 1318529     | 1312701     | 1308816         |
| STACK TEMP.           |             |             |             |                 |
| (DEG. F)              | 307.3       | 308.9       | 310.3       | 308.8           |
| ISOKINETIC            |             |             |             |                 |
| (%)                   | 102.4       | 103.7       | 102.8       | 103.0           |
| MOISTURE              |             |             |             |                 |
| (% H2O)               | 9.70        | 10.30       | 9.30        | 9.77            |
| SAMPLE VOLUME         |             |             |             |                 |
| (dscf)                | 34.732      | 35.406      | 35.248      | 35.129          |
| CONDENSATE VOL.       |             |             |             |                 |
| (ml)                  | 78.8        | 85.9        | 76.6        | 80.4            |
| METER TEMP.           |             |             |             |                 |
| (DEG. F)              | 101         | 102         | 100         | 101             |
| PART. EMISSIONS       |             |             |             |                 |
| (lbs / MM Btu)        |             |             |             |                 |
| Emissions by F-factor | 0.06207     | 0.07456     | 0.07897     | 0.07187         |



# TEST SUMMARY

## SULFUR DIOXIDE TEST RESULTS

---

|                           |                      |
|---------------------------|----------------------|
| <b>PLANT:</b>             | F. J. GANNON STATION |
| <b>SAMPLING LOCATION:</b> | BOILER NO. 6         |
| <b>DATE:</b>              | March 13, 2001       |

### USEPA Method 6C

| Run Number | lbs. SO <sub>2</sub> /MMBtu's |
|------------|-------------------------------|
| 1          | 1.728                         |
| 2          | 1.730                         |
| 3          | 1.760                         |
| 4          | 1.836                         |
| 5          | 1.905                         |
| 6          | 1.948                         |
| 7          | 1.964                         |
| 8          | 1.973                         |
| 9          | 1.942                         |

**TEST AVERAGE:** 1.865 lbs. SO<sub>2</sub>/MM Btu



**Visible Emissions Determination from Opacity Monitor**

**Facility:** F.J. Gannon

**Unit:** Unit 6

**Operating Conditions:** Non-sootblowing

| Record# | DATE       | TIME   | GN1OPA11 | Record# | DATE       | TIME   | GN1OPA11 |
|---------|------------|--------|----------|---------|------------|--------|----------|
| 1       | 08/14/2001 | 114900 | 11.028   | 31      | 08/14/2001 | 121900 | 11.004   |
| 2       | 08/14/2001 | 115000 | 10.957   | 32      | 08/14/2001 | 122000 | 11.886   |
| 3       | 08/14/2001 | 115100 | 11.676   | 33      | 08/14/2001 | 122100 | 11.198   |
| 4       | 08/14/2001 | 115200 | 11.078   | 34      | 08/14/2001 | 122200 | 11.881   |
| 5       | 08/14/2001 | 115300 | 12.798   | 35      | 08/14/2001 | 122300 | 10.440   |
| 6       | 08/14/2001 | 115400 | 11.199   | 36      | 08/14/2001 | 122400 | 10.409   |
| 7       | 08/14/2001 | 115500 | 10.919   | 37      | 08/14/2001 | 122500 | 10.420   |
| 8       | 08/14/2001 | 115600 | 10.829   | 38      | 08/14/2001 | 122600 | 10.385   |
| 9       | 08/14/2001 | 115700 | 10.889   | 39      | 08/14/2001 | 122700 | 10.380   |
| 10      | 08/14/2001 | 115800 | 10.955   | 40      | 08/14/2001 | 122800 | 11.387   |
| 11      | 08/14/2001 | 115900 | 10.862   | 41      | 08/14/2001 | 122900 | 11.472   |
| 12      | 08/14/2001 | 120000 | 10.893   | 42      | 08/14/2001 | 123000 | 11.447   |
| 13      | 08/14/2001 | 120100 | 10.896   | 43      | 08/14/2001 | 123100 | 11.423   |
| 14      | 08/14/2001 | 120200 | 10.867   | 44      | 08/14/2001 | 123200 | 11.436   |
| 15      | 08/14/2001 | 120300 | 10.881   | 45      | 08/14/2001 | 123300 | 10.459   |
| 16      | 08/14/2001 | 120400 | 11.986   | 46      | 08/14/2001 | 123400 | 10.416   |
| 17      | 08/14/2001 | 120500 | 11.165   | 47      | 08/14/2001 | 123500 | 9.584    |
| 18      | 08/14/2001 | 120600 | 11.754   | 48      | 08/14/2001 | 123600 | 9.364    |
| 19      | 08/14/2001 | 120700 | 10.929   | 49      | 08/14/2001 | 123700 | 9.369    |
| 20      | 08/14/2001 | 120800 | 10.919   | 50      | 08/14/2001 | 123800 | 10.009   |
| 21      | 08/14/2001 | 120900 | 10.996   | 51      | 08/14/2001 | 123900 | 10.376   |
| 22      | 08/14/2001 | 121000 | 10.705   | 52      | 08/14/2001 | 124000 | 10.357   |
| 23      | 08/14/2001 | 121100 | 9.946    | 53      | 08/14/2001 | 124100 | 10.743   |
| 24      | 08/14/2001 | 121200 | 10.193   | 54      | 08/14/2001 | 124200 | 11.539   |
| 25      | 08/14/2001 | 121300 | 10.969   | 55      | 08/14/2001 | 124300 | 11.512   |
| 26      | 08/14/2001 | 121400 | 11.105   | 56      | 08/14/2001 | 124400 | 11.538   |
| 27      | 08/14/2001 | 121500 | 12.016   | 57      | 08/14/2001 | 124500 | 10.660   |
| 28      | 08/14/2001 | 121600 | 12.018   | 58      | 08/14/2001 | 124600 | 11.179   |
| 29      | 08/14/2001 | 121700 | 11.993   | 59      | 08/14/2001 | 124700 | 11.622   |
| 30      | 08/14/2001 | 121800 | 12.004   | 60      | 08/14/2001 | 124800 | 11.661   |

Test Average: 11.016 %  
 Minimum One Minute Average: 9.364 %  
 Maximum One Minute Average: 12.798 %  
 Maximum Six Minute Average: 11.820 %



### Visible Emissions Determination from Opacity Monitor

Facility: F.J. Gannon

Unit: Unit 6

Operating Conditions: Sootblowing

| Record# | DATE       | TIME   | GN1OPA11 | Record# | DATE       | TIME   | GN1OPA11 |
|---------|------------|--------|----------|---------|------------|--------|----------|
| 1       | 08/14/2001 | 184100 | 13.357   | 31      | 08/14/2001 | 191100 | 14.417   |
| 2       | 08/14/2001 | 184200 | 12.722   | 32      | 08/14/2001 | 191200 | 13.349   |
| 3       | 08/14/2001 | 184300 | 12.749   | 33      | 08/14/2001 | 191300 | 13.476   |
| 4       | 08/14/2001 | 184400 | 13.323   | 34      | 08/14/2001 | 191400 | 13.144   |
| 5       | 08/14/2001 | 184500 | 14.514   | 35      | 08/14/2001 | 191500 | 13.245   |
| 6       | 08/14/2001 | 184600 | 15.491   | 36      | 08/14/2001 | 191600 | 13.584   |
| 7       | 08/14/2001 | 184700 | 13.691   | 37      | 08/14/2001 | 191700 | 13.788   |
| 8       | 08/14/2001 | 184800 | 13.696   | 38      | 08/14/2001 | 191800 | 14.551   |
| 9       | 08/14/2001 | 184900 | 13.705   | 39      | 08/14/2001 | 191900 | 15.484   |
| 10      | 08/14/2001 | 185000 | 14.220   | 40      | 08/14/2001 | 192000 | 14.101   |
| 11      | 08/14/2001 | 185100 | 14.890   | 41      | 08/14/2001 | 192100 | 13.190   |
| 12      | 08/14/2001 | 185200 | 14.474   | 42      | 08/14/2001 | 192200 | 12.900   |
| 13      | 08/14/2001 | 185300 | 13.702   | 43      | 08/14/2001 | 192300 | 11.912   |
| 14      | 08/14/2001 | 185400 | 13.076   | 44      | 08/14/2001 | 192400 | 11.908   |
| 15      | 08/14/2001 | 185500 | 13.372   | 45      | 08/14/2001 | 192500 | 12.691   |
| 16      | 08/14/2001 | 185600 | 14.741   | 46      | 08/14/2001 | 192600 | 13.272   |
| 17      | 08/14/2001 | 185700 | 14.609   | 47      | 08/14/2001 | 192700 | 13.568   |
| 18      | 08/14/2001 | 185800 | 13.705   | 48      | 08/14/2001 | 192800 | 14.871   |
| 19      | 08/14/2001 | 185900 | 13.651   | 49      | 08/14/2001 | 192900 | 16.959   |
| 20      | 08/14/2001 | 190000 | 13.605   | 50      | 08/14/2001 | 193000 | 15.336   |
| 21      | 08/14/2001 | 190100 | 12.637   | 51      | 08/14/2001 | 193100 | 15.615   |
| 22      | 08/14/2001 | 190200 | 12.561   | 52      | 08/14/2001 | 193200 | 14.840   |
| 23      | 08/14/2001 | 190300 | 12.806   | 53      | 08/14/2001 | 193300 | 14.421   |
| 24      | 08/14/2001 | 190400 | 12.669   | 54      | 08/14/2001 | 193400 | 13.542   |
| 25      | 08/14/2001 | 190500 | 13.255   | 55      | 08/14/2001 | 193500 | 13.074   |
| 26      | 08/14/2001 | 190600 | 14.482   | 56      | 08/14/2001 | 193600 | 14.581   |
| 27      | 08/14/2001 | 190700 | 15.453   | 57      | 08/14/2001 | 193700 | 14.523   |
| 28      | 08/14/2001 | 190800 | 16.833   | 58      | 08/14/2001 | 193800 | 14.577   |
| 29      | 08/14/2001 | 190900 | 16.079   | 59      | 08/14/2001 | 193900 | 13.674   |
| 30      | 08/14/2001 | 191000 | 16.356   | 60      | 08/14/2001 | 194000 | 13.473   |

Test Average: 13.975 %  
Minimum One Minute Average: 11.908 %  
Maximum One Minute Average: 16.959 %  
Maximum Six Minute Average: 15.603 %

# COMPLIANCE TEST DATA

F. J. GANNON STATION

BOILER NO. 6 TEST DATE 8/14/01

UNIT LOAD (MN) 368

BASE LOADED (TIME) 0500

**TEST DATA**

| MEGAWATTS INTEGRATOR                               | INITIALS  |
|--|-----------|
| BEGIN MWH <u>1249</u> BEGIN SAMPLING <u>835053</u> | <u>EB</u> |
| END MWH <u>0139</u> END SAMPLING <u>839837</u>     | <u>EB</u> |

**SOOTBLOWING**

| RUN   | BEGIN TIME | END TIME | INITIALS                |
|-------|------------|----------|-------------------------|
| 1 NSB | 1249       | 1421     | EB / <u>[Signature]</u> |
| 2 NSB | 1514       | 1647     | EB / <u>[Signature]</u> |
| 3 NSB | 1732       | 1902     | EB / <u>[Signature]</u> |
| 1 SB  | 1941       | 2112     | EB / <u>[Signature]</u> |

**FLYASH REINJECTION**

| RUN   | REINJECTION (Y/N) | % REINJECTION | INITIALS  |
|-------|-------------------|---------------|-----------|
| 1 NSB | no                | 0%            | EB / TGC  |
| 2 NSB | no                | 0%            | EB / TGC  |
| 3 NSB | no                | 0%            | EB / E.P. |
| 1 SB  | no                | 0%            | EB / E.P. |
|       |                   |               |           |
|       |                   |               |           |
|       |                   |               |           |
|       |                   |               |           |

# COMPLIANCE TEST DATA

F. J. GANNON STATION

BOILER NO. 6 TEST DATE 8/14/01

UNIT LOAD (MN) 368

BASE LOADED (TIME) 0500

**TEST DATA**

| MEGAWATTS INTEGRATOR                               | INITIALS  |
|--|-----------|
| BEGIN MWH <u>1249</u> BEGIN SAMPLING <u>835053</u> | <u>CB</u> |
| END MWH <u>0139</u> END SAMPLING <u>839837</u>     | <u>CB</u> |

**SOOTBLOWING**

| RUN        | BEGIN TIME  | END TIME    | INITIALS        |
|------------|-------------|-------------|-----------------|
| <u>2SB</u> | <u>2155</u> | <u>2327</u> | <u>CB/ E.P.</u> |
| <u>3SB</u> | <u>0008</u> | <u>0139</u> | <u>CB/ E.P.</u> |
|            |             |             |                 |
|            |             |             |                 |

**FLYASH REINJECTION**

| RUN        | REINJECTION (Y/N) | % REINJECTION | INITIALS        |
|------------|-------------------|---------------|-----------------|
| <u>2SB</u> | <u>no</u>         | <u>0%</u>     | <u>CB/ E.P.</u> |
| <u>3SB</u> | <u>no</u>         | <u>0%</u>     | <u>CB/ E.P.</u> |
|            |                   |               |                 |
|            |                   |               |                 |
|            |                   |               |                 |
|            |                   |               |                 |
|            |                   |               |                 |
|            |                   |               |                 |

STACK TEST CHECKLIST

UNIT NO. 6

DATE 8/14/01

SHIFT Day

BTO check items

Fly ash system operational - YES/NO \_\_\_\_\_ (Initial) TGC  
(check for stuck feeder gates or blower failure)

100% Ash reinjection - YES/NO \_\_\_\_\_ (Initial) TGC

Precipitator fully operational - YES/NO \* \_\_\_\_\_ (Initial) TGC

COMMENTS \* CI-DI EAST SIDE HOPPER HI-LEVEL AND GROUND  
OUT.

SHIFT Night

BTO check items

Fly ash sytem operational - YES/NO E.P. (Initial)  
(check for stuck feeder gates or blower failure)

100% Ash reinjection - YES/NO E.P. (Initial)

Precipitator fully operational - YES/NO E.P. (Initial)

COMMENTS CI-DI east side grounded

SHIFT \_\_\_\_\_

BTO check items

Fly ash system operational - YES/NO \_\_\_\_\_ (Initial)  
(check for stuck feeder gates or blower failure)

100% Ash reinjection - YES/NO \_\_\_\_\_ (Initial)

Precipitator fully operational - YES/NO \_\_\_\_\_ (Initial)

COMMENTS \_\_\_\_\_


# CORPORATE ENVIRONMENTAL SERVICES

## AIR PROGRAMS REPORT

SOURCE EMISSION TEST  
F. J. GANNON GENERATING STATION

BOILER NO. 6  
AIRS #0570040  
MARCH 8, 2000

PARTICULATE, SULFUR DIOXIDE  
AND VISIBLE EMISSION TESTING



## 1.0 SUMMARY OF RESULTS

On March 8, 2000, Corporate Environmental Services, Air Services and Auditing group of Tampa Electric Company, performed source emission tests at the Gannon Station, Boiler number 6, Airs # 0570040. Testing was conducted according to procedures stipulated by the Florida Department of Environmental Protection (FDEP) for fossil fuel steam generators, and requirements in Permit # A029-203512. A summary of the test results are shown in Section 3.0.

The particulate emission rate, under sootblowing conditions, was derived from three test runs. The calculated average is 0.05 pounds of particulate matter per million Btu ( $\text{lb}/10^6 \text{ Btu}$ ). The FDEP allowable emission rate under sootblowing conditions is 0.3  $\text{lb}/10^6 \text{ Btu}$ . This test under sootblowing conditions demonstrates compliance with the non-sootblowing emission limitation of 0.1  $\text{lb}/10^6 \text{ Btu}$ .

The sulfur dioxide ( $\text{SO}_2$ ) emission rate was derived from three test runs. The calculated average is 2.1  $\text{lb}/10^6 \text{ Btu}$ . The FDEP allowable emission rate is 2.4  $\text{lb}/10^6 \text{ Btu}$ .

A visible emission test was performed during sootblowing conditions. The average opacity observed during the one hour test was 5 percent. The FDEP allowable emission rate is 20 percent opacity.

During the tests on March 8, 2000 the boiler was operated at an average heat input rate of  $3685 \times 10^6 \text{ Btu/hr}$  and a average load of 355 megawatts. The average quantity of fuel burned was 155 tons per hour. Details of boiler operation are included in Appendix C.





TEST SUMMARY  
PARTICULATE EMISSIONS  
TEST RESULTS

| SOURCE INFORMATION                |  |  |  |  |
|-----------------------------------|--|--|--|--|
| PLANT: F.J. GANNON STATION        |  |  |  |  |
| DATE: 03/08/00                    |  |  |  |  |
| SAMPLING LOCATION : UNIT NO.6     |  |  |  |  |
| OPERATING CONDITION : SOOTBLOWING |  |  |  |  |

| RESULTS               | RUN NO.<br>2-S | RUN NO.<br>3-S | RUN NO.<br>4-S | TEST<br>AVERAGE |
|-----------------------|----------------|----------------|----------------|-----------------|
| GAS FLOW RATE         |                |                |                |                 |
| (dscf/min)            | 746394         | 741327         | 756183         | 747968          |
| (acf/min)             | 1178663        | 1168464        | 1194689        | 1180605         |
| STACK TEMP.           |                |                |                |                 |
| (DEG. F)              | 294.5          | 293.9          | 297.8          | 295.4           |
| ISOKINETIC            |                |                |                |                 |
| (%)                   | 103.0          | 103.4          | 102.3          | 102.9           |
| MOISTURE              |                |                |                |                 |
| (% H2O)               | 9.60           | 9.50           | 9.40           | 9.50            |
| SAMPLE VOLUME         |                |                |                |                 |
| (dscf)                | 35.452         | 35.377         | 35.715         | 35.515          |
| CONDENSATE VOL.       |                |                |                |                 |
| (ml)                  | 79.9           | 78.4           | 78.2           | 78.8            |
| METER TEMP.           |                |                |                |                 |
| (DEG. F)              | 87             | 93             | 97             | 92              |
| PART. EMISSIONS       |                |                |                |                 |
| (lbs / MM Btu)        |                |                |                |                 |
| Emissions by F-factor | 0.04604        | 0.04074        | 0.06102        | 0.04927         |

# TEST SUMMARY SULFUR DIOXIDE TEST RESULTS

---

|                    |                      |
|--------------------|----------------------|
| PLANT:             | F. J. GANNON STATION |
| SAMPLING LOCATION: | BOILER NO. 6         |
| DATE:              | MARCH 8, 2000        |

USEPA Method 6C

| RUN NO. | lbs. SO <sub>2</sub> /MM Btu |
|---------|------------------------------|
| 1       | 2.120                        |
|         |                              |
| 2       | 2.100                        |
|         |                              |
| 3       | 2.122                        |
|         |                              |

TEST AVERAGE: 2.114 lbs SO<sub>2</sub>/MM Btu

# COMPLIANCE TEST DATA

F. J. GANNON STATION

BOILER NO. 6 TEST DATE 3/8/00

UNIT LOAD (MW) 360 MW

BASE LOADED (TIME) 6:00 AM

**TEST DATA**

| MEGAWATTS INTEGRATOR   | INITIALS  |
|--|-----------|
| BEGIN MWH <u>738696</u> BEGIN SAMPLING <u>0815</u>               | <u>CB</u> |
| END MWH <del>740269</del> <u>740654</u> END SAMPLING <u>1341</u> | <u>CB</u> |

**SOOTBLOWING**

| RUN        | BEGIN TIME  | END TIME    | INITIALS        |
|------------|-------------|-------------|-----------------|
| <u>1SB</u> | <u>0815</u> | <u>—</u>    | <u>CB / JAF</u> |
| <u>2SB</u> | <u>0931</u> | <u>1036</u> | <u>CB / JAF</u> |
| <u>3SB</u> | <u>1104</u> | <u>1210</u> | <u>CB / JAF</u> |
| <u>4SB</u> | <u>1237</u> | <u>1341</u> | <u>CB / JAF</u> |

**FLYASH REINJECTION**

| RUN        | REINJECTION (Y/N) | % REINJECTION | INITIALS       |
|------------|-------------------|---------------|----------------|
| <u>1SB</u> | <u>yes</u>        | <u>100%</u>   | <u>CB / SM</u> |
| <u>2SB</u> | <u>yes</u>        | <u>100%</u>   | <u>CB / SM</u> |
| <u>3SB</u> | <u>yes</u>        | <u>100%</u>   | <u>CB / SM</u> |
| <u>4SB</u> | <u>yes</u>        | <u>100%</u>   | <u>CB / SM</u> |
|            |                   |               |                |
|            |                   |               |                |
|            |                   |               |                |
|            |                   |               |                |

**ATTACHEMENT 3**

FULL ELEMENTAL SPECIATION ANALYSIS OF FLY ASH AND  
SLAG

**Environmental Affairs  
Laboratory**

5012 Causeway Blvd \* Tampa Fl. 33619 \* Ph (813)630-7378 \* Fax (813)630-7360 \* CompQAP #910140G \* DOH

Report Raiza Calderon, EA-PSC

Report 12/14/2001

**Laboratory ID: AA63293**

**Sample**

|                              |                             |                |             |
|------------------------------|-----------------------------|----------------|-------------|
| <b>Location</b>              | <b>SPECL-EP</b>             | <b>Sampled</b> |             |
| <b>Location</b>              | Envir. Plan. Sample Request | <b>Date</b>    | 11/29/2001  |
| <b>Project Account</b>       | M73                         | <b>Time</b>    | 12:00:00 AM |
| GANNON STATION FLYASH        |                             |                |             |
| RESULT REPORTED AS DRY BASIS |                             |                |             |
| FL YASH                      |                             |                |             |

**Laboratory Results**

| <b>Parameter</b>                  | <b>Result</b> | <b>Units</b>   | <b>MDL</b> | <b>Lower Limit</b> | <b>Upper Limit</b> | <b>Violation Check</b> |
|-----------------------------------|---------------|----------------|------------|--------------------|--------------------|------------------------|
| 60 Mesh Residual Moisture, Flyash | 10.82         | %              |            |                    |                    |                        |
| Aluminum Oxide, Al2O3             | 20.5          | %              |            |                    |                    |                        |
| Calcium Oxide, CaO                | 2.6           | %              |            |                    |                    |                        |
| Iron Oxide, Fe2O3                 | 13.9          | %              |            |                    |                    |                        |
| Magnesium Oxide, MgO              | 1.3           | %              |            |                    |                    |                        |
| Mercury by Cold Vapor             | 0.306         | mg/kg          |            |                    |                    |                        |
| Phosphorus, P2O5                  | 0.4           | %              |            |                    |                    |                        |
| Potassium Oxide, K2O              | 2.4           | %              |            |                    |                    |                        |
| Silicon Dioxide, SiO2             | 50.0          | %              |            |                    |                    |                        |
| Sodium Oxide, Na2O                | 1.0           | %              |            |                    |                    |                        |
| Sulfur in Ash                     | 0.36          | %              | 0.01       |                    |                    |                        |
| Titanium Dioxide, TiO2            | 1.1           | %              |            |                    |                    |                        |
| Arsenic                           | 215.4         | ug/g dry basis |            |                    |                    |                        |
| Barium                            | 571.8         | ug/g dry basis |            |                    |                    |                        |
| Beryllium                         | 11.6          | ug/g dry basis |            |                    |                    |                        |
| Chromium                          | 299.2         | ug/g dry basis |            |                    |                    |                        |
| Cobalt                            | 53.9          | ug/g dry basis |            |                    |                    |                        |
| Copper                            | 97.2          | ug/g dry basis |            |                    |                    |                        |
| Lead                              | 214.4         | ug/g dry basis |            |                    |                    |                        |
| Manganese                         | 389.8         | ug/g dry basis |            |                    |                    |                        |
| Molybdenum                        | 26.3          | ug/g dry basis |            |                    |                    |                        |
| Nickel                            | 161.1         | ug/g dry basis |            |                    |                    |                        |
| Vanadium                          | 300.2         | ug/g dry basis |            |                    |                    |                        |
| Zinc                              | 316.4         | ug/g dry basis |            |                    |                    |                        |

**Environmental Affairs  
Laboratory**

5012 Causeway Blvd \* Tampa Fl. 33619 \* Ph (813)630-7378 \* Fax (813)630-7360 \* CompQAP #910140G \* DOH

**Comment**

Result reported as dry basis flyash.

Robert  
Manager, Environmental Services

**Environmental Affairs  
Laboratory**

5012 Causeway Blvd \* Tampa Fl. 33619 \* Ph (813)630-7378 \* Fax (813)630-7360 \* CompQAP #910140G \* DOH

Report Raiza Calderon, EA-PSC

Report 12/14/2001

**Laboratory ID: AA63294**

**Sample**

|                                   |                             |                |             |
|-----------------------------------|-----------------------------|----------------|-------------|
| <b>Location</b>                   | <b>SPECL-EP</b>             | <b>Sampled</b> |             |
| <b>Location</b>                   | Envir. Plan. Sample Request | <b>Date</b>    | 11/29/2001  |
| <b>Project Account</b>            | M73                         | <b>Time</b>    | 12:00:00 AM |
| GANNON STATION SLAG               |                             |                |             |
| RESULT REPORTED AS DRY BASIS SLAG |                             |                |             |

**Laboratory Results**

| <b>Parameter</b>                               | <b>Result</b> | <b>Units</b>   | <b>MDL</b> | <b>Lower<br/>Limit</b> | <b>Upper<br/>Limit</b> | <b>Violation<br/>Check</b> |
|--|---------------|----------------|------------|------------------------|------------------------|----------------------------|
| 60 Mesh Residual Moisture, Slag                | 1.94          | %              |            |                        |                        |                            |
| Aluminum Oxide, Al <sub>2</sub> O <sub>3</sub> | 21.1          | %              |            |                        |                        |                            |
| Calcium Oxide, CaO                             | 2.8           | %              |            |                        |                        |                            |
| Iron Oxide, Fe <sub>2</sub> O <sub>3</sub>     | 16.1          | %              |            |                        |                        |                            |
| Magnesium Oxide, MgO                           | 1.3           | %              |            |                        |                        |                            |
| Mercury by Cold Vapor                          | 0.063         | mg/kg          |            |                        |                        |                            |
| Phosphorus, P <sub>2</sub> O <sub>5</sub>      | 0.3           | %              |            |                        |                        |                            |
| Potassium Oxide, K <sub>2</sub> O              | 2.00          | %              |            |                        |                        |                            |
| Silicon Dioxide, SiO <sub>2</sub>              | 53.7          | %              |            |                        |                        |                            |
| Sodium Oxide, Na <sub>2</sub> O                | 0.7           | %              |            |                        |                        |                            |
| Sulfur in Ash                                  | 0.02          | %              | 0.01       |                        |                        |                            |
| Titanium Dioxide, TiO <sub>2</sub>             | 0.9           | %              |            |                        |                        |                            |
| Arsenic  | 8.1           | ug/g dry basis |            |                        |                        |                            |
| Barium   | 538.9         | ug/g dry basis |            |                        |                        |                            |
| Beryllium                                      | 7.9           | ug/g dry basis |            |                        |                        |                            |
| Chromium                                       | 164.1         | ug/g dry basis |            |                        |                        |                            |
| Cobalt   | 77.0          | ug/g dry basis |            |                        |                        |                            |
| Copper   | 39.3          | ug/g dry basis |            |                        |                        |                            |
| Lead   | 27.8          | ug/g dry basis |            |                        |                        |                            |
| Manganese                                      | 496.2         | ug/g dry basis |            |                        |                        |                            |
| Molybdenum                                     | 3.0           | ug/g dry basis |            |                        |                        |                            |
| Nickel   | 114.3         | ug/g dry basis |            |                        |                        |                            |
| Vanadium                                       | 206.8         | ug/g dry basis |            |                        |                        |                            |
| Zinc   | 74.2          | ug/g dry basis |            |                        |                        |                            |

**Environmental Affairs  
Laboratory**

5012 Causeway Blvd \* Tampa Fl. 33619 \* Ph (813)630-7378 \* Fax (813)630-7360 \* CompQAP #910140G \* DOH

**Comment**

Result reported as dry basis Slag

Robert  
Manager, Environmental Services



**ATTACHEMENT 4**

**BOILER PROCESS FLOW DIAGRAM WITH FLY ASH REINJECTION  
(TITLE V PERMIT APPLICATION (VOLUME II) - FIGURE II.D.3.6)**




FIGURE ILD.3.6.  
 F.J. GANNON STATION  
 BOILER PROCESS FLOW DIAGRAM  
 Source: ECT, 1996.

**LEGEND**

CS-00 EMISSION POINT

**ECT**  
 Environmental Consulting & Technology, Inc.

## ATTACHEMENT 5

TABLE 1. ESTIMATED PM10 EMISSIONS (PROPOSED NEW SOURCES)

TABLE 2. ESTIMATED PM EMISSIONS (PROPOSED NEW SOURCES)

**Table 1. Estimated PM<sub>10</sub> Emissions (Proposed New Sources)**

| EU ID         | Process Description                              | Reference to Flow Diag. | Emission Factors |        | Emission Factor Source | Operating Parameters |          |            |        | Potential PM <sub>10</sub> Emissions |              |
|---------------|--|-------------------------|------------------|--------|------------------------|----------------------|----------|------------|--------|--------------------------------------|--------------|
|               |  |                         | Factor           | Units  |                        | tpy                  | max. tph | max. hr/yr | VMT/yr | (tpy)                                | (lb/hr)      |
| AH006         | Truck Traffic on Paved Roads                     | Arrows                  | 0.4136           | lb/VMT | AP-42 13.2.1 (10/97)   | n/a                  | n/a      | n/a        | 691    | 0.1072                               | 0.0766       |
| AH007         | Unloading Byproducts to Misc. Pile               | 5                       | 0.0006           | lb/ton | AP-42, 13.2.4 (1/95)   | 36500                | 50       | 2912       | n/a    | 0.0115                               | 0.0314       |
| AH008         | Working with Misc. Pile                          | 5                       | 6.0762           | lb/VMT | AP-42, 13.2.2 (9/98)   | 36500                | 50       | 2912       | 183    | 0.5545                               | 0.3808       |
| AH009         | Wind Erosion from Misc. Pile                     | 5                       | n/a              | n/a    | AP-42, 13.2.5 (1/95)   | n/a                  | n/a      | n/a        | n/a    | 0.0021                               | 0.0007       |
| AH010         | Transfer from Misc. Pile to Screen               | 5 to 6                  | 0.0006           | lb/ton | AP-42, 13.2.4 (1/95)   | 36500                | 50       | 2912       | n/a    | 0.0011                               | 0.0031       |
| AH011         | Screening  | 6                       | 55.0             | lb/ton | AP-42, 11.8 (1/95)     | 36500                | 50       | 2912       | n/a    | 10.04                                | 27.50        |
| AH012         | Transfer from Screen to Temporary Pile           |                         | 0.0006           | lb/ton | AP-42, 13.2.4 (1/95)   | 36500                | 50       | 2912       | n/a    | 0.0011                               | 0.0031       |
| AH013         | Wind Erosion from Temporary Pile                 |                         | n/a              | n/a    | AP-42, 13.2.5 (1/95)   | n/a                  | n/a      | n/a        | n/a    | 0.0021                               | 0.0007       |
| AH014         | Transfer from Temp. Pile to Portable Conveyor    | 6 to 7                  | 0.0006           | lb/ton | AP-42, 13.2.4 (1/95)   | 36500                | 50       | 2912       | n/a    | 0.0011                               | 0.0031       |
| AH015         | Transfer from Portable Conveyor to "J" Conveyors | 7 to 8                  | 0.0006           | lb/ton | AP-42, 13.2.4 (1/95)   | 36500                | 50       | 2912       | n/a    | 0.0011                               | 0.0031       |
| <b>TOTALS</b> |  |                         |                  |        |                        |                      |          |            |        | <b>10.72</b>                         | <b>28.00</b> |

Note:

n/a = not applicable

Assumed PM<sub>10</sub>/PM = 0.5 for the screening emission factor

Applied a control efficiency of 90-99% for keeping the materials sufficiently wet (EPRI, 1984)

Applied a control efficiency of 25% to the uncontrolled truck traffic emissions for using precautions such as speed limits (AP-40)

tpy = tons per year, tph = tons per hour, lb = pounds, yr = year

hr = hours, VMT = vehicle miles traveled

PM = Particulate Matter, PM<sub>10</sub> = Particulate Matter Less than 10 micron in aerodynamic diameter

Sources: TECO, 2001; U.S. EPA, 1995-1998; ECT, 2001.

**Table 2. Estimated PM Emissions (Proposed New Sources)**

| EU ID         | Process Description                              | Reference to Flow Diag. | Emission Factors |        | Emission Factor Source | Operating Parameters |          |            |        | Potential PM Emissions |              |
|---------------|--|-------------------------|------------------|--------|------------------------|----------------------|----------|------------|--------|------------------------|--------------|
|               |  |                         | Factor           | Units  |                        | tpy                  | max. tph | max. hr/yr | VMT/yr | (tpy)                  | (lb/hr)      |
| AH006         | Truck Traffic on Paved Roads                     | Arrows                  | 2.1195           | lb/VMT | AP-42 13.2.1 (10/97)   | n/a                  | n/a      | n/a        | 691    | 0.5494                 | 0.3925       |
| AH007         | Unloading Byproducts to Misc. Pile               | 5                       | 0.0013           | lb/ton | AP-42, 13.2.4 (1/95)   | 36500                | 50       | 2912       | n/a    | 0.0243                 | 0.0664       |
| AH008         | Working with Misc. Pile                          | 5                       | 23.37            | lb/VMT | AP-42, 13.2.2 (9/98)   | 36500                | 50       | 2912       | 183    | 2.1325                 | 1.4646       |
| AH009         | Wind Erosion from Misc. Pile                     | 5                       | n/a              | n/a    | AP-42, 13.2.5 (1/95)   | n/a                  | n/a      | n/a        | n/a    | 0.0042                 | 0.0014       |
| AH010         | Transfer from Misc. Pile to Screen               | 5 to 6                  | 0.0013           | lb/ton | AP-42, 13.2.4 (1/95)   | 36500                | 50       | 2912       | n/a    | 0.0024                 | 0.0066       |
| AH011         | Screening  | 6                       | 110.0            | lb/ton | AP-42, 11.8 (1/95)     | 36500                | 50       | 2912       | n/a    | 20.0750                | 55.00        |
| AH012         | Transfer from Screen to Temporary Pile           |                         | 0.0013           | lb/ton | AP-42, 13.2.4 (1/95)   | 36500                | 50       | 2912       | n/a    | 0.0024                 | 0.0066       |
| AH013         | Wind Erosion from Temporary Pile                 |                         | n/a              | n/a    | AP-42, 13.2.5 (1/95)   | n/a                  | n/a      | n/a        | n/a    | 0.0042                 | 0.0014       |
| AH014         | Transfer from Temp. Pile to Portable Conveyor    | 6 to 7                  | 0.0013           | lb/ton | AP-42, 13.2.4 (1/95)   | 36500                | 50       | 2912       | n/a    | 0.0024                 | 0.0066       |
| AH015         | Transfer from Portable Conveyor to "J" Conveyors | 7 to 8                  | 0.0013           | lb/ton | AP-42, 13.2.4 (1/95)   | 36500                | 50       | 2912       | n/a    | 0.0024                 | 0.0066       |
| <b>TOTALS</b> |  |                         |                  |        |                        |                      |          |            |        | <b>22.80</b>           | <b>56.95</b> |

Note:

n/a = not applicable

Applied a control efficiency of 90-99% for keeping the materials sufficiently wet (EPRI, 1984)

Applied a control efficiency of 25% to the uncontrolled truck traffic emissions for using precautions such as speed limits (AP-40)

tpy = tons per year, tph = tons per hour, lb = pounds, yr = year

hr = hours, VMT = vehicle miles traveled

PM = Particulate Matter, PM10 = Particulate Matter Less than 10 micron in aerodynamic diameter

Sources: TECO, 2001; U.S. EPA, 1995-1998; ECT, 2001.

**ATTACHEMENT 6**

EMISSION FACTOR DERIVATION BASED ON AVAILABLE DATA  
(TEC-GANNON, BYPRODUCT BENEFICIATION PROJECT)

### Emission Factor Derivation Based on Available Data (TEC-Gannon, Byproduct Beneficiation Project)

| Source   | Reference       | Material      | Process                                 | PM | PM-10 | EF (lb/ton) |              | Control Type  | Assumed EF (%) | EF Rating |
|----------|-----------------|---------------|---|----|-------|-------------|--------------|---------------|----------------|-----------|
|          |                 |               |   |    |       | Controlled  | Uncontrolled |               |                |           |
| AP-42    | Table 11.17-4   | Lime          | Primary Screening                       | x  |       | 0.00061     |              | Fabric Filter |                | D         |
| AP-42    | Table 11.17-4   | Lime          | Scalping Screen and Hammermill          | x  |       |             | 0.62         |               |                | E         |
| AP-42    | Table 11.17-4   | Lime          | Product Loading (Open Truck)            | x  |       |             | 1.5          |               |                | D         |
| AP-42    | Table 11.26-1   | Talc          | Screening                               | x  |       | 0.0086      |              | Fabric Filter |                | D         |
| AP-42    | Table 11.12-2   | Cement        | Loading/Unloading                       | x  |       |             | 0.145        |               |                | D-E       |
| AP-42    | Table 11.19.2-1 | Crushed Stone | Fines Screening                         |    | x     | 0.00441     | 0.1491       | Baghouse      | 97.0%          | E         |
| AP-42    | Table 11.19.2-1 | Crushed Stone | Fines Screening                         | x  |       | 0.00926     | 0.3131       |               |                |           |
| AP-42    | Table 11.8-2    | Fly Ash       | Crushing, Screening, Sintering, Storage | x  |       |             | 110          |               |                | E         |
| EPRI     | Table 3-23      | Fly Ash       | Handling                                | x  |       |             | 66           |               | up to 100%     | E         |
| EPRI     | Table 3-23      | Fly Ash       | Handling                                | x  |       |             | 110          |               | up to 100%     | E         |
| TECO/ECT |                 | Fly Ash/Slag  | Handling                                | x  |       | 1.1         | 110          | Wetness       | 99.0%          |           |
|          |                 | Fly Ash/Slag  | Handling                                |    | x     | 0.55        | 55           | Wetness       | 99.0%          |           |

**ATTACHEMENT 7**

PROFESSIONAL ENGINEER CERTIFICATION



**TAMPA ELECTRIC COMPANY  
FJ GANNON STATION  
BYPRODUCT BENEFICIATION AND RE-USE**

**Professional Engineer Certification**

Professional Engineer Statement:

*I, the undersigned, hereby certify, except as particularly noted herein\*, that:*


*(1) To the best of my knowledge, there is reasonable assurance that the air pollutant emissions unit(s) and the air pollutant control equipment described in this Application for Air Permit, when properly operated and maintained, will comply with all applicable standards for control of air pollutant emissions found in the Florida Statutes and rules of the Department of Environmental Protection; and*

*(2) To the best of my knowledge, any modifications to the emission estimates reported or relied on in this application are true, accurate, and complete and are either based upon reasonable techniques available for calculating emissions or, for emission estimates of air pollutants not regulated for an emissions unit, based solely upon the materials, information and calculations provided with this certification.*

Signature

Date

*12/19/2001*



\* Certification is applicable to the non-PSD permit application request for the Tampa Electric Company FJ Gannon Station byproduct, beneficiation and re-use process.

**ATTACHEMENT 8**

RESPONSIBLE OFFICIAL CERTIFICATION

**Responsible Official Certification**

I have reviewed the testing results in this report, and hereby certify that this test report is authentic and accurate to the best of my knowledge.

Date 12-20-01

Signature Karen A. Sheffield  
General Manager  
FJ Gannon Power Station