



LGM ENGINEERS CONSTRUCTORS

E-85-100

March 11, 1986

DER

MAR 18 1986

BAQM

Department of Environmental Regulation
Bureau of Air Quality Management
2600 Blair Stone Road
Tallahassee, FL 32301

ATTENTION: Clair Fancy, P.E.
Deputy Bureau Chief

SUBJECT: Application to Construct Air Pollution Sources,
Lake County Waste to Energy Facility

Gentlemen:

NRG/Recovery Group proposes to construct a 500 ton per day municipal solid waste energy recovery facility in Lake County, Florida.

We submit herewith the subject application and supporting documents for your consideration on behalf of NRG/Recovery Group, applicant. Enclosed is a check in the amount of \$1000.00 to cover the application processing fee.

We have worked closely with your staff during design of the facility and preparation of the application, and we believe the facility meets Florida DER criteria.

The funding for this project is contingent on meeting a fast-track schedule. We would appreciate your expeditious review of this permit application. Should you or your staff require any additional information or have any questions regarding this application, please let us know.

Thank you for your continued assistance.

Yours truly,

Robert Mayfield
Manager, Energy Division

RM:BC:jdm

PREVENTION OF SIGNIFICANT DETERIORATION
PERMIT APPLICATION
FOR THE PROPOSED
NRG/RECOVERY GROUP
LAKE COUNTY WASTE TO ENERGY FACILITY
AT LAKE COUNTY, FLORIDA

Submitted by:

NRG/Recovery Group
1616 Athens Street
Lakeland, Florida 33803

Prepared by:

LGM Engineers Constructors
1330 West Peachtree Street
Atlanta, Georgia 30367

Job No. E-85-100
March 11, 1986

NIRG/Recovery Group, Inc.

**LAKE COUNTY
WASTE TO ENERGY FACILITY**

**Application to Construct
Air Pollution Sources**

LGM

LGM ENGINEERS CONSTRUCTORS

CONTENTS

TABLE OF CONTENTS

| <u>TAB</u> | | <u>PAGE</u> |
|------------|--|-------------|
| 1. | FLORIDA DER APPLICATION FOR PERMIT TO CONSTRUCT | |
| 2. | PREVENTION OF SIGNIFICANT DETRIORATION REPORT | |
| 1.0 | INTRODUCTION | 1 |
| 2.0 | PROJECT DESCRIPTION | 3 |
| 2.1 | General | 3 |
| 2.2 | Site Description | 3 |
| 2.3 | Process Description | 6 |
| 2.4 | Emission Sources and Controls | 10 |
| 2.5 | Project Schedule | 15 |
| 2.6 | Operating Schedule | 15 |
| 3.0 | PROJECT EMISSION SOURCE INFORMATION | 16 |
| 3.1 | Emission Sources and Emission Rates | 16 |
| 3.2 | Derivation of Emission Rate | 20 |
| 3.3 | Stack Height | 25 |
| 4.0 | APPLICABLE REGULATIONS | 27 |
| 4.1 | Applicable Pollutants | 27 |
| 4.2 | Ambient Air Quality Impact Analysis Requirements | 27 |
| 4.3 | Emission Limits and Performance Standards | 29 |
| 4.4 | Preconstruction Monitoring Requirements | 30 |
| 5.0 | BEST AVAILABLE CONTROL TECHNOLOGY ANALYSIS | 31 |
| 5.1 | Pollutants and Emission Sources Requiring BACT Analysis | 31 |
| 5.2 | Comparative Analysis of Alternative Flue gas Treatment Technology | 31 |
| 5.3 | BACT for Sulfur Dioxide | 33 |
| 5.4 | BACT for Nitrogen Oxides | 37 |
| 5.5 | BACT for Particulate Matter | 37 |
| 5.6 | BACT for Carbon Monoxide | 38 |
| 5.7 | BACT for Lead, Mercury and Fluorides | 38 |

| | | |
|-----|---|----|
| 6.0 | EXISTING AIR QUALITY CONDITIONS | 39 |
| 6.1 | Other Emission Sources | 39 |
| 6.2 | Existing Air Quality | 40 |
| 6.3 | PSD Class 1 and Non attainment Areas | 40 |
| 7.0 | MODELING METHODOLOGY | 41 |
| 7.1 | Dispersion Model | 41 |
| 7.2 | Meteorological Data | 41 |
| 7.3 | Receptor Grids | 42 |
| 7.4 | Other Modeling Considerations | 42 |
| 7.5 | Modeling Results | 43 |
| | 7.5.1 Maximum Facility Impact and Significant Impact Area | 43 |
| | 7.5.2 Compliance with PSD Class II Increments | 48 |
| | 7.5.3 Compliance with PSD Class I Increments | 49 |
| | 7.5.4 Compliance with Ambient Air Quality Standards | 49 |
| | 7.5.5 Preconstruction Ambient Monitoring Exemption | 50 |
| | 7.5.6 Impact of Hydrogen Chloride (HCl) Emissions | 52 |
| 8.0 | ADDITIONAL IMPACT ANALYSIS | 54 |
| 8.1 | Visibility Effect | 54 |
| 8.2 | Vegetation and Soils Effects | 54 |
| 8.3 | Air Quality Impact of Project Related Growth | 56 |
| 9.0 | REFERENCES | 58 |

APPENDIX

| | |
|------------|---------------------------------------|
| APPENDIX A | Computer Printout of Modeling Results |
| APPENDIX B | BACT/LAER Clearinghouse Report |

LIST OF TABLES

| <u>TABLE NUMBER</u> | <u>TITLE</u> | <u>PAGE</u> |
|-------------------------|---|-------------|
| 3-1 | Summary of controlled Potential Emission Rates from the Proposed NRG Waste to Energy Facility. | 17 |
| 3-2 | Stack Parameters for NRG Units No. 1 and No. 2. | 18 |
| 3-3 | Source Applicability Determination. | 19 |
| 4-1 | Applicable Ambient Air Quality Limits and Significant Impact Levels. | 28 |
| 5-1 | Summary of Proposed BACT Emission Limitations and Control Technologies for Lake County Waste to Energy Facility. | 32 |
| 5-2 | Capital and O & M Costs for Alternative Pollution Control Strategies. | 34 |
| 5-3 | Pollutant Reduction and Economic Comparison of Pollution Control Alternatives. | 35 |
| 7-1 | Summary of Maximum Predicted Radii of Significant Impact for SO ₂ Resulting from the Operation of the Proposed NRG Waste to Energy Facility. | 45 |
| 7-2 | Summary of Maximum Predicted SO ₂ Concentrations Attributable to the Operation of the Proposed NRG Waste to Energy Facility. | 47 |
| 7-3 | Comparison of Maximum Possible SO ₂ Concentrations with NAAQS in the vicinity of the Proposed NRG Waste to Energy Facility. | 51 |

LIST OF FIGURES

| <u>Figure Number</u> | <u>Title</u> | <u>Page</u> |
|--------------------------|-----------------------------------|-------------|
| 1 | Site Location | 4 |
| 2 | Site Plan | 5 |
| 3 | Fuel Air Combustion Flow Diagram | 7 |
| 4 | Ash System Flow Diagram | 8 |
| 5 | Steam, Water and Air Flow Diagram | 9 |

ONE

FLORIDA DEPARTMENT OF ENVIRONMENTAL REGULATION
APPLICATION FOR PERMIT TO CONSTRUCT


FOR

NRG/RECOVERY GROUP
LAKE COUNTY WASTE TO ENERGY FACILITY
AT LAKE COUNTY, FLORIDA

MARCH 11, 1986

DEPARTMENT OF ENVIRONMENTAL REGULATION

TWIN TOWERS OFFICE BUILDING
2500 BLAIR STONE ROAD
TALLAHASSEE, FLORIDA 32301-8241



DER

MAR 18 1986

BOB GRAHAM
GOVERNORVICTORIA J. TSCHINKEL
SECRETARY

BAOM

APPLICATION TO OPERATE/CONSTRUCT AIR POLLUTION SOURCES

SOURCE TYPE: Waste-to-Energy Facility [X] New¹ [] Existing¹

APPLICATION TYPE: [X] Construction [] Operation [] Modification

COMPANY NAME: Lake County Waste to Energy Facility COUNTY: LakeIdentify the specific emission point source(s) addressed in this application (i.e. Lime
Kiln No. 4 with Venturi Scrubber; Peaking Unit No. 2, Gas Fired) WTE Unit No. 1 and No. 2SOURCE LOCATION: Street Jim Rogers Road City OkahumpkaUTM: East 413.12 km North 3179.26 kmLatitude 28 ° 44 ' 22 "N Longitude 81 ° 53 ' 23 "WAPPLICANT NAME AND TITLE: NRG/Recovery Group (owner)APPLICANT ADDRESS: 1616 Athens Street, Lakeland, Florida 33803

SECTION I: STATEMENTS BY APPLICANT AND ENGINEER

A. APPLICANT

I am the undersigned owner or authorized representative* of NRG/Recovery Group

I certify that the statements made in this application for a construction permit are true, correct and complete to the best of my knowledge and belief. Further, I agree to maintain and operate the pollution control source and pollution control facilities in such a manner as to comply with the provision of Chapter 403, Florida Statutes, and all the rules and regulations of the department and revisions thereof. I also understand that a permit, if granted by the department, will be non-transferable and I will promptly notify the department upon sale or legal transfer of the permitted establishment.

*Attach letter of authorization

Signed: Walt WaltersWalt Walters, President
Name and Title (Please Type)Date: 3/11/86 Telephone No. (813) 687-4593

B. PROFESSIONAL ENGINEER REGISTERED IN FLORIDA (where required by Chapter 471, F.S.)

This is to certify that the engineering features of this pollution control project have been designed/examined by me and found to be in conformity with modern engineering principles applicable to the treatment and disposal of pollutants characterized in the permit application. There is reasonable assurance, in my professional judgment, that

¹ See Florida Administrative Code Rule 17-2.100(57) and (104)

the pollution control facilities, when properly maintained and operated, will discharge an effluent that complies with all applicable statutes of the State of Florida and the rules and regulations of the department. It is also agreed that the undersigned will furnish, if authorized by the owner, the applicant a set of instructions for the proper maintenance and operation of the pollution control facilities and, if applicable, pollution sources.



Signed C. P. Nichols

C. P. Nichols

Name (Please Type)

Lockwood Greene Engineers, Inc.

Company Name (Please Type)

1330 W. Peachtree Street, Atlanta, GA 30367

Mailing Address (Please Type)

Florida Registration No. 30845 Date: 3/11/86 Telephone No. (404) 873-3261

SECTION II: GENERAL PROJECT INFORMATION

A. Describe the nature and extent of the project. Refer to pollution control equipment, and expected improvements in source performance as a result of installation. State whether the project will result in full compliance. Attach additional sheet if necessary.

The Lake County Waste to Energy Facility proposes to install a new municipal solid waste (MSW) conversion facility with capacity to burn 500 tons/day to generate steam and electric power. Two incinerator/boilers will be installed each having 250 tons/day capacity. Discharge is to one stack. (see attached description)

B. Schedule of project covered in this application (Construction Permit Application Only)

Start of Construction July 1986 Completion of Construction December 1987

C. Costs of pollution control system(s): (Note: Show breakdown of estimated costs only for individual components/units of the project serving pollution control purposes. Information on actual costs shall be furnished with the application for operation permit.)

Electrostatic Precipitator and associated equipment and erection

\$2,080,000.

D. Indicate any previous DER permits, orders and notices associated with the emission point, including permit issuance and expiration dates.

None.

Requested permitted equipment operating time: hrs/day 24 ; days/wk 7 ; wks/yr 52 ;
if power plant, hrs/yr _____; if seasonal, describe: Not seasonal.

If this is a new source or major modification, answer the following questions.
(Yes or No)

1. Is this source in a non-attainment area for a particular pollutant? No.
a. If yes, has "offset" been applied? _____
b. If yes, has "Lowest Achievable Emission Rate" been applied? _____
c. If yes, list non-attainment pollutants. _____

2. Does best available control technology (BACT) apply to this source?
If yes, see Section VI. Yes

3. Does the State "Prevention of Significant Deterioration" (PSD)
requirement apply to this source? If yes, see Sections VI and VII. Yes

4. Do "Standards of Performance for New Stationary Sources" (NSPS)
apply to this source? Yes

5. Do "National Emission Standards for Hazardous Air Pollutants"
(NESHAP) apply to this source? No.

Do "Reasonably Available Control Technology" (RACT) requirements apply
to this source? No.

- a. If yes, for what pollutants? _____
b. If yes, in addition to the information required in this form,
any information requested in Rule 17-2.650 must be submitted.

Attach all supportive information related to any answer of "Yes". Attach any justifi-
cation for any answer of "No" that might be considered questionable.

Supportive information is attached.

SECTION III: AIR POLLUTION SOURCES & CONTROL DEVICES (Other than Incinerators)

A. Raw Materials and Chemicals Used in your Process, if applicable:

Municipal solid waste; see subsection E. Fuels.

| Description | Contaminants | | Utilization Rate - lbs/hr | Relate to Flow Diagram |
|-------------|--------------|------|---------------------------|------------------------|
| | Type | % Wt | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

B. Process Rate, if applicable: (See Section V, Item 1) Not Applicable.

- Total Process Input Rate (lbs/hr): _____
- Product Weight (lbs/hr): _____

C. Airborne Contaminants Emitted: (Information in this table must be submitted for each emission point, use additional sheets as necessary)

| Name of Contaminant | Emission ¹ | | Allowed Emission Rate per Rule 17-2 | Allowable ³ Emission lbs/hr | Potential ⁴ Emission | | Relate to Flow Diagram |
|---------------------|-----------------------|-------------|-------------------------------------|--|---------------------------------|------|------------------------|
| | Maximum lbs/hr | Actual T/yr | | | units = lbs/hr | T/yr | |
| Particulate | 13.76 | 60 | 0.10 lb./10 ⁶ BTU* | 20.8 | 830+ | 3650 | |
| Sulfur Dioxide | 125 | 547 | NA | NA | 125 | 547 | |
| NO _x | 104 | 455 | NA | NA | 104 | 455 | |
| CO | 93 | 102 | NA | NA | 93 | 102 | |
| Pb | 0.25 | 1.1 | | | 6.25 | 27 | |

* proposed 40CFR60 Subpart Db.

¹See Section V, Item 2.

²Reference applicable emission standards and units (e.g. Rule 17-2.600(5)(b)2. Table II, E. (1) - 0.1 pounds per million BTU heat input)

³Calculated from operating rate and applicable standard.

⁴Emission, if source operated without control (See Section V, Item 3).

Control Devices: (See Section V, Item 4)

| Name and Type (Model & Serial No.) | Contaminant | Efficiency (%) | Range of Particles Size Collected (in microns) (If applicable) | Basis for Efficiency (Section V Item 5) |
|---------------------------------------|-------------|-------------------|---|--|
| ESP | Particulate | 98.5 + | | Vendor Experience |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

Fuels

| Type (Be Specific) | Consumption* | | Maximum Heat Input (MMBTU/hr) |
|-----------------------|---------------|---------------|--|
| | avg/hr | max./hr | |
| Municipal solid waste | 35,000 lb./hr | 41,667 lb./hr | 208 (104 x 10 ⁶ BTU/hr. each) |
| Wood chips | | 11,500 | 50 (supplement MSW up to unit capacity) |
| | | | |
| | | | |

*Units: Natural Gas--MMCF/hr; Fuel Oils--gallons/hr; Coal, wood, refuse, other--lbs/hr.

Fuel Analysis: Design MSW

Percent Sulfur: 0.3 Percent Ash: 20.1
 Density: _____ lbs/gal Typical Percent Nitrogen: 0.8
 Heat Capacity: 5000 BTU/lb _____ BTU/gal
 Other Fuel Contaminants (which may cause air pollution): Chlorine

F. If applicable, indicate the percent of fuel used for space heating. Not Applicable.

Annual Average _____ Maximum _____

G. Indicate liquid or solid wastes generated and method of disposal.

Grate ash and flyash are wetted and mixed to prevent fugitive dust and disposed of in the Astatula landfill. Noncontact cooling water and boiler system blowdown is disposed of by percolation ponds.

H. Emission Stack Geometry and Flow Characteristics (Provide data for each stack):

Stack Height: 125 ft. Stack Diameter: 6' effective ft.
 Gas Flow Rate: 111,200 ACFM 53500 DSCFM Gas Exit Temperature: 350°(a) °F.
 Water Vapor Content: 9 % Velocity: 66 FPS

(a.) Lowest estimate for vendor equipment under consideration.

SECTION IV: INCINERATOR INFORMATION

| Type of Waste | Type 0 (Plastics) | Type I (Rubbish) * | Type II (Refuse) * | Type III (Garbage) * | Type IV (Pathological) ** | Type V (Liq. & Gas By-prod.) | Type VI (Solid By-prod.) |
|--------------------------|-------------------|---|-----------------------|-------------------------|--|------------------------------|--------------------------|
| Actual lb/hr Incinerated | | * Facility capacity is a total of 20.83 tons/hr. of Type I, II and III. | | | ** Type IV to be incinerated only with the specific approval of Fla. DER and in accordance with approved procedures. | | |
| Uncontrolled (lbs/hr) | SEE | III | | | | | |

Description of Waste Residential and commercial municipal solid waste.

Total Weight Incinerated (lbs/hr) 41,666 Design Capacity (lbs/hr) 41,666

Approximate Number of Hours of Operation per day 24 day/wk 7 wks/yr. 52

Manufacturer to be determined.

Date Constructed 7/86 to 12/87 Model No. to be determined

| Each Unit | Volume (ft) ³ | Heat Release (BTU/hr) | Fuel | | Temperature (°F) |
|------------------------------|--------------------------|-----------------------|------|-----------------------|------------------|
| | | | Type | BTU/hr | |
| Primary Chamber | 10,000 + | 104 x 10 ⁶ | MSW | 104 X 10 ⁶ | 1800° 1 sec. + |
| Secondary Chamber | | | | | 1500° 3 sec. |

Stack Height: 125 ft. Stack Diameter: 6' effective Stack Temp. 350°F

Gas Flow Rate: 111,200 ACFM 53500 @ 12% CO₂ DSCFM* Velocity: 66 FPS

*If 50 or more tons per day design capacity, submit the emissions rate in grains per standard cubic foot dry gas corrected to 50% excess air.

Type of pollution control device: Cyclone Wet Scrubber Afterburner

Other (specify) ESP

Brief description of operating characteristics of control devices: _____

Three field dry electrostatic precipitator, rigid frame type, guaranteed
emission rate less than 0.03 grains particulate/dscf corrected to 12% CO₂.

Ultimate disposal of any effluent other than that emitted from the stack (scrubber water, ash, etc.):

See Section 8.

NOTE: Items 2, 3, 4, 6, 7, 8, and 10 in Section V must be included where applicable.

SECTION V: SUPPLEMENTAL REQUIREMENTS

Please provide the following supplements where required for this application.

1. Total process input rate and product weight -- show derivation [Rule 17-2.100(127)] N/A
2. To a construction application, attach basis of emission estimate (e.g., design calculations, design drawings, pertinent manufacturer's test data, etc.) and attach proposed methods (e.g., FR Part 60 Methods 1, 2, 3, 4, 5) to show proof of compliance with applicable standards. To an operation application, attach test results or methods used to show proof of compliance. Information provided when applying for an operation permit from a construction permit shall be indicative of the time at which the test was made.
3. Attach basis of potential discharge (e.g., emission factor, that is, AP42 test).
4. With construction permit application, include design details for all air pollution control systems (e.g., for baghouse include cloth to air ratio; for scrubber include cross-section sketch, design pressure drop, etc.)
5. With construction permit application, attach derivation of control device(s) efficiency. Include test or design data. Items 2, 3 and 5 should be consistent: actual emissions = potential (1-efficiency).
6. An 8 1/2" x 11" flow diagram which will, without revealing trade secrets, identify the individual operations and/or processes. Indicate where raw materials enter, where solid and liquid waste exit, where gaseous emissions and/or airborne particles are evolved and where finished products are obtained.
7. An 8 1/2" x 11" plot plan showing the location of the establishment, and points of airborne emissions, in relation to the surrounding area, residences and other permanent structures and roadways (Example: Copy of relevant portion of USGS topographic map).
8. An 8 1/2" x 11" plot plan of facility showing the location of manufacturing processes and outlets for airborne emissions. Relate all flows to the flow diagram.

9. The appropriate application fee in accordance with Rule 17-4.05. The check should be made payable to the Department of Environmental Regulation.
10. With an application for operation permit, attach a Certificate of Completion of Construction indicating that the source was constructed as shown in the construction permit.

SECTION VI: BEST AVAILABLE CONTROL TECHNOLOGY

- A. Are standards of performance for new stationary sources pursuant to 40 C.F.R. Part 60 applicable to the source?
- Yes No See PSD report.

| Contaminant | Rate or Concentration |
|-------------|--|
| Particulate | 0.08 grains/dscf (Subpart E) |
| Particulate | 0.10 lb./million BTU input (Subpart Db-proposed) |
| | |
| | |

- B. Has EPA declared the best available control technology for this class of sources (If yes, attach copy)
- Yes No See PSD report, BACT/LAER Compilation

| Contaminant | Rate or Concentration |
|-----------------|----------------------------|
| Particulate | 0.02 to 0.05 gr/dscf |
| Sulfur Dioxide | 0.2 to 1.3 lb./million BTU |
| Nitrogen Oxides | 0.3 to 0.7 lb./million BTU |
| | |

- C. What emission levels do you propose as best available control technology?

| Contaminant | See PSD report | Rate or Concentration |
|-----------------|----------------|---|
| Particulate | | 0.03 gr/dscf corrected to 12% CO ₂ |
| Particulate | | 0.067 lb./million BTU |
| Sulfur Dioxide | | 0.6 lb./million BTU |
| Nitrogen Oxides | | 0.5 lb./million BTU |

- D. Describe the existing control and treatment technology (if any).
- | | |
|-------------------------------|---|
| 1. Control Device/System: ESP | 2. Operating Principles: Electrostatic charge |
| 3. Efficiency: * 98.5 | 4. Capital Costs: \$2,080,000 |

*Explain method of determining

5. Useful Life: 20 years +

6. Operating Costs: \$65,000/yr.

7. Energy: 50 kwh

8. Maintenance Cost: \$42,000/yr.

9. Emissions:

Contaminant

Rate or Concentration

Particulate

0.03 gr./dscf corrected to 12% CO₂

10. Stack Parameters

- a. Height: 125 ft.
- b. Diameter: effective 6 ft.
- c. Flow Rate: 111,200 ACFM
- d. Temperature: 350 °F.
- e. Velocity: 66 FPS

E. Describe the control and treatment technology available (As many types as applicable, use additional pages if necessary).

1. See above.

- a. Control Device: ESP
- b. Operating Principles:
- c. Efficiency:¹
- d. Capital Cost:
- e. Useful Life:
- f. Operating Cost:
- g. Energy:²
- h. Maintenance Cost:
- i. Availability of construction materials and process chemicals:
- j. Applicability to manufacturing processes:
- k. Ability to construct with control device, install in available space, and operate within proposed levels:

2.

- a. Control Device:
- b. Operating Principles:
- c. Efficiency:¹
- d. Capital Cost:
- e. Useful Life:
- f. Operating Cost:
- g. Energy:²
- h. Maintenance Cost:
- i. Availability of construction materials and process chemicals:

Explain method of determining efficiency.

Energy to be reported in units of electrical power - KWH design rate.

- j. Applicability to manufacturing processes:
- k. Ability to construct with control device, install in available space, and operate within proposed levels:

3.

- a. Control Device:
- b. Operating Principles:
- c. Efficiency:¹
- d. Capital Cost:
- e. Useful Life:
- f. Operating Cost:
- g. Energy:²
- h. Maintenance Cost:
- i. Availability of construction materials and process chemicals:
- j. Applicability to manufacturing processes:
- k. Ability to construct with control device, install in available space, and operate within proposed levels:

4.

- a. Control Device:
- b. Operating Principles:
- c. Efficiency:¹
- d. Capital Costs:
- e. Useful Life:
- f. Operating Cost:
- g. Energy:²
- h. Maintenance Cost:
- i. Availability of construction materials and process chemicals:
- j. Applicability to manufacturing processes:
- k. Ability to construct with control device, install in available space, and operate within proposed levels:

F. Describe the control technology selected: See above

- 1. Control Device: ESP
- 2. Efficiency:¹
- 3. Capital Cost:
- 4. Useful Life:
- 5. Operating Cost:
- 6. Energy:²
- 7. Maintenance Cost:
- 8. Manufacturer:
- 9. Other locations where employed on similar processes:
- a. (1) Company: Pinellas County
- (2) Mailing Address: Solid Waste Management, Pinellas County.
- (3) City:
- (4) State: Florida

¹Explain method of determining efficiency.

²Energy to be reported in units of electrical power - KWH design rate.

(5) Environmental Manager: Bob Van Deman

(6) Telephone No.: (813) 825-1565

(7) Emissions:¹

Contaminant

Rate or Concentration

Particulate

<0.03 gr/dscf corrected to 12% CO₂

(8) Process Rate:¹

b. (1) Company:

(2) Mailing Address:

(3) City:

(4) State:

(5) Environmental Manager:

(6) Telephone No.:

(7) Emissions:¹

Contaminant

Rate or Concentration

(8) Process Rate:¹

10. Reason for selection and description of systems:

Applicant must provide this information when available. Should this information not be available, applicant must state the reason(s) why.

SECTION VII - PREVENTION OF SIGNIFICANT DETERIORATION

A. Company Monitored Data None

1. _____ no. sites _____ TSP _____ () SO₂* _____ Wind spd/dir

Period of Monitoring _____ / _____ / _____ to _____ / _____ / _____
month day year month day year

Other data recorded Refer to PSD permit application report for discussion on ambient monitoring exemption.

Attach all data or statistical summaries to this application.

*Specify bubbler (B) or continuous (C).

2. Instrumentation, Field and Laboratory

- a. Was instrumentation EPA referenced or its equivalent? [] Yes [] No
b. Was instrumentation calibrated in accordance with Department procedures?
[] Yes [] No [] Unknown

B. Meteorological Data Used for Air Quality Modeling

1. 5 Year(s) of data from 01 / 01 / 74 to 12 / 31 / 78
month day year month day year
2. Surface data obtained from (location) Orlando, Florida
3. Upper air (mixing height) data obtained from (location) Tampa, Florida
4. Stability wind rose (STAR) data obtained from (location) N/A

C. Computer Models Used

1. ISCST - modified to include Modified? If yes, attach description.
2. EPA calm wind Modified? If yes, attach description.
3. adjustment method Modified? If yes, attach description.
4. _____ Modified? If yes, attach description.

Attach copies of all final model runs showing input data, receptor locations, and principle output tables.

D. Applicant's Maximum Allowable Emission Data

| Pollutant | Emission Rate |
|-----------------|------------------------|
| TSP | <u>1.735</u> grams/sec |
| SO ₂ | <u>15.8</u> grams/sec |

E. Emission Data Used in Modeling See attached PSD report.

Attach list of emission sources. Emission data required is source name, description of point source (on NEDS point number), UTM coordinates, stack data, allowable emissions, and normal operating time.

F. Attach all other information supportive to the PSD review.

G. Discuss the social and economic impact of the selected technology versus other applicable technologies (i.e., jobs, payroll, production, taxes, energy, etc.). Include assessment of the environmental impact of the sources.

H. Attach scientific, engineering, and technical material, reports, publications, journals, and other competent relevant information describing the theory and application of the requested best available control technology.

FACILITY DESCRIPTION

The overall facility will be designed for the efficient receipt, handling and combustion of municipal solid waste for the generation of steam and power and for the disposal of ash residues. Within this overall purpose, the following items are pertinent:

- Fuel Handling Equipment
- Steam Generation Equipment
- Power Generation
- Environmental Systems
- Structures
- Sitework

Each of these items are discussed in the following sections.

FUEL HANDLING EQUIPMENT

Waste will be received from municipal and/or contractor trucks principally on a five day week basis. An above ground 60 ton truck scale (70 feet long) is provided in the access road to the unloading area. The scale is remote monitored, with weight data recorded by camera.

The trucks will be routed to a waste pit provided with multiple unloading bays. The waste will be dumped in the pit which has approximately four days storage volume (1,800 tons). Two overhead cranes provided with grapple feeders will service this area for distribution of the waste to the combustion equipment. Either crane will be capable of servicing the design throughput of the facility while the other crane is being maintained. A single crane operating room will be provided high in the building, with complete visibility of the waste pit to allow for control of either crane. Each crane has a capacity of $7\frac{1}{2}$ tons.

STEAM GENERATION EQUIPMENT

Waste will be distributed to two boilers for combustion and generation of steam. The combustion system for each boiler will consist of a waste hopper, hydraulic ram feeder and reciprocating grates. Waste will be fed into the furnace by the hydraulic ram feeder which responds to steam load requirements. The combustion process is further controlled by modulating the reciprocating grates and the undergrate combustion air. Negative furnace pressure will be controlled by modulating the inlet dampers to the induced draft fan. An overfire air system will be used to provide turbulence throughout the lower section of the furnace resulting in optimum combustion. Both the undergrate air and the overfire air fans will take suction from the waste pit area to aid in ventilation and provide odor control.

Steam will be generated in two natural circulation boilers with water cooled furnace walls. The units will be designed to operate at 625 PSIG/750°F at superheater outlet. They shall each have the capability of handling 250 tons MSW per day. The steam generation system will include an economizer, boiler and superheater. Furnace volume and gas path areas will be liberally sized for proper combustion of the municipal solid waste with an assumed heating value of 5,000 BTU/LB. The sizing will also ensure good superheater, convection bank and economizer tube life and heat transfer. Retractable soot blowers will be provided in the superheater areas and rotary soot blowers will be provided in the convection bank and economizer areas, in order to maintain clean, efficient heat transfer surfaces.

Materials of construction will be selected to ensure that corrosion and mechanical wear problems associated with municipal solid waste combustion will be minimal.

The feedwater system shall consist of the following:

- Demineralizer
- Demineralized Water Storage Tank
- Demineralized Water Transfer Pumps
- One Continuous Boiler Blowdown Heat Exchangers
to Heat the Water to the Deaerator
- One Motor Driven Feedwater Pump
- One Steam Turbine Driven Feed Water Pump
Using Steam From the 150 PSI Extraction Point on
the Power Turbine
- Deaerator, Complete with Trim
- One Chemical Feed Set for the Boilers
- One Chemical Feed Set for the Deaerator

All hot pipes and breeching with usable energy will be insulated and lagged for outdoor service. Other hot lines and breeching will be insulated and lagged where required for personnel protection.

A set of platforms and stairs will be supplied to serve all operating points of all equipment. An additional egress mode will be supplied in the form of OSHA standard ladders.

All equipment will be completely piped per applicable codes.

The instrumentation and control systems shall allow automatic or manual operation of the stoker, feedwater flow and feedwater treatment system.

A cooling tower to cool the circulating water of the steam condenser will be placed alongside the power turbine. Cooling air will be induced over the trickling water by fans in the top of the tower. To control algae and other contaminants, a chemical feed set will be installed.

Water will be circulated back to the condenser by one of two full capacity pumps.

The following station service, instrument and controls work will be performed:

- Set motor control centers
- Set instrument and control panel boards
- Install complete electrical raceway system
- Install all power and control wiring
- Install complete indoor and outdoor lighting system per OSHA and NEC
- Install TV and communication system

POWER GENERATION

A single steam turbine generator will be used to generate power at 12.3 MW. for distribution to the utility grid. This steam turbine generator will be an extraction-condensing unit with a nominal throttle condition of 625 PSIG/750°F, an extraction pressure of 150 PSIG and an exhaust pressure of 3 inch H_gA. This generator will be supported with the normal auxiliary equipment such as air ejection equipment, gland seal equipment and condensate pumps. The generator will be designed to utilize the steam flow from both boilers when operating at full load.

A primary feeder from the generator to the utility breaker and meter station will be installed, in addition to a full complement of switchgear.

ENVIRONMENTAL SYSTEMS

The pollution control and ash handling systems will be designed to provide for disposal of combustion products in an environmentally acceptable manner. This is accomplished by the installation of equipment to capture fly ash and bottom ash. The system will include bottom grate ash conveyors. These conveyors move heavy ash into an ash container. Ash will be sprayed with water to quench and control fugitive dust. Fly ash will be collected in the boiler pass and economizer hoppers and routed by gravity through rotary seal valves to the bottom ash collection system.

Fine material falling through the grate system (siftings) into the under stoker air plenum hoppers will be routed into the bottom ash conveyor.

The final control of fly ash will be accomplished by an electrostatic precipitator. This equipment provides for the particulate collection efficiencies mandated by environmental regulations. Fly ash that is collected by the precipitator will be routed through rotary seal valves and mechanical conveyors to the bottom ash conveyor. The combustion gases of each boiler will be drawn through the system by an induced draft fan. Each fan will discharge into a Corten, free standing stack complying with EPA height standards. The stack will be fitted with test ports and platform with access ladder.

The process wastewater system collects boiler blowdown, demineralizer regenerant wastes, floor drains in the water treatment area and the chemical treatment area, and the cooling tower blowdown. The wastewater will be disposed of in a three-cell percolation pond.

Sanitary waste will be processed by a septic tank system.

STRUCTURES

The refuse recovery building is 120 feet long by 55 feet wide by 70 feet high at the eaves, plus a 110 feet long by 30 feet wide truck unloading enclosure which is 30 feet high at the low eave and shares one long side with the main building. The larger building encloses the refuse pit (100 feet by 40 feet wide by 15 feet deep). Structures are wide flange steel column and beam with appropriate cross bracing, channel girts to support siding and LH bar joists for the roof of the larger building. Uninsulated 26 gauge painted metal siding and roofing is used to enclose the refuse recovery building and truck unloading area. Also enclosed in the refuse recovery building are the switchgear room, control room and crane operator control area which are all "stacked" in the 30 feet by 15 feet area between the hoppers. These control rooms are air-conditioned. Control room windows face the boilers. The boilers are supported on structural steel outside the building. The control room is on the 15 feet operating level. Crane operator space has glass on three sides, with the floor level above the hoppers to allow vision into the hoppers and the pit.

Access to the control rooms and switchgear room is by the outside stair tower which also serves the boiler platforms. Boiler platform floors and stair treads are structural bar grating, except for a 20 feet by 30 feet area of 6 inch concrete slab on metal deck which serves as the deaerator platform and covers the boiler feed water equipment (on original ground level). Another 6 inch concrete slab on metal deck forms a mezzanine on three sides of refuse pit inside the building.

Access to the unloading building is through four 20 feet wide by 16 feet high motor operated doors. Doors and cranes are controlled from the crane operator's room. Crane rails run the entire length of the building, allowing the grapples to rest on the end mezzanines. Stoker supply hoppers are supported on a structural steel frame.

The pit area will have motorized ventilation in-take louvers. Air will be exhausted through the boiler air induction system. Four roof exhaust fans will operate when the boilers are shut down.

A locker room, shower, and restroom are located at operating level with access from outside. Included are basic lockers, benches and toilet accessories.

Air-conditioning for boiler and crane control rooms will be supplied by ducts from a central air-conditioning unit. Shower, locker, and restrooms are to be ventilated with outside air by exhaust fans.

A fire protection system will be installed to include Halon in control room, plus sprinkler systems in the pit area. Fire hose stand pipe will be located in the boiler area. The fire protection loop is to be tied to a "city type water system" and encompass the facility. Three fire hydrants are to be located on each side and the rear of the building. If a "city type water system" does not exist at the site, a storage tank and fire pump will need to be installed, as an extra to the contract.

Electrostatic precipitators are supported by spread footings and piers. Boilers, economizers, and dust collectors are supported on spread footings and piers. The ash removal system is supported by structural steel on concrete footings and piers. All other equipment outside the building, including the Turbine Generator, is on concrete slabs at or near existing grade.

Soil bearing capability is based on 2,000 LB/SF. The Turbine Generator will be housed in a "knock down" type of enclosure with interior lighting and ventilation. Turbine maintenance or a repair service company will supply necessary structural framework and lifts for this structure as necessary.

SITWORK

Spread footings and mat foundations have been considered adequate for all structures and equipment. Maximum depth of excavation considered is 10 feet, with the water table assumed lower than 10 feet. No extensive dewatering has been considered.

The proposal is based on an estimated site of about 6 acres, requiring only light dozer clearing and grading with disposal of all waste on site or within $\frac{1}{4}$ mile. A 15 feet wide gravel (8 inches compacted locally available aggregate) entrance and perimeter road serving all facilities are included. A concrete maneuvering apron is provided in front of the enclosed truck unloading area. Included is construction of a lined holding pond (100 feet by 100 feet by 5 feet) for waste water retention. Also included in the civil work is excavation for the refuse storage pit.

A MSW building pit depth of 20 feet (10 feet below existing grade) is achieved by compacted earth fill 10 feet above grade on three sides of the building and formed concrete wall on the fourth (boiler) side of the building. Ramps to the scale are built of the same material as the gravel roads.

Landscaping consists of grading, replacing topsoil and reseeding (with grass) areas disturbed by construction.

The site is to be enclosed with 2,400 linear feet of 7 feet chain link fence with access through one manually operated gate.

EMISSION CONTROL DESIGN DETAILS

1. Type:
Electrostatic Precipitator
Rigid Frame
Three field
2. Gas flow:
55,600 acfm at 350°F approximate
Gas flow dependent upon selected incinerator/boiler
3. Gas velocity:
3.7 ft./sec. approximate
4. Specific collection area:
To be determined
5. Outlet gas particulate concentration:
Guaranteed <0.03 gr/dscf corrected to 12% CO₂.

BOILER DESIGN DETAILS

1. Fuel:
Unprepared municipal solid waste (MSW)
Design heat value: 5000 BTU/lb.
Design moisture content: 18.4%
Design ash content: 20.1%
2. Boiler type:
Mass burning water-wall furnace
3. Boiler efficiency:
70% approximate
4. Heat release:
<10,000 BTU/cu. ft.
5. Design capacity:
250 tons MSW/day
104 million BTU input/hr.

Boiler Run 1
Pg 1

BOILER PERFORMANCE

FEB 21, 1986

PROGRAM CALLED 'BOILCO2.BAS', ISSUED 1/31/86

PREPARED BY: LOCKWOOD GREENE ENGINEERS, INC.
1330 W. PEACHTREE STREET, N W
ATLANTA, GEORGIA 30367
(404) 873-3261
GARY MCAULIFFE

JOB NO. 85463.02
CUSTOMER: NRG
LEESBURG
LAKE COUNTY
FLORIDA

GAS FLOW FOR 250 TPD
FEED RATE @ 82%
EXCESS AIR @ 375°F
OUTLET GAS TEMP.

CONDITIONS: FUEL: MUNICIPAL SOLID WASTE
EXCESS AIR PERCENT: 82
STEAMING RATE (LB/HR): 62418.4
OPERATING PRES (PSIG): 650 AT 1379.18 BTU/LB
FEEDWATER TEMP (F) : 228
EXIT FLUE GAS TEMP F : 375
UNBURNED FUEL FACTOR : .05
RAD & UNACCT FOR LOSS: .0205
OVERALL EFFICIENCY : .708992

COMBUSTION AIR: FLOW RATE (LB/HR): 138233
FLOW RATE (ACFM) : 31744.6 AT 80 F
DENSITY : .0725758

FLUE GAS: FLOW RATE (LB/HR): 154047
FLOW RATE (ACFM) : 54862.6 AT 375 F ←
DENSITY : .0467977

FUEL INPUT: FIRING RATE (LB/HR) : 20833 ← 250 TPD
MOISTURE CONTENT AS FIRED (%) : 18.43

ASH GENERATED: FLOW RATE (LB/HR): 5019.71

| FUEL ANALYSIS | LAB SAMPLE | AS FIRED |
|---------------|------------|----------|
| C | 30.61 | 30.61 |
| H | 4.08 | 4.08 |
| S | .13 | .13 |
| O | 25.85 | 25.85 |
| N | .8 | .8 |
| H2O | 18.43 | 18.43 |
| ASH | 20.1 | 20.1 |
| TOTAL | 100 | 100 |

HEATING VALUE: 5000 5000

NOTE: THIS INFORMATION IS FOR THE EXCLUSIVE USE OF
LOCKWOOD GREENE PERSONNEL AND IS NOT TO BE RELEASED
WITHOUT WRITTEN PERMISSION OF THE ENGINEERING MANAGER.
LOCKWOOD GREENE ENGINEERS, INC. ACCEPTS NO RESPONSIBILITY
FOR EVENTS ARISING FROM USE OF THESE DATA BY PERSONS
OTHER THAN LOCKWOOD GREENE PERSONNEL.

PAGE NO. 2
JOB NO. 85463.02
% EXCESS AIR 82

FEB 21, 1986
NRG
MUNICIPAL SOLID WASTE

CHARACTERISTICS OF WET FLUE GASES :

LB/HR TOTAL MOISTURE IN FG : 12662.4
 LB/HR MOISTURE FROM AIR IN FG : 1805.14
 LB/HR MOISTURE ABSORBED IN FUEL : 3647.55
 LB/HR MOISTURE FROM H2 IN FUEL : 7209.71
 PERCENT BY WT OF H2O IN FG : 8.21985
 MOL WT OF WET FG : 28.5314
 AVE SPEC HT (SENS) ABOVE 80 F : .259319
 LAT HT LOSS/HR IN FG : 1.12915E+07
 TOTAL HT LOSS/HR IN FG : 2.3076E+07

CHARACTERISTICS OF DRY FLUE GASES :

MOL WT OF DRY FG : 30.1091
 DENSITY OF DRY FG AT 68 F : .0781001
 CU FT AT 68 F/BTU INPUT : .0182938
 F METHOD FACTOR : 100.515
 PERCENT CO2 IN DRY FG : 10.7511
 PERCENT O2 IN DRY FG : 9.53535
 PERCENT SO2 IN DRY FG : .0171225
 PERCENT N2 IN DRY FG : 79.6964

SINGLE UNIT DISCHARGE GAS FLOW

BASIS: BOILER DISCHARGE: 54,600 acfm @ 375° F
 IN-LEAKAGE AT ESP: 15,600 scfm
 RESULTING GAS TEMP. @ STACK: 350° F

$$\text{Flue Gas} = \left(\frac{54,600 \text{ ft}^3}{\text{min}} \right) \left(\frac{460+350}{460+375} \right) + \left(\frac{15,600 \text{ ft}^3}{\text{min}} \right) \left(\frac{460+350}{460+70} \right)$$

| |
|---|
| SINGLE UNIT FLOW = 55,600 acfm @ 350° F |
| TOTAL GAS FLOW = 111,200 acfm @ 350° F |

GAS TEMP BASED ON LOWEST GAS TEMP
 PROPOSED BY BOILER VENDORS UNDER
 CONSIDERATION.

TYPE B: ANSWER.DAT

BOILER PERFORMANCE

Boiler Run 2
Pg 1

JAN 27, 1986

PROGRAM CALLED 'BOILFU.BAS', ISSUED 6/10/83

PREPARED BY: LOCKWOOD GREENE ENGINEERS, INC.
1330 W. PEACHTREE STREET, N W
ATLANTA, GEORGIA 30367
(404) 873-3261
GARY MCAULIFFE

JOB NO. 85463.02

CUSTOMER: NRG
LEESBURG
LAKE COUNTY
FLORIDA

TOTAL GAS FLOW FOR
500 TPD FEED RATE
@ 12% CO₂

CONDITIONS: FUEL: MUNICIPAL SOLID WASTE
EXCESS AIR PERCENT: 63.1867
STEAMING RATE (LB/HR): 123871
OPERATING PRES (PSIG): 650 AT 1380 BTU/LB
FEEDWATER TEMP (F) : 228
EXIT FLUE GAS TEMP F : 400
UNBURNED FUEL FACTOR : .06
RAD & UNACCT FOR LOSS: .019
OVERALL EFFICIENCY : .703965

COMBUSTION AIR: FLOW RATE (LB/HR): 245289
FLOW RATE (ACFM) : 56329.4 AT 80 F
DENSITY : .0725758

FLUE GAS: FLOW RATE (LB/HR): 276584 ←
FLOW RATE (ACFM) : 101483 AT 400 F
DENSITY : .0454236

FUEL INPUT: FIRING RATE (LB/HR) : 41667.7 ← 500 TPD
MOISTURE CONTENT AS FIRED (%) : 18.43

ASH GENERATED: FLOW RATE (LB/HR): 10372.6

| FUEL ANALYSIS | LAB SAMPLE | AS FIRED |
|------------------|------------|----------|
| C | 30.61 | 30.61 |
| H | 4.08 | 4.08 |
| S | .13 | .13 |
| O | 25.85 | 25.85 |
| N | .6 | .6 |
| H ₂ O | 18.43 | 18.43 |
| ASH | 20.1 | 20.1 |
| TOTAL | 100 | 100 |

HEATING VALUE: 5000 5000

NOTE: THIS INFORMATION IS FOR THE EXCLUSIVE USE OF LOCKWOOD GREENE PERSONNEL AND IS NOT TO BE RELEASED WITHOUT WRITTEN PERMISSION OF THE ENGINEERING MANAGER. LOCKWOOD GREENE ENGINEERS, INC. ACCEPTS NO RESPONSIBILITY FOR EVENTS ARISING FROM USE OF THESE DATA BY PERSONS OTHER THAN LOCKWOOD GREENE PERSONNEL.



LGM ENGINEERS CONSTRUCTORS

JOB NO. 25463.01

SHEET NO. 1 OF 21

DATE 2/19/86

JOB NAME NRG

COMPUTED BY RVC

SUBJECT SO₂ EMISSION FACTORS

CHECKED BY WER

| REFERENCE | SO ₂ EMISSION FACTOR | | | LB./10 ⁶ BTU |
|---------------------------|---------------------------------|----------------------------|-----------------------------|-------------------------|
| | LOW | HIGH | AVG. | |
| <u>CARB 5/24/84</u> | | | | |
| TAMPA WASTE | | | 0.3% S | |
| % DISCHARGE | | | 25% | 0.3 |
| SUMMARY TABLE 19 | 72 ppm | 159 ppm | 123 ppm | 0.33 |
| | 0.13 lb/10 ⁶ BTU | 0.31 | 0.22 | 0.22 |
| NASHVILLE | | | 0.14 lb/10 ⁶ BTU | 0.14 |
| CHICAGO | | | 0.32 lb/10 ⁶ BTU | 0.32 |
| BROOKLYN | 1.44 lb/TOW | 2.3 lb/T | 5.13 lb/T | 0.51 |
| GALLATIN | 0.8 lb/T | 6.9 lb/T | 2.8 lb/T | 0.28 |
| | 0.08 lb/10 ⁶ BTU | 1.2 lb/10 ⁶ BTU | 0.42 lb/10 ⁶ BTU | 0.42 |
| PINELLAS | | | 1.33 lb/T | |
| | | | 0.15 lb/10 ⁶ BTU | 0.15 |
| DADE | 3.0 lb/T | 5.5 lb/T | 3.5 lb/T | 0.35 |
| | | | 0.29 lb/10 ⁶ BTU | |
| E. HAMILTON | | | 4.5 lb/T | 0.45 |
| ALBANY | | | 1.4 lb/T | |
| <u>Sommer, E., et al.</u> | | | | |
| Gallatin | | | 0.12% S | |
| | | | 2.80 lb/T | 0.28 |
| <u>Battelle Report</u> | | | | |
| Summary | | | 2.25 lb/T | 0.23 |

NRG UNCONTROLLED SO₂ EMISSION FACTOR
 SO₂ PRESENT AVG. = 0.32 LB/10⁶BTU
 SO₂ FUTURE = 0.6 LB/10⁶BTU (Projected)



LGM ENGINEERS CONSTRUCTORS

JOB NO. 25AUB.01

SHEET NO. 2 OF 21

DATE 2/19/86

JOB NAME NRG

COMPUTED BY RVC

SUBJECT SO₂ Emissions

CHECKED BY WBR

Basis for estimates: 3 lb. SO₂/ton average
6 lb. SO₂/ton maximum

EMISSION RATE

① 3 lb./TON

$$\text{Emission rate} = \left(\frac{3 \text{ lb}}{\text{ton}}\right) \left(\frac{250 \text{ tons}}{24 \text{ hr}}\right) = 31.25 \frac{\text{lb}}{\text{hr}}$$

$$\text{Emission rate} = \left(\frac{3 \text{ lb}}{\text{ton}}\right) \left(\frac{\text{ton}}{10 \times 10^6 \text{ BTU}}\right) = 0.30 \frac{\text{lb}}{10^6 \text{ BTU}}$$

$$\text{Emission rate} = \left(31.25 \frac{\text{lb}}{\text{hr}}\right) \left(\frac{\text{hr}}{60 \text{ min}}\right) \left(\frac{\text{min}}{26,750 \text{ dscf}}\right) \left(\frac{7000 \text{ gr}}{\text{lb}}\right) = 0.1363 \frac{\text{gr}}{\text{dscf}}$$

② 6 lb./TON

$$\text{Emission rate} = 62.50 \text{ lb/hr.}$$

$$\text{Emission rate} = 0.60 \text{ lb}/10^6 \text{ BTU}$$

$$\text{Emission rate} = 0.2726 \text{ gr/dscf with } 12\% \text{ CO}_2$$

$$\text{SO}_2 \text{ Concentration} = \left(\frac{62.5 \text{ lb}}{\text{hr}}\right) \left(\frac{\text{hr}}{60 \text{ min}}\right) \left(\frac{\text{min}}{26,750 \text{ dscf}}\right) \left(\frac{7000 \text{ gr}}{\text{lb}}\right) = 6.27 \frac{\text{gr}}{\text{dscf}}$$

POTENTIAL ANNUAL EMISSION

$$\text{SO}_2 = \left(\frac{62.5 \text{ lb}}{\text{hr}}\right) (2) \left(\frac{24 \text{ hr}}{15 \text{ hrs}}\right) \left(\frac{365 \text{ Day}}{\text{yr}}\right) \left(\frac{\text{TON}}{2000 \text{ lb}}\right) = 547 \frac{\text{Tons}}{\text{yr}}$$

STACK DISCHARGE RATE

Basis: 2 units discharge through combined stack
6 lb. SO₂/ton

$$\text{SO}_2 \text{ emission rate} = \left(\frac{62.5 \text{ lb}}{\text{hr}}\right) (2) \left(\frac{454 \text{ gm}}{\text{lb}}\right) \left(\frac{\text{hr}}{3600 \text{ sec}}\right) = 15.8 \frac{\text{gm}}{\text{sec}}$$



LGM ENGINEERS CONSTRUCTORS

JOB NO. 25463.01

SHEET NO. 3 OF 21

DATE 2/20/26

JOB NAME NRG

COMPUTED BY RVC

SUBJECT NOx EMISSION FACTOR

CHECKED BY WBR

| REFERENCE | NOx EMISSION FACTOR | | | Lb./10 ⁶ BTU |
|---------------------------|--|-----------------|--|-------------------------|
| | LOW | HIGH | AVG | |
| <u>CARB 1980</u> | | | | |
| Summary p. 31 | 145 ppm 0.11 Lb/10 ⁶ BTU | 279 ppm 0.47 | 223 ppm 0.37 Lb/10 ⁶ BTU | 0.37 |
| Nashville | | | 0.32 Lb/10 ⁶ BTU | 0.32 |
| Harrisburg | 0.15 | 0.42 | 0.27 Lb/10 ⁶ BTU | 0.27 |
| Chicago | | | 0.34 Lb/10 ⁶ BTU | 0.34 |
| Braintree | 0.13 | 0.26 | 0.19 Lb/10 ⁶ BTU | 0.19 |
| Gallatin | | | 0.30 Lb/10 ⁶ BTU | 0.30 |
| Saugus | | | 0.39 Lb/10 ⁶ BTU | 0.39 |
| Chicago D.I.W. | 0.34 | 0.44 | 0.39 Lb/10 ⁶ BTU | 0.39 |
| <u>Sommer, E., et al.</u> | | | | |
| Gallatin | | | 2.20 Lb/ton | 0.22 |
| <u>Battelle</u> | | | | |
| Summary | | | 2.4 Lb/ton | 0.24 |
| <u>BOILER VENDORS</u> | | | | |
| EST. | 0.3 | 0.5 | 0.4 Lb/10 ⁶ BTU | |

NRG NOx EMISSION FACTOR

NOx ≤ 0.50 Lb./10⁶BTU

(Design Spec. & Vendor Guarantee)



LGM ENGINEERS CONSTRUCTORS

JOB NO. 25463.01SHEET NO. 4 OF 21DATE 2/20/26JOB NAME NRG COMPUTED BY RUCSUBJECT NO_x Emission CHECKED BY WBR

Basis for estimates:

$$\text{NO}_x = 0.50 \text{ lb}/10^6 \text{ BTU}$$

Emission Rate, each unit

$$\text{Emission rate} = 0.50 \text{ lb}/10^6 \text{ BTU}$$

$$\text{Emission rate} = \left(\frac{0.50 \text{ lb}}{10^6 \text{ BTU}} \right) \left(\frac{10^6 \text{ BTU}}{\text{Ton MSW}} \right) = 5.0 \frac{\text{lb}}{\text{Ton}}$$

$$\text{Emission rate} = \left(\frac{5.0 \text{ lb}}{\text{Ton}} \right) \left(\frac{250 \text{ Ton}}{\text{day}} \right) \left(\frac{\text{day}}{24 \text{ hr}} \right) = 52 \frac{\text{lb}}{\text{hr.}}$$

$$\text{NO}_x \text{ Concentration} = \left(\frac{52 \text{ lb}}{\text{hr}} \right) \left(\frac{\text{hr}}{60 \text{ min}} \right) \left(\frac{\text{min}}{26,750 \text{ dscf}} \right) \left(\frac{7000 \text{ gr}}{\text{lb}} \right) = 0.23 \frac{\text{gr}}{\text{dscf}}$$


POTENTIAL ANNUAL EMISSION

$$\text{NO}_x = \left(\frac{52 \text{ lb}}{\text{hr}} \right) (2) \left(\frac{24 \text{ hr}}{\text{DAY}} \right) \left(\frac{365 \text{ DAY}}{\text{yr}} \right) \left(\frac{\text{Ton}}{2000 \text{ lb}} \right) = 455 \frac{\text{Ton}}{\text{yr.}}$$

STACK DISCHARGE RATE

Basis: 2 units discharge to 1 common stack

$$\text{NO}_x \text{ emission rate} = \left(\frac{52 \text{ lb}}{\text{hr}} \right) (2) \left(\frac{454 \text{ gm}}{\text{lb}} \right) \left(\frac{\text{hr}}{3600 \text{ sec}} \right) = 13.12 \frac{\text{gm}}{\text{sec}}$$



LGM ENGINEERS CONSTRUCTORS

JOB NO. 25463.01

SHEET NO. 5 OF 21

DATE 2/19/86

JOB NAME NRG

COMPUTED BY KVC

SUBJECT PARTICULATE EMISSION FACTOR

CHECKED BY WBR

| REFERENCE | PM EMISSION FACTOR | | | LB/10 ⁶ BTU |
|---------------------------------------|--------------------|-------------|---|------------------------|
| | LOW | HIGH | AVG | |
| <u>CARB 1984</u> Summary p. 146 | 0.33 0.68 | 3.5 7.4 | 1.4 gr/dscf 3.1 lb/10 ⁶ BTU | 3.1 |
| <u>Battelle</u> Summary Est. | 0.6 | 2.6 gr/dscf | 2 gr/dscf | 4 + |
| <u>Sommer, E., et al.</u> Gallatin | | | 42.5 lb/ton | 4.3 |
| <u>BOILER VENDORS</u> EST. | 40 | 90 lb/ton | 72 lb/ton | 7.2 |

NRG UNCONTROLLED EMISSION FACTOR
 PART. = 4 lb/10⁶ BTU (Arbitrary)



LGM ENGINEERS CONSTRUCTORS

JOB NO. 05463.01

SHEET NO. 6 OF 21

DATE 2/19/90

JOB NAME NRG

COMPUTED BY RVC

SUBJECT PARTICULATE EMISSION

CHECKED BY WBR

Basis for estimate: 0.03 gr/dscf corrected to 12% CO₂
 DSCF corrected to 12% CO₂ = 26,750 dscfm
 EMISSION RATE EACH UNIT

$$\text{Emission rate} = \left(\frac{0.03 \text{ gr}}{\text{dscf}} \right) \left(\frac{26,750 \text{ dscfm}}{\text{m}} \right) \left(\frac{454 \text{ gm}}{\text{lb}} \right) \left(\frac{1 \text{ hr}}{3600 \text{ s}} \right) = 6.88 \frac{\text{lb}}{\text{hr}}$$

$$\text{Emission rate} = \left(\frac{6.88 \text{ lb}}{\text{hr}} \right) \left(\frac{24 \text{ hr}}{26.0 \text{ m}} \right) = 0.6603 \frac{\text{lb}}{\text{ton}}$$

$$\text{Emission rate} = 0.6603 \frac{\text{lb}}{\text{ton}} \frac{\text{TON}}{10 \times 10^6 \text{ BTU}} = 0.066 \frac{\text{lb}}{10^6 \text{ BTU}}$$

POTENTIAL ANNUAL EMISSION

$$\text{PARTICULATE} = \left(6.88 \frac{\text{lb}}{\text{hr}} \right) (2 \text{ UNITS}) \left(\frac{24 \text{ hr}}{\text{DAY}} \right) \left(\frac{365 \text{ DAY}}{\text{YR}} \right) \left(\frac{\text{TON}}{2000 \text{ lb}} \right)$$

$$= 60 \text{ Tons/yr.}$$

STACK DISCHARGE RATE

Basis: 2 units discharge through single combined stack

$$\text{Particulate emission rate} = \left(\frac{6.88 \text{ lb}}{\text{hr}} \right) (2) \left(\frac{454 \text{ gm}}{\text{lb}} \right) \left(\frac{1 \text{ hr}}{3600 \text{ s}} \right) = 1.735 \frac{\text{gm}}{\text{sec}}$$



LGM ENGINEERS CONSTRUCTORS

JOB NO. 05A63.01

SHEET NO. 7 OF 21

DATE 2/20/00

JOB NAME NRG

COMPUTED BY RVC

SUBJECT CO EMISSION FACTOR

CHECKED BY WBR

| REFERENCE | CO EMISSION FACTOR | | | LB./10 ⁶ BTU |
|--------------------------|-----------------------------|---------|-----------------------------|-------------------------|
| | LOW | HIGH | AVG | |
| <u>CARB 1984</u> | | | | |
| Summary p. 175 | 102 ppm | 643 ppm | 144 ppm | |
| | 0.18 LB/10 ⁶ BTU | 0.73 | 0.26 | 0.24 |
| Nashville | | | 0.24 LB/10 ⁶ BTU | 0.24 |
| Baintree | | | 1.06 LB/10 ⁶ BTU | 1.06 |
| Gallatin | | | 0.63 LB/10 ⁶ BTU | 0.63 |
| Dade | | | 0.63 LB/10 ⁶ BTU | 0.63 |
| | | | 769 ppm | 0.89 |
| E. Hamilton | | | 1.4 LB/10 ⁶ BTU | 1.4 |
| | | | 1,730 ppm | 2.0 |
| <u>Sommer, E., et al</u> | | | | |
| Gallatin | | | 4.5 LB/Ton | 0.45 |
| <u>Battelle</u> | | | | |
| Estimate | | | 1.9 LB/Ton | 0.19 |
| <u>BOILER VENDORS</u> | | | | |
| 8 hr. Avg | | 400 ppm | | 0.45 |
| 4 day Avg | | 100 ppm | | 0.11 |

NRG CO EMISSION FACTOR

CO = 0.45 LB./10⁶BTU (8 hr. Avg.)

0.11 LB./10⁶BTU (4 day Avg.)



LGM ENGINEERS CONSTRUCTORS

JOB NO. 25463.01SHEET NO. 8 OF 21DATE 2/20/86JOB NAME NRGCOMPLETED BY RVCSUBJECT CO EMISSIONCHECKED BY WBRBasis of CO estimates8 Hr. avg. 400 ppm corrected to 12% CO₂

4 Day avg. 100 ppm "

EMISSION RATE, EACH UNIT

Concentration = 400 ppm

$$\text{Concentration} = \left(\frac{400 \text{ dscft CO}}{10^6 \text{ dscft flue gas}} \right) \left(\frac{28 \text{ lb CO}}{387 \text{ dscft}} \right) \left(\frac{7000 \text{ gr}}{\text{Lb}} \right)$$

$$= 0.203 \text{ gr./dscft corrected to 12\% CO}_2$$

$$\text{Emission Rate} = \left(\frac{400}{10^6} \right) \left(\frac{26750 \text{ dscft}}{\text{min}} \right) \left(\frac{28 \text{ Lb}}{387 \text{ dscft}} \right) \left(\frac{60 \text{ min}}{\text{hr.}} \right) = 46.4 \frac{\text{Lb.}}{\text{Hr.}}$$

$$\text{Emission Rate} = \left(46.4 \frac{\text{Lb.}}{\text{Hr.}} \right) \left(\frac{24 \text{ Hr}}{250 \text{ TON}} \right) = 4.45 \frac{\text{Lb.}}{\text{TON}}$$

$$\text{Emission Rate} = \left(4.45 \frac{\text{Lb.}}{\text{TON}} \right) \left(\frac{\text{Ton}}{10^6 \text{ BTU}} \right) = 0.445 \frac{\text{Lb.}}{10^6 \text{ BTU}}$$


$$\text{Long Term Avg. Emission} = \left(46.4 \frac{\text{Lb.}}{\text{Hr.}} \right) \left(\frac{100}{400} \right) = 11.6 \frac{\text{Lb.}}{\text{Hr.}}$$

POTENTIAL ANNUAL EMISSION

$$\text{CO} = \left(11.6 \frac{\text{Lb.}}{\text{Hr.}} \right) (2) \left(\frac{24 \text{ Hr}}{\text{Day}} \right) \left(\frac{365 \text{ Day}}{\text{Yr.}} \right) \left(\frac{\text{Ton}}{2000 \text{ Lb.}} \right) = 101 \frac{\text{Ton}}{\text{Yr.}}$$

STACK DISCHARGE RATEBasis: 2 units discharge to single stack
400 ppm emission conc.

$$\text{CO emission rate} = \left(46.4 \frac{\text{Lb.}}{\text{Hr.}} \right) (2) \left(\frac{454 \text{ g}}{\text{Lb.}} \right) \left(\frac{\text{Hr.}}{3600 \text{ Sec.}} \right) = 11.7 \frac{\text{g.}}{\text{Sec.}}$$



LGM ENGINEERS CONSTRUCTORS

JOB NO. 85463-01

SHEET NO. 9 OF 21

DATE 3/7/06

JOB NAME NRG

COMPUTED BY RVC

SUBJECT LEAD EMISSION FACTOR

CHECKED BY WRB

| REFERENCE | Pb EMISSION FACTOR | | | Lb/10 ⁶ BTU |
|--------------------------------|--------------------|--------|-------------------------------|------------------------|
| | LOW | HIGH | AVE. | |
| CARB 1984 Summary p.192 | 5,600 | 16,000 | 9531 μg/MJ | 0.013 |
| Braintree | 127 | 154 | 131 g/10 ⁶ BTU | 0.019 |
| Sommer, E., et al. Bulletin | | | 0.27 lb/ton (uncontrolled) | 0.027 |
| Battelle Summary | | | 0.012 lb/ton (controlled) | 0.0012 (controlled) |
| Estimate | | | | 0.030 |
| CARB 1984 Bulletin, pg.196 | | | | 0.035 |

NRG UNCONTROLLED LEAD EMISSION FACTOR

Pb = 0.030 Lb/10⁶BTU (EST.)



LGM ENGINEERS CONSTRUCTORS

JOB NO. B5463.01SHEET NO. 10 OF 21DATE 3/7/86JOB NAME NRG COMPUTED BY RVCSUBJECT LEAD EMISSION CHECKED BY WBR

Basis for estimate: Uncontrolled Pb = 0.030 lb/10⁶ BTU
 ESP provides 96% Pb control

Emission Rate Each Unit

$$\text{Emission Rate} = \left(\frac{0.030 \text{ Lb.}}{10^6 \text{ BTU}} \right) \left(\frac{10^4 \times 10^6 \text{ BTU}}{\text{Hr.}} \right) \left(\frac{100 - 96}{100} \right) = 0.125 \frac{\text{Lb}}{\text{Hr}}$$

$$\text{Emission Rate} = \left(\frac{0.030 \text{ Lb.}}{10^6 \text{ BTU}} \right) \left(\frac{100 - 96}{100} \right) = 0.00120 \frac{\text{Lb.}}{10^4 \text{ BTU}}$$

$$\text{Emission Rate} = \left(\frac{0.0012 \text{ Lb.}}{10^4 \text{ BTU}} \right) \left(\frac{10 \times 10^6 \text{ BTU}}{\text{Ton}} \right) = 0.012 \frac{\text{Lb}}{\text{Ton}}$$

$$\begin{aligned} \text{Pb concentration} &= \left(\frac{0.125 \text{ Lb}}{\text{Hr}} \right) \left(\frac{\text{Hr.}}{60 \text{ min}} \right) \left(\frac{\text{min}}{26750 \text{ dscf}} \right) \left(\frac{7000 \text{ gr}}{\text{Lb}} \right) \\ &= 0.00055 \text{ gr/dscf} \end{aligned}$$

POTENTIAL ANNUAL EMISSION

$$\text{Pb} = \left(0.125 \frac{\text{Lb}}{\text{Hr}} \right) (2) \left(\frac{24 \text{ Hr}}{\text{Day}} \right) \left(\frac{365 \text{ Day}}{\text{Yr}} \right) \left(\frac{\text{Ton}}{2000 \text{ Lb}} \right) = 1.1 \frac{\text{Ton}}{\text{Yr}}$$

STACK DISCHARGE RATE

Basis: 2 units to a single stack

$$\text{Pb} = \left(0.125 \frac{\text{Lb}}{\text{Hr}} \right) (2) = 0.25 \frac{\text{Lb}}{\text{Hr}}$$

$$\text{Pb} = \left(0.25 \frac{\text{Lb}}{\text{Hr}} \right) \left(\frac{454 \text{ g}}{\text{Lb}} \right) \left(\frac{\text{Hr}}{3600 \text{ sec}} \right) = 0.03 \text{ g/s}$$



LGM ENGINEERS CONSTRUCTORS

JOB NO. 05463.01

SHEET NO. 11 OF 21

DATE 3/7/96

JOB NAME NRG

COMPUTED BY RVC

SUBJECT NMHC (VOC) EMISSION FACTOR

CHECKED BY WBR

| REFERENCE | VOC EMISSION FACTOR | | | LB./10 ⁶ BTU |
|---------------------------|--------------------------|-------|------------------------------|-------------------------|
| | LOW | HIGH | AVG. | |
| <u>CARB 118A</u> | | | | |
| Summary p. 17A | 0.001 LB/10 ⁶ | 0.004 | 0.003 LB/10 ⁶ BTU | 0.003 |
| Bainbridge | | | 0.014 LB/10 ⁶ BTU | 0.014 |
| Gallatin | | | 0.037 LB/10 ⁶ BTU | 0.037 |
| Dade | | | 0.01 LB/10 ⁶ BTU | 0.01 |
| Chicago | | | 0.003 LB/10 ⁶ BTU | 0.003 |
| E. Hamilton | | | 0.1 LB/10 ⁶ BTU | 0.1 |
| <u>Sommer, P., et al.</u> | | | | |
| Gallatin | | | 0.23 LB/T | 0.023 |
| <u>Battelle</u> | | | | |
| Test summary | | | 0.46 LB/T | 0.046 |
| Estimate | | | 0.12 LB/T | 0.012 |

NRG VOC EMISSION FACTOR

VOC = 0.04 LB./10⁶ BTU (Conservative Est.)



LGM ENGINEERS CONSTRUCTORS

JOB NO. 254631A

SHEET NO. 12 OF 21

DATE 3/7/86

JOB NAME NRG

COMPUTED BY RVC

SUBJECT VOC EMISSION

CHECKED BY WBR

Basis for estimate: VOC = 0.04 lb/10⁴ BTU

EMISSION RATE EACH UNIT

$$\text{Emission Rate} = 0.04 \text{ lb} / 10^4 \text{ BTU}$$

$$\text{Emission Rate} = \left(0.04 \frac{\text{lb}}{10^4 \text{ BTU}}\right) \left(10 \times \frac{10^4 \text{ BTU}}{\text{Ton}}\right) = 0.4 \frac{\text{lb}}{\text{Ton}}$$

$$\text{Emission Rate} = \left(0.04 \frac{\text{lb}}{10^4 \text{ BTU}}\right) \left(\frac{10^4 \times 10^4 \text{ BTU}}{\text{Hr}}\right) = 4.16 \frac{\text{lb}}{\text{Hr}}$$

$$\begin{aligned} \text{VOC concentration} &= \left(4.16 \frac{\text{lb}}{\text{Hr}}\right) \left(\frac{\text{Hr}}{60 \text{ min}}\right) \left(\frac{\text{min}}{26750 \text{ dscf}}\right) \left(\frac{7000 \text{ gr}}{\text{lb}}\right) \\ &= 0.018 \text{ gr/dscf} \end{aligned}$$

POTENTIAL ANNUAL EMISSION

$$\text{VOC} = \left(4.16 \frac{\text{lb}}{\text{Hr}}\right) (2) \left(\frac{24 \text{ Hr}}{12 \times 24 \text{ hr}}\right) \left(\frac{365 \text{ Days}}{\text{yr}}\right) \left(\frac{\text{Ton}}{2000 \text{ lb}}\right) = 36 \frac{\text{Ton}}{\text{yr}}$$

STACK DISCHARGE RATE

Basis: 2 units to a single stack

$$\text{VOC} = \left(4.16 \frac{\text{lb}}{\text{Hr}}\right) (2) = 8.3 \frac{\text{lb}}{\text{Hr}}$$

$$\text{VOC} = \left(8.3 \frac{\text{lb}}{\text{Hr}}\right) \left(\frac{454 \text{ g}}{\text{lb}}\right) \left(\frac{\text{Hr}}{3600 \text{ sec}}\right) = 1.05 \text{ g/s}$$



LGM ENGINEERS CONSTRUCTORS

JOB NO. 35463.01

SHEET NO. 13 OF 21

DATE 3/7/86

JOB NAME NRG

COMPUTED BY RVC

SUBJECT MERCURY EMISSION FACTOR

CHECKED BY WBR

| REFERENCE | Hg EMISSION FACTOR | | | LB/10 ⁶ BTU |
|---|--------------------|--------|---|------------------------|
| | LOW | HIGH | AVG. | |
| CARB 1984 Summary p. 192 Bulletin, p. 196 | 17 | 390 | 157 $\mu\text{g}/\text{MJ}$ 93 $\mu\text{g}/\text{MJ}$ | 0.00037 0.00022 |
| Battelle Summary | | | 0.0064 LB/T | 0.00064 |
| Weston Summary | 1,710 | 19,700 | 6.905×10^{-6} LB/T | 0.00068 |

NRG UNCONTROLLED MERCURY EMISSION FACTOR
 Hg = 0.0007 LB./10⁶ BTU (conservative est.)



LGM ENGINEERS CONSTRUCTORS

JOB NO. 05463.01

SHEET NO. 14 OF 21

DATE 3/7/86

JOB NAME NRG COMPUTED BY RVC

SUBJECT MERCURY EMISSION CHECKED BY WBR

Basis for estimate: $Hg = 0.0007 \text{ LB}/10^6 \text{ BTU}$

EMISSION RATE EACH UNIT

$$\text{EMISSION RATE} = 0.0007 \text{ LB}/10^6 \text{ BTU}$$

$$\text{EMISSION RATE} = \left(0.0007 \frac{\text{LB}}{10^6 \text{ BTU}} \right) \left(\frac{10 \times 10^6 \text{ BTU}}{\text{TON}} \right) = 0.007 \frac{\text{LB}}{\text{TON}}$$

$$\text{EMISSION RATE} = \left(0.0007 \frac{\text{LB}}{10^6 \text{ BTU}} \right) \left(\frac{104 \times 10^6 \text{ BTU}}{\text{HR}} \right) = 0.073 \frac{\text{LB}}{\text{HR}}$$

$$\begin{aligned} \text{Hg Concentration} &= \left(0.073 \frac{\text{LB}}{\text{HR}} \right) \left(\frac{\text{HR}}{60 \text{ min}} \right) \left(\frac{\text{min}}{26750 \text{ dscf}} \right) \left(\frac{7000 \text{ gr}}{\text{LB}} \right) \\ &= 0.0003 \text{ gr/dscf} \end{aligned}$$

POTENTIAL ANNUAL EMISSION

$$\text{Hg} = \left(0.073 \frac{\text{LB}}{\text{HR}} \right) (2) \left(\frac{24 \text{ HR}}{\text{day}} \right) \left(\frac{365 \text{ day}}{\text{yr}} \right) \left(\frac{\text{Ton}}{2000 \text{ LB}} \right) = 0.6 \frac{\text{Ton}}{\text{yr}}$$

STACK DISCHARGE RATE

Basis: 2 units to a single stack

$$\text{Hg} = \left(0.073 \frac{\text{LB}}{\text{HR}} \right) (2) = 0.15 \frac{\text{LB}}{\text{HR}}$$

$$\text{Hg} = \left(0.15 \frac{\text{LB}}{\text{HR}} \right) \left(\frac{454 \text{ g}}{\text{LB}} \right) \left(\frac{\text{HR}}{3600 \text{ sec}} \right) = 0.019 \text{ g/s}$$



LGM ENGINEERS CONSTRUCTORS

JOB NO. 25463.01

SHEET NO. 15 OF 21

DATE 3/3/96

JOB NAME NRG

COMPUTED BY RVL

SUBJECT HF⁻ EMISSION FACTOR

CHECKED BY WBR

| REFERENCE | HF ⁻ EMISSION FACTOR | | | Lb./10 ⁶ BTU |
|--|---------------------------------|------|--|-------------------------|
| | LOW | HIGH | AVG. | |
| <u>CARB 1984</u> <u>Summary p.114</u> <u>Babylon</u> | 0.002 | 0.01 | 0.003 Lb./10 ⁶ BTU 0.006 Lb./10 ⁶ | 0.003 0.006 |
| <u>Battelle</u> <u>Summary</u> | | | 0.06 Lb/TON | 0.006 |
| <u>Sommer, E., et al</u> <u>Gallatin</u> | | | 0.031 Lb/TON | 0.003 |

NRG UNCONTROLLED HF⁻ EMISSION FACTOR
 HF⁻ = 0.006 Lb./10⁶ BTU (conservative est.)



LGM ENGINEERS CONSTRUCTORS

JOB NO. 25463.01SHEET NO. 16 OF 21DATE 3/3/86JOB NAME NRG COMPUTED BY RVCSUBJECT FLUORIDES EMISSION CHECKED BY WBTRBasis for estimate: $0.006 \text{ Lb.} / 10^6 \text{ BTU}$

EMISSION RATE EACH UNIT

$$\text{Emission Rate} = 0.006 \text{ Lb} / 10^6 \text{ BTU}$$

$$\text{Emission Rate} = \left(0.006 \frac{\text{Lb}}{10^6 \text{ BTU}} \right) \left(10 \times 10^6 \frac{\text{BTU}}{\text{Ton}} \right) = 0.06 \frac{\text{Lb}}{\text{Ton}}$$

$$\text{Emission Rate} = \left(0.006 \frac{\text{Lb}}{10^6 \text{ BTU}} \right) \left(104 \times 10^6 \frac{\text{BTU}}{\text{Hr}} \right) = 0.624 \frac{\text{Lb}}{\text{Hr}}$$

$$\begin{aligned} \text{F}^- \text{ concentration} &= \left(0.624 \frac{\text{Lb}}{\text{Hr}} \right) \left(\frac{\text{Hr}}{60 \text{ min}} \right) \left(\frac{\text{min}}{26750 \text{ dscf}} \right) \left(\frac{7000 \text{ gr}}{\text{Lb}} \right) \\ &= 0.0027 \text{ gr/dscf} \end{aligned}$$

POTENTIAL ANNUAL EMISSION

$$\text{F}^- = \left(0.624 \frac{\text{Lb}}{\text{Hr}} \right) (2) \left(\frac{24 \text{ Hr}}{\text{Day}} \right) \left(\frac{365 \text{ Day}}{\text{Yr}} \right) \left(\frac{\text{Ton}}{2000 \text{ Lb}} \right) = 5.5 \frac{\text{Ton}}{\text{Yr}}$$

STACK DISCHARGE RATE

Basis: 2 units to single stack

$$\text{F}^- = \left(0.624 \frac{\text{Lb}}{\text{Hr}} \right) (2) = 1.25 \frac{\text{Lb}}{\text{Hr}}$$

$$\text{F}^- = \left(1.25 \frac{\text{Lb}}{\text{Hr}} \right) \left(\frac{454 \text{ g}}{\text{Lb}} \right) \left(\frac{\text{Hr}}{3600 \text{ Sec}} \right) = 0.16 \text{ g/s}$$



LGM ENGINEERS CONSTRUCTORS

JOB NO. 85463.01

SHEET NO. 17 OF 21

DATE 3/7/86

JOB NAME NRG

COMPUTED BY RVC

SUBJECT BERYLLIUM EMISSION FACTOR

CHECKED BY WBR

| REFERENCE | Be EMISSION FACTOR | | | Lb./10 ⁶ BTU |
|------------------------------------|--------------------|------|--|--|
| | LOW | HIGH | AVG | |
| CARB 1984 p.192 Gallatin p.196 | <0.08 | 3 | 1.05 mg/MJ 2.66 kg/MJ | 2.5 x 10 ⁻⁶ 6.2 x 10 ⁻⁶ |
| Battelle (little data) Estimate | | | (Controlled) < 5.6 x 10 ⁻³ lb/T (Controlled) < 0.15 mg/g TSP | 0.6 x 10 ⁻³ 1.0 x 10 ⁻³ |
| Weston, Roy F., Inc. Gallatin | | | < 4.8 x 10 ⁻⁵ lb/T | 4.8 x 10 ⁻⁶ |

NRG UNCONTROLLED BERYLLIUM EMISSION RATE
 $Be = 5 \times 10^{-6} \text{ LB.} / 10^6 \text{ BTU (AVG.)}^*$

* Low confidence in this value



LGM ENGINEERS CONSTRUCTORS

JOB NO. B5463.01SHEET NO. 18 OF 21DATE 3/7/86JOB NAME NRG COMPUTED BY RVCSUBJECT BERYLLIUM EMISSION CHECKED BY WBR

Basis for estimate: Uncontrolled Be = 5×10^{-6} Lb./ 10^6 BTU
 ESP provides 98% Be control

EMISSION RATE EACH UNIT

$$\text{Emission Rate} = \left(5 \times 10^{-6} \frac{\text{Lb.}}{10^6 \text{ BTU}} \right) \left(\frac{100-98}{100} \right) = 1.0 \times 10^{-7} \frac{\text{Lb.}}{10^6 \text{ BTU}}$$

$$\text{Emission Rate} = \left(1.0 \times 10^{-7} \frac{\text{Lb.}}{10^6 \text{ BTU}} \right) \left(104 \times \frac{10^4 \text{ BTU}}{\text{Hr.}} \right) = 1.0 \times 10^{-5} \frac{\text{Lb.}}{\text{Hr}}$$

$$\text{Emission Rate} = \left(1.0 \times 10^{-5} \frac{\text{Lb.}}{10^6 \text{ BTU}} \right) \left(10 \times \frac{10^6 \text{ BTU}}{\text{TON}} \right) = 1.0 \times 10^{-6} \frac{\text{Lb.}}{\text{TON}}$$

$$\begin{aligned} \text{Be concentration} &= \left(1.0 \times 10^{-5} \frac{\text{Lb.}}{\text{Hr.}} \right) \left(\frac{\text{Hr.}}{60 \text{ min}} \right) \left(\frac{\text{min}}{24 \times 60 \text{ dsec}} \right) \left(\frac{7000 \text{ gr}}{\text{Lb.}} \right) \\ &= 4.4 \times 10^{-8} \text{ gr/dscf} \end{aligned}$$

POTENTIAL ANNUAL EMISSION

$$\begin{aligned} \text{Be} &= \left(1.0 \times 10^{-5} \frac{\text{Lb.}}{\text{Hr.}} \right) (2) \left(\frac{24 \text{ Hr.}}{\text{Day}} \right) \left(\frac{365 \text{ Days}}{\text{Yr.}} \right) \left(\frac{\text{Ton}}{2000 \text{ Lb.}} \right) = 9 \times 10^{-5} \frac{\text{Ton}}{\text{Yr.}} \\ &\sim 1 \times 10^{-4} \frac{\text{Ton}}{\text{Yr.}} \end{aligned}$$

STACK DISCHARGE RATE

Basis: 2 units to single stack

$$\text{Be} = \left(1.0 \times 10^{-5} \frac{\text{Lb.}}{\text{Hr.}} \right) (2) = 2 \times 10^{-5} \frac{\text{Lb.}}{\text{Hr}}$$

$$\text{Be} = \left(2 \times 10^{-5} \frac{\text{Lb.}}{\text{Hr.}} \right) \left(\frac{454 \text{ g}}{\text{Lb.}} \right) \left(\frac{\text{Hr.}}{3600 \text{ sec}} \right) = 2.5 \times 10^{-6} \text{ g/s}$$



LGM ENGINEERS CONSTRUCTORS

JOB NO. 35463.01SHEET NO. 19 OF 21DATE 3/7/96JOB NAME NRG COMPUTED BY RVCSUBJECT SULFURIC ACID MIST EMISSION CHECKED BY WKR

Basis for estimate:

$$\text{H}_2\text{SO}_4 \text{ Emission Factor} = (1.5\%) (\text{SO}_2 \text{ Emission Rate})$$

$$\text{SO}_2 \text{ Emission Rate} = 3 \text{ lb./ton MSW}$$

Emission Rate Each Unit

$$\text{Emission Rate} = (0.015) \left(0.3 \frac{\text{lb}}{10^6 \text{ BTU}} \right) = 0.0045 \frac{\text{lb}}{10^6 \text{ BTU}}$$

$$\text{Emission Rate} = \left(0.0045 \frac{\text{lb}}{10^6 \text{ BTU}} \right) \left(\frac{10 \times 10^6 \text{ BTU}}{\text{ton}} \right) = 0.045 \frac{\text{lb}}{\text{ton}}$$

$$\text{Emission Rate} = \left(0.0045 \frac{\text{lb}}{10^6 \text{ BTU}} \right) \left(10^4 \times \frac{10^6 \text{ BTU}}{\text{hr}} \right) = 0.47 \frac{\text{lb}}{\text{hr}}$$

$$\begin{aligned} \text{H}_2\text{SO}_4 \text{ Concentration} &= \left(0.47 \frac{\text{lb}}{\text{hr}} \right) \left(\frac{\text{hr}}{60 \text{ min}} \right) \left(\frac{\text{min}}{26750 \text{ dscf}} \right) \left(\frac{7000 \text{ gr}}{\text{lb}} \right) \\ &= 0.002 \text{ gr/dscf} \end{aligned}$$

POTENTIAL ANNUAL EMISSION

$$\text{H}_2\text{SO}_4 = \left(0.47 \frac{\text{lb}}{\text{hr}} \right) (2) \left(\frac{24 \text{ hr}}{\text{day}} \right) \left(\frac{365 \text{ day}}{\text{yr}} \right) \left(\frac{1 \text{ ton}}{2000 \text{ lb}} \right) = 4.1 \frac{\text{ton}}{\text{yr}}$$

STACK DISCHARGE RATE

Basis: 2 units to single stack

$$\text{H}_2\text{SO}_4 = \left(0.47 \frac{\text{lb}}{\text{hr}} \right) (2) = 0.9 \frac{\text{lb}}{\text{hr}}$$

$$\text{H}_2\text{SO}_4 = \left(0.9 \frac{\text{lb}}{\text{hr}} \right) \left(\frac{454 \text{ g}}{\text{lb}} \right) \left(\frac{\text{hr}}{3600 \text{ sec}} \right) = 0.11 \text{ g/s}$$



LGM ENGINEERS CONSTRUCTORS

JOB NO. 95A63.01

SHEET NO. 20 OF 21

DATE 3/3/86

JOB NAME NRG

COMPUTED BY RVC

SUBJECT HCl EMISSION FACTOR

CHECKED BY WET

| REFERENCE | HCl EMISSION FACTOR | | | Lb./10 ⁶ BTU |
|-----------|---------------------|------|------|-------------------------|
| | LOW | HIGH | AVG. | |

CARB 1984

| | | | | |
|------------------|--------|-------------------------------|-----------------------------|------|
| Tampa MSW Est. | | | 0.3% HCl | |
| % Discharge Est. | | | 50% | 0.30 |
| Summary p. 113 | 70 ppm | 605 ppm | 227 ppm | |
| | 0.18 | 0.73 | 0.26 Lb/10 ⁶ BTU | 0.26 |
| Nashville | 0.14 | 0.34 | 0.22 Lb/10 ⁶ BTU | |
| Braintree | 10,000 | 13,700 gr/10 ⁶ BTU | | 1.95 |
| Babylon | 0.50 | 0.67 | 0.57 Lb/10 ⁶ BTU | 0.6 |
| Gallatin | 0.25 | 1.84 | 0.70 Lb/10 ⁶ BTU | 0.7 |
| Saugus | | | 0.73 Lb/10 ⁶ BTU | 0.7 |
| E. Hamilton | 0.3 | 0.6 | 0.4 Lb/10 ⁶ BTU | 0.4 |

Battelle

Summary 3.4 Lb/ton 0.34

Sommer, E., et al

Gallatin 5.3 Lb/ton 0.53

Ozvacic, V., et al.

Toronto 5 Lb/ton 0.5

SWARU 5.5 Lb/ton 0.55

NRG UNCONTROLLED HCl EMISSION FACTOR

HCl PRESENT = 0.6 Lb/10⁶ BTU (EST.)

HCl FUTURE = 0.9 Lb./10⁶ BTU (Projected)



LGM ENGINEERS CONSTRUCTORS

JOB NO. 95463.01SHEET NO. 21 OF 21DATE 3/3/86JOB NAME NRGCOMPUTED BY RVCSUBJECT HCl EMISSIONCHECKED BY WBRBasis for estimate: $0.9 \text{ Lb./}10^6 \text{ BTU}$

EMISSION RATE EACH UNIT

$$\text{Emission Rate} = 0.9 \text{ Lb./}10^6 \text{ BTU}$$

$$\text{Emission Rate} = \left(0.9 \frac{\text{Lb}}{10^6 \text{ BTU}}\right) \left(\frac{10 \times 10^6 \text{ BTU}}{\text{Ton}}\right) = 9 \frac{\text{Lb}}{\text{Ton}}$$

$$\text{Emission Rate} = \left(0.9 \frac{\text{Lb}}{10^6 \text{ BTU}}\right) \left(\frac{10^4 \times 10^6 \text{ BTU}}{\text{Hr}}\right) = 93.6 \frac{\text{Lb}}{\text{Hr}}$$

$$\begin{aligned} \text{HCl concentration} &= \left(93.6 \frac{\text{Lb}}{\text{Hr}}\right) \left(\frac{\text{Hr}}{60 \text{ min}}\right) \left(\frac{\text{min}}{20750 \text{ dscf}}\right) \left(\frac{7000 \text{ gr}}{\text{Lb.}}\right) \\ &= 0.4 \text{ gr/dscf} \end{aligned}$$

POTENTIAL ANNUAL EMISSION

$$\text{HCl} = \left(93.6 \frac{\text{Lb.}}{\text{Hr.}}\right) (2) \left(\frac{24 \text{ Hr.}}{\text{Day}}\right) \left(\frac{365 \text{ Day}}{\text{Yr.}}\right) \left(\frac{\text{Ton}}{2000 \text{ Lb.}}\right) = 820 \frac{\text{Ton}}{\text{Yr.}}$$

STACK DISCHARGE RATE

Basis: 2 units to single stack

$$\text{HCl} = \left(93.6 \frac{\text{Lb.}}{\text{Hr.}}\right) (2) = 187 \frac{\text{Lb.}}{\text{Hr.}}$$


$$\text{HCl} = \left(187 \frac{\text{Lb.}}{\text{Hr.}}\right) \left(\frac{454 \text{ g}}{\text{Lb.}}\right) \left(\frac{\text{Hr.}}{3600 \text{ sec}}\right) = 23.6 \text{ g/s}$$

FIGURE 1


SITE LOCATION
NRG/RECOVERY GROUP
LAKE COUNTY WASTE TO ENERGY FACILITY

CENTER HILL QUADRANGLE
FLORIDA
7.5 MINUTE SERIES (TOPOGRAPHIC)

26° 14' 55" N
81° 52' 30" W
LEESBURG EAST




SCALE 1:24 000



CONTOUR INTERVAL 5 FEET
DATUM IS MEAN SEA LEVEL



FIGURE 2



| | | | | |
|-----|---------|-------------------------------|----|-------|
| NO. | DATE | DESCRIPTION | BY | CHKD. |
| 1 | 1-15-86 | ISSUED FOR PERMIT | AS | AS |
| 2 | 1-15-86 | ISSUED FOR OPERATION & MAINT. | AS | AS |
| 3 | 1-15-86 | ISSUED FOR CONSTRUCTION | AS | AS |
| 4 | 1-15-86 | ISSUED FOR CONSTRUCTION | AS | AS |

IGM
LOW ENGINEERS, CONSULTANTS

NRG/RECOVERY GROUP, INC.
WASTE TO ENERGY FACILITY
LAKE COUNTY, FLORIDA


SITE PLAN

Scale: 1" = 40' (Graphic Scale F.T.)

DATE: 1-15-86
BY: AS
CHKD.: C

FIGURE 3


AF 36420A



TYPICAL FOR ONE
TWO REQUIRED

| | | | |
|---|--------------------------|--|--|
| LGM | | <small>INTERNATIONAL ASSOCIATION OF ENGINEERS AND ARCHITECTS 1914-1915</small> | |
| LGM ENGINEERS CONSTRUCTORS | | | |
| LAKE COUNTY WASTE TO ENERGY FACILITY OKAHUMPKA, FLA. | | | |
| TITLE: FUEL AIR COMBUSTION FLOW DIAGRAM | | | |
| Drawn By: <u>W.S.L.</u> | Eng. Plot: <u>W.S.L.</u> | | |
| Checked By: _____ | Plot Op: _____ | | |
| Coord. Chk: _____ | Chkd: _____ | | |
| Scale: <u>1/8" = 1'-0"</u> | Date: <u>5-8-85</u> | Rev: <u>A</u> | |
| Job No. _____ | Draw. No. <u>M-101</u> | | |


FIGURE 4



TYPICAL FOR ONE
TWO REQUIRED

| | | | |
|---|--|---|---------------------|
| LGM | | 13500 Highway 200, Inc. Aurora, Illinois 60009 (815) 897-1000 | |
| LGM ENGINEERS CONSTRUCTORS | | | |
| LAKE COUNTY WASTE TO ENERGY FACILITY OKAHUMPKA, FLA. | | | |
| Title ASH SYSTEM FLOW DIAGRAM | | | |
| Drawn By: BRG | Checked By: BRG | Scale: 1/8"=1'-0" | Date: 5-8-85 |
| Design: BRG | Project: LAKE COUNTY WASTE TO ENERGY FACILITY | Sheet: 1 | Rev: A |
| Job No. M-100 | Drawn No. M-100 | | |

FIGURE 5



LGM ENGINEERS CONSULTANTS
 LAKE COUNTY
 WASTE TO ENERGY
 FACILITY
 OKAHUMPKA, FLA.

THIS STEAM, WATER & AIR
 FLOW DIAGRAM

| | |
|----------------|-------------------------|
| Drawn By: SAUL | Checked By: [Signature] |
| Scale: NONE | Date: 5-9-85 |
| Job No.: | Draw. No. M-102 |

TWO

PREVENTION OF SIGNIFICANT DETERIORATION REPORT
FOR THE PROPOSED
NRG/RECOVERY GROUP
LAKE COUNTY WASTE TO ENERGY FACILITY
AT LAKE COUNTY, FLORIDA

MARCH 11, 1986

PREFACE

This PSD report has been prepared by LGM Engineers Constructors and Dames and Moore for the review of regulatory officials and interested parties. It is the objective of the report to provide a complete and thorough description of the proposed facility and its potential air quality impact. Questions regarding facility design, engineering, emissions estimates, and BACT analysis should be directed to Bob Chalfant of LGM Engineers Constructors. Questions regarding dispersion modeling and impact assessment may be directed to Bob Chalfant or to George Howroyd of Dames and Moore.

Robert V. Chalfant, P.E.
LGM Engineers Constructors
Lockwood Greene Engineers, Inc.
1330 West Peachtree Street, NW
Atlanta, Georgia 30367
(404) 873-3261

George C. Howroyd, Ph.D., P.E.
Dames & Moore
455 East Paces Ferry Road
Suite 200
Atlanta, Georgia 30363
(404) 262-2915

1.0 INTRODUCTION

NRG/Recovery Group of Lakeland, Florida is a private developer of waste-to-energy resource recovery facilities. NRG/Recovery Group (NRG) proposes to install a new municipal solid waste (MSW) energy conversion facility having a design capacity of 500 tons per day near Leesburg, Florida in Lake County.

The waste-to-energy facility (WTE) will mass burn unprepared MSW in two waterwall incinerator/boiler units each having a capacity of 250 tons MSW per day. The incinerator/boiler units will generate high pressure steam for the purpose of generating electric power with conventional steam turbine - generator equipment. The facility will employ state-of-the-art incinerator/boilers and air pollution control equipment that will meet or exceed all current regulatory requirements to control emissions.

This report constitutes a complete application for a Prevention of Significant Deterioration (PSD) permit for construction of the proposed Lake County Waste to Energy Facility. It is intended to comply will all applicable federal and Florida air pollution control regulatory requirements. Information contained in this report includes the following:

1. A description of the proposed facility and air pollution control equipment.
2. Potential air pollutant emissions resulting from the proposed facility and the applicable air quality regulations.
3. A demonstration that the PSD preconstruction ambient air monitoring requirement is exempted for the proposed facility.
4. A demonstration that the emission control technology associated with the proposed facility is in conformance with Best Available

Control Technology. (BACT) requirements for applicable air pollutants.

5. An atmospheric dispersion modeling analysis demonstrating that the proposed facility is in conformance with PSD increments and National Ambient Air Quality Standards (NAAQS).
6. A growth related air quality impact analysis and assessment of air quality impacts on soil, vegetation, and visibility associated with the proposed facility.

2.0 PROJECT DESCRIPTION

2.1 General

There is a contractual agreement between Lake County and NRG for Lake County to deliver its residential and commercial MSW to NRG, up to the 500 tons per day capacity of the facility. Lake County has interlocal agreements with Leesburg, Tavares, Eustis, Mt. Dora and Clermont. Lake County anticipates the initial annual delivery to be 120,000 tons MSW per year.

The NRG facility will dramatically reduce the Lake County landfill burden and is an important part of community planning. The residue from incineration at NRG will be disposed of by the County at its Astatula Landfill. While volume reduction is the primary purpose of the facility, electric power generation makes this project economically viable for NRG.

This section presents a description of the proposed facility and its associated air pollution control equipment.

2.2 Site Description

The proposed facility is to be located in Jim Rogers Industrial Park off Florida State Road 33 approximately three-quarters of a mile southeast of the community of Okahumpka and five miles south of Leesburg.


The site includes 15.24 acres within the property boundary and is in a rural location bound by land that was primarily dedicated to citrus groves. The WTE facility itself is confined to approximately 6 acres within the overall property site with the remaining property utilized for percolation ponds and buffer zone areas.

FIGURE 1


SITE LOCATION
NRG/RECOVERY GROUP
LAKE COUNTY WASTE TO ENERGY FACILITY

CENTER HILL QUADRANGLE
FLORIDA
7.5 MINUTE SERIES (TOPOGRAPHIC)

96°14' SE
LEESBURG EAST




SCALE 1:24 000



CONTOUR INTERVAL 5 FEET
DATUM IS MEAN SEA LEVEL



FIGURE 2



| | | | | |
|---|------|-------------|----|-----|
| 1 | DATE | DESCRIPTION | BY | CHK |
| 2 | DATE | DESCRIPTION | BY | CHK |
| 3 | DATE | DESCRIPTION | BY | CHK |
| 4 | DATE | DESCRIPTION | BY | CHK |
| 5 | DATE | DESCRIPTION | BY | CHK |

LMV
LMV ENGINEERS CONSTRUCTORS

NRG/RECOVERY GROUP, INC.
WASTE TO ENERGY FACILITY
LAKE COUNTY, FLORIDA

SITE PLAN

DATE: 1-15-06
SCALE: AS SHOWN
PROJECT: 05463.02

-5-

The discharge stack will be located at approximate UTM coordinates 413.12 East and 3179.26 North in UTM Zone 17.


2.3 Process Description

Waste will be received from municipal and/or contractor trucks principally on a five day a week basis. Trucks will be routed to an enclosed waste pit with multiple unloading bays. The waste pit will have approximately four days storage volume (1800 tons). Overhead cranes with grapple feeders will distribute the waste to the combustion equipment. Combustion air fans will take suction from the enclosed unloading and waste pit area to aid in ventilation and provide odor control.

The waste will be distributed to two boilers for combustion and generation of steam. The combustion system for each boiler will consist of a waste hopper, hydraulic ram feeder and reciprocating grates. The combustion process will be controlled by modulating feed rate, reciprocating grates, undergrate combustion air and overfire air. Furnace draft will be controlled by modulating inlet dampers to the induced draft fan.

The fuel supply will be Lake County MSW supplemented with up to twenty-five percent of total heat input with wood chips having a heat value of 4,500 BTU/lb. at fifty percent moisture content. The total daily input of combined fuels per unit shall not exceed the total heat input from 250 TPD of 5,000 BTU/lb. MSW only. The intent is to utilize wood only at times when there is a deficiency of MSW.

FIGURE 3




-7-

TYPICAL FOR ONE
TWO REQUIRED

| | | | |
|---|--------------------|---|------------|
| LGM | | LGM ENGINEERS CONSTRUCTORS 1000 S.W. 10th St. Fort Lauderdale, FL 33304 | |
| LGM ENGINEERS CONSTRUCTORS | | | |
| LAKE COUNTY WASTE TO ENERGY FACILITY OKAHUMPKA, FLA. | | | |
| Title: FUEL AIR, COMBUSTION FLOW DIAGRAM | | | |
| Drawn By: ELA/JL | Eng. P.M. J. J. J. | Checked By: | Proj. Dir. |
| Coord. CA | Chart | | |
| Scale: NONE | Date: 5-8-85 | Rev.: | A |
| Job No. | Draw No. M-101 | | |

FIGURE 4




-8-

TYPICAL FOR ONE
TWO REQUIRED

| | | | |
|---|-----------|---|------------|
| LGM | | 125 ENGINEERING DIVISION ANN ARBOR, MICHIGAN 48106 | |
| LGM ENGINEERS CONSTRUCTORS | | | |
| LAKE COUNTY WASTE TO ENERGY FACILITY OKAHUMPKA, FLA. | | | |
| Title ASH SYSTEM FLOW DIAGRAM | | | |
| Drawn By | RAUL | Eng. P.L. | (125) (20) |
| Checked By | | Proj. Dir. | |
| Coord. Eng. | | Exec. | |
| Scale | 1/2" = 1' | Date | 5-8-85 |
| Job No. | | Rev. | A |
| | | No. | M-100 |

FIGURE 5

AF 38420A



-9-

LGM
 LGM ENGINEERS CONSTRUCTORS

LAKE COUNTY
 WASTE TO ENERGY
 FACILITY
 OKAHUMPKA, FLA.

THE STEAM, WATER & AIR
 FLOW DIAGRAM

| | |
|------------------|----------------------|
| Drawn By: MSA/JL | Eng. P.M. G.P. & S. |
| Checked By: | Prof. Dr. |
| Coord. Eng. | Chem. |
| Scale: NONE | Date: 5-9-85 Rev: 13 |
| Job No.: | No. M-102 |

The furnace shall have a gross heat liberation rate not to exceed 10,000 BTU/cu. ft. to insure maximum destruction of volatile organic components and minimum products of incomplete combustion.

The steam generator shall be of the water tube type. Normal steam flow per unit shall be 60,000 lb./hr. net (at 250 TPD of MSW). Steam conditions shall be 650 PSIG and 755°F with a feedwater temperature of 228° F.

The steam from the two boilers will be used to generate power with a single extraction-condensing turbine generator having a nominal capacity of 12.3 megawatts.

Particulate emissions are proposed to be controlled by a three field electrostatic precipitator (ESP) serving each boiler. Each induced draft fan will discharge to a free standing stack 125 feet in height.

2.4 Emission Sources and Controls

The potential sources of emissions include the regulated incinerator/boilers and fugitive sources. Fugitive emissions could potentially come from the waste receiving and storage pit and the ash handling system.

Dust can be generated during handling of the waste. The waste will be discharged, stacked and reclaimed with an overhead grapple and then fed to the incinerators. Unless the waste is very dry, these

operators do not generate visible dust. Rigo & Rigo Associates reports that at the Resource Authority in Sumner County Waste-to-Energy Plant (incineration system) at Gallatin, Tennessee, Cooper engineers measured dust levels in the storage pit area less than 10 mg/m³. Similar dust levels have been observed and reported for operations at: North Little Rock, Arkansas; Franklin, Ohio; and Baltimore, Maryland. It is also reported that ambient high volume air monitors located up-wind and down-wind of the North Little Rock plant were unable to detect any fugitive emissions from the facility. Odor, which may be associated with the waste, cannot be quantitatively assessed, but it should only rarely be detectable outside the waste building and should not be detectable at the property line. Dust and odor will be controlled by locating the combustion air intakes over the storage and feed hopper areas keeping the area under negative pressure and directing these pollutants to the incinerator combustion chamber.

Fugitive emissions are not expected from the ash handling system. The incinerator bottom ash and the ESP flyash handling systems are totally enclosed conveyors operating under negative pressure and only discharge the ash residue in the enclosed housings to the ash drag-out or water spray conditioning systems. As a result, ash removed from the incinerator system will be moistened and will not be subject to dusting. Ash deposited in the removal containers should have 20 to 35% moisture.

In consideration of the fugitive dust controls to be employed and the fact that there are not references or emission factors indicating these areas to be a source of quantifiable emissions, potential emissions are projected to be negligible.

The primary source and only quantifiable source of emissions is the combustion process. Emissions of air pollutants from incineration depend largely upon the waste type and quantity to be combusted, which may vary significantly from day to day and from one geographic location to another, and upon the combustion process and emission controls. The facility will receive Lake County residential and commercial refuse. Any waste, inadvertently delivered to the facility, which cannot be incinerated will be sorted and separated by the loader operators. Separated materials may include non-burnable wastes such as tree stumps, white goods and hazardous materials such as gas cylinders that might normally be collected with MSW. This material will be trucked off site for appropriate disposal. Wood chips may be received to supplement the MSW waste input. NRG will not accept hazardous waste or waste of a special nature incompatible with the facility design. Standard plant operating procedures will counteract the accidental or illicit disposal of these wastes at the NRG facility.

Each incinerator unit will be capable of incinerating 250 tons of MSW per 24 hour day. The incinerator will be a reciprocating grate type with controlled under fire and over fire air for optimum combustion conditions. The rate of combustion will be controlled by modulating the amount of primary and secondary air, the rate of waste feed, and the waste detention time in the combustion chamber. This method of control will be utilized to maintain heat rate to the boiler system and control steam flow. Good gas flow control is ensured by the design of the incinerator package, mixing and burning of the waste,

and the use of primary and secondary air. The products of combustion will be mixed and burned to completion within the incinerator.

Gaseous pollutants such as sulfur dioxide, acid gases, and trace element contaminants in the flue gas are largely a fact of the waste analysis and the amount of retention with the ash. Gaseous pollutants such as CO and NO_x are somewhat dependent upon the incinerator design and operating conditions. Particulate matter is emitted as a result of incomplete combustion of fuel as well as entrainment of noncombustibles in the flue gas stream. Particulate may exist as solids or aerosols. The size of these particles range from less than 0.1 micron to more than 500 microns. In some instances, the particles may contain metals or polycyclic organic matter.

When solids are burned particulate matter comes from three sources: inorganic substances, organometallic substances, or the fuel molecules themselves. Inorganic matter is not destroyed during the combustion process, and most of this material remains as bottom ash. Turbulent mixing during combustion result in the entrainment of some of these inorganic materials as fly ash. High temperatures and oxidizing conditions can result in volatilization and oxidation of organometallic compounds present in solid fuels. As a result, the metallic portion of the organometallic compounds may appear as inorganic oxides or metal salts in the flue gases. Fuel molecules themselves can contribute a significant portion of particulate matter emissions resulting from combustion of solid fuels. Little is known about the

exact mechanisms of particle formation. However, it is known that pyrolytic reactions occurring near the fuel bed can lead to formation of large organic molecules. Further growth of these molecules may be induced by inorganic materials that act as nucleation sites. It is also possible that organic particles can result from self nucleation. Agglomeration processes lead to larger aggregates of small particles.

The size and quantity of particles emitted from solid fuel combustion depends on such factors as residence time, temperature, oxidizing/reducing conditions of the furnace, and trace chemistry of the particles and fuel. Long residence times allow for more complete burnout of organic particles with a commensurate decrease in particle size and mass. High temperatures and oxidizing conditions promote more complete combustion.

The grate system and refractory walled section of the incinerator is designed to maintain combustion temperatures in the range of 1800°F in the lower refractory walled section of the combustion chamber. The radiant waterwall section of the combustion chamber cools the flue gases to approximately 1300°F before entering the superheater section of the boiler. The flue gases must be cooled to prevent excessive slagging and high temperature corrosion of the boiler tubes. The design furnace heat release rate is low, in the range of 10,000 BTU/cu. ft. hr., to provide long residence time for more complete combustion of the fuel and to minimize products of incomplete combustion. At design capacity and fuel conditions the furnace residence time to 1800°F is greater than 1 second and furnace residence time to 1500°F is greater than 3 seconds.

The reciprocating grate system design is relatively long and narrow with a gross heat release rate not to exceed 300,000 BTU/sq. ft. hr. to provide for maximum burnout of the combustible portion of the waste fuel. The forced draft fans are provided with steam coil air heaters to be used to assist in drying the waste fuel on the grates and improving combustion when incoming fuel is excessively wet.

Particulate laden gases leaving the boiler are directed to an electrostatic precipitator for particulate control before being discharged to the atmosphere through a common 125 ft. stack serving the two units. The stack will have either a common flue serving the two units or two flues contained in a common shell stack.

2.5 Project Schedule

The projected start of construction is July 1986 and initial start of operation is December 1987.

2.6 Operating Schedule

The project operating schedule is 24 hours per day, 7 days per week. Each unit will have an annual maintenance shutdown, however, these are not yet scheduled. Emission potentials are based on 100 percent capacity, while the actual capacity factor is projected to be closer to 85 percent.

3.0 PROJECT EMISSION SOURCE INFORMATION

3.1 Emission Sources and Emission Rates

As indicated previously, this project will involve only one primary point source of emission, namely the single exhaust stack serving two municipal solid waste energy recovery mass burn incinerators. Each of these units will have a capacity of 250 tons per unit, for a total facility capacity of 500 tons/day. The waste will be distributed to two boilers for combustion and the generation of steam. The fuel supply will be Lake County Municipal solid waste (MSW) supplemented (with up to 25 percent of total heat input) with wood chips. A summary of the maximum emission rates for the two boilers combined is provided in Table 3-1. The emission stack parameters are provided in Table 3-2.

The estimated annual emissions (ton/yr) for each of the pollutants listed in Table 3-1 are shown in Table 3-3. Also shown are the EPA-defined significant emission rates for use in determining pollutant applicability for PSD review. As illustrated in the table, the pollutants that will be emitted in quantities greater than the EPA-defined levels of significant emission are SO₂, NO_x, PM, CO, Hg, and F⁻. The reader will note that no significant emission rate has been defined for HCl emissions. This pollutant was included in the analysis at the request of FDER.

The estimated emission rates and proposed emission limitations are based on numerous governmental and private industry reports and personal communications. These data are considered to be more

TABLE 3-1

SUMMARY OF CONTROLLED POTENTIAL EMISSION RATES
FROM THE PROPOSED NRG WASTE TO ENERGY FACILITY

| <u>MAXIMUM EMISSION RATES^a</u> | <u>lb/hr</u> | <u>g/s</u> |
|--|----------------------|------------------------|
| Sulfur Dioxide (SO ₂) | 125.3 | 15.80 |
| Nitrogen Oxides (NO _x) | 104.0 | 13.12 |
| Particulate Matter (PM) | 13.8 | 1.74 |
| Carbon Monoxide (CO) | 92.8 | 11.70 |
| Lead (Pb) | 0.25 | 0.03 |
| Volatile Organic Compounds (VOC) | 8.3 | 1.05 |
| Mercury (Hg) | 0.15 | 0.02 |
| Fluorides (F ⁻) | 1.25 | 0.16 |
| Beryllium (Be) | 2 x 10 ⁻⁵ | 2.5 x 10 ⁻⁶ |
| Asbestos (As) | Neg ^b | - |
| Vinyl Chloride (CH ₂ CHCl) | Neg ^b | - |
| Sulfuric Acid Mist (H ₂ SO ₄) | 0.9 | 0.11 |
| Hydrogen Sulfide (H ₂ S) | Neg ^b | - |
| Hydrogen Chloride (HCl) | 187 | 23.6 |
| Total Reduced Sulfur (TRS) | Neg ^b | - |
| Reduced Sulfur Compounds (RSC) | Neg ^b | - |

a Worst case hourly emissions from both units.

b Negligible emissions (O'Connell, et al., 1982).

TABLE 3-2

STACK PARAMETERS FOR NRG UNITS No. 1 and No. 2

STACK CHARACTERISTICS

| | | |
|----------------------------------|---------------|----------|
| Exhaust Stack Height | 125.0 ft. | 38.1 m |
| Stack Exit Diameter ^a | 6.0 ft. | 1.83 m |
| Stack Gas Exit Velocity | 65.6 ft./sec. | 20.0 m/s |
| Stack Gas Exit Temperature | 350°F | 450°K |

INCINERATOR BUILDING DIMENSIONS:

| | | |
|--------|-----------|--------|
| Height | 72.0 ft. | 22.0 m |
| Length | 125.0 ft. | 38.1 m |
| Width | 65.0 ft. | 19.8 m |

- ^a The single stack will have either a single flue 6'-0" diameter combining the two gas flows or two flues each 4'-3" diameter.

TABLE 3-3

SOURCE APPLICABILITY DETERMINATION

| <u>Pollutant</u> | <u>Potential Annual Emissions (tons/yr)^a</u> | <u>Significant Emission (tons/yr)^b</u> | <u>PSD Pollutant Applicability</u> |
|--------------------------------|---|---|------------------------------------|
| SO ₂ | 547 | 40 | Yes |
| NO _x | 455 | 40 | Yes |
| PM | 60 | 25 | Yes |
| CO | 101 | 100 | Yes |
| Pb | 1.1 | 0.6 | Yes |
| VOC | 36 | 40 | No |
| Hg | 0.6 | 0.1 | Yes |
| F ⁻ | 5.5 | 3 | Yes |
| Be | 0.0001 | .0004 | No |
| As | - | .007 | No |
| CH ₂ CHCl | - | 1 | No |
| H ₂ SO ₄ | 4 | 7 | No |
| H ₂ S | - | 10 | No |
| HCl | (547 to 820) ^c | N/A ^c | N/A |
| TRS | - | 10 | No |
| RSC | - | 10 | No |

a Based on 500 tons MSW/day, 365 days/yr.

b As defined by EPA

c No significant emission rate is defined for HCl.

reliable than the U.S. EPA Report No. AP-42, Compilation of Air Pollutant Emission Factors. To account for waste variability, average emission factors were adjusted upward on a pollutant specific basis to arrive at "worst-case" hourly emission rates for all regulated pollutants. While the MSW fuel may be supplemented with wood chips, emissions are based on 100 percent MSW fuel, because it is projected that for all regulated pollutants emissions should be equivalent or less when burning mixed MSW and wood chip fuel.

Stack gas characteristics are based on calculated exhaust gas flow rate at capacity with 82 percent excess air at the boiler exit plus in-leakage at the ESP. Exhaust gas temperature is based on a low vendor estimate and a 25°F drop in temperature across the flues and ESP resulting in a 350°F outlet temperature. If vendor equipment having a higher exhaust gas temperature is selected, effective plume height should be greater and modeling results should be lower than those included in this report.

3.2 Derivation of Emission Rates

3.2.1 Sulfur Dioxide

There is no applicable sulfur dioxide standard. Sulfur dioxide emissions are a result of the sulfur content of the waste fuel and rate of conversion to sulfur dioxide. Review of numerous test results finds a wide range of sulfur dioxide emissions from less than 1 lb./ton MSW to over 7 lb./ton MSW. A 1984 California Air Resources Board (CARB) report, Air Pollution Control at Resource Recovery Facilities, states that Florida refuse has approximately 0.3 percent sulfur and that refractory wall mass burning facilities release approximately 25 percent of the sulfur

as SO₂, with the remaining sulfur distributed in the grate ash and fly ash. A Battelle report indicates a 50 percent retention factor. These sulfur content and retention values would indicate a sulfur dioxide emission rate in the range of 3 to 6 lb./ton MSW, and we presently find most test results in the range of 3 lb. SO₂/ton MSW. For NRG the expected initial average emission is around 3 lb./ton MSW and the maximum expected and requested limit is 6 lb./ton MSW.

3.2.2 Nitrogen Oxides

There is no applicable NO_x standard. The emission of nitrogen oxides from combustion sources are due to the conversion of nitrogen in the fuel to nitrogen oxides and the fixation of atmospheric nitrogen. Emission factors are in the range of 4 lb./ton MSW (0.4 to 0.5 lb./million BTU), and emissions at NRG are projected to be less than 0.5 lb./million BTU input.

3.2.3 Particulate Matter

Each 250 TPD waste fuel boiler has a design heat input rating of approximately 100 million BTU/hr., which is at the lower end of applicability of proposed Subpart Db NSPS. The proposed standard is 0.10 lb./million BTU (0.045 grains/dscf corrected to 12% CO₂). The existing Subpart E standard is 0.08 grains/dscf. The projected uncontrolled emission factors for the vendor units under consideration are 40 to 90 lb./ton MSW. NRG proposes to install an electrostatic precipitator designed for 98.5% to

99% control and having an emission limit of 0.067 lb./million BTU (0.03 grains/dscf corrected to 12% CO₂). Average emissions are expected to be less than this value.

3.2.4 Carbon Monoxide

There is no applicable standard for carbon monoxide. Carbon monoxide emissions from a well tuned boiler are normally negligible. Boiler design for good turbulent mixing and use of fuel/air ratio controls insures that excess oxygen does not fall below necessary levels for near complete combustion of the fuel. It is projected that carbon monoxide levels in the exhaust gas should average less than 400 ppm (0.45 lb./million BTU) over an eight hour period and that the long term average should be in the range of 100 ppm.

3.2.5 Lead

There is no applicable lead emission standard. The predicted uncontrolled lead emission factor is 0.3 lb./ton MSW. The proposed ESP should provide better than 96% control of potential lead emissions for estimated emission rate of 0.012 lb./ton MSW.

3.2.6 Volatile Organic Compounds (VOC)

There is no applicable emission standard for VOC. As with carbon monoxide, emissions of VOC are minimized by good design and combustion practices. As long as carbon monoxide emissions are below 400 ppm, emissions of VOC are very small.

Emissions of VOC are projected to be less than 0.04 lb./million BTU.

3.2.7 Mercury

Trace amounts of mercury have been found in the emissions of MSW incinerators. Reported emission factors are primarily in the range of 0.003 to 0.007 lb./ton MSW. A conservative emission factor of 0.007 lb./ton MSW has been chosen as an emission estimate.

3.2.8 Fluorides

There is no applicable emission standard for fluorides from MSW incinerators. However, traces of hydrogen fluoride from the combustion of fluorinated plastics or similar materials appear in the flue gas of MSW incinerators. Average test results at existing facilities range from 0.03 to 0.08 lb./ton MSW. A conservative fluoride emission factor of 0.06 lb./ton MSW has been projected.

3.2.9 Beryllium

Very little data exist regarding the emission of beryllium from MSW incineration, and the data that are available offer a wide range of emission factors. The ESP should provide greater than 98% control, and the emission rate of beryllium is projected to be less than 1.0×10^{-6} lb./ton MSW.

3.2.10 Asbestos

No emission of asbestos is projected because it is not likely to be present in the waste streams in any significant quantity. Strict environmental regulations preclude disposal of asbestos in the NRG facility, and NRG will not receive demolition type waste which might contain asbestos.

3.2.11 Vinyl Chloride

Vinyl chloride is used primarily as a feedstock for production of PVC and will not be disposed of in the NRG facility. Also, if present it would not be likely to survive the combustion conditions in its original toxic form. There is no available data in the literature that can be used to derive any meaningful emission rate.

3.2.12 Sulfuric Acid Mist

Very little data is available on sulfuric acid emissions from MSW incineration. The reaction carrying SO₂ to sulfuric acid mist is highly dependent upon variable combustion conditions. Estimates have projected conversion rates of approximately 1.5 percent of the SO₂ emission rate or 0.04 lb./ton MSW.

3.2.13 Hydrogen Sulfide, Total Reduced Sulfur, Reduced Sulfur Compounds

Hydrogen sulfide, total reduced sulfur and other reduced sulfur compounds are not expected to be present in the flue gas. These compounds, if formed in the precombustion process, will be converted principally to SO₂.

3.2.14 Hydrogen Chloride

There is no applicable hydrogen chloride emission standard, and HCl is not regulated under PSD. However, HCl is a pollutant of concern. HCl emission is determined by fuel chlorine content and rate of conversion to HCl. The CARB report indicates conversion in the range of 50 percent for mass burning units and chlorine content for Florida waste in the range of 0.3 percent by weight.

Emission test reports indicate average HCl emission rates in the range of 2 to 6 lbs./ton MSW with excursions higher. The chlorine content of MSW is expected to increase in the future. For review purposes the initial HCl emission rate is expected to be less than 6 lb./ton MSW with the future average emission rate going as high as 9 lb./ton MSW.

3.3 Stack Height

Federal stack height regulations (40 CFR 51.1, 50FR27892, July 8, 1985) require that the maximum stack height used to predict the concentration of pollutants in the ambient air be no taller than that dictated by Good Engineering Practice (GEP). GEP stack height is the greater of:

- 1) 65 meters; or
- 2) H_g , where H_g is given by the following equation:

$$H_g = H + 1.5 H_L, \text{ where}$$

H = height of nearby structure(s)

H_L = lesser dimension (height or projected width) of nearby structure(s).

The GEP stack height for this facility calculated by method (2) is approximately 180 ft. (54.8m) based on the boiler house dimensions given in Table 3-2. The proposed stack height for this facility is 125 ft. (38.1m) which is less than the GEP stack height, thereby necessitating the consideration of building wake and downwash effects in the dispersion modeling analysis (Section 7.0).

4.0 APPLICABLE REGULATIONS

4.1 Applicable Pollutants

Expected emission rates for the NRG/Recovery Group MSW energy recovery facility were previously given in Section 3.0. As discussed in that section, emissions for sulfur dioxide (SO₂), nitrogen dioxide (NO₂), particulate matter (PM), carbon monoxide (CO), and lead (Pb) will each be emitted in quantities greater than EPA's defined significant emission rates. As a result, an ambient air quality impact analysis and demonstration of Best Available Control Technology (BACT) will be required for each of these pollutants. Additionally, emissions of mercury (Hg) and fluoride (F⁻) will also be emitted in excess of EPA's significant emission rates. Since no ambient standards exist for these pollutants, it is only necessary to demonstrate BACT for those pollutants. VOC emissions are expected to be less than EPA's significant emission rate, therefore no further analysis of this pollutant is required.

4.2 Ambient Air Quality Impact Analysis Requirements

The ambient limits with which the proposed project must comply are the National Ambient Air Quality standards for SO₂, NO₂, CO, PM, and Pb, and the PSD Class II and Class I increments for SO₂ and PM. These limits are listed in Table 4-1. Compliance with ambient limits is discussed in Section 7.0.

Also listed in Table 4-2 are the "significant" impact levels for SO₂, NO₂, CO, and PM. When the ambient concentrations at a particular

TABLE 4-1

APPLICABLE AMBIENT AIR QUALITY LIMITS
AND SIGNIFICANT IMPACT LEVELS
(Concentrations in $\mu\text{g}/\text{m}^3$)

| Pollutant and Averaging Period | National Ambient Air Quality Standards | | PSD Increments | | Significant Impact Levels |
|---|---|--------------------|------------------|-----------------|------------------------------|
| | Primary | Secondary | Class II | Class I | |
| <u>SO₂</u> | | | | | |
| 3-Hour | --- | 1,300 ^a | 512 ^a | 25 ^a | 25 |
| 24-Hour | 365 ^a | --- | 91 ^a | 5 ^a | 5 |
| Annual | 80 | --- | 20 | 2 | 1 |
| <u>NO₂</u> | | | | | |
| Annual | 100 | 100 | N/A ^b | N/A | 1 |
| <u>PM</u> | | | | | |
| 24-Hour | 260 ^a | 150 ^a | 37 ^a | 10 ^a | 5 |
| Annual | 75 | -- | 19 | 5 | 1 |
| <u>CO</u> | | | | | |
| 1-Hour | 40,000 ^a | -- | N/A | N/A | 2,000 |
| 8-Hour | 10,000 ^a | -- | N/A | N/A | 500 |
| <u>Pb</u> | | | | | |
| 3 Month | 1.5 | -- | N/A | N/A | -- |

a Concentrations not to be exceeded more than once a year.

b N/A denotes no increments applicable.

location attributable to a given emission source are below these levels, the impact of the source at that location is considered insignificant. Correspondingly, "significant impact area" refers to the area from the source to the distance at which the source no longer produces a significant impact.

In addition to showing compliance with ambient limits, a PSD impact analysis must also comment on the potential for adverse effects on visibility, vegetation and soils, and on the air quality consequences of any industrial, commercial, or residential growth associated with the proposed project. These requirements are covered in Section 8.0.

4.3 Emission Limits and Performance Standards

The only emission limit regulations applicable to this project are FDER regulation 17-2.600(1)(c), and the proposed Federal New Source Performance Standard for Incinerators, 40 CFR 60, Subpart Db. The State of Florida regulation limits PM emissions to 0.08 grains/dscf, corrected to 12 percent CO₂, and specify that no objectionable odor is allowed. There are no Florida emission limit regulations applicable to this project for any other pollutant. Proposed federal new source performance standards (NSPS) for Industrial-Commercial-Institutional Steam Generating Units (40 CFR 60 Subpart Db) as proposed June 19, 1984 (49FR25146) would limit PM emissions from this facility to 0.10 lb/million BTU heat input (which equates to approximately 0.045 grains/dscf, corrected to 12 percent CO₂). There are no existing or proposed federal emission limits applicable to this project for any other pollutant.

Emission limits for all pollutants that will be emitted from this facility will necessarily result from a judgement on what constitutes Best Available Control Technology for this facility. BACT is discussed in Section 5.0.

4.4 Preconstruction Ambient Air Quality Monitoring Requirements

PSD regulations require an analysis of ambient air quality in the area of the proposed project at the time an application is submitted. An acceptable means for doing this is to establish an air quality monitoring program specifically for project permitting needs. In lieu of preconstruction monitoring, the applicant has three alternatives:

1. Provide support to show that available data from nearby existing monitoring stations are representative.
2. Show through modeling that the maximum concentration attributable to the project will probably be less than the de minimis impact level.
3. Show through modeling of existing emission sources (with addition of a suitable background concentration to account for sources not specifically modeled) that predicted current concentrations are less than the de minimis level, and therefore that little if anything would be detected if a monitoring program were carried out.

As will be shown in Section 7, support for an exemption from preconstruction monitoring has been developed for SO₂ based on alternative No. 3. The predicted impact of the emissions of all other pollutants from the NRG facility is less than EPA's de minimis levels for those pollutants, thereby providing for an exemption from monitoring for all pollutants.

5.0 BEST AVAILABLE CONTROL TECHNOLOGY ANALYSIS

5.1 Pollutants and Emission Sources Requiring BACT Analysis

The proposed Lake County Waste to Energy Facility is a major stationary source, and as such, PSD regulations require that best available control technology (BACT) be applied for each pollutant subject to regulation under the Act that the source has the potential to emit in significant amounts. The pollutants subject to BACT analysis are sulfur dioxide (SO₂), nitrogen oxides (NO_x), particulate matter (PM), carbon monoxide (CO), lead (Pb), mercury (Hg) and fluorides (F⁻). A summary of the proposed BACT emission limitations is given in Table 5-1.

5.2 Comparative Analysis of Alternative Flue Gas Treatment Technology

Pollutant emission controls fall into the category of combustion modifications or flue gas emission controls. Each applicable flue gas emission control has impact on a multiple of pollutants.

Flue gas emission control systems having demonstrated applicability to MSW incineration were considered for the NRG facility. Wet scrubbing for particulate and gaseous emission control was determined not to be applicable for the proposed facility because the site location is in a rural area without sewer service, and wastewater from scrubber blowdown could not be disposed of in an acceptable manner. Two devices for dry particulate control were given consideration: an electrostatic precipitator (ESP) and a baghouse. The ESP is utilized successfully on most existing MSW incineration facilities. An in depth evaluation of applicability of a baghouse was undertaken, and it was

TABLE 5-1

SUMMARY OF PROPOSED BACT EMISSION LIMITATIONS AND CONTROL
TECHNOLOGIES FOR LAKE COUNTY WASTE TO ENERGY FACILITY

| <u>Pollutant</u> | <u>Proposed BACT Emission Limit</u> | | <u>Control Technology</u> |
|--------------------|-------------------------------------|--|---|
| | <u>lb./million BTU</u> | <u>gr/dscf corrected to 12% CO₂</u> | |
| Sulfur Dioxide | 0.6 | 0.27 | Low sulfur fuel |
| Nitrogen Oxides | 0.5 | 0.23 | Combustion Controls |
| Particulate Matter | 0.067 | 0.03 | ESP |
| Carbon Monoxide | 0.45 | 0.20 | Combustion Control to 400 ppm 8 hr. avg. |
| Lead | 0.0012 | 0.0005 | ESP |
| Mercury | 0.0007 | 0.0003 | ESP |
| Fluorides | 0.006 | 0.0027 | ESP |

determined from vendors and users that a baghouse alone without additive injection would have severe potential for blinding problems and unacceptable bag life due to chemical attack. Both the ESP and baghouse are applicable to particulate control when used in conjunction with lime slurry spray dryer systems for sulfur dioxide and acid gas control, including HCl reduction.

ESP alone, baghouse with spray dryer system and ESP with spray dryer system were determined to be flue gas emission control alternatives for the NRG facility. These systems were compared with regard to emission reduction and operating costs. It was determined that particulate alone could be controlled by the ESP for an annual cost of approximately \$136 per ton of particulate controlled. The incremental cost for a spray dryer system to remove sulfur dioxide and acid gases would be approximately \$1,200 per ton of gaseous pollutant controlled. The added cost to the local government and waste haulers for gaseous control would be approximately \$4.50 per ton of MSW delivered to the NRG facility. The capital and operation and maintenance costs including energy, are summarized in Table 5-2, and the pollutant reduction and economic comparison of the pollution control alternatives is given in Table 5-3.

5.3 BACT for Sulfur Dioxide

There is no applicable sulfur dioxide emission standard for MSW incineration systems. Larger coal fired boiler systems are allowed 1.2 lb./million BTU under present NSPS for that category. The

TABLE 5-2

CAPITAL AND O & M COSTS FOR ALTERNATIVE
POLLUTION CONTROL STRATEGIES
(\$1000)

| | <u>ESP</u> | <u>Baghouse w/Spray Dryer</u> | <u>ESP w/Spray Dryer</u> |
|-------------------------------------|------------|-----------------------------------|------------------------------|
| <u>Capital Costs</u> | | | |
| <u>Capital Cost</u> | 2,100 | 4,200 | 4,500 |
| Annualized ⁽¹⁾ | 294 | 588 | 630 |
| <u>O & M</u> | | | |
| Power ⁽²⁾ | 34 | 148 | 67 |
| Op. Labor ⁽³⁾ | 30 | 120 | 120 |
| Maintenance ⁽⁴⁾ | 42 | 100 | 114 |
| Chemical Cost ⁽⁵⁾ | - | 79 | 88 |
| Bag Replacement ⁽⁶⁾ | - | 60 | - |
| <u>Waste Disposal⁽⁷⁾</u> | <u>-</u> | <u>20</u> | <u>20</u> |
| Total O & M | 106 | 527 | 409 |
| <u>Total Annualized Cost</u> | 400 | 1,115 | 1,039 |

-
1. 14% lease rate
 2. \$0.08/Kwh, base i.d. fan power cost is with ESP
 3. Base shift labor rate \$30,000/yr. including benefits, 4 shifts/week
 4. BH 1%, ESP 2%, spray dryer systems 3%
 5. 85% annual capacity factor, 150,000 tons MSW/yr.
 6. Bag replacement 50%/yr., \$50/bag, \$10 installation, approx. 1000 bags/bh
 7. Added cost for acid reagent disposal at \$10/ton

TABLE 5-3

POLLUTANT REDUCTION AND ECONOMIC COMPARISON
OF POLLUTION CONTROL ALTERNATIVES

| | <u>ESP</u> | <u>Baghouse</u> w/Spray Dry | <u>ESP</u> w/Spray Dry |
|--|--------------|--------------------------------|---------------------------|
| Particulate Reduction ⁽¹⁾ Tons/yr. (% of 3000) | 2950 (98.3%) | 2967 (98.9%) | 2950 (98.3%) |
| Acid Gas Reduction ⁽¹⁾ | | | |
| SO ₂ tons/yr. (% 225) | - | 180 (80%) | 135 (60%) |
| F, SO ₃ tons/yr. (% 6) | - | 5 (90%) | 5 (90%) |
| <u>HCl tons/yr. (% 450)</u> | <u>-</u> | <u>405 (90%)</u> | <u>405 (90%)</u> |
| Total Gas | 0 | 590 (87%) | 545 (80%) |
| Total Pollutant Removed | 2950 | 3557 | 3495 |
| Annualized Cost \$1000/year | 400 | 1115 | 1039 |
| \$/Ton Pollutant Removed | 136 | 313 | 297 |
| Increment \$/Ton Acid Gas Removed | - | 1212 | 1173 |
| \$/Ton MSW | 2.67 | 7.43 | 6.92 |
| Increment \$/Ton MSW for Acid Gas Removal | - | 4.77 | 4.26 |

1. Based on average emission rate and annual capacity factor, 150,000 tons MSW/yr.

BACT/LAER Compilation for Refuse Incineration includes BACT emission limitations ranging from 0.2 to 1.3 lb./million BTU.

NRG proposes a BACT emission limitation of 0.6 lb./million BTU. This is accomplished without add-on flue gas controls and is well within the range of low sulfur fuel fired combustion systems.

The alternative lime slurry spray dryer system with an ESP or a baghouse could possibly accomplish a 70 percent reduction of SO₂ and 90 percent reduction of acid gases, but at significant cost. The installation of the dry scrubber system could add over \$2.0 million in capital investment and \$400,000 in annual operation and maintenance. The incremental cost for SO₂ and acid gas removal is approximately \$1,200 per ton of pollutant removed, and the added cost, to dispose of the waste is \$4.50 to \$5.00 per ton MSW. It is proposed that a lime slurry spray dryer system is excessively costly and would impose an unreasonable economic burden on the residents of Lake County.

The flue gas SO₂ control system would have minimal environmental benefit. Projected impact without control is well within accepted standards. The potential for upset conditions and reliability problems would be dramatically increased requiring the bypass of gaseous and particulate emission controls. Water usage would be significantly increased over current requirements. Increased solid waste products would be generated.

5.4 BACT for Nitrogen Oxides

There is no applicable MSW incineration standard for nitrogen oxides. The BACT/LAER compilation includes BACT emission limitations ranging from 0.3 to 0.7 lb./million BTU.

NRG proposes a BACT emission level for NO_x of 0.5 lb./million BTU. Furnace design and combustion controls provide for emission control. Grate burning with over fire air provides for staged combustion, which is recognized to reduce emissions. Injection systems and flue gas controls are rejected as being unproven and unnecessary. Operation at low excess air is rejected as having a detrimental effect on control of CO and products of incomplete combustion.

5.5 BACT for Particulate Matter

The most stringent particulate emission standard for MSW incineration is the proposed Subpart Db for industrial boilers larger than 100 million BTU input/hr. The proposed units at 100 million BTU/hr. are just at the lower size limit of applicability. The proposed standard is 0.10 lb./million BTU (0.045 grains/dscf corrected to 12% CO₂). The BACT/LAER compilation includes BACT emission limitations for particulate matter ranging from 0.044 lb./million BTU (0.02 gr./dscf) to 0.11 lb./million BTU (0.05 yr./dscf).

NRG proposes a BACT emission limitation of 0.067 lb./million BTU (0.03 gr./dscf corrected to 12% CO₂). The proposed limitation is well within the standards.

As demonstrated in the comparative analysis of alternative controls, the cost of alternative fabric filter systems with lime injection is excessively costly. The projected ambient impact resulting from the proposed emission level is less than significant, and it is believed that additional reduction of particulate matter emissions is unjustified.

5.6 BACT for Carbon Monoxide

There is no applicable carbon monoxide emission standard for MSW incineration. BACT/LAER compilation includes BACT emission limitations for CO ranging from 0.1 to 0.5 lb./million BTU.

NRG proposes a BACT emission limit for CO of 0.45 lb./million BTU (400 ppm corrected to 12% CO₂). Furnace design and combustion controls provide for emission control.

5.7 BACT for Lead, Mercury and Fluorides

There are no applicable emissions standards for lead, mercury or fluoride emissions from MSW incineration. These elements are found in trace amounts in MSW.

NRG proposes that an effective ESP is BACT for these pollutants and that additional emission reduction is unnecessary.

6.0 EXISTING AIR QUALITY CONDITIONS

6.1 Other Emission Sources

As is discussed in Section 7.0, the only pollutant for which NRG emissions are predicted to result in a significant ambient air quality impact (as defined by EPA) is SO₂. Therefore, in evaluating the interaction of the NRG facility with other emission sources, it is only necessary to consider sources of SO₂. To assist in the impact modeling analysis, FDER supplied a comprehensive source inventory of all PSD and baseline SO₂ emission sources in the area that might interact with emissions from the proposed NRG facility. The source inventory was developed by FDER and was based in part on the predicted radius of influence of NRG's SO₂ emissions of 8 km (see Section 7.0) and FDER's knowledge of the area.

FDER's emission source inventory consisted of only one source with significant SO₂ emission potential. That source is Asphalt Production Coporation near Leesburg, Florida. The emissions and emission source characteristics for this source are as follows:

Source: Asphalt Production Corporation

UTM Location: 407.1 E, 3180 9N

SO₂ Emission Rate: 20.0 lb./hr.

Stack Height: 25 ft.

Stack Diameter: 7.5 ft.

Stack Temperature: 165°F

Stack Velocity: 15.1 ft./sec.

This source is a baseline source and does not consume PSD increment. There are no existing or permitted PSD increment consuming sources in the area.

6.2 Existing Air Quality

As previously discussed, the only pollutant predicted to result in "significant" impact is SO₂. As will be shown in Section 7.0, the ambient ground-level concentrations of all other pollutants are predicted to be less than EPA's defined levels of significant impact. Therefore existing or background levels of those pollutants need not be considered.

There are no nearby ambient air quality monitors presently being operated that can provide air quality data representative of the site. The closest monitor is located at Zellwood, approximately 30 km east of the site and only monitors for particulate matter. There are no other monitors being operated within 50 km of the site.

Due to the relatively remote nature of the proposed site it is expected that ambient levels of all pollutants will be very low in the area and that no threat to any ambient standard exists.

6.3 PSD Class I and Nonattainment Areas

The nearest PSD Class I area is the Chassahowitzka National Wilderness area about 70 km west of the NRG site. There are no other Class I areas within 100 km of the site. There are no nonattainment areas within 50 km of the proposed facility site.

7.0 MODELING METHODOLOGY

The dispersion modeling analyses documented here were designed to assess the impact on ambient air quality of the proposed MSW energy recovery facility. The dispersion model, meteorological data, modeling methodology, and results are described in this section.

7.1 Dispersion Model

Dispersion modeling results were obtained by using EPA's Industrial Source Complex (ISC) Model (EPA, 1979). The short-term version of this model (ISCST) was used to determine both short-term (24-hours or less) and annual average concentrations.

7.2 Meteorological Data

Meteorological input data required for the ISCST model were supplied by the FDER. Five years of hourly data were made available covering the period 1974 through 1978. These data are based on hourly surface observations made at the Orlando airport National Weather Service (NWS) station and twice daily upper air balloon soundings from the NWS station at Tampa, Florida. The data were supplied in a format for direct use in the model without further processing. These data sets have previously been used by FDER for air quality evaluations in this area, and are the most recent data available in a processed format for modeling.

7.3 Receptor Grids

The general procedure for determining maximum concentrations in the vicinity of the site was to perform initial modeling using a grid spacing of 0.5 or 1.0 km. For areas within the grid where higher concentrations were predicted, a more refined analysis was performed using a grid spacing of 0.1 km for short-term averaging periods. A polar coordinate system was utilized for all analyses, with a radial spacing of 10 degrees (10°, 20°, 30° etc.). For modeling of the proposed facility alone, only offsite concentrations were considered.

The determination of the significant impact area of the proposed facility was made using a greater receptor ring spacing than discussed above. Range distances used in this analysis extended out to distances of up to 12 km.

The actual receptor grids used in the analyses are specifically identified in the computer printouts contained in Appendix A.

7.4 Other Modeling Considerations

The ISCST model contains options that determine the way in which calculations are made. The choice of options was made consistent with the normally recommended approach; for example, gradual plume rise calculations were used in conjunction with the building wake effects option and final plume rise calculations were used when wake effects were not considered. Options were also selected consistent

with the land use and topography of the site area. Specifically, the site environment was treated as a rural, level-terrain area.

The ISCST model is not considered suitable for evaluating short-term concentrations during calm or very light wind conditions. Therefore, all short-term modeling results were checked for the possible influence of calm winds and EPA's calm wind adjustment method was utilized where necessary. (U.S. Environmental Protection Agency, 1984).

7.5 Modeling Results

7.5.1 Maximum Facility Impact and Significant Impact Area

The emissions from the proposed NRG facility have previously been discussed in Section 3.0. As indicated in that section, the emissions of SO₂, NO_x, PM, CO, Pb, Hb, and F⁻ from this facility are all expected to be greater than the EPA-Defined levels of significant emission, and an ambient air quality modeling analysis must be performed for each of these pollutants. No other regulated pollutants will have a significant rate of emission as a result of the operation of this facility. The emissions and source data for the above mentioned pollutants were used in the dispersion modeling analysis to determine the significant impact area (as defined by the radius of influence) and the maximum impact of the proposed facility.

A determination of the consumption of PSD increments and a demonstration of compliance with the NAAQS must be made within the above-mentioned radii of influence. The radii of influence for

this facility have been determined by dispersion modeling of SO₂, NO_x, PM, and CO. There are no significant impact levels defined for Pb, Hg, and F⁻. The size of this region of influence is characterized by the distance (radius) at which ground-level concentrations (that result from facility emissions) fall below the following levels of significant concentrations defined by EPA (43FR26398):

| Pollutant | Significant Impact Level (µg/m ³) | | | | |
|-----------------|---|---------|--------|--------|--------|
| | Annual | 24-Hour | 8-Hour | 3-Hour | 1-Hour |
| SO ₂ | 1 | 5 | -- | 25 | -- |
| NO ₂ | 1 | -- | -- | -- | -- |
| PM | 1 | 5 | -- | -- | -- |
| CO | -- | -- | 500 | -- | 2000 |

The ISCST program was used to determine the radius of influence for each of the above pollutants. Ground level concentrations for each averaging period were calculated at distances of up to 12 km using a polar receptor grid.

The results of this analysis are shown in Table 7-1. As can be seen, the maximum radius of influence for SO₂ was found to be 8 km, based on the highest predicted concentrations for the 24-hour averaging period using 1974 data. For NO₂, PM, and CO, the radius of influence was predicted to be zero, with the maximum predicted concentrations for each pollutant being less than their respective significant impact levels. As a result, no further modeling of those pollutants is required.

TABLE 7-1

SUMMARY OF MAXIMUM PREDICTED RADII OF SIGNIFICANT
IMPACT FOR SO₂ RESULTING FROM THE OPERATION OF THE
PROPOSED NRG WASTE TO ENERGY FACILITY

| <u>YEAR</u> | <u>PREDICTED RADIUS OF SIGNIFICANT IMPACT (km)^a</u> | | |
|-------------|--|----------------|---------------|
| | <u>ANNUAL</u> | <u>24-HOUR</u> | <u>3-HOUR</u> |
| 1974 | 0 | 8.0 | 1.7 |
| 1975 | 0 | 6.0 | 1.5 |
| 1976 | 0 | 5.0 | 1.5 |
| 1977 | 0 | 7.0 | 2.0 |
| 1978 | 0 | 6.0 | 3.0 |

^a Based on highest predicted concentrations.

The maximum predicted concentrations of SO₂ from this facility are summarized in Table 7-2. As can be seen, the highest predicted annual average SO₂ concentration is 0.9 µg/m³ and was obtained using both the 1976 and 1978 meteorological data. Highest predicted 24-and 3-hour SO₂ concentrations were 29 µg/m³ and 78 µg/m³, which were obtained using the 1976 and 1978 data, respectively. Also shown in the table are the locations at which the highest concentrations were predicted and the days on which the short-term concentrations were calculated. The reader will note that all of the short-term concentrations reported in Table 7-2 were predicted at a distance of 200 meters from the source. The reason that these values were predicted at such a close distance (the closest average offsite distance) was that building wake and downwash effects were included in the analysis. Analysis made without downwash and wake effect result in predicted concentrations that were approximately 35 percent of those given in Table 7-2.

Maximum predicted concentrations of Pb for the annual and 24 hour averaging periods (i.e. as determined by ratioing the results of the SO₂ impact analysis according to the ratio of Pb to SO₂ emissions) were 0.002 and 0.06 Mg/m³, respectively. Although there are no significant impact levels defined for Pb, the highest predicted 24 hour concentration is less than the de minimis impact level of 0.1 Mg/m³. Inasmuch as there are no other sources of lead in the area, no further modeling analysis of this pollutant should be required.

TABLE 7-2

SUMMARY OF MAXIMUM PREDICTED SO₂ CONCENTRATIONS
 ATTRIBUTABLE TO THE OPERATION OF THE PROPOSED
 NRG WASTE TO ENERGY FACILITY

| YEAR | SO ₂ CONCENTRATION (µg/m ³) ^a | | |
|------|---|---------------------|---------------------|
| | ANNUAL | 24-HOUR | 3-HOUR |
| 1974 | 0.6 [1500, 180°] | 24 [200, 180°, 279] | 66 [200, 10°, 354] |
| 1975 | 0.7 [1000, 360°] | 20 [200, 340°, 12] | 70 [200, 360°, 290] |
| 1976 | 0.9 [1500, 180°] | 29 [200, 180°, 302] | 68 [200, 110°, 17] |
| 1977 | 0.8 [1500, 360°] | 28 [200, 180°, 40] | 70 [200, 110°, 51] |
| 1978 | 0.9 [1000, 270°] | 27 [200, 120°, 53] | 78 [200, 360°, 25] |

^a Locations of highest predicted concentrations and associated meteorological episodes (for short-term) concentrations given as follows:

ANNUAL: [Distance (m), Direction (°)]

24-,3-HOUR: [Distance (m), Direction (°); Julian Day]

7.5.2 Compliance with PSD Class II Increments

Presently, the only pollutants for which PSD increments exist are SO₂ and PM. Inasmuch as the projected impact of this facility on ambient PM concentrations is less than the significance levels for PM, it is necessary only to demonstrate that the proposed emissions of SO₂ from this facility will not result in an exceedance of the PSD increments at any location. Since there are no existing or permitted PSD increment consuming sources in the area (refer to Section 6.0), the only source that will consume any increment will be the proposed NRG waste to energy facility.

In light of these facts, the maximum annual, 24-hour, and 3-hour concentrations obtained for this facility (based on highest predicted concentrations using five years of data) will be representative of increment consumption in the vicinity of the site. These results, compared with the Class II increments are:

| <u>Averaging Period</u> | <u>Maximum SO₂ Concentration (PSD Increment Consumption) (µg/m³)</u> | <u>Class II PSD Increment (µg/m³)</u> |
|-------------------------|--|--|
| Annual | 0.9 | 20 |
| 24-Hour | 29 | 91 |
| 3-Hour | 78 | 512 |

As can be seen, the maximum percentage consumption of the annual, 24-hour, and 3-hour increments are 5, 32, and 15 percent, respectively.

7.5.3 Compliance with PSD Class I Increments

The nearest PSD Class I area is Chassahowitzka National Wilderness area about 70 km west of the NRG site. Pollutant emissions from this facility are not expected to result in any measurable impact on this PSD Class I area, due to its distance from the site. To verify this, the SO₂ emissions from this facility were modeled, using 1974 meteorological data, in the Class I area. The maximum predicted annual, 3-hour and 24-hour concentrations were 0.04, 4.3, and 0.8 µg/m³, all of which are well below the PSD Class I increment levels set by EPA (Table 4-1).

7.5.4 Compliance with Ambient Air Quality Standards

The purpose of this section is to demonstrate that the operation of the proposed NRG facility will not cause or contribute to a violation of the NAAQS for any pollutant. Inasmuch as SO₂ is the only pollutant for which this facility will result in a significant impact, it is necessary only to address that pollutant.

As explained in Section 6.0, there is only one source of SO₂ emissions (existing or permitted) in the area. This source is Asphalt Production Corporation, which is located approximately 6 km to the west of the proposed NRG site. The SO₂ emissions and emission source characteristics for this source were provided in Section 6.0.

The methodology employed to determine the maximum predicted ground-level SO₂ concentration (for comparison with the NAAQS) was to model the existing SO₂ source using five years of data and a receptor grid in the vicinity of the NRG maximum impact area (i.e., within 0.5 km of the NRG stack) and then conservatively add

the highest results obtained to the corresponding maximum impacts attributable to the NRC facility. Table 7-3 summarizes these results. A review of the results reveals that the maximum predicted percentage consumption of the NAAQS are:

| <u>Averaging Period</u> | <u>Maximum Percentage Consumption of NAAQS (%)</u> |
|-------------------------|--|
| Annual | 1.3 |
| 24-Hour | 8.6 |
| 3-Hour | 7.1 |

The reader will note that no ambient background concentrations have been included in these results. FDER guidance suggests that background concentrations in this area are so low that they can be expected to be on the order of the sensitivity threshold of the monitoring instrumentation. In light of these very low concentrations, it is clearly evident that the emissions from this facility will in no way threaten or cause an exceedance of the NAAQS for SO₂.

7.5.5 Preconstruction Ambient Monitoring Exemption

The purpose of this section is to provide a justification for an exemption from the ambient air monitoring requirements as discussed in Section 4.4. This exemption is being sought on the basis of a less than de minimis impact of existing and permitted sources of SO₂ in the vicinity of the proposed site and a less than de minimis impact of the proposed facility for all other pollutants. The predicted existing source impacts were previously shown in Table 7-3. As can be seen, the predicted 24-hour SO₂ concentrations from the existing sources are less than the de minimis monitoring exemption level of 13 µ/gm³. Furthermore,

TABLE 7-3

COMPARISON OF MAXIMUM POSSIBLE SO₂ CONCENTRATIONS
WITH NAAQS IN THE VICINITY OF THE PROPOSED NRG
WASTE TO ENERGY FACILITY

| <u>Predicted SO₂ Concentrations (µg/m³)</u> | | | | | |
|---|-------------------------|--|--|--------------|---------------------------------|
| <u>YEAR</u> | <u>Averaging Period</u> | <u>A</u> | <u>B</u> | <u>A + B</u> | <u>NAAQS (µg/m³)</u> |
| | | Existing Sources (µg/m ³) ^a | NRG Facility (µg/m ³) ^a | | |
| 1974 | Annual | 0.1 | 0.6 | 0.7 | 80 |
| | 24-Hour | 3.9 | 24.0 | 27.9 | 365 |
| | 3-Hour | 19.1 | 66.0 | 85.1 | 1300 |
| 1975 | Annual | 0.2 | 0.7 | 0.9 | 80 |
| | 24-Hour | 5.7 | 20.0 | 25.7 | 365 |
| | 3-Hour | 18.4 | 70.0 | 88.4 | 1300 |
| 1976 | Annual | 0.1 | 0.9 | 1.0 | 80 |
| | 24-Hour | 2.5 | 29.0 | 31.5 | 365 |
| | 3-Hour | 15.4 | 68.0 | 83.5 | 1300 |
| 1977 | Annual | 0.1 | 0.8 | 0.9 | 80 |
| | 24-Hour | 2.7 | 28.0 | 30.7 | 365 |
| | 3-Hour | 13.3 | 70.0 | 83.3 | 1300 |
| 1978 | Annual | 0.1 | 0.9 | 1.0 | 80 |
| | 24-Hour | 2.6 | 27.0 | 29.6 | 365 |
| | 3-Hour | 13.7 | 78.0 | 91.7 | 1300 |

with the exception of the 24-hour value for 1975, all predicted concentrations are less than EPA's significant impact levels. (In fact, the highest second-highest values are all less than the significant impact levels). For all other pollutants, predicted concentrations of all other pollutants attributable to the operation of the NRG facility itself are less than both the respective de minimis and significant impact levels. Therefore, preconstruction ambient monitoring should not be required for this facility for any pollutant.

7.5.6 Impact of Hydrogen Chloride (HCl) Emissions

At the request of FDER an assessment was made of the impact of HCl emissions on ambient ground-level concentrations. As stated in Section 3.0, maximum HCl emissions from this facility are expected to be 187 lb./hr. [23.6 g/s]. On the basis of the modeling analyses performed for SO₂, the maximum hourly ground-level HCl concentration is estimated to be approximately 150 µg/m³. This estimate was obtained by scaling the maximum 3-hour NRG SO₂ results by the ratio of HCl to SO₂ emissions and estimating the 1-hour concentration by using a conversion ratio of 0.8 for 3-hour to 1-hour concentrations (U. S. Environmental Protection Agency, 1977).

For comparison purposes, the published threshold limit value (TLV) (American Conference of Governmental Industrial Hygienists, 1985) for HCl is 7000 µg/m³. This TLV is published as a ceiling value that should not be exceeded in areas of human exposure. Repeated human exposures at levels below this TLV are considered to be permissible

with no adverse effects. Given the fact that the highest predicted HCl concentration is only about 2 percent of the TLV for HCl, there should be no adverse health effects associated with HCl emissions from this facility.

8.0 ADDITIONAL IMPACT ANALYSIS

8.1 Visibility Effect

The visibility impact of SO₂ emissions from NRC's proposed MSW incinerator was assessed on the Chassahowitzka Class I area using EPA's Level-1 Screening Analysis method (U. S. Environmental Protection Agency, 1980). With this method, three contrast parameters are calculated and compared with a reference value of 0.10. If the absolute values of all of the contrast parameters are less than the reference value, it is highly unlikely that adverse visibility impairment will result.

The first two contrast parameters, designated C₁ and C₂ were estimated to be .0006 and .0001, based on the proposed emissions of PM and NO_x. The third contrast parameter, C₃, represents a change in sky/terrain contrast caused by primary and secondary aerosols. It therefore depends in part on SO₂ emissions which lead to secondary aerosol formation. For the NRC facility, C₃ is computed to have an absolute value of .0002, thus indicating that SO₂ emissions are not likely to cause noticeable visibility impairment in the Class I area.

8.2 Vegetation and Soils Effects

Vegetation

As pointed out in a draft EPA document reviewing the effects of SO₂ on vegetation (U. S. Environmental Protection Agency, 1981), the response of vegetation to SO₂ exposure depends on a variety of factors such as pollutant dose (concentration times duration of exposure), the time of day at which exposure occurs, plant maturity

stage, and the stress which a plant may be undergoing as a result of disease organisms, soil moisture, and soil nutrient conditions. In addition, potential vegetation response to the presence of SO₂ vary from no detectable responses, to increased growth, to visible damage symptoms with no reduction in growth and yield, to reduction in growth and yield without visible symptoms, etc. Obviously, a detailed discussion of vegetation effects due to pollutant exposure is beyond the scope of this report.

One indicator of potential vegetation effects is a comparison of predicted ambient concentrations with ambient air quality standards. In particular, the 3-hour secondary SO₂ ambient standard was established to protect against adverse "welfare" effects such as vegetation damage. As discussed in Section 7.0, predicted 3-hour concentrations attributable to NRG facility emissions and all other sources within its radius of influence are well within the ambient standard for SO₂. Based on this comparison, vegetation damage due to operation of this facility is not likely.

Another indication that vegetation damage is unlikely can be found in the results of research on vegetation effects in the southeastern U.S. near coal-fired power plants (Jones and others, 1974). Based on visible injury, plant species were grouped into three categories of response to SO₂ exposure: sensitive, intermediate, and resistant. Among the sensitive species were Southern pines such as would be found in the vicinity of the NRG facility site. Even among these sensitive species, however, the concentrations estimated to produce

the injuries observed are considerably greater than those predicted for this project. Specifically, the 3-hour second-high concentrations due to the emission from this project and all other sources considered are well below the lower end of this range.

Soils

The direct addition of sulfur compounds to the soils in the vicinity of the NRG site poses little likelihood of adverse effects. The site is within an area where soils are considered sulfur deficient for agricultural purposes (U. S. Environmental Protection Agency, 1981).

Any contribution of SO₂ emissions to regional acid deposition could have some adverse effect on soils since the soils of this area by one estimate are considered medium in sensitivity to acidification (National Wildlife Federation, 1982). However, this project will increase existing SO₂ emissions within the site region by only a very small amount.

8.3 Air Quality Impact of Project Related Growth

Construction of the NRG MSW Energy Recovery facility will last approximately 20 months. Construction impact on air quality will consist mainly of the relatively minor amounts of pollutants emitted from construction equipment required for site preparation and from fugitive dust emissions. General construction vehicles (both gasoline and diesel-powered) and other diesel-powered engines will be used. These engines emit minor amounts of VOC, SO₂, CO, NO₂, and PM. The contaminants are expected to cause localized, temporary increases in existing air quality levels, but are not expected to cause any adverse impacts on or beyond the site boundary.

Fugitive dust emissions will probably be the most noticeable impact during construction. Dust associated with ground excavation, cut-and-fill operations, and other activities should add only minimally to existing background PM levels in the area. Various control techniques will be taken to prevent PM from becoming airborne.

The operation of the proposed facility will result in inconsequential population or commercial growth in the Lake County area. Several new jobs will be created to maintain and operate the proposed facility.

The majority of the plant employees will most likely live in the general area surrounding the plant. Emission increases due to additional residential housing or employee traffic in the plant site area resulting from the operation of the proposed facility are not expected to be significant.

9.0 REFERENCES

1. California Air Resources Board, Air Pollution Aspects of Resource Recovery, March 1980.
2. California Air Resources Board, Air Pollution Control at Resource Recovery Facilities, May 24, 1984.
3. Cooper Engineers, Inc., Air Emissions Tests of Solid Waste Combustion in a Rotary Combustor/Boiler System at Gallatin, Tennessee, Richmond, CA., 1983.
4. Edwards, L.O., et. al., "Trace Metals and Stationary Conventional Combustion Processes", Project Summary, EPA Report No. 600/S7-80-155, February 1981.
5. Hay, D., Finkelstein, A., and Klicius, R., "The National Incinerator Testing and Evaluation Program (NITEP)", Environmental Protection Services, Environment Canada, Ottawa, Ontario.
6. Jones, H., Weber, D., and Balsillie, F., 1974. "Acceptable Limits for Air Pollution Dosages and Vegetation Effect: Sulfur dioxide" Presented at the 67th Annual Meeting of the Air Pollution Control Association, Denver, Colorado, Paper No. 74-225.
7. National Wildlife Federation, 1982. "Acid Rain Vulnerability of the 27 States East of the Mississippi River". Presented at the 46th Annual Meeting, Milwaukee, Wisconsin.

8. O'Connell, W., Stotler, G., and Clark, R., Battelle's Columbus Laboratories, "Emissions and Emission Controls in Modern Municipal Incinerators", Proceedings of 1982 National Waste Processing Conference, American Society of Mechanical Engineers, pp. 285-297.
9. Ozvacic, V., et. al., "Emissions of Chlorinated Organics from Two Municipal Incinerators in Ontario", JAPCA, Vol. 35 No. 8, Aug. 1985, p. 849.
10. Rigo & Rigo Associates, "NEMMS Resource Recovery Project, Technical Description and Environmental Assessment", Unpublished report for NEMMS, Keene, New Hampshire, 1985.
11. Sommer, E., Kenny, G., Kearley, J., and Roos, C., "Effects of MSW Preprocessing on Thermal Conversion of MSW in Mass Burn Incineration", Executive Summary, DOE/SBIR Phase I Research, Contract No. DE-AC05-84ER80177, May 31, 1985.
12. Sussman, D.B., U.S. Environmental Protection Agency, Communication and summary of Municipal Waste Combustor Working Group Meeting, June 25, 26, 1985.
13. U. S. Environmental Protection Agency, 1975. "Compilation of Air Pollutant Emission Factors, Forth Edition". Office of Air Quality Planning and Standards, Publication No. AP-42.
14. U. S. Environmental Protection Agency, 1977. "Guidelines for Air Quality Maintenance Planning and Analysis Volume 10": Procedures for Evaluating Air Quality Impact of New Stationary Sources. Office of Air Quality Planning and Standards. EPA-450/4-77-001. October, 1977.

15. U. S. Environmental Protection Agency, 1979. "Industrial Source Complex (ISC) Dispersion Model User's Guide, Volume I." Office of Air Quality Planning and Standards, Publication No. EPA-450/4-70-030.
16. U. S. Environmental Protection Agency, 1980. "Workbook for Estimating Visibility Impairment". Office of Air Quality Planning and Standards, Publication No. EPA-450/4-80-031.
17. U. S. Environmental Protection Agency, 1981. "Air Quality Criteria for Particulate Matter and Sulfur Oxides, Volume III". Office of Health and Environmental Assessment, External Review Draft No. 2.
18. U. S. Environmental Protection Agency, 1983 (revised). "Regional Workshop on Air Quality Modeling: a Summary Report". Office of Air Quality Planning and Standards, Publication No. EPA-450/4-82-015, p. 5 and 5a.
19. U. S. Environmental Protection Agency, 1984. "Guideline on Air Quality Models (Revised)". Draft Document. Office of Air Quality Planning and Standards, November 1984.
20. Weston, Roy F., Inc., "Toxic Air Risk Assessment of the Proposed Greater Portland (Maine) Resource Recovery Facility", Unpublished report, October, 1985.

APPENDIX A
COMPUTER PRINT OUTS

SUMMARY OF MODELING RUNS

| <u>RUN NO.</u> | <u>DESCRIPTION</u> |
|----------------|---|
| IST 1-13 | NRG facility only - 1974-1978 met data. Includes separate runs to determine maximum concentration on selected days and to establish maximum radii of influence. |
| 14-18 | Existing SO ₂ sources only. Maximum impact in immediate vicinity of NRG site. |
| 19 | NRG facility only. 1974 met data used to check impact in Chassahowitzka Class I area. |

| | |
|---|----------------------|
| CALCULATE (CONCENTRATION=1, DEPOSITION=2) | ISW(1) = 1 |
| RECEPTOR GRID SYSTEM (RECTANGULAR=1 OR 3, POLAR=2 OR 4) | ISW(2) = 4 |
| DISCRETE RECEPTOR SYSTEM (RECTANGULAR=1, POLAR=2) | ISW(3) = 2 |
| TERRAIN ELEVATIONS ARE READ (YES=1, NO=0) | ISW(4) = 0 |
| CALCULATIONS ARE WRITTEN TO TAPE (YES=1, NO=0) | ISW(5) = 0 |
| LIST ALL INPUT DATA (NO=0, YES=1, MET DATA ALSO=2) | ISW(6) = 1 |
| | |
| COMPUTE AVERAGE CONCENTRATION (OR TOTAL DEPOSITION) | |
| WITH THE FOLLOWING TIME PERIODS: | |
| HOURLY (YES=1, NO=0) | ISW(7) = 0 |
| 2-HOUR (YES=1, NO=0) | ISW(8) = 0 |
| 3-HOUR (YES=1, NO=0) | ISW(9) = 1 |
| 4-HOUR (YES=1, NO=0) | ISW(10) = 0 |
| 6-HOUR (YES=1, NO=0) | ISW(11) = 0 |
| 8-HOUR (YES=1, NO=0) | ISW(12) = 0 |
| 12-HOUR (YES=1, NO=0) | ISW(13) = 0 |
| 24-HOUR (YES=1, NO=0) | ISW(14) = 1 |
| PRINT "N"-DAY TABLE(S) (YES=1, NO=0) | ISW(15) = 1 |
| | |
| PRINT THE FOLLOWING TYPES OF TABLES WHOSE TIME PERIODS ARE | |
| SPECIFIED BY ISW(7) THROUGH ISW(14): | |
| DAILY TABLES (YES=1, NO=0) | ISW(15) = 0 |
| HIGHEST & SECOND HIGHEST TABLES (YES=1, NO=0) | ISW(17) = 1 |
| MAXIMUM 50 TABLES (YES=1, NO=0) | ISW(18) = 1 |
| METEOROLOGICAL DATA INPUT METHOD (PRE-PROCESSED=1, CARD=2) | ISW(19) = 1 |
| RURAL-URBAN OPTION (RURAL=0, URBAN MODE 1=1, URBAN MODE 2=2) | ISW(20) = 0 |
| WIND PROFILE EXPONENT VALUES (DEFAULTS=1, USER ENTERS=2, 3) | ISW(21) = 1 |
| VERTICAL POT. TEMP. GRADIENT VALUES (DEFAULTS=1, USER ENTERS=2, 3) | ISW(22) = 1 |
| SCALE EMISSION RATES FOR ALL SOURCES (NO=0, YES>0) | ISW(23) = 0 |
| PROGRAM CALCULATES FINAL PLUME RISE ONLY (YES=1, NO=2) | ISW(24) = 2 |
| PROGRAM ADJUSTS ALL STACK HEIGHTS FOR DOWNWASH (YES=2, NO=1) | ISW(25) = 1 |
| | |
| INPUT SPECIAL DIRECTION-DEPENDENT BUILDING DIMENSIONS (YES=1, NO=0) | ISW(26) = 0 |
| | |
| OMIT TABLES FOR HOURLY CONCENTRATIONS (YES=1, NO=0) | ISW(27) = 0 |
| | |
| USEPA ADJUSTMENT FOR CALM HOURS (YES=1, NO=0) | ISW(28) = 1 |
| | |
| NUMBER OF INPUT SOURCES | NSOURC = 1 |
| NUMBER OF SOURCE GROUPS (=0, ALL SOURCES) | NGROUP = 0 |
| TIME PERIOD INTERVAL TO BE PRINTED (=0, ALL INTERVALS) | IPERG = 0 |
| NUMBER OF X (RANGE) GRID VALUES | NXPNTS = 5 |
| NUMBER OF Y (THETA) GRID VALUES | NYPNTS = 36 |
| NUMBER OF DISCRETE RECEPTORS | NXWYPT = 0 |
| SOURCE EMISSION RATE UNITS CONVERSION FACTOR | TK = 10000E+07 |
| ENTRAINMENT COEFFICIENT FOR UNSTABLE ATMOSPHERE | BETA1 = 0.500 |
| ENTRAINMENT COEFFICIENT FOR STABLE ATMOSPHERE | BETA2 = 0.500 |
| HEIGHT ABOVE GROUND AT WHICH WIND SPEED WAS MEASURED | ZR = 10.00 METERS |
| LOGICAL UNIT NUMBER OF METEOROLOGICAL DATA | IMET = 9 |
| DECAY COEFFICIENT FOR PHYSICAL OR CHEMICAL DEPLETION | DECAY = 0.000000E+00 |
| SURFACE STATION NO. | ISS = 12815 |
| YEAR OF SURFACE DATA | ISY = 74 |
| UPPER AIR STATION NO. | IUS = 12842 |
| YEAR OF UPPER AIR DATA | IUY = 74 |
| ALLOCATED DATA STORAGE | LIMIT = 43500 WORDS |

IST-1

1974 NRG ONLY SO₂

*** RANGES OF POLAR GRID SYSTEM ***
(METERS)

500. 0. 1000. 0. 1500. 0. 2000. 0. 2500. 0.

*** RADIAL ANGLES OF POLAR GRID SYSTEM ***

(DEGREES)

| | | | | | | | | | |
|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| 10. 0. | 20. 0. | 30. 0. | 40. 0. | 50. 0. | 60. 0. | 70. 0. | 80. 0. | 90. 0. | 100. 0. |
| 110. 0. | 120. 0. | 130. 0. | 140. 0. | 150. 0. | 160. 0. | 170. 0. | 180. 0. | 190. 0. | 200. 0. |
| 210. 0. | 220. 0. | 230. 0. | 240. 0. | 250. 0. | 260. 0. | 270. 0. | 280. 0. | 290. 0. | 300. 0. |
| 310. 0. | 320. 0. | 330. 0. | 340. 0. | 350. 0. | 360. 0. | | | | |

*** SOURCE DATA ***

| SOURCE NUMBER | T W Y A P K E E | PART. CATS. | EMISSION RATE | | X (METERS) | Y (METERS) | BASE ELEV. (METERS) | HEIGHT (METERS) | TEMP. | EXIT VEL. | | BLDG. HEIGHT (METERS) | BLDG. LENGTH TYPE=0 (METERS) | BLDG. WIDTH TYPE=0 (METERS) |
|---------------|--------------------------|----------------|--------------------------|-----------------------|---------------|---------------|---------------------------|--------------------|--------------------|-------------------|---------------------------------|-----------------------------|---------------------------------------|--------------------------------------|
| | | | TYPE=0, 1 (GRAMS/SEC) | TYPE=2 (GRAMS/SEC) | | | | | TYPE=0 (DEC. K) | TYPE=0 (M/SEC) | VERT. DIM TYPE=1 (METERS) | | | |
| 101 | 0 | 0 | 0 | 0.15800E+02 | 0.0 | 0.0 | 0.0 | 38.10 | 450.00 | 20.00 | 1.83 | 22.00 | 38.10 | 19.80 |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* 365-DAY AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 0.57149 AND OCCURRED AT (1500.0, 180.0) *

| DIRECTION / (DEGREES) / | RANGE (METERS) | | | | |
|----------------------------|----------------|---------|-----------|---------|---------|
| | 500.0 | 1000.0 | 1500.0 | 2000.0 | 2500.0 |
| 360.0 / | 0.34112 | 0.51839 | 0.53369 | 0.46743 | 0.43976 |
| 350.0 / | 0.27206 | 0.41856 | 0.41371 | 0.36874 | 0.32429 |
| 340.0 / | 0.33282 | 0.45164 | 0.45634 | 0.41617 | 0.37242 |
| 330.0 / | 0.26656 | 0.37517 | 0.36005 | 0.31733 | 0.27838 |
| 320.0 / | 0.27271 | 0.40460 | 0.39712 | 0.35386 | 0.31265 |
| 310.0 / | 0.26977 | 0.41746 | 0.42296 | 0.30427 | 0.34248 |
| 300.0 / | 0.27729 | 0.43413 | 0.45864 | 0.42726 | 0.36447 |
| 290.0 / | 0.25872 | 0.39852 | 0.41152 | 0.36027 | 0.34119 |
| 280.0 / | 0.27384 | 0.42773 | 0.44487 | 0.41042 | 0.36654 |
| 270.0 / | 0.25836 | 0.46209 | 0.47701 | 0.43911 | 0.39406 |
| 260.0 / | 0.27296 | 0.42109 | 0.42421 | 0.38738 | 0.35015 |
| 250.0 / | 0.26936 | 0.44204 | 0.46823 | 0.43806 | 0.40033 |
| 240.0 / | 0.30099 | 0.47061 | 0.49023 | 0.45102 | 0.40432 |
| 230.0 / | 0.36602 | 0.52387 | 0.53741 | 0.47501 | 0.44611 |
| 220.0 / | 0.37249 | 0.50984 | 0.50928 | 0.46671 | 0.42389 |
| 210.0 / | 0.30635 | 0.42604 | 0.42465 | 0.36856 | 0.35140 |
| 200.0 / | 0.27595 | 0.41796 | 0.44557 | 0.43088 | 0.40511 |
| 190.0 / | 0.22252 | 0.33370 | 0.34503 | 0.31943 | 0.28851 |
| 180.0 / | 0.33960 | 0.51949 | 0.57149 ✓ | 0.55554 | 0.52320 |
| 170.0 / | 0.21023 | 0.36179 | 0.38276 | 0.35172 | 0.31569 |
| 160.0 / | 0.15526 | 0.28371 | 0.29557 | 0.26390 | 0.22974 |
| 150.0 / | 0.16957 | 0.28715 | 0.30731 | 0.28185 | 0.24878 |
| 140.0 / | 0.24339 | 0.36369 | 0.37123 | 0.33493 | 0.29365 |
| 130.0 / | 0.24288 | 0.34201 | 0.34484 | 0.31201 | 0.27453 |
| 120.0 / | 0.25793 | 0.35871 | 0.36064 | 0.32924 | 0.29428 |
| 110.0 / | 0.22684 | 0.31717 | 0.31728 | 0.28970 | 0.26024 |
| 100.0 / | 0.20826 | 0.29033 | 0.29356 | 0.26884 | 0.23909 |
| 90.0 / | 0.17469 | 0.28382 | 0.28935 | 0.27053 | 0.24748 |
| 80.0 / | 0.21454 | 0.29571 | 0.28274 | 0.25400 | 0.22678 |
| 70.0 / | 0.22476 | 0.32728 | 0.31579 | 0.28154 | 0.24822 |
| 60.0 / | 0.24137 | 0.36209 | 0.36224 | 0.33003 | 0.29474 |
| 50.0 / | 0.24039 | 0.35652 | 0.34982 | 0.31085 | 0.27141 |
| 40.0 / | 0.21737 | 0.32278 | 0.32132 | 0.28874 | 0.25557 |
| 30.0 / | 0.18646 | 0.29002 | 0.28865 | 0.25947 | 0.23043 |
| 20.0 / | 0.24178 | 0.36030 | 0.34670 | 0.30489 | 0.26652 |
| 10.0 / | 0.27522 | 0.43666 | 0.42127 | 0.36618 | 0.31538 |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* HIGHEST 3-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *
* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 33.37221 AND OCCURRED AT (500.0, 50.0) *

| DIRECTION / (DEGREES) / | RANGE (METERS) | | | | |
|----------------------------|-------------------|-------------------|-------------------|-------------------|-------------------|
| | 500.0 | 1000.0 | 1500.0 | 2000.0 | 2500.0 |
| 360.0 / | 21.92350 (135, 4) | 26.48906 (135, 4) | 19.25830 (135, 4) | 17.85899 (28, 5) | 16.06267 (176, 1) |
| 350.0 / | 17.60119 (131, 5) | 21.44637 (130, 5) | 17.60302 (27, 4) | 16.53598 (27, 4) | 14.75706 (27, 4) |
| 340.0 / | 25.28077 (132, 1) | 23.11578 (132, 1) | 24.72700 (186, 4) | 21.37229 (186, 4) | 17.29935 (186, 4) |
| 330.0 / | 23.99370 (250, 4) | 23.69375 (250, 4) | 17.63807 (63, 4) | 16.94285 (63, 4) | 15.17637 (63, 4) |
| 320.0 / | 25.43696 (103, 5) | 23.68771 (103, 5) | 17.77888 (103, 5) | 14.35951 (131, 3) | 12.27661 (24, 5) |
| 310.0 / | 14.02879 (207, 7) | 19.37129 (49, 5) | 18.31600 (49, 5) | 14.85582 (52, 4) | 13.35735 (51, 6) |
| 300.0 / | 18.82389 (241, 5) | 21.62689 (241, 5) | 19.24624 (239, 6) | 16.39780 (239, 6) | 14.24007 (184, 4) |
| 290.0 / | 20.69789 (139, 5) | 24.48147 (139, 5) | 19.95887 (243, 5) | 17.90046 (3, 6) | 18.08550 (3, 6) |
| 280.0 / | 15.27675 (111, 4) | 18.74595 (133, 5) | 15.40622 (215, 6) | 14.48114 (102, 3) | 13.79951 (102, 3) |
| 270.0 / | 25.23728 (111, 4) | 21.60755 (140, 4) | 17.11919 (287, 4) | 19.36149 (54, 6) | 11.52447 (25, 7) |
| 260.0 / | 17.43761 (101, 5) | 23.48090 (224, 5) | 20.06702 (224, 5) | 16.27010 (301, 5) | 13.22778 (301, 5) |
| 250.0 / | 14.23489 (235, 5) | 19.80170 (340, 5) | 17.25467 (224, 5) | 14.05901 (198, 4) | 12.92107 (306, 6) |
| 240.0 / | 15.00062 (117, 6) | 17.55171 (110, 4) | 16.09870 (255, 6) | 17.98722 (73, 7) | 18.04065 (73, 7) |
| 230.0 / | 27.13737 (278, 5) | 31.43979 (195, 4) | 26.48208 (195, 4) | 19.92370 (195, 4) | 15.19869 (133, 7) |
| 220.0 / | 23.01605 (225, 5) | 27.01716 (258, 5) | 23.23509 (258, 5) | 17.60823 (258, 5) | 15.26047 (283, 5) |
| 210.0 / | 26.53164 (330, 4) | 23.20473 (330, 4) | 21.40722 (330, 4) | 18.57986 (330, 4) | 15.84314 (330, 4) |
| 200.0 / | 20.51489 (296, 5) | 18.82485 (296, 5) | 18.89486 (296, 6) | 19.06810 (296, 6) | 18.11222 (296, 6) |
| 190.0 / | 13.60620 (276, 6) | 18.56251 (265, 4) | 17.94978 (108, 3) | 16.99695 (108, 3) | 14.57200 (108, 3) |
| 180.0 / | 27.64359 (279, 6) | 29.66875 (297, 5) | 27.12409 (297, 5) | 22.95057 (297, 4) | 19.89506 (297, 4) |
| 170.0 / | 11.29461 (96, 4) | 23.64062 (72, 4) | 18.46170 (311, 2) | 20.21770 (311, 2) | 19.72769 (311, 2) |
| 160.0 / | 12.22004 (279, 8) | 16.81384 (76, 4) | 15.99223 (338, 5) | 14.92764 (338, 5) | 12.52353 (338, 5) |
| 150.0 / | 18.99012 (211, 4) | 17.90875 (196, 5) | 17.15870 (326, 4) | 15.22113 (280, 4) | 14.00106 (280, 4) |
| 140.0 / | 25.18256 (211, 4) | 24.94367 (163, 4) | 19.75440 (325, 4) | 18.23065 (325, 4) | 16.66835 (316, 8) |
| 130.0 / | 17.89514 (151, 5) | 20.34650 (163, 4) | 17.71074 (196, 6) | 15.97422 (196, 6) | 13.32475 (355, 3) |
| 120.0 / | 24.95053 (145, 4) | 28.10335 (145, 4) | 19.87960 (145, 4) | 15.47537 (326, 5) | 14.05274 (326, 5) |
| 110.0 / | 25.07877 (150, 5) | 21.50875 (202, 4) | 19.97994 (202, 4) | 17.46431 (335, 3) | 15.94597 (335, 3) |
| 100.0 / | 19.48418 (97, 5) | 31.78459 (97, 5) | 25.37569 (97, 5) | 21.47611 (113, 6) | 19.26079 (113, 6) |
| 90.0 / | 10.50892 (123, 4) | 16.31327 (270, 6) | 18.20155 (270, 6) | 15.40349 (270, 6) | 12.67194 (150, 3) |
| 80.0 / | 16.19451 (123, 4) | 17.46176 (203, 4) | 15.58527 (193, 5) | 14.63629 (146, 7) | 15.21622 (146, 7) |
| 70.0 / | 19.70891 (89, 5) | 23.65402 (203, 4) | 17.38913 (203, 4) | 14.79315 (163, 3) | 13.02362 (324, 6) |
| 60.0 / | 25.89107 (176, 4) | 21.47279 (230, 5) | 17.81469 (98, 5) | 15.99941 (88, 5) | 14.71054 (90, 6) |
| 50.0 / | 33.37221 (174, 5) | 26.74454 (174, 5) | 20.98876 (174, 5) | 18.12713 (349, 8) | 17.26119 (349, 8) |
| 40.0 / | 21.28988 (125, 5) | 23.53182 (153, 4) | 19.79919 (143, 6) | 20.70703 (143, 6) | 19.70937 (143, 6) |
| 30.0 / | 15.96645 (84, 4) | 16.74500 (34, 5) | 16.01520 (34, 5) | 13.81040 (34, 5) | 12.17061 (174, 8) |
| 20.0 / | 23.00479 (50, 5) | 21.23848 (78, 4) | 19.09087 (78, 4) | 15.11300 (38, 4) | 13.10832 (38, 4) |
| 10.0 / | 27.89272 (354, 5) | 25.95272 (354, 5) | 24.80759 (354, 5) | 22.00515 (354, 5) | 19.01911 (354, 5) |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* SECOND HIGHEST 3-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *
* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 25.57455 AND OCCURRED AT (1500.0, 180.0) *

| DIRECTION / (DEGREES) / | RANGE (METERS) | | | | |
|----------------------------|-------------------|-------------------|-------------------|-------------------|-------------------|
| | 500.0 | 1000.0 | 1500.0 | 2000.0 | 2500.0 |
| 360.0 / | 16.63400 (98, 4) | 20.06440 (15, 5) | 18.82319 (28, 5) | 17.45158 (176, 1) | 16.02973 (28, 5) |
| 350.0 / | 17.48256 (152, 5) | 20.28677 (152, 5) | 16.42499 (130, 5) | 13.41364 (353, 5) | 13.90652 (342, 2) |
| 340.0 / | 20.54462 (177, 2) | 22.75543 (94, 5) | 21.83488 (132, 1) | 19.24204 (132, 1) | 16.55576 (132, 1) |
| 330.0 / | 20.50034 (94, 4) | 19.75613 (94, 4) | 17.31815 (250, 4) | 13.67075 (94, 4) | 11.40612 (239, 4) |
| 320.0 / | 19.09790 (243, 4) | 21.42059 (159, 4) | 16.45317 (131, 3) | 13.45479 (24, 5) | 12.15266 (131, 3) |
| 310.0 / | 13.32336 (142, 4) | 17.25167 (62, 4) | 16.96990 (52, 4) | 14.84611 (70, 6) | 12.90185 (70, 6) |
| 300.0 / | 15.75809 (131, 4) | 18.39930 (62, 5) | 17.22136 (65, 4) | 15.54079 (184, 4) | 13.20435 (237, 6) |
| 290.0 / | 13.61335 (321, 4) | 21.73475 (243, 5) | 19.22820 (139, 5) | 15.60491 (243, 5) | 12.52899 (52, 6) |
| 280.0 / | 12.67208 (221, 4) | 18.46734 (246, 4) | 15.32623 (264, 6) | 14.31713 (264, 6) | 12.49398 (264, 6) |
| 270.0 / | 15.79714 (140, 4) | 21.04427 (111, 4) | 16.40767 (357, 4) | 12.70422 (287, 4) | 11.17359 (243, 6) |
| 260.0 / | 16.94701 (140, 5) | 19.56967 (301, 5) | 19.43197 (301, 5) | 15.16086 (224, 5) | 11.47647 (73, 5) |
| 250.0 / | 11.96420 (303, 4) | 19.22532 (262, 4) | 16.99725 (262, 4) | 13.57182 (235, 5) | 12.60008 (198, 4) |
| 240.0 / | 13.30123 (111, 5) | 16.47206 (195, 3) | 16.04667 (195, 3) | 14.77599 (255, 6) | 12.27196 (255, 6) |
| 230.0 / | 21.27057 (195, 4) | 21.99427 (278, 5) | 19.04637 (278, 5) | 16.22907 (285, 5) | 15.02723 (195, 4) |
| 220.0 / | 20.25920 (117, 5) | 24.44456 (100, 4) | 18.94292 (293, 5) | 17.36223 (283, 5) | 13.31936 (298, 5) |
| 210.0 / | 24.65697 (277, 5) | 21.00089 (238, 5) | 18.78317 (238, 5) | 15.07166 (277, 5) | 12.59140 (277, 5) |
| 200.0 / | 15.91511 (276, 5) | 16.33606 (296, 6) | 17.98995 (257, 4) | 15.72881 (257, 4) | 14.00935 (257, 4) |
| 190.0 / | 13.35825 (279, 4) | 16.43044 (319, 4) | 17.34123 (265, 4) | 13.50104 (265, 4) | 11.65834 (330, 7) |
| 180.0 / | 20.21565 (279, 5) | 25.48751 (298, 4) | 25.57455 (277, 4) | 21.54437 (298, 4) | 18.74650 (297, 3) |
| 170.0 / | 10.52104 (72, 4) | 16.54654 (149, 4) | 18.29479 (57, 4) | 15.41192 (57, 4) | 13.99147 (57, 4) |
| 160.0 / | 10.17223 (48, 4) | 16.77737 (72, 4) | 15.34896 (107, 4) | 12.28726 (107, 4) | 10.50920 (114, 3) |
| 150.0 / | 17.10671 (196, 5) | 16.59291 (326, 4) | 15.92935 (153, 6) | 14.79757 (326, 4) | 12.29001 (326, 4) |
| 140.0 / | 19.27361 (325, 4) | 20.58538 (291, 4) | 19.43486 (163, 4) | 17.25445 (316, 8) | 16.08622 (325, 4) |
| 130.0 / | 17.86643 (337, 4) | 20.20912 (96, 5) | 15.96042 (337, 4) | 14.33952 (337, 4) | 13.18524 (196, 6) |
| 120.0 / | 17.24887 (150, 5) | 20.60681 (201, 4) | 17.35040 (201, 4) | 13.76394 (145, 4) | 12.25148 (325, 6) |
| 110.0 / | 19.55165 (163, 5) | 20.42275 (150, 5) | 18.05890 (167, 5) | 16.07326 (351, 6) | 14.25344 (351, 6) |
| 100.0 / | 15.91393 (150, 5) | 20.36094 (113, 6) | 22.63970 (113, 6) | 19.41441 (99, 5) | 13.58510 (99, 5) |
| 90.0 / | 13.01694 (147, 6) | 14.35423 (192, 3) | 15.75637 (192, 3) | 14.26514 (192, 3) | 12.94755 (270, 6) |
| 80.0 / | 14.93261 (132, 6) | 17.09307 (193, 5) | 13.13090 (168, 3) | 13.38062 (193, 5) | 11.34162 (193, 5) |
| 70.0 / | 15.90382 (132, 6) | 17.50812 (89, 5) | 16.04958 (163, 3) | 14.73037 (324, 6) | 12.92462 (163, 3) |
| 60.0 / | 19.17968 (88, 5) | 20.99393 (176, 4) | 17.15314 (88, 6) | 15.48149 (88, 6) | 13.90424 (88, 5) |
| 50.0 / | 25.49583 (146, 5) | 23.53065 (146, 5) | 18.33484 (146, 5) | 16.47019 (174, 5) | 15.43937 (50, 7) |
| 40.0 / | 20.58689 (132, 4) | 21.50392 (125, 5) | 19.46561 (153, 4) | 17.62211 (39, 2) | 17.85916 (39, 2) |
| 30.0 / | 13.69041 (50, 5) | 16.26226 (84, 4) | 13.15176 (84, 4) | 12.55212 (34, 4) | 11.89500 (34, 4) |
| 20.0 / | 18.15893 (38, 4) | 19.23991 (152, 4) | 16.92611 (38, 4) | 14.78041 (78, 4) | 11.32757 (78, 4) |
| 10.0 / | 25.28721 (50, 6) | 24.24519 (135, 4) | 18.71718 (50, 6) | 15.81530 (50, 6) | 14.26677 (334, 0) |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* 50 MAXIMUM 3-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) | RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) |
|------|----------|------|-----|------------------------------|---|------|----------|------|-----|------------------------------|---|
| 1 | 33.37221 | 5 | 174 | 500.0 | 50.0 | 26 | 25.18258 | 4 | 211 | 500.0 | 140.0 |
| 2 | 31.78454 | 5 | 97 | 1000.0 | 100.0 | 27 | 25.13359 | 4 | 290 | 1500.0 | 180.0 |
| 3 | 31.43579 | 4 | 195 | 1000.0 | 230.0 | 28 | 25.07977 | 5 | 150 | 500.0 | 110.0 |
| 4 | 29.66675 | 5 | 297 | 1000.0 | 180.0 | 29 | 25.04288 | 6 | 279 | 1000.0 | 180.0 |
| 5 | 28.10335 | 4 | 145 | 1000.0 | 120.0 | 30 | 24.95053 | 4 | 145 | 500.0 | 120.0 |
| 6 | 27.89272 | 5 | 354 | 500.0 | 10.0 | 31 | 24.94367 | 4 | 163 | 1000.0 | 140.0 |
| 7 | 27.64357 | 6 | 279 | 500.0 | 180.0 | 32 | 24.80759 | 5 | 354 | 1500.0 | 10.0 |
| 8 | 27.13737 | 5 | 278 | 500.0 | 230.0 | 33 | 24.72700 | 4 | 186 | 1500.0 | 340.0 |
| 9 | 27.12409 | 5 | 297 | 1500.0 | 160.0 | 34 | 24.65597 | 5 | 277 | 500.0 | 210.0 |
| 10 | 27.01716 | 5 | 298 | 1000.0 | 220.0 | 35 | 24.48147 | 5 | 139 | 1000.0 | 290.0 |
| 11 | 26.89107 | 4 | 176 | 500.0 | 60.0 | 36 | 24.44456 | 4 | 100 | 1000.0 | 220.0 |
| 12 | 26.74454 | 5 | 174 | 1000.0 | 50.0 | 37 | 24.24519 | 4 | 135 | 1000.0 | 10.0 |
| 13 | 26.53164 | 4 | 330 | 500.0 | 210.0 | 38 | 24.14745 | 4 | 176 | 500.0 | 50.0 |
| 14 | 26.48906 | 4 | 135 | 1000.0 | 350.0 | 39 | 23.99370 | 4 | 250 | 500.0 | 330.0 |
| 15 | 26.48208 | 4 | 195 | 1500.0 | 230.0 | 40 | 23.69375 | 4 | 250 | 1000.0 | 330.0 |
| 16 | 25.95272 | 5 | 354 | 1000.0 | 10.0 | 41 | 23.68771 | 5 | 103 | 1000.0 | 320.0 |
| 17 | 25.57455 | 4 | 297 | 1500.0 | 180.0 | 42 | 23.65402 | 4 | 203 | 1000.0 | 70.0 |
| 18 | 25.48751 | 4 | 298 | 1000.0 | 180.0 | 43 | 23.64062 | 4 | 72 | 1000.0 | 170.0 |
| 19 | 25.48583 | 5 | 146 | 500.0 | 50.0 | 44 | 23.63065 | 5 | 146 | 1000.0 | 50.0 |
| 20 | 25.43676 | 5 | 103 | 500.0 | 320.0 | 45 | 23.53182 | 4 | 153 | 1000.0 | 40.0 |
| 21 | 25.37567 | 5 | 99 | 1500.0 | 100.0 | 46 | 23.50901 | 6 | 279 | 1500.0 | 180.0 |
| 22 | 25.36388 | 4 | 297 | 1000.0 | 180.0 | 47 | 23.48090 | 5 | 224 | 1000.0 | 260.0 |
| 23 | 25.28721 | 6 | 50 | 500.0 | 10.0 | 48 | 23.45840 | 4 | 265 | 1000.0 | 180.0 |
| 24 | 25.28077 | 1 | 132 | 500.0 | 340.0 | 49 | 23.23509 | 5 | 259 | 1500.0 | 220.0 |
| 25 | 25.23728 | 4 | 111 | 500.0 | 270.0 | 50 | 23.20473 | 4 | 330 | 1000.0 | 210.0 |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* HIGHEST 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *
* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 12.08277 AND OCCURRED AT (1500.0, 180.0) *

| DIRECTION / (DEGREES) / | RANGE (METERS) | | | | |
|----------------------------|------------------|-------------------|---------------------|-------------------|-------------------|
| | 500.0 | 1000.0 | 1500.0 | 2000.0 | 2500.0 |
| 360.0 / | 4.85658 (33, 1) | 6.33211 (33, 1) | 6.59551 (33, 1) | 6.23728 (33, 1) | 5.71989 (33, 1) |
| 350.0 / | 3.42336 (341, 1) | 4.76969 (188, 1) | 4.21912 (188, 1) | 3.38627 (353, 1) | 3.24927 (95, 1) |
| 340.0 / | 5.00174 (132, 1) | 5.43325 (94, 1) | 5.19273 (94, 1) | 4.61766 (94, 1) | 4.01333 (94, 1) |
| 330.0 / | 4.57753 (63, 1) | 6.26116 (63, 1) | 6.76354 (63, 1) | 6.08567 (63, 1) | 5.18182 (63, 1) |
| 320.0 / | 4.47553 (131, 1) | 4.93276 (131, 1) | 4.84671 (131, 1) | 4.35240 (131, 1) | 3.82126 (131, 1) |
| 310.0 / | 3.95178 (131, 1) | 5.43732 (62, 1) | 4.95093 (65, 1) | 4.18527 (65, 1) | 3.47502 (131, 1) |
| 300.0 / | 4.67033 (139, 1) | 7.69860 (62, 1) | 6.67573 (62, 1) | 5.21943 (62, 1) | 4.10760 (62, 1) |
| 290.0 / | 4.75767 (139, 1) | 5.73659 (139, 1) | 5.42696 (102, 1) | 5.50711 (102, 1) | 5.23997 (102, 1) |
| 280.0 / | 3.73878 (101, 1) | 4.97824 (219, 1) | 4.68662 (102, 1) | 4.69299 (102, 1) | 4.34198 (102, 1) |
| 270.0 / | 5.23448 (101, 1) | 5.34136 (111, 1) | 4.62247 (101, 1) | 4.04475 (101, 1) | 3.45906 (302, 1) |
| 260.0 / | 4.08298 (101, 1) | 4.01659 (301, 1) | 4.56126 (301, 1) | 3.71997 (301, 1) | 3.62669 (365, 1) |
| 250.0 / | 3.49962 (110, 1) | 5.24706 (110, 1) | 5.51576 (110, 1) | 4.84802 (110, 1) | 4.07726 (110, 1) |
| 240.0 / | 4.92380 (194, 1) | 5.83448 (194, 1) | 5.55736 (194, 1) | 5.35330 (73, 1) | 5.91920 (73, 1) |
| 230.0 / | 5.59342 (171, 1) | 7.04208 (171, 1) | 5.81668 (295, 1) | 5.90114 (267, 1) | 5.58939 (267, 1) |
| 220.0 / | 5.03201 (294, 1) | 6.19053 (100, 1) | 5.47446 (294, 1) | 5.14053 (294, 1) | 4.61111 (294, 1) |
| 210.0 / | 6.50348 (277, 1) | 5.65991 (277, 1) | 5.65984 (277, 1) | 5.04180 (277, 1) | 4.99489 (348, 1) |
| 200.0 / | 5.31717 (276, 1) | 6.06226 (295, 1) | 7.00539 (296, 1) | 7.20503 (296, 1) | 6.97015 (295, 1) |
| 190.0 / | 7.29198 (279, 1) | 6.43709 (279, 1) | 6.31732 (279, 1) | 5.85307 (313, 1) | 5.45311 (313, 1) |
| 180.0 / | 9.71472 (279, 1) | 11.00757 (297, 1) | 12.08277 (297, 1) ✓ | 11.45839 (297, 1) | 10.50395 (297, 1) |
| 170.0 / | 4.68406 (57, 1) | 5.94565 (57, 1) | 6.19202 (57, 1) | 5.49479 (57, 1) | 4.68038 (57, 1) |
| 160.0 / | 3.43227 (280, 1) | 4.73119 (107, 1) | 5.06250 (280, 1) | 5.14002 (280, 1) | 4.78661 (280, 1) |
| 150.0 / | 3.60970 (280, 1) | 4.74258 (41, 1) | 5.19427 (41, 1) | 5.15800 (280, 1) | 4.77125 (280, 1) |
| 140.0 / | 5.69084 (325, 1) | 5.65322 (325, 1) | 6.20218 (325, 1) | 6.02551 (325, 1) | 5.53578 (325, 1) |
| 130.0 / | 4.30454 (337, 1) | 4.91696 (114, 1) | 4.43165 (40, 1) | 4.57271 (40, 1) | 4.39705 (40, 1) |
| 120.0 / | 5.44634 (145, 1) | 6.54010 (145, 1) | 5.16630 (145, 1) | 3.04885 (40, 1) | 4.95498 (40, 1) |
| 110.0 / | 4.31047 (99, 1) | 6.72504 (99, 1) | 5.82475 (99, 1) | 4.74832 (351, 1) | 4.65875 (351, 1) |
| 100.0 / | 5.32034 (99, 1) | 8.27948 (99, 1) | 6.92807 (99, 1) | 5.24447 (99, 1) | 3.99902 (59, 1) |
| 90.0 / | 3.55389 (192, 1) | 5.68211 (192, 1) | 5.95182 (192, 1) | 5.44563 (192, 1) | 4.89841 (192, 1) |
| 80.0 / | 5.25604 (132, 1) | 4.74471 (169, 1) | 4.45239 (132, 1) | 3.96769 (132, 1) | 3.45524 (132, 1) |
| 70.0 / | 4.43633 (89, 1) | 4.32937 (89, 1) | 4.37703 (89, 1) | 4.06806 (89, 1) | 3.64609 (89, 1) |
| 60.0 / | 5.79059 (88, 1) | 5.71837 (88, 1) | 5.81280 (88, 1) | 5.43282 (88, 1) | 4.94538 (88, 1) |
| 50.0 / | 4.77996 (146, 1) | 5.25216 (146, 1) | 4.37492 (146, 1) | 4.32669 (39, 1) | 4.10892 (39, 1) |
| 40.0 / | 6.20269 (125, 1) | 5.93473 (125, 1) | 3.47641 (39, 1) | 3.77636 (39, 1) | 3.68454 (147, 1) |
| 30.0 / | 3.55559 (84, 1) | 3.90070 (84, 1) | 3.89137 (98, 1) | 3.60044 (34, 1) | 3.23845 (34, 1) |
| 20.0 / | 3.75065 (50, 1) | 5.23658 (78, 1) | 4.39423 (78, 1) | 3.26178 (78, 1) | 2.83880 (38, 1) |
| 10.0 / | 5.10821 (50, 1) | 4.15186 (152, 1) | 4.51939 (104, 1) | 4.08165 (11, 1) | 3.77137 (11, 1) |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* SECOND HIGHEST 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *
* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 9.34561 AND OCCURRED AT (1000.0, 180.0) *

| DIRECTION / (DEGREES) / | RANGE (METERS) | | | | |
|----------------------------|------------------|------------------|------------------|------------------|------------------|
| | 500.0 | 1000.0 | 1500.0 | 2000.0 | 2500.0 |
| 360.0 / | 4.24673 (176, 1) | 5.69470 (91, 1) | 5.15693 (28, 1) | 5.07796 (28, 1) | 4.66499 (28, 1) |
| 350.0 / | 3.07382 (353, 1) | 3.96157 (213, 1) | 3.62109 (353, 1) | 3.26115 (95, 1) | 3.01372 (353, 1) |
| 340.0 / | 4.69084 (94, 1) | 4.98202 (93, 1) | 4.99244 (93, 1) | 4.47942 (93, 1) | 3.88123 (93, 1) |
| 330.0 / | 4.50610 (131, 1) | 4.89883 (250, 1) | 4.19271 (250, 1) | 3.76337 (94, 1) | 3.33655 (94, 1) |
| 320.0 / | 4.05825 (220, 1) | 4.57570 (134, 1) | 4.29525 (134, 1) | 3.59770 (134, 1) | 3.14603 (249, 1) |
| 310.0 / | 2.51763 (52, 1) | 4.91346 (49, 1) | 4.83407 (62, 1) | 3.90673 (131, 1) | 3.45919 (37, 1) |
| 300.0 / | 4.21008 (241, 1) | 5.63024 (139, 1) | 4.80422 (139, 1) | 3.75639 (139, 1) | 3.30307 (361, 1) |
| 290.0 / | 4.09459 (102, 1) | 4.76053 (243, 1) | 4.99561 (139, 1) | 4.01500 (139, 1) | 3.94951 (3, 1) |
| 280.0 / | 3.57995 (219, 1) | 4.85034 (240, 1) | 4.64783 (219, 1) | 4.16423 (74, 1) | 4.01958 (74, 1) |
| 270.0 / | 5.12113 (111, 1) | 4.91433 (101, 1) | 4.60942 (111, 1) | 3.84960 (302, 1) | 3.44591 (101, 1) |
| 260.0 / | 3.17962 (140, 1) | 4.32451 (300, 1) | 4.19899 (300, 1) | 3.63157 (365, 1) | 3.12179 (110, 1) |
| 250.0 / | 2.75170 (117, 1) | 4.66502 (340, 1) | 4.80330 (340, 1) | 4.36521 (340, 1) | 3.94123 (340, 1) |
| 240.0 / | 4.35169 (117, 1) | 5.16053 (110, 1) | 4.86841 (110, 1) | 4.81480 (194, 1) | 4.09480 (194, 1) |
| 230.0 / | 5.22192 (295, 1) | 5.33653 (195, 1) | 5.74508 (267, 1) | 5.66624 (295, 1) | 5.23501 (295, 1) |
| 220.0 / | 4.85343 (277, 1) | 5.28463 (171, 1) | 5.28473 (283, 1) | 4.84845 (283, 1) | 4.28538 (283, 1) |
| 210.0 / | 6.19093 (330, 1) | 5.58125 (109, 1) | 5.08961 (330, 1) | 4.70675 (348, 1) | 4.36067 (277, 1) |
| 200.0 / | 5.70830 (296, 1) | 4.78810 (276, 1) | 4.27715 (274, 1) | 3.58587 (274, 1) | 3.30910 (278, 1) |
| 190.0 / | 4.22399 (313, 1) | 5.01742 (313, 1) | 5.83370 (313, 1) | 5.74350 (279, 1) | 5.07348 (279, 1) |
| 180.0 / | 6.44133 (297, 1) | 9.34561 (279, 1) | 9.29819 (279, 1) | 8.45161 (279, 1) | 7.40371 (279, 1) |
| 170.0 / | 3.06400 (280, 1) | 5.14492 (107, 1) | 5.00164 (107, 1) | 4.78279 (311, 1) | 4.63908 (311, 1) |
| 160.0 / | 3.21388 (48, 1) | 4.17830 (280, 1) | 4.50204 (107, 1) | 3.50206 (107, 1) | 3.22345 (48, 1) |
| 150.0 / | 3.16502 (211, 1) | 4.33820 (280, 1) | 5.14589 (280, 1) | 4.69191 (41, 1) | 4.14011 (41, 1) |
| 140.0 / | 4.19710 (211, 1) | 4.96760 (114, 1) | 4.40420 (114, 1) | 4.35575 (316, 1) | 4.08577 (316, 1) |
| 130.0 / | 3.90921 (145, 1) | 4.65844 (96, 1) | 4.39531 (337, 1) | 4.04830 (337, 1) | 3.62575 (337, 1) |
| 120.0 / | 5.31413 (150, 1) | 5.51415 (191, 1) | 4.67758 (40, 1) | 4.71484 (316, 1) | 4.57474 (316, 1) |
| 110.0 / | 4.23567 (335, 1) | 3.89783 (335, 1) | 4.40311 (351, 1) | 4.60342 (99, 1) | 4.02207 (335, 1) |
| 100.0 / | 4.10689 (89, 1) | 3.59790 (89, 1) | 4.00921 (113, 1) | 3.84671 (113, 1) | 3.49096 (113, 1) |
| 90.0 / | 3.11001 (89, 1) | 3.71813 (7, 1) | 4.25633 (7, 1) | 3.92293 (87, 1) | 3.55846 (87, 1) |
| 80.0 / | 3.49958 (193, 1) | 4.71545 (132, 1) | 4.20927 (168, 1) | 3.60434 (193, 1) | 3.31185 (71, 1) |
| 70.0 / | 3.21943 (192, 1) | 4.28280 (203, 1) | 4.03232 (90, 1) | 3.50278 (90, 1) | 2.88700 (90, 1) |
| 60.0 / | 4.87967 (176, 1) | 5.19343 (90, 1) | 4.57544 (90, 1) | 4.15313 (90, 1) | 3.74524 (90, 1) |
| 50.0 / | 4.44227 (125, 1) | 4.13620 (125, 1) | 4.17109 (39, 1) | 3.51567 (146, 1) | 2.98394 (146, 1) |
| 40.0 / | 3.00789 (132, 1) | 3.53576 (153, 1) | 3.34816 (105, 1) | 3.44679 (147, 1) | 3.67545 (39, 1) |
| 30.0 / | 2.97191 (125, 1) | 3.70880 (98, 1) | 3.82755 (34, 1) | 3.29738 (98, 1) | 2.68113 (98, 1) |
| 20.0 / | 3.61777 (38, 1) | 3.56562 (152, 1) | 3.42105 (38, 1) | 3.13356 (38, 1) | 2.43672 (78, 1) |
| 10.0 / | 4.51995 (354, 1) | 4.13073 (50, 1) | 4.22127 (11, 1) | 4.04359 (104, 1) | 3.48077 (104, 1) |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* 50 MAXIMUM 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) | RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) |
|------|----------|------|-----|------------------------------|---|------|---------|------|-----|------------------------------|---|
| 1 | 12.08277 | 1 | 297 | 1500.0 | 180.0 | 26 | 6.52758 | 1 | 57 | 2500.0 | 180.0 |
| 2 | 11.46839 | 1 | 297 | 2000.0 | 180.0 | 27 | 6.50348 | 1 | 277 | 500.0 | 210.0 |
| 3 | 11.00757 | 1 | 297 | 1000.0 | 180.0 | 28 | 6.44133 | 1 | 297 | 500.0 | 180.0 |
| 4 | 10.50395 | 1 | 297 | 2500.0 | 180.0 | 29 | 6.43709 | 1 | 277 | 1000.0 | 190.0 |
| 5 | 9.71472 | 1 | 277 | 500.0 | 180.0 | 30 | 6.37080 | 1 | 57 | 500.0 | 180.0 |
| 6 | 9.34561 | 1 | 279 | 1000.0 | 180.0 | 31 | 6.33211 | 1 | 33 | 1000.0 | 360.0 |
| 7 | 9.29819 | 1 | 277 | 1500.0 | 180.0 | 32 | 6.31732 | 1 | 277 | 1500.0 | 190.0 |
| 8 | 8.45161 | 1 | 277 | 2000.0 | 180.0 | 33 | 6.31717 | 1 | 276 | 500.0 | 200.0 |
| 9 | 8.27946 | 1 | 97 | 1000.0 | 100.0 | 34 | 6.26116 | 1 | 63 | 1000.0 | 330.0 |
| 10 | 7.69800 | 1 | 62 | 1000.0 | 300.0 | 35 | 6.23728 | 1 | 33 | 2000.0 | 360.0 |
| 11 | 7.40371 | 1 | 277 | 2500.0 | 180.0 | 36 | 6.20269 | 1 | 125 | 500.0 | 40.0 |
| 12 | 7.31892 | 1 | 57 | 1500.0 | 180.0 | 37 | 6.20218 | 1 | 325 | 1500.0 | 140.0 |
| 13 | 7.29198 | 1 | 277 | 500.0 | 190.0 | 38 | 6.19202 | 1 | 57 | 1500.0 | 170.0 |
| 14 | 7.20503 | 1 | 296 | 2000.0 | 200.0 | 39 | 6.19093 | 1 | 330 | 500.0 | 210.0 |
| 15 | 7.11037 | 1 | 57 | 2000.0 | 180.0 | 40 | 6.19053 | 1 | 100 | 1000.0 | 220.0 |
| 16 | 7.04208 | 1 | 171 | 1000.0 | 230.0 | 41 | 6.16299 | 1 | 313 | 2000.0 | 180.0 |
| 17 | 7.00539 | 1 | 296 | 1500.0 | 200.0 | 42 | 6.08567 | 1 | 63 | 2000.0 | 330.0 |
| 18 | 6.97015 | 1 | 296 | 2500.0 | 200.0 | 43 | 6.06667 | 1 | 298 | 1500.0 | 180.0 |
| 19 | 6.92807 | 1 | 99 | 1500.0 | 100.0 | 44 | 6.06226 | 1 | 276 | 1000.0 | 200.0 |
| 20 | 6.76354 | 1 | 63 | 1500.0 | 330.0 | 45 | 6.04033 | 1 | 313 | 1500.0 | 180.0 |
| 21 | 6.72504 | 1 | 99 | 1000.0 | 110.0 | 46 | 6.02551 | 1 | 325 | 2000.0 | 140.0 |
| 22 | 6.67573 | 1 | 62 | 1500.0 | 300.0 | 47 | 5.95903 | 1 | 265 | 2000.0 | 180.0 |
| 23 | 6.59551 | 1 | 33 | 1500.0 | 360.0 | 48 | 5.95182 | 1 | 192 | 1500.0 | 90.0 |
| 24 | 6.56260 | 1 | 57 | 1000.0 | 180.0 | 49 | 5.94565 | 1 | 57 | 1000.0 | 170.0 |
| 25 | 6.54010 | 1 | 145 | 1000.0 | 120.0 | 50 | 5.93493 | 1 | 125 | 1000.0 | 40.0 |

| | |
|---|---------------------|
| CALCULATE (CONCENTRATION=1, DEPOSITION=2) | ISW(1) = 1 |
| RECEPTOR GRID SYSTEM (RECTANGULAR=1 OR 3, POLAR=2 OR 4) | ISW(2) = 4 |
| DISCRETE RECEPTOR SYSTEM (RECTANGULAR=1, POLAR=2) | ISW(3) = 2 |
| TERRAIN ELEVATIONS ARE READ (YES=1, NO=0) | ISW(4) = 0 |
| CALCULATIONS ARE WRITTEN TO TAPE (YES=1, NO=0) | ISW(5) = 0 |
| LIST ALL INPUT DATA (NO=0, YES=1, MET DATA ALSO=2) | ISW(6) = 1 |
| | |
| COMPUTE AVERAGE CONCENTRATION (OR TOTAL DEPOSITION) | |
| WITH THE FOLLOWING TIME PERIODS: | |
| HOURLY (YES=1, NO=0) | ISW(7) = 0 |
| 2-HOUR (YES=1, NO=0) | ISW(8) = 0 |
| 3-HOUR (YES=1, NO=0) | ISW(9) = 1 |
| 4-HOUR (YES=1, NO=0) | ISW(10) = 0 |
| 6-HOUR (YES=1, NO=0) | ISW(11) = 0 |
| 8-HOUR (YES=1, NO=0) | ISW(12) = 0 |
| 12-HOUR (YES=1, NO=0) | ISW(13) = 0 |
| 24-HOUR (YES=1, NO=0) | ISW(14) = 1 |
| PRINT "N"-DAY TABLE(S) (YES=1, NO=0) | ISW(15) = 0 |
| | |
| PRINT THE FOLLOWING TYPES OF TABLES WHOSE TIME PERIODS ARE | |
| SPECIFIED BY ISW(7) THROUGH ISW(14): | |
| DAILY TABLES (YES=1, NO=0) | ISW(16) = 0 |
| HIGHEST & SECOND HIGHEST TABLES (YES=1, NO=0) | ISW(17) = 0 |
| MAXIMUM 50 TABLES (YES=1, NO=0) | ISW(18) = 1 |
| METEOROLOGICAL DATA INPUT METHOD (PRE-PROCESSED=1, CARD=2) | ISW(19) = 1 |
| RURAL-URBAN OPTION (RURAL=0, URBAN MODE 1=1, URBAN MODE 2=2) | ISW(20) = 0 |
| WIND PROFILE EXPONENT VALUES (DEFAULTS=1, USER ENTERS=2, 3) | ISW(21) = 1 |
| VERTICAL POT. TEMP. GRADIENT VALUES (DEFAULTS=1, USER ENTERS=2, 3) | ISW(22) = 1 |
| SCALE EMISSION RATES FOR ALL SOURCES (NO=0, YES>0) | ISW(23) = 0 |
| PROGRAM CALCULATES FINAL PLUME RISE ONLY (YES=1, NO=2) | ISW(24) = 2 |
| PROGRAM ADJUSTS ALL STACK HEIGHTS FOR DOWNWASH (YES=2, NO=1) | ISW(25) = 1 |
| | |
| INPUT SPECIAL DIRECTION-DEPENDENT BUILDING DIMENSIONS (YES=1, NO=0) | ISW(26) = 0 |
| | |
| OMIT TABLES FOR HOURLY CONCENTRATIONS (YES=1, NO=0) | ISW(27) = 0 |
| | |
| USEPA ADJUSTMENT FOR CALM HOURS (YES=1, NO=0) | ISW(29) = 1 |
| | |
| NUMBER OF INPUT SOURCES | NSOURC = 1 |
| NUMBER OF SOURCE GROUPS (=0, ALL SOURCES) | NGROUP = 0 |
| TIME PERIOD INTERVAL TO BE PRINTED (=0, ALL INTERVALS) | IPERD = 0 |
| NUMBER OF X (RANGE) GRID VALUES | NXPNTS = 10 |
| NUMBER OF Y (THETA) GRID VALUES | NYPNTS = 36 |
| NUMBER OF DISCRETE RECEPTORS | NXWYPT = 0 |
| SOURCE EMISSION RATE UNITS CONVERSION FACTOR | TK = 10000E+07 |
| ENTRAINMENT COEFFICIENT FOR UNSTABLE ATMOSPHERE | BETA1 = 0.600 |
| ENTRAINMENT COEFFICIENT FOR STABLE ATMOSPHERE | BETA2 = 0.600 |
| HEIGHT ABOVE GROUND AT WHICH WIND SPEED WAS MEASURED | ZR = 10.00 METERS |
| LOGICAL UNIT NUMBER OF METEOROLOGICAL DATA | IMET = 9 |
| DECAY COEFFICIENT FOR PHYSICAL OR CHEMICAL DEPLETION | DECAY = 0.00000E+00 |
| SURFACE STATION NO. | ISS = 12815 |
| YEAR OF SURFACE DATA | ISY = 74 |
| UPPER AIR STATION NO. | IUS = 12842 |
| YEAR OF UPPER AIR DATA | IUY = 74 |
| ALLOCATED DATA STORAGE | LIMIT = 43500 WORDS |

IST-2

1974 - NRG ONLY SO₂
(selected days)

*** RANGES OF POLAR GRID SYSTEM ***
(METERS)

| | | | | | | | | | |
|--------|--------|--------|--------|--------|--------|--------|---------|---------|---------|
| 200.0, | 300.0, | 400.0, | 600.0, | 700.0, | 800.0, | 900.0, | 1200.0, | 1400.0, | 1700.0, |
|--------|--------|--------|--------|--------|--------|--------|---------|---------|---------|

*** RADIAL ANGLES OF POLAR GRID SYSTEM ***

(DEGREES)

| | | | | | | | | | |
|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| 10.0, | 20.0, | 30.0, | 40.0, | 50.0, | 60.0, | 70.0, | 80.0, | 90.0, | 100.0, |
| 110.0, | 120.0, | 130.0, | 140.0, | 150.0, | 160.0, | 170.0, | 180.0, | 190.0, | 200.0, |
| 210.0, | 220.0, | 230.0, | 240.0, | 250.0, | 260.0, | 270.0, | 280.0, | 290.0, | 300.0, |
| 310.0, | 320.0, | 330.0, | 340.0, | 350.0, | 360.0, | | | | |

*** SOURCE DATA ***

| SOURCE NUMBER | P K E | T W Y A NUMBER | PART. CATS. | EMISSION RATE | | X (METERS) | Y (METERS) | BASE ELEV. (METERS) | HEIGHT (METERS) | TEMP. | EXIT VEL. | | | BLDG. HEIGHT (METERS) | BLDG. LENGTH (METERS) | BLDG. WIDTH (METERS) |
|---------------|-------|----------------|-------------|----------------------|--------------------|------------|------------|---------------------|-----------------|--|---|--------------------------|-------|-----------------------|-----------------------|----------------------|
| | | | | TYPE=0,1 (GRAMS/SEC) | TYPE=2 (GRAMS/SEC) | | | | | TYPE=0 (DEG. K); VERT. DIM TYPE=1 (METERS) | TYPE=0 (M/SEC); HORZ. DIM TYPE=1,2 (METERS) | DIAMETER TYPE=0 (METERS) | | | | |
| 101 | 0 0 | 0 | 0 | 0.15800E+02 | | 0.0 | 0.0 | 0.0 | 38.10 | 450.00 | 20.00 | 1.83 | 22.00 | 38.10 | 19.80 | |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* 50 MAXIMUM 3-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CON. | PER. | DAY | X | Y (METERS) | RANK | CON. | PER. | DAY | X | Y (METERS) |
|------|----------|------|-----|-------------------------|------------------------------|------|----------|------|-----|-------------------------|------------------------------|
| | | | | OR RANGE (METERS) | OR DIRECTION (DEGREES) | | | | | OR RANGE (METERS) | OR DIRECTION (DEGREES) |
| 1 | 65.70599 | 5 | 354 | 200.0 | 10.0 | 26 | 30.94335 | 4 | 195 | 900.0 | 230.0 |
| 2 | 64.79088 | 6 | 279 | 200.0 | 180.0 | 27 | 30.68432 | 6 | 354 | 200.0 | 360.0 |
| 3 | 57.37053 | 5 | 174 | 200.0 | 50.0 | 28 | 30.31571 | 4 | 195 | 1200.0 | 230.0 |
| 4 | 54.30011 | 5 | 354 | 300.0 | 10.0 | 29 | 29.97215 | 5 | 99 | 1200.0 | 100.0 |
| 5 | 53.42713 | 6 | 279 | 300.0 | 180.0 | 30 | 29.90605 | 5 | 99 | 800.0 | 100.0 |
| 6 | 52.12655 | 5 | 174 | 300.0 | 50.0 | 31 | 29.85774 | 5 | 297 | 1200.0 | 180.0 |
| 7 | 46.15890 | 5 | 279 | 200.0 | 180.0 | 32 | 29.67452 | 4 | 145 | 800.0 | 120.0 |
| 8 | 44.31376 | 7 | 279 | 200.0 | 180.0 | 33 | 29.29259 | 4 | 195 | 800.0 | 230.0 |
| 9 | 42.39250 | 5 | 174 | 400.0 | 50.0 | 34 | 29.28637 | 4 | 145 | 900.0 | 120.0 |
| 10 | 40.39884 | 5 | 354 | 400.0 | 10.0 | 35 | 29.23419 | 5 | 174 | 700.0 | 50.0 |
| 11 | 39.82148 | 6 | 279 | 400.0 | 180.0 | 36 | 29.07681 | 2 | 57 | 300.0 | 180.0 |
| 12 | 39.30048 | 1 | 57 | 200.0 | 180.0 | 37 | 29.04630 | 5 | 174 | 600.0 | 50.0 |
| 13 | 38.15720 | 5 | 279 | 300.0 | 180.0 | 38 | 28.72963 | 5 | 174 | 800.0 | 50.0 |
| 14 | 38.14175 | 4 | 297 | 200.0 | 180.0 | 39 | 28.68524 | 5 | 279 | 400.0 | 180.0 |
| 15 | 37.71254 | 2 | 279 | 200.0 | 190.0 | 40 | 28.60578 | 4 | 145 | 700.0 | 120.0 |
| 16 | 37.36956 | 2 | 57 | 200.0 | 180.0 | 41 | 28.55538 | 6 | 174 | 300.0 | 70.0 |
| 17 | 35.82644 | 7 | 279 | 300.0 | 180.0 | 42 | 28.33520 | 5 | 297 | 900.0 | 180.0 |
| 18 | 35.14147 | 6 | 174 | 200.0 | 70.0 | 43 | 28.23900 | 5 | 297 | 1400.0 | 180.0 |
| 19 | 34.48989 | 3 | 279 | 200.0 | 200.0 | 44 | 27.92768 | 3 | 279 | 300.0 | 200.0 |
| 20 | 34.29166 | 4 | 297 | 300.0 | 180.0 | 45 | 27.86917 | 4 | 195 | 1400.0 | 230.0 |
| 21 | 33.07432 | 8 | 279 | 200.0 | 160.0 | 46 | 27.83660 | 5 | 174 | 900.0 | 50.0 |
| 22 | 31.87090 | 1 | 57 | 300.0 | 180.0 | 47 | 27.72842 | 2 | 279 | 300.0 | 190.0 |
| 23 | 31.54053 | 5 | 99 | 900.0 | 100.0 | 48 | 27.35340 | 3 | 279 | 200.0 | 190.0 |
| 24 | 31.49869 | 4 | 279 | 200.0 | 190.0 | 49 | 27.23460 | 5 | 279 | 200.0 | 190.0 |
| 25 | 31.19017 | 4 | 354 | 200.0 | 340.0 | 50 | 26.96299 | 5 | 99 | 1400.0 | 100.0 |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* 50 MAXIMUM 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y (METERS) OR DIRECTION (DEGREES) | RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y (METERS) OR DIRECTION (DEGREES) |
|------|----------|------|-----|------------------------------|--|------|---------|------|-----|------------------------------|--|
| 1 | 24.37474 | 1 | 279 | 200.0 | 180.0 | 26 | 8.82170 | 1 | 279 | 800.0 | 180.0 |
| 2 | 20.17289 | 1 | 279 | 200.0 | 190.0 | 27 | 8.65411 | 1 | 57 | 300.0 | 170.0 |
| 3 | 19.85328 | 1 | 279 | 300.0 | 180.0 | 28 | 8.46206 | 1 | 354 | 200.0 | 360.0 |
| 4 | 18.29790 | 1 | 57 | 200.0 | 180.0 | 29 | 8.37454 | 1 | 279 | 700.0 | 180.0 |
| 5 | 15.72704 | 1 | 279 | 300.0 | 190.0 | 30 | 8.15836 | 1 | 99 | 900.0 | 100.0 |
| 6 | 14.46021 | 1 | 279 | 400.0 | 180.0 | 31 | 8.05798 | 1 | 174 | 200.0 | 50.0 |
| 7 | 14.30381 | 1 | 57 | 300.0 | 180.0 | 32 | 7.95151 | 1 | 99 | 1200.0 | 100.0 |
| 8 | 12.09255 | 1 | 297 | 1400.0 | 180.0 | 33 | 7.93568 | 1 | 297 | 400.0 | 180.0 |
| 9 | 11.91319 | 1 | 297 | 1700.0 | 180.0 | 34 | 7.79054 | 1 | 297 | 700.0 | 180.0 |
| 10 | 11.84919 | 1 | 297 | 1200.0 | 180.0 | 35 | 7.78329 | 1 | 279 | 600.0 | 180.0 |
| 11 | 11.54615 | 1 | 279 | 200.0 | 200.0 | 36 | 7.70976 | 1 | 99 | 800.0 | 100.0 |
| 12 | 11.40093 | 1 | 297 | 200.0 | 180.0 | 37 | 7.52209 | 1 | 62 | 1200.0 | 300.0 |
| 13 | 11.00122 | 1 | 279 | 400.0 | 190.0 | 38 | 7.47529 | 1 | 62 | 900.0 | 300.0 |
| 14 | 10.99101 | 1 | 354 | 200.0 | 10.0 | 39 | 7.30150 | 1 | 57 | 1700.0 | 180.0 |
| 15 | 10.23361 | 1 | 297 | 900.0 | 180.0 | 40 | 7.29267 | 1 | 99 | 1400.0 | 100.0 |
| 16 | 10.14117 | 1 | 57 | 200.0 | 170.0 | 41 | 7.27696 | 1 | 57 | 1400.0 | 180.0 |
| 17 | 10.13911 | 1 | 297 | 300.0 | 180.0 | 42 | 7.17077 | 1 | 174 | 300.0 | 50.0 |
| 18 | 9.87486 | 1 | 57 | 400.0 | 180.0 | 43 | 7.16988 | 1 | 171 | 900.0 | 230.0 |
| 19 | 9.49823 | 1 | 279 | 1200.0 | 180.0 | 44 | 7.06271 | 1 | 171 | 800.0 | 230.0 |
| 20 | 9.40589 | 1 | 279 | 1400.0 | 180.0 | 45 | 7.05070 | 1 | 57 | 1200.0 | 180.0 |
| 21 | 9.25045 | 1 | 297 | 800.0 | 180.0 | 46 | 6.98520 | 1 | 62 | 1400.0 | 300.0 |
| 22 | 9.13708 | 1 | 279 | 900.0 | 180.0 | 47 | 6.89547 | 1 | 62 | 800.0 | 300.0 |
| 23 | 9.00358 | 1 | 279 | 1700.0 | 180.0 | 48 | 6.82320 | 1 | 354 | 300.0 | 360.0 |
| 24 | 8.97241 | 1 | 354 | 300.0 | 10.0 | 49 | 6.80988 | 1 | 99 | 700.0 | 100.0 |
| 25 | 8.90965 | 1 | 279 | 300.0 | 200.0 | 50 | 6.66927 | 1 | 145 | 900.0 | 120.0 |

| | |
|---|----------------------|
| CALCULATE (CONCENTRATION=1, DEPOSITION=2) | ISW(1) = 1 |
| RECEPTOR GRID SYSTEM (RECTANGULAR=1 OR 3, POLAR=2 OR 4) | ISW(2) = 4 |
| DISCRETE RECEPTOR SYSTEM (RECTANGULAR=1, POLAR=2) | ISW(3) = 2 |
| TERRAIN ELEVATIONS ARE READ (YES=1, NO=0) | ISW(4) = 0 |
| CALCULATIONS ARE WRITTEN TO TAPE (YES=1, NO=0) | ISW(5) = 0 |
| LIST ALL INPUT DATA (NO=0, YES=1, MET DATA ALSO=2) | ISW(6) = 1 |
| | |
| COMPUTE AVERAGE CONCENTRATION (OR TOTAL DEPOSITION) | |
| WITH THE FOLLOWING TIME PERIODS: | |
| HOURLY (YES=1, NO=0) | ISW(7) = 0 |
| 2-HOUR (YES=1, NO=0) | ISW(8) = 0 |
| 3-HOUR (YES=1, NO=0) | ISW(9) = 1 |
| 4-HOUR (YES=1, NO=0) | ISW(10) = 0 |
| 6-HOUR (YES=1, NO=0) | ISW(11) = 0 |
| 8-HOUR (YES=1, NO=0) | ISW(12) = 0 |
| 12-HOUR (YES=1, NO=0) | ISW(13) = 0 |
| 24-HOUR (YES=1, NO=0) | ISW(14) = 1 |
| PRINT "N"-DAY TABLE(S) (YES=1, NO=0) | ISW(15) = 1 |
| | |
| PRINT THE FOLLOWING TYPES OF TABLES WHOSE TIME PERIODS ARE | |
| SPECIFIED BY ISW(7) THROUGH ISW(14): | |
| DAILY TABLES (YES=1, NO=0) | ISW(16) = 0 |
| HIGHEST & SECOND HIGHEST TABLES (YES=1, NO=0) | ISW(17) = 1 |
| MAXIMUM 50 TABLES (YES=1, NO=0) | ISW(18) = 1 |
| METEOROLOGICAL DATA INPUT METHOD (PRE-PROCESSED=1, CARD=2) | ISW(19) = 1 |
| RURAL-URBAN OPTION (RURAL=0, URBAN MODE 1=1, URBAN MODE 2=2) | ISW(20) = 0 |
| WIND PROFILE EXPONENT VALUES (DEFAULTS=1, USER ENTERS=2, 3) | ISW(21) = 1 |
| VERTICAL POT. TEMP. GRADIENT VALUES (DEFAULTS=1, USER ENTERS=2, 3) | ISW(22) = 1 |
| SCALE EMISSION RATES FOR ALL SOURCES (NO=0, YES>0) | ISW(23) = 0 |
| PROGRAM CALCULATES FINAL PLUME RISE ONLY (YES=1, NO=2) | ISW(24) = 2 |
| PROGRAM ADJUSTS ALL STACK HEIGHTS FOR DOWNWASH (YES=2, NO=1) | ISW(25) = 1 |
| | |
| INPUT SPECIAL DIRECTION-DEPENDENT BUILDING DIMENSIONS (YES=1, NO=0) | ISW(26) = 0 |
| | |
| OMIT TABLES FOR HOURLY CONCENTRATIONS (YES=1, NO=0) | ISW(27) = 0 |
| | |
| USEPA ADJUSTMENT FOR CALM HOURS (YES=1, NO=0) | ISW(28) = 1 |
| | |
| NUMBER OF INPUT SOURCES | NSOURC = 1 |
| NUMBER OF SOURCE GROUPS (=0, ALL SOURCES) | NGROUP = 0 |
| TIME PERIOD INTERVAL TO BE PRINTED (=0, ALL INTERVALS) | IPERD = 0 |
| NUMBER OF X (RANGE) GRID VALUES | NXPPTS = 3 |
| NUMBER OF Y (THETA) GRID VALUES | NYPPTS = 36 |
| NUMBER OF DISCRETE RECEPTORS | NXWYPT = 0 |
| SOURCE EMISSION RATE UNITS CONVERSION FACTOR | TK = 10000E+07 |
| ENTRAINMENT COEFFICIENT FOR UNSTABLE ATMOSPHERE | BETA1 = 0.600 |
| ENTRAINMENT COEFFICIENT FOR STABLE ATMOSPHERE | BETA2 = 0.600 |
| HEIGHT ABOVE GROUND AT WHICH WIND SPEED WAS MEASURED | ZR = 10.00 METERS |
| LOGICAL UNIT NUMBER OF METEOROLOGICAL DATA | IMET = 9 |
| DECAY COEFFICIENT FOR PHYSICAL OR CHEMICAL DEPLETION | DECAY = 0.000000E+00 |
| SURFACE STATION NO. | ISS = 12815 |
| YEAR OF SURFACE DATA | ISY = 74 |
| UPPER AIR STATION NO. | IUS = 12842 |
| YEAR OF UPPER AIR DATA | IUY = 74 |
| ALLOCATED DATA STORAGE | LIMIT = 49300 WORDS |

IST-3

1974 - NRG ONLY - SO₂
 Radius of Influence Check

*** RANGES OF POLAR GRID SYSTEM ***
(METERS)

6000.0, 9000.0, 12000.0,

*** RADIAL ANGLES OF POLAR GRID SYSTEM ***

(DEGREES)

| | | | | | | | | | |
|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| 10.0, | 20.0, | 30.0, | 40.0, | 50.0, | 60.0, | 70.0, | 80.0, | 90.0, | 100.0, |
| 110.0, | 120.0, | 130.0, | 140.0, | 150.0, | 160.0, | 170.0, | 180.0, | 190.0, | 200.0, |
| 210.0, | 220.0, | 230.0, | 240.0, | 250.0, | 260.0, | 270.0, | 280.0, | 290.0, | 300.0, |
| 310.0, | 320.0, | 330.0, | 340.0, | 350.0, | 360.0, | | | | |

*** SOURCE DATA ***

| SOURCE NUMBER | P | K | Y A NUMBER | E E CATS. | EMISSION RATE | Y | BASE ELEV. | HEIGHT | TEMP. | EXIT VEL. | BLDG. HEIGHT | BLDG. LENGTH | BLDG. WIDTH | | |
|---------------|---|---|------------|-----------|------------------------|----------|------------|----------|------------------|----------------|--------------|--------------|-------------|-------|-------|
| | | | | | (GRAMS/SEC) TYPE=2 | | | | (DEG. K.) TYPE=1 | (M/SEC) TYPE=0 | | | | | |
| NUMBER | | | | | *PER METER**2 (METERS) | (METERS) | (METERS) | (METERS) | (METERS) | (METERS) | (METERS) | (METERS) | (METERS) | | |
| 101 | 0 | 0 | 0 | | 0.15900E+02 | 0.0 | 0.0 | 0.0 | 38.10 | 450.00 | 20.00 | 1.83 | 22.00 | 38.10 | 19.80 |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* 50 MAXIMUM 3-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CON. | PER. | DAY | X OR RANGE | | Y(METERS) OR DIRECTION | | RANK | CON. | PER. | DAY | X OR RANGE | | Y(METERS) OR DIRECTION | |
|------|----------|------|-----|------------------|-----------|------------------------------|-----------|------|------|--------|-------|------------------|-----------|------------------------------|--|
| | | | | (METERS) | (DEGREES) | (METERS) | (DEGREES) | | | | | (METERS) | (DEGREES) | | |
| 1 | 65.70599 | 5 | 354 | 200.0 | 10.0 | 26 | 30.94335 | 4 | 195 | 900.0 | 230.0 | | | | |
| 2 | 64.79088 | 6 | 279 | 200.0 | 180.0 | 27 | 30.68432 | 6 | 354 | 200.0 | 360.0 | | | | |
| 3 | 57.37053 | 5 | 174 | 200.0 | 50.0 | 28 | 30.31571 | 4 | 195 | 1200.0 | 230.0 | | | | |
| 4 | 54.30011 | 5 | 354 | 300.0 | 10.0 | 29 | 29.97215 | 5 | 99 | 1200.0 | 100.0 | | | | |
| 5 | 53.42913 | 6 | 279 | 300.0 | 180.0 | 30 | 29.90605 | 5 | 99 | 800.0 | 100.0 | | | | |
| 6 | 52.12655 | 5 | 174 | 300.0 | 50.0 | 31 | 29.85774 | 5 | 297 | 1200.0 | 180.0 | | | | |
| 7 | 46.15890 | 5 | 279 | 200.0 | 180.0 | 32 | 29.67452 | 4 | 145 | 800.0 | 120.0 | | | | |
| 8 | 44.31376 | 7 | 279 | 200.0 | 180.0 | 33 | 29.29259 | 4 | 195 | 800.0 | 230.0 | | | | |
| 9 | 42.39250 | 5 | 174 | 400.0 | 50.0 | 34 | 29.28637 | 4 | 145 | 900.0 | 120.0 | | | | |
| 10 | 40.39886 | 5 | 354 | 400.0 | 10.0 | 35 | 29.23419 | 5 | 174 | 700.0 | 50.0 | | | | |
| 11 | 39.82148 | 6 | 279 | 400.0 | 180.0 | 36 | 29.07681 | 2 | 57 | 300.0 | 180.0 | | | | |
| 12 | 39.30048 | 1 | 57 | 200.0 | 180.0 | 37 | 29.04630 | 5 | 174 | 600.0 | 50.0 | | | | |
| 13 | 38.15720 | 5 | 279 | 300.0 | 180.0 | 38 | 28.72963 | 5 | 174 | 800.0 | 50.0 | | | | |
| 14 | 38.14175 | 4 | 297 | 200.0 | 180.0 | 39 | 28.68524 | 5 | 279 | 400.0 | 180.0 | | | | |
| 15 | 37.71254 | 2 | 279 | 200.0 | 190.0 | 40 | 28.60578 | 4 | 145 | 700.0 | 120.0 | | | | |
| 16 | 37.36956 | 2 | 57 | 200.0 | 180.0 | 41 | 28.55538 | 6 | 174 | 300.0 | 70.0 | | | | |
| 17 | 35.82644 | 7 | 279 | 300.0 | 180.0 | 42 | 28.33520 | 5 | 297 | 900.0 | 180.0 | | | | |
| 18 | 35.14147 | 6 | 174 | 200.0 | 70.0 | 43 | 28.23900 | 5 | 297 | 1400.0 | 180.0 | | | | |
| 19 | 34.48989 | 3 | 279 | 200.0 | 200.0 | 44 | 27.92768 | 3 | 279 | 300.0 | 200.0 | | | | |
| 20 | 34.29166 | 4 | 297 | 300.0 | 180.0 | 45 | 27.86917 | 4 | 195 | 1400.0 | 230.0 | | | | |
| 21 | 33.07432 | 8 | 279 | 200.0 | 160.0 | 46 | 27.83660 | 5 | 174 | 900.0 | 50.0 | | | | |
| 22 | 31.87090 | 1 | 57 | 300.0 | 180.0 | 47 | 27.72842 | 2 | 279 | 300.0 | 190.0 | | | | |
| 23 | 31.54053 | 5 | 99 | 900.0 | 100.0 | 48 | 27.35340 | 3 | 279 | 200.0 | 190.0 | | | | |
| 24 | 31.49869 | 4 | 279 | 200.0 | 190.0 | 49 | 27.23460 | 5 | 279 | 200.0 | 190.0 | | | | |
| 25 | 31.19017 | 4 | 354 | 200.0 | 340.0 | 50 | 26.96299 | 5 | 99 | 1400.0 | 100.0 | | | | |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* 50 MAXIMUM 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) | RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) |
|------|----------|------|-----|------------------------------|---|------|---------|------|-----|------------------------------|---|
| 1 | 24.37474 | 1 | 279 | 200.0 | 180.0 | 26 | 8.82170 | 1 | 279 | 800.0 | 180.0 |
| 2 | 20.17289 | 1 | 279 | 200.0 | 190.0 | 27 | 8.65411 | 1 | 57 | 300.0 | 170.0 |
| 3 | 19.85828 | 1 | 279 | 300.0 | 180.0 | 28 | 8.46206 | 1 | 354 | 200.0 | 360.0 |
| 4 | 18.29990 | 1 | 57 | 200.0 | 180.0 | 29 | 8.37454 | 1 | 279 | 700.0 | 180.0 |
| 5 | 15.72704 | 1 | 279 | 300.0 | 170.0 | 30 | 8.15836 | 1 | 99 | 900.0 | 100.0 |
| 6 | 14.46021 | 1 | 279 | 400.0 | 180.0 | 31 | 8.05798 | 1 | 174 | 200.0 | 50.0 |
| 7 | 14.30381 | 1 | 57 | 300.0 | 180.0 | 32 | 7.95151 | 1 | 99 | 1200.0 | 100.0 |
| 8 | 12.09255 | 1 | 297 | 1400.0 | 180.0 | 33 | 7.93568 | 1 | 297 | 400.0 | 180.0 |
| 9 | 11.91319 | 1 | 297 | 1700.0 | 180.0 | 34 | 7.79054 | 1 | 297 | 700.0 | 180.0 |
| 10 | 11.84919 | 1 | 297 | 1200.0 | 180.0 | 35 | 7.78329 | 1 | 279 | 600.0 | 180.0 |
| 11 | 11.54615 | 1 | 279 | 200.0 | 200.0 | 36 | 7.70976 | 1 | 99 | 800.0 | 100.0 |
| 12 | 11.40093 | 1 | 297 | 200.0 | 180.0 | 37 | 7.52209 | 1 | 62 | 1200.0 | 300.0 |
| 13 | 11.00122 | 1 | 279 | 400.0 | 190.0 | 38 | 7.47529 | 1 | 62 | 900.0 | 300.0 |
| 14 | 10.99101 | 1 | 354 | 200.0 | 10.0 | 39 | 7.30150 | 1 | 57 | 1700.0 | 180.0 |
| 15 | 10.23361 | 1 | 297 | 900.0 | 180.0 | 40 | 7.29267 | 1 | 99 | 1400.0 | 100.0 |
| 16 | 10.14117 | 1 | 57 | 200.0 | 170.0 | 41 | 7.27696 | 1 | 57 | 1400.0 | 180.0 |
| 17 | 10.13911 | 1 | 297 | 300.0 | 180.0 | 42 | 7.17077 | 1 | 174 | 300.0 | 50.0 |
| 18 | 9.87486 | 1 | 57 | 400.0 | 180.0 | 43 | 7.16988 | 1 | 171 | 900.0 | 230.0 |
| 19 | 9.49823 | 1 | 279 | 1200.0 | 180.0 | 44 | 7.06271 | 1 | 171 | 800.0 | 230.0 |
| 20 | 9.40589 | 1 | 279 | 1400.0 | 180.0 | 45 | 7.05070 | 1 | 57 | 1200.0 | 180.0 |
| 21 | 9.25045 | 1 | 297 | 800.0 | 180.0 | 46 | 6.98520 | 1 | 62 | 1400.0 | 300.0 |
| 22 | 9.13908 | 1 | 279 | 900.0 | 180.0 | 47 | 6.89547 | 1 | 62 | 800.0 | 300.0 |
| 23 | 9.00358 | 1 | 279 | 1700.0 | 180.0 | 48 | 6.82320 | 1 | 354 | 300.0 | 360.0 |
| 24 | 8.97241 | 1 | 354 | 300.0 | 10.0 | 49 | 6.80988 | 1 | 99 | 700.0 | 100.0 |
| 25 | 8.90965 | 1 | 279 | 300.0 | 200.0 | 50 | 6.66927 | 1 | 145 | 900.0 | 120.0 |

| | |
|---|----------------------|
| CALCULATE (CONCENTRATION=1, DEPOSITION=2) | ISW(1) = 1 |
| RECEPTOR GRID SYSTEM (RECTANGULAR=1 OR 3, POLAR=2 OR 4) | ISW(2) = 4 |
| DISCRETE RECEPTOR SYSTEM (RECTANGULAR=1, POLAR=2) | ISW(3) = 2 |
| TERRAIN ELEVATIONS ARE READ (YES=1, NO=0) | ISW(4) = 0 |
| CALCULATIONS ARE WRITTEN TO TAPE (YES=1, NO=0) | ISW(5) = 0 |
| LIST ALL INPUT DATA (NO=0, YES=1, MET DATA ALSO=2) | ISW(6) = 1 |
| | |
| COMPUTE AVERAGE CONCENTRATION (OR TOTAL DEPOSITION) | |
| WITH THE FOLLOWING TIME PERIODS: | |
| HOURLY (YES=1, NO=0) | ISW(7) = 0 |
| 2-HOUR (YES=1, NO=0) | ISW(8) = 0 |
| 3-HOUR (YES=1, NO=0) | ISW(9) = 1 |
| 4-HOUR (YES=1, NO=0) | ISW(10) = 0 |
| 6-HOUR (YES=1, NO=0) | ISW(11) = 0 |
| 8-HOUR (YES=1, NO=0) | ISW(12) = 0 |
| 12-HOUR (YES=1, NO=0) | ISW(13) = 0 |
| 24-HOUR (YES=1, NO=0) | ISW(14) = 1 |
| PRINT "N"-DAY TABLE(S) (YES=1, NO=0) | ISW(15) = 1 |
| | |
| PRINT THE FOLLOWING TYPES OF TABLES WHOSE TIME PERIODS ARE | |
| SPECIFIED BY ISW(7) THROUGH ISW(14): | |
| DAILY TABLES (YES=1, NO=0) | ISW(16) = 0 |
| HIGHEST & SECOND HIGHEST TABLES (YES=1, NO=0) | ISW(17) = 1 |
| MAXIMUM 50 TABLES (YES=1, NO=0) | ISW(18) = 1 |
| METEOROLOGICAL DATA INPUT METHOD (PRE-PROCESSED=1, CARD=2) | ISW(19) = 1 |
| RURAL-URBAN OPTION (RURAL=0, URBAN MODE 1=1, URBAN MODE 2=2) | ISW(20) = 0 |
| WIND PROFILE EXPONENT VALUES (DEFAULTS=1, USER ENTERS=2, 3) | ISW(21) = 1 |
| VERTICAL PDT. TEMP. GRADIENT VALUES (DEFAULTS=1, USER ENTERS=2, 3) | ISW(22) = 1 |
| SCALE EMISSION RATES FOR ALL SOURCES (NO=0, YES>0) | ISW(23) = 0 |
| PROGRAM CALCULATES FINAL PLUME RISE ONLY (YES=1, NO=2) | ISW(24) = 2 |
| PROGRAM ADJUSTS ALL STACK HEIGHTS FOR DOWNWASH (YES=2, NO=1) | ISW(25) = 1 |
| | |
| INPUT SPECIAL DIRECTION-DEPENDENT BUILDING DIMENSIONS (YES=1, NO=0) | ISW(26) = 0 |
| | |
| OMIT TABLES FOR HOURLY CONCENTRATIONS (YES=1, NO=0) | ISW(27) = 0 |
| | |
| USEPA ADJUSTMENT FOR CALM HOURS (YES=1, NO=0) | ISW(28) = 1 |
| | |
| NUMBER OF INPUT SOURCES | NSOURC = 1 |
| NUMBER OF SOURCE GROUPS (=0, ALL SOURCES) | NGROUP = 0 |
| TIME PERIOD INTERVAL TO BE PRINTED (=0, ALL INTERVALS) | IPERD = 0 |
| NUMBER OF X (RANGE) GRID VALUES | NXPNTS = 3 |
| NUMBER OF Y (THETA) GRID VALUES | NYPNTS = 36 |
| NUMBER OF DISCRETE RECEPTORS | NXWYPT = 0 |
| SOURCE EMISSION RATE UNITS CONVERSION FACTOR | TK = 1.0000E+07 |
| ENTRAINMENT COEFFICIENT FOR UNSTABLE ATMOSPHERE | BETA1 = 0.600 |
| ENTRAINMENT COEFFICIENT FOR STABLE ATMOSPHERE | BETA2 = 0.600 |
| HEIGHT ABOVE GROUND AT WHICH WIND SPEED WAS MEASURED | ZR = 10.00 METERS |
| LOGICAL UNIT NUMBER OF METEOROLOGICAL DATA | IMET = 9 |
| DECAY COEFFICIENT FOR PHYSICAL OR CHEMICAL DEPLETION | DECAY = 0.000000E+00 |
| SURFACE STATION NO. | ISS = 12815 |
| YEAR OF SURFACE DATA | ISY = 74 |
| UPPER AIR STATION NO. | IUS = 12842 |
| YEAR OF UPPER AIR DATA | IUY = 74 |
| ALLOCATED DATA STORAGE | LIMIT = 49500 WORDS |

IST-3

1974 - NRG ONLY - SO₂
 Radius of Influence Check

*** RANGES OF POLAR GRID SYSTEM ***
(METERS)

6000. 0. 9000. 0. 12000. 0.

*** RADIAL ANGLES OF POLAR GRID SYSTEM ***

(DEGREES)

| | | | | | | | | | |
|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| 10. 0. | 20. 0. | 30. 0. | 40. 0. | 50. 0. | 60. 0. | 70. 0. | 80. 0. | 90. 0. | 100. 0. |
| 110. 0. | 120. 0. | 130. 0. | 140. 0. | 150. 0. | 160. 0. | 170. 0. | 180. 0. | 190. 0. | 200. 0. |
| 210. 0. | 220. 0. | 230. 0. | 240. 0. | 250. 0. | 260. 0. | 270. 0. | 280. 0. | 290. 0. | 300. 0. |
| 310. 0. | 320. 0. | 330. 0. | 340. 0. | 350. 0. | 360. 0. | | | | |

*** SOURCE DATA ***

| SOURCE NUMBER | T W Y A P K E E | PART. CATS. | EMISSION RATE | X (METERS) | Y (METERS) | BASE ELEV. (METERS) | HEIGHT (METERS) | TEMP. | VERT. DIM TYPE=1 (METERS) | EXIT VEL. | HORZ. DIM TYPE=1,2 (METERS) | DIAMETER TYPE=0 (METERS) | BLDG. | BLDG. | BLDG. |
|---------------|--------------------------|----------------|---|---------------|---------------|---------------------------|--------------------|-----------|---------------------------------|-----------|-----------------------------------|--------------------------------|------------------------------|------------------------------|-----------------------------|
| | | | TYPE=0,1 (GRAMS/SEC) TYPE=2 (GRAMS/SEC) *PER METER**2 | | | | | (DEG. K.) | | (M/SEC) | | | HEIGHT TYPE=0 (METERS) | LENGTH TYPE=0 (METERS) | WIDTH TYPE=0 (METERS) |
| 101 | 0 0 | 0 | 0.15900E+02 | 0.0 | 0.0 | 0.0 | 38.10 | 450.00 | | 20.00 | 1.83 | | 22.00 | 38.10 | 19.80 |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* 365-DAY AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 0.38749 AND OCCURRED AT (6000.0, 180.0) *

DIRECTION / RANGE (METERS)
(DEGREES) / 6000.0 9000.0 12000.0

| | | | |
|---------|---------|---------|---------|
| 350.0 / | 0.27173 | 0.21409 | 0.17789 |
| 350.0 / | 0.19421 | 0.14113 | 0.11547 |
| 340.0 / | 0.22365 | 0.17149 | 0.13933 |
| 330.0 / | 0.15205 | 0.12590 | 0.10335 |
| 320.0 / | 0.19289 | 0.15495 | 0.13004 |
| 310.0 / | 0.20005 | 0.15256 | 0.12337 |
| 300.0 / | 0.23015 | 0.18255 | 0.15316 |
| 290.0 / | 0.19631 | 0.14858 | 0.12028 |
| 280.0 / | 0.20342 | 0.14898 | 0.11732 |
| 270.0 / | 0.24165 | 0.18905 | 0.15566 |
| 260.0 / | 0.23451 | 0.19399 | 0.16575 |
| 250.0 / | 0.27441 | 0.22814 | 0.19523 |
| 240.0 / | 0.24999 | 0.20344 | 0.17337 |
| 230.0 / | 0.28343 | 0.22747 | 0.19049 |
| 220.0 / | 0.29509 | 0.24419 | 0.20577 |
| 210.0 / | 0.24084 | 0.20276 | 0.17520 |
| 200.0 / | 0.29769 | 0.25255 | 0.21906 |
| 190.0 / | 0.19479 | 0.14893 | 0.12538 |
| 190.0 / | 0.38749 | 0.33042 | 0.28520 |
| 170.0 / | 0.19641 | 0.15507 | 0.12802 |
| 160.0 / | 0.12800 | 0.10031 | 0.08328 |
| 150.0 / | 0.12873 | 0.09219 | 0.07207 |
| 140.0 / | 0.14609 | 0.10141 | 0.07725 |
| 130.0 / | 0.14142 | 0.10139 | 0.07910 |
| 120.0 / | 0.17079 | 0.13093 | 0.10689 |
| 110.0 / | 0.15619 | 0.12238 | 0.10122 |
| 100.0 / | 0.13449 | 0.09894 | 0.07814 |
| 90.0 / | 0.15414 | 0.11845 | 0.09567 |
| 90.0 / | 0.13759 | 0.10658 | 0.08720 |
| 70.0 / | 0.13966 | 0.10641 | 0.08641 |
| 60.0 / | 0.17521 | 0.13497 | 0.11010 |
| 50.0 / | 0.14292 | 0.10241 | 0.07959 |
| 40.0 / | 0.15604 | 0.12172 | 0.09982 |
| 30.0 / | 0.14185 | 0.11023 | 0.08993 |
| 20.0 / | 0.15459 | 0.11771 | 0.09490 |
| 10.0 / | 0.16501 | 0.12166 | 0.09690 |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* 50 MAXIMUM 3-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) | RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) |
|------|----------|------|-----|------------------------------|---|------|----------|------|-----|------------------------------|---|
| 1 | 14.45964 | 8 | 209 | 6000.0 | 360.0 | 26 | 10.45400 | 2 | 107 | 9000.0 | 180.0 |
| 2 | 13.95005 | 1 | 85 | 9000.0 | 180.0 | 27 | 10.23366 | 2 | 270 | 9000.0 | 320.0 |
| 3 | 13.00511 | 1 | 297 | 6000.0 | 200.0 | 28 | 10.22667 | 8 | 316 | 6000.0 | 140.0 |
| 4 | 12.83788 | 1 | 85 | 12000.0 | 180.0 | 29 | 10.21164 | 7 | 354 | 6000.0 | 40.0 |
| 5 | 12.72612 | 1 | 85 | 6000.0 | 180.0 | 30 | 10.19625 | 1 | 146 | 6000.0 | 80.0 |
| 6 | 12.29019 | 7 | 325 | 6000.0 | 90.0 | 31 | 10.14399 | 2 | 21 | 6000.0 | 350.0 |
| 7 | 12.21781 | 6 | 3 | 6000.0 | 290.0 | 32 | 10.11763 | 1 | 277 | 6000.0 | 170.0 |
| 8 | 12.05925 | 7 | 133 | 6000.0 | 230.0 | 33 | 10.06826 | 7 | 354 | 7000.0 | 40.0 |
| 9 | 11.96814 | 2 | 107 | 6000.0 | 180.0 | 34 | 10.05092 | 2 | 270 | 6000.0 | 320.0 |
| 10 | 11.95522 | 2 | 342 | 6000.0 | 350.0 | 35 | 9.98942 | 1 | 297 | 12000.0 | 200.0 |
| 11 | 11.95089 | 7 | 50 | 6000.0 | 50.0 | 36 | 9.93296 | 1 | 41 | 6000.0 | 150.0 |
| 12 | 11.83147 | 2 | 311 | 6000.0 | 170.0 | 37 | 9.92039 | 8 | 332 | 6000.0 | 200.0 |
| 13 | 11.76633 | 2 | 39 | 6000.0 | 40.0 | 38 | 9.89326 | 2 | 139 | 12000.0 | 270.0 |
| 14 | 11.58725 | 7 | 73 | 6000.0 | 240.0 | 39 | 9.86386 | 1 | 146 | 9000.0 | 80.0 |
| 15 | 11.56827 | 1 | 297 | 9000.0 | 200.0 | 40 | 9.80284 | 1 | 148 | 9000.0 | 220.0 |
| 16 | 11.56215 | 1 | 148 | 6000.0 | 220.0 | 41 | 9.66149 | 8 | 349 | 6000.0 | 50.0 |
| 17 | 11.51604 | 8 | 209 | 9000.0 | 360.0 | 42 | 9.64474 | 7 | 37 | 6000.0 | 310.0 |
| 18 | 11.48401 | 7 | 146 | 6000.0 | 80.0 | 43 | 9.61996 | 8 | 174 | 6000.0 | 30.0 |
| 19 | 11.46225 | 3 | 297 | 6000.0 | 180.0 | 44 | 9.53557 | 2 | 267 | 6000.0 | 220.0 |
| 20 | 11.32927 | 2 | 147 | 6000.0 | 40.0 | 45 | 9.51445 | 8 | 207 | 6000.0 | 360.0 |
| 21 | 11.13165 | 1 | 89 | 6000.0 | 60.0 | 46 | 9.50911 | 2 | 139 | 9000.0 | 270.0 |
| 22 | 11.09122 | 6 | 143 | 6000.0 | 40.0 | 47 | 9.43803 | 1 | 175 | 6000.0 | 30.0 |
| 23 | 10.88381 | 7 | 325 | 9000.0 | 90.0 | 48 | 9.42668 | 3 | 324 | 6000.0 | 360.0 |
| 24 | 10.69809 | 6 | 296 | 6000.0 | 200.0 | 49 | 9.39067 | 7 | 325 | 12000.0 | 90.0 |
| 25 | 10.52118 | 6 | 30 | 6000.0 | 60.0 | 50 | 9.37967 | 6 | 113 | 6000.0 | 100.0 |

*** NRC/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* HIGHEST 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *
* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 5.91405 AND OCCURRED AT (5000.0, 180.0) *

| DIRECTION / (DEGREES) / | RANGE (METERS) | | |
|----------------------------|--------------------|--------------------|------------------|
| | 6000.0 | 9000.0 | 12000.0 |
| 360.0 / | 3.76177 (33, 1) | 3.08406 (209, 1) | 2.85997 (209, 1) |
| 350.0 / | 2.29921 (21, 1) | 1.92485 (21, 1) | 1.57437 (21, 1) |
| 340.0 / | 2.32068 (50, 1) | 2.02318 (50, 1) | 1.71973 (50, 1) |
| 330.0 / | 1.94701 (63, 1) | 1.61484 (354, 1) | 1.36685 (354, 1) |
| 320.0 / | 2.19026 (183, 1) | 1.74477 (183, 1) | 1.40017 (75, 1) |
| 310.0 / | 2.53313 (37, 1) | 1.92922 (37, 1) | 1.49900 (37, 1) |
| 300.0 / | 2.26276 (361, 1) | 2.00776 (25, 1) | 2.00207 (25, 1) |
| 290.0 / | 3.05965 (102, 1) | 2.08400 (102, 1) | 1.52489 (102, 1) |
| 280.0 / | 2.44253 (74, 1) | 1.75183 (65, 1) | 1.85135 (65, 1) |
| 270.0 / | 1.83236 (302, 1) | 1.70612 (111, 1) | 1.72570 (111, 1) |
| 260.0 / | 2.57071 (365, 1) | 1.87753 (365, 1) | 1.65623 (242, 1) |
| 250.0 / | 2.27182 (340, 1) | 2.16515 (66, 1) | 2.29452 (66, 1) |
| 240.0 / | 3.36618 (73, 1) | 2.23668 (73, 1) | 1.75632 (320, 1) |
| 230.0 / | 3.25835 (267, 1) | 2.17620 (267, 1) | 1.71805 (227, 1) |
| 220.0 / | 2.39359 (267, 1) | 2.21172 (267, 1) | 2.11786 (287, 1) |
| 210.0 / | 4.76534 (348, 1) | 3.74682 (348, 1) | 2.96003 (348, 1) |
| 200.0 / | 4.54831 (296, 1) | 3.33598 (296, 1) | 2.60129 (296, 1) |
| 190.0 / | 2.86450 (313, 1) | 1.80712 (313, 1) | 1.41645 (318, 1) |
| 180.0 / | 5.91405 (297, 1) ✓ | 4.11100 (297, 1) ✓ | 3.06265 (297, 1) |
| 170.0 / | 2.85057 (311, 1) | 1.93005 (311, 1) | 1.50937 (277, 1) |
| 160.0 / | 2.45600 (280, 1) | 1.52399 (315, 1) | 1.69346 (315, 1) |
| 150.0 / | 2.41797 (280, 1) | 1.58920 (363, 1) | 1.35101 (363, 1) |
| 140.0 / | 2.89185 (325, 1) | 1.87989 (325, 1) | 1.34706 (325, 1) |
| 130.0 / | 2.66784 (40, 1) | 1.84132 (40, 1) | 1.35993 (40, 1) |
| 120.0 / | 3.08333 (40, 1) | 2.15412 (316, 1) | 1.65506 (316, 1) |
| 110.0 / | 3.08413 (351, 1) | 2.24474 (7, 1) | 1.95457 (7, 1) |
| 100.0 / | 2.61997 (351, 1) | 2.01755 (351, 1) | 1.56548 (351, 1) |
| 90.0 / | 2.84419 (192, 1) | 2.18064 (192, 1) | 1.76882 (192, 1) |
| 80.0 / | 3.50526 (146, 1) | 2.91912 (146, 1) | 2.38116 (146, 1) |
| 70.0 / | 1.99164 (89, 1) | 1.60382 (89, 1) | 1.41974 (89, 1) |
| 60.0 / | 2.91125 (88, 1) | 2.13840 (88, 1) | 1.68854 (88, 1) |
| 50.0 / | 2.29760 (39, 1) | 1.47776 (39, 1) | 1.15636 (98, 1) |
| 40.0 / | 2.94078 (147, 1) | 2.14867 (147, 1) | 1.62067 (147, 1) |
| 30.0 / | 2.14898 (7, 1) | 2.11255 (7, 1) | 1.84146 (7, 1) |
| 20.0 / | 2.01037 (79, 1) | 1.58619 (79, 1) | 1.24538 (359, 1) |
| 10.0 / | 2.11217 (11, 1) | 1.47388 (178, 1) | 1.18431 (178, 1) |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* SECOND HIGHEST 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *
* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 3.50303 AND OCCURRED AT (6000.0, 180.0) *

| DIRECTION / (DEGREES) / | RANGE (METERS) | | |
|----------------------------|--------------------|------------------|------------------|
| | 6000.0 | 9000.0 | 12000.0 |
| 360.0 / | 3.08809 (209, 1) | 2.81813 (33, 1) | 2.18887 (33, 1) |
| 350.0 / | 2.17897 (95, 1) | 1.51636 (95, 1) | 1.12226 (95, 1) |
| 340.0 / | 2.29234 (217, 1) | 1.93468 (217, 1) | 1.62155 (217, 1) |
| 330.0 / | 1.80684 (354, 1) | 1.39206 (27, 1) | 1.32719 (27, 1) |
| 320.0 / | 1.85537 (248, 1) | 1.66772 (75, 1) | 1.39979 (183, 1) |
| 310.0 / | 1.98312 (130, 1) | 1.57461 (130, 1) | 1.36604 (190, 1) |
| 300.0 / | 2.19294 (357, 1) | 1.82330 (357, 1) | 1.83037 (221, 1) |
| 290.0 / | 2.66877 (3, 1) | 1.87278 (3, 1) | 1.40738 (3, 1) |
| 280.0 / | 2.19443 (102, 1) | 1.61299 (74, 1) | 1.52441 (60, 1) |
| 270.0 / | 1.77789 (361, 1) | 1.46915 (112, 1) | 1.49377 (112, 1) |
| 260.0 / | 2.11512 (302, 1) | 1.65836 (302, 1) | 1.44988 (139, 1) |
| 250.0 / | 2.08509 (248, 1) | 1.86329 (248, 1) | 1.89246 (111, 1) |
| 240.0 / | 2.07616 (320, 1) | 1.96267 (320, 1) | 1.60730 (73, 1) |
| 230.0 / | 2.79016 (295, 1) | 1.89803 (327, 1) | 1.58567 (267, 1) |
| 220.0 / | 2.35202 (258, 1) | 1.92993 (258, 1) | 1.65194 (258, 1) |
| 210.0 / | 1.85993 (224, 1) | 1.64096 (224, 1) | 1.37902 (224, 1) |
| 200.0 / | 2.86388 (360, 1) | 2.37290 (360, 1) | 1.94927 (360, 1) |
| 190.0 / | 2.38352 (279, 1) | 1.59656 (310, 1) | 1.26527 (313, 1) |
| 180.0 / | 3.50303 (276, 1) ✓ | 2.96678 (107, 1) | 2.68711 (59, 1) |
| 170.0 / | 2.67528 (332, 1) | 1.86053 (332, 1) | 1.40972 (36, 1) |
| 160.0 / | 1.95621 (48, 1) | 1.52054 (280, 1) | 1.46554 (286, 1) |
| 150.0 / | 2.13563 (41, 1) | 1.51924 (41, 1) | 1.15801 (41, 1) |
| 140.0 / | 2.27721 (316, 1) | 1.51301 (316, 1) | 1.16712 (355, 1) |
| 130.0 / | 2.35092 (355, 1) | 1.75480 (355, 1) | 1.33950 (355, 1) |
| 120.0 / | 2.96465 (316, 1) | 2.09180 (40, 1) | 1.52225 (40, 1) |
| 110.0 / | 2.57850 (335, 1) | 2.24028 (351, 1) | 1.71882 (351, 1) |
| 100.0 / | 2.01511 (39, 1) | 1.37893 (95, 1) | 1.22260 (95, 1) |
| 90.0 / | 1.82773 (144, 1) | 1.43025 (325, 1) | 1.24829 (325, 1) |
| 80.0 / | 2.73947 (71, 1) | 2.44464 (71, 1) | 2.15643 (71, 1) |
| 70.0 / | 1.54772 (88, 1) | 1.14701 (272, 1) | 1.11712 (272, 1) |
| 60.0 / | 2.04485 (90, 1) | 1.66928 (31, 1) | 1.43294 (31, 1) |
| 50.0 / | 1.74137 (98, 1) | 1.41062 (98, 1) | 1.04415 (39, 1) |
| 40.0 / | 2.30301 (31, 1) | 1.77176 (31, 1) | 1.36654 (31, 1) |
| 30.0 / | 2.13429 (126, 1) | 1.99429 (126, 1) | 1.79548 (126, 1) |
| 20.0 / | 1.82498 (38, 1) | 1.41089 (359, 1) | 1.21396 (79, 1) |
| 10.0 / | 1.74311 (178, 1) | 1.40791 (11, 1) | 1.01827 (11, 1) |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* 50 MAXIMUM 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) | RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) |
|------|---------|------|-----|------------------------------|---|------|---------|------|-----|------------------------------|---|
| 1 | 5.91405 | 1 | 297 | 6000.0 | 180.0 | 26 | 2.96003 | 1 | 348 | 12000.0 | 210.0 |
| 2 | 4.76534 | 1 | 348 | 6000.0 | 210.0 | 27 | 2.94078 | 1 | 147 | 6000.0 | 40.0 |
| 3 | 4.54831 | 1 | 296 | 6000.0 | 200.0 | 28 | 2.91912 | 1 | 146 | 9000.0 | 80.0 |
| 4 | 4.11100 | 1 | 297 | 9000.0 | 180.0 | 29 | 2.91125 | 1 | 88 | 6000.0 | 60.0 |
| 5 | 3.76177 | 1 | 33 | 6000.0 | 360.0 | 30 | 2.89185 | 1 | 325 | 6000.0 | 140.0 |
| 6 | 3.74682 | 1 | 348 | 9000.0 | 210.0 | 31 | 2.86450 | 1 | 313 | 6000.0 | 190.0 |
| 7 | 3.50526 | 1 | 146 | 6000.0 | 80.0 | 32 | 2.86388 | 1 | 360 | 6000.0 | 200.0 |
| 8 | 3.50303 | 1 | 276 | 6000.0 | 180.0 | 33 | 2.85397 | 1 | 209 | 12000.0 | 360.0 |
| 9 | 3.41029 | 1 | 57 | 6000.0 | 180.0 | 34 | 2.85057 | 1 | 311 | 6000.0 | 170.0 |
| 10 | 3.36616 | 1 | 73 | 6000.0 | 240.0 | 35 | 2.84419 | 1 | 192 | 6000.0 | 90.0 |
| 11 | 3.33598 | 1 | 296 | 9000.0 | 200.0 | 36 | 2.81813 | 1 | 33 | 9000.0 | 360.0 |
| 12 | 3.30301 | 1 | 313 | 6000.0 | 180.0 | 37 | 2.79016 | 1 | 295 | 6000.0 | 230.0 |
| 13 | 3.29745 | 1 | 107 | 6000.0 | 180.0 | 38 | 2.73949 | 1 | 71 | 6000.0 | 80.0 |
| 14 | 3.28695 | 1 | 279 | 6000.0 | 180.0 | 39 | 2.69115 | 1 | 276 | 9000.0 | 180.0 |
| 15 | 3.26682 | 1 | 298 | 6000.0 | 180.0 | 40 | 2.68711 | 1 | 59 | 12000.0 | 180.0 |
| 16 | 3.25835 | 1 | 267 | 6000.0 | 230.0 | 41 | 2.67528 | 1 | 332 | 6000.0 | 170.0 |
| 17 | 3.10336 | 1 | 266 | 6000.0 | 180.0 | 42 | 2.66879 | 1 | 3 | 6000.0 | 290.0 |
| 18 | 3.08809 | 1 | 209 | 6000.0 | 360.0 | 43 | 2.66784 | 1 | 40 | 6000.0 | 130.0 |
| 19 | 3.08413 | 1 | 351 | 6000.0 | 110.0 | 44 | 2.61997 | 1 | 351 | 6000.0 | 100.0 |
| 20 | 3.08406 | 1 | 209 | 9000.0 | 360.0 | 45 | 2.60129 | 1 | 296 | 12000.0 | 200.0 |
| 21 | 3.08333 | 1 | 40 | 6000.0 | 120.0 | 46 | 2.59538 | 1 | 107 | 12000.0 | 180.0 |
| 22 | 3.06265 | 1 | 297 | 12000.0 | 180.0 | 47 | 2.57850 | 1 | 335 | 6000.0 | 110.0 |
| 23 | 3.05965 | 1 | 102 | 6000.0 | 290.0 | 48 | 2.57091 | 1 | 365 | 6000.0 | 260.0 |
| 24 | 2.96678 | 1 | 107 | 9000.0 | 180.0 | 49 | 2.56202 | 1 | 85 | 6000.0 | 180.0 |
| 25 | 2.96465 | 1 | 316 | 6000.0 | 120.0 | 50 | 2.55348 | 1 | 28 | 6000.0 | 360.0 |

| | |
|---|----------------------|
| CALCULATE (CONCENTRATION=1, DEPOSITION=2) | ISW(1) = 1 |
| RECEPTOR GRID SYSTEM (RECTANGULAR=1 OR 3, POLAR=2 OR 4) | ISW(2) = 4 |
| DISCRETE RECEPTOR SYSTEM (RECTANGULAR=1, POLAR=2) | ISW(3) = 2 |
| TERRAIN ELEVATIONS ARE READ (YES=1, NO=0) | ISW(4) = 0 |
| CALCULATIONS ARE WRITTEN TO TAPE (YES=1, NO=0) | ISW(5) = 0 |
| LIST ALL INPUT DATA (NO=0, YES=1, MET DATA ALSO=2) | ISW(6) = 1 |
| COMPUTE AVERAGE CONCENTRATION (OR TOTAL DEPOSITION) | |
| WITH THE FOLLOWING TIME PERIODS: | |
| HOURLY (YES=1, NO=0) | ISW(7) = 0 |
| 2-HOUR (YES=1, NO=0) | ISW(8) = 0 |
| 3-HOUR (YES=1, NO=0) | ISW(9) = 1 |
| 4-HOUR (YES=1, NO=0) | ISW(10) = 0 |
| 6-HOUR (YES=1, NO=0) | ISW(11) = 0 |
| 8-HOUR (YES=1, NO=0) | ISW(12) = 0 |
| 12-HOUR (YES=1, NO=0) | ISW(13) = 0 |
| 24-HOUR (YES=1, NO=0) | ISW(14) = 1 |
| PRINT "N"-DAY TABLE(S) (YES=1, NO=0) | ISW(15) = 1 |
| PRINT THE FOLLOWING TYPES OF TABLES WHOSE TIME PERIODS ARE | |
| SPECIFIED BY ISW(7) THROUGH ISW(14): | |
| DAILY TABLES (YES=1, NO=0) | ISW(16) = 0 |
| HIGHEST & SECOND HIGHEST TABLES (YES=1, NO=0) | ISW(17) = 1 |
| MAXIMUM 50 TABLES (YES=1, NO=0) | ISW(18) = 1 |
| METEOROLOGICAL DATA INPUT METHOD (PRE-PROCESSED=1, CARD=2) | ISW(19) = 1 |
| RURAL-URBAN OPTION (RURAL=0, URBAN MODE 1=1, URBAN MODE 2=2) | ISW(20) = 0 |
| WIND PROFILE EXPONENT VALUES (DEFAULTS=1, USER ENTERS=2, 3) | ISW(21) = 1 |
| VERTICAL POT. TEMP. GRADIENT VALUES (DEFAULTS=1, USER ENTERS=2, 3) | ISW(22) = 1 |
| SCALE EMISSION RATES FOR ALL SOURCES (NO=0, YES=0) | ISW(23) = 0 |
| PROGRAM CALCULATES FINAL PLUME RISE ONLY (YES=1, NO=2) | ISW(24) = 2 |
| PROGRAM ADJUSTS ALL STACK HEIGHTS FOR DOWNWASH (YES=2, NO=1) | ISW(25) = 1 |
| INPUT SPECIAL DIRECTION-DEPENDENT BUILDING DIMENSIONS (YES=1, NO=0) | ISW(26) = 0 |
| OMIT TABLES FOR HOURLY CONCENTRATIONS (YES=1, NO=0) | ISW(27) = 0 |
| USEPA ADJUSTMENT FOR CALM HOURS (YES=1, NO=0) | ISW(28) = 1 |
| NUMBER OF INPUT SOURCES | NSOURC = 1 |
| NUMBER OF SOURCE GROUPS (=0, ALL SOURCES) | NGROUP = 0 |
| TIME PERIOD INTERVAL TO BE PRINTED (=0, ALL INTERVALS) | IPERD = 0 |
| NUMBER OF X (RANGE) GRID VALUES | NXPNTS = 5 |
| NUMBER OF Y (THETA) GRID VALUES | NYPNTS = 36 |
| NUMBER OF DISCRETE RECEPTORS | NXWYPT = 0 |
| SOURCE EMISSION RATE UNITS CONVERSION FACTOR | TK = 10000E+07 |
| ENTRAINMENT COEFFICIENT FOR UNSTABLE ATMOSPHERE | BETA1 = 0.600 |
| ENTRAINMENT COEFFICIENT FOR STABLE ATMOSPHERE | BETA2 = 0.600 |
| HEIGHT ABOVE GROUND AT WHICH WIND SPEED WAS MEASURED | ZR = 10.00 METERS |
| LOGICAL UNIT NUMBER OF METEOROLOGICAL DATA | IMET = 9 |
| DECAY COEFFICIENT FOR PHYSICAL OR CHEMICAL DEPLETION | DECAY = 0.000000E+00 |
| SURFACE STATION NO. | ISS = 12815 |
| YEAR OF SURFACE DATA | IGY = 75 |
| UPPER AIR STATION NO. | IUS = 12842 |
| YEAR OF UPPER AIR DATA | IUY = 75 |
| ALLOCATED DATA STORAGE | LIMIT = 43500 WORDS |

IST-4

1975 NRG ONLY SO2

*** RANGES OF POLAR GRID SYSTEM ***
(METERS)

500.0, 1000.0, 1500.0, 2000.0, 2500.0,

*** RADIAL ANGLES OF POLAR GRID SYSTEM ***

(DEGREES)

10.0, 20.0, 30.0, 40.0, 50.0, 60.0, 70.0, 80.0, 90.0, 100.0,
110.0, 120.0, 130.0, 140.0, 150.0, 160.0, 170.0, 180.0, 190.0, 200.0,
210.0, 220.0, 230.0, 240.0, 250.0, 260.0, 270.0, 280.0, 290.0, 300.0,
310.0, 320.0, 330.0, 340.0, 350.0, 360.0,

T W
Y H NUMB
SOURCE P K PAR
NUMBER E E CAT

101 0 0 0

*** SOURCE DATA ***

| SOURCE NUMBER | PK | PART. | E | E | CATS. | EMISSION RATE | | X | Y | BASE ELEV | HEIGHT | TEMP. | EXIT VEL. | | | BLDG. HEIGHT | BLDG. LENGTH | BLDG. WIDTH |
|---------------|----|-------|---|---|-------|-------------------------|-----------------------|----------|----------|-----------|----------|----------|--------------------|-------------------|---------------------|--------------|--------------|-------------|
| | | | | | | TYPE=0.1 (GRAMS/SEC) | TYPE=2 (GRAMS/SEC) | | | | | | TYPE=0 (DEG. K) | TYPE=0 (M/SEC) | TYPE=1 VERT. DIM | | | |
| NUMBER | E | E | | | | *PER METER**2 | (METERS) | (METERS) | (METERS) | (METERS) | (METERS) | (METERS) | (METERS) | (METERS) | (METERS) | (METERS) | (METERS) | (METERS) |
| 101 | 0 | 0 | 0 | | | 0.15000E+02 | 0.0 | 0.0 | 0.0 | 0.0 | 38.10 | 450.00 | 20.00 | 1.83 | 22.00 | 38.10 | 19.80 | |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* 365-DAY AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 0.66174 AND OCCURRED AT (1000.0, 360.0) *

| DIRECTION / (DEGREES) / | RANGE (METERS) | | | | | |
|----------------------------|----------------|-----------|---------|---------|---------|--|
| | 500.0 | 1000.0 | 1500.0 | 2000.0 | 2500.0 | |
| 360.0 / | 0.51133 | 0.66174 ✓ | 0.64029 | 0.50135 | 0.51475 | |
| 350.0 / | 0.37666 | 0.52007 | 0.50026 | 0.44306 | 0.38748 | |
| 340.0 / | 0.43814 | 0.56808 | 0.56566 | 0.47795 | 0.43315 | |
| 330.0 / | 0.37172 | 0.49414 | 0.46679 | 0.40612 | 0.35125 | |
| 320.0 / | 0.27637 | 0.38705 | 0.38120 | 0.34760 | 0.31425 | |
| 310.0 / | 0.25856 | 0.39341 | 0.38659 | 0.34931 | 0.31055 | |
| 300.0 / | 0.33308 | 0.49928 | 0.51364 | 0.47448 | 0.43000 | |
| 290.0 / | 0.25682 | 0.39796 | 0.38655 | 0.34152 | 0.30071 | |
| 280.0 / | 0.30075 | 0.45559 | 0.44607 | 0.39933 | 0.35195 | |
| 270.0 / | 0.35153 | 0.53846 | 0.57275 | 0.53980 | 0.49492 | |
| 260.0 / | 0.24737 | 0.37350 | 0.38132 | 0.34556 | 0.30787 | |
| 250.0 / | 0.26458 | 0.41245 | 0.42054 | 0.37042 | 0.35878 | |
| 240.0 / | 0.37351 | 0.54802 | 0.54673 | 0.47464 | 0.44070 | |
| 230.0 / | 0.40867 | 0.60845 | 0.63238 | 0.59013 | 0.54161 | |
| 220.0 / | 0.30076 | 0.46277 | 0.48470 | 0.45720 | 0.42676 | |
| 210.0 / | 0.27198 | 0.41381 | 0.42858 | 0.41503 | 0.38540 | |
| 200.0 / | 0.23262 | 0.34973 | 0.38335 | 0.37543 | 0.35870 | |
| 190.0 / | 0.19197 | 0.28527 | 0.30339 | 0.20615 | 0.26265 | |
| 180.0 / | 0.26443 | 0.39560 | 0.44146 | 0.43709 | 0.41760 | |
| 170.0 / | 0.21763 | 0.32874 | 0.34209 | 0.32011 | 0.29472 | |
| 160.0 / | 0.22222 | 0.33264 | 0.34705 | 0.32284 | 0.29316 | |
| 150.0 / | 0.21782 | 0.31607 | 0.31708 | 0.28580 | 0.25257 | |
| 140.0 / | 0.30272 | 0.41607 | 0.40366 | 0.35206 | 0.30145 | |
| 130.0 / | 0.35117 | 0.47360 | 0.46132 | 0.40699 | 0.35411 | |
| 120.0 / | 0.35173 | 0.47450 | 0.46109 | 0.40672 | 0.35334 | |
| 110.0 / | 0.31377 | 0.40847 | 0.39360 | 0.35031 | 0.30965 | |
| 100.0 / | 0.20080 | 0.27075 | 0.26087 | 0.23005 | 0.20086 | |
| 90.0 / | 0.18659 | 0.26307 | 0.27161 | 0.25020 | 0.22579 | |
| 80.0 / | 0.19725 | 0.28933 | 0.28704 | 0.25546 | 0.22326 | |
| 70.0 / | 0.23305 | 0.32938 | 0.32703 | 0.27435 | 0.26084 | |
| 60.0 / | 0.23517 | 0.32545 | 0.31596 | 0.28088 | 0.24672 | |
| 50.0 / | 0.31388 | 0.41513 | 0.40333 | 0.36222 | 0.32027 | |
| 40.0 / | 0.27360 | 0.38153 | 0.36334 | 0.31688 | 0.27419 | |
| 30.0 / | 0.23578 | 0.35087 | 0.33240 | 0.28048 | 0.23489 | |
| 20.0 / | 0.30510 | 0.43278 | 0.41685 | 0.36002 | 0.30904 | |
| 10.0 / | 0.38431 | 0.53236 | 0.50642 | 0.43549 | 0.37172 | |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* HIGHEST 3-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *
* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 35.05761 AND OCCURRED AT (500.0, 30.0) *

| DIRECTION / (DEGREES) / | RANGE (METERS) | | | | |
|----------------------------|-------------------|-------------------|-------------------|-------------------|-------------------|
| | 500.0 | 1000.0 | 1500.0 | 2000.0 | 2500.0 |
| 360.0 / | 30.84091 (290, 4) | 27.48871 (290, 4) | 25.27772 (290, 4) | 21.91789 (290, 4) | 18.69539 (290, 4) |
| 350.0 / | 22.04594 (109, 4) | 20.69554 (120, 4) | 16.58789 (209, 5) | 15.99318 (71, 5) | 14.64472 (71, 5) |
| 340.0 / | 27.27339 (359, 8) | 23.93079 (359, 8) | 24.78109 (194, 3) | 22.58609 (194, 3) | 19.43115 (194, 3) |
| 330.0 / | 23.25622 (10, 8) | 23.58043 (10, 8) | 24.01015 (10, 8) | 22.04357 (10, 8) | 19.42149 (10, 8) |
| 320.0 / | 12.65995 (120, 5) | 15.82206 (316, 4) | 14.08164 (108, 8) | 13.56152 (108, 8) | 13.47511 (290, 1) |
| 310.0 / | 14.40644 (104, 4) | 15.54887 (281, 4) | 15.38717 (19, 4) | 12.63915 (19, 4) | 12.00127 (364, 2) |
| 300.0 / | 24.90326 (87, 5) | 25.15131 (87, 5) | 22.74179 (87, 5) | 19.28601 (87, 5) | 16.16606 (87, 5) |
| 290.0 / | 14.09529 (86, 4) | 21.17017 (196, 6) | 17.93336 (205, 6) | 17.43695 (77, 6) | 16.04347 (77, 6) |
| 280.0 / | 22.69597 (114, 4) | 26.48679 (114, 4) | 20.55326 (114, 4) | 15.45650 (205, 6) | 13.26906 (126, 6) |
| 270.0 / | 25.71849 (112, 5) | 23.13315 (112, 5) | 18.85946 (112, 5) | 15.89019 (347, 4) | 15.97802 (287, 5) |
| 260.0 / | 20.16329 (112, 4) | 18.36059 (287, 4) | 17.04593 (287, 4) | 15.32272 (210, 6) | 13.76865 (210, 6) |
| 250.0 / | 21.75909 (181, 6) | 32.35304 (181, 6) | 27.63246 (181, 6) | 20.95338 (181, 6) | 15.88499 (181, 6) |
| 240.0 / | 20.43987 (174, 4) | 23.00628 (284, 5) | 22.27483 (182, 6) | 19.20759 (182, 6) | 16.14341 (182, 6) |
| 230.0 / | 19.57065 (306, 5) | 22.07051 (141, 5) | 18.06585 (398, 4) | 16.72580 (131, 6) | 15.57770 (131, 6) |
| 220.0 / | 16.90353 (295, 5) | 19.66220 (175, 6) | 19.43640 (175, 6) | 15.64749 (175, 6) | 14.95718 (319, 5) |
| 210.0 / | 18.49326 (285, 4) | 24.06855 (285, 4) | 21.58925 (285, 4) | 17.82530 (285, 4) | 14.62283 (285, 4) |
| 200.0 / | 17.98035 (17, 4) | 16.78472 (17, 4) | 19.14324 (52, 6) | 19.77749 (52, 6) | 18.68132 (52, 6) |
| 190.0 / | 18.99824 (106, 5) | 23.02692 (131, 4) | 21.00120 (303, 4) | 18.80550 (303, 4) | 16.14221 (303, 4) |
| 180.0 / | 19.59497 (85, 5) | 20.24558 (293, 5) | 17.33732 (293, 5) | 14.56664 (303, 8) | 13.95057 (74, 3) |
| 170.0 / | 13.58909 (155, 4) | 16.38895 (14, 5) | 16.05921 (14, 5) | 14.44438 (353, 2) | 13.91127 (353, 9) |
| 160.0 / | 15.28191 (353, 1) | 21.24667 (165, 4) | 20.64686 (68, 3) | 18.04033 (68, 3) | 15.39102 (353, 1) |
| 150.0 / | 16.16752 (94, 4) | 21.58840 (94, 4) | 17.94213 (361, 4) | 15.41599 (352, 7) | 14.01418 (352, 7) |
| 140.0 / | 21.33290 (231, 5) | 31.07622 (231, 5) | 23.77326 (231, 5) | 21.68594 (355, 3) | 19.55106 (355, 3) |
| 130.0 / | 30.08136 (317, 4) | 27.56232 (244, 5) | 24.39089 (317, 4) | 21.23288 (317, 4) | 18.15272 (317, 4) |
| 120.0 / | 24.50401 (317, 5) | 20.91807 (317, 5) | 18.98149 (317, 5) | 17.62832 (6, 5) | 16.32224 (355, 5) |
| 110.0 / | 22.00867 (93, 6) | 25.86541 (129, 4) | 18.52394 (93, 6) | 18.41506 (344, 6) | 17.57529 (344, 6) |
| 100.0 / | 26.31584 (138, 5) | 26.00016 (186, 6) | 23.57323 (186, 6) | 18.23422 (186, 6) | 14.12035 (124, 6) |
| 90.0 / | 20.96747 (78, 4) | 20.56363 (1, 5) | 19.31350 (1, 5) | 15.47993 (325, 5) | 13.42441 (325, 5) |
| 80.0 / | 24.42751 (157, 4) | 29.12420 (157, 4) | 20.70244 (325, 4) | 18.81446 (91, 6) | 16.84002 (91, 6) |
| 70.0 / | 25.67729 (73, 5) | 27.56293 (110, 4) | 22.20900 (73, 5) | 19.63114 (73, 5) | 16.92520 (73, 5) |
| 60.0 / | 21.59331 (186, 4) | 24.16258 (186, 4) | 18.24344 (186, 4) | 14.12095 (43, 6) | 12.17189 (43, 6) |
| 50.0 / | 29.04378 (25, 5) | 22.34429 (186, 4) | 18.77322 (89, 5) | 15.80397 (89, 5) | 14.75092 (61, 2) |
| 40.0 / | 20.22816 (83, 6) | 25.86120 (166, 5) | 18.58655 (166, 5) | 14.00983 (83, 6) | 11.92153 (83, 6) |
| 30.0 / | 35.05761 (89, 4) | 29.14104 (89, 4) | 24.66244 (89, 4) | 20.49582 (89, 4) | 17.07333 (89, 4) |
| 20.0 / | 21.53517 (119, 4) | 24.41856 (119, 4) | 21.09179 (119, 4) | 17.06935 (119, 4) | 14.52091 (119, 9) |
| 10.0 / | 24.30997 (119, 5) | 26.38409 (167, 4) | 20.36990 (167, 4) | 16.01156 (331, 4) | 14.14196 (331, 4) |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-05 ***

* SECOND HIGHEST 3-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER)
* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 26.46408 AND OCCURRED AT (1000.0, 2500.0) *

| DIRECTION / (DEGREES) / | RANGE (METERS) | | | | |
|----------------------------|-------------------|-------------------|-------------------|-------------------|-------------------|
| | 500.0 | 1000.0 | 1500.0 | 2000.0 | 2500.0 |
| 350.0 / | 23.47917 (109, 4) | 23.25024 (190, 5) | 19.35533 (13, 2) | 19.24883 (13, 2) | 17.77108 (13, 2) |
| 350.0 / | 17.30402 (55, 3) | 20.07011 (115, 4) | 16.33634 (120, 4) | 14.30260 (209, 5) | 12.49527 (72, 6) |
| 340.0 / | 22.11366 (266, 3) | 22.74613 (151, 4) | 23.59180 (8, 4) | 21.90285 (8, 4) | 19.42724 (8, 4) |
| 330.0 / | 19.98109 (359, 4) | 21.45010 (210, 5) | 16.53120 (359, 4) | 15.55705 (359, 6) | 14.06705 (359, 6) |
| 320.0 / | 12.56390 (123, 4) | 14.69707 (53, 5) | 13.91913 (316, 4) | 13.31289 (266, 1) | 12.89715 (266, 1) |
| 310.0 / | 13.52364 (117, 5) | 14.85147 (19, 4) | 13.63776 (197, 4) | 12.41768 (364, 2) | 10.11846 (19, 4) |
| 300.0 / | 19.75613 (113, 5) | 20.78146 (117, 5) | 19.47994 (103, 6) | 17.29217 (103, 6) | 14.84454 (103, 6) |
| 290.0 / | 12.75220 (77, 6) | 18.67719 (205, 6) | 17.59650 (77, 6) | 15.88848 (86, 5) | 14.45215 (86, 5) |
| 290.0 / | 19.03027 (197, 5) | 23.33371 (197, 5) | 19.22965 (197, 5) | 15.35933 (340, 5) | 13.10595 (203, 6) |
| 270.0 / | 20.57636 (114, 4) | 22.22271 (114, 4) | 17.73038 (347, 4) | 15.56619 (203, 6) | 13.82288 (347, 4) |
| 260.0 / | 16.57662 (287, 4) | 17.79047 (112, 4) | 15.72739 (210, 6) | 14.47988 (287, 4) | 12.07757 (287, 4) |
| 250.0 / | 15.17061 (103, 5) | 26.46408 (144, 5) | 20.90034 (144, 5) | 14.82611 (144, 5) | 13.45341 (239, 6) |
| 240.0 / | 20.28127 (142, 5) | 22.99617 (182, 6) | 19.41382 (300, 5) | 17.20859 (174, 4) | 14.92845 (307, 5) |
| 230.0 / | 19.42661 (141, 5) | 21.40369 (339, 4) | 17.71515 (294, 4) | 14.73267 (305, 5) | 13.53552 (305, 6) |
| 220.0 / | 15.31565 (2, 5) | 19.30677 (96, 4) | 17.93930 (283, 5) | 15.53986 (319, 6) | 13.63605 (76, 6) |
| 210.0 / | 15.63901 (141, 4) | 21.22493 (320, 4) | 17.92874 (320, 4) | 14.38757 (183, 3) | 14.15477 (262, 3) |
| 200.0 / | 14.17610 (141, 4) | 16.57706 (45, 4) | 16.44529 (21, 4) | 14.61288 (17, 4) | 14.05500 (292, 7) |
| 190.0 / | 18.52054 (64, 4) | 22.73281 (64, 4) | 20.26344 (131, 4) | 14.67570 (131, 4) | 14.20396 (5, 3) |
| 190.0 / | 16.59870 (106, 5) | 19.90650 (85, 5) | 14.97629 (7, 4) | 14.37029 (74, 3) | 13.78445 (303, 9) |
| 170.0 / | 13.50915 (85, 5) | 14.92263 (95, 4) | 14.64986 (68, 2) | 14.23731 (69, 2) | 13.70139 (94, 2) |
| 160.0 / | 14.70352 (230, 4) | 20.60613 (102, 4) | 19.68876 (165, 4) | 16.98445 (353, 1) | 15.08810 (68, 3) |
| 150.0 / | 14.77386 (125, 4) | 20.74486 (125, 4) | 15.50992 (94, 4) | 14.67683 (361, 4) | 12.72212 (268, 5) |
| 140.0 / | 21.11293 (355, 3) | 21.14491 (355, 3) | 22.77000 (355, 3) | 16.77661 (231, 5) | 12.14065 (231, 5) |
| 130.0 / | 19.67333 (244, 5) | 26.34741 (317, 4) | 22.52061 (244, 5) | 17.50589 (244, 5) | 15.37157 (105, 6) |
| 120.0 / | 23.15111 (55, 5) | 18.52932 (55, 5) | 18.57740 (6, 5) | 17.43587 (356, 5) | 15.81980 (6, 5) |
| 110.0 / | 20.16978 (129, 4) | 22.08277 (128, 5) | 18.28562 (344, 6) | 16.17262 (93, 6) | 13.79690 (93, 6) |
| 100.0 / | 19.54194 (93, 5) | 22.55435 (138, 5) | 17.31886 (124, 6) | 15.98369 (124, 6) | 13.92083 (186, 6) |
| 90.0 / | 20.51971 (124, 5) | 20.22775 (267, 4) | 18.88701 (267, 4) | 15.24022 (1, 5) | 11.52219 (78, 4) |
| 90.0 / | 21.52626 (157, 5) | 24.04074 (157, 5) | 19.86446 (91, 6) | 17.94152 (325, 4) | 15.49367 (81, 6) |
| 70.0 / | 20.66936 (186, 5) | 23.41454 (73, 5) | 18.90537 (110, 4) | 13.78163 (150, 4) | 12.45347 (150, 4) |
| 60.0 / | 21.34265 (37, 6) | 20.27041 (191, 4) | 16.15333 (37, 6) | 13.74603 (37, 6) | 11.59573 (37, 6) |
| 50.0 / | 25.43665 (89, 5) | 21.65551 (91, 5) | 17.64673 (91, 5) | 15.22129 (61, 2) | 13.31231 (4, 6) |
| 40.0 / | 18.02527 (188, 4) | 21.20977 (188, 4) | 16.35337 (188, 4) | 13.17951 (50, 5) | 11.41005 (50, 5) |
| 30.0 / | 19.10727 (66, 5) | 20.35296 (66, 5) | 17.40278 (66, 5) | 13.99133 (186, 3) | 12.93343 (186, 3) |
| 20.0 / | 18.14924 (207, 5) | 19.47681 (207, 5) | 16.40897 (245, 4) | 15.25088 (245, 4) | 13.82243 (119, 4) |
| 10.0 / | 20.61949 (167, 4) | 23.71878 (119, 5) | 19.42516 (191, 3) | 15.61148 (119, 6) | 13.20328 (119, 6) |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* 50 MAXIMUM 3-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREE) | RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREE) |
|------|----------|------|-----|------------------------------|--|------|----------|------|-----|------------------------------|--|
| 1 | 35.05761 | 4 | 89 | 500.0 | 30.0 | 26 | 25.15131 | 5 | 87 | 1000.0 | 300.0 |
| 2 | 32.35384 | 6 | 181 | 1000.0 | 250.0 | 27 | 24.90326 | 5 | 87 | 500.0 | 300.0 |
| 3 | 31.07622 | 5 | 231 | 1000.0 | 140.0 | 28 | 24.78109 | 3 | 194 | 1500.0 | 340.0 |
| 4 | 30.84091 | 4 | 290 | 500.0 | 360.0 | 29 | 24.66244 | 4 | 89 | 1500.0 | 30.0 |
| 5 | 30.08136 | 4 | 317 | 500.0 | 130.0 | 30 | 24.50401 | 5 | 317 | 500.0 | 120.0 |
| 6 | 29.14104 | 4 | 87 | 1000.0 | 30.0 | 31 | 24.43509 | 5 | 91 | 500.0 | 50.0 |
| 7 | 29.12420 | 4 | 157 | 1000.0 | 80.0 | 32 | 24.42731 | 4 | 157 | 500.0 | 80.0 |
| 8 | 29.04578 | 5 | 25 | 500.0 | 50.0 | 33 | 24.41856 | 4 | 119 | 1000.0 | 20.0 |
| 9 | 27.63246 | 6 | 181 | 1500.0 | 250.0 | 34 | 24.39089 | 4 | 317 | 1500.0 | 130.0 |
| 10 | 27.56292 | 4 | 110 | 1000.0 | 70.0 | 35 | 24.30797 | 5 | 119 | 500.0 | 10.0 |
| 11 | 27.56232 | 5 | 244 | 1000.0 | 130.0 | 36 | 24.16298 | 4 | 186 | 1000.0 | 60.0 |
| 12 | 27.48871 | 4 | 290 | 1000.0 | 360.0 | 37 | 24.06895 | 4 | 285 | 1000.0 | 210.0 |
| 13 | 27.27339 | 8 | 359 | 500.0 | 340.0 | 38 | 24.04074 | 5 | 157 | 1000.0 | 80.0 |
| 14 | 26.48679 | 4 | 114 | 1000.0 | 280.0 | 39 | 24.01015 | 8 | 10 | 1500.0 | 330.0 |
| 15 | 26.46408 | 5 | 144 | 1000.0 | 250.0 | 40 | 23.93079 | 8 | 359 | 1000.0 | 340.0 |
| 16 | 26.38409 | 4 | 167 | 1000.0 | 10.0 | 41 | 23.84985 | 4 | 128 | 1000.0 | 130.0 |
| 17 | 26.34741 | 4 | 317 | 1000.0 | 130.0 | 42 | 23.77326 | 5 | 231 | 1500.0 | 140.0 |
| 18 | 26.31584 | 5 | 138 | 500.0 | 100.0 | 43 | 23.71878 | 5 | 119 | 1000.0 | 10.0 |
| 19 | 26.00016 | 6 | 186 | 1000.0 | 100.0 | 44 | 23.59180 | 4 | 8 | 1500.0 | 340.0 |
| 20 | 25.86541 | 4 | 129 | 1000.0 | 110.0 | 45 | 23.58043 | 8 | 10 | 1000.0 | 330.0 |
| 21 | 25.86120 | 5 | 166 | 1000.0 | 40.0 | 46 | 23.57323 | 6 | 186 | 1500.0 | 100.0 |
| 22 | 25.71849 | 5 | 112 | 500.0 | 270.0 | 47 | 23.47917 | 4 | 109 | 500.0 | 360.0 |
| 23 | 25.67728 | 5 | 73 | 500.0 | 70.0 | 48 | 23.41454 | 5 | 73 | 1000.0 | 70.0 |
| 24 | 25.43565 | 5 | 89 | 500.0 | 50.0 | 49 | 23.33371 | 5 | 197 | 1000.0 | 280.0 |
| 25 | 25.27772 | 4 | 290 | 1500.0 | 360.0 | 50 | 23.25622 | 8 | 10 | 500.0 | 330.0 |

*** NRS/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* HIGHEST 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *
* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS B. 44108 AND OCCURRED AT (1500.0, 340.0) *

| DIRECTION / (DEGREES) / | RANGE (METERS) | | | | |
|----------------------------|------------------|------------------|------------------|------------------|------------------|
| | 500.0 | 1000.0 | 1500.0 | 2000.0 | 2500.0 |
| 360.0 / | 7.31763 (290, 1) | 6.80225 (290, 1) | 6.66606 (290, 1) | 6.08182 (290, 1) | 5.37435 (290, 1) |
| 350.0 / | 4.59277 (55, 1) | 4.81611 (223, 1) | 4.42435 (55, 1) | 4.01798 (55, 1) | 3.51987 (55, 1) |
| 340.0 / | 7.47675 (12, 1) | 7.95079 (12, 1) | 8.44108 (12, 1) | 7.96771 (12, 1) | 7.22423 (12, 1) |
| 330.0 / | 7.81122 (359, 1) | 7.15500 (359, 1) | 7.05115 (359, 1) | 6.40784 (359, 1) | 5.61664 (359, 1) |
| 320.0 / | 2.77991 (10, 1) | 3.15224 (227, 1) | 3.50597 (10, 1) | 3.65973 (10, 1) | 3.69472 (109, 1) |
| 310.0 / | 3.27850 (117, 1) | 3.91982 (117, 1) | 3.60936 (196, 1) | 3.09117 (104, 1) | 2.99544 (104, 1) |
| 300.0 / | 6.40713 (87, 1) | 7.91571 (117, 1) | 6.88427 (117, 1) | 5.61520 (117, 1) | 4.80266 (87, 1) |
| 270.0 / | 3.79064 (86, 1) | 4.63100 (214, 1) | 3.92741 (214, 1) | 3.39116 (313, 1) | 3.47971 (313, 1) |
| 290.0 / | 4.08967 (114, 1) | 5.59609 (205, 1) | 4.62498 (205, 1) | 4.11149 (205, 1) | 3.51227 (205, 1) |
| 270.0 / | 5.44931 (112, 1) | 5.49124 (247, 1) | 6.02613 (247, 1) | 5.45602 (247, 1) | 4.71656 (247, 1) |
| 260.0 / | 4.95596 (112, 1) | 4.51471 (112, 1) | 3.72778 (144, 1) | 3.27332 (144, 1) | 2.79309 (144, 1) |
| 250.0 / | 4.35207 (181, 1) | 7.00483 (181, 1) | 6.19293 (181, 1) | 4.75558 (181, 1) | 3.62331 (181, 1) |
| 240.0 / | 5.06243 (174, 1) | 6.23379 (174, 1) | 6.01705 (174, 1) | 5.27307 (174, 1) | 4.51631 (174, 1) |
| 230.0 / | 4.31322 (304, 1) | 4.76707 (145, 1) | 4.43532 (174, 1) | 4.40383 (305, 1) | 4.34368 (305, 1) |
| 220.0 / | 3.84790 (2, 1) | 4.42042 (145, 1) | 3.90846 (2, 1) | 3.88820 (17, 1) | 3.91522 (17, 1) |
| 210.0 / | 3.57360 (285, 1) | 4.50713 (285, 1) | 4.52181 (111, 1) | 4.13093 (111, 1) | 3.68609 (332, 1) |
| 200.0 / | 3.01000 (17, 1) | 3.78421 (21, 1) | 3.98129 (52, 1) | 4.30614 (52, 1) | 4.25048 (52, 1) |
| 190.0 / | 4.33794 (64, 1) | 5.17816 (64, 1) | 5.00722 (64, 1) | 4.38830 (64, 1) | 3.74328 (64, 1) |
| 180.0 / | 4.75730 (293, 1) | 6.86058 (293, 1) | 7.54538 (293, 1) | 7.29059 (293, 1) | 6.90298 (293, 1) |
| 170.0 / | 4.01506 (353, 1) | 4.65124 (95, 1) | 5.68347 (353, 1) | 6.14422 (353, 1) | 6.14462 (353, 1) |
| 160.0 / | 3.75639 (102, 1) | 5.94298 (102, 1) | 5.45025 (102, 1) | 4.57799 (102, 1) | 3.92276 (102, 1) |
| 150.0 / | 3.95467 (125, 1) | 5.52127 (125, 1) | 5.04785 (125, 1) | 4.22229 (14, 1) | 3.81628 (14, 1) |
| 140.0 / | 5.32438 (355, 1) | 5.26643 (355, 1) | 5.59002 (355, 1) | 5.26190 (355, 1) | 4.73124 (355, 1) |
| 130.0 / | 7.25215 (317, 1) | 6.27492 (317, 1) | 5.85999 (317, 1) | 5.33965 (67, 1) | 4.71653 (67, 1) |
| 120.0 / | 5.92969 (317, 1) | 7.55708 (180, 1) | 6.08877 (356, 1) | 5.82511 (356, 1) | 5.25089 (356, 1) |
| 110.0 / | 6.72741 (78, 1) | 6.44397 (79, 1) | 6.44236 (78, 1) | 5.89066 (78, 1) | 5.16648 (78, 1) |
| 100.0 / | 4.28530 (124, 1) | 4.17503 (124, 1) | 3.96706 (124, 1) | 3.87500 (78, 1) | 3.59588 (78, 1) |
| 90.0 / | 5.41174 (124, 1) | 4.82102 (124, 1) | 4.84436 (124, 1) | 4.77758 (124, 1) | 4.68843 (124, 1) |
| 80.0 / | 6.12324 (157, 1) | 7.26304 (157, 1) | 5.27105 (157, 1) | 4.45231 (81, 1) | 4.05185 (81, 1) |
| 70.0 / | 5.20703 (158, 1) | 5.91281 (157, 1) | 5.28481 (178, 1) | 4.52158 (178, 1) | 4.11002 (158, 1) |
| 60.0 / | 3.80509 (37, 1) | 3.91892 (110, 1) | 3.74917 (188, 1) | 3.49299 (188, 1) | 3.11636 (189, 1) |
| 50.0 / | 5.26425 (25, 1) | 4.50086 (160, 1) | 4.12984 (160, 1) | 3.76345 (351, 1) | 3.68185 (351, 1) |
| 40.0 / | 3.37996 (66, 1) | 4.35527 (188, 1) | 3.83698 (188, 1) | 3.50004 (66, 1) | 3.24484 (66, 1) |
| 30.0 / | 4.42956 (89, 1) | 5.23610 (202, 1) | 4.97161 (202, 1) | 4.13476 (202, 1) | 3.37739 (202, 1) |
| 20.0 / | 6.12873 (119, 1) | 6.82587 (119, 1) | 5.39599 (119, 1) | 4.09410 (20, 1) | 3.69449 (19, 1) |
| 10.0 / | 6.78487 (119, 1) | 7.76253 (119, 1) | 6.17548 (119, 1) | 5.86479 (331, 1) | 5.23751 (331, 1) |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* SECOND HIGHEST 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *
* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 6.44353 AND OCCURRED AT (1000.0, 300.0) *

| DIRECTION / (DEGREES) / | RANGE (METERS) | | | | |
|----------------------------|------------------|------------------|------------------|------------------|------------------|
| | 500.0 | 1000.0 | 1500.0 | 2000.0 | 2500.0 |
| 360.0 / | 6.28229 (109, 1) | 5.81180 (109, 1) | 4.68890 (55, 1) | 4.23408 (55, 1) | 4.07273 (316, 1) |
| 350.0 / | 4.03813 (72, 1) | 4.43610 (55, 1) | 3.84924 (209, 1) | 3.51957 (194, 1) | 3.41321 (199, 1) |
| 340.0 / | 5.23435 (266, 1) | 6.25524 (261, 1) | 5.63343 (261, 1) | 4.38154 (261, 1) | 3.85719 (266, 1) |
| 330.0 / | 6.15017 (10, 1) | 5.78024 (10, 1) | 5.62023 (10, 1) | 5.01654 (10, 1) | 4.33876 (10, 1) |
| 320.0 / | 2.52249 (266, 1) | 2.99997 (10, 1) | 3.05094 (265, 1) | 3.34273 (109, 1) | 3.61192 (10, 1) |
| 310.0 / | 2.85140 (227, 1) | 3.80643 (196, 1) | 3.13042 (104, 1) | 2.93956 (196, 1) | 2.65398 (364, 1) |
| 300.0 / | 6.25088 (117, 1) | 6.44353 (87, 1) | 6.24468 (87, 1) | 5.55592 (87, 1) | 4.58945 (117, 1) |
| 290.0 / | 3.12619 (205, 1) | 4.25581 (205, 1) | 3.67879 (268, 1) | 3.22377 (86, 1) | 2.77415 (86, 1) |
| 280.0 / | 3.84184 (222, 1) | 5.24706 (214, 1) | 4.81307 (268, 1) | 3.90781 (289, 1) | 3.25822 (222, 1) |
| 270.0 / | 4.53534 (234, 1) | 5.14429 (112, 1) | 4.32923 (205, 1) | 3.71753 (314, 1) | 3.66369 (314, 1) |
| 260.0 / | 9.15274 (287, 1) | 3.76406 (144, 1) | 3.60512 (112, 1) | 3.04330 (247, 1) | 2.67032 (169, 1) |
| 250.0 / | 3.23260 (144, 1) | 5.58523 (144, 1) | 4.78635 (144, 1) | 3.72334 (144, 1) | 3.23510 (251, 1) |
| 240.0 / | 4.59080 (142, 1) | 5.32104 (300, 1) | 5.17864 (182, 1) | 4.42703 (182, 1) | 3.69424 (182, 1) |
| 230.0 / | 3.84163 (306, 1) | 4.74433 (45, 1) | 4.36240 (182, 1) | 4.15341 (309, 1) | 3.81241 (309, 1) |
| 220.0 / | 3.84527 (182, 1) | 3.93328 (285, 1) | 3.78016 (63, 1) | 3.62777 (2, 1) | 3.34964 (240, 1) |
| 210.0 / | 3.54766 (141, 1) | 4.12157 (111, 1) | 3.85873 (285, 1) | 3.49907 (273, 1) | 3.59052 (111, 1) |
| 200.0 / | 2.37040 (52, 1) | 3.08441 (52, 1) | 3.95703 (292, 1) | 3.94484 (292, 1) | 3.53329 (5, 1) |
| 190.0 / | 3.08581 (353, 1) | 3.41231 (353, 1) | 3.94427 (353, 1) | 3.89317 (353, 1) | 3.57250 (353, 1) |
| 180.0 / | 4.05597 (85, 1) | 4.46428 (260, 1) | 5.61737 (269, 1) | 5.84303 (268, 1) | 5.63613 (260, 1) |
| 170.0 / | 3.25868 (155, 1) | 4.46023 (353, 1) | 4.90042 (95, 1) | 4.47395 (95, 1) | 4.04453 (95, 1) |
| 160.0 / | 3.74410 (94, 1) | 4.46151 (95, 1) | 4.41123 (94, 1) | 4.22759 (94, 1) | 3.91330 (94, 1) |
| 150.0 / | 3.15276 (352, 1) | 4.04688 (14, 1) | 4.44229 (14, 1) | 4.20013 (125, 1) | 3.57244 (352, 1) |
| 140.0 / | 4.12679 (38, 1) | 5.17550 (139, 1) | 4.49714 (291, 1) | 3.94253 (291, 1) | 3.38325 (291, 1) |
| 130.0 / | 6.00642 (67, 1) | 5.79318 (67, 1) | 5.82764 (67, 1) | 5.11604 (317, 1) | 4.49973 (356, 1) |
| 120.0 / | 5.44173 (13, 1) | 5.29052 (356, 1) | 5.81054 (190, 1) | 5.01928 (13, 1) | 4.46605 (13, 1) |
| 110.0 / | 5.44688 (93, 1) | 4.65168 (129, 1) | 4.44029 (13, 1) | 4.21364 (13, 1) | 3.78722 (13, 1) |
| 100.0 / | 4.27285 (138, 1) | 3.91911 (138, 1) | 3.90903 (78, 1) | 3.52813 (124, 1) | 3.05898 (124, 1) |
| 90.0 / | 4.06965 (78, 1) | 4.56729 (1, 1) | 4.59051 (325, 1) | 4.36940 (325, 1) | 4.07075 (325, 1) |
| 80.0 / | 3.51649 (81, 1) | 4.30151 (133, 1) | 4.58217 (81, 1) | 3.87756 (157, 1) | 3.25666 (325, 1) |
| 70.0 / | 4.90806 (157, 1) | 5.04244 (158, 1) | 4.82604 (158, 1) | 4.49344 (158, 1) | 3.69152 (178, 1) |
| 60.0 / | 3.60794 (186, 1) | 3.76168 (186, 1) | 3.31453 (100, 1) | 2.64223 (60, 1) | 2.51146 (60, 1) |
| 50.0 / | 4.09474 (89, 1) | 4.05483 (186, 1) | 3.50705 (351, 1) | 3.31782 (160, 1) | 3.12801 (61, 1) |
| 40.0 / | 3.34031 (188, 1) | 4.18391 (166, 1) | 3.62891 (66, 1) | 3.16950 (188, 1) | 2.62298 (188, 1) |
| 30.0 / | 3.59179 (66, 1) | 3.86997 (66, 1) | 3.52366 (66, 1) | 3.15015 (24, 1) | 2.73849 (24, 1) |
| 20.0 / | 4.28415 (215, 1) | 4.71506 (215, 1) | 4.29497 (20, 1) | 4.08231 (119, 1) | 3.67832 (20, 1) |
| 10.0 / | 4.71237 (167, 1) | 6.14623 (167, 1) | 6.04040 (331, 1) | 4.70206 (119, 1) | 3.64203 (119, 1) |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-05 ***

* 50 MAXIMUM 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) | RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) |
|------|---------|------|-----|------------------------------|---|------|---------|------|-----|------------------------------|---|
| 1 | 8.44108 | 1 | 12 | 1500.0 | 340.0 | 26 | 6.44393 | 1 | 87 | 1000.0 | 300.0 |
| 2 | 7.96771 | 1 | 12 | 2000.0 | 340.0 | 27 | 6.44387 | 1 | 78 | 1000.0 | 110.0 |
| 3 | 7.95079 | 1 | 12 | 1000.0 | 340.0 | 28 | 6.44236 | 1 | 78 | 1500.0 | 110.0 |
| 4 | 7.91571 | 1 | 117 | 1000.0 | 300.0 | 29 | 6.40784 | 1 | 359 | 2000.0 | 330.0 |
| 5 | 7.81122 | 1 | 359 | 500.0 | 330.0 | 30 | 6.40713 | 1 | 87 | 500.0 | 300.0 |
| 6 | 7.76253 | 1 | 119 | 1000.0 | 10.0 | 31 | 6.28229 | 1 | 109 | 500.0 | 360.0 |
| 7 | 7.55706 | 1 | 180 | 1000.0 | 120.0 | 32 | 6.27492 | 1 | 317 | 1000.0 | 130.0 |
| 8 | 7.54538 | 1 | 293 | 1500.0 | 180.0 | 33 | 6.25524 | 1 | 261 | 1000.0 | 340.0 |
| 9 | 7.47575 | 1 | 12 | 500.0 | 340.0 | 34 | 6.25088 | 1 | 117 | 500.0 | 300.0 |
| 10 | 7.31763 | 1 | 290 | 500.0 | 360.0 | 35 | 6.24468 | 1 | 87 | 1500.0 | 300.0 |
| 11 | 7.28059 | 1 | 293 | 2000.0 | 180.0 | 36 | 6.23379 | 1 | 174 | 1000.0 | 240.0 |
| 12 | 7.26394 | 1 | 157 | 1000.0 | 80.0 | 37 | 6.19293 | 1 | 181 | 1500.0 | 250.0 |
| 13 | 7.26215 | 1 | 317 | 500.0 | 130.0 | 38 | 6.17548 | 1 | 117 | 1500.0 | 10.0 |
| 14 | 7.22423 | 1 | 12 | 2500.0 | 340.0 | 39 | 6.15017 | 1 | 10 | 500.0 | 330.0 |
| 15 | 7.15500 | 1 | 359 | 1000.0 | 330.0 | 40 | 6.14623 | 1 | 167 | 1000.0 | 10.0 |
| 16 | 7.05115 | 1 | 359 | 1500.0 | 330.0 | 41 | 6.14462 | 1 | 353 | 2500.0 | 170.0 |
| 17 | 7.00483 | 1 | 181 | 1000.0 | 250.0 | 42 | 6.14422 | 1 | 353 | 2000.0 | 170.0 |
| 18 | 6.68427 | 1 | 117 | 1500.0 | 300.0 | 43 | 6.12873 | 1 | 119 | 500.0 | 20.0 |
| 19 | 6.86058 | 1 | 293 | 1000.0 | 180.0 | 44 | 6.12324 | 1 | 157 | 500.0 | 80.0 |
| 20 | 6.82587 | 1 | 119 | 1000.0 | 20.0 | 45 | 6.08977 | 1 | 355 | 1500.0 | 120.0 |
| 21 | 6.80225 | 1 | 293 | 2500.0 | 180.0 | 46 | 6.08200 | 1 | 113 | 500.0 | 300.0 |
| 22 | 6.80225 | 1 | 290 | 1000.0 | 360.0 | 47 | 6.08162 | 1 | 290 | 2000.0 | 360.0 |
| 23 | 6.78457 | 1 | 119 | 500.0 | 10.0 | 48 | 6.04040 | 1 | 331 | 1500.0 | 10.0 |
| 24 | 6.72741 | 1 | 78 | 500.0 | 110.0 | 49 | 6.02513 | 1 | 247 | 1500.0 | 270.0 |
| 25 | 6.66606 | 1 | 290 | 1500.0 | 360.0 | 50 | 6.01705 | 1 | 174 | 1500.0 | 240.0 |

| | |
|---|----------------------|
| CALCULATE (CONCENTRATION=1, DEPOSITION=2) | ISW(1) = 1 |
| RECEPTOR GRID SYSTEM (RECTANGULAR=1 OR 3, POLAR=2 OR 4) | ISW(2) = 4 |
| DISCRETE RECEPTOR SYSTEM (RECTANGULAR=1, POLAR=2) | ISW(3) = 2 |
| TERRAIN ELEVATIONS ARE READ (YES=1, NO=0) | ISW(4) = 0 |
| CALCULATIONS ARE WRITTEN TO TAPE (YES=1, NO=0) | ISW(5) = 0 |
| LIST ALL INPUT DATA (NO=0, YES=1, MET DATA ALSO=2) | ISW(6) = 1 |
| | |
| COMPUTE AVERAGE CONCENTRATION (OR TOTAL DEPOSITION) | |
| WITH THE FOLLOWING TIME PERIODS: | |
| HOURLY (YES=1, NO=0) | ISW(7) = 0 |
| 2-HOUR (YES=1, NO=0) | ISW(8) = 0 |
| 3-HOUR (YES=1, NO=0) | ISW(9) = 1 |
| 4-HOUR (YES=1, NO=0) | ISW(10) = 0 |
| 6-HOUR (YES=1, NO=0) | ISW(11) = 0 |
| 8-HOUR (YES=1, NO=0) | ISW(12) = 0 |
| 12-HOUR (YES=1, NO=0) | ISW(13) = 0 |
| 24-HOUR (YES=1, NO=0) | ISW(14) = 1 |
| PRINT "N"-DAY TABLE(S) (YES=1, NO=0) | ISW(15) = 0 |
| | |
| PRINT THE FOLLOWING TYPES OF TABLES WHOSE TIME PERIODS ARE SPECIFIED BY ISW(7) THROUGH ISW(14): | |
| DAILY TABLES (YES=1, NO=0) | ISW(16) = 0 |
| HIGHEST & SECOND HIGHEST TABLES (YES=1, NO=0) | ISW(17) = 0 |
| MAXIMUM 50 TABLES (YES=1, NO=0) | ISW(19) = 1 |
| METEOROLOGICAL DATA INPUT METHOD (PRE-PROCESSED=1, CARD=2) | ISW(19) = 1 |
| RURAL-URBAN OPTION (RURAL=0, URBAN MODE 1=1, URBAN MODE 2=2) | ISW(20) = 0 |
| WIND PROFILE EXPONENT VALUES (DEFAULTS=1, USER ENTERS=2,3) | ISW(21) = 1 |
| VERTICAL PRT. TEMP. GRADIENT VALUES (DEFAULTS=1, USER ENTERS=2,3) | ISW(22) = 1 |
| SCALE EMISSION RATES FOR ALL SOURCES (NO=0, YES>0) | ISW(23) = 0 |
| PROGRAM CALCULATES FINAL PLUME RISE ONLY (YES=1, NO=2) | ISW(24) = 2 |
| PROGRAM ADJUSTS ALL STACK HEIGHTS FOR DOWNWASH (YES=2, NO=1) | ISW(25) = 1 |
| | |
| INPUT SPECIAL DIRECTION-DEPENDENT BUILDING DIMENSIONS (YES=1, NO=0) | ISW(26) = 0 |
| | |
| OMIT TABLES FOR HOURLY CONCENTRATIONS (YES=1, NO=0) | ISW(27) = 0 |
| | |
| USEPA ADJUSTMENT FOR CALM HOURS (YES=1, NO=0) | ISW(28) = 1 |
| | |
| NUMBER OF INPUT SOURCES | NSOURC = 1 |
| NUMBER OF SOURCE GROUPS (=0, ALL SOURCES) | NGROUP = 0 |
| TIME PERIOD INTERVAL TO BE PRINTED (=0, ALL INTERVALS) | IPERD = 0 |
| NUMBER OF X (RANGE) GRID VALUES | NXPNTS = 10 |
| NUMBER OF Y (THETA) GRID VALUES | NYPNTS = 36 |
| NUMBER OF DISCRETE RECEPTORS | NXWYPT = 0 |
| SOURCE EMISSION RATE UNITS CONVERSION FACTOR | TK = 10000E+07 |
| ENTRAINMENT COEFFICIENT FOR UNSTABLE ATMOSPHERE | BETA1 = 0.500 |
| ENTRAINMENT COEFFICIENT FOR STABLE ATMOSPHERE | BETA2 = 0.500 |
| HEIGHT ABOVE GROUND AT WHICH WIND SPEED WAS MEASURED | ZR = 10.00 METERS |
| LOGICAL UNIT NUMBER OF METEOROLOGICAL DATA | IMET = 9 |
| DECAY COEFFICIENT FOR PHYSICAL OR CHEMICAL DEPLETION | DECAY = 0.000000E+00 |
| SURFACE STATION NO. | ISS = 12815 |
| YEAR OF SURFACE DATA | ISY = 75 |
| UPPER AIR STATION NO. | IUS = 12842 |
| YEAR OF UPPER AIR DATA | IUY = 75 |
| ALLOCATED DATA STORAGE | LIMIT = 43500 WORDS |

IST-5

1975 NRG ONLY SO₂
(Selected Days)

*** RANGES OF POLAR GRID SYSTEM ***
(METERS)

200.0, 300.0, 400.0, 600.0, 700.0, 800.0, 900.0, 1200.0, 1400.0, 1700.0,

*** RADIAL ANGLES OF POLAR GRID SYSTEM ***

(DEGREES)

10.0, 20.0, 30.0, 40.0, 50.0, 60.0, 70.0, 80.0, 90.0, 100.0,
110.0, 120.0, 130.0, 140.0, 150.0, 160.0, 170.0, 180.0, 190.0, 200.0,
210.0, 220.0, 230.0, 240.0, 250.0, 260.0, 270.0, 280.0, 290.0, 300.0,
310.0, 320.0, 330.0, 340.0, 350.0, 360.0.

*** SOURCE DATA ***

| SOURCE NUMBER | P E | K E | PART. CATS. | EMISSION RATE | | X (METERS) | Y (METERS) | BASE ELEV. (METERS) | HEIGHT (METERS) | TEMP. | EXIT VEL. | BLDG. HEIGHT (METERS) | BLDG. LENGTH (METERS) | BLDG. WIDTH (METERS) | |
|---------------|-----|-----|-------------|----------------------|--------------------|------------|------------|---------------------|-----------------|-----------|-----------|-----------------------|-----------------------|----------------------|-------|
| | | | | TYPE=0,1 (GRAMS/SEC) | TYPE=2 (GRAMS/SEC) | | | | | (DEG. K); | (M/SEC); | | | | |
| 101 | 0 | 0 | 0 | 0.15900E+02 | | 0.0 | 0.0 | 0.0 | 38.10 | 450.00 | 20.00 | 1.83 | 22.00 | 38.10 | 19.80 |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* 50 MAXIMUM 3-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CON. | PER. | DAY | X OR RANGE (METERS) | | Y(METERS) OR DIRECTION (DEGREES) | | RANK | CON. | PER. | DAY | X OR RANGE (METERS) | | Y(METERS) OR DIRECTION (DEGREES) | |
|------|----------|------|-----|------------------------------|-------|---|----------|------|------|--------|-------|------------------------------|--|---|--|
| | | | | | | | | | | | | | | | |
| 1 | 70.19772 | 4 | 290 | 200.0 | 360.0 | 26 | 36.36890 | 7 | 317 | 200.0 | 110.0 | | | | |
| 2 | 68.90119 | 4 | 317 | 200.0 | 130.0 | 27 | 35.83118 | 5 | 89 | 400.0 | 50.0 | | | | |
| 3 | 63.91370 | 4 | 89 | 200.0 | 30.0 | 28 | 35.02093 | 5 | 317 | 400.0 | 120.0 | | | | |
| 4 | 63.32747 | 8 | 359 | 200.0 | 340.0 | 29 | 34.94394 | 8 | 12 | 200.0 | 340.0 | | | | |
| 5 | 58.23714 | 4 | 290 | 300.0 | 360.0 | 30 | 31.71664 | 6 | 181 | 900.0 | 250.0 | | | | |
| 6 | 57.92264 | 5 | 89 | 200.0 | 50.0 | 31 | 31.40389 | 6 | 181 | 1200.0 | 250.0 | | | | |
| 7 | 57.42823 | 4 | 89 | 300.0 | 30.0 | 32 | 31.22021 | 5 | 231 | 900.0 | 140.0 | | | | |
| 8 | 57.39693 | 5 | 317 | 200.0 | 120.0 | 33 | 30.54041 | 4 | 119 | 300.0 | 20.0 | | | | |
| 9 | 56.98250 | 4 | 317 | 300.0 | 130.0 | 34 | 30.45523 | 4 | 119 | 200.0 | 20.0 | | | | |
| 10 | 52.16842 | 8 | 359 | 300.0 | 340.0 | 35 | 30.38268 | 5 | 359 | 200.0 | 330.0 | | | | |
| 11 | 47.64022 | 5 | 89 | 300.0 | 50.0 | 36 | 30.36380 | 4 | 89 | 700.0 | 30.0 | | | | |
| 12 | 46.98251 | 5 | 317 | 300.0 | 120.0 | 37 | 30.29858 | 6 | 12 | 200.0 | 330.0 | | | | |
| 13 | 46.78093 | 4 | 359 | 200.0 | 330.0 | 38 | 30.29595 | 4 | 89 | 800.0 | 30.0 | | | | |
| 14 | 46.24045 | 4 | 12 | 200.0 | 340.0 | 39 | 30.26907 | 8 | 317 | 300.0 | 140.0 | | | | |
| 15 | 46.08212 | 5 | 290 | 200.0 | 360.0 | 40 | 30.09605 | 5 | 231 | 800.0 | 140.0 | | | | |
| 16 | 45.87842 | 4 | 89 | 400.0 | 30.0 | 41 | 29.89275 | 6 | 181 | 800.0 | 250.0 | | | | |
| 17 | 45.28519 | 1 | 290 | 200.0 | 320.0 | 42 | 29.83396 | 4 | 89 | 900.0 | 30.0 | | | | |
| 18 | 43.82031 | 4 | 290 | 400.0 | 360.0 | 43 | 29.77248 | 4 | 89 | 600.0 | 30.0 | | | | |
| 19 | 42.79799 | 4 | 317 | 400.0 | 130.0 | 44 | 29.69927 | 7 | 359 | 200.0 | 330.0 | | | | |
| 20 | 38.99323 | 8 | 359 | 400.0 | 340.0 | 45 | 29.59470 | 5 | 290 | 200.0 | 350.0 | | | | |
| 21 | 38.31227 | 4 | 12 | 300.0 | 340.0 | 46 | 29.48559 | 6 | 359 | 300.0 | 330.0 | | | | |
| 22 | 37.81305 | 4 | 359 | 300.0 | 330.0 | 47 | 29.19773 | 1 | 290 | 300.0 | 320.0 | | | | |
| 23 | 37.64730 | 5 | 290 | 300.0 | 360.0 | 48 | 29.08799 | 7 | 317 | 300.0 | 110.0 | | | | |
| 24 | 37.61014 | 8 | 317 | 200.0 | 140.0 | 49 | 29.01781 | 6 | 181 | 1400.0 | 250.0 | | | | |
| 25 | 36.88528 | 6 | 359 | 200.0 | 330.0 | 50 | 28.73603 | 5 | 231 | 1200.0 | 140.0 | | | | |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* 50 MAXIMUM 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) | RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) |
|------|----------|------|-----|------------------------------|---|------|---------|------|-----|------------------------------|---|
| 1 | 20.34323 | 1 | 12 | 200.0 | 340.0 | 26 | 8.30731 | 1 | 12 | 1700.0 | 340.0 |
| 2 | 19.85964 | 1 | 359 | 200.0 | 330.0 | 27 | 8.25084 | 1 | 89 | 200.0 | 30.0 |
| 3 | 17.95250 | 1 | 317 | 200.0 | 130.0 | 28 | 7.88555 | 1 | 119 | 900.0 | 10.0 |
| 4 | 17.77008 | 1 | 290 | 200.0 | 360.0 | 29 | 7.85725 | 1 | 89 | 300.0 | 50.0 |
| 5 | 16.00315 | 1 | 359 | 300.0 | 330.0 | 30 | 7.85455 | 1 | 117 | 900.0 | 300.0 |
| 6 | 15.98145 | 1 | 12 | 300.0 | 340.0 | 31 | 7.79979 | 1 | 119 | 800.0 | 10.0 |
| 7 | 14.92629 | 1 | 317 | 200.0 | 120.0 | 32 | 7.77966 | 1 | 12 | 300.0 | 330.0 |
| 8 | 14.52427 | 1 | 290 | 300.0 | 360.0 | 33 | 7.64484 | 1 | 117 | 1200.0 | 300.0 |
| 9 | 14.50667 | 1 | 317 | 300.0 | 130.0 | 34 | 7.62219 | 1 | 180 | 900.0 | 120.0 |
| 10 | 12.77227 | 1 | 359 | 200.0 | 340.0 | 35 | 7.59507 | 1 | 12 | 900.0 | 340.0 |
| 11 | 12.01709 | 1 | 317 | 300.0 | 120.0 | 36 | 7.55682 | 1 | 117 | 800.0 | 300.0 |
| 12 | 11.59301 | 1 | 359 | 400.0 | 330.0 | 37 | 7.51923 | 1 | 317 | 200.0 | 110.0 |
| 13 | 11.14864 | 1 | 12 | 400.0 | 340.0 | 38 | 7.48337 | 1 | 119 | 300.0 | 10.0 |
| 14 | 10.68323 | 1 | 290 | 400.0 | 360.0 | 39 | 7.46976 | 1 | 359 | 400.0 | 340.0 |
| 15 | 10.61707 | 1 | 317 | 400.0 | 130.0 | 40 | 7.39249 | 1 | 180 | 800.0 | 120.0 |
| 16 | 10.27340 | 1 | 359 | 300.0 | 340.0 | 41 | 7.38728 | 1 | 117 | 400.0 | 300.0 |
| 17 | 9.94777 | 1 | 12 | 200.0 | 330.0 | 42 | 7.38055 | 1 | 119 | 700.0 | 10.0 |
| 18 | 9.67030 | 1 | 89 | 200.0 | 50.0 | 43 | 7.36047 | 1 | 119 | 400.0 | 10.0 |
| 19 | 8.74404 | 1 | 317 | 400.0 | 120.0 | 44 | 7.34341 | 1 | 89 | 300.0 | 30.0 |
| 20 | 8.67047 | 1 | 317 | 200.0 | 140.0 | 45 | 7.22736 | 1 | 359 | 1200.0 | 330.0 |
| 21 | 8.65963 | 1 | 290 | 200.0 | 320.0 | 46 | 7.20688 | 1 | 119 | 1200.0 | 10.0 |
| 22 | 8.65426 | 1 | 117 | 200.0 | 300.0 | 47 | 7.19266 | 1 | 12 | 800.0 | 340.0 |
| 23 | 8.61537 | 1 | 117 | 300.0 | 300.0 | 48 | 7.15349 | 1 | 117 | 1400.0 | 300.0 |
| 24 | 8.46021 | 1 | 12 | 1400.0 | 340.0 | 49 | 7.13751 | 1 | 359 | 1400.0 | 330.0 |
| 25 | 8.35161 | 1 | 12 | 1200.0 | 340.0 | 50 | 7.06407 | 1 | 119 | 300.0 | 20.0 |

| | |
|---|----------------------|
| CALCULATE (CONCENTRATION=1, DEPOSITION=2) | ISW(1) = 1 |
| RECEPTOR GRID SYSTEM (RECTANGULAR=1 OR 3, POLAR=2 OR 4) | ISW(2) = 4 |
| DISCRETE RECEPTOR SYSTEM (RECTANGULAR=1, POLAR=2) | ISW(3) = 2 |
| TERRAIN ELEVATIONS ARE READ (YES=1, NO=0) | ISW(4) = 0 |
| CALCULATIONS ARE WRITTEN TO TAPE (YES=1, NO=0) | ISW(5) = 0 |
| LIST ALL INPUT DATA (NO=0, YES=1, MET DATA ALSO=2) | ISW(6) = 1 |
| COMPUTE AVERAGE CONCENTRATION (OR TOTAL DEPOSITION) | |
| WITH THE FOLLOWING TIME PERIODS: | |
| HOURLY (YES=1, NO=0) | ISW(7) = 0 |
| 2-HOUR (YES=1, NO=0) | ISW(8) = 0 |
| 3-HOUR (YES=1, NO=0) | ISW(9) = 1 |
| 4-HOUR (YES=1, NO=0) | ISW(10) = 0 |
| 6-HOUR (YES=1, NO=0) | ISW(11) = 0 |
| 8-HOUR (YES=1, NO=0) | ISW(12) = 0 |
| 12-HOUR (YES=1, NO=0) | ISW(13) = 0 |
| 24-HOUR (YES=1, NO=0) | ISW(14) = 1 |
| PRINT "N"-DAY TABLE(S) (YES=1, NO=0) | ISW(15) = 1 |
| PRINT THE FOLLOWING TYPES OF TABLES WHOSE TIME PERIODS ARE | |
| SPECIFIED BY ISW(7) THROUGH ISW(14): | |
| DAILY TABLES (YES=1, NO=0) | ISW(16) = 0 |
| HIGHEST & SECOND HIGHEST TABLES (YES=1, NO=0) | ISW(17) = 1 |
| MAXIMUM 50 TABLES (YES=1, NO=0) | ISW(18) = 1 |
| METEOROLOGICAL DATA INPUT METHOD (PRE-PROCESSED=1, CARD=2) | ISW(19) = 1 |
| RURAL-URBAN OPTION (RURAL=0, URBAN MODE 1=1, URBAN MODE 2=2) | ISW(20) = 0 |
| WIND PROFILE EXPONENT VALUES (DEFAULTS=1, USER ENTERS=2, 3) | ISW(21) = 1 |
| VERTICAL POT. TEMP. GRADIENT VALUES (DEFAULTS=1, USER ENTERS=2, 3) | ISW(22) = 1 |
| SCALE EMISSION RATES FOR ALL SOURCES (NO=0, YES>0) | ISW(23) = 0 |
| PROGRAM CALCULATES FINAL PLUME RISE ONLY (YES=1, NO=2) | ISW(24) = 2 |
| PROGRAM ADJUSTS ALL STACK HEIGHTS FOR DOWNWASH (YES=2, NO=1) | ISW(25) = 1 |
| INPUT SPECIAL DIRECTION-DEPENDENT BUILDING DIMENSIONS (YES=1, NO=0) | ISW(26) = 0 |
| OMIT TABLES FOR HOURLY CONCENTRATIONS (YES=1, NO=0) | ISW(27) = 0 |
| USEPA ADJUSTMENT FOR CALM HOURS (YES=1, NO=0) | ISW(28) = 1 |
| NUMBER OF INPUT SOURCES | NSOURC = 1 |
| NUMBER OF SOURCE GROUPS (=0, ALL SOURCES) | NNGROUP = 0 |
| TIME PERIOD INTERVAL TO BE PRINTED (=0, ALL INTERVALS) | IPERD = 0 |
| NUMBER OF X (RANGE) GRID VALUES | NXPNTS = 5 |
| NUMBER OF Y (THETA) GRID VALUES | NYPNTS = 36 |
| NUMBER OF DISCRETE RECEPTORS | NXWYPT = 0 |
| SOURCE EMISSION RATE UNITS CONVERSION FACTOR | TK = 10000E+07 |
| ENTRAINMENT COEFFICIENT FOR UNSTABLE ATMOSPHERE | BETA1 = 0.600 |
| ENTRAINMENT COEFFICIENT FOR STABLE ATMOSPHERE | BETA2 = 0.600 |
| HEIGHT ABOVE GROUND AT WHICH WIND SPEED WAS MEASURED | ZR = 10.00 METERS |
| LOGICAL UNIT NUMBER OF METEOROLOGICAL DATA | IMET = 9 |
| DECAY COEFFICIENT FOR PHYSICAL OR CHEMICAL DEPLETION | DECAY = 0.000000E+00 |
| SURFACE STATION NO. | ISS = 12815 |
| YEAR OF SURFACE DATA | ISY = 76 |
| UPPER AIR STATION NO. | IUS = 12842 |
| YEAR OF UPPER AIR DATA | IUY = 75 |
| ALLOCATED DATA STORAGE | LIMIT = 43500 WORDS |

IST-6

1976--NRG ONLY--SO₂

*** RANGES OF POLAR GRID SYSTEM ***
(METERS)

500. 0, 1000. 0, 1500. 0, 2000. 0, 2500. 0,

*** RADIAL ANGLES OF POLAR GRID SYSTEM ***

(DEGREES)

| | | | | | | | | | |
|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| 10. 0, | 20. 0, | 30. 0, | 40. 0, | 50. 0, | 60. 0, | 70. 0, | 80. 0, | 90. 0, | 100. 0, |
| 110. 0, | 120. 0, | 130. 0, | 140. 0, | 150. 0, | 160. 0, | 170. 0, | 180. 0, | 190. 0, | 200. 0, |
| 210. 0, | 220. 0, | 230. 0, | 240. 0, | 250. 0, | 260. 0, | 270. 0, | 280. 0, | 290. 0, | 300. 0, |
| 310. 0, | 320. 0, | 330. 0, | 340. 0, | 350. 0, | 360. 0, | | | | |

*** SOURCE DATA ***

| SOURCE NUMBER | P | K | T W Y A NUMBER PART. CATS. | EMISSION RATE TYPE=0.1 (GRAMS/SEC) TYPE=2 (GRAMS/SEC) *PER METER**2 | X (METERS) | Y (METERS) | BASE ELEV. (METERS) | HEIGHT (METERS) | TEMP. | EXIT VEL. | BLDG. HEIGHT (METERS) | BLDG. LENGTH (METERS) | BLDG. WIDTH (METERS) | |
|---------------|---|---|-------------------------------------|--|---------------|---------------|---------------------------|--------------------|--|---|-----------------------------|-----------------------------|----------------------------|-------|
| | | | | | | | | | TYPE=0 (DEG. K); VERT. DIM TYPE=1 (METERS) | TYPE=0 (M/SEC); HORZ. DIM TYPE=1,2 (METERS) | | | | |
| 101 | 0 | 0 | 0 | 0.15800E+02 | 0.0 | 0.0 | 0.0 | 38.10 | 450.00 | 20.00 | 1.83 | 22.00 | 38.10 | 19.80 |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* 365-DAY AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 0.96354 AND OCCURRED AT (1500.0, 180.0) *

| DIRECTION / (DEGREES) / | RANCE (METERS) | | | | |
|----------------------------|----------------|---------|---------|---------|---------|
| | 500.0 | 1000.0 | 1500.0 | 2000.0 | 2500.0 |
| 360.0 / | 0.45008 | 0.61502 | 0.62806 | 0.58577 | 0.53649 |
| 350.0 / | 0.28655 | 0.40703 | 0.39769 | 0.35677 | 0.31716 |
| 340.0 / | 0.31200 | 0.45427 | 0.46607 | 0.43313 | 0.39337 |
| 330.0 / | 0.25302 | 0.38540 | 0.39268 | 0.35522 | 0.31292 |
| 320.0 / | 0.28190 | 0.43044 | 0.43720 | 0.39663 | 0.35239 |
| 310.0 / | 0.30277 | 0.44537 | 0.45020 | 0.40850 | 0.36390 |
| 300.0 / | 0.33915 | 0.47150 | 0.48707 | 0.45514 | 0.41688 |
| 290.0 / | 0.31838 | 0.43787 | 0.43551 | 0.39549 | 0.35207 |
| 280.0 / | 0.29418 | 0.41563 | 0.39716 | 0.34999 | 0.30545 |
| 270.0 / | 0.32460 | 0.46367 | 0.47537 | 0.44783 | 0.41403 |
| 260.0 / | 0.26789 | 0.37853 | 0.37881 | 0.34752 | 0.31485 |
| 250.0 / | 0.26875 | 0.39402 | 0.39772 | 0.36604 | 0.33267 |
| 240.0 / | 0.33244 | 0.47490 | 0.49305 | 0.46365 | 0.42579 |
| 230.0 / | 0.35687 | 0.48621 | 0.50748 | 0.48479 | 0.45142 |
| 220.0 / | 0.34439 | 0.43518 | 0.43758 | 0.40545 | 0.36772 |
| 210.0 / | 0.36712 | 0.43636 | 0.43422 | 0.39977 | 0.36200 |
| 200.0 / | 0.48940 | 0.56752 | 0.57603 | 0.53428 | 0.48258 |
| 190.0 / | 0.46870 | 0.55491 | 0.57515 | 0.53461 | 0.47977 |
| 180.0 / | 0.62520 | 0.77760 | 0.86354 | 0.84694 | 0.79283 |
| 170.0 / | 0.34628 | 0.46154 | 0.50619 | 0.49151 | 0.45818 |
| 160.0 / | 0.28397 | 0.38558 | 0.42555 | 0.41581 | 0.38902 |
| 150.0 / | 0.26811 | 0.36181 | 0.36949 | 0.33895 | 0.30195 |
| 140.0 / | 0.33835 | 0.44265 | 0.43977 | 0.39437 | 0.34416 |
| 130.0 / | 0.33864 | 0.45437 | 0.45690 | 0.41033 | 0.35766 |
| 120.0 / | 0.28613 | 0.38977 | 0.40111 | 0.37019 | 0.33282 |
| 110.0 / | 0.22610 | 0.29794 | 0.30946 | 0.29174 | 0.26749 |
| 100.0 / | 0.24494 | 0.31345 | 0.32103 | 0.29821 | 0.27116 |
| 90.0 / | 0.32452 | 0.41727 | 0.42940 | 0.39440 | 0.35267 |
| 80.0 / | 0.22522 | 0.30349 | 0.30251 | 0.26796 | 0.23221 |
| 70.0 / | 0.21258 | 0.29691 | 0.29180 | 0.26089 | 0.23198 |
| 60.0 / | 0.28086 | 0.39004 | 0.38540 | 0.34487 | 0.30630 |
| 50.0 / | 0.31542 | 0.41730 | 0.41369 | 0.36956 | 0.32565 |
| 40.0 / | 0.26231 | 0.35260 | 0.34226 | 0.30254 | 0.26464 |
| 30.0 / | 0.26658 | 0.36233 | 0.34044 | 0.29079 | 0.24672 |
| 20.0 / | 0.32033 | 0.42980 | 0.41520 | 0.36696 | 0.31970 |
| 10.0 / | 0.35411 | 0.47676 | 0.44999 | 0.39195 | 0.34063 |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* HIGHEST 3-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *
* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 30.22696 AND OCCURRED AT (500.0, 200.0) *

| DIRECTION / (DEGREES) / | RANGE (METERS) | | | | |
|----------------------------|-------------------|-------------------|-------------------|-------------------|-------------------|
| | 500.0 | 1000.0 | 1500.0 | 2000.0 | 2500.0 |
| 360.0 / | 24.65615 (49, 4) | 27.75782 (134, 4) | 22.90251 (216, 4) | 19.26638 (363, 4) | 17.89923 (363, 4) |
| 350.0 / | 20.83274 (27, 4) | 21.92358 (102, 4) | 18.19580 (172, 3) | 15.22205 (128, 5) | 14.97660 (129, 5) |
| 340.0 / | 17.85574 (61, 8) | 20.90864 (281, 4) | 19.45202 (281, 4) | 18.48754 (294, 2) | 17.84403 (294, 2) |
| 330.0 / | 22.47744 (192, 4) | 22.50924 (24, 5) | 22.68348 (24, 5) | 20.08636 (24, 5) | 17.18665 (24, 5) |
| 320.0 / | 16.67089 (189, 5) | 21.87045 (269, 4) | 18.60517 (269, 4) | 16.24210 (135, 3) | 15.12001 (135, 3) |
| 310.0 / | 14.00655 (189, 5) | 21.16171 (126, 4) | 18.44481 (86, 4) | 17.66958 (136, 2) | 17.22298 (136, 2) |
| 300.0 / | 15.11446 (64, 4) | 19.43320 (249, 5) | 17.18530 (64, 4) | 15.09387 (126, 6) | 14.51990 (126, 6) |
| 290.0 / | 19.42505 (298, 4) | 26.17892 (298, 4) | 21.92174 (298, 4) | 17.61536 (86, 6) | 16.09232 (86, 6) |
| 280.0 / | 15.22847 (84, 5) | 25.58028 (204, 5) | 16.02822 (298, 5) | 14.22053 (64, 6) | 12.68894 (269, 5) |
| 270.0 / | 14.78323 (114, 6) | 19.52705 (80, 5) | 18.93883 (121, 6) | 19.01068 (121, 6) | 17.68319 (121, 6) |
| 260.0 / | 23.14207 (59, 4) | 27.98689 (59, 4) | 24.43754 (59, 4) | 19.82943 (59, 4) | 16.07160 (59, 4) |
| 250.0 / | 19.32009 (307, 5) | 19.11445 (49, 5) | 18.88310 (307, 5) | 17.05566 (307, 5) | 14.85095 (307, 5) |
| 240.0 / | 19.72365 (344, 5) | 23.52058 (224, 5) | 19.80101 (224, 5) | 18.23587 (165, 6) | 16.51634 (165, 6) |
| 230.0 / | 19.52814 (240, 4) | 27.06534 (240, 4) | 21.10429 (240, 4) | 19.81377 (232, 2) | 16.31599 (344, 5) |
| 220.0 / | 23.99130 (166, 4) | 22.03458 (166, 4) | 21.18133 (232, 4) | 20.19525 (232, 4) | 18.15000 (232, 4) |
| 210.0 / | 17.45915 (19, 6) | 26.85423 (51, 5) | 22.15553 (51, 5) | 16.76819 (19, 6) | 14.82642 (19, 6) |
| 200.0 / | 30.22696 (100, 5) | 25.90606 (285, 5) | 24.08548 (286, 5) | 21.05614 (286, 5) | 18.03864 (286, 5) |
| 190.0 / | 22.90232 (58, 4) | 19.84289 (58, 4) | 18.04110 (302, 3) | 15.74138 (302, 3) | 13.85362 (292, 7) |
| 180.0 / | 26.93621 (313, 4) | 24.49432 (313, 4) | 24.71043 (302, 1) | 22.62187 (302, 1) | 19.90793 (302, 1) |
| 170.0 / | 19.22173 (220, 5) | 13.67783 (15, 1) | 15.53371 (15, 1) | 15.13245 (339, 2) | 15.99433 (339, 2) |
| 160.0 / | 22.22017 (356, 3) | 19.66150 (301, 4) | 19.15655 (356, 3) | 17.23937 (356, 3) | 16.02065 (335, 8) |
| 150.0 / | 17.38885 (54, 1) | 23.19472 (208, 4) | 19.88478 (67, 5) | 16.18490 (99, 8) | 14.70085 (99, 8) |
| 140.0 / | 25.64396 (54, 2) | 23.90794 (54, 2) | 22.99550 (54, 2) | 20.51264 (54, 2) | 17.78196 (54, 2) |
| 130.0 / | 20.87429 (362, 1) | 18.60881 (362, 1) | 19.58852 (151, 4) | 17.21218 (310, 1) | 17.36656 (310, 1) |
| 120.0 / | 17.25323 (17, 4) | 21.02572 (77, 6) | 21.03118 (77, 6) | 17.94160 (77, 6) | 14.06609 (77, 6) |
| 110.0 / | 29.74504 (17, 6) | 24.73850 (17, 6) | 22.88154 (17, 6) | 19.99995 (17, 6) | 17.16708 (17, 6) |
| 100.0 / | 24.82898 (17, 5) | 23.26868 (198, 3) | 22.24594 (198, 3) | 18.93397 (198, 3) | 15.82520 (198, 3) |
| 90.0 / | 28.69705 (139, 5) | 22.54531 (196, 5) | 21.12626 (117, 6) | 18.81133 (117, 6) | 16.25766 (117, 6) |
| 80.0 / | 22.11150 (145, 5) | 22.98470 (197, 3) | 21.76890 (197, 3) | 19.25406 (122, 6) | 17.28649 (122, 6) |
| 70.0 / | 24.81938 (145, 4) | 20.06553 (133, 3) | 18.57094 (315, 5) | 14.21022 (315, 5) | 12.84168 (350, 5) |
| 60.0 / | 27.12601 (145, 3) | 24.18950 (145, 3) | 22.43162 (145, 3) | 19.55532 (145, 3) | 16.72576 (145, 3) |
| 50.0 / | 24.34703 (69, 5) | 22.71605 (95, 5) | 19.84171 (145, 2) | 18.36679 (145, 2) | 16.23981 (145, 2) |
| 40.0 / | 20.02534 (69, 5) | 18.55443 (273, 4) | 19.16825 (325, 6) | 19.63119 (325, 6) | 18.40176 (325, 6) |
| 30.0 / | 21.58353 (69, 4) | 20.42531 (187, 4) | 18.16205 (214, 3) | 16.00787 (210, 5) | 14.39867 (210, 5) |
| 20.0 / | 18.54016 (69, 4) | 21.11223 (187, 4) | 19.60705 (68, 5) | 15.45405 (68, 5) | 12.44980 (363, 8) |
| 10.0 / | 22.43026 (32, 5) | 20.28118 (299, 4) | 21.61131 (299, 4) | 20.34332 (299, 4) | 18.16731 (299, 4) |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* SECOND HIGHEST 3-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *
* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 28.78926 AND OCCURRED AT (500.0, 200.0) *

| DIRECTION / (DEGREES) / | RANGE (METERS) | | | | |
|----------------------------|-------------------|-------------------|-------------------|-------------------|-------------------|
| | 500.0 | 1000.0 | 1500.0 | 2000.0 | 2500.0 |
| 360.0 / | 21.19865 (222, 5) | 24.83574 (216, 4) | 21.90362 (134, 4) | 18.95196 (75, 4) | 17.52147 (75, 4) |
| 350.0 / | 18.13273 (102, 4) | 20.41935 (148, 5) | 18.04944 (148, 5) | 15.85781 (172, 3) | 13.54404 (48, 6) |
| 340.0 / | 17.44827 (331, 5) | 18.89658 (229, 4) | 17.24978 (294, 2) | 15.29574 (281, 4) | 13.17252 (331, 5) |
| 330.0 / | 17.39426 (360, 5) | 20.26411 (153, 4) | 16.93501 (187, 6) | 15.08141 (360, 5) | 13.13486 (360, 5) |
| 320.0 / | 16.34606 (47, 4) | 21.79969 (168, 4) | 18.27926 (2, 5) | 15.63531 (2, 5) | 14.50977 (167, 4) |
| 310.0 / | 13.98037 (135, 4) | 19.56631 (86, 4) | 16.38690 (126, 4) | 15.20405 (149, 3) | 13.41100 (149, 3) |
| 300.0 / | 13.49223 (126, 6) | 18.14613 (62, 4) | 16.79549 (126, 6) | 15.91860 (64, 4) | 14.10809 (64, 4) |
| 290.0 / | 15.43405 (134, 6) | 18.29134 (279, 4) | 17.95035 (86, 6) | 16.43940 (298, 4) | 14.65016 (345, 4) |
| 280.0 / | 14.36148 (64, 6) | 18.44854 (63, 5) | 15.56416 (63, 5) | 13.92426 (269, 6) | 12.57179 (64, 6) |
| 270.0 / | 13.64539 (121, 6) | 16.17679 (121, 6) | 15.95572 (80, 5) | 13.41803 (241, 5) | 12.27164 (241, 5) |
| 260.0 / | 16.46848 (278, 4) | 22.02718 (290, 4) | 19.36260 (290, 4) | 14.91974 (290, 4) | 13.93369 (240, 6) |
| 250.0 / | 15.72117 (141, 4) | 19.01974 (307, 5) | 14.58536 (43, 5) | 12.97506 (303, 5) | 11.48361 (303, 5) |
| 240.0 / | 19.12640 (224, 5) | 16.52935 (119, 5) | 18.88920 (165, 6) | 15.82135 (344, 5) | 14.66190 (257, 1) |
| 230.0 / | 17.76539 (118, 6) | 20.71124 (242, 4) | 19.89018 (232, 2) | 19.05444 (344, 6) | 18.27200 (232, 2) |
| 220.0 / | 17.45387 (232, 4) | 19.43097 (232, 4) | 16.78427 (329, 4) | 15.80458 (57, 4) | 14.46039 (57, 4) |
| 210.0 / | 16.97569 (204, 4) | 17.32732 (17, 6) | 18.06491 (19, 6) | 15.31797 (51, 5) | 13.21933 (57, 5) |
| 200.0 / | 29.78926 (286, 5) | 25.56489 (100, 5) | 21.50704 (100, 5) | 19.60515 (318, 6) | 18.00573 (319, 5) |
| 190.0 / | 22.33957 (302, 3) | 19.42893 (302, 3) | 17.98516 (58, 4) | 15.48604 (58, 4) | 13.63161 (159, 6) |
| 180.0 / | 24.61501 (302, 1) | 24.41068 (302, 1) | 23.69100 (313, 4) | 21.16586 (313, 4) | 18.69434 (335, 6) |
| 170.0 / | 13.15342 (313, 3) | 13.49495 (220, 5) | 15.44541 (114, 3) | 15.15497 (15, 1) | 13.92058 (15, 1) |
| 160.0 / | 13.08532 (313, 5) | 19.57834 (356, 3) | 15.99520 (301, 4) | 16.67881 (335, 8) | 15.01824 (356, 3) |
| 150.0 / | 14.82560 (100, 2) | 20.64909 (67, 5) | 16.64477 (99, 8) | 15.55425 (124, 6) | 13.93677 (124, 6) |
| 140.0 / | 21.21754 (8, 8) | 22.94789 (295, 4) | 20.45815 (309, 5) | 16.20554 (309, 5) | 13.16045 (18, 2) |
| 130.0 / | 17.35160 (361, 6) | 18.31378 (235, 4) | 18.19962 (362, 1) | 16.73991 (151, 4) | 14.13546 (362, 1) |
| 120.0 / | 14.48059 (213, 5) | 18.67837 (323, 5) | 18.30204 (30, 4) | 16.14561 (30, 4) | 13.59000 (22, 1) |
| 110.0 / | 21.06238 (213, 5) | 21.05647 (275, 5) | 18.47312 (275, 5) | 16.04689 (16, 5) | 14.26178 (16, 5) |
| 100.0 / | 19.31375 (204, 6) | 19.34538 (213, 6) | 19.00292 (213, 6) | 15.31979 (213, 6) | 15.41175 (361, 7) |
| 90.0 / | 25.43123 (196, 5) | 21.85227 (117, 6) | 17.45446 (195, 5) | 15.87447 (261, 5) | 14.13067 (361, 4) |
| 80.0 / | 10.54558 (198, 4) | 21.82035 (198, 4) | 20.26891 (122, 6) | 17.67670 (197, 3) | 14.10661 (197, 3) |
| 70.0 / | 17.95394 (53, 6) | 19.81060 (145, 4) | 17.35209 (133, 3) | 14.09396 (145, 4) | 11.74264 (145, 4) |
| 60.0 / | 26.73297 (117, 5) | 20.71922 (117, 5) | 17.62177 (41, 5) | 15.23513 (139, 4) | 14.03103 (137, 4) |
| 50.0 / | 20.98389 (117, 4) | 19.84570 (117, 4) | 18.08387 (254, 3) | 16.81687 (258, 4) | 15.35967 (258, 4) |
| 40.0 / | 17.87000 (8, 4) | 18.14794 (186, 6) | 17.10649 (355, 7) | 15.95459 (355, 7) | 14.20364 (355, 7) |
| 30.0 / | 19.29300 (49, 6) | 19.57273 (214, 3) | 17.70790 (98, 4) | 14.39029 (214, 3) | 12.27176 (97, 5) |
| 20.0 / | 16.66059 (187, 4) | 20.92169 (68, 5) | 16.42828 (187, 4) | 14.11461 (363, 8) | 11.95450 (68, 5) |
| 10.0 / | 18.76932 (299, 4) | 17.39830 (152, 6) | 16.26551 (187, 3) | 12.66632 (187, 3) | 11.15941 (53, 3) |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* 50 MAXIMUM 3-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) | RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) |
|------|----------|------|-----|------------------------------|---|------|----------|------|-----|------------------------------|---|
| 1 | 30.22696 | 5 | 100 | 500.0 | 200.0 | 26 | 24.49432 | 4 | 313 | 1000.0 | 180.0 |
| 2 | 29.74504 | 6 | 17 | 500.0 | 110.0 | 27 | 24.43754 | 4 | 59 | 1500.0 | 260.0 |
| 3 | 28.78726 | 5 | 286 | 500.0 | 200.0 | 28 | 24.41068 | 1 | 302 | 1000.0 | 180.0 |
| 4 | 28.69705 | 5 | 139 | 500.0 | 90.0 | 29 | 24.34703 | 5 | 69 | 500.0 | 50.0 |
| 5 | 27.98689 | 4 | 59 | 1000.0 | 260.0 | 30 | 24.18960 | 3 | 145 | 1000.0 | 60.0 |
| 6 | 27.75782 | 4 | 134 | 1000.0 | 360.0 | 31 | 24.16302 | 6 | 75 | 500.0 | 60.0 |
| 7 | 27.12601 | 3 | 145 | 500.0 | 60.0 | 32 | 24.13099 | 4 | 54 | 500.0 | 180.0 |
| 8 | 27.06534 | 4 | 240 | 1000.0 | 230.0 | 33 | 24.08648 | 5 | 286 | 1500.0 | 200.0 |
| 9 | 26.94376 | 4 | 100 | 500.0 | 200.0 | 34 | 23.99130 | 4 | 166 | 500.0 | 220.0 |
| 10 | 26.93521 | 4 | 313 | 500.0 | 180.0 | 35 | 23.80794 | 2 | 54 | 1000.0 | 140.0 |
| 11 | 26.85423 | 5 | 51 | 1000.0 | 210.0 | 36 | 23.69100 | 4 | 313 | 1500.0 | 180.0 |
| 12 | 26.73299 | 5 | 117 | 500.0 | 60.0 | 37 | 23.52058 | 5 | 224 | 1000.0 | 240.0 |
| 13 | 26.64396 | 2 | 54 | 500.0 | 140.0 | 38 | 23.26868 | 3 | 199 | 1000.0 | 100.0 |
| 14 | 26.17892 | 4 | 298 | 1000.0 | 290.0 | 39 | 23.19472 | 4 | 208 | 1000.0 | 150.0 |
| 15 | 25.80606 | 5 | 286 | 1000.0 | 200.0 | 40 | 23.14207 | 4 | 59 | 500.0 | 260.0 |
| 16 | 25.58028 | 5 | 204 | 1000.0 | 280.0 | 41 | 23.01945 | 6 | 117 | 500.0 | 90.0 |
| 17 | 25.56489 | 5 | 100 | 1000.0 | 200.0 | 42 | 22.99550 | 2 | 54 | 1500.0 | 140.0 |
| 18 | 25.43123 | 5 | 196 | 500.0 | 90.0 | 43 | 22.98470 | 3 | 197 | 1000.0 | 80.0 |
| 19 | 24.83574 | 4 | 216 | 1000.0 | 360.0 | 44 | 22.94789 | 4 | 295 | 1000.0 | 140.0 |
| 20 | 24.82998 | 5 | 17 | 500.0 | 100.0 | 45 | 22.90251 | 4 | 216 | 1500.0 | 360.0 |
| 21 | 24.81938 | 4 | 145 | 500.0 | 70.0 | 46 | 22.90232 | 4 | 58 | 500.0 | 190.0 |
| 22 | 24.75850 | 6 | 17 | 1000.0 | 110.0 | 47 | 22.88154 | 6 | 17 | 1500.0 | 110.0 |
| 23 | 24.71043 | 1 | 302 | 1500.0 | 180.0 | 48 | 22.71605 | 5 | 95 | 1000.0 | 50.0 |
| 24 | 24.65615 | 4 | 49 | 500.0 | 360.0 | 49 | 22.68348 | 5 | 24 | 1500.0 | 330.0 |
| 25 | 24.61501 | 1 | 302 | 500.0 | 180.0 | 50 | 22.62187 | 1 | 302 | 2000.0 | 180.0 |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* HIGHEST 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *
* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 11.56452 AND OCCURRED AT (500.0, 180.0) *

| DIRECTION / (DEGREES) / | RANGE (METERS) | | | | |
|----------------------------|-------------------|-------------------|-------------------|------------------|------------------|
| | 500.0 | 1000.0 | 1500.0 | 2000.0 | 2500.0 |
| 350.0 / | 4.75880 (188, 1) | 5.81250 (189, 1) | 5.86360 (188, 1) | 5.31180 (188, 1) | 4.93028 (363, 1) |
| 350.0 / | 4.44757 (172, 1) | 5.20100 (172, 1) | 4.89403 (172, 1) | 4.39627 (48, 1) | 4.11252 (49, 1) |
| 340.0 / | 4.77525 (144, 1) | 6.27146 (185, 1) | 5.14573 (195, 1) | 4.14779 (331, 1) | 3.99338 (331, 1) |
| 330.0 / | 4.09797 (192, 1) | 4.72836 (24, 1) | 4.56289 (24, 1) | 3.95292 (360, 1) | 3.72635 (360, 1) |
| 320.0 / | 4.96584 (135, 1) | 5.51220 (47, 1) | 5.37715 (47, 1) | 4.97878 (135, 1) | 4.58847 (135, 1) |
| 310.0 / | 4.95674 (135, 1) | 4.89725 (135, 1) | 6.50593 (136, 1) | 7.20267 (136, 1) | 7.10628 (136, 1) |
| 300.0 / | 4.86969 (120, 1) | 5.05963 (120, 1) | 4.40297 (64, 1) | 4.21395 (64, 1) | 3.84678 (64, 1) |
| 290.0 / | 5.29969 (120, 1) | 6.53891 (120, 1) | 5.89996 (120, 1) | 5.09812 (120, 1) | 4.43526 (120, 1) |
| 280.0 / | 3.53468 (63, 1) | 5.66443 (63, 1) | 4.88327 (269, 1) | 4.24045 (269, 1) | 3.62204 (269, 1) |
| 270.0 / | 4.37166 (114, 1) | 4.53079 (80, 1) | 4.36947 (241, 1) | 3.97661 (241, 1) | 3.49644 (241, 1) |
| 260.0 / | 5.39115 (59, 1) | 6.57444 (59, 1) | 6.37109 (278, 1) | 5.37994 (278, 1) | 4.51394 (59, 1) |
| 250.0 / | 4.67771 (141, 1) | 5.87527 (141, 1) | 5.67587 (141, 1) | 5.03277 (141, 1) | 4.38219 (141, 1) |
| 240.0 / | 5.29991 (165, 1) | 6.66661 (101, 1) | 5.80693 (101, 1) | 5.09858 (165, 1) | 4.50648 (165, 1) |
| 230.0 / | 4.86480 (242, 1) | 6.14411 (242, 1) | 5.82781 (130, 1) | 5.73426 (130, 1) | 5.35152 (130, 1) |
| 220.0 / | 5.78502 (166, 1) | 5.44313 (166, 1) | 5.52123 (232, 1) | 5.11548 (232, 1) | 4.52655 (232, 1) |
| 210.0 / | 5.51211 (100, 1) | 5.50001 (164, 1) | 5.71367 (98, 1) | 5.51456 (98, 1) | 5.04885 (98, 1) |
| 200.0 / | 7.18974 (100, 1) | 6.02191 (292, 1) | 6.50176 (57, 1) | 6.68639 (57, 1) | 6.33798 (57, 1) |
| 190.0 / | 9.39582 (318, 1) | 8.62594 (318, 1) | 9.10919 (318, 1) | 9.51921 (318, 1) | 7.57120 (318, 1) |
| 180.0 / | 11.56452 (302, 1) | 10.86030 (302, 1) | 10.73517 (302, 1) | 9.71076 (302, 1) | 8.48044 (302, 1) |
| 170.0 / | 4.64669 (77, 1) | 5.18951 (77, 1) | 5.58464 (337, 1) | 5.48101 (337, 1) | 4.99998 (337, 1) |
| 160.0 / | 4.88991 (356, 1) | 4.56765 (337, 1) | 5.44432 (337, 1) | 5.50362 (337, 1) | 5.13576 (337, 1) |
| 150.0 / | 4.83325 (100, 1) | 4.76844 (28, 1) | 5.06114 (327, 1) | 4.93825 (327, 1) | 4.52275 (327, 1) |
| 140.0 / | 7.34921 (18, 1) | 8.15697 (18, 1) | 8.45411 (18, 1) | 7.71742 (18, 1) | 6.75015 (18, 1) |
| 130.0 / | 5.30079 (362, 1) | 6.57626 (362, 1) | 7.00597 (362, 1) | 6.41015 (362, 1) | 5.59037 (362, 1) |
| 120.0 / | 4.44301 (17, 1) | 5.45380 (93, 1) | 5.10144 (22, 1) | 5.77513 (22, 1) | 6.01745 (22, 1) |
| 110.0 / | 6.49088 (17, 1) | 5.83280 (17, 1) | 5.90496 (17, 1) | 5.55359 (17, 1) | 5.06618 (17, 1) |
| 100.0 / | 5.86066 (17, 1) | 4.68413 (17, 1) | 4.28277 (17, 1) | 3.77352 (17, 1) | 3.70482 (16, 1) |
| 90.0 / | 8.13536 (196, 1) | 7.90596 (196, 1) | 7.84560 (197, 1) | 7.07173 (197, 1) | 6.18226 (197, 1) |
| 80.0 / | 5.18647 (145, 1) | 4.14961 (195, 1) | 3.96730 (197, 1) | 3.31086 (197, 1) | 2.99047 (122, 1) |
| 70.0 / | 5.40142 (145, 1) | 4.18966 (133, 1) | 3.76363 (315, 1) | 3.95699 (350, 1) | 3.96619 (350, 1) |
| 60.0 / | 4.97860 (76, 1) | 5.20076 (95, 1) | 4.52938 (95, 1) | 3.67609 (194, 1) | 3.52737 (195, 1) |
| 50.0 / | 6.20217 (69, 1) | 6.12129 (95, 1) | 4.95391 (95, 1) | 3.98441 (117, 1) | 3.89903 (233, 1) |
| 40.0 / | 3.95371 (116, 1) | 6.46721 (185, 1) | 5.08784 (196, 1) | 4.97859 (299, 1) | 4.63135 (299, 1) |
| 30.0 / | 4.83426 (69, 1) | 6.29659 (186, 1) | 4.80342 (186, 1) | 3.48709 (144, 1) | 3.07117 (144, 1) |
| 20.0 / | 4.55418 (363, 1) | 5.71041 (186, 1) | 4.70104 (186, 1) | 4.35543 (363, 1) | 3.95703 (363, 1) |
| 10.0 / | 4.79579 (32, 1) | 5.03765 (152, 1) | 4.18672 (299, 1) | 4.09848 (299, 1) | 3.75801 (299, 1) |

*** NRC/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* SECOND HIGHEST 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *
* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS B. 500.0 AND OCCURRED AT (500.0, 100.0) *

| DIRECTION / (DEGREES) / | RANGE (METERS) | | | | |
|----------------------------|------------------|------------------|------------------|------------------|------------------|
| | 500.0 | 1000.0 | 1500.0 | 2000.0 | 2500.0 |
| 350.0 / | 4.20567 (215, 1) | 5.54257 (152, 1) | 5.09506 (363, 1) | 5.12185 (363, 1) | 4.66060 (189, 1) |
| 350.0 / | 3.49098 (102, 1) | 4.53833 (228, 1) | 4.32117 (46, 1) | 4.17906 (172, 1) | 3.50692 (172, 1) |
| 340.0 / | 3.32160 (149, 1) | 5.40471 (228, 1) | 4.19110 (149, 1) | 4.13167 (149, 1) | 3.08104 (149, 1) |
| 330.0 / | 3.61064 (24, 1) | 4.48762 (153, 1) | 3.86967 (360, 1) | 3.90665 (24, 1) | 3.26639 (24, 1) |
| 320.0 / | 4.59742 (47, 1) | 4.95292 (135, 1) | 5.17262 (135, 1) | 4.86922 (47, 1) | 4.34156 (47, 1) |
| 310.0 / | 4.15198 (168, 1) | 4.75871 (168, 1) | 4.86756 (168, 1) | 4.66272 (168, 1) | 4.42685 (168, 1) |
| 300.0 / | 4.15096 (64, 1) | 4.12477 (64, 1) | 4.18073 (120, 1) | 3.92231 (80, 1) | 3.60884 (80, 1) |
| 290.0 / | 4.03461 (127, 1) | 4.96143 (63, 1) | 4.19607 (127, 1) | 3.99199 (72, 1) | 3.64520 (72, 1) |
| 280.0 / | 3.17862 (64, 1) | 4.86931 (269, 1) | 4.45777 (63, 1) | 3.79723 (179, 1) | 3.34238 (179, 1) |
| 270.0 / | 3.35353 (80, 1) | 4.50673 (269, 1) | 4.17224 (268, 1) | 3.56239 (268, 1) | 3.08654 (269, 1) |
| 260.0 / | 4.53079 (278, 1) | 6.56968 (278, 1) | 6.12508 (59, 1) | 5.28622 (59, 1) | 4.43035 (278, 1) |
| 250.0 / | 3.81864 (307, 1) | 5.75672 (225, 1) | 4.92500 (225, 1) | 3.67874 (225, 1) | 2.86253 (307, 1) |
| 240.0 / | 5.07730 (101, 1) | 5.75983 (165, 1) | 5.64328 (165, 1) | 4.64562 (101, 1) | 3.79542 (297, 1) |
| 230.0 / | 4.09622 (240, 1) | 5.99898 (240, 1) | 5.28799 (240, 1) | 4.99129 (232, 1) | 4.55144 (232, 1) |
| 220.0 / | 5.27040 (232, 1) | 5.34320 (232, 1) | 4.34985 (166, 1) | 3.46465 (130, 1) | 2.92197 (348, 1) |
| 210.0 / | 4.55730 (57, 1) | 5.16208 (98, 1) | 4.78655 (57, 1) | 4.46606 (57, 1) | 3.97200 (57, 1) |
| 200.0 / | 6.39073 (286, 1) | 5.76333 (140, 1) | 6.42525 (292, 1) | 6.16569 (292, 1) | 5.63147 (292, 1) |
| 190.0 / | 8.35475 (302, 1) | 7.05089 (302, 1) | 6.88762 (292, 1) | 6.66639 (292, 1) | 6.13436 (292, 1) |
| 180.0 / | 8.56561 (336, 1) | 8.26588 (336, 1) | 8.55970 (336, 1) | 7.93577 (336, 1) | 7.01909 (336, 1) |
| 170.0 / | 4.52109 (337, 1) | 4.85668 (337, 1) | 4.90973 (77, 1) | 4.68512 (19, 1) | 4.73362 (19, 1) |
| 160.0 / | 4.10832 (337, 1) | 4.43182 (356, 1) | 4.75214 (335, 1) | 4.87905 (335, 1) | 4.58153 (335, 1) |
| 150.0 / | 4.36759 (28, 1) | 4.74587 (100, 1) | 5.04861 (67, 1) | 4.47281 (28, 1) | 3.92442 (28, 1) |
| 140.0 / | 4.42219 (1, 1) | 6.00253 (1, 1) | 5.69445 (1, 1) | 4.90332 (1, 1) | 4.16410 (1, 1) |
| 130.0 / | 4.87992 (361, 1) | 5.10876 (235, 1) | 4.41469 (361, 1) | 4.44737 (310, 1) | 4.29499 (310, 1) |
| 120.0 / | 3.70611 (200, 1) | 4.33753 (235, 1) | 4.70308 (326, 1) | 4.92469 (326, 1) | 4.68886 (326, 1) |
| 110.0 / | 3.49873 (16, 1) | 3.76249 (198, 1) | 3.84265 (16, 1) | 3.90701 (326, 1) | 3.80915 (326, 1) |
| 100.0 / | 3.96735 (8, 1) | 4.24153 (199, 1) | 3.89713 (198, 1) | 3.74613 (16, 1) | 3.29984 (17, 1) |
| 90.0 / | 6.02453 (197, 1) | 7.70035 (197, 1) | 6.57885 (196, 1) | 5.38455 (196, 1) | 4.43474 (196, 1) |
| 80.0 / | 3.82337 (196, 1) | 4.10525 (197, 1) | 3.74896 (195, 1) | 3.24965 (122, 1) | 2.69803 (197, 1) |
| 70.0 / | 3.26765 (53, 1) | 4.12422 (146, 1) | 3.66320 (146, 1) | 3.15952 (42, 1) | 2.80774 (42, 1) |
| 60.0 / | 4.72205 (145, 1) | 4.75827 (194, 1) | 4.38071 (194, 1) | 3.58995 (315, 1) | 3.14679 (194, 1) |
| 50.0 / | 5.93513 (117, 1) | 5.35106 (117, 1) | 4.65094 (117, 1) | 3.94231 (145, 1) | 3.49928 (145, 1) |
| 40.0 / | 3.87379 (95, 1) | 4.96501 (95, 1) | 4.91041 (299, 1) | 4.77113 (355, 1) | 4.48662 (355, 1) |
| 30.0 / | 3.79479 (186, 1) | 4.39701 (214, 1) | 3.92188 (88, 1) | 3.35070 (186, 1) | 2.95423 (299, 1) |
| 20.0 / | 4.29150 (186, 1) | 5.25729 (187, 1) | 4.60499 (363, 1) | 3.55885 (186, 1) | 3.04409 (50, 1) |
| 10.0 / | 4.22413 (152, 1) | 3.74152 (299, 1) | 3.40246 (152, 1) | 2.71772 (50, 1) | 2.53021 (50, 1) |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* 50 MAXIMUM 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) | RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) |
|------|----------|------|-----|------------------------------|---|------|---------|------|-----|------------------------------|---|
| 1 | 11.56452 | 1 | 302 | 500.0 | 180.0 | 26 | 7.50153 | 1 | 335 | 2000.0 | 180.0 |
| 2 | 10.86030 | 1 | 302 | 1000.0 | 180.0 | 27 | 7.46441 | 1 | 339 | 2000.0 | 180.0 |
| 3 | 10.73517 | 1 | 302 | 1500.0 | 180.0 | 28 | 7.34921 | 1 | 18 | 500.0 | 140.0 |
| 4 | 9.71076 | 1 | 302 | 2000.0 | 180.0 | 29 | 7.20267 | 1 | 136 | 2000.0 | 310.0 |
| 5 | 9.10819 | 1 | 318 | 1500.0 | 190.0 | 30 | 7.18974 | 1 | 100 | 500.0 | 200.0 |
| 6 | 8.62594 | 1 | 318 | 1000.0 | 190.0 | 31 | 7.18556 | 1 | 340 | 2000.0 | 180.0 |
| 7 | 8.56561 | 1 | 336 | 500.0 | 180.0 | 32 | 7.10528 | 1 | 136 | 2500.0 | 310.0 |
| 8 | 8.55970 | 1 | 336 | 1500.0 | 180.0 | 33 | 7.07173 | 1 | 197 | 2000.0 | 90.0 |
| 9 | 8.51921 | 1 | 318 | 2000.0 | 190.0 | 34 | 7.05089 | 1 | 302 | 1000.0 | 190.0 |
| 10 | 8.48044 | 1 | 302 | 2500.0 | 180.0 | 35 | 7.01909 | 1 | 336 | 2500.0 | 180.0 |
| 11 | 8.45411 | 1 | 18 | 1500.0 | 140.0 | 36 | 7.01836 | 1 | 340 | 2500.0 | 180.0 |
| 12 | 8.39582 | 1 | 318 | 500.0 | 190.0 | 37 | 7.00697 | 1 | 362 | 1500.0 | 130.0 |
| 13 | 8.35475 | 1 | 302 | 500.0 | 190.0 | 38 | 6.92875 | 1 | 335 | 2500.0 | 180.0 |
| 14 | 8.26588 | 1 | 336 | 1000.0 | 180.0 | 39 | 6.88762 | 1 | 292 | 1500.0 | 190.0 |
| 15 | 8.16536 | 1 | 196 | 500.0 | 90.0 | 40 | 6.75015 | 1 | 18 | 2500.0 | 140.0 |
| 16 | 8.15697 | 1 | 18 | 1000.0 | 140.0 | 41 | 6.68639 | 1 | 57 | 2000.0 | 200.0 |
| 17 | 7.97232 | 1 | 339 | 1500.0 | 180.0 | 42 | 6.67526 | 1 | 362 | 1000.0 | 130.0 |
| 18 | 7.93577 | 1 | 336 | 2000.0 | 180.0 | 43 | 6.66698 | 1 | 339 | 500.0 | 180.0 |
| 19 | 7.84560 | 1 | 197 | 1500.0 | 90.0 | 44 | 6.66561 | 1 | 101 | 1000.0 | 240.0 |
| 20 | 7.80586 | 1 | 196 | 1000.0 | 90.0 | 45 | 6.66639 | 1 | 292 | 2000.0 | 190.0 |
| 21 | 7.71742 | 1 | 18 | 2000.0 | 140.0 | 46 | 6.65449 | 1 | 339 | 2500.0 | 180.0 |
| 22 | 7.70035 | 1 | 197 | 1000.0 | 90.0 | 47 | 6.62629 | 1 | 340 | 1500.0 | 180.0 |
| 23 | 7.57120 | 1 | 318 | 2500.0 | 190.0 | 48 | 6.57085 | 1 | 196 | 1500.0 | 90.0 |
| 24 | 7.56695 | 1 | 339 | 1000.0 | 180.0 | 49 | 6.57444 | 1 | 59 | 1000.0 | 260.0 |
| 25 | 7.51366 | 1 | 335 | 1500.0 | 180.0 | 50 | 6.56768 | 1 | 278 | 1000.0 | 260.0 |

| | |
|---|----------------------|
| CALCULATE (CONCENTRATION=1, DEPOSITION=2) | ISW(1) = 1 |
| RECEPTOR GRID SYSTEM (RECTANGULAR=1 OR 3, POLAR=2 OR 4) | ISW(2) = 4 |
| DISCRETE RECEPTOR SYSTEM (RECTANGULAR=1, POLAR=2) | ISW(3) = 2 |
| TERRAIN ELEVATIONS ARE READ (YES=1, NO=0) | ISW(4) = 0 |
| CALCULATIONS ARE WRITTEN TO TAPE (YES=1, NO=0) | ISW(5) = 0 |
| LIST ALL INPUT DATA (NO=0, YES=1, MET DATA ALSO=2) | ISW(6) = 1 |
| COMPUTE AVERAGE CONCENTRATION (OR TOTAL DEPOSITION) | |
| WITH THE FOLLOWING TIME PERIODS: | |
| HOURLY (YES=1, NO=0) | ISW(7) = 0 |
| 2-HOUR (YES=1, NO=0) | ISW(8) = 0 |
| 3-HOUR (YES=1, NO=0) | ISW(9) = 1 |
| 4-HOUR (YES=1, NO=0) | ISW(10) = 0 |
| 6-HOUR (YES=1, NO=0) | ISW(11) = 0 |
| 8-HOUR (YES=1, NO=0) | ISW(12) = 0 |
| 12-HOUR (YES=1, NO=0) | ISW(13) = 0 |
| 24-HOUR (YES=1, NO=0) | ISW(14) = 1 |
| PRINT "N"-DAY TABLE(S) (YES=1, NO=0) | ISW(15) = 0 |
| PRINT THE FOLLOWING TYPES OF TABLES WHOSE TIME PERIODS ARE | |
| SPECIFIED BY ISW(7) THROUGH ISW(14): | |
| DAILY TABLES (YES=1, NO=0) | ISW(16) = 0 |
| HIGHEST & SECOND HIGHEST TABLES (YES=1, NO=0) | ISW(17) = 0 |
| MAXIMUM 50 TABLES (YES=1, NO=0) | ISW(18) = 1 |
| METEOROLOGICAL DATA INPUT METHOD (PRE-PROCESSED=1, CARD=2) | ISW(19) = 1 |
| RURAL-URBAN OPTION (RURAL=0, URBAN MODE 1=1, URBAN MODE 2=2) | ISW(20) = 0 |
| WIND PROFILE EXPONENT VALUES (DEFAULTS=1, USER ENTERS=2, 3) | ISW(21) = 1 |
| VERTICAL PDT. TEMP. GRADIENT VALUES (DEFAULTS=1, USER ENTERS=2, 3) | ISW(22) = 1 |
| SCALE EMISSION RATES FOR ALL SOURCES (NO=0, YES>0) | ISW(23) = 0 |
| PROGRAM CALCULATES FINAL PLUME RISE ONLY (YES=1, NO=2) | ISW(24) = 2 |
| PROGRAM ADJUSTS ALL STACK HEIGHTS FOR DOWNWASH (YES=2, NO=1) | ISW(25) = 1 |
| INPUT SPECIAL DIRECTION-DEPENDENT BUILDING DIMENSIONS (YES=1, NO=0) | ISW(26) = 0 |
| OMIT TABLES FOR HOURLY CONCENTRATIONS (YES=1, NO=0) | ISW(27) = 0 |
| USEPA ADJUSTMENT FOR CALM HOURS (YES=1, NO=0) | ISW(28) = 1 |
| NUMBER OF INPUT SOURCES | NSOURC = 1 |
| NUMBER OF SOURCE GROUPS (≠0, ALL SOURCES) | NGROUP = 0 |
| TIME PERIOD INTERVAL TO BE PRINTED (≠0, ALL INTERVALS) | IPERD = 0 |
| NUMBER OF X (RANGE) GRID VALUES | NXPNTS = 10 |
| NUMBER OF Y (THETA) GRID VALUES | NYPNTS = 36 |
| NUMBER OF DISCRETE RECEPTORS | NXWYPT = 0 |
| SOURCE EMISSION RATE UNITS CONVERSION FACTOR | TK = 10000E+07 |
| ENTRAINMENT COEFFICIENT FOR UNSTABLE ATMOSPHERE | BETA1 = 0.600 |
| ENTRAINMENT COEFFICIENT FOR STABLE ATMOSPHERE | BETA2 = 0.600 |
| HEIGHT ABOVE GROUND AT WHICH WIND SPEED WAS MEASURED | ZR = 10.00 METERS |
| LOGICAL UNIT NUMBER OF METEOROLOGICAL DATA | IMET = 9 |
| DECAY COEFFICIENT FOR PHYSICAL OR CHEMICAL DEPLETION | DECAY = 0.000000E+00 |
| SURFACE STATION NO. | ISS = 12815 |
| YEAR OF SURFACE DATA | ISY = 76 |
| UPPER AIR STATION NO. | IUS = 12842 |
| YEAR OF UPPER AIR DATA | IUY = 76 |
| ALLOCATED DATA STORAGE | LIMIT = 43500 WORDS |

EST-7

1976 - NRG ONLY - SO₂
(selected Days)

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09

*** RANGES OF POLAR GRID SYSTEM ***
(METERS)

| | | | | | | | | | |
|--------|--------|--------|--------|--------|--------|--------|---------|---------|---------|
| 200.0, | 300.0, | 400.0, | 500.0, | 700.0, | 850.0, | 900.0, | 1200.0, | 1400.0, | 1700.0, |
|--------|--------|--------|--------|--------|--------|--------|---------|---------|---------|

*** RADIAL ANGLES OF POLAR GRID SYSTEM ***
(DEGREES)

| | | | | | | | | | |
|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| 10.0, | 20.0, | 30.0, | 40.0, | 50.0, | 60.0, | 70.0, | 80.0, | 90.0, | 100.0, |
| 110.0, | 120.0, | 130.0, | 140.0, | 150.0, | 160.0, | 170.0, | 180.0, | 190.0, | 200.0, |
| 210.0, | 220.0, | 230.0, | 240.0, | 250.0, | 260.0, | 270.0, | 280.0, | 290.0, | 300.0, |
| 310.0, | 320.0, | 330.0, | 340.0, | 350.0, | 360.0, | | | | |

*** SOURCE DATA ***

| SOURCE NUMBER | P E | K E | PART. CATS. | EMISSION RATE | | | X (METERS) | Y (METERS) | BASE ELEV. (METERS) | HEIGHT (METERS) | TEMP. | EXIT VEL. | | BLDG. HEIGHT (METERS) | BLDG. LENGTH (METERS) | BLDG. WIDTH (METERS) |
|---------------|-----|-----|-------------|-----------------------------|-----------|----------|------------|------------|---------------------|-----------------|------------------|--------------------|-----------------|-----------------------|-----------------------|----------------------|
| | | | | TYPE=0.1 (GRAMS/SEC) TYPE=2 | (DEG. K); | (M/SEC); | | | | | VERT. DIM TYPE=1 | HORZ. DIM TYPE=1,2 | DIAMETER TYPE=0 | | | |
| 101 | 0 | 0 | 0 | 0.15800E+02 | | | 0.0 | 0.0 | 0.0 | 38.10 | 450.00 | 20.00 | 1.83 | 22.00 | 38.10 | 19.80 |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

► 50 MAXIMUM 3-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) ►

* FROM ALL SOURCES *

| RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) | RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) |
|------|----------|------|-----|------------------------------|---|------|----------|------|-----|------------------------------|---|
| 1 | 67.57371 | 6 | 17 | 200.0 | 110.0 | 26 | 38.18905 | 5 | 319 | 200.0 | 180.0 |
| 2 | 66.74905 | 5 | 286 | 200.0 | 200.0 | 27 | 38.01271 | 1 | 100 | 200.0 | 150.0 |
| 3 | 61.06427 | 1 | 302 | 200.0 | 180.0 | 28 | 37.65272 | 4 | 319 | 200.0 | 190.0 |
| 4 | 55.68066 | 6 | 17 | 300.0 | 110.0 | 29 | 37.55079 | 2 | 100 | 200.0 | 150.0 |
| 5 | 55.18454 | 5 | 286 | 300.0 | 200.0 | 30 | 36.73504 | 1 | 302 | 400.0 | 180.0 |
| 6 | 54.71575 | 5 | 17 | 200.0 | 100.0 | 31 | 36.62931 | 5 | 302 | 200.0 | 200.0 |
| 7 | 54.10024 | 5 | 100 | 200.0 | 200.0 | 32 | 36.53527 | 7 | 302 | 300.0 | 180.0 |
| 8 | 52.81154 | 3 | 302 | 200.0 | 190.0 | 33 | 36.44593 | 6 | 302 | 300.0 | 180.0 |
| 9 | 52.28996 | 4 | 286 | 200.0 | 200.0 | 34 | 36.35989 | 3 | 19 | 200.0 | 140.0 |
| 10 | 50.19469 | 1 | 302 | 300.0 | 180.0 | 35 | 36.02138 | 3 | 286 | 200.0 | 180.0 |
| 11 | 49.08342 | 5 | 100 | 300.0 | 200.0 | 36 | 35.67308 | 6 | 336 | 300.0 | 180.0 |
| 12 | 45.24207 | 7 | 302 | 200.0 | 180.0 | 37 | 34.99133 | 7 | 336 | 200.0 | 180.0 |
| 13 | 44.65088 | 5 | 17 | 300.0 | 100.0 | 38 | 34.89172 | 6 | 196 | 300.0 | 90.0 |
| 14 | 44.18292 | 6 | 302 | 200.0 | 180.0 | 39 | 34.76303 | 2 | 318 | 200.0 | 190.0 |
| 15 | 43.31315 | 6 | 336 | 200.0 | 180.0 | 40 | 34.68403 | 8 | 336 | 200.0 | 180.0 |
| 16 | 43.22659 | 3 | 302 | 300.0 | 190.0 | 41 | 34.52754 | 5 | 17 | 200.0 | 90.0 |
| 17 | 42.65503 | 4 | 286 | 300.0 | 200.0 | 42 | 34.35528 | 4 | 302 | 200.0 | 210.0 |
| 18 | 42.37495 | 6 | 196 | 200.0 | 90.0 | 43 | 34.26497 | 5 | 139 | 300.0 | 90.0 |
| 19 | 42.25999 | 6 | 319 | 200.0 | 200.0 | 44 | 33.98637 | 6 | 319 | 300.0 | 200.0 |
| 20 | 41.92215 | 6 | 17 | 400.0 | 110.0 | 45 | 33.95519 | 5 | 17 | 400.0 | 100.0 |
| 21 | 41.27127 | 5 | 286 | 400.0 | 200.0 | 46 | 33.37597 | 4 | 100 | 300.0 | 200.0 |
| 22 | 40.00658 | 6 | 139 | 200.0 | 90.0 | 47 | 32.92441 | 6 | 139 | 300.0 | 90.0 |
| 23 | 39.35655 | 2 | 18 | 200.0 | 140.0 | 48 | 32.72742 | 2 | 302 | 200.0 | 180.0 |
| 24 | 39.32617 | 5 | 100 | 400.0 | 200.0 | 49 | 32.58770 | 5 | 302 | 200.0 | 190.0 |
| 25 | 38.71727 | 4 | 17 | 200.0 | 120.0 | 50 | 32.46196 | 4 | 139 | 200.0 | 60.0 |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* 50 MAXIMUM 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CON | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) | RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) |
|------|----------|------|-----|------------------------------|---|------|----------|------|-----|------------------------------|---|
| 1 | 29.00511 | 1 | 302 | 200.0 | 180.0 | 26 | 12.21690 | 1 | 302 | 400.0 | 190.0 |
| 2 | 23.58575 | 1 | 302 | 300.0 | 180.0 | 27 | 12.04032 | 1 | 286 | 200.0 | 180.0 |
| 3 | 22.94646 | 1 | 318 | 200.0 | 190.0 | 28 | 11.91354 | 1 | 17 | 200.0 | 120.0 |
| 4 | 22.76950 | 1 | 336 | 200.0 | 180.0 | 29 | 11.40541 | 1 | 17 | 300.0 | 100.0 |
| 5 | 20.92275 | 1 | 302 | 200.0 | 190.0 | 30 | 11.31197 | 1 | 302 | 300.0 | 200.0 |
| 6 | 18.43918 | 1 | 318 | 300.0 | 190.0 | 31 | 11.23217 | 1 | 336 | 200.0 | 170.0 |
| 7 | 18.32189 | 1 | 336 | 300.0 | 180.0 | 32 | 11.00664 | 1 | 302 | 1200.0 | 180.0 |
| 8 | 17.18555 | 1 | 302 | 400.0 | 180.0 | 33 | 10.94446 | 1 | 100 | 200.0 | 210.0 |
| 9 | 16.79954 | 1 | 18 | 200.0 | 140.0 | 34 | 10.87209 | 1 | 302 | 1400.0 | 180.0 |
| 10 | 16.77360 | 1 | 302 | 300.0 | 190.0 | 35 | 10.78212 | 1 | 100 | 200.0 | 200.0 |
| 11 | 16.29657 | 1 | 17 | 200.0 | 110.0 | 36 | 10.63631 | 1 | 302 | 900.0 | 180.0 |
| 12 | 15.54231 | 1 | 318 | 200.0 | 200.0 | 37 | 10.57623 | 1 | 18 | 400.0 | 140.0 |
| 13 | 15.14085 | 1 | 286 | 200.0 | 200.0 | 38 | 10.52574 | 1 | 336 | 200.0 | 190.0 |
| 14 | 14.32858 | 1 | 17 | 200.0 | 100.0 | 39 | 10.43273 | 1 | 100 | 300.0 | 200.0 |
| 15 | 14.21076 | 1 | 19 | 300.0 | 140.0 | 40 | 10.37307 | 1 | 302 | 1700.0 | 180.0 |
| 16 | 14.16967 | 1 | 302 | 200.0 | 200.0 | 41 | 10.28287 | 1 | 302 | 800.0 | 180.0 |
| 17 | 13.49360 | 1 | 196 | 200.0 | 90.0 | 42 | 10.26940 | 1 | 196 | 400.0 | 90.0 |
| 18 | 13.13325 | 1 | 318 | 200.0 | 180.0 | 43 | 10.19351 | 1 | 100 | 300.0 | 150.0 |
| 19 | 13.09016 | 1 | 336 | 400.0 | 180.0 | 44 | 10.14131 | 1 | 286 | 200.0 | 190.0 |
| 20 | 13.06520 | 1 | 318 | 400.0 | 190.0 | 45 | 10.07382 | 1 | 318 | 300.0 | 180.0 |
| 21 | 13.00141 | 1 | 17 | 300.0 | 110.0 | 46 | 9.77734 | 1 | 302 | 700.0 | 180.0 |
| 22 | 12.58431 | 1 | 196 | 300.0 | 90.0 | 47 | 9.55970 | 1 | 100 | 300.0 | 210.0 |
| 23 | 12.57746 | 1 | 100 | 200.0 | 150.0 | 48 | 9.41634 | 1 | 17 | 400.0 | 110.0 |
| 24 | 12.41102 | 1 | 286 | 300.0 | 200.0 | 49 | 9.27353 | 1 | 139 | 200.0 | 90.0 |
| 25 | 12.33465 | 1 | 318 | 300.0 | 200.0 | 50 | 9.24403 | 1 | 17 | 300.0 | 120.0 |

| | |
|---|----------------------|
| CALCULATE (CONCENTRATION=1, DEPOSITION=2) | ISW(1) = 1 |
| RECEPTOR GRID SYSTEM (RECTANGULAR=1 OR 3, POLAR=2 OR 4) | ISW(2) = 4 |
| DISCRETE RECEPTOR SYSTEM (RECTANGULAR=1, POLAR=2) | ISW(3) = 2 |
| TERRAIN ELEVATIONS ARE READ (YES=1, NO=0) | ISW(4) = 0 |
| CALCULATIONS ARE WRITTEN TO TAPE (YES=1, NO=0) | ISW(5) = 0 |
| LIST ALL INPUT DATA (NO=0, YES=1, MET DATA ALSO=0) | ISW(6) = 1 |
| | |
| COMPUTE AVERAGE CONCENTRATION (OR TOTAL DEPOSITION) | |
| WITH THE FOLLOWING TIME PERIODS: | |
| HOURLY (YES=1, NO=0) | ISW(7) = 0 |
| 2-HOUR (YES=1, NO=0) | ISW(8) = 0 |
| 3-HOUR (YES=1, NO=0) | ISW(9) = 1 |
| 4-HOUR (YES=1, NO=0) | ISW(10) = 0 |
| 6-HOUR (YES=1, NO=0) | ISW(11) = 0 |
| 8-HOUR (YES=1, NO=0) | ISW(12) = 0 |
| 12-HOUR (YES=1, NO=0) | ISW(13) = 0 |
| 24-HOUR (YES=1, NO=0) | ISW(14) = 1 |
| PRINT "N"-DAY TABLE(S) (YES=1, NO=0) | ISW(15) = 1 |
| | |
| PRINT THE FOLLOWING TYPES OF TABLES WHOSE TIME PERIODS ARE | |
| SPECIFIED BY ISW(7) THROUGH ISW(14): | |
| DAILY TABLES (YES=1, NO=0) | ISW(16) = 0 |
| HIGHEST & SECOND HIGHEST TABLES (YES=1, NO=0) | ISW(17) = 1 |
| MAXIMUM 50 TABLES (YES=1, NO=0) | ISW(18) = 1 |
| METEOROLOGICAL DATA INPUT METHOD (PRE-PROCESSED=1, CARD=2) | ISW(19) = 1 |
| RURAL-URBAN OPTION (RURAL=0, URBAN MODE 1=1, URBAN MODE 2=2) | ISW(20) = 0 |
| WIND PROFILE EXPONENT VALUES (DEFAULTS=1, USER ENTERS=2,3) | ISW(21) = 1 |
| VERTICAL POT. TEMP. GRADIENT VALUES (DEFAULTS=1, USER ENTERS=2,3) | ISW(22) = 1 |
| SCALE EMISSION RATES FOR ALL SOURCES (NO=0, YES=1) | ISW(23) = 0 |
| PROGRAM CALCULATES FINAL PLUME RISE ONLY (YES=1, NO=2) | ISW(24) = 2 |
| PROGRAM ADJUSTS ALL STACK HEIGHTS FOR DOWNWASH (YES=2, NO=1) | ISW(25) = 1 |
| | |
| INPUT SPECIAL DIRECTION-DEPENDENT BUILDING DIMENSIONS (YES=1, NO=0) | ISW(26) = 0 |
| | |
| OMIT TABLES FOR HOURLY CONCENTRATIONS (YES=1, NO=0) | ISW(27) = 0 |
| | |
| USEPA ADJUSTMENT FOR CALM HOURS (YES=1, NO=0) | ISW(28) = 1 |
| | |
| NUMBER OF INPUT SOURCES | NSOURC = 1 |
| NUMBER OF SOURCE GROUPS (=0, ALL SOURCES) | NGROUP = 0 |
| TIME PERIOD INTERVAL TO BE PRINTED (=0, ALL INTERVALS) | IPERD = 0 |
| NUMBER OF X (RANGE) GRID VALUES | NXPNTS = 2 |
| NUMBER OF Y (THETA) GRID VALUES | NYPNTS = 36 |
| NUMBER OF DISCRETE RECEPTORS | NXWYPT = 0 |
| SOURCE EMISSION RATE UNITS CONVERSION FACTOR | TK = 1.0000E+07 |
| ENTRAINMENT COEFFICIENT FOR UNSTABLE ATMOSPHERE | BETA1 = 0.600 |
| ENTRAINMENT COEFFICIENT FOR STABLE ATMOSPHERE | BETA2 = 0.600 |
| HEIGHT ABOVE GROUND AT WHICH WIND SPEED WAS MEASURED | ZR = 10.00 METERS |
| LOGICAL UNIT NUMBER OF METEOROLOGICAL DATA | IMET = 9 |
| DECAY COEFFICIENT FOR PHYSICAL OR CHEMICAL DEPLETION | DECAY = 0.000000E+00 |
| SURFACE STATION NO. | ISS = 12815 |
| YEAR OF SURFACE DATA | ISY = 76 |
| UPPER AIR STATION NO. | IUS = 12842 |
| YEAR OF UPPER AIR DATA | IUY = 76 |
| ALLOCATED DATA STORAGE | LIMIT = 43500 WORDS |

IST-8

1976 - NRG ONLY - SO₂
Radius of Influence Check

*** RANGES OF POLAR GRID SYSTEM ***
(METERS)

6000. 0. 9000. 0.

*** RADIAL ANGLES OF POLAR GRID SYSTEM ***

(DEGREES)

| | | | | | | | | | |
|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| 10. 0. | 20. 0. | 30. 0. | 40. 0. | 50. 0. | 60. 0. | 70. 0. | 80. 0. | 90. 0. | 100. 0. |
| 110. 0. | 120. 0. | 130. 0. | 140. 0. | 150. 0. | 160. 0. | 170. 0. | 180. 0. | 190. 0. | 200. 0. |
| 210. 0. | 220. 0. | 230. 0. | 240. 0. | 250. 0. | 260. 0. | 270. 0. | 280. 0. | 290. 0. | 300. 0. |
| 310. 0. | 320. 0. | 330. 0. | 340. 0. | 350. 0. | 360. 0. | | | | |

*** SOURCE DATA ***

| SOURCE NUMBER | P | K | T W Y A NUMBER PART E E CATS. | EMISSION RATE TYPE=0,1 (GRAMS/SEC) TYPE=2 (GRAMS/SEC) *PER METER**2 | X (METERS) | Y (METERS) | BASE ELEV. (METERS) | HEIGHT (METERS) | TEMP. | EXIT VEL. | | | BLDG. HEIGHT (METERS) | BLDG. LENGTH (METERS) | BLDG. WIDTH (METERS) |
|---------------|---|---|--|--|---------------|---------------|---------------------------|--------------------|--|--|--|--|-----------------------------|-----------------------------|----------------------------|
| | | | | | | | | | TYPE=0 (DEG. K); VERT. DIM TYPE=1 (METERS) | TYPE=0 (M/SEC); HORIZ. DIM TYPE=1,2 (METERS) | TYPE=0 DIAMETER TYPE=0 (METERS) | TYPE=0 HEIGHT TYPE=0 (METERS) | | | |
| 101 | 0 | 0 | 0 | 0.15800E+02 | 0.0 | 0.0 | 0.0 | 39.10 | 450.00 | 20.00 | 1.83 | 22.00 | 38.10 | 19.80 | |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* 365-DAY AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 0.49648 AND OCCURRED AT (6000.0, 180.0) *

DIRECTION / RANGE (METERS)
(DEGREES) / 6000.0 9000.0

| | | |
|---------|---------|---------|
| 360.0 / | 0.34725 | 0.26847 |
| 350.0 / | 0.19022 | 0.14468 |
| 340.0 / | 0.24328 | 0.18139 |
| 330.0 / | 0.16668 | 0.11977 |
| 320.0 / | 0.20405 | 0.15258 |
| 310.0 / | 0.20986 | 0.15397 |
| 300.0 / | 0.27921 | 0.22007 |
| 290.0 / | 0.19884 | 0.14574 |
| 280.0 / | 0.16177 | 0.11553 |
| 270.0 / | 0.28036 | 0.22040 |
| 260.0 / | 0.19878 | 0.15301 |
| 250.0 / | 0.22014 | 0.17415 |
| 240.0 / | 0.26654 | 0.20287 |
| 230.0 / | 0.30100 | 0.23141 |
| 220.0 / | 0.22882 | 0.17629 |
| 210.0 / | 0.22848 | 0.17788 |
| 200.0 / | 0.28877 | 0.21797 |
| 190.0 / | 0.26460 | 0.19261 |
| 180.0 / | 0.49648 | 0.36641 |
| 170.0 / | 0.28383 | 0.20659 |
| 160.0 / | 0.24713 | 0.18494 |
| 150.0 / | 0.16286 | 0.11450 |
| 140.0 / | 0.16411 | 0.10913 |
| 130.0 / | 0.17537 | 0.11927 |
| 120.0 / | 0.18952 | 0.13813 |
| 110.0 / | 0.16273 | 0.12445 |
| 100.0 / | 0.15613 | 0.11565 |
| 90.0 / | 0.19684 | 0.14281 |
| 80.0 / | 0.11445 | 0.07856 |
| 70.0 / | 0.13961 | 0.10715 |
| 60.0 / | 0.17559 | 0.13058 |
| 50.0 / | 0.17912 | 0.12809 |
| 40.0 / | 0.14470 | 0.10479 |
| 30.0 / | 0.12116 | 0.08617 |
| 20.0 / | 0.16246 | 0.11384 |
| 10.0 / | 0.18741 | 0.13706 |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* 50 MAXIMUM 3-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) | RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) |
|------|----------|------|-----|------------------------------|---|------|----------|------|-----|------------------------------|---|
| 1 | 14.25965 | 2 | 311 | 6000.0 | 160.0 | 26 | 10.52341 | 7 | 292 | 5000.0 | 170.0 |
| 2 | 13.58739 | 1 | 22 | 5000.0 | 120.0 | 27 | 10.50143 | 2 | 182 | 9000.0 | 360.0 |
| 3 | 13.45133 | 1 | 297 | 6000.0 | 180.0 | 28 | 10.45674 | 1 | 352 | 6000.0 | 140.0 |
| 4 | 13.36725 | 1 | 60 | 6000.0 | 230.0 | 29 | 10.44907 | 6 | 250 | 6000.0 | 70.0 |
| 5 | 12.87045 | 1 | 345 | 6000.0 | 230.0 | 30 | 10.39721 | 2 | 294 | 6000.0 | 340.0 |
| 6 | 12.65320 | 3 | 84 | 6000.0 | 230.0 | 31 | 10.39526 | 6 | 335 | 6000.0 | 180.0 |
| 7 | 12.60526 | 7 | 93 | 6000.0 | 100.0 | 32 | 10.39176 | 5 | 340 | 6000.0 | 180.0 |
| 8 | 12.08048 | 8 | 117 | 6000.0 | 90.0 | 33 | 10.35857 | 7 | 365 | 5000.0 | 310.0 |
| 9 | 11.96183 | 7 | 114 | 6000.0 | 270.0 | 34 | 10.24155 | 7 | 252 | 6000.0 | 260.0 |
| 10 | 11.74701 | 2 | 311 | 9000.0 | 160.0 | 35 | 10.23234 | 2 | 78 | 5000.0 | 180.0 |
| 11 | 11.55616 | 7 | 285 | 6000.0 | 180.0 | 36 | 10.19819 | 7 | 296 | 6000.0 | 180.0 |
| 12 | 11.43598 | 2 | 257 | 5000.0 | 230.0 | 37 | 10.19242 | 7 | 114 | 9000.0 | 270.0 |
| 13 | 11.43100 | 7 | 361 | 6000.0 | 100.0 | 38 | 10.17455 | 1 | 214 | 6000.0 | 360.0 |
| 14 | 11.42082 | 1 | 310 | 6000.0 | 130.0 | 39 | 10.16334 | 1 | 87 | 5000.0 | 320.0 |
| 15 | 11.21036 | 1 | 22 | 9000.0 | 120.0 | 40 | 10.15709 | 4 | 361 | 6000.0 | 90.0 |
| 16 | 11.07511 | 1 | 124 | 6000.0 | 110.0 | 41 | 10.15144 | 2 | 136 | 6000.0 | 310.0 |
| 17 | 11.02542 | 3 | 19 | 6000.0 | 170.0 | 42 | 10.13893 | 1 | 293 | 6000.0 | 200.0 |
| 18 | 11.02086 | 1 | 297 | 9000.0 | 180.0 | 43 | 10.03929 | 8 | 117 | 9000.0 | 90.0 |
| 19 | 11.01629 | 1 | 345 | 9000.0 | 230.0 | 44 | 10.00887 | 1 | 69 | 6000.0 | 360.0 |
| 20 | 10.91674 | 2 | 305 | 6000.0 | 360.0 | 45 | 9.99446 | 7 | 93 | 9000.0 | 100.0 |
| 21 | 10.84643 | 1 | 305 | 6000.0 | 360.0 | 46 | 9.89294 | 7 | 252 | 9000.0 | 260.0 |
| 22 | 10.84016 | 1 | 257 | 6000.0 | 240.0 | 47 | 9.88493 | 2 | 23 | 9000.0 | 160.0 |
| 23 | 10.74021 | 1 | 60 | 9000.0 | 230.0 | 48 | 9.87177 | 1 | 305 | 5000.0 | 160.0 |
| 24 | 10.73720 | 6 | 344 | 6000.0 | 230.0 | 49 | 9.86861 | 8 | 270 | 9000.0 | 300.0 |
| 25 | 10.54633 | 7 | 234 | 6000.0 | 10.0 | 50 | 9.86367 | 2 | 339 | 5000.0 | 170.0 |

*** NRC/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* HIGHEST 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *
* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 4.64205 AND OCCURRED AT (6000.0, 120.0) *

| DIRECTION / (DEGREES) / | RANGE (METERS) | |
|----------------------------|--------------------|------------------|
| | 6000.0 | 9000.0 |
| 350.0 / | 3.57353 (333, 1) | 2.71508 (333, 1) |
| 350.0 / | 2.16751 (48, 1) | 1.67225 (3, 1) |
| 340.0 / | 2.42306 (149, 1) | 1.96355 (48, 1) |
| 330.0 / | 2.05388 (360, 1) | 1.31836 (360, 1) |
| 320.0 / | 2.79323 (135, 1) | 2.17208 (135, 1) |
| 310.0 / | 4.39253 (136, 1) | 2.88189 (136, 1) |
| 300.0 / | 3.34212 (25, 1) | 3.06043 (25, 1) |
| 290.0 / | 2.21534 (120, 1) | 1.50437 (120, 1) |
| 280.0 / | 2.17795 (169, 1) | 1.61689 (169, 1) |
| 270.0 / | 2.50652 (148, 1) | 2.03458 (148, 1) |
| 260.0 / | 2.29451 (252, 1) | 1.99493 (252, 1) |
| 250.0 / | 2.13417 (141, 1) | 1.87191 (108, 1) |
| 240.0 / | 2.89828 (256, 1) | 2.29748 (256, 1) |
| 230.0 / | 3.22551 (130, 1) | 2.31325 (240, 1) |
| 220.0 / | 2.03466 (232, 1) | 1.45505 (104, 1) |
| 210.0 / | 2.77485 (98, 1) | 1.83163 (98, 1) |
| 200.0 / | 3.56692 (57, 1) | 2.31866 (57, 1) |
| 190.0 / | 3.45581 (318, 1) | 2.14625 (292, 1) |
| 180.0 / | 4.26548 (340, 1) | 2.79808 (340, 1) |
| 170.0 / | 3.30803 (19, 1) | 2.35795 (19, 1) |
| 160.0 / | 2.79719 (306, 1) | 2.42209 (23, 1) |
| 150.0 / | 2.34423 (327, 1) | 1.54536 (327, 1) |
| 140.0 / | 2.99670 (18, 1) | 1.82881 (18, 1) |
| 130.0 / | 2.53627 (310, 1) | 1.66819 (310, 1) |
| 120.0 / | 4.64205 (22, 1) ✓ | 3.51909 (22, 1) |
| 110.0 / | 2.79761 (17, 1) | 1.95085 (17, 1) |
| 100.0 / | 2.50451 (259, 1) | 2.09998 (259, 1) |
| 90.0 / | 2.98085 (197, 1) | 2.06531 (117, 1) |
| 80.0 / | 1.74673 (132, 1) | 1.38339 (132, 1) |
| 70.0 / | 2.68304 (350, 1) | 1.84717 (198, 1) |
| 60.0 / | 2.83925 (233, 1) | 2.09021 (233, 1) |
| 50.0 / | 2.46052 (233, 1) | 1.64917 (249, 1) |
| 40.0 / | 2.46858 (355, 1) | 1.58907 (355, 1) |
| 30.0 / | 1.60164 (123, 1) | 1.58254 (123, 1) |
| 20.0 / | 2.04796 (363, 1) | 1.53807 (333, 1) |
| 10.0 / | 2.21480 (234, 1) | 1.95113 (234, 1) |

1.5

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* SECOND HIGHEST 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *
* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 3.72917 AND OCCURRED AT (6000.0, 180.0) *

| DIRECTION / (DEGREES) / | RANGE (METERS) | |
|----------------------------|------------------|------------------|
| | 6000.0 | 9000.0 |
| 360.0 / | 3.21406 (363, 1) | 2.59259 (363, 1) |
| 350.0 / | 2.14617 (27, 1) | 1.47264 (27, 1) |
| 340.0 / | 2.41154 (331, 1) | 1.77245 (149, 1) |
| 330.0 / | 1.74676 (292, 1) | 1.17205 (173, 1) |
| 320.0 / | 2.27957 (47, 1) | 1.59051 (324, 1) |
| 310.0 / | 3.14337 (168, 1) | 2.40317 (168, 1) |
| 300.0 / | 2.83203 (80, 1) | 2.32681 (80, 1) |
| 290.0 / | 1.83255 (345, 1) | 1.43087 (168, 1) |
| 280.0 / | 1.85782 (269, 1) | 1.47105 (269, 1) |
| 270.0 / | 2.40070 (290, 1) | 1.98670 (290, 1) |
| 260.0 / | 1.99647 (59, 1) | 1.53150 (241, 1) |
| 250.0 / | 1.95372 (108, 1) | 1.70442 (175, 1) |
| 240.0 / | 2.55230 (257, 1) | 1.86524 (257, 1) |
| 230.0 / | 2.67475 (344, 1) | 2.27786 (130, 1) |
| 220.0 / | 1.89925 (104, 1) | 1.39081 (204, 1) |
| 210.0 / | 1.87398 (125, 1) | 1.40688 (125, 1) |
| 200.0 / | 2.88285 (292, 1) | 1.91746 (279, 1) |
| 190.0 / | 3.26866 (292, 1) | 2.10249 (318, 1) |
| 180.0 / | 3.72917 (302, 1) | 2.67445 (328, 1) |
| 170.0 / | 2.49492 (15, 1) | 1.66767 (285, 1) |
| 160.0 / | 2.77197 (309, 1) | 2.32918 (309, 1) |
| 150.0 / | 1.75065 (28, 1) | 1.34654 (351, 1) |
| 140.0 / | 2.39453 (301, 1) | 1.80085 (301, 1) |
| 130.0 / | 2.37958 (362, 1) | 1.63676 (351, 1) |
| 120.0 / | 2.60150 (326, 1) | 1.68516 (39, 1) |
| 110.0 / | 2.49037 (300, 1) | 1.80478 (300, 1) |
| 100.0 / | 2.46457 (16, 1) | 1.75243 (300, 1) |
| 90.0 / | 2.84714 (117, 1) | 2.02381 (197, 1) |
| 80.0 / | 1.54290 (122, 1) | 0.98342 (33, 1) |
| 70.0 / | 2.23710 (198, 1) | 1.81103 (350, 1) |
| 60.0 / | 2.45756 (195, 1) | 1.82854 (195, 1) |
| 50.0 / | 2.03289 (116, 1) | 1.63239 (233, 1) |
| 40.0 / | 2.36430 (299, 1) | 1.46435 (299, 1) |
| 30.0 / | 1.52434 (299, 1) | 0.99999 (183, 1) |
| 20.0 / | 1.85743 (333, 1) | 1.35264 (363, 1) |
| 10.0 / | 2.10394 (214, 1) | 1.75657 (214, 1) |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* 50 MAXIMUM 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y (METERS) OR DIRECTION (DEGREES) | RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y (METERS) OR DIRECTION (DEGREES) |
|------|---------|------|-----|------------------------------|--|------|---------|------|-----|------------------------------|--|
| 1 | 4.64205 | 1 | 22 | 6000.0 | 120.0 | 26 | 3.06043 | 1 | 25 | 7000.0 | 300.0 |
| 2 | 4.39253 | 1 | 136 | 6000.0 | 310.0 | 27 | 3.03810 | 1 | 231 | 6000.0 | 180.0 |
| 3 | 4.26548 | 1 | 340 | 6000.0 | 180.0 | 28 | 2.99670 | 1 | 18 | 6000.0 | 140.0 |
| 4 | 3.72717 | 1 | 302 | 6000.0 | 180.0 | 29 | 2.98085 | 1 | 197 | 6000.0 | 90.0 |
| 5 | 3.71212 | 1 | 338 | 6000.0 | 180.0 | 30 | 2.93445 | 1 | 265 | 6000.0 | 360.0 |
| 6 | 3.58692 | 1 | 57 | 6000.0 | 200.0 | 31 | 2.90006 | 1 | 4 | 6000.0 | 180.0 |
| 7 | 3.57353 | 1 | 333 | 6000.0 | 360.0 | 32 | 2.89828 | 1 | 256 | 6000.0 | 240.0 |
| 8 | 3.53203 | 1 | 335 | 6000.0 | 180.0 | 33 | 2.88285 | 1 | 292 | 6000.0 | 200.0 |
| 9 | 3.51909 | 1 | 22 | 7000.0 | 120.0 | 34 | 2.88218 | 1 | 359 | 6000.0 | 180.0 |
| 10 | 3.45581 | 1 | 318 | 6000.0 | 190.0 | 35 | 2.88189 | 1 | 136 | 7000.0 | 310.0 |
| 11 | 3.37168 | 1 | 322 | 6000.0 | 180.0 | 36 | 2.85734 | 1 | 358 | 6000.0 | 180.0 |
| 12 | 3.34698 | 1 | 285 | 6000.0 | 180.0 | 37 | 2.84714 | 1 | 117 | 6000.0 | 90.0 |
| 13 | 3.34212 | 1 | 25 | 6000.0 | 300.0 | 38 | 2.83925 | 1 | 233 | 6000.0 | 60.0 |
| 14 | 3.30803 | 1 | 19 | 6000.0 | 170.0 | 39 | 2.83203 | 1 | 80 | 6000.0 | 300.0 |
| 15 | 3.26856 | 1 | 292 | 6000.0 | 190.0 | 40 | 2.83092 | 1 | 296 | 6000.0 | 180.0 |
| 16 | 3.22551 | 1 | 130 | 6000.0 | 230.0 | 41 | 2.79808 | 1 | 340 | 7000.0 | 180.0 |
| 17 | 3.21406 | 1 | 363 | 5000.0 | 360.0 | 42 | 2.79761 | 1 | 17 | 5000.0 | 110.0 |
| 18 | 3.16394 | 1 | 336 | 6000.0 | 180.0 | 43 | 2.79719 | 1 | 306 | 6000.0 | 160.0 |
| 19 | 3.14337 | 1 | 168 | 5000.0 | 310.0 | 44 | 2.79323 | 1 | 135 | 5000.0 | 320.0 |
| 20 | 3.12673 | 1 | 316 | 6000.0 | 180.0 | 45 | 2.77913 | 1 | 284 | 6000.0 | 180.0 |
| 21 | 3.12264 | 1 | 339 | 5000.0 | 180.0 | 46 | 2.77485 | 1 | 95 | 5000.0 | 210.0 |
| 22 | 3.11840 | 1 | 329 | 6000.0 | 180.0 | 47 | 2.77197 | 1 | 309 | 6000.0 | 160.0 |
| 23 | 3.11267 | 1 | 328 | 5000.0 | 180.0 | 48 | 2.73548 | 1 | 54 | 5000.0 | 180.0 |
| 24 | 3.10807 | 1 | 214 | 6000.0 | 360.0 | 49 | 2.72760 | 1 | 337 | 6000.0 | 160.0 |
| 25 | 3.06727 | 1 | 158 | 6000.0 | 190.0 | 50 | 2.72040 | 1 | 305 | 6000.0 | 360.0 |

| | |
|---|------------|
| CALCULATE (CONCENTRATION=1, DEPOSITION=2) | ISW(1) = 1 |
| RECEPTOR GRID SYSTEM (RECTANGULAR=1 OR 3, POLAR=2 OR 4) | ISW(2) = 4 |
| DISCRETE RECEPTOR SYSTEM (RECTANGULAR=1, POLAR=2) | ISW(3) = 2 |
| TERRAIN ELEVATIONS ARE READ (YES=1, NO=0) | ISW(4) = 0 |
| CALCULATIONS ARE WRITTEN TO TAPE (YES=1, NO=0) | ISW(5) = 0 |
| LIST ALL INPUT DATA (NO=0, YES=1, MET DATA ALSO=2) | ISW(6) = 1 |

| | |
|---|-------------|
| COMPUTE AVERAGE CONCENTRATION (OR TOTAL DEPOSITION) WITH THE FOLLOWING TIME PERIODS: | |
| HOURLY (YES=1, NO=0) | ISW(7) = 0 |
| 2-HOUR (YES=1, NO=0) | ISW(8) = 0 |
| 3-HOUR (YES=1, NO=0) | ISW(9) = 1 |
| 4-HOUR (YES=1, NO=0) | ISW(10) = 0 |
| 6-HOUR (YES=1, NO=0) | ISW(11) = 0 |
| 8-HOUR (YES=1, NO=0) | ISW(12) = 0 |
| 12-HOUR (YES=1, NO=0) | ISW(13) = 0 |
| 24-HOUR (YES=1, NO=0) | ISW(14) = 1 |
| PRINT "N"-DAY TABLE(S) (YES=1, NO=0) | ISW(15) = 1 |

| | |
|--|-------------|
| PRINT THE FOLLOWING TYPES OF TABLES WHOSE TIME PERIODS ARE SPECIFIED BY ISW(7) THROUGH ISW(14): | |
| DAILY TABLES (YES=1, NO=0) | ISW(16) = 0 |
| HIGHEST & SECOND HIGHEST TABLES (YES=1, NO=0) | ISW(17) = 1 |
| MAXIMUM 50 TABLES (YES=1, NO=0) | ISW(18) = 1 |
| METEOROLOGICAL DATA INPUT METHOD (PRE-PROCESSED=1, CARD=2) | ISW(19) = 1 |
| RURAL-URBAN OPTION (RURAL=0, URBAN MODE 1=1, URBAN MODE 2=2) | ISW(20) = 0 |
| WIND PROFILE EXPONENT VALUES (DEFAULTS=1, USER ENTERS=2, 3) | ISW(21) = 1 |
| VERTICAL PDY TEMP. GRADIENT VALUES (DEFAULTS=1, USER ENTERS=2, 3) | ISW(22) = 1 |
| SCALE EMISSION RATES FOR ALL SOURCES (NO=0, YES=1) | ISW(23) = 0 |
| PROGRAM CALCULATES FINAL PLUME RISE ONLY (YES=1, NO=2) | ISW(24) = 2 |
| PROGRAM ADJUSTS ALL STACK HEIGHTS FOR DOWNWASH (YES=2, NO=1) | ISW(25) = 1 |

| | |
|---|-------------|
| INPUT SPECIAL DIRECTION-DEPENDENT BUILDING DIMENSIONS (YES=1, NO=0) | ISW(26) = 0 |
|---|-------------|

| | |
|---|-------------|
| OMIT TABLES FOR HOURLY CONCENTRATIONS (YES=1, NO=0) | ISW(27) = 0 |
|---|-------------|

| | |
|---|-------------|
| USEPA ADJUSTMENT FOR CALM HOURS (YES=1, NO=0) | ISW(28) = 1 |
|---|-------------|

| | |
|--|----------------------|
| NUMBER OF INPUT SOURCES | NSOURC = 1 |
| NUMBER OF SOURCE GROUPS (=0, ALL SOURCES) | NGROUP = 0 |
| TIME PERIOD INTERVAL TO BE PRINTED (=0, ALL INTERVALS) | IPERD = 0 |
| NUMBER OF X (RANGE) GRID VALUES | NXPNTS = 5 |
| NUMBER OF Y (THETA) GRID VALUES | NYPNTS = 36 |
| NUMBER OF DISCRETE RECEPTORS | NXWYPT = 0 |
| SOURCE EMISSION RATE UNITS CONVERSION FACTOR | TK = 10000E+07 |
| ENTRAINMENT COEFFICIENT FOR UNSTABLE ATMOSPHERE | BETA1 = 0.600 |
| ENTRAINMENT COEFFICIENT FOR STABLE ATMOSPHERE | BETA2 = 0.600 |
| HEIGHT ABOVE GROUND AT WHICH WIND SPEED WAS MEASURED | ZR = 10.00 METERS |
| LOGICAL UNIT NUMBER OF METEOROLOGICAL DATA | IMET = 9 |
| DECAY COEFFICIENT FOR PHYSICAL OR CHEMICAL DEPLETION | DECAY = 0.000000E+00 |
| SURFACE STATION NO. | ISS = 12815 |
| YEAR OF SURFACE DATA | ISY = 77 |
| UPPER AIR STATION NO. | IUS = 12842 |
| YEAR OF UPPER AIR DATA | IUY = 77 |
| ALLOCATED DATA STORAGE | LIMIT = 43500 WORDS |

IST-9

1977 - NRG ONLY - SO2

*** RANGES OF POLAR GRID SYSTEM ***
(METERS)

500.0, 1000.0, 1500.0, 2000.0, 2500.0,

*** RADIAL ANGLES OF POLAR GRID SYSTEM ***

(DEGREES)

10.0, 20.0, 30.0, 40.0, 50.0, 60.0, 70.0, 80.0, 90.0, 100.0,
110.0, 120.0, 130.0, 140.0, 150.0, 160.0, 170.0, 180.0, 190.0, 200.0,
210.0, 220.0, 230.0, 240.0, 250.0, 260.0, 270.0, 280.0, 290.0, 300.0,
310.0, 320.0, 330.0, 340.0, 350.0, 360.0,

*** SOURCE DATA ***

| SOURCE NUMBER | P | K | T W Y A NUMBER PART. | E E CATS | EMISSION RATE | X | Y | BASE ELEV. | HEIGHT | TEMP. | EXIT VEL. | BLDG HEIGHT | BLDG. LENGTH | BLDG. WIDTH | |
|---------------|---|---|----------------------------|-------------|--|----------|----------|---------------|----------|---------------------|----------------------|--------------------|-----------------|----------------|-------|
| | | | | | TYPE=0, 1 (GRAMS/SEC) | | | | | TYPE=0 (DEG. K); | TYPE=0 (M/SEC); | | | | |
| NUMBER | | | | | TYPE=2 (GRAMS/SEC) *PER METER**2 | (METERS) | (METERS) | (METERS) | (METERS) | VERT. DIM TYPE=1 | HRZ. DIM TYPE=1.2 | DIAMETER TYPE=0 | TYPE=0 | TYPE=0 | |
| 101 | 0 | 0 | 0 | | 0.15800E+02 | 0.0 | 0.0 | 0.0 | 38.10 | 450.00 | 20.00 | 1.83 | 22.00 | 38.10 | 19.80 |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* 365-DAY AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 0.80863 AND OCCURRED AT (1500.0, 360 0) *

| DIRECTION / (DEGREES) / | RANGE (METERS) | | | | |
|----------------------------|----------------|---------|-----------|---------|---------|
| | 500.0 | 1000.0 | 1500.0 | 2000.0 | 2500.0 |
| 360.0 / | 0.57041 | 0.79631 | 0.80863 ✓ | 0.74243 | 0.67011 |
| 350.0 / | 0.32688 | 0.44911 | 0.44161 | 0.39592 | 0.35170 |
| 340.0 / | 0.26722 | 0.37899 | 0.38159 | 0.35052 | 0.31776 |
| 330.0 / | 0.22435 | 0.33517 | 0.32823 | 0.29544 | 0.26438 |
| 320.0 / | 0.24942 | 0.37463 | 0.37610 | 0.34214 | 0.30571 |
| 310.0 / | 0.34686 | 0.47921 | 0.47110 | 0.42287 | 0.37440 |
| 300.0 / | 0.44385 | 0.58850 | 0.57867 | 0.51859 | 0.45822 |
| 290.0 / | 0.30274 | 0.39601 | 0.37729 | 0.33018 | 0.28696 |
| 280.0 / | 0.35365 | 0.47958 | 0.47002 | 0.41796 | 0.36657 |
| 270.0 / | 0.53259 | 0.73821 | 0.75734 | 0.69807 | 0.63033 |
| 260.0 / | 0.35465 | 0.48794 | 0.48162 | 0.43292 | 0.38508 |
| 250.0 / | 0.32956 | 0.45057 | 0.45695 | 0.42131 | 0.38231 |
| 240.0 / | 0.39757 | 0.53890 | 0.56719 | 0.53522 | 0.49262 |
| 230.0 / | 0.38028 | 0.51689 | 0.54953 | 0.52683 | 0.49355 |
| 220.0 / | 0.24146 | 0.33201 | 0.35780 | 0.34553 | 0.32579 |
| 210.0 / | 0.22712 | 0.30195 | 0.33418 | 0.33093 | 0.31695 |
| 200.0 / | 0.21966 | 0.28455 | 0.30942 | 0.30149 | 0.28390 |
| 190.0 / | 0.22817 | 0.29151 | 0.30527 | 0.28880 | 0.26591 |
| 180.0 / | 0.41889 | 0.54610 | 0.61180 | 0.60513 | 0.57374 |
| 170.0 / | 0.28586 | 0.41564 | 0.43340 | 0.39785 | 0.35630 |
| 160.0 / | 0.22458 | 0.34422 | 0.34582 | 0.30742 | 0.27037 |
| 150.0 / | 0.24476 | 0.36354 | 0.35266 | 0.30449 | 0.26032 |
| 140.0 / | 0.28117 | 0.40034 | 0.40159 | 0.35928 | 0.31455 |
| 130.0 / | 0.32557 | 0.42233 | 0.41155 | 0.36166 | 0.31160 |
| 120.0 / | 0.33119 | 0.43622 | 0.41977 | 0.36983 | 0.32301 |
| 110.0 / | 0.28658 | 0.37015 | 0.35405 | 0.31306 | 0.27498 |
| 100.0 / | 0.27082 | 0.34881 | 0.33296 | 0.29347 | 0.25715 |
| 90.0 / | 0.32532 | 0.42423 | 0.43656 | 0.40849 | 0.37436 |
| 80.0 / | 0.22850 | 0.29517 | 0.28597 | 0.25562 | 0.22773 |
| 70.0 / | 0.23420 | 0.31138 | 0.29459 | 0.26191 | 0.23221 |
| 60.0 / | 0.28205 | 0.39474 | 0.39401 | 0.36383 | 0.33033 |
| 50.0 / | 0.31695 | 0.43377 | 0.42961 | 0.39246 | 0.35249 |
| 40.0 / | 0.28276 | 0.39058 | 0.37221 | 0.32958 | 0.29045 |
| 30.0 / | 0.20019 | 0.30947 | 0.29229 | 0.25152 | 0.21530 |
| 20.0 / | 0.23939 | 0.35634 | 0.34846 | 0.30949 | 0.27192 |
| 10.0 / | 0.35626 | 0.50392 | 0.46828 | 0.39466 | 0.33267 |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-07 ***

* HIGHEST 3-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER)
* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 32.15228 AND OCCURRED AT (500.0, 340.0) *

| DIRECTION / (DEGREES) / | RANGE (METERS) | | | | |
|----------------------------|---------------------|-------------------|-------------------|-------------------|-------------------|
| | 500.0 | 1000.0 | 1500.0 | 2000.0 | 2500.0 |
| 360.0 / | 29.04137 (94, 4) | 30.90844 (144, 5) | 25.95377 (55, 4) | 23.30919 (65, 4) | 20.29523 (65, 4) |
| 350.0 / | 24.02512 (63, 4) | 21.30620 (63, 4) | 19.67146 (63, 4) | 17.06783 (63, 4) | 14.52954 (63, 4) |
| 340.0 / | 32.15229 (87, 5) ✓ | 26.90972 (87, 5) | 22.17906 (87, 5) | 19.02503 (87, 5) | 17.17351 (339, 2) |
| 330.0 / | 19.41729 (55, 2) | 20.97499 (210, 6) | 20.14937 (210, 6) | 17.89261 (338, 4) | 17.33041 (339, 4) |
| 320.0 / | 15.29572 (71, 5) | 24.78472 (237, 5) | 20.86057 (237, 5) | 16.20743 (71, 5) | 14.50356 (71, 5) |
| 310.0 / | 24.55659 (112, 4) | 23.72609 (112, 4) | 21.68490 (192, 6) | 21.73549 (192, 6) | 20.20118 (192, 6) |
| 300.0 / | 31.83809 (216, 5) | 31.17037 (258, 4) | 25.50442 (258, 4) | 20.59949 (62, 6) | 18.50328 (62, 6) |
| 290.0 / | 20.59781 (112, 6) | 20.36053 (237, 5) | 19.13053 (112, 6) | 17.14122 (112, 6) | 14.89810 (112, 6) |
| 280.0 / | 20.02091 (136, 5) | 18.53690 (222, 6) | 17.65295 (222, 6) | 15.79481 (70, 6) | 14.57392 (70, 6) |
| 270.0 / | 26.99198 (242, 5) | 26.65485 (198, 5) | 24.66341 (242, 4) | 22.46715 (242, 4) | 20.36083 (137, 4) |
| 260.0 / | 20.86067 (243, 4) | 21.72980 (130, 5) | 22.04785 (130, 5) | 17.87503 (130, 5) | 17.33197 (130, 5) |
| 250.0 / | 27.14692 (101, 4) | 30.41488 (219, 4) | 24.66986 (219, 4) | 22.03213 (100, 6) | 19.19139 (100, 6) |
| 240.0 / | 24.97974 (141, 4) | 31.18217 (141, 4) | 26.83346 (278, 5) | 21.93638 (278, 5) | 17.79170 (278, 5) |
| 230.0 / | 28.67516 (100, 4) | 24.52901 (100, 4) | 20.87698 (273, 5) | 16.94863 (322, 4) | 15.22741 (322, 4) |
| 220.0 / | 22.32232 (133, 4) | 19.07297 (133, 4) | 17.80174 (224, 5) | 15.34283 (197, 3) | 15.42953 (197, 3) |
| 210.0 / | 20.52224 (205, 5) | 20.00776 (105, 4) | 17.01443 (66, 7) | 19.73633 (66, 7) | 18.32778 (65, 7) |
| 200.0 / | 30.04090 (99, 5) | 26.60861 (99, 5) | 22.24761 (99, 5) | 18.15254 (99, 5) | 15.00212 (13, 6) |
| 190.0 / | 19.54817 (186, 4) | 15.56271 (41, 4) | 17.65371 (8, 4) | 15.30535 (11, 4) | 14.15482 (11, 4) |
| 180.0 / | 18.57607 (290, 3) | 21.99082 (143, 3) | 19.05230 (143, 3) | 16.06998 (39, 1) | 15.46125 (39, 1) |
| 170.0 / | 19.48951 (315, 4) | 23.89375 (315, 4) | 21.35697 (315, 4) | 17.22961 (315, 4) | 13.80637 (315, 4) |
| 160.0 / | 23.12034 (315, 1) | 19.34242 (203, 5) | 16.87004 (29, 5) | 15.62186 (341, 2) | 14.14528 (341, 2) |
| 150.0 / | 14.52739 (163, 4) | 18.46190 (163, 4) | 18.45254 (74, 4) | 14.78582 (286, 2) | 13.96662 (362, 6) |
| 140.0 / | 19.49627 (173, 5) | 20.23082 (173, 5) | 16.60218 (360, 1) | 16.60335 (360, 1) | 15.71587 (359, 8) |
| 130.0 / | 28.57867 (115, 4) | 22.62567 (115, 4) | 20.50517 (19, 3) | 18.26842 (19, 3) | 15.80457 (17, 3) |
| 120.0 / | 22.45288 (161, 4) | 23.95747 (161, 4) | 17.92178 (270, 5) | 15.55055 (115, 3) | 13.77045 (3, 8) |
| 110.0 / | 31.62851 (51, 5) | 26.98198 (127, 6) | 25.66134 (127, 6) | 21.41317 (127, 6) | 17.52356 (127, 6) |
| 100.0 / | 23.84778 (20, 6) | 21.96779 (36, 3) | 23.36326 (36, 3) | 22.03040 (36, 3) | 19.72909 (36, 3) |
| 90.0 / | 25.35649 (128, 6) | 25.92118 (129, 6) | 22.91126 (128, 6) | 19.30377 (128, 6) | 16.14890 (129, 6) |
| 80.0 / | 22.76814 (3, 6) | 19.48052 (3, 6) | 17.76522 (3, 6) | 15.35003 (3, 6) | 14.00982 (115, 7) |
| 70.0 / | 26.34571 (114, 6) | 25.34184 (114, 6) | 24.86390 (114, 6) | 22.37828 (114, 6) | 19.53701 (114, 6) |
| 60.0 / | 19.80148 (78, 5) | 22.47791 (79, 5) | 19.82064 (251, 6) | 15.09145 (78, 5) | 13.13729 (79, 5) |
| 50.0 / | 19.29477 (180, 4) | 20.10026 (177, 4) | 19.44581 (282, 5) | 17.83265 (282, 5) | 15.66497 (282, 5) |
| 40.0 / | 25.44504 (145, 5) | 29.40576 (149, 5) | 25.88287 (148, 5) | 20.70203 (148, 5) | 16.50145 (149, 5) |
| 30.0 / | 19.38929 (213, 4) | 22.62343 (240, 5) | 22.16702 (285, 4) | 18.94298 (285, 4) | 15.22265 (285, 4) |
| 20.0 / | 17.69060 (145, 4) | 21.31228 (145, 4) | 16.54848 (285, 5) | 14.65365 (50, 4) | 13.72755 (50, 4) |
| 10.0 / | 19.04235 (58, 4) | 22.11790 (231, 4) | 19.34408 (188, 6) | 15.91390 (58, 4) | 14.31227 (65, 6) |

*** NRC/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* SECOND HIGHEST 3-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *
* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 29.72624 AND OCCURRED AT (1000.0, 240.0) *

| DIRECTION / (DEGREES) / | RANGE (METERS) | | | | |
|----------------------------|-------------------|-------------------|-------------------|-------------------|-------------------|
| | 500.0 | 1000.0 | 1500.0 | 2000.0 | 2500.0 |
| 360.0 / | 27.60012 (65, 4) | 27.90824 (262, 4) | 23.99381 (207, 6) | 20.07619 (95, 2) | 17.96294 (95, 2) |
| 350.0 / | 17.98421 (94, 5) | 16.05504 (250, 4) | 15.09655 (250, 4) | 13.54323 (114, 3) | 12.35341 (114, 3) |
| 340.0 / | 18.69943 (113, 4) | 20.57181 (206, 6) | 19.84732 (206, 6) | 17.75315 (339, 2) | 15.47450 (343, 4) |
| 330.0 / | 15.73496 (93, 5) | 20.63866 (188, 5) | 15.72704 (63, 2) | 16.04125 (210, 6) | 13.91873 (63, 2) |
| 320.0 / | 12.59862 (181, 4) | 21.20892 (313, 5) | 18.47571 (313, 5) | 15.34069 (237, 5) | 13.33859 (54, 9) |
| 310.0 / | 23.84764 (111, 5) | 23.42277 (237, 5) | 19.36129 (237, 5) | 16.32060 (57, 3) | 15.69071 (57, 3) |
| 300.0 / | 27.50332 (111, 5) | 29.68845 (136, 4) | 23.17764 (136, 4) | 19.38588 (122, 6) | 17.29687 (122, 6) |
| 290.0 / | 15.86168 (227, 5) | 19.61931 (112, 6) | 15.60030 (281, 6) | 14.45969 (281, 6) | 12.84268 (281, 6) |
| 280.0 / | 13.95100 (109, 5) | 17.02587 (228, 4) | 15.77792 (70, 6) | 15.18784 (222, 6) | 12.98606 (222, 6) |
| 270.0 / | 24.19479 (242, 4) | 26.47952 (217, 4) | 23.90987 (239, 6) | 22.10931 (239, 6) | 19.70836 (242, 4) |
| 260.0 / | 16.53709 (130, 5) | 20.35930 (222, 5) | 15.75020 (222, 5) | 15.78299 (245, 5) | 14.64197 (245, 5) |
| 250.0 / | 25.91101 (100, 6) | 25.48275 (101, 4) | 24.49679 (100, 6) | 18.05941 (219, 4) | 14.56582 (279, 5) |
| 240.0 / | 21.97601 (278, 5) | 29.72624 (279, 5) | 24.74457 (141, 4) | 19.14262 (141, 4) | 14.47628 (293, 5) |
| 230.0 / | 24.52841 (133, 4) | 24.26457 (293, 5) | 19.94913 (100, 4) | 15.96656 (303, 6) | 14.51436 (303, 6) |
| 220.0 / | 20.06878 (276, 6) | 18.25528 (276, 6) | 17.68244 (103, 4) | 16.21296 (103, 4) | 14.29058 (103, 4) |
| 210.0 / | 16.77449 (67, 4) | 17.01449 (205, 5) | 15.98329 (105, 4) | 14.33895 (39, 7) | 12.53266 (39, 7) |
| 200.0 / | 18.15523 (99, 6) | 20.05990 (154, 4) | 17.84472 (154, 4) | 16.18598 (12, 6) | 14.88847 (99, 5) |
| 190.0 / | 15.24440 (41, 4) | 15.27862 (8, 4) | 16.14320 (41, 4) | 14.97062 (41, 4) | 13.26456 (41, 4) |
| 180.0 / | 17.86790 (315, 3) | 19.43173 (341, 5) | 17.39697 (345, 4) | 15.39469 (315, 3) | 13.53551 (315, 3) |
| 170.0 / | 15.84193 (98, 5) | 20.27705 (98, 5) | 17.24550 (317, 4) | 15.28896 (317, 4) | 13.07560 (66, 6) |
| 160.0 / | 14.20978 (341, 2) | 18.77391 (315, 1) | 16.64808 (315, 1) | 14.20268 (305, 4) | 13.85145 (305, 4) |
| 150.0 / | 13.94567 (286, 2) | 17.98426 (74, 4) | 15.63492 (286, 2) | 14.77364 (74, 4) | 13.26348 (286, 2) |
| 140.0 / | 19.52553 (117, 4) | 19.62737 (117, 4) | 16.05049 (355, 3) | 16.03011 (359, 8) | 15.33455 (360, 1) |
| 130.0 / | 24.89178 (19, 3) | 21.20373 (19, 3) | 16.56057 (175, 5) | 14.65272 (66, 5) | 13.14516 (66, 5) |
| 120.0 / | 20.20136 (19, 4) | 21.70875 (178, 5) | 17.80721 (161, 4) | 14.35503 (3, 8) | 13.41095 (115, 3) |
| 110.0 / | 17.44344 (127, 6) | 25.63994 (51, 5) | 22.24989 (51, 5) | 19.65184 (51, 5) | 16.89559 (129, 3) |
| 100.0 / | 21.66762 (36, 3) | 20.07012 (20, 6) | 18.50504 (20, 6) | 16.41264 (47, 6) | 14.97969 (47, 6) |
| 90.0 / | 19.53115 (81, 5) | 22.22058 (176, 5) | 19.30557 (81, 5) | 17.47388 (81, 5) | 15.41951 (81, 6) |
| 80.0 / | 17.94836 (20, 5) | 17.19198 (176, 5) | 16.63705 (20, 5) | 15.22714 (20, 5) | 13.43458 (20, 5) |
| 70.0 / | 22.52863 (3, 5) | 21.80680 (127, 4) | 20.80350 (3, 5) | 19.20111 (3, 5) | 17.06908 (3, 5) |
| 60.0 / | 17.00076 (190, 5) | 20.51876 (251, 6) | 19.65060 (78, 5) | 15.81321 (251, 6) | 12.68373 (72, 6) |
| 50.0 / | 18.22298 (282, 5) | 19.05733 (282, 5) | 15.70216 (231, 5) | 13.84936 (145, 3) | 12.61748 (145, 3) |
| 40.0 / | 22.86809 (148, 5) | 27.41063 (252, 4) | 20.86315 (145, 5) | 16.97976 (145, 5) | 13.98010 (145, 5) |
| 30.0 / | 17.79612 (251, 5) | 22.11123 (175, 6) | 21.79986 (175, 6) | 17.45585 (175, 6) | 14.03122 (251, 4) |
| 20.0 / | 14.99847 (95, 3) | 18.83980 (248, 5) | 14.74841 (72, 5) | 14.51631 (285, 5) | 12.41444 (72, 5) |
| 10.0 / | 16.21357 (339, 5) | 20.69597 (188, 6) | 18.10842 (231, 4) | 15.62813 (65, 6) | 13.83972 (58, 4) |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* 50 MAXIMUM 3-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) | RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) |
|------|----------|------|-----|------------------------------|---|------|----------|------|-----|------------------------------|---|
| 1 | 32.15228 | 5 | 87 | 500.0 | 340.0 | 26 | 26.75454 | 4 | 136 | 500.0 | 300.0 |
| 2 | 31.83808 | 5 | 216 | 500.0 | 300.0 | 27 | 26.65485 | 5 | 198 | 1000.0 | 270.0 |
| 3 | 31.62951 | 5 | 51 | 500.0 | 110.0 | 28 | 26.63756 | 4 | 231 | 1000.0 | 360.0 |
| 4 | 31.18217 | 4 | 141 | 1000.0 | 240.0 | 29 | 26.60861 | 5 | 99 | 1000.0 | 200.0 |
| 5 | 31.17037 | 4 | 259 | 1000.0 | 300.0 | 30 | 26.56927 | 4 | 214 | 1000.0 | 360.0 |
| 6 | 30.80844 | 5 | 144 | 1000.0 | 360.0 | 31 | 26.54004 | 4 | 65 | 1000.0 | 360.0 |
| 7 | 30.41488 | 4 | 219 | 1000.0 | 250.0 | 32 | 26.50914 | 5 | 94 | 500.0 | 360.0 |
| 8 | 30.04090 | 5 | 99 | 500.0 | 200.0 | 33 | 26.47962 | 4 | 217 | 1000.0 | 270.0 |
| 9 | 29.72624 | 5 | 270 | 1000.0 | 240.0 | 34 | 26.44504 | 5 | 145 | 500.0 | 40.0 |
| 10 | 29.68945 | 4 | 136 | 1000.0 | 300.0 | 35 | 26.35549 | 6 | 128 | 500.0 | 90.0 |
| 11 | 29.40576 | 5 | 148 | 1000.0 | 40.0 | 36 | 26.34571 | 6 | 114 | 500.0 | 70.0 |
| 12 | 29.14692 | 4 | 101 | 500.0 | 250.0 | 37 | 25.95377 | 4 | 65 | 1500.0 | 360.0 |
| 13 | 28.68387 | 5 | 216 | 1000.0 | 300.0 | 38 | 25.94137 | 4 | 214 | 500.0 | 360.0 |
| 14 | 28.67516 | 4 | 100 | 500.0 | 230.0 | 39 | 25.92118 | 6 | 128 | 1000.0 | 90.0 |
| 15 | 28.57867 | 4 | 115 | 500.0 | 130.0 | 40 | 25.91101 | 6 | 100 | 500.0 | 250.0 |
| 16 | 28.04137 | 4 | 94 | 500.0 | 360.0 | 41 | 25.88287 | 5 | 148 | 1500.0 | 40.0 |
| 17 | 27.90824 | 4 | 262 | 1000.0 | 360.0 | 42 | 25.66134 | 6 | 127 | 1500.0 | 110.0 |
| 18 | 27.60012 | 4 | 65 | 500.0 | 360.0 | 43 | 25.63994 | 5 | 51 | 1000.0 | 110.0 |
| 19 | 27.50332 | 5 | 111 | 500.0 | 300.0 | 44 | 25.50442 | 4 | 298 | 1500.0 | 300.0 |
| 20 | 27.41063 | 4 | 252 | 1000.0 | 40.0 | 45 | 25.48275 | 4 | 101 | 1000.0 | 250.0 |
| 21 | 26.99198 | 5 | 242 | 500.0 | 270.0 | 46 | 25.47883 | 6 | 207 | 1000.0 | 360.0 |
| 22 | 26.98198 | 6 | 127 | 1000.0 | 110.0 | 47 | 25.46611 | 5 | 145 | 1000.0 | 40.0 |
| 23 | 26.97033 | 5 | 121 | 500.0 | 300.0 | 48 | 25.34184 | 6 | 114 | 1000.0 | 70.0 |
| 24 | 26.83346 | 5 | 278 | 1500.0 | 240.0 | 49 | 24.99341 | 6 | 100 | 1000.0 | 250.0 |
| 25 | 26.80972 | 5 | 87 | 1000.0 | 340.0 | 50 | 24.97974 | 4 | 141 | 500.0 | 240.0 |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* HIGHEST 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *
* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 10.75905 AND OCCURRED AT (1500.0, 180.0) *

| DIRECTION / (DEGREES) / | RANGE (METERS) | | | | |
|----------------------------|---------------------|------------------|---------------------|-------------------|------------------|
| | 500.0 | 1000.0 | 1500.0 | 2000.0 | 2500.0 |
| 360.0 / | 9.62887 (94, 1) | 7.74702 (94, 1) | 8.30065 (65, 1) | 8.37108 (65, 1) | 8.02047 (65, 1) |
| 350.0 / | 5.56095 (63, 1) | 5.16865 (63, 1) | 5.22377 (63, 1) | 4.93753 (63, 1) | 4.48449 (63, 1) |
| 340.0 / | 4.15037 (92, 1) | 4.43852 (206, 1) | 4.36473 (88, 1) | 4.25205 (89, 1) | 3.88967 (88, 1) |
| 330.0 / | 3.47469 (55, 1) | 5.82204 (249, 1) | 5.08600 (249, 1) | 3.71414 (249, 1) | 3.31815 (63, 1) |
| 320.0 / | 3.13885 (87, 1) | 6.28130 (249, 1) | 6.08364 (249, 1) | 4.90755 (249, 1) | 3.76614 (249, 1) |
| 310.0 / | 7.17692 (121, 1) | 7.33111 (121, 1) | 6.80390 (121, 1) | 5.96722 (121, 1) | 5.13434 (121, 1) |
| 300.0 / | 8.32282 (136, 1) | 8.71506 (258, 1) | 8.77209 (62, 1) | 8.61300 (62, 1) | 8.00344 (62, 1) |
| 270.0 / | 5.92353 (86, 1) | 5.64493 (86, 1) | 5.38003 (86, 1) | 4.84448 (86, 1) | 4.28843 (86, 1) |
| 290.0 / | 4.12216 (136, 1) | 4.99902 (135, 1) | 4.72036 (138, 1) | 4.21639 (138, 1) | 3.59183 (139, 1) |
| 270.0 / | 8.51148 (242, 1) | 8.67847 (242, 1) | 8.06827 (242, 1) | 7.12119 (242, 1) | 6.26281 (242, 1) |
| 250.0 / | 4.69636 (243, 1) | 5.15703 (255, 1) | 4.19436 (218, 1) | 3.81601 (245, 1) | 3.76302 (245, 1) |
| 250.0 / | 5.49989 (101, 1) | 6.29889 (219, 1) | 5.47796 (219, 1) | 4.25647 (219, 1) | 3.43030 (141, 1) |
| 240.0 / | 7.94176 (102, 1) | 7.88775 (102, 1) | 7.48853 (102, 1) | 6.51512 (102, 1) | 5.93109 (102, 1) |
| 230.0 / | 7.09925 (142, 1) | 6.84280 (142, 1) | 6.36715 (103, 1) | 5.20991 (103, 1) | 5.72842 (103, 1) |
| 220.0 / | 4.61662 (133, 1) | 4.68021 (133, 1) | 4.47769 (133, 1) | 3.96212 (133, 1) | 3.41819 (133, 1) |
| 210.0 / | 4.97478 (304, 1) | 4.76408 (304, 1) | 4.92059 (304, 1) | 4.75311 (41, 1) | 4.42046 (304, 1) |
| 200.0 / | 9.13955 (99, 1) | 8.25774 (99, 1) | 7.55148 (99, 1) | 6.52136 (99, 1) | 5.53355 (99, 1) |
| 170.0 / | 7.05986 (344, 1) | 6.72577 (344, 1) | 7.34769 (344, 1) | 6.91310 (344, 1) | 6.16344 (344, 1) |
| 190.0 / | 9.95626 (40, 1) | 9.94282 (40, 1) | 10.75905 (40, 1) ✓ | 10.31036 (40, 1) | 9.35376 (40, 1) |
| 170.0 / | 5.62942 (315, 1) | 6.98542 (315, 1) | 6.53157 (315, 1) | 5.46943 (315, 1) | 4.54334 (315, 1) |
| 150.0 / | 6.52902 (315, 1) | 6.87410 (315, 1) | 6.50293 (315, 1) | 5.65641 (315, 1) | 5.07600 (305, 1) |
| 150.0 / | 3.75995 (286, 1) | 4.54022 (362, 1) | 4.69440 (362, 1) | 4.20068 (362, 1) | 3.80508 (32, 1) |
| 140.0 / | 4.44043 (340, 1) | 5.40595 (117, 1) | 4.88724 (360, 1) | 4.64139 (360, 1) | 4.11764 (360, 1) |
| 130.0 / | 10.46584 (19, 1) ✓ | 8.66983 (19, 1) | 8.22505 (19, 1) | 7.25380 (19, 1) | 6.23474 (19, 1) |
| 120.0 / | 5.15400 (19, 1) | 5.22802 (161, 1) | 4.48096 (272, 1) | 3.71197 (272, 1) | 3.14645 (330, 1) |
| 110.0 / | 6.78196 (51, 1) | 6.40012 (127, 1) | 5.88732 (127, 1) | 4.82126 (127, 1) | 3.90419 (127, 1) |
| 100.0 / | 7.30934 (36, 1) | 7.31102 (36, 1) | 7.76690 (36, 1) | 7.31736 (36, 1) | 6.54017 (36, 1) |
| 70.0 / | 5.90246 (36, 1) | 5.71942 (36, 1) | 6.03312 (36, 1) | 5.77313 (36, 1) | 5.31093 (36, 1) |
| 90.0 / | 3.55384 (300, 1) | 3.92671 (300, 1) | 4.19547 (300, 1) | 3.91575 (300, 1) | 3.50159 (300, 1) |
| 70.0 / | 6.53838 (114, 1) | 6.09491 (114, 1) | 5.86553 (114, 1) | 5.29711 (114, 1) | 4.64464 (114, 1) |
| 60.0 / | 4.46418 (77, 1) | 4.45329 (172, 1) | 4.65062 (77, 1) | 4.61399 (77, 1) | 4.40317 (77, 1) |
| 50.0 / | 3.94185 (234, 1) | 6.05109 (172, 1) | 5.57366 (172, 1) | 4.63906 (282, 1) | 4.25869 (282, 1) |
| 40.0 / | 4.31160 (145, 1) | 6.65087 (148, 1) | 5.80615 (148, 1) | 4.52681 (148, 1) | 4.07695 (157, 1) |
| 30.0 / | 3.69073 (251, 1) | 4.92191 (251, 1) | 4.85594 (251, 1) | 4.39810 (251, 1) | 3.86996 (251, 1) |
| 20.0 / | 3.35922 (248, 1) | 4.44060 (248, 1) | 3.75443 (285, 1) | 3.37024 (49, 1) | 3.31275 (49, 1) |
| 10.0 / | 4.45464 (339, 1) | 6.64201 (230, 1) | 6.38550 (230, 1) | 5.05788 (230, 1) | 3.92470 (230, 1) |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* SECOND HIGHEST 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *
* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 8.31162 AND OCCURRED AT (1000.0, 300.0) *

| DIRECTION / (DEGREES) / | RANGE (METERS) | | | | |
|----------------------------|------------------|------------------|------------------|------------------|------------------|
| | 500.0 | 1000.0 | 1500.0 | 2000.0 | 2500.0 |
| 360.0 / | 6.85188 (65. 1) | 7.66266 (207. 1) | 7.93863 (335. 1) | 8.00830 (335. 1) | 7.56527 (354. 1) |
| 350.0 / | 4.44252 (9. 1) | 4.46855 (57. 1) | 4.10158 (57. 1) | 3.51287 (9. 1) | 3.15617 (9. 1) |
| 340.0 / | 4.04001 (87. 1) | 4.34667 (92. 1) | 4.16343 (206. 1) | 3.54773 (92. 1) | 3.37888 (153. 1) |
| 330.0 / | 3.07891 (93. 1) | 4.69979 (202. 1) | 4.35357 (202. 1) | 3.55591 (202. 1) | 3.27637 (338. 1) |
| 320.0 / | 2.93364 (108. 1) | 4.62085 (229. 1) | 3.45956 (338. 1) | 3.50051 (338. 1) | 3.17138 (338. 1) |
| 310.0 / | 4.66457 (209. 1) | 5.30392 (209. 1) | 4.51654 (192. 1) | 4.50477 (192. 1) | 4.19619 (192. 1) |
| 300.0 / | 7.86094 (86. 1) | 8.31162 (136. 1) | 7.23429 (86. 1) | 6.70398 (86. 1) | 6.04106 (86. 1) |
| 290.0 / | 4.21325 (112. 1) | 5.06244 (258. 1) | 4.37019 (258. 1) | 3.93715 (123. 1) | 3.19323 (123. 1) |
| 280.0 / | 3.78060 (109. 1) | 4.42712 (228. 1) | 4.05413 (155. 1) | 3.75853 (222. 1) | 3.38616 (222. 1) |
| 270.0 / | 6.42055 (240. 1) | 8.24685 (217. 1) | 7.61173 (217. 1) | 6.30465 (217. 1) | 5.38892 (240. 1) |
| 260.0 / | 4.07356 (218. 1) | 5.13284 (218. 1) | 4.07793 (253. 1) | 3.39948 (238. 1) | 3.02958 (217. 1) |
| 250.0 / | 4.44520 (255. 1) | 4.85346 (255. 1) | 4.56599 (141. 1) | 3.98245 (141. 1) | 3.95250 (219. 1) |
| 240.0 / | 5.31719 (278. 1) | 7.58042 (278. 1) | 7.19083 (278. 1) | 5.12574 (278. 1) | 5.16523 (278. 1) |
| 230.0 / | 5.32437 (103. 1) | 5.76659 (103. 1) | 6.15489 (142. 1) | 5.31527 (142. 1) | 4.57947 (142. 1) |
| 220.0 / | 4.23605 (276. 1) | 3.91478 (142. 1) | 3.71982 (304. 1) | 3.47282 (304. 1) | 3.11752 (304. 1) |
| 210.0 / | 4.61694 (39. 1) | 4.41293 (41. 1) | 4.50650 (41. 1) | 4.72910 (304. 1) | 4.31857 (41. 1) |
| 200.0 / | 4.26493 (39. 1) | 4.53932 (39. 1) | 5.11273 (39. 1) | 4.96469 (39. 1) | 4.50797 (39. 1) |
| 190.0 / | 3.92336 (99. 1) | 3.76280 (40. 1) | 3.98084 (40. 1) | 3.72840 (40. 1) | 3.31013 (40. 1) |
| 180.0 / | 6.94763 (344. 1) | 6.97246 (344. 1) | 7.68057 (344. 1) | 7.44361 (344. 1) | 6.78047 (344. 1) |
| 170.0 / | 4.09245 (341. 1) | 5.26925 (341. 1) | 5.47519 (341. 1) | 4.87295 (341. 1) | 4.39850 (316. 1) |
| 160.0 / | 5.22142 (96. 1) | 5.44998 (96. 1) | 5.63642 (96. 1) | 5.36676 (96. 1) | 4.95854 (96. 1) |
| 150.0 / | 3.56846 (117. 1) | 4.48714 (117. 1) | 4.41735 (32. 1) | 4.12557 (32. 1) | 3.71796 (362. 1) |
| 140.0 / | 4.36674 (117. 1) | 4.20706 (360. 1) | 4.29583 (117. 1) | 3.95915 (254. 1) | 3.55392 (254. 1) |
| 130.0 / | 5.92695 (330. 1) | 5.13604 (330. 1) | 4.80115 (330. 1) | 4.19232 (330. 1) | 3.80224 (21. 1) |
| 120.0 / | 4.51075 (161. 1) | 5.02755 (164. 1) | 4.38924 (164. 1) | 3.44530 (330. 1) | 2.90933 (272. 1) |
| 110.0 / | 4.34205 (95. 1) | 5.72629 (51. 1) | 5.24114 (51. 1) | 4.54315 (51. 1) | 3.87575 (51. 1) |
| 100.0 / | 4.13530 (10. 1) | 3.48748 (275. 1) | 3.53430 (47. 1) | 3.51646 (47. 1) | 3.39633 (47. 1) |
| 90.0 / | 5.60268 (81. 1) | 5.45655 (81. 1) | 5.60487 (91. 1) | 5.20395 (81. 1) | 4.63411 (81. 1) |
| 80.0 / | 3.34987 (3. 1) | 3.59945 (176. 1) | 2.89106 (129. 1) | 2.53099 (115. 1) | 2.69617 (115. 1) |
| 70.0 / | 4.69538 (3. 1) | 4.79315 (253. 1) | 4.59814 (253. 1) | 3.79520 (253. 1) | 3.10258 (253. 1) |
| 60.0 / | 3.59124 (158. 1) | 4.33737 (77. 1) | 4.17294 (172. 1) | 4.08962 (157. 1) | 3.83893 (157. 1) |
| 50.0 / | 3.92066 (158. 1) | 5.68981 (177. 1) | 4.85383 (177. 1) | 4.48639 (172. 1) | 4.10470 (158. 1) |
| 40.0 / | 4.17174 (148. 1) | 5.31231 (145. 1) | 4.48955 (145. 1) | 4.23899 (157. 1) | 3.57108 (148. 1) |
| 30.0 / | 3.63080 (145. 1) | 4.09874 (145. 1) | 3.45161 (285. 1) | 2.95804 (234. 1) | 3.07117 (234. 1) |
| 20.0 / | 2.96016 (80. 1) | 4.01158 (119. 1) | 3.55281 (230. 1) | 3.14187 (50. 1) | 3.02159 (50. 1) |
| 10.0 / | 3.81145 (58. 1) | 5.76771 (207. 1) | 4.61687 (166. 1) | 3.64834 (339. 1) | 3.15862 (339. 1) |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-07 ***

► 50 MAXIMUM 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) ►

* FROM ALL SOURCES *

| RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) | RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) |
|------|----------|------|-----|------------------------------|---|------|---------|------|-----|------------------------------|---|
| 1 | 10.75905 | 1 | 40 | 1500.0 | 180.0 | 26 | 8.00344 | 1 | 62 | 2500.0 | 300.0 |
| 2 | 10.46584 | 1 | 19 | 500.0 | 130.0 | 27 | 7.94176 | 1 | 102 | 500.0 | 240.0 |
| 3 | 10.31036 | 1 | 40 | 2000.0 | 180.0 | 28 | 7.93863 | 1 | 335 | 1500.0 | 360.0 |
| 4 | 9.98626 | 1 | 40 | 500.0 | 180.0 | 29 | 7.91301 | 1 | 62 | 1000.0 | 300.0 |
| 5 | 9.94282 | 1 | 40 | 1000.0 | 180.0 | 30 | 7.88775 | 1 | 102 | 1000.0 | 240.0 |
| 6 | 9.62887 | 1 | 94 | 500.0 | 360.0 | 31 | 7.86094 | 1 | 86 | 500.0 | 300.0 |
| 7 | 9.35376 | 1 | 40 | 2500.0 | 180.0 | 32 | 7.76690 | 1 | 36 | 1500.0 | 100.0 |
| 8 | 9.13955 | 1 | 99 | 500.0 | 200.0 | 33 | 7.74702 | 1 | 94 | 1000.0 | 360.0 |
| 9 | 8.77209 | 1 | 62 | 1500.0 | 300.0 | 34 | 7.73093 | 1 | 62 | 500.0 | 300.0 |
| 10 | 8.71506 | 1 | 259 | 1000.0 | 300.0 | 35 | 7.68057 | 1 | 344 | 1500.0 | 180.0 |
| 11 | 8.67847 | 1 | 242 | 1000.0 | 270.0 | 36 | 7.66406 | 1 | 354 | 2000.0 | 360.0 |
| 12 | 8.66983 | 1 | 17 | 1000.0 | 130.0 | 37 | 7.66266 | 1 | 207 | 1000.0 | 360.0 |
| 13 | 8.61300 | 1 | 62 | 2000.0 | 300.0 | 38 | 7.64408 | 1 | 121 | 500.0 | 300.0 |
| 14 | 8.51148 | 1 | 242 | 500.0 | 270.0 | 39 | 7.61173 | 1 | 217 | 1500.0 | 270.0 |
| 15 | 8.37108 | 1 | 65 | 2000.0 | 360.0 | 40 | 7.58042 | 1 | 278 | 1000.0 | 240.0 |
| 16 | 8.32282 | 1 | 136 | 500.0 | 300.0 | 41 | 7.56527 | 1 | 354 | 2500.0 | 360.0 |
| 17 | 8.31162 | 1 | 136 | 1000.0 | 300.0 | 42 | 7.55148 | 1 | 99 | 1500.0 | 200.0 |
| 18 | 8.30065 | 1 | 65 | 1500.0 | 360.0 | 43 | 7.49741 | 1 | 335 | 2500.0 | 360.0 |
| 19 | 8.25774 | 1 | 99 | 1000.0 | 200.0 | 44 | 7.48833 | 1 | 102 | 1500.0 | 240.0 |
| 20 | 8.24685 | 1 | 217 | 1000.0 | 270.0 | 45 | 7.44361 | 1 | 344 | 2000.0 | 180.0 |
| 21 | 8.22505 | 1 | 19 | 1500.0 | 130.0 | 46 | 7.42665 | 1 | 65 | 1000.0 | 360.0 |
| 22 | 8.09539 | 1 | 121 | 1000.0 | 300.0 | 47 | 7.34969 | 1 | 344 | 1500.0 | 190.0 |
| 23 | 8.06827 | 1 | 242 | 1500.0 | 270.0 | 48 | 7.33111 | 1 | 121 | 1000.0 | 310.0 |
| 24 | 8.02047 | 1 | 65 | 2500.0 | 360.0 | 49 | 7.31736 | 1 | 36 | 2000.0 | 100.0 |
| 25 | 8.00830 | 1 | 335 | 2000.0 | 360.0 | 50 | 7.31102 | 1 | 36 | 1000.0 | 100.0 |

| | |
|---|----------------------|
| CALCULATE (CONCENTRATION=1, DEPOSITION=2) | ISW(1) = 1 |
| RECEPTOR GRID SYSTEM (RECTANGULAR=1 OR 3, POLAR=2 OR 4) | ISW(2) = 4 |
| DISCRETE RECEPTOR SYSTEM (RECTANGULAR=1, POLAR=2) | ISW(3) = 2 |
| TERRAIN ELEVATIONS ARE READ (YES=1, NO=0) | ISW(4) = 0 |
| CALCULATIONS ARE WRITTEN TO TAPE (YES=1, NO=0) | ISW(5) = 0 |
| LIST ALL INPUT DATA (NO=0, YES=1, MET DATA ALSO=2) | ISW(6) = 1 |
| | |
| COMPUTE AVERAGE CONCENTRATION (OR TOTAL DEPOSITION) | |
| WITH THE FOLLOWING TIME PERIODS: | |
| HOURLY (YES=1, NO=0) | ISW(7) = 0 |
| 2-HOUR (YES=1, NO=0) | ISW(8) = 0 |
| 3-HOUR (YES=1, NO=0) | ISW(9) = 1 |
| 4-HOUR (YES=1, NO=0) | ISW(10) = 0 |
| 6-HOUR (YES=1, NO=0) | ISW(11) = 0 |
| 8-HOUR (YES=1, NO=0) | ISW(12) = 0 |
| 12-HOUR (YES=1, NO=0) | ISW(13) = 0 |
| 24-HOUR (YES=1, NO=0) | ISW(14) = 1 |
| PRINT "N"-DAY TABLE(S) (YES=1, NO=0) | ISW(15) = 0 |
| | |
| PRINT THE FOLLOWING TYPES OF TABLES WHOSE TIME PERIODS ARE | |
| SPECIFIED BY ISW(7) THROUGH ISW(14): | |
| DAILY TABLES (YES=1, NO=0) | ISW(16) = 0 |
| HIGHEST & SECOND HIGHEST TABLES (YES=1, NO=0) | ISW(17) = 0 |
| MAXIMUM 50 TABLES (YES=1, NO=0) | ISW(18) = 1 |
| METEOROLOGICAL DATA INPUT METHOD (PRE-PROCESSED=1, CARD=2) | ISW(19) = 1 |
| RURAL-URBAN OPTION (RURAL=0, URBAN MODE 1=1, URBAN MODE 2=2) | ISW(20) = 0 |
| WIND PROFILE EXPONENT VALUES (DEFAULTS=1, USER ENTERS=2, 3) | ISW(21) = 1 |
| VERTICAL POT. TEMP. GRADIENT VALUES (DEFAULTS=1, USER ENTERS=2, 3) | ISW(22) = 1 |
| SCALE EMISSION RATES FOR ALL SOURCES (NO=0, YES>0) | ISW(23) = 0 |
| PROGRAM CALCULATES FINAL PLUME RISE ONLY (YES=1, NO=2) | ISW(24) = 2 |
| PROGRAM ADJUSTS ALL STACK HEIGHTS FOR DOWNWASH (YES=2, NO=1) | ISW(25) = 1 |
| | |
| INPUT SPECIAL DIRECTION-DEPENDENT BUILDING DIMENSIONS (YES=1, NO=0) | ISW(26) = 0 |
| | |
| OMIT TABLES FOR HOURLY CONCENTRATIONS (YES=1, NO=0) | ISW(27) = 0 |
| | |
| USEPA ADJUSTMENT FOR CALM HOURS (YES=1, NO=0) | ISW(28) = 1 |
| | |
| NUMBER OF INPUT SOURCES | NSDURC = 1 |
| NUMBER OF SOURCE GROUPS (=0, ALL SOURCES) | NGROUP = 0 |
| TIME PERIOD INTERVAL TO BE PRINTED (=0, ALL INTERVALS) | IPERD = 0 |
| NUMBER OF X (RANGE) GRID VALUES | NXPNTS = 10 |
| NUMBER OF Y (THETA) GRID VALUES | NYPNTS = 36 |
| NUMBER OF DISCRETE RECEPTORS | NXWYPT = 0 |
| SOURCE EMISSION RATE UNITS CONVERSION FACTOR | TK = 10000E+07 |
| ENTRAINMENT COEFFICIENT FOR UNSTABLE ATMOSPHERE | BETA1 = 0.500 |
| ENTRAINMENT COEFFICIENT FOR STABLE ATMOSPHERE | BETA2 = 0.500 |
| HEIGHT ABOVE GROUND AT WHICH WIND SPEED WAS MEASURED | ZR = 10.00 METERS |
| LOGICAL UNIT NUMBER OF METEOROLOGICAL DATA | IMET = 9 |
| DECAY COEFFICIENT FOR PHYSICAL OR CHEMICAL DEPLETION | DECAY = 0.000000E+00 |
| SURFACE STATION NO. | ISS = 12815 |
| YEAR OF SURFACE DATA | ISY = 77 |
| UPPER AIR STATION NO. | IUS = 12842 |
| YEAR OF UPPER AIR DATA | IUY = 77 |
| ALLOCATED DATA STORAGE | LIMIT = 43300 WORDS |

IST-10

1977 - NRG ONLY - 80
(Selected Days)

*** RANGES OF POLAR GRID SYSTEM ***
(METERS)

| | | | | | | | | | |
|--------|--------|--------|--------|--------|--------|--------|---------|---------|---------|
| 200.0, | 300.0, | 400.0, | 600.0, | 700.0, | 800.0, | 900.0, | 1200.0, | 1400.0, | 1700.0, |
|--------|--------|--------|--------|--------|--------|--------|---------|---------|---------|

*** RADIAL ANGLES OF POLAR GRID SYSTEM ***

(DEGREES)

| | | | | | | | | | |
|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| 10.0, | 20.0, | 30.0, | 40.0, | 50.0, | 60.0, | 70.0, | 90.0, | 90.0, | 100.0, |
| 110.0, | 120.0, | 130.0, | 140.0, | 150.0, | 160.0, | 170.0, | 190.0, | 190.0, | 200.0, |
| 210.0, | 220.0, | 230.0, | 240.0, | 250.0, | 260.0, | 270.0, | 290.0, | 290.0, | 300.0, |
| 310.0, | 320.0, | 330.0, | 340.0, | 350.0, | 360.0, | | | | |

*** SOURCE DATA ***

| SOURCE NUMBER | PK | PART | E E | CATS. | EMISSION RATE | | X | Y | BASE ELEV. | HEIGHT | TEMP. TYPE=0 (DEG. K); VERT. DIM TYPE=1 (METERS) | EXIT VEL. | | | BLDG. HEIGHT (METERS) | BLDG. LENGTH (METERS) | BLDG. WIDTH (METERS) |
|---------------|----|------|-----|-------|----------------------|--------------------|-----|-----|------------|--------|--|-----------------------------|--------------------------|-----------------|-----------------------|-----------------------|----------------------|
| | | | | | TYPE=0,1 (GRAMS/SEC) | TYPE=2 (GRAMS/SEC) | | | | | | HDRZ. DIM TYPE=1,2 (METERS) | DIAMETER TYPE=0 (METERS) | TYPE=0 (METERS) | | | |
| 101 | 0 | 0 | 0 | 0 | 0.15800E+02 | *PER METER**2 | 0.0 | 0.0 | 0.0 | 38.10 | 450.00 | 20.00 | 1.83 | 22.00 | 38.10 | 19.80 | |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* 50 MAXIMUM 3-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y (METERS) OR DIRECTION (DEGREES) | RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y (METERS) OR DIRECTION (DEGREES) |
|------|----------|------|-----|------------------------------|--|------|----------|------|-----|------------------------------|--|
| 1 | 69.59486 | 5 | 51 | 200.0 | 110.0 | 26 | 38.82438 | 5 | 99 | 400.0 | 200.0 |
| 2 | 59.98905 | 3 | 19 | 200.0 | 130.0 | 27 | 37.57761 | 4 | 19 | 300.0 | 120.0 |
| 3 | 58.52740 | 5 | 87 | 200.0 | 340.0 | 28 | 37.22967 | 5 | 216 | 400.0 | 300.0 |
| 4 | 57.56598 | 5 | 51 | 300.0 | 110.0 | 29 | 36.83534 | 7 | 99 | 300.0 | 200.0 |
| 5 | 52.99155 | 5 | 99 | 200.0 | 200.0 | 30 | 36.59052 | 4 | 94 | 400.0 | 360.0 |
| 6 | 52.30331 | 5 | 87 | 300.0 | 340.0 | 31 | 36.22225 | 3 | 19 | 400.0 | 130.0 |
| 7 | 51.61990 | 4 | 94 | 200.0 | 360.0 | 32 | 35.68717 | 5 | 94 | 200.0 | 350.0 |
| 8 | 51.21322 | 2 | 19 | 200.0 | 130.0 | 33 | 35.23911 | 6 | 99 | 200.0 | 190.0 |
| 9 | 49.01497 | 3 | 19 | 300.0 | 130.0 | 34 | 34.22640 | 6 | 216 | 200.0 | 270.0 |
| 10 | 48.19339 | 5 | 99 | 300.0 | 200.0 | 35 | 34.12436 | 6 | 99 | 300.0 | 200.0 |
| 11 | 46.10723 | 4 | 19 | 200.0 | 120.0 | 36 | 33.77392 | 4 | 40 | 200.0 | 180.0 |
| 12 | 45.92691 | 4 | 94 | 300.0 | 360.0 | 37 | 33.53215 | 5 | 94 | 400.0 | 360.0 |
| 13 | 45.47030 | 7 | 99 | 200.0 | 200.0 | 38 | 33.03918 | 6 | 19 | 300.0 | 110.0 |
| 14 | 44.85070 | 5 | 94 | 200.0 | 360.0 | 39 | 32.72956 | 5 | 136 | 200.0 | 280.0 |
| 15 | 43.88745 | 6 | 19 | 200.0 | 110.0 | 40 | 32.17449 | 6 | 40 | 300.0 | 180.0 |
| 16 | 43.80431 | 5 | 51 | 400.0 | 110.0 | 41 | 31.75994 | 4 | 19 | 300.0 | 130.0 |
| 17 | 42.37231 | 5 | 216 | 300.0 | 300.0 | 42 | 31.50704 | 6 | 94 | 200.0 | 360.0 |
| 18 | 41.84482 | 5 | 87 | 400.0 | 340.0 | 43 | 31.36153 | 4 | 141 | 900.0 | 240.0 |
| 19 | 41.56203 | 2 | 19 | 300.0 | 130.0 | 44 | 31.31458 | 8 | 94 | 200.0 | 360.0 |
| 20 | 41.52353 | 6 | 99 | 200.0 | 200.0 | 45 | 31.03914 | 5 | 94 | 300.0 | 350.0 |
| 21 | 41.13793 | 5 | 94 | 300.0 | 360.0 | 46 | 30.99044 | 4 | 258 | 900.0 | 300.0 |
| 22 | 40.67433 | 5 | 216 | 200.0 | 300.0 | 47 | 30.78887 | 2 | 19 | 400.0 | 130.0 |
| 23 | 39.68136 | 3 | 87 | 200.0 | 310.0 | 48 | 30.76106 | 6 | 141 | 200.0 | 260.0 |
| 24 | 39.25979 | 6 | 40 | 200.0 | 180.0 | 49 | 30.67477 | 5 | 136 | 300.0 | 280.0 |
| 25 | 39.22096 | 4 | 19 | 200.0 | 130.0 | 50 | 30.61536 | 3 | 87 | 300.0 | 310.0 |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* 50 MAXIMUM 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) | RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) |
|------|----------|------|-----|------------------------------|---|------|---------|------|-----|------------------------------|---|
| 1 | 28.01319 | 1 | 40 | 200.0 | 180.0 | 26 | 9.85483 | 1 | 136 | 200.0 | 300.0 |
| 2 | 25.55253 | 1 | 19 | 200.0 | 130.0 | 27 | 9.68515 | 1 | 51 | 400.0 | 110.0 |
| 3 | 22.17275 | 1 | 40 | 300.0 | 180.0 | 28 | 9.63031 | 1 | 94 | 200.0 | 350.0 |
| 4 | 20.93532 | 1 | 94 | 200.0 | 360.0 | 29 | 9.49591 | 1 | 40 | 900.0 | 180.0 |
| 5 | 20.69506 | 1 | 19 | 300.0 | 130.0 | 30 | 9.48056 | 1 | 136 | 400.0 | 300.0 |
| 6 | 20.12777 | 1 | 99 | 200.0 | 200.0 | 31 | 9.20192 | 1 | 215 | 300.0 | 300.0 |
| 7 | 17.37512 | 1 | 94 | 300.0 | 360.0 | 32 | 8.96570 | 1 | 40 | 800.0 | 180.0 |
| 8 | 16.97798 | 1 | 99 | 300.0 | 200.0 | 33 | 8.74155 | 1 | 40 | 300.0 | 190.0 |
| 9 | 16.17776 | 1 | 51 | 200.0 | 110.0 | 34 | 8.73005 | 1 | 99 | 200.0 | 190.0 |
| 10 | 15.49614 | 1 | 40 | 400.0 | 180.0 | 35 | 8.68752 | 1 | 258 | 900.0 | 300.0 |
| 11 | 15.21967 | 1 | 19 | 400.0 | 130.0 | 36 | 8.63083 | 1 | 136 | 200.0 | 270.0 |
| 12 | 13.10589 | 1 | 51 | 300.0 | 110.0 | 37 | 8.61989 | 1 | 19 | 1200.0 | 130.0 |
| 13 | 12.99329 | 1 | 94 | 400.0 | 360.0 | 38 | 8.58907 | 1 | 19 | 900.0 | 130.0 |
| 14 | 12.84596 | 1 | 19 | 200.0 | 120.0 | 39 | 8.50935 | 1 | 136 | 800.0 | 300.0 |
| 15 | 12.82954 | 1 | 99 | 400.0 | 200.0 | 40 | 8.49800 | 1 | 136 | 900.0 | 300.0 |
| 16 | 11.11715 | 1 | 40 | 200.0 | 190.0 | 41 | 8.41309 | 1 | 19 | 800.0 | 130.0 |
| 17 | 11.10592 | 1 | 87 | 200.0 | 310.0 | 42 | 8.38492 | 1 | 19 | 1400.0 | 130.0 |
| 18 | 10.73755 | 1 | 40 | 1400.0 | 180.0 | 43 | 8.38445 | 1 | 19 | 600.0 | 130.0 |
| 19 | 10.66788 | 1 | 40 | 1700.0 | 180.0 | 44 | 8.37957 | 1 | 87 | 300.0 | 310.0 |
| 20 | 10.53821 | 1 | 136 | 300.0 | 300.0 | 45 | 8.37633 | 1 | 258 | 800.0 | 300.0 |
| 21 | 10.50810 | 1 | 40 | 1200.0 | 180.0 | 46 | 8.28771 | 1 | 40 | 700.0 | 180.0 |
| 22 | 10.26288 | 1 | 19 | 300.0 | 120.0 | 47 | 8.26377 | 1 | 258 | 1200.0 | 300.0 |
| 23 | 10.19945 | 1 | 40 | 200.0 | 170.0 | 48 | 8.25649 | 1 | 99 | 900.0 | 200.0 |
| 24 | 9.90222 | 1 | 215 | 200.0 | 300.0 | 49 | 8.24797 | 1 | 136 | 700.0 | 300.0 |
| 25 | 9.87729 | 1 | 87 | 200.0 | 320.0 | 50 | 8.15842 | 1 | 99 | 800.0 | 200.0 |

| | |
|---|----------------------|
| CALCULATE (CONCENTRATION=1, DEPOSITION=2) | ISW(1) = 1 |
| RECEPTOR GRID SYSTEM (RECTANGULAR=1 OR 3, POLAR=2 OR 4) | ISW(2) = 4 |
| DISCRETE RECEPTOR SYSTEM (RECTANGULAR=1, POLAR=2) | ISW(3) = 2 |
| TERRAIN ELEVATIONS ARE READ (YES=1, NO=0) | ISW(4) = 0 |
| CALCULATIONS ARE WRITTEN TO TAPE (YES=1, NO=0) | ISW(5) = 0 |
| LIST ALL INPUT DATA (NO=0, YES=1, MET DATA ALSO=2) | ISW(6) = 1 |
| | |
| COMPUTE AVERAGE CONCENTRATION (OR TOTAL DEPOSITION) | |
| WITH THE FOLLOWING TIME PERIODS: | |
| HOURLY (YES=1, NO=0) | ISW(7) = 0 |
| 2-HOUR (YES=1, NO=0) | ISW(8) = 0 |
| 3-HOUR (YES=1, NO=0) | ISW(9) = 1 |
| 4-HOUR (YES=1, NO=0) | ISW(10) = 0 |
| 6-HOUR (YES=1, NO=0) | ISW(11) = 0 |
| 8-HOUR (YES=1, NO=0) | ISW(12) = 0 |
| 12-HOUR (YES=1, NO=0) | ISW(13) = 0 |
| 24-HOUR (YES=1, NO=0) | ISW(14) = 1 |
| PRINT "N"-DAY TABLE(S) (YES=1, NO=0) | ISW(15) = 1 |
| | |
| PRINT THE FOLLOWING TYPES OF TABLES WHOSE TIME PERIODS ARE SPECIFIED BY ISW(7) THROUGH ISW(14): | |
| DAILY TABLES (YES=1, NO=0) | ISW(16) = 0 |
| HIGHEST & SECOND HIGHEST TABLES (YES=1, NO=0) | ISW(17) = 1 |
| MAXIMUM 50 TABLES (YES=1, NO=0) | ISW(18) = 1 |
| METEOROLOGICAL DATA INPUT METHOD (PRE-PROCESSED=1, CARD=2) | ISW(19) = 1 |
| RURAL-URBAN OPTION (RURAL=0, URBAN MODE 1=1, URBAN MODE 2=2) | ISW(20) = 0 |
| WIND PROFILE EXPONENT VALUES (DEFAULTS=1, USER ENTERS=2, 3) | ISW(21) = 1 |
| VERTICAL PDT. TEMP. GRADIENT VALUES (DEFAULTS=1, USER ENTERS=2, 3) | ISW(22) = 1 |
| SCALE EMISSION RATES FOR ALL SOURCES (NO=0, YES>0) | ISW(23) = 0 |
| PROGRAM CALCULATES FINAL PLUME RISE ONLY (YES=1, NO=2) | ISW(24) = 2 |
| PROGRAM ADJUSTS ALL STACK HEIGHTS FOR DOWNWASH (YES=2, NO=1) | ISW(25) = 1 |
| | |
| INPUT SPECIAL DIRECTION-DEPENDENT BUILDING DIMENSIONS (YES=1, NO=0) | ISW(26) = 0 |
| | |
| OMIT TABLES FOR HOURLY CONCENTRATIONS (YES=1, NO=0) | ISW(27) = 0 |
| | |
| USEPA ADJUSTMENT FOR CALM HOURS (YES=1, NO=0) | ISW(28) = 1 |
| | |
| NUMBER OF INPUT SOURCES | NSOURC = 1 |
| NUMBER OF SOURCE GROUPS (=0, ALL SOURCES) | NGROUP = 0 |
| TIME PERIOD INTERVAL TO BE PRINTED (=0, ALL INTERVALS) | IPERD = 0 |
| NUMBER OF X (RANGE) GRID VALUES | NXPNTS = 2 |
| NUMBER OF Y (THETA) GRID VALUES | NYPNTS = 36 |
| NUMBER OF DISCRETE RECEPTORS | NXWYPT = 0 |
| SOURCE EMISSION RATE UNITS CONVERSION FACTOR | TK = 10000E+07 |
| ENTRAINMENT COEFFICIENT FOR UNSTABLE ATMOSPHERE | BETA1 = 0.600 |
| ENTRAINMENT COEFFICIENT FOR STABLE ATMOSPHERE | BETA2 = 0.600 |
| HEIGHT ABOVE GROUND AT WHICH WIND SPEED WAS MEASURED | ZR = 10.00 METERS |
| LOGICAL UNIT NUMBER OF METEOROLOGICAL DATA | IMET = 9 |
| DECAY COEFFICIENT FOR PHYSICAL OR CHEMICAL DEPLETION | DECAY = 0.000000E+00 |
| SURFACE STATION NO. | ISS = 12815 |
| YEAR OF SURFACE DATA | ISY = 77 |
| UPPER AIR STATION NO. | IUS = 12842 |
| YEAR OF UPPER AIR DATA | IUY = 77 |
| ALLOCATED DATA STORAGE | LIMIT = 49500 WORDS |

IST-11

1977 - NRG ONLY - SO₂
 Radius of Influence check

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

*** RANGES OF POLAR GRID SYSTEM ***
(METERS)

6000. 0. 9000. 0.

*** RADIAL ANGLES OF POLAR GRID SYSTEM ***

(DEGREES)

| | | | | | | | | | |
|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| 10. 0. | 20. 0. | 30. 0. | 40. 0. | 50. 0. | 60. 0. | 70. 0. | 80. 0. | 90. 0. | 100. 0. |
| 110. 0. | 120. 0. | 130. 0. | 140. 0. | 150. 0. | 160. 0. | 170. 0. | 180. 0. | 190. 0. | 200. 0. |
| 210. 0. | 220. 0. | 230. 0. | 240. 0. | 250. 0. | 260. 0. | 270. 0. | 280. 0. | 290. 0. | 300. 0. |
| 310. 0. | 320. 0. | 330. 0. | 340. 0. | 350. 0. | 360. 0. | | | | |

*** SOURCE DATA ***

| SOURCE NUMBER | P E | K CATS. | T W Y A NUMBER PART. | EMISSION RATE | X | Y | BASE ELEV. | HEIGHT | TEMP. | EXIT VEL. | BLDG. HEIGHT | BLDG. LENGTH | BLDG. WIDTH | |
|---------------|-----|---------|----------------------------|---|-----|-----|---------------|--------|----------|-----------|-----------------|-----------------|----------------|----------|
| | | | | TYPE=0.1 (GRAMS/SEC) TYPE=2 (GRAMS/SEC) *PER METER**2 | | | | | (METERS) | (METERS) | | | | (METERS) |
| 101 | 0 | 0 | 0 | 0.15800E+02 | 0.0 | 0.0 | 0.0 | 38.10 | 450.00 | 20.00 | 1.83 | 22.00 | 38.10 | 19.80 |

"N"-DAY
365 DAYS
SGROUP# 1

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* 365-DAY AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 0.40844 AND OCCURRED AT (6000.0, 360.0) *

DIRECTION / RANGE (METERS)
(DEGREES) / 6000.0 9000.0

| | | |
|---------|---------|---------|
| 360.0 / | 0.40844 | 0.31027 |
| 350.0 / | 0.21292 | 0.16356 |
| 340.0 / | 0.20980 | 0.16820 |
| 330.0 / | 0.16592 | 0.12708 |
| 320.0 / | 0.17839 | 0.13333 |
| 310.0 / | 0.21567 | 0.16233 |
| 300.0 / | 0.26123 | 0.19857 |
| 290.0 / | 0.15242 | 0.10964 |
| 280.0 / | 0.20330 | 0.15168 |
| 270.0 / | 0.38588 | 0.29219 |
| 260.0 / | 0.23438 | 0.18275 |
| 250.0 / | 0.24464 | 0.18907 |
| 240.0 / | 0.32688 | 0.25813 |
| 230.0 / | 0.36562 | 0.30325 |
| 220.0 / | 0.24903 | 0.21109 |
| 210.0 / | 0.23952 | 0.19483 |
| 200.0 / | 0.19066 | 0.14858 |
| 190.0 / | 0.16696 | 0.12614 |
| 180.0 / | 0.38485 | 0.29658 |
| 170.0 / | 0.19964 | 0.14526 |
| 160.0 / | 0.15425 | 0.11554 |
| 150.0 / | 0.12483 | 0.08612 |
| 140.0 / | 0.15799 | 0.10700 |
| 130.0 / | 0.14607 | 0.09750 |
| 120.0 / | 0.17574 | 0.12893 |
| 110.0 / | 0.14827 | 0.10608 |
| 100.0 / | 0.13379 | 0.09368 |
| 90.0 / | 0.23190 | 0.17332 |
| 80.0 / | 0.14010 | 0.10916 |
| 70.0 / | 0.13393 | 0.09786 |
| 60.0 / | 0.20608 | 0.15871 |
| 50.0 / | 0.21143 | 0.16311 |
| 40.0 / | 0.16738 | 0.12709 |
| 30.0 / | 0.10867 | 0.07811 |
| 20.0 / | 0.15285 | 0.11299 |
| 10.0 / | 0.16356 | 0.11676 |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* 50 MAXIMUM 3-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CON | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) | RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) |
|------|----------|------|-----|------------------------------|---|------|----------|------|-----|------------------------------|---|
| 1 | 13.24128 | 1 | 363 | 6000.0 | 180.0 | 26 | 10.70436 | 1 | 277 | 6000.0 | 200.0 |
| 2 | 12.34964 | 1 | 65 | 6000.0 | 360.0 | 27 | 10.70103 | 6 | 362 | 6000.0 | 150.0 |
| 3 | 12.30647 | 7 | 349 | 6000.0 | 360.0 | 28 | 10.68139 | 6 | 192 | 6000.0 | 310.0 |
| 4 | 12.12723 | 2 | 113 | 6000.0 | 310.0 | 29 | 10.60998 | 8 | 177 | 6000.0 | 90.0 |
| 5 | 12.02491 | 8 | 30 | 6000.0 | 200.0 | 30 | 10.56925 | 7 | 258 | 6000.0 | 280.0 |
| 6 | 11.92087 | 2 | 232 | 6000.0 | 360.0 | 31 | 10.56719 | 2 | 278 | 9000.0 | 220.0 |
| 7 | 11.80747 | 8 | 258 | 6000.0 | 270.0 | 32 | 10.55478 | 1 | 304 | 6000.0 | 210.0 |
| 8 | 11.79754 | 7 | 217 | 6000.0 | 260.0 | 33 | 10.53723 | 4 | 137 | 6000.0 | 270.0 |
| 9 | 11.72029 | 2 | 71 | 9000.0 | 260.0 | 34 | 10.49820 | 7 | 258 | 9000.0 | 280.0 |
| 10 | 11.60291 | 7 | 115 | 6000.0 | 80.0 | 35 | 10.49688 | 1 | 203 | 6000.0 | 210.0 |
| 11 | 11.53215 | 2 | 232 | 9000.0 | 360.0 | 36 | 10.46495 | 8 | 169 | 9000.0 | 360.0 |
| 12 | 11.42884 | 8 | 169 | 6000.0 | 360.0 | 37 | 10.45971 | 2 | 2 | 6000.0 | 180.0 |
| 13 | 11.38942 | 7 | 93 | 6000.0 | 320.0 | 38 | 10.44018 | 2 | 69 | 6000.0 | 250.0 |
| 14 | 11.38033 | 8 | 258 | 9000.0 | 270.0 | 39 | 10.35293 | 1 | 172 | 6000.0 | 360.0 |
| 15 | 11.23593 | 1 | 290 | 6000.0 | 140.0 | 40 | 10.33081 | 7 | 194 | 6000.0 | 230.0 |
| 16 | 11.19431 | 8 | 30 | 9000.0 | 200.0 | 41 | 10.24345 | 2 | 278 | 6000.0 | 220.0 |
| 17 | 11.17484 | 8 | 354 | 6000.0 | 360.0 | 42 | 10.21492 | 7 | 240 | 6000.0 | 260.0 |
| 18 | 11.07355 | 1 | 115 | 6000.0 | 50.0 | 43 | 10.17913 | 3 | 57 | 6000.0 | 310.0 |
| 19 | 11.03877 | 1 | 305 | 6000.0 | 160.0 | 44 | 10.17207 | 7 | 292 | 6000.0 | 90.0 |
| 20 | 11.01578 | 7 | 66 | 6000.0 | 210.0 | 45 | 10.15751 | 2 | 157 | 6000.0 | 60.0 |
| 21 | 11.01637 | 1 | 197 | 9000.0 | 230.0 | 46 | 10.00225 | 2 | 21 | 6000.0 | 90.0 |
| 22 | 11.01349 | 2 | 51 | 6000.0 | 360.0 | 47 | 9.94113 | 2 | 339 | 6000.0 | 340.0 |
| 23 | 10.95810 | 2 | 113 | 9000.0 | 310.0 | 48 | 9.90943 | 1 | 62 | 6000.0 | 220.0 |
| 24 | 10.95224 | 1 | 363 | 9000.0 | 180.0 | 49 | 9.87413 | 2 | 345 | 6000.0 | 160.0 |
| 25 | 10.94841 | 2 | 30 | 6000.0 | 180.0 | 50 | 9.85206 | 8 | 157 | 6000.0 | 40.0 |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* HIGHEST 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *
* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 5 38792 AND OCCURRED AT (6000.0, 360.0) *

DIRECTION / RANGE (METERS)
(DEGREES) / 6000.0 9000.0

| | | |
|---------|--------------------|------------------|
| 350.0 / | 5 38792 (354, 1) ✓ | 4 17750 (233, 1) |
| 350.0 / | 2 34704 (63, 1) | 1 50939 (50, 1) |
| 340.0 / | 2 71796 (153, 1) | 2 12544 (153, 1) |
| 330.0 / | 2 21663 (338, 1) | 1 69891 (338, 1) |
| 320.0 / | 2 45705 (93, 1) | 1 98275 (93, 1) |
| 310.0 / | 2 77059 (113, 1) | 2 33521 (113, 1) |
| 300.0 / | 4 34043 (62, 1) | 2 85549 (62, 1) |
| 290.0 / | 2 20336 (86, 1) | 1 47754 (86, 1) |
| 280.0 / | 2 23767 (258, 1) | 1 94944 (258, 1) |
| 270.0 / | 3 49479 (242, 1) | 2 61154 (258, 1) |
| 260.0 / | 2 46861 (245, 1) | 2 34425 (71, 1) |
| 250.0 / | 2 37980 (69, 1) | 2 00716 (69, 1) |
| 240.0 / | 2 89491 (277, 1) | 2 17555 (297, 1) |
| 230.0 / | 3 14901 (103, 1) | 2 32401 (243, 1) |
| 220.0 / | 2 31716 (242, 1) | 2 13797 (242, 1) |
| 210.0 / | 3 03887 (102, 1) | 2 41921 (102, 1) |
| 200.0 / | 2 49407 (277, 1) | 1 93312 (277, 1) |
| 190.0 / | 2 81815 (344, 1) | 1 70191 (344, 1) |
| 180.0 / | 4 64455 (40, 1) | 2 94191 (40, 1) |
| 170.0 / | 3 32750 (316, 1) | 2 54192 (316, 1) |
| 160.0 / | 3 69473 (305, 1) | 2 65787 (305, 1) |
| 150.0 / | 2 29065 (32, 1) | 1 67400 (32, 1) |
| 140.0 / | 2 00079 (360, 1) | 1 34399 (290, 1) |
| 130.0 / | 2 60313 (19, 1) | 1 54772 (19, 1) |
| 120.0 / | 1 72479 (330, 1) | 1 22832 (16, 1) |
| 110.0 / | 2 16103 (76, 1) | 1 52628 (76, 1) |
| 100.0 / | 3 04155 (36, 1) | 1 92378 (47, 1) |
| 90.0 / | 2 88794 (21, 1) | 2 49736 (21, 1) |
| 80.0 / | 2 40165 (115, 1) | 1 89393 (115, 1) |
| 70.0 / | 2 11793 (114, 1) | 1 30525 (114, 1) |
| 60.0 / | 2 75867 (77, 1) | 1 90074 (77, 1) |
| 50.0 / | 2 74567 (78, 1) | 1 99056 (78, 1) |
| 40.0 / | 2 67823 (157, 1) | 2 01641 (157, 1) |
| 30.0 / | 2 19559 (234, 1) | 1 48623 (234, 1) |
| 20.0 / | 2 04639 (49, 1) | 1 50755 (49, 1) |
| 10.0 / | 1 61717 (65, 1) | 1 30862 (149, 1) |

8
✓

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* SECOND HIGHEST 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *
* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 5.37707 AND OCCURRED AT (6000.0, 360.0) *

| DIRECTION / (DEGREES) / | RANGE (METERS) | |
|----------------------------|--------------------|------------------|
| | 6000.0 | 9000.0 |
| 360.0 / | 5.37707 (233, 1) ✓ | 4.07466 (354, 1) |
| 350.0 / | 2.03467 (92, 1) | 1.50913 (63, 1) |
| 340.0 / | 2.57800 (229, 1) | 2.02636 (229, 1) |
| 330.0 / | 1.99198 (307, 1) | 1.68924 (307, 1) |
| 320.0 / | 1.89317 (87, 1) | 1.35257 (87, 1) |
| 310.0 / | 2.43635 (121, 1) | 1.74391 (57, 1) |
| 300.0 / | 3.12730 (86, 1) | 2.77583 (215, 1) |
| 290.0 / | 1.72628 (53, 1) | 1.40385 (54, 1) |
| 280.0 / | 1.87918 (70, 1) | 1.98745 (111, 1) |
| 270.0 / | 2.87414 (258, 1) | 2.49244 (242, 1) |
| 260.0 / | 1.98343 (71, 1) | 1.65546 (245, 1) |
| 250.0 / | 1.95324 (297, 1) | 1.45588 (297, 1) |
| 240.0 / | 2.61774 (297, 1) | 2.07550 (277, 1) |
| 230.0 / | 2.59037 (131, 1) | 2.24798 (324, 1) |
| 220.0 / | 2.23254 (205, 1) | 1.79262 (205, 1) |
| 210.0 / | 2.66882 (304, 1) | 2.00902 (205, 1) |
| 200.0 / | 2.23668 (99, 1) | 1.78933 (30, 1) |
| 190.0 / | 1.48615 (40, 1) | 1.25536 (361, 1) |
| 180.0 / | 3.52669 (38, 1) | 2.63779 (363, 1) |
| 170.0 / | 2.49218 (31, 1) | 1.69237 (31, 1) |
| 160.0 / | 2.82257 (96, 1) | 1.95649 (345, 1) |
| 150.0 / | 2.01349 (362, 1) | 1.42523 (362, 1) |
| 140.0 / | 1.91615 (290, 1) | 1.34355 (360, 1) |
| 130.0 / | 2.12089 (21, 1) | 1.50881 (21, 1) |
| 120.0 / | 1.59194 (59, 1) | 1.18418 (330, 1) |
| 110.0 / | 1.94589 (128, 1) | 1.36485 (128, 1) |
| 100.0 / | 2.43852 (47, 1) | 1.85914 (36, 1) |
| 90.0 / | 2.88408 (36, 1) | 2.04052 (299, 1) |
| 80.0 / | 1.89737 (300, 1) | 1.40890 (300, 1) |
| 70.0 / | 1.65130 (329, 1) | 1.29422 (15, 1) |
| 60.0 / | 2.37176 (157, 1) | 1.78172 (259, 1) |
| 50.0 / | 2.57174 (282, 1) | 1.94552 (282, 1) |
| 40.0 / | 1.59209 (203, 1) | 1.44828 (203, 1) |
| 30.0 / | 1.87356 (251, 1) | 1.18860 (251, 1) |
| 20.0 / | 1.87049 (50, 1) | 1.31028 (50, 1) |
| 10.0 / | 1.60281 (27, 1) | 1.20102 (50, 1) |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* 50 MAXIMUM 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CON. | PER | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) | RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) |
|------|---------|-----|-----|------------------------------|---|------|---------|------|-----|------------------------------|---|
| 1 | 5.38792 | 1 | 354 | 5000.0 | 360.0 | 26 | 3.03987 | 1 | 102 | 5000.0 | 210.0 |
| 2 | 5.37707 | 1 | 233 | 5000.0 | 360.0 | 27 | 2.94181 | 1 | 40 | 9000.0 | 180.0 |
| 3 | 5.06414 | 1 | 65 | 5000.0 | 360.0 | 28 | 2.89491 | 1 | 277 | 5000.0 | 240.0 |
| 4 | 4.64456 | 1 | 40 | 5000.0 | 180.0 | 29 | 2.88794 | 1 | 21 | 5000.0 | 90.0 |
| 5 | 4.34043 | 1 | 62 | 5000.0 | 300.0 | 30 | 2.88408 | 1 | 36 | 5000.0 | 90.0 |
| 6 | 4.17750 | 1 | 233 | 9000.0 | 360.0 | 31 | 2.87414 | 1 | 258 | 5000.0 | 270.0 |
| 7 | 4.11961 | 1 | 172 | 5000.0 | 360.0 | 32 | 2.86379 | 1 | 2 | 5000.0 | 180.0 |
| 8 | 4.07466 | 1 | 354 | 9000.0 | 360.0 | 33 | 2.85549 | 1 | 62 | 9000.0 | 300.0 |
| 9 | 4.02912 | 1 | 335 | 5000.0 | 360.0 | 34 | 2.84946 | 1 | 240 | 5000.0 | 270.0 |
| 10 | 3.69473 | 1 | 305 | 5000.0 | 160.0 | 35 | 2.82257 | 1 | 95 | 5000.0 | 160.0 |
| 11 | 3.60265 | 1 | 65 | 9000.0 | 360.0 | 36 | 2.81815 | 1 | 344 | 5000.0 | 190.0 |
| 12 | 3.52569 | 1 | 39 | 5000.0 | 180.0 | 37 | 2.80464 | 1 | 245 | 5000.0 | 270.0 |
| 13 | 3.49478 | 1 | 242 | 5000.0 | 270.0 | 38 | 2.77583 | 1 | 215 | 9000.0 | 300.0 |
| 14 | 3.48819 | 1 | 172 | 9000.0 | 360.0 | 39 | 2.77353 | 1 | 355 | 5000.0 | 360.0 |
| 15 | 3.42728 | 1 | 41 | 5000.0 | 180.0 | 40 | 2.77058 | 1 | 113 | 5000.0 | 310.0 |
| 16 | 3.34400 | 1 | 344 | 5000.0 | 180.0 | 41 | 2.76747 | 1 | 215 | 5000.0 | 300.0 |
| 17 | 3.32750 | 1 | 316 | 5000.0 | 170.0 | 42 | 2.75867 | 1 | 77 | 5000.0 | 60.0 |
| 18 | 3.31174 | 1 | 27 | 5000.0 | 360.0 | 43 | 2.74567 | 1 | 78 | 5000.0 | 50.0 |
| 19 | 3.24962 | 1 | 363 | 5000.0 | 180.0 | 44 | 2.71796 | 1 | 153 | 5000.0 | 340.0 |
| 20 | 3.20340 | 1 | 6 | 5000.0 | 360.0 | 45 | 2.70981 | 1 | 348 | 5000.0 | 360.0 |
| 21 | 3.17759 | 1 | 30 | 5000.0 | 180.0 | 46 | 2.69999 | 1 | 232 | 5000.0 | 360.0 |
| 22 | 3.14901 | 1 | 103 | 5000.0 | 230.0 | 47 | 2.68896 | 1 | 39 | 5000.0 | 180.0 |
| 23 | 3.13716 | 1 | 12 | 5000.0 | 180.0 | 48 | 2.67981 | 1 | 64 | 5000.0 | 360.0 |
| 24 | 3.12730 | 1 | 86 | 5000.0 | 300.0 | 49 | 2.67823 | 1 | 157 | 5000.0 | 40.0 |
| 25 | 3.04156 | 1 | 36 | 5000.0 | 100.0 | 50 | 2.66982 | 1 | 304 | 5000.0 | 210.0 |

| | |
|---|----------------------|
| CALCULATE (CONCENTRATION=1, DEPOSITION=2) | ISW(1) = 1 |
| RECEPTOR GRID SYSTEM (RECTANGULAR=1 OR 3, POLAR=2 OR 4) | ISW(2) = 4 |
| DISCRETE RECEPTOR SYSTEM (RECTANGULAR=1, POLAR=2) | ISW(3) = 2 |
| TERRAIN ELEVATIONS ARE READ (YES=1, NO=0) | ISW(4) = 0 |
| CALCULATIONS ARE WRITTEN TO TAPE (YES=1, NO=0) | ISW(5) = 0 |
| LIST ALL INPUT DATA (NO=0, YES=1, MET DATA ALSO=2) | ISW(6) = 1 |
| | |
| COMPUTE AVERAGE CONCENTRATION (OR TOTAL DEPOSITION) | |
| WITH THE FOLLOWING TIME PERIODS: | |
| HOURLY (YES=1, NO=0) | ISW(7) = 0 |
| 2-HOUR (YES=1, NO=0) | ISW(8) = 0 |
| 3-HOUR (YES=1, NO=0) | ISW(9) = 1 |
| 4-HOUR (YES=1, NO=0) | ISW(10) = 0 |
| 6-HOUR (YES=1, NO=0) | ISW(11) = 0 |
| 8-HOUR (YES=1, NO=0) | ISW(12) = 0 |
| 12-HOUR (YES=1, NO=0) | ISW(13) = 0 |
| 24-HOUR (YES=1, NO=0) | ISW(14) = 1 |
| PRINT "N"-DAY TABLE(S) (YES=1, NO=0) | ISW(15) = 1 |
| | |
| PRINT THE FOLLOWING TYPES OF TABLES WHOSE TIME PERIODS ARE SPECIFIED BY ISW(7) THROUGH ISW(14): | |
| DAILY TABLES (YES=1, NO=0) | ISW(16) = 0 |
| HIGHEST & SECOND HIGHEST TABLES (YES=1, NO=0) | ISW(17) = 1 |
| MAXIMUM 50 TABLES (YES=1, NO=0) | ISW(18) = 1 |
| METEOROLOGICAL DATA INPUT METHOD (PRE-PROCESSED=1, CARD=2) | ISW(19) = 1 |
| RURAL-URBAN OPTION (RURAL=0, URBAN MODE 1=1, URBAN MODE 2=2) | ISW(20) = 0 |
| WIND PROFILE EXPONENT VALUES (DEFAULTS=1, USER ENTERS=2, 3) | ISW(21) = 1 |
| VERTICAL PDT. TEMP. GRADIENT VALUES (DEFAULTS=1, USER ENTERS=2, 3) | ISW(22) = 1 |
| SCALE EMISSION RATES FOR ALL SOURCES (NO=0, YES>0) | ISW(23) = 0 |
| PROGRAM CALCULATES FINAL PLUME RISE ONLY (YES=1, NO=2) | ISW(24) = 2 |
| PROGRAM ADJUSTS ALL STACK HEIGHTS FOR DOWNWASH (YES=2, NO=1) | ISW(25) = 1 |
| | |
| INPUT SPECIAL DIRECTION-DEPENDENT BUILDING DIMENSIONS (YES=1, NO=0) | ISW(26) = 0 |
| | |
| OMIT TABLES FOR HOURLY CONCENTRATIONS (YES=1, NO=0) | ISW(27) = 0 |
| | |
| USEPA ADJUSTMENT FOR CALM HOURS (YES=1, NO=0) | ISW(28) = 1 |
| | |
| NUMBER OF INPUT SOURCES | NSOURC = 1 |
| NUMBER OF SOURCE GROUPS (=0, ALL SOURCES) | NORGRP = 0 |
| TIME PERIOD INTERVAL TO BE PRINTED (=0, ALL INTERVALS) | IPERD = 0 |
| NUMBER OF X (RANGE) GRID VALUES | NXPNTS = 5 |
| NUMBER OF Y (THETA) GRID VALUES | NYPNTS = 36 |
| NUMBER OF DISCRETE RECEPTORS | NXWYPT = 0 |
| SOURCE EMISSION RATE UNITS CONVERSION FACTOR | TK = 10000E+07 |
| ENTRAINMENT COEFFICIENT FOR UNSTABLE ATMOSPHERE | BETA1 = 0.600 |
| ENTRAINMENT COEFFICIENT FOR STABLE ATMOSPHERE | BETA2 = 0.600 |
| HEIGHT ABOVE GROUND AT WHICH WIND SPEED WAS MEASURED | ZR = 10.00 METERS |
| LOGICAL UNIT NUMBER OF METEOROLOGICAL DATA | IMET = 9 |
| DECAY COEFFICIENT FOR PHYSICAL OR CHEMICAL DEPLETION | DECAY = 0.000000E+00 |
| SURFACE STATION NO. | ISS = 12815 |
| YEAR OF SURFACE DATA | ISY = 78 |
| UPPER AIR STATION NO. | IUS = 12842 |
| YEAR OF UPPER AIR DATA | IUY = 78 |
| ALLOCATED DATA STORAGE | LIMIT = 43300 WORDS |

IST-12

1978 - NRG ONLY - 502

*** NRC/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09

*** RANGES OF POLAR GRID SYSTEM ***
(METERS)

500.0, 1000.0, 1500.0, 2000.0, 2500.0,

*** RADIAL ANGLES OF POLAR GRID SYSTEM ***

(DEGREES)

10.0, 20.0, 30.0, 40.0, 50.0, 60.0, 70.0, 80.0, 90.0, 100.0,
110.0, 120.0, 130.0, 140.0, 150.0, 160.0, 170.0, 180.0, 190.0, 200.0,
210.0, 220.0, 230.0, 240.0, 250.0, 260.0, 270.0, 280.0, 290.0, 300.0,
310.0, 320.0, 330.0, 340.0, 350.0, 360.0,

*** SOURCE DATA ***

| SOURCE NUMBER | P K E | Y A NUMBER | PART. CATS. | EMISSION RATE | | X (METERS) | Y (METERS) | BASE ELEV. (METERS) | HEIGHT (METERS) | TEMP. | EXIT VEL. | BLDG. HEIGHT (METERS) | BLDG. LENGTH (METERS) | BLDG. WIDTH (METERS) | |
|---------------|-------|------------|-------------|-----------------------------|----------------------------|------------|------------|---------------------|-----------------|------------------------------------|-----------|-----------------------|-----------------------|----------------------|-------|
| | | | | TYPE=0.1 (GRAMS/SEC) TYPE=2 | (DEG. K); VERT. DIM TYPE=1 | | | | | (M/SEC); HORZ. DIM DIAMETER TYPE=0 | | | | | |
| 101 | 0 0 | 0 | 0 | 0.15800E+02 | | 0.0 | 0.0 | 0.0 | 38.10 | 450.00 | 20.00 | 1.83 | 22.00 | 38.10 | 19.80 |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* 365-DAY AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 0.87472 AND OCCURRED AT (1000.0, 270.0) *

| DIRECTION / (DEGREES) / | RANGE (METERS) | | | | |
|----------------------------|----------------|-----------|---------|---------|---------|
| | 500.0 | 1000.0 | 1500.0 | 2000.0 | 2500.0 |
| 360.0 / | 0.47095 | 0.60725 | 0.59614 | 0.53378 | 0.46856 |
| 350.0 / | 0.42780 | 0.57967 | 0.55405 | 0.48487 | 0.42125 |
| 340.0 / | 0.39913 | 0.55727 | 0.54922 | 0.49778 | 0.44700 |
| 330.0 / | 0.35493 | 0.50376 | 0.51170 | 0.47368 | 0.43161 |
| 320.0 / | 0.29994 | 0.45855 | 0.45506 | 0.40921 | 0.36422 |
| 310.0 / | 0.33483 | 0.52644 | 0.52237 | 0.46754 | 0.41383 |
| 300.0 / | 0.37309 | 0.57559 | 0.56534 | 0.50563 | 0.44824 |
| 290.0 / | 0.31353 | 0.48433 | 0.45660 | 0.39002 | 0.32920 |
| 280.0 / | 0.44287 | 0.64801 | 0.63220 | 0.55888 | 0.48746 |
| 270.0 / | 0.61447 | 0.87472 ✓ | 0.85938 | 0.76860 | 0.67795 |
| 260.0 / | 0.52403 | 0.76560 | 0.74052 | 0.65608 | 0.57776 |
| 250.0 / | 0.38444 | 0.57685 | 0.55084 | 0.48563 | 0.42868 |
| 240.0 / | 0.42374 | 0.61213 | 0.59396 | 0.52918 | 0.46817 |
| 230.0 / | 0.43221 | 0.61837 | 0.60945 | 0.55150 | 0.49349 |
| 220.0 / | 0.37287 | 0.53161 | 0.53129 | 0.49591 | 0.45642 |
| 210.0 / | 0.34446 | 0.46712 | 0.46775 | 0.43828 | 0.40313 |
| 200.0 / | 0.30323 | 0.40867 | 0.42225 | 0.39820 | 0.36755 |
| 190.0 / | 0.29895 | 0.40504 | 0.43340 | 0.40802 | 0.37009 |
| 180.0 / | 0.41874 | 0.57492 | 0.65396 | 0.64754 | 0.61160 |
| 170.0 / | 0.25827 | 0.35352 | 0.39040 | 0.38095 | 0.35790 |
| 160.0 / | 0.17974 | 0.24714 | 0.26649 | 0.25301 | 0.23248 |
| 150.0 / | 0.19255 | 0.28021 | 0.29250 | 0.26906 | 0.24093 |
| 140.0 / | 0.23600 | 0.32811 | 0.32475 | 0.28774 | 0.24908 |
| 130.0 / | 0.23170 | 0.32018 | 0.31915 | 0.28457 | 0.24718 |
| 120.0 / | 0.23373 | 0.29930 | 0.31183 | 0.29034 | 0.26228 |
| 110.0 / | 0.15909 | 0.19746 | 0.20410 | 0.19211 | 0.17609 |
| 100.0 / | 0.17811 | 0.21299 | 0.21582 | 0.20408 | 0.18765 |
| 90.0 / | 0.26003 | 0.30733 | 0.31219 | 0.29422 | 0.26999 |
| 80.0 / | 0.16451 | 0.20288 | 0.18882 | 0.16656 | 0.14621 |
| 70.0 / | 0.15200 | 0.19396 | 0.18351 | 0.16568 | 0.14783 |
| 60.0 / | 0.21210 | 0.25617 | 0.24378 | 0.21956 | 0.19538 |
| 50.0 / | 0.23287 | 0.28408 | 0.27880 | 0.25692 | 0.23158 |
| 40.0 / | 0.24642 | 0.30702 | 0.30976 | 0.29072 | 0.26538 |
| 30.0 / | 0.19249 | 0.25174 | 0.23569 | 0.20642 | 0.17847 |
| 20.0 / | 0.26903 | 0.34218 | 0.32358 | 0.28795 | 0.25425 |
| 10.0 / | 0.30711 | 0.39841 | 0.37600 | 0.32887 | 0.28382 |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* HIGHEST 3-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *
* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 97.44953 AND OCCURRED AT (500.0, 360.0) *

| DIRECTION / (DEGREES) / | RANGE (METERS) | | | | |
|----------------------------|-------------------|-------------------|-------------------|-------------------|-------------------|
| | 500.0 | 1000.0 | 1500.0 | 2000.0 | 2500.0 |
| 360.0 / | 37.44953 (103, 4) | 30.14454 (103, 4) | 26.23345 (25, 7) | 22.18445 (25, 7) | 18.56799 (25, 7) |
| 350.0 / | 31.50995 (129, 4) | 32.77479 (160, 4) | 27.47127 (160, 4) | 20.64319 (160, 4) | 15.90941 (183, 3) |
| 340.0 / | 28.70117 (67, 4) | 28.06080 (154, 4) | 23.85571 (199, 4) | 18.51227 (210, 4) | 15.85706 (210, 4) |
| 330.0 / | 27.95366 (108, 4) | 24.79239 (100, 5) | 21.00276 (100, 5) | 20.37369 (124, 6) | 18.96557 (124, 6) |
| 320.0 / | 19.06355 (108, 4) | 26.51271 (222, 4) | 21.89275 (173, 5) | 16.41958 (173, 5) | 13.49049 (62, 1) |
| 310.0 / | 21.59093 (107, 4) | 29.99939 (107, 4) | 24.77109 (107, 4) | 18.46552 (107, 4) | 13.94359 (96, 6) |
| 300.0 / | 19.94055 (218, 4) | 25.58083 (218, 4) | 21.11969 (78, 5) | 18.43715 (83, 6) | 16.41856 (83, 6) |
| 290.0 / | 16.98837 (205, 5) | 26.16680 (176, 5) | 19.97172 (239, 6) | 16.06837 (113, 4) | 14.47482 (113, 4) |
| 280.0 / | 26.04930 (148, 5) | 22.34625 (148, 5) | 21.86708 (24, 5) | 19.73343 (24, 5) | 17.19540 (24, 5) |
| 270.0 / | 23.42101 (202, 5) | 29.12359 (5, 4) | 26.30125 (5, 4) | 22.25248 (171, 6) | 18.78496 (171, 6) |
| 260.0 / | 30.46677 (169, 5) | 31.56114 (149, 5) | 24.29491 (163, 6) | 21.55027 (163, 6) | 18.42956 (163, 6) |
| 250.0 / | 19.68361 (363, 5) | 21.73186 (310, 4) | 22.04144 (147, 3) | 20.73062 (147, 3) | 17.58260 (147, 3) |
| 240.0 / | 21.23634 (130, 5) | 22.91157 (106, 5) | 19.69555 (240, 6) | 16.41263 (295, 4) | 15.01893 (295, 4) |
| 230.0 / | 16.21202 (106, 5) | 27.19122 (267, 4) | 24.93867 (267, 4) | 18.89749 (267, 4) | 16.73174 (261, 4) |
| 220.0 / | 21.55201 (252, 5) | 22.03493 (252, 5) | 20.09024 (269, 6) | 17.43155 (271, 6) | 16.48894 (271, 6) |
| 210.0 / | 18.50878 (362, 5) | 28.34539 (145, 5) | 20.58163 (145, 5) | 16.12827 (243, 5) | 13.73678 (362, 5) |
| 200.0 / | 26.21179 (35, 5) | 20.10141 (125, 4) | 18.39189 (315, 5) | 16.12008 (315, 5) | 13.65922 (315, 5) |
| 190.0 / | 20.70784 (305, 5) | 21.44284 (305, 5) | 22.33116 (305, 5) | 20.77850 (305, 5) | 18.44253 (305, 5) |
| 180.0 / | 20.12180 (304, 6) | 24.01109 (324, 4) | 23.85118 (305, 4) | 22.94385 (305, 4) | 20.77239 (305, 4) |
| 170.0 / | 15.45237 (346, 4) | 20.68510 (3, 5) | 18.35333 (3, 5) | 18.26977 (344, 7) | 17.36134 (344, 7) |
| 150.0 / | 14.58790 (307, 5) | 21.75807 (81, 4) | 18.13301 (307, 7) | 18.45617 (307, 7) | 17.27543 (307, 7) |
| 150.0 / | 17.49275 (110, 4) | 24.25380 (254, 4) | 18.74823 (254, 4) | 14.11609 (27, 2) | 12.96796 (306, 8) |
| 140.0 / | 25.62579 (76, 2) | 24.72219 (279, 5) | 23.69379 (117, 1) | 22.90183 (117, 1) | 20.80256 (117, 1) |
| 130.0 / | 29.51460 (117, 5) | 33.05315 (117, 5) | 25.29531 (117, 5) | 18.29951 (117, 5) | 15.95914 (15, 2) |
| 120.0 / | 18.99419 (53, 4) | 18.02203 (280, 5) | 19.11464 (14, 8) | 18.28886 (14, 8) | 16.49141 (14, 8) |
| 110.0 / | 18.69740 (182, 4) | 13.17018 (37, 6) | 14.22946 (37, 6) | 13.49823 (37, 6) | 12.10848 (37, 6) |
| 100.0 / | 29.02392 (9, 3) | 23.04952 (9, 3) | 20.22072 (9, 3) | 17.06297 (9, 3) | 14.31251 (9, 3) |
| 90.0 / | 30.75609 (14, 4) | 30.74945 (14, 4) | 31.25569 (14, 3) | 30.30799 (14, 3) | 27.62382 (14, 3) |
| 80.0 / | 27.35587 (26, 6) | 23.39766 (26, 6) | 21.41953 (26, 6) | 18.53104 (26, 6) | 15.78138 (26, 6) |
| 70.0 / | 19.43826 (116, 5) | 21.63144 (353, 5) | 21.46620 (353, 5) | 19.30012 (353, 5) | 16.78950 (353, 5) |
| 60.0 / | 22.54489 (134, 5) | 20.12167 (134, 5) | 17.58084 (69, 6) | 15.65998 (69, 6) | 13.54869 (69, 6) |
| 50.0 / | 27.00461 (135, 5) | 23.98187 (133, 4) | 20.90428 (133, 4) | 19.83321 (69, 2) | 18.51837 (69, 2) |
| 40.0 / | 16.96014 (343, 6) | 21.27450 (122, 5) | 19.30234 (211, 6) | 17.29160 (343, 6) | 13.34885 (343, 6) |
| 30.0 / | 15.36483 (136, 4) | 18.34457 (119, 4) | 15.87947 (97, 4) | 14.68782 (133, 7) | 13.43392 (133, 7) |
| 20.0 / | 22.69603 (25, 5) | 25.73012 (155, 4) | 23.51567 (155, 4) | 19.65970 (160, 6) | 18.23744 (160, 6) |
| 10.0 / | 21.49105 (212, 5) | 22.67545 (135, 5) | 18.50319 (136, 5) | 15.85314 (335, 2) | 16.52397 (335, 2) |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* SECOND HIGHEST 3-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *
* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 35.77426 AND OCCURRED AT (500.0, 360.0) *

| DIRECTION / (DEGREES) / | RANGE (METERS) | | | | |
|----------------------------|-------------------|-------------------|-------------------|-------------------|-------------------|
| | 500.0 | 1000.0 | 1500.0 | 2000.0 | 2500.0 |
| 360.0 / | 35.77426 (25, 7) | 29.86373 (25, 7) | 22.59195 (103, 4) | 19.40127 (339, 2) | 18.06190 (339, 2) |
| 350.0 / | 29.87691 (128, 4) | 26.56101 (129, 4) | 21.70296 (209, 4) | 18.99332 (183, 3) | 15.56996 (160, 4) |
| 340.0 / | 21.90015 (128, 4) | 26.19862 (199, 4) | 23.21114 (154, 4) | 18.44829 (199, 4) | 14.51355 (67, 4) |
| 330.0 / | 23.99033 (73, 4) | 24.46399 (207, 5) | 20.82523 (124, 6) | 16.73416 (100, 5) | 14.16851 (208, 7) |
| 320.0 / | 17.35112 (173, 5) | 26.31162 (173, 5) | 19.27838 (222, 4) | 15.00330 (62, 1) | 13.12112 (66, 5) |
| 310.0 / | 18.67464 (203, 5) | 22.47362 (218, 4) | 17.60027 (218, 4) | 14.52039 (96, 6) | 13.85591 (107, 4) |
| 300.0 / | 17.27955 (226, 6) | 23.32203 (78, 5) | 19.66086 (83, 6) | 15.35339 (78, 5) | 13.30508 (124, 1) |
| 290.0 / | 15.70864 (176, 5) | 21.76333 (239, 6) | 18.06429 (203, 6) | 15.61636 (239, 6) | 12.60001 (203, 6) |
| 280.0 / | 22.52061 (24, 5) | 22.11240 (24, 5) | 18.75465 (94, 5) | 15.89355 (93, 4) | 13.82423 (202, 6) |
| 270.0 / | 22.65897 (169, 4) | 27.68127 (204, 3) | 26.19700 (204, 3) | 21.69811 (204, 3) | 18.53326 (169, 6) |
| 260.0 / | 29.44081 (149, 5) | 29.18978 (169, 5) | 23.50407 (149, 5) | 18.04235 (169, 5) | 14.29884 (169, 5) |
| 250.0 / | 17.89966 (146, 4) | 21.23470 (131, 5) | 17.20777 (310, 4) | 16.03796 (243, 6) | 14.56494 (243, 6) |
| 240.0 / | 18.08436 (106, 5) | 21.52020 (87, 4) | 18.79404 (262, 3) | 15.54069 (262, 3) | 14.69140 (264, 6) |
| 230.0 / | 16.08192 (252, 5) | 22.85009 (323, 5) | 20.11261 (323, 5) | 18.51074 (261, 4) | 16.39332 (318, 6) |
| 220.0 / | 16.57910 (161, 5) | 21.27081 (269, 5) | 17.41081 (64, 4) | 16.82749 (269, 6) | 13.93786 (269, 6) |
| 210.0 / | 18.18969 (258, 4) | 24.16330 (258, 4) | 19.11567 (258, 4) | 15.81189 (362, 5) | 13.36299 (289, 4) |
| 200.0 / | 16.93779 (35, 4) | 19.75914 (35, 5) | 17.13925 (125, 4) | 15.45487 (344, 5) | 13.65828 (344, 5) |
| 190.0 / | 17.57305 (304, 4) | 21.14047 (304, 4) | 21.44532 (304, 4) | 19.47917 (304, 4) | 17.04256 (304, 4) |
| 180.0 / | 18.96327 (305, 4) | 22.64371 (281, 4) | 20.93482 (324, 4) | 18.69160 (344, 3) | 16.70563 (344, 3) |
| 170.0 / | 13.11914 (3, 5) | 17.79844 (322, 5) | 17.42680 (344, 7) | 15.06952 (291, 6) | 14.35053 (291, 6) |
| 160.0 / | 12.73738 (308, 5) | 19.79949 (308, 5) | 18.10226 (81, 4) | 14.16253 (361, 6) | 13.89463 (361, 6) |
| 150.0 / | 14.80307 (27, 2) | 18.23391 (110, 4) | 15.25261 (359, 4) | 13.62525 (307, 6) | 12.85353 (307, 6) |
| 140.0 / | 19.46937 (117, 1) | 21.29819 (117, 1) | 20.33238 (279, 5) | 16.40855 (76, 2) | 13.85326 (76, 2) |
| 130.0 / | 18.16185 (255, 5) | 24.53806 (249, 4) | 19.59733 (359, 5) | 17.16721 (15, 2) | 13.53559 (117, 5) |
| 120.0 / | 18.75292 (53, 1) | 17.49487 (14, 8) | 17.86474 (116, 8) | 17.20661 (116, 8) | 15.60700 (116, 8) |
| 110.0 / | 12.65993 (37, 6) | 11.56946 (328, 4) | 11.73030 (15, 6) | 11.89161 (15, 6) | 11.25292 (15, 6) |
| 100.0 / | 14.09389 (75, 6) | 15.07927 (57, 4) | 15.17939 (75, 6) | 14.32843 (75, 6) | 12.86955 (75, 6) |
| 90.0 / | 23.09727 (14, 3) | 28.27552 (14, 3) | 28.04441 (14, 4) | 24.32839 (14, 4) | 20.85316 (14, 4) |
| 80.0 / | 17.31566 (110, 5) | 18.13328 (111, 6) | 15.31245 (111, 6) | 12.39599 (339, 5) | 11.48266 (339, 5) |
| 70.0 / | 17.41640 (353, 5) | 18.33103 (121, 6) | 15.23844 (121, 6) | 13.06208 (199, 6) | 11.67433 (50, 8) |
| 60.0 / | 20.04561 (69, 6) | 18.16549 (69, 6) | 16.48668 (134, 5) | 14.56321 (110, 6) | 13.34123 (110, 6) |
| 50.0 / | 16.20815 (343, 5) | 21.89733 (353, 4) | 19.64567 (353, 4) | 15.92730 (133, 4) | 12.66535 (343, 5) |
| 40.0 / | 16.69690 (122, 5) | 20.47173 (211, 6) | 18.52708 (343, 6) | 15.29124 (243, 4) | 14.17808 (355, 7) |
| 30.0 / | 14.65049 (73, 6) | 15.64268 (136, 4) | 14.98080 (133, 7) | 12.83605 (73, 6) | 11.17868 (73, 6) |
| 20.0 / | 21.94656 (25, 6) | 20.37306 (184, 5) | 17.90274 (160, 6) | 19.25942 (155, 4) | 15.96506 (69, 1) |
| 10.0 / | 18.23502 (44, 5) | 21.68046 (212, 5) | 16.60122 (212, 5) | 14.19597 (335, 1) | 14.14126 (335, 1) |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* 50 MAXIMUM 3-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) | RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) |
|------|----------|------|-----|------------------------------|---|------|----------|------|-----|------------------------------|---|
| 1 | 37.44953 | 4 | 103 | 500.0 | 360.0 | 26 | 27.81701 | 5 | 143 | 1000.0 | 260.0 |
| 2 | 35.77426 | 7 | 25 | 500.0 | 360.0 | 27 | 27.68127 | 3 | 204 | 1000.0 | 270.0 |
| 3 | 33.05315 | 5 | 117 | 1000.0 | 130.0 | 28 | 27.62382 | 3 | 14 | 2500.0 | 90.0 |
| 4 | 32.77479 | 4 | 160 | 1000.0 | 350.0 | 29 | 27.47127 | 4 | 160 | 1500.0 | 350.0 |
| 5 | 31.56114 | 5 | 149 | 1000.0 | 260.0 | 30 | 27.35587 | 6 | 26 | 500.0 | 80.0 |
| 6 | 31.50995 | 4 | 129 | 500.0 | 350.0 | 31 | 27.19122 | 4 | 267 | 1000.0 | 230.0 |
| 7 | 31.25569 | 3 | 14 | 1500.0 | 90.0 | 32 | 27.00461 | 5 | 135 | 500.0 | 50.0 |
| 8 | 30.75609 | 4 | 14 | 500.0 | 90.0 | 33 | 26.56101 | 4 | 129 | 1000.0 | 350.0 |
| 9 | 30.74945 | 4 | 14 | 1000.0 | 90.0 | 34 | 26.51271 | 4 | 222 | 1000.0 | 320.0 |
| 10 | 30.46677 | 5 | 169 | 500.0 | 260.0 | 35 | 26.31162 | 5 | 173 | 1000.0 | 320.0 |
| 11 | 30.30799 | 3 | 14 | 2000.0 | 90.0 | 36 | 26.30125 | 4 | 5 | 1500.0 | 270.0 |
| 12 | 30.14454 | 4 | 103 | 1000.0 | 360.0 | 37 | 26.23345 | 7 | 25 | 1500.0 | 360.0 |
| 13 | 29.99939 | 4 | 107 | 1000.0 | 310.0 | 38 | 26.21179 | 5 | 35 | 500.0 | 200.0 |
| 14 | 29.86373 | 7 | 25 | 1000.0 | 360.0 | 39 | 26.19900 | 3 | 204 | 1500.0 | 270.0 |
| 15 | 29.51460 | 5 | 117 | 500.0 | 130.0 | 40 | 26.19862 | 4 | 199 | 1000.0 | 340.0 |
| 16 | 29.44081 | 5 | 149 | 500.0 | 260.0 | 41 | 26.16680 | 5 | 176 | 1000.0 | 290.0 |
| 17 | 29.18978 | 5 | 169 | 1000.0 | 260.0 | 42 | 26.04930 | 5 | 149 | 500.0 | 280.0 |
| 18 | 29.12359 | 4 | 5 | 1000.0 | 270.0 | 43 | 25.74158 | 5 | 191 | 1000.0 | 340.0 |
| 19 | 29.02352 | 3 | 9 | 500.0 | 100.0 | 44 | 25.73012 | 4 | 155 | 1000.0 | 20.0 |
| 20 | 28.70117 | 4 | 67 | 500.0 | 340.0 | 45 | 25.62579 | 2 | 76 | 500.0 | 140.0 |
| 21 | 28.34539 | 5 | 145 | 1000.0 | 210.0 | 46 | 25.58083 | 4 | 218 | 1000.0 | 300.0 |
| 22 | 28.27552 | 3 | 14 | 1000.0 | 90.0 | 47 | 25.29531 | 5 | 117 | 1500.0 | 130.0 |
| 23 | 28.06080 | 4 | 154 | 1000.0 | 340.0 | 48 | 24.93867 | 4 | 267 | 1500.0 | 230.0 |
| 24 | 28.04441 | 4 | 14 | 1500.0 | 90.0 | 49 | 24.79239 | 5 | 100 | 1000.0 | 330.0 |
| 25 | 27.96366 | 4 | 108 | 500.0 | 330.0 | 50 | 24.77109 | 4 | 107 | 1500.0 | 310.0 |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* HIGHEST 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *
* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 10.70997 AND OCCURRED AT (500.0, 120.0) *

| DIRECTION / (DEGREES) / | RANGE (METERS) | | | | |
|----------------------------|------------------|------------------|------------------|------------------|------------------|
| | 500.0 | 1000.0 | 1500.0 | 2000.0 | 2500.0 |
| 360.0 / | 7.59728 (25, 1) | 8.01000 (102, 1) | 6.59415 (102, 1) | 5.98955 (338, 1) | 5.43918 (338, 1) |
| 350.0 / | 5.96546 (120, 1) | 7.08690 (160, 1) | 6.10308 (160, 1) | 4.93809 (102, 1) | 4.14120 (102, 1) |
| 340.0 / | 5.13574 (128, 1) | 6.20465 (154, 1) | 6.18975 (210, 1) | 6.27710 (210, 1) | 6.13522 (210, 1) |
| 330.0 / | 6.26256 (108, 1) | 5.38422 (108, 1) | 5.78069 (208, 1) | 5.81042 (208, 1) | 5.39571 (208, 1) |
| 320.0 / | 5.27073 (66, 1) | 6.15638 (222, 1) | 5.47367 (66, 1) | 5.00379 (66, 1) | 4.45590 (66, 1) |
| 310.0 / | 5.75491 (107, 1) | 7.25854 (222, 1) | 6.17389 (222, 1) | 5.68085 (84, 1) | 5.17545 (84, 1) |
| 300.0 / | 6.69087 (203, 1) | 8.89368 (203, 1) | 7.44336 (203, 1) | 5.73062 (203, 1) | 4.66334 (83, 1) |
| 290.0 / | 4.27753 (113, 1) | 6.10003 (205, 1) | 5.37936 (205, 1) | 4.89865 (113, 1) | 4.37851 (113, 1) |
| 280.0 / | 6.02166 (24, 1) | 6.56550 (24, 1) | 6.52775 (24, 1) | 6.22624 (113, 1) | 5.69187 (113, 1) |
| 270.0 / | 8.20945 (169, 1) | 8.88185 (169, 1) | 8.48256 (169, 1) | 7.56839 (169, 1) | 6.63636 (169, 1) |
| 260.0 / | 6.20119 (143, 1) | 9.23877 (143, 1) | 7.35122 (163, 1) | 6.32239 (163, 1) | 5.75160 (166, 1) |
| 250.0 / | 5.90052 (363, 1) | 7.29073 (106, 1) | 6.16336 (147, 1) | 5.54640 (147, 1) | 4.71629 (147, 1) |
| 240.0 / | 4.43383 (114, 1) | 6.38607 (240, 1) | 6.02201 (262, 1) | 5.15703 (262, 1) | 4.29061 (262, 1) |
| 230.0 / | 4.17384 (269, 1) | 6.61940 (269, 1) | 6.02649 (267, 1) | 5.49735 (104, 1) | 5.19584 (104, 1) |
| 220.0 / | 3.75574 (235, 1) | 5.73207 (235, 1) | 5.69504 (271, 1) | 5.15031 (271, 1) | 4.48094 (271, 1) |
| 210.0 / | 3.58015 (35, 1) | 5.31541 (145, 1) | 4.40236 (316, 1) | 5.08902 (23, 1) | 5.16265 (23, 1) |
| 200.0 / | 9.80635 (35, 1) | 7.83268 (35, 1) | 6.93662 (35, 1) | 5.86683 (35, 1) | 4.95052 (34, 1) |
| 190.0 / | 6.17331 (40, 1) | 6.32430 (40, 1) | 6.82457 (40, 1) | 6.47142 (40, 1) | 5.79906 (40, 1) |
| 180.0 / | 6.41220 (40, 1) | 7.35098 (325, 1) | 8.71223 (325, 1) | 8.67996 (40, 1) | 8.03113 (40, 1) |
| 170.0 / | 5.15225 (346, 1) | 5.98559 (41, 1) | 6.40212 (41, 1) | 6.01758 (41, 1) | 5.39157 (41, 1) |
| 160.0 / | 7.21567 (307, 1) | 7.65533 (307, 1) | 8.83478 (307, 1) | 8.84388 (307, 1) | 8.27646 (307, 1) |
| 150.0 / | 4.90381 (27, 1) | 6.01182 (27, 1) | 6.12570 (27, 1) | 5.40125 (27, 1) | 4.58711 (27, 1) |
| 140.0 / | 7.12285 (117, 1) | 7.70725 (117, 1) | 7.24199 (117, 1) | 6.30301 (117, 1) | 5.37339 (117, 1) |
| 130.0 / | 8.34800 (117, 1) | 9.08746 (117, 1) | 7.88861 (117, 1) | 6.47824 (117, 1) | 5.31939 (117, 1) |
| 120.0 / | 10.70997 (53, 1) | 9.30574 (53, 1) | 9.06439 (53, 1) | 8.19082 (53, 1) | 7.18154 (53, 1) |
| 110.0 / | 4.27132 (15, 1) | 4.76438 (15, 1) | 5.13721 (15, 1) | 4.90318 (15, 1) | 4.49291 (15, 1) |
| 100.0 / | 4.78800 (9, 1) | 3.95764 (9, 1) | 4.13186 (20, 1) | 3.89778 (20, 1) | 3.51311 (20, 1) |
| 90.0 / | 7.71339 (14, 1) | 8.81616 (14, 1) | 9.43496 (14, 1) | 9.08126 (14, 1) | 8.28287 (14, 1) |
| 80.0 / | 8.50077 (26, 1) | 7.43148 (26, 1) | 7.05120 (26, 1) | 6.23133 (26, 1) | 5.36744 (26, 1) |
| 70.0 / | 3.00899 (69, 1) | 3.78208 (353, 1) | 4.00207 (353, 1) | 3.76542 (353, 1) | 3.37235 (353, 1) |
| 60.0 / | 6.66723 (69, 1) | 5.67636 (69, 1) | 5.31260 (69, 1) | 4.69428 (69, 1) | 4.08108 (69, 1) |
| 50.0 / | 6.50497 (69, 1) | 5.98376 (69, 1) | 6.01686 (69, 1) | 5.52780 (69, 1) | 4.87990 (69, 1) |
| 40.0 / | 6.14499 (135, 1) | 5.76162 (135, 1) | 5.53586 (135, 1) | 4.81102 (135, 1) | 4.29024 (334, 1) |
| 30.0 / | 5.66436 (133, 1) | 5.89447 (133, 1) | 5.76399 (133, 1) | 5.21258 (133, 1) | 4.56092 (133, 1) |
| 20.0 / | 5.58036 (25, 1) | 6.91232 (184, 1) | 6.08696 (184, 1) | 5.79885 (355, 1) | 5.41915 (355, 1) |
| 10.0 / | 4.71980 (212, 1) | 5.14278 (212, 1) | 4.40052 (335, 1) | 5.09248 (335, 1) | 5.14326 (335, 1) |

*** NRC/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* SECOND HIGHEST 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *
* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 8.64737 AND OCCURRED AT (1500.0, 180.0) *

| DIRECTION / (DEGREES) / | RANGE (METERS) | | | | |
|----------------------------|------------------|------------------|------------------|------------------|------------------|
| | 500.0 | 1000.0 | 1500.0 | 2000.0 | 2500.0 |
| 360.0 / | 7.27505 (103, 1) | 7.21490 (120, 1) | 6.43100 (338, 1) | 5.02163 (339, 1) | 4.60127 (339, 1) |
| 350.0 / | 5.78545 (129, 1) | 6.68645 (102, 1) | 5.96461 (102, 1) | 4.70673 (160, 1) | 3.62979 (160, 1) |
| 340.0 / | 5.06993 (190, 1) | 5.61947 (199, 1) | 5.90849 (199, 1) | 5.38576 (199, 1) | 4.90572 (196, 1) |
| 330.0 / | 4.74314 (124, 1) | 5.37578 (158, 1) | 5.71299 (124, 1) | 5.54222 (124, 1) | 5.09759 (124, 1) |
| 320.0 / | 3.87613 (108, 1) | 5.46498 (66, 1) | 5.01248 (222, 1) | 4.09978 (190, 1) | 3.76314 (8, 1) |
| 310.0 / | 3.73184 (123, 1) | 6.60579 (107, 1) | 5.88300 (107, 1) | 5.29506 (80, 1) | 4.74552 (80, 1) |
| 300.0 / | 5.02005 (83, 1) | 6.03373 (83, 1) | 5.91768 (83, 1) | 5.31132 (83, 1) | 4.49956 (7, 1) |
| 290.0 / | 4.09379 (205, 1) | 5.54755 (203, 1) | 5.24908 (113, 1) | 4.11331 (205, 1) | 3.10875 (205, 1) |
| 280.0 / | 5.83623 (148, 1) | 6.06222 (94, 1) | 6.35506 (113, 1) | 5.86186 (24, 1) | 5.08585 (24, 1) |
| 270.0 / | 5.50310 (131, 1) | 7.56716 (204, 1) | 6.86572 (204, 1) | 6.54300 (168, 1) | 5.90432 (168, 1) |
| 260.0 / | 5.91612 (163, 1) | 7.91022 (163, 1) | 7.07589 (143, 1) | 5.10552 (166, 1) | 5.41753 (163, 1) |
| 250.0 / | 5.16256 (106, 1) | 5.59142 (363, 1) | 5.69307 (363, 1) | 5.26134 (363, 1) | 4.66160 (363, 1) |
| 240.0 / | 4.40557 (106, 1) | 6.10909 (262, 1) | 5.25056 (240, 1) | 3.94614 (234, 1) | 3.52398 (234, 1) |
| 230.0 / | 3.95436 (237, 1) | 6.43944 (267, 1) | 5.87858 (269, 1) | 4.87179 (267, 1) | 4.70187 (318, 1) |
| 220.0 / | 3.73272 (271, 1) | 5.49206 (271, 1) | 4.86311 (235, 1) | 3.69076 (235, 1) | 3.60166 (277, 1) |
| 210.0 / | 3.32890 (77, 1) | 4.98604 (316, 1) | 4.33713 (23, 1) | 3.49625 (316, 1) | 3.09385 (362, 1) |
| 200.0 / | 3.54647 (36, 1) | 4.49349 (145, 1) | 5.22150 (36, 1) | 5.19048 (36, 1) | 4.91206 (35, 1) |
| 190.0 / | 5.52059 (35, 1) | 5.28176 (35, 1) | 5.64718 (36, 1) | 5.74814 (36, 1) | 5.39742 (35, 1) |
| 180.0 / | 6.05157 (344, 1) | 7.25072 (40, 1) | 8.64737 (40, 1) | 8.63106 (325, 1) | 7.95840 (325, 1) |
| 170.0 / | 4.69836 (41, 1) | 4.91099 (346, 1) | 5.43070 (346, 1) | 5.36193 (346, 1) | 5.02675 (346, 1) |
| 160.0 / | 3.67072 (346, 1) | 4.61921 (81, 1) | 3.90012 (81, 1) | 3.69841 (346, 1) | 3.44307 (346, 1) |
| 150.0 / | 2.93850 (110, 1) | 4.03856 (254, 1) | 4.44532 (307, 1) | 4.63946 (307, 1) | 4.43615 (307, 1) |
| 140.0 / | 4.00083 (76, 1) | 6.07384 (279, 1) | 5.45287 (279, 1) | 4.25036 (279, 1) | 3.77044 (29, 1) |
| 130.0 / | 5.22678 (53, 1) | 5.70290 (279, 1) | 4.89787 (279, 1) | 3.73176 (279, 1) | 3.24239 (10, 1) |
| 120.0 / | 4.36781 (28, 1) | 4.48341 (28, 1) | 5.06665 (15, 1) | 5.11732 (15, 1) | 4.83911 (15, 1) |
| 110.0 / | 3.21145 (53, 1) | 2.58734 (53, 1) | 2.79911 (14, 1) | 2.85702 (14, 1) | 2.70699 (14, 1) |
| 100.0 / | 4.17701 (116, 1) | 3.91162 (20, 1) | 3.68845 (9, 1) | 3.31048 (9, 1) | 2.95075 (9, 1) |
| 90.0 / | 6.51277 (26, 1) | 5.68687 (20, 1) | 6.65468 (20, 1) | 6.76321 (20, 1) | 6.45741 (20, 1) |
| 80.0 / | 3.60290 (69, 1) | 4.34771 (111, 1) | 3.64817 (111, 1) | 2.80649 (111, 1) | 2.22518 (111, 1) |
| 70.0 / | 2.94941 (353, 1) | 3.58452 (111, 1) | 3.31722 (13, 1) | 3.37006 (13, 1) | 3.14418 (13, 1) |
| 60.0 / | 3.82465 (135, 1) | 3.60011 (134, 1) | 3.50266 (20, 1) | 3.36268 (20, 1) | 3.03358 (20, 1) |
| 50.0 / | 5.06035 (135, 1) | 4.23192 (133, 1) | 4.23557 (355, 1) | 3.87167 (355, 1) | 3.40765 (355, 1) |
| 40.0 / | 4.11825 (85, 1) | 5.79320 (119, 1) | 5.09825 (334, 1) | 4.78622 (334, 1) | 4.09632 (135, 1) |
| 30.0 / | 3.11576 (119, 1) | 5.39946 (119, 1) | 4.12988 (119, 1) | 2.81727 (119, 1) | 2.68367 (74, 1) |
| 20.0 / | 4.97714 (184, 1) | 4.76671 (119, 1) | 5.68154 (355, 1) | 5.13504 (184, 1) | 4.41022 (184, 1) |
| 10.0 / | 4.37319 (44, 1) | 4.45661 (247, 1) | 4.00937 (247, 1) | 3.64531 (44, 1) | 3.29379 (44, 1) |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* 50 MAXIMUM 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) | RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) |
|------|----------|------|-----|------------------------------|---|------|---------|------|-----|------------------------------|---|
| 1 | 10.70997 | 1 | 53 | 500.0 | 120.0 | 26 | 8.01000 | 1 | 102 | 1000.0 | 360.0 |
| 2 | 9.80635 | 1 | 35 | 500.0 | 200.0 | 27 | 7.95840 | 1 | 325 | 2500.0 | 180.0 |
| 3 | 9.43496 | 1 | 14 | 1500.0 | 90.0 | 28 | 7.91022 | 1 | 163 | 1000.0 | 260.0 |
| 4 | 9.30574 | 1 | 53 | 1000.0 | 120.0 | 29 | 7.88861 | 1 | 117 | 1500.0 | 130.0 |
| 5 | 9.23877 | 1 | 143 | 1000.0 | 260.0 | 30 | 7.83268 | 1 | 35 | 1000.0 | 200.0 |
| 6 | 9.08746 | 1 | 117 | 1000.0 | 130.0 | 31 | 7.71339 | 1 | 14 | 500.0 | 90.0 |
| 7 | 9.08126 | 1 | 14 | 2000.0 | 90.0 | 32 | 7.70725 | 1 | 117 | 1000.0 | 140.0 |
| 8 | 9.06439 | 1 | 53 | 1500.0 | 120.0 | 33 | 7.65533 | 1 | 307 | 1000.0 | 160.0 |
| 9 | 8.89368 | 1 | 203 | 1000.0 | 300.0 | 34 | 7.59728 | 1 | 25 | 500.0 | 360.0 |
| 10 | 8.88185 | 1 | 169 | 1000.0 | 270.0 | 35 | 7.56938 | 1 | 169 | 2000.0 | 270.0 |
| 11 | 8.84388 | 1 | 307 | 2000.0 | 160.0 | 36 | 7.56716 | 1 | 204 | 1000.0 | 270.0 |
| 12 | 8.83478 | 1 | 307 | 1500.0 | 160.0 | 37 | 7.45771 | 1 | 11 | 1500.0 | 180.0 |
| 13 | 8.81616 | 1 | 14 | 1000.0 | 90.0 | 38 | 7.44336 | 1 | 203 | 1500.0 | 300.0 |
| 14 | 8.71223 | 1 | 325 | 1500.0 | 180.0 | 39 | 7.43148 | 1 | 26 | 1000.0 | 80.0 |
| 15 | 8.67996 | 1 | 40 | 2000.0 | 180.0 | 40 | 7.38475 | 1 | 149 | 1000.0 | 260.0 |
| 16 | 8.64737 | 1 | 40 | 1500.0 | 180.0 | 41 | 7.35122 | 1 | 163 | 1500.0 | 260.0 |
| 17 | 8.63106 | 1 | 325 | 2000.0 | 180.0 | 42 | 7.35098 | 1 | 325 | 1000.0 | 180.0 |
| 18 | 8.50077 | 1 | 25 | 500.0 | 80.0 | 43 | 7.29073 | 1 | 106 | 1000.0 | 250.0 |
| 19 | 8.48256 | 1 | 169 | 1500.0 | 270.0 | 44 | 7.27505 | 1 | 103 | 500.0 | 360.0 |
| 20 | 8.34800 | 1 | 117 | 500.0 | 130.0 | 45 | 7.25854 | 1 | 222 | 1000.0 | 310.0 |
| 21 | 8.28287 | 1 | 14 | 2500.0 | 90.0 | 46 | 7.25072 | 1 | 40 | 1000.0 | 180.0 |
| 22 | 8.27646 | 1 | 307 | 2500.0 | 160.0 | 47 | 7.24199 | 1 | 117 | 1500.0 | 140.0 |
| 23 | 8.20946 | 1 | 169 | 500.0 | 270.0 | 48 | 7.21567 | 1 | 307 | 500.0 | 160.0 |
| 24 | 8.18082 | 1 | 53 | 2000.0 | 120.0 | 49 | 7.21480 | 1 | 120 | 1000.0 | 360.0 |
| 25 | 8.03113 | 1 | 40 | 2500.0 | 180.0 | 50 | 7.18154 | 1 | 53 | 2500.0 | 120.0 |

| | |
|---|----------------------|
| CALCULATE (CONCENTRATION=1, DEPOSITION=2) | ISW(1) = 1 |
| RECEPTOR GRID SYSTEM (RECTANGULAR=1 OR 3, POLAR=2 OR 4) | ISW(2) = 4 |
| DISCRETE RECEPTOR SYSTEM (RECTANGULAR=1, POLAR=2) | ISW(3) = 2 |
| TERRAIN ELEVATIONS ARE READ (YES=1, NO=0) | ISW(4) = 0 |
| CALCULATIONS ARE WRITTEN TO TAPE (YES=1, NO=0) | ISW(5) = 0 |
| LIST ALL INPUT DATA (NO=0, YES=1, MET DATA ALSO=2) | ISW(6) = 1 |
| | |
| COMPUTE AVERAGE CONCENTRATION (OR TOTAL DEPOSITION) | |
| WITH THE FOLLOWING TIME PERIODS: | |
| HOURLY (YES=1, NO=0) | ISW(7) = 0 |
| 2-HOUR (YES=1, NO=0) | ISW(8) = 0 |
| 3-HOUR (YES=1, NO=0) | ISW(9) = 1 |
| 4-HOUR (YES=1, NO=0) | ISW(10) = 0 |
| 6-HOUR (YES=1, NO=0) | ISW(11) = 0 |
| 8-HOUR (YES=1, NO=0) | ISW(12) = 0 |
| 12-HOUR (YES=1, NO=0) | ISW(13) = 0 |
| 24-HOUR (YES=1, NO=0) | ISW(14) = 1 |
| PRINT "N"-DAY TABLE(S) (YES=1, NO=0) | ISW(15) = 0 |
| | |
| PRINT THE FOLLOWING TYPES OF TABLES WHOSE TIME PERIODS ARE | |
| SPECIFIED BY ISW(7) THROUGH ISW(14): | |
| DAILY TABLES (YES=1, NO=0) | ISW(16) = 0 |
| HIGHEST & SECOND HIGHEST TABLES (YES=1, NO=0) | ISW(17) = 0 |
| MAXIMUM 50 TABLES (YES=1, NO=0) | ISW(18) = 1 |
| METEOROLOGICAL DATA INPUT METHOD (PRE-PROCESSED=1, CARD=2) | ISW(19) = 1 |
| RURAL-URBAN OPTION (RURAL=0, URBAN MODE 1=1, URBAN MODE 2=2) | ISW(20) = 0 |
| WIND PROFILE EXPONENT VALUES (DEFAULTS=1, USER ENTERS=2, 3) | ISW(21) = 1 |
| VERTICAL POT. TEMP. GRADIENT VALUES (DEFAULTS=1, USER ENTERS=2, 3) | ISW(22) = 1 |
| SCALE EMISSION RATES FOR ALL SOURCES (NO=0, YES>0) | ISW(23) = 0 |
| PROGRAM CALCULATES FINAL PLUME RISE ONLY (YES=1, NO=2) | ISW(24) = 2 |
| PROGRAM ADJUSTS ALL STACK HEIGHTS FOR DOWNWASH (YES=2, NO=1) | ISW(25) = 1 |
| | |
| INPUT SPECIAL DIRECTION-DEPENDENT BUILDING DIMENSIONS (YES=1, NO=0) | ISW(26) = 0 |
| | |
| OMIT TABLES FOR HOURLY CONCENTRATIONS (YES=1, NO=0) | ISW(27) = 0 |
| | |
| USEPA ADJUSTMENT FOR CALM HOURS (YES=1, NO=0) | ISW(28) = 1 |
| | |
| NUMBER OF INPUT SOURCES | NSOURC = 1 |
| NUMBER OF SOURCE GROUPS (=0, ALL SOURCES) | NGROUP = 0 |
| TIME PERIOD INTERVAL TO BE PRINTED (=0, ALL INTERVALS) | IPERD = 0 |
| NUMBER OF X (RANGE) GRID VALUES | NXPNTS = 10 |
| NUMBER OF Y (THETA) GRID VALUES | NYPNTS = 36 |
| NUMBER OF DISCRETE RECEPTORS | NXWYPT = 0 |
| SOURCE EMISSION RATE UNITS CONVERSION FACTOR | TK = 10000E+07 |
| ENTRAINMENT COEFFICIENT FOR UNSTABLE ATMOSPHERE | BETA1 = 0.600 |
| ENTRAINMENT COEFFICIENT FOR STABLE ATMOSPHERE | BETA2 = 0.500 |
| HEIGHT ABOVE GROUND AT WHICH WIND SPEED WAS MEASURED | ZR = 10.00 METERS |
| LOGICAL UNIT NUMBER OF METEOROLOGICAL DATA | IMET = 9 |
| DECAY COEFFICIENT FOR PHYSICAL OR CHEMICAL DEPLETION | DECAY = 0.000000E+00 |
| SURFACE STATION NO. | ISS = 12815 |
| YEAR OF SURFACE DATA | ISY = 78 |
| UPPER AIR STATION NO. | IUS = 12842 |
| YEAR OF UPPER AIR DATA | IUY = 78 |
| ALLOCATED DATA STORAGE | LIMIT = 43500 WORDS |

IST-13

1978 - NRG ONLY - SO₂
(Selected Days)

*** NRG/RECOVERY GRDUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

*** RANGES OF POLAR GRID SYSTEM ***
(METERS)

| | | | | | | | | | |
|--------|--------|--------|--------|--------|--------|--------|---------|---------|---------|
| 200.0, | 300.0, | 400.0, | 600.0, | 700.0, | 800.0, | 900.0, | 1200.0, | 1400.0, | 1700.0, |
|--------|--------|--------|--------|--------|--------|--------|---------|---------|---------|

*** RADIAL ANGLES OF POLAR GRID SYSTEM ***

(DEGREES)

| | | | | | | | | | |
|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| 10.0, | 20.0, | 30.0, | 40.0, | 50.0, | 60.0, | 70.0, | 80.0, | 90.0, | 100.0, |
| 110.0, | 120.0, | 130.0, | 140.0, | 150.0, | 160.0, | 170.0, | 180.0, | 190.0, | 200.0, |
| 210.0, | 220.0, | 230.0, | 240.0, | 250.0, | 260.0, | 270.0, | 280.0, | 290.0, | 300.0, |
| 310.0, | 320.0, | 330.0, | 340.0, | 350.0, | 360.0, | | | | |

*** SOURCE DATA ***

| SOURCE NUMBER | T W Y A P K E E | PART. CATS. | EMISSION RATE TYPE=0.1 (GRAMS/SEC) | | | X (METERS) | Y (METERS) | BASE ELEV. (METERS) | HEIGHT (METERS) | TEMP. TYPE=0 (DEG. K); TYPE=1 | EXIT VEL. TYPE=0 (M/SEC); TYPE=1.2 | | BLDG. HEIGHT (METERS) | BLDG. LENGTH (METERS) | BLDG. WIDTH (METERS) |
|---------------|--------------------------|----------------|--|-----------------------|-----------------------|---------------|---------------|---------------------------|--------------------|--|---|-------|-----------------------------|-----------------------------|----------------------------|
| | | | TYPE=2 (GRAMS/SEC) *PER METER**2 | VERT. DIM (METERS) | HORZ. DIM (METERS) | | | | | DIAMETER (METERS) | | | | | |
| 101 | 0 0 | 0 | 0.15800E+02 | 0.0 | 0.0 | 0.0 | 38.10 | 450.00 | 20.00 | 1.83 | 22.00 | 38.10 | 19.80 | | |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* 50 MAXIMUM 3-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) | RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) |
|------|----------|------|-----|------------------------------|---|------|----------|------|-----|------------------------------|---|
| 1 | 77.82088 | 7 | 25 | 200.0 | 360.0 | 26 | 37.66792 | 4 | 14 | 400.0 | 90.0 |
| 2 | 64.77444 | 7 | 25 | 300.0 | 360.0 | 27 | 37.17531 | 6 | 25 | 200.0 | 10.0 |
| 3 | 58.28250 | 5 | 35 | 200.0 | 200.0 | 28 | 37.16309 | 3 | 53 | 200.0 | 120.0 |
| 4 | 53.37336 | 3 | 14 | 200.0 | 90.0 | 29 | 37.07553 | 1 | 53 | 300.0 | 120.0 |
| 5 | 52.55439 | 1 | 117 | 200.0 | 140.0 | 30 | 37.05155 | 4 | 53 | 300.0 | 120.0 |
| 6 | 52.16971 | 4 | 14 | 200.0 | 90.0 | 31 | 36.12422 | 5 | 35 | 400.0 | 200.0 |
| 7 | 51.37901 | 5 | 25 | 200.0 | 20.0 | 32 | 35.55608 | 4 | 25 | 200.0 | 350.0 |
| 8 | 51.30612 | 4 | 103 | 300.0 | 360.0 | 33 | 35.30158 | 7 | 40 | 200.0 | 180.0 |
| 9 | 50.61794 | 4 | 103 | 200.0 | 360.0 | 34 | 33.73544 | 4 | 103 | 700.0 | 360.0 |
| 10 | 49.47960 | 7 | 25 | 400.0 | 360.0 | 35 | 33.71002 | 5 | 117 | 900.0 | 130.0 |
| 11 | 48.92204 | 6 | 25 | 200.0 | 20.0 | 36 | 33.42348 | 5 | 117 | 800.0 | 130.0 |
| 12 | 47.64288 | 5 | 35 | 300.0 | 200.0 | 37 | 33.40190 | 4 | 103 | 600.0 | 360.0 |
| 13 | 47.08641 | 8 | 14 | 200.0 | 120.0 | 38 | 33.08783 | 3 | 25 | 200.0 | 340.0 |
| 14 | 45.83849 | 4 | 53 | 200.0 | 120.0 | 39 | 32.99199 | 4 | 103 | 800.0 | 360.0 |
| 15 | 45.27522 | 4 | 14 | 300.0 | 90.0 | 40 | 32.89828 | 4 | 14 | 300.0 | 80.0 |
| 16 | 45.00710 | 1 | 53 | 200.0 | 120.0 | 41 | 32.65398 | 5 | 149 | 800.0 | 260.0 |
| 17 | 44.44921 | 4 | 103 | 400.0 | 360.0 | 42 | 32.65229 | 3 | 14 | 400.0 | 90.0 |
| 18 | 43.74593 | 3 | 14 | 300.0 | 90.0 | 43 | 32.50929 | 5 | 149 | 900.0 | 260.0 |
| 19 | 42.76057 | 1 | 117 | 300.0 | 140.0 | 44 | 32.32430 | 4 | 160 | 900.0 | 350.0 |
| 20 | 42.13093 | 5 | 25 | 300.0 | 20.0 | 45 | 32.18642 | 2 | 53 | 200.0 | 120.0 |
| 21 | 40.22337 | 6 | 25 | 300.0 | 20.0 | 46 | 32.15305 | 3 | 117 | 200.0 | 130.0 |
| 22 | 39.11254 | 3 | 35 | 200.0 | 200.0 | 47 | 31.94650 | 3 | 35 | 300.0 | 200.0 |
| 23 | 38.97272 | 2 | 40 | 200.0 | 190.0 | 48 | 31.88848 | 4 | 14 | 200.0 | 80.0 |
| 24 | 38.71792 | 4 | 35 | 200.0 | 200.0 | 49 | 31.88504 | 2 | 40 | 300.0 | 190.0 |
| 25 | 37.99110 | 8 | 14 | 300.0 | 120.0 | 50 | 31.83500 | 5 | 149 | 300.0 | 260.0 |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* 50 MAXIMUM 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) | RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) |
|------|----------|------|-----|------------------------------|---|------|----------|------|-----|------------------------------|---|
| 1 | 26.92204 | 1 | 53 | 200.0 | 120.0 | 26 | 10.52921 | 1 | 14 | 400.0 | 90.0 |
| 2 | 23.19058 | 1 | 35 | 200.0 | 200.0 | 27 | 10.29445 | 1 | 25 | 300.0 | 20.0 |
| 3 | 21.62903 | 1 | 53 | 300.0 | 120.0 | 28 | 10.16100 | 1 | 117 | 400.0 | 130.0 |
| 4 | 19.89355 | 1 | 40 | 200.0 | 180.0 | 29 | 10.11795 | 1 | 103 | 200.0 | 360.0 |
| 5 | 18.79836 | 1 | 35 | 300.0 | 200.0 | 30 | 10.09590 | 1 | 103 | 300.0 | 360.0 |
| 6 | 17.06899 | 1 | 40 | 200.0 | 190.0 | 31 | 9.65639 | 1 | 40 | 400.0 | 190.0 |
| 7 | 16.77330 | 1 | 25 | 200.0 | 360.0 | 32 | 9.45623 | 1 | 117 | 400.0 | 140.0 |
| 8 | 16.72649 | 1 | 14 | 200.0 | 90.0 | 33 | 9.41813 | 1 | 14 | 1400.0 | 90.0 |
| 9 | 15.71473 | 1 | 53 | 400.0 | 120.0 | 34 | 9.36405 | 1 | 14 | 1700.0 | 90.0 |
| 10 | 15.65991 | 1 | 40 | 300.0 | 180.0 | 35 | 9.35610 | 1 | 53 | 1200.0 | 120.0 |
| 11 | 15.39277 | 1 | 35 | 200.0 | 190.0 | 36 | 9.34497 | 1 | 143 | 900.0 | 260.0 |
| 12 | 13.96221 | 1 | 35 | 400.0 | 200.0 | 37 | 9.24237 | 1 | 14 | 1200.0 | 90.0 |
| 13 | 13.88255 | 1 | 25 | 300.0 | 360.0 | 38 | 9.19522 | 1 | 53 | 1400.0 | 120.0 |
| 14 | 13.82227 | 1 | 14 | 300.0 | 90.0 | 39 | 9.16302 | 1 | 53 | 900.0 | 120.0 |
| 15 | 13.68217 | 1 | 40 | 300.0 | 190.0 | 40 | 9.08319 | 1 | 143 | 800.0 | 260.0 |
| 16 | 13.45715 | 1 | 53 | 200.0 | 130.0 | 41 | 9.08153 | 1 | 117 | 900.0 | 130.0 |
| 17 | 13.23301 | 1 | 117 | 200.0 | 140.0 | 42 | 9.01025 | 1 | 25 | 200.0 | 10.0 |
| 18 | 12.53798 | 1 | 25 | 200.0 | 20.0 | 43 | 8.93813 | 1 | 53 | 800.0 | 120.0 |
| 19 | 12.27805 | 1 | 117 | 200.0 | 130.0 | 44 | 8.86151 | 1 | 117 | 800.0 | 130.0 |
| 20 | 12.20868 | 1 | 35 | 300.0 | 190.0 | 45 | 8.81713 | 1 | 35 | 200.0 | 210.0 |
| 21 | 12.07056 | 1 | 117 | 300.0 | 130.0 | 46 | 8.76857 | 1 | 40 | 1700.0 | 180.0 |
| 22 | 12.01498 | 1 | 117 | 300.0 | 140.0 | 47 | 8.74162 | 1 | 53 | 1700.0 | 120.0 |
| 23 | 10.67634 | 1 | 53 | 300.0 | 130.0 | 48 | 8.74025 | 1 | 117 | 1200.0 | 130.0 |
| 24 | 10.64663 | 1 | 40 | 400.0 | 180.0 | 49 | 8.68049 | 1 | 103 | 400.0 | 360.0 |
| 25 | 10.55255 | 1 | 25 | 400.0 | 360.0 | 50 | 8.65381 | 1 | 25 | 200.0 | 340.0 |

*** LAKE COUNTY, FLORIDA EXISTING SO2 EMISSION SOURCE ANALYSIS 1 ***

| | |
|---|----------------------|
| CALCULATE (CONCENTRATION=1, DEPOSITION=2) | ISW(1) = 1 |
| RECEPTOR GRID SYSTEM (RECTANGULAR=1 OR 3, POLAR=2 OR 4) | ISW(2) = 3 |
| DISCRETE RECEPTOR SYSTEM (RECTANGULAR=1, POLAR=2) | ISW(3) = 1 |
| TERRAIN ELEVATIONS ARE READ (YES=1, NO=0) | ISW(4) = 0 |
| CALCULATIONS ARE WRITTEN TO TAPE (YES=1, NO=0) | ISW(5) = 0 |
| LIST ALL INPUT DATA (NO=0, YES=1, MET DATA ALSO=2) | ISW(6) = 1 |
| | |
| COMPUTE AVERAGE CONCENTRATION (OR TOTAL DEPOSITION) | |
| WITH THE FOLLOWING TIME PERIODS: | |
| HOURLY (YES=1, NO=0) | ISW(7) = 0 |
| 2-HOUR (YES=1, NO=0) | ISW(8) = 0 |
| 3-HOUR (YES=1, NO=0) | ISW(9) = 1 |
| 4-HOUR (YES=1, NO=0) | ISW(10) = 0 |
| 6-HOUR (YES=1, NO=0) | ISW(11) = 0 |
| 8-HOUR (YES=1, NO=0) | ISW(12) = 0 |
| 12-HOUR (YES=1, NO=0) | ISW(13) = 0 |
| 24-HOUR (YES=1, NO=0) | ISW(14) = 1 |
| PRINT "N"-DAY TABLE(S) (YES=1, NO=0) | ISW(15) = 1 |
| | |
| PRINT THE FOLLOWING TYPES OF TABLES WHOSE TIME PERIODS ARE | |
| SPECIFIED BY ISW(7) THROUGH ISW(14): | |
| DAILY TABLES (YES=1, NO=0) | ISW(16) = 0 |
| HIGHEST & SECOND HIGHEST TABLES (YES=1, NO=0) | ISW(17) = 0 |
| MAXIMUM 50 TABLES (YES=1, NO=0) | ISW(18) = 1 |
| METEOROLOGICAL DATA INPUT METHOD (PRE-PROCESSED=1, CARD=2) | ISW(19) = 1 |
| RURAL-URBAN OPTION (RURAL=0, URBAN MODE 1=1, URBAN MODE 2=2) | ISW(20) = 0 |
| WIND PROFILE EXPONENT VALUES (DEFAULTS=1, USER ENTERS=2, 3) | ISW(21) = 1 |
| VERTICAL POT. TEMP. GRADIENT VALUES (DEFAULTS=1, USER ENTERS=2, 3) | ISW(22) = 1 |
| SCALE EMISSION RATES FOR ALL SOURCES (NO=0, YES>0) | ISW(23) = 0 |
| PROGRAM CALCULATES FINAL PLUME RISE ONLY (YES=1, NO=2) | ISW(24) = 1 |
| PROGRAM ADJUSTS ALL STACK HEIGHTS FOR DOWNWASH (YES=2, NO=1) | ISW(25) = 1 |
| | |
| INPUT SPECIAL DIRECTION-DEPENDENT BUILDING DIMENSIONS (YES=1, NO=0) | ISW(26) = 0 |
| | |
| OMIT TABLES FOR HOURLY CONCENTRATIONS (YES=1, NO=0) | ISW(27) = 0 |
| | |
| USEPA ADJUSTMENT FOR CALM HOURS (YES=1, NO=0) | ISW(29) = 1 |
| | |
| NUMBER OF INPUT SOURCES | NSOURC = 1 |
| NUMBER OF SOURCE GROUPS (=0, ALL SOURCES) | NGROUP = 0 |
| TIME PERIOD INTERVAL TO BE PRINTED (=0, ALL INTERVALS) | IPERD = 0 |
| NUMBER OF X (RANGE) GRID VALUES | NXPNTS = 3 |
| NUMBER OF Y (THETA) GRID VALUES | NYPNTS = 3 |
| NUMBER OF DISCRETE RECEPTORS | NXWYPT = 0 |
| SOURCE EMISSION RATE UNITS CONVERSION FACTOR | TK = 1.0000E+07 |
| ENTRAINMENT COEFFICIENT FOR UNSTABLE ATMOSPHERE | BETA1 = 0.600 |
| ENTRAINMENT COEFFICIENT FOR STABLE ATMOSPHERE | BETA2 = 0.600 |
| HEIGHT ABOVE GROUND AT WHICH WIND SPEED WAS MEASURED | ZR = 10.00 METERS |
| LOGICAL UNIT NUMBER OF METEOROLOGICAL DATA | IMET = 9 |
| DECAY COEFFICIENT FOR PHYSICAL OR CHEMICAL DEPLETION | DECAY = 0.000000E+00 |
| SURFACE STATION NO. | ISS = 12815 |
| YEAR OF SURFACE DATA | ISY = 74 |
| UPPER AIR STATION NO. | IUS = 12842 |

IST-14

1974- EXISTING SO2

*** LAKE COUNTY, FLORIDA EXISTING SO2 EMISSION SOURCE ANALYSIS 1 ***

*** X-COORDINATES OF RECTANGULAR GRID SYSTEM ***
(METERS)

412600.0, 413100.0, 413600.0,

*** Y-COORDINATES OF RECTANGULAR GRID SYSTEM ***
(METERS)

3178800.0, 3179300.0, 3179800.0,

*** LAKE COUNTY, FLORIDA EXISTING SO2 EMISSION SOURCE ANALYSIS 1 ***

*** SOURCE DATA ***

| SOURCE NUMBER | T W Y A P K E E | PART. CATS. | EMISSION RATE | | X (METERS) | Y (METERS) | BASE ELEV. (METERS) | HEIGHT (METERS) | TEMP. | EXIT VEL. | BLDG. HEIGHT (METERS) | BLDG. LENGTH (METERS) | BLDG. WIDTH (METERS) |
|---------------|-----------------|-------------|--------------------|--------------------|------------|------------|---------------------|-----------------|--------------------|-----------|-----------------------|-----------------------|----------------------|
| | | | (GRAMS/SEC) TYPE=2 | (GRAMS/SEC) TYPE=1 | | | | | (DEG. K); (M/SEC); | (M/SEC); | | | |
| 321 | 0 0 0 | 0 | 0.25200E+01 | 407100.0 | 3180900.0 | 0.0 | 7.62 | 347.00 | 4.60 | 2.28 | 0.00 | 0.00 | 0.00 |

*** LAKE COUNTY, FLORIDA EXISTING SO2 EMISSION SOURCE ANALYSIS 1 ***

* 365-DAY AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 0.13788 AND OCCURRED AT (412600.0, 3179300.0) *

| Y-AXIS / (METERS) / | 412600.0 | 413100.0 | 413600.0 | X-AXIS (METERS) |
|------------------------|----------|----------|----------|-----------------|
| 3179800.0 / | 0.10368 | 0.09298 | 0.08716 | |
| 3179300.0 / | 0.13788 | 0.11398 | 0.09601 | |
| 3178800.0 / | 0.13717 | 0.12231 | 0.11699 | |

*** LAKE COUNTY, FLORIDA EXISTING SO2 EMISSION SOURCE ANALYSIS 1 ***

* 50 MAXIMUM 3-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y (METERS) OR DIRECTION (DEGREES) | RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y (METERS) OR DIRECTION (DEGREES) |
|------|----------|------|-----|------------------------------|--|------|---------|------|-----|------------------------------|--|
| 1 | 19.05912 | 1 | 123 | 412600.0 | 3178800.0 | 26 | 9.37227 | 7 | 99 | 412600.0 | 3178800.0 |
| 2 | 17.04555 | 7 | 42 | 412600.0 | 3178900.0 | 27 | 9.28386 | 8 | 76 | 413600.0 | 3178900.0 |
| 3 | 13.66376 | 2 | 72 | 412600.0 | 3179800.0 | 28 | 9.27248 | 2 | 339 | 412600.0 | 3178800.0 |
| 4 | 13.39333 | 2 | 72 | 413100.0 | 3179800.0 | 29 | 9.20109 | 2 | 167 | 412600.0 | 3178800.0 |
| 5 | 12.96172 | 7 | 122 | 412600.0 | 3179300.0 | 30 | 9.10289 | 8 | 363 | 412600.0 | 3179300.0 |
| 6 | 12.62529 | 8 | 105 | 412600.0 | 3178900.0 | 31 | 8.97414 | 8 | 53 | 412600.0 | 3179300.0 |
| 7 | 12.45089 | 2 | 72 | 413600.0 | 3179800.0 | 32 | 8.95339 | 1 | 192 | 412600.0 | 3179800.0 |
| 8 | 11.81661 | 1 | 22 | 412600.0 | 3179800.0 | 33 | 8.94586 | 2 | 197 | 413100.0 | 3179300.0 |
| 9 | 11.73769 | 1 | 290 | 413100.0 | 3178800.0 | 34 | 8.71251 | 7 | 42 | 413100.0 | 3178800.0 |
| 10 | 11.56313 | 1 | 290 | 413600.0 | 3178800.0 | 35 | 8.59277 | 1 | 22 | 413100.0 | 3179800.0 |
| 11 | 11.49473 | 7 | 7 | 412600.0 | 3178800.0 | 36 | 8.48931 | 7 | 76 | 412600.0 | 3178800.0 |
| 12 | 11.21153 | 1 | 114 | 412600.0 | 3178800.0 | 37 | 8.44285 | 1 | 123 | 413100.0 | 3178900.0 |
| 13 | 10.74944 | 1 | 155 | 412600.0 | 3179300.0 | 38 | 8.42083 | 1 | 155 | 413100.0 | 3179300.0 |
| 14 | 10.68153 | 8 | 122 | 413100.0 | 3179300.0 | 39 | 8.23106 | 7 | 343 | 412600.0 | 3178800.0 |
| 15 | 10.40887 | 8 | 122 | 412600.0 | 3179300.0 | 40 | 8.21079 | 1 | 17 | 412600.0 | 3179300.0 |
| 16 | 10.37902 | 8 | 122 | 413600.0 | 3178800.0 | 41 | 8.21034 | 2 | 114 | 412600.0 | 3179300.0 |
| 17 | 10.36398 | 8 | 122 | 413600.0 | 3179300.0 | 42 | 8.20055 | 8 | 15 | 412600.0 | 3179300.0 |
| 18 | 10.31273 | 7 | 122 | 413100.0 | 3179300.0 | 43 | 8.09617 | 8 | 315 | 413100.0 | 3179300.0 |
| 19 | 10.30344 | 8 | 315 | 412600.0 | 3179300.0 | 44 | 7.99526 | 8 | 95 | 413600.0 | 3179800.0 |
| 20 | 10.04313 | 2 | 197 | 413600.0 | 3179300.0 | 45 | 7.98327 | 8 | 337 | 413600.0 | 3179300.0 |
| 21 | 10.00814 | 8 | 95 | 412600.0 | 3179800.0 | 46 | 7.92699 | 8 | 53 | 413600.0 | 3178800.0 |
| 22 | 9.83764 | 1 | 125 | 412600.0 | 3179800.0 | 47 | 7.90606 | 1 | 338 | 413100.0 | 3178800.0 |
| 23 | 9.78934 | 8 | 95 | 413100.0 | 3179800.0 | 48 | 7.88056 | 7 | 90 | 413600.0 | 3179300.0 |
| 24 | 9.57186 | 8 | 17 | 413600.0 | 3178800.0 | 49 | 7.82501 | 8 | 335 | 412600.0 | 3178800.0 |
| 25 | 9.42575 | 7 | 76 | 413100.0 | 3178900.0 | 50 | 7.81500 | 1 | 364 | 413100.0 | 3178900.0 |

*** LAKE COUNTY, FLORIDA EXISTING SO2 EMISSION SOURCE ANALYSIS 1 ***

* 50 MAXIMUM 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) | RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) |
|------|---------|------|-----|------------------------------|---|------|---------|------|-----|------------------------------|---|
| 1 | 3.93549 | 1 | 122 | 412600.0 | 3179300.0 | 26 | 1.76651 | 1 | 17 | 413100.0 | 3178900.0 |
| 2 | 3.54613 | 1 | 122 | 413100.0 | 3179300.0 | 27 | 1.75282 | 1 | 72 | 413600.0 | 3179800.0 |
| 3 | 2.98500 | 1 | 123 | 412600.0 | 3178900.0 | 28 | 1.71920 | 1 | 351 | 412600.0 | 3178900.0 |
| 4 | 2.95024 | 1 | 7 | 412600.0 | 3178800.0 | 29 | 1.69353 | 1 | 351 | 413100.0 | 3178800.0 |
| 5 | 2.85949 | 1 | 42 | 412600.0 | 3178900.0 | 30 | 1.68975 | 1 | 22 | 412600.0 | 3179900.0 |
| 6 | 2.77543 | 1 | 122 | 413600.0 | 3178800.0 | 31 | 1.67723 | 1 | 95 | 412600.0 | 3179800.0 |
| 7 | 2.62075 | 1 | 122 | 413600.0 | 3179300.0 | 32 | 1.63961 | 1 | 125 | 412600.0 | 3179900.0 |
| 8 | 2.41749 | 1 | 76 | 413100.0 | 3178800.0 | 33 | 1.62338 | 1 | 342 | 412600.0 | 3178800.0 |
| 9 | 2.39724 | 1 | 17 | 413600.0 | 3178800.0 | 34 | 1.59562 | 1 | 351 | 413100.0 | 3179300.0 |
| 10 | 2.19351 | 1 | 72 | 412600.0 | 3179800.0 | 35 | 1.58188 | 1 | 95 | 413100.0 | 3179800.0 |
| 11 | 2.15951 | 1 | 76 | 413600.0 | 3178900.0 | 36 | 1.57908 | 1 | 351 | 413600.0 | 3178900.0 |
| 12 | 2.10351 | 1 | 17 | 412600.0 | 3179300.0 | 37 | 1.57903 | 1 | 351 | 412600.0 | 3179800.0 |
| 13 | 1.99393 | 1 | 72 | 413100.0 | 3179800.0 | 38 | 1.56140 | 1 | 16 | 412600.0 | 3179300.0 |
| 14 | 1.99251 | 1 | 338 | 413100.0 | 3178800.0 | 39 | 1.54660 | 1 | 122 | 413100.0 | 3178800.0 |
| 15 | 1.93932 | 1 | 351 | 412600.0 | 3179300.0 | 40 | 1.52254 | 1 | 17 | 413100.0 | 3179800.0 |
| 16 | 1.92091 | 1 | 335 | 412600.0 | 3178800.0 | 41 | 1.51430 | 1 | 351 | 413600.0 | 3179800.0 |
| 17 | 1.90962 | 1 | 7 | 413100.0 | 3178800.0 | 42 | 1.50408 | 1 | 351 | 413100.0 | 3179800.0 |
| 18 | 1.90927 | 1 | 343 | 412600.0 | 3178900.0 | 43 | 1.48881 | 1 | 123 | 413100.0 | 3178900.0 |
| 19 | 1.86493 | 1 | 338 | 413600.0 | 3178800.0 | 44 | 1.48692 | 1 | 339 | 412600.0 | 3178800.0 |
| 20 | 1.83427 | 1 | 17 | 413600.0 | 3179800.0 | 45 | 1.48019 | 1 | 99 | 412600.0 | 3178800.0 |
| 21 | 1.83325 | 1 | 114 | 412600.0 | 3179800.0 | 46 | 1.46928 | 1 | 53 | 412600.0 | 3179300.0 |
| 22 | 1.82226 | 1 | 76 | 412600.0 | 3178800.0 | 47 | 1.45792 | 1 | 197 | 413600.0 | 3179300.0 |
| 23 | 1.82084 | 1 | 290 | 413100.0 | 3178900.0 | 48 | 1.45541 | 1 | 42 | 413100.0 | 3178800.0 |
| 24 | 1.81989 | 1 | 290 | 413600.0 | 3178800.0 | 49 | 1.43278 | 1 | 76 | 412600.0 | 3179300.0 |
| 25 | 1.80361 | 1 | 105 | 412600.0 | 3178900.0 | 50 | 1.41625 | 1 | 114 | 412600.0 | 3179300.0 |

FORTRAN STOP
\$EXIT:
\$COST/F

| | | | |
|-----------------|------|------------|-----------|
| Username | AT21 | Process | BATCH_794 |
| Buffered I/O | 0.02 | | |
| Direct I/O | 0.30 | | |
| Page Faults | 0.04 | | |
| CPU Time | 3.50 | | |
| Connect Time | 0.00 | | |
| Volumes mounted | 0.00 | | |
| Total Cost: | 3.86 | BATCH\$LOW | |

\$EXIT

AT21 job terminated at 27-FEB-1986 11:06:38.41

*** LAKE COUNTY, FLORIDA EXISTING SO2 EMISSION SOURCE ANALYSIS 1 ***

| | |
|---|----------------------|
| CALCULATE (CONCENTRATION=1, DEPOSITION=2) | ISW(1) = 1 |
| RECEPTOR GRID SYSTEM (RECTANGULAR=1 OR 3, POLAR=2 OR 4) | ISW(2) = 3 |
| DISCRETE RECEPTOR SYSTEM (RECTANGULAR=1, POLAR=2) | ISW(3) = 1 |
| TERRAIN ELEVATIONS ARE READ (YES=1, NO=0) | ISW(4) = 0 |
| CALCULATIONS ARE WRITTEN TO TAPE (YES=1, NO=0) | ISW(5) = 0 |
| LIST ALL INPUT DATA (NO=0, YES=1, MET DATA ALGO=2) | ISW(6) = 1 |
| | |
| COMPUTE AVERAGE CONCENTRATION (OR TOTAL DEPOSITION) | |
| WITH THE FOLLOWING TIME PERIODS: | |
| HOURLY (YES=1, NO=0) | ISW(7) = 0 |
| 2-HOUR (YES=1, NO=0) | ISW(8) = 0 |
| 3-HOUR (YES=1, NO=0) | ISW(9) = 1 |
| 4-HOUR (YES=1, NO=0) | ISW(10) = 0 |
| 6-HOUR (YES=1, NO=0) | ISW(11) = 0 |
| 8-HOUR (YES=1, NO=0) | ISW(12) = 0 |
| 12-HOUR (YES=1, NO=0) | ISW(13) = 0 |
| 24-HOUR (YES=1, NO=0) | ISW(14) = 1 |
| PRINT "N"-DAY TABLE(S) (YES=1, NO=0) | ISW(15) = 1 |
| | |
| PRINT THE FOLLOWING TYPES OF TABLES WHOSE TIME PERIODS ARE | |
| SPECIFIED BY ISW(7) THROUGH ISW(14): | |
| DAILY TABLES (YES=1, NO=0) | ISW(16) = 0 |
| HIGHEST & SECOND HIGHEST TABLES (YES=1, NO=0) | ISW(17) = 0 |
| MAXIMUM 50 TABLES (YES=1, NO=0) | ISW(18) = 1 |
| METEOROLOGICAL DATA INPUT METHOD (PRE-PROCESSED=1, CARD=2) | ISW(19) = 1 |
| RURAL-URBAN OPTION (RURAL=0, URBAN MODE 1=1, URBAN MODE 2=2) | ISW(20) = 0 |
| WIND PROFILE EXPONENT VALUES (DEFAULTS=1, USER ENTERS=2, 3) | ISW(21) = 1 |
| VERTICAL POT. TEMP. GRADIENT VALUES (DEFAULTS=1, USER ENTERS=2, 3) | ISW(22) = 1 |
| SCALE EMISSION RATES FOR ALL SOURCES (NO=0, YES=0) | ISW(23) = 0 |
| PROGRAM CALCULATES FINAL PLUME RISE ONLY (YES=1, NO=2) | ISW(24) = 1 |
| PROGRAM ADJUSTS ALL STACK HEIGHTS FOR DOWNWASH (YES=2, NO=1) | ISW(25) = 1 |
| | |
| INPUT SPECIAL DIRECTION-DEPENDENT BUILDING DIMENSIONS (YES=1, NO=0) | ISW(26) = 0 |
| | |
| OMIT TABLES FOR HOURLY CONCENTRATIONS (YES=1, NO=0) | ISW(27) = 0 |
| | |
| USEPA ADJUSTMENT FOR CALM HOURS (YES=1, NO=0) | ISW(28) = 1 |
| | |
| NUMBER OF INPUT SOURCES | NSOURC = 1 |
| NUMBER OF SOURCE GROUPS (=0, ALL SOURCES) | NGROUP = 0 |
| TIME PERIOD INTERVAL TO BE PRINTED (=0, ALL INTERVALS) | IPERD = 0 |
| NUMBER OF X (RANGE) GRID VALUES | NXPNTS = 3 |
| NUMBER OF Y (THETA) GRID VALUES | NYPNTS = 3 |
| NUMBER OF DISCRETE RECEPTORS | NXWYPT = 0 |
| SOURCE EMISSION RATE UNITS CONVERSION FACTOR | TK = 10000E+07 |
| ENTRAINMENT COEFFICIENT FOR UNSTABLE ATMOSPHERE | BETA1 = 0.600 |
| ENTRAINMENT COEFFICIENT FOR STABLE ATMOSPHERE | BETA2 = 0.600 |
| HEIGHT ABOVE GROUND AT WHICH WIND SPEED WAS MEASURED | ZR = 10.00 METERS |
| LOGICAL UNIT NUMBER OF METEOROLOGICAL DATA | IMET = 9 |
| DECAY COEFFICIENT FOR PHYSICAL OR CHEMICAL DEPLETION | DECAY = 0.000000E+00 |
| SURFACE STATION NO. | ISS = 12815 |
| YEAR OF SURFACE DATA | ISY = 75 |
| UPPER AIR STATION NO. | IUS = 12842 |

IST-15

1975 - EXISTING SO2

*** LAKE COUNTY, FLORIDA EXISTING SO2 EMISSION SOURCE ANALYSIS 1 ***

*** X-COORDINATES OF RECTANGULAR GRID SYSTEM ***
(METERS)

412600. 0. 413100. 0. 413600. 0.

*** Y-COORDINATES OF RECTANGULAR GRID SYSTEM ***
(METERS)

3178800. 0. 3179300. 0. 3179800. 0.

*** LAKE COUNTY, FLORIDA EXISTING SO2 EMISSION SOURCE ANALYSIS 1 ***

*** SOURCE DATA ***

| SOURCE NUMBER | P K | Y A NUMBER | PART. CATS. | EMISSION RATE TYPE=0,1 (GRAMS/SEC) TYPE=2 (GRAMS/SEC) *PER METER**2 | X (METERS) | Y (METERS) | BASE ELEV. (METERS) | HEIGHT (METERS) | TEMP. | EXIT VEL. | BLDG. HEIGHT (METERS) | BLDG. LENGTH (METERS) | BLDG. WIDTH (METERS) | |
|---------------|-----|------------|-------------|--|---------------|---------------|---------------------------|--------------------|---|--|-----------------------------|-----------------------------|----------------------------|------|
| | | | | | | | | | TYPE=0 (DEG. K); TYPE=1 (METERS) | TYPE=0 (M/SEC); TYPE=1,2 (METERS) | | | | |
| 321 | 0 | 0 | 0 | 0.25200E+01 | 407100.0 | 3180900.0 | 0.0 | 7.52 | 347.00 | 4.60 | 2.28 | 0.00 | 0.00 | 0.00 |

*** LAKE COUNTY, FLORIDA EXISTING SO2 EMISSION SOURCE ANALYSIS 1 ***

* 365-DAY AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 0.15908 AND OCCURRED AT (412600.0, 3179300.0) *

| Y-AXIS (METERS) | 412600.0 | 413100.0 | 413600.0 | X-AXIS (METERS) |
|--------------------|----------|----------|----------|-----------------|
| 3179800.0 / | 0.08693 | 0.07984 | 0.07553 | |
| 3179300.0 / | 0.15908 | 0.11766 | 0.08708 | |
| 3178800.0 / | 0.14120 | 0.14394 | 0.14356 | |

*** LAKE COUNTY, FLORIDA EXISTING SO2 EMISSION SOURCE ANALYSIS 1 ***

* 50 MAXIMUM 3-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y (METERS) OR DIRECTION (DEGREES) | RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y (METERS) OR DIRECTION (DEGREES) |
|------|----------|------|-----|------------------------------|--|------|---------|------|-----|------------------------------|--|
| 1 | 18 42765 | 8 | 163 | 412600.0 | 3179300.0 | 26 | 8.70412 | 3 | 107 | 412600.0 | 3179300.0 |
| 2 | 15.52397 | 8 | 164 | 412600.0 | 3179300.0 | 27 | 8.61209 | 1 | 299 | 413100.0 | 3178800.0 |
| 3 | 13.28538 | 2 | 164 | 413100.0 | 3179800.0 | 28 | 8.56726 | 7 | 58 | 413100.0 | 3179300.0 |
| 4 | 13.04420 | 8 | 164 | 413600.0 | 3178800.0 | 29 | 8.54014 | 1 | 164 | 413600.0 | 3178800.0 |
| 5 | 12.71128 | 2 | 164 | 412600.0 | 3179800.0 | 30 | 8.46226 | 2 | 163 | 413100.0 | 3179300.0 |
| 6 | 12.39017 | 7 | 58 | 412600.0 | 3179300.0 | 31 | 8.40695 | 7 | 56 | 413100.0 | 3178800.0 |
| 7 | 12.32394 | 1 | 327 | 412600.0 | 3178800.0 | 32 | 8.38410 | 8 | 80 | 412600.0 | 3179800.0 |
| 8 | 11.73636 | 8 | 163 | 413600.0 | 3178800.0 | 33 | 8.37810 | 2 | 130 | 413600.0 | 3178800.0 |
| 9 | 11.65553 | 8 | 163 | 413100.0 | 3179300.0 | 34 | 8.37741 | 2 | 139 | 413100.0 | 3179900.0 |
| 10 | 11.54172 | 2 | 164 | 413600.0 | 3179800.0 | 35 | 8.34074 | 7 | 58 | 413600.0 | 3178800.0 |
| 11 | 10.80646 | 2 | 163 | 412600.0 | 3179300.0 | 36 | 8.32189 | 1 | 255 | 412600.0 | 3179300.0 |
| 12 | 10.79095 | 1 | 166 | 412600.0 | 3178800.0 | 37 | 8.31752 | 1 | 66 | 413100.0 | 3179300.0 |
| 13 | 10.56786 | 1 | 327 | 413100.0 | 3178900.0 | 38 | 8.25415 | 8 | 365 | 412600.0 | 3179800.0 |
| 14 | 10.51702 | 1 | 255 | 413100.0 | 3179300.0 | 39 | 8.19456 | 8 | 361 | 413600.0 | 3178800.0 |
| 15 | 9.92553 | 1 | 163 | 413600.0 | 3178900.0 | 40 | 8.17285 | 1 | 164 | 413600.0 | 3179900.0 |
| 16 | 9.82526 | 8 | 224 | 412600.0 | 3179800.0 | 41 | 8.13180 | 1 | 81 | 412600.0 | 3178800.0 |
| 17 | 9.57186 | 1 | 85 | 413600.0 | 3178800.0 | 42 | 8.09186 | 8 | 361 | 413100.0 | 3179800.0 |
| 18 | 9.40480 | 7 | 327 | 413600.0 | 3179300.0 | 43 | 8.00722 | 7 | 1 | 413600.0 | 3179300.0 |
| 19 | 9.38377 | 1 | 66 | 413600.0 | 3179300.0 | 44 | 7.99272 | 7 | 56 | 413600.0 | 3178800.0 |
| 20 | 9.30639 | 2 | 59 | 413100.0 | 3178800.0 | 45 | 7.90023 | 2 | 117 | 413100.0 | 3178800.0 |
| 21 | 9.27730 | 2 | 139 | 412600.0 | 3179800.0 | 46 | 7.84635 | 8 | 6 | 412600.0 | 3179300.0 |
| 22 | 8.98844 | 8 | 361 | 413100.0 | 3178800.0 | 47 | 7.84477 | 2 | 117 | 412600.0 | 3178800.0 |
| 23 | 8.88295 | 2 | 59 | 413600.0 | 3178800.0 | 48 | 7.84330 | 6 | 318 | 412600.0 | 3178800.0 |
| 24 | 8.82498 | 7 | 327 | 413100.0 | 3179300.0 | 49 | 7.77663 | 1 | 255 | 413600.0 | 3179300.0 |
| 25 | 8.71814 | 7 | 1 | 413100.0 | 3179300.0 | 50 | 7.72330 | 8 | 361 | 413600.0 | 3179800.0 |

*** LAKE COUNTY, FLORIDA EXISTING SO2 EMISSION SOURCE ANALYSIS 1 ***

* 50 MAXIMUM 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) | RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) |
|------|---------|------|-----|------------------------------|---|------|---------|------|-----|------------------------------|---|
| 1 | 5.73824 | 1 | 163 | 412600.0 | 3179300.0 | 26 | 1.61228 | 1 | 59 | 412600.0 | 3178800.0 |
| 2 | 4.53194 | 1 | 163 | 413600.0 | 3178800.0 | 27 | 1.58380 | 1 | 6 | 413100.0 | 3179300.0 |
| 3 | 3.56793 | 1 | 163 | 413100.0 | 3179300.0 | 28 | 1.56626 | 1 | 166 | 412600.0 | 3178800.0 |
| 4 | 3.44388 | 1 | 164 | 413600.0 | 3179800.0 | 29 | 1.55723 | 1 | 327 | 413600.0 | 3178800.0 |
| 5 | 3.16683 | 1 | 164 | 413100.0 | 3179300.0 | 30 | 1.54104 | 1 | 361 | 413600.0 | 3178800.0 |
| 6 | 3.07237 | 1 | 164 | 412600.0 | 3179300.0 | 31 | 1.53749 | 1 | 80 | 412600.0 | 3179600.0 |
| 7 | 3.02633 | 1 | 164 | 413600.0 | 3178800.0 | 32 | 1.47379 | 1 | 224 | 412600.0 | 3179800.0 |
| 8 | 2.61946 | 1 | 163 | 413100.0 | 3178600.0 | 33 | 1.47325 | 1 | 125 | 413600.0 | 3178800.0 |
| 9 | 2.50420 | 1 | 164 | 412600.0 | 3179800.0 | 34 | 1.46107 | 1 | 1 | 413100.0 | 3179300.0 |
| 10 | 2.22193 | 1 | 6 | 412600.0 | 3179300.0 | 35 | 1.40757 | 1 | 64 | 413600.0 | 3179300.0 |
| 11 | 2.20752 | 1 | 164 | 413100.0 | 3178800.0 | 36 | 1.40713 | 1 | 355 | 412600.0 | 3179300.0 |
| 12 | 2.17764 | 1 | 361 | 413100.0 | 3179300.0 | 37 | 1.39952 | 1 | 327 | 412600.0 | 3179300.0 |
| 13 | 2.17620 | 1 | 164 | 412600.0 | 3178800.0 | 38 | 1.39442 | 1 | 79 | 412600.0 | 3178900.0 |
| 14 | 2.17320 | 1 | 327 | 413100.0 | 3178800.0 | 39 | 1.38699 | 1 | 255 | 412600.0 | 3179300.0 |
| 15 | 2.16247 | 1 | 59 | 413100.0 | 3178900.0 | 40 | 1.38167 | 1 | 80 | 413100.0 | 3179900.0 |
| 16 | 2.15379 | 1 | 327 | 412600.0 | 3178800.0 | 41 | 1.37433 | 1 | 107 | 412600.0 | 3179300.0 |
| 17 | 1.97971 | 1 | 361 | 412600.0 | 3178900.0 | 42 | 1.36769 | 1 | 299 | 413100.0 | 3178900.0 |
| 18 | 1.85317 | 1 | 59 | 413600.0 | 3178800.0 | 43 | 1.35849 | 1 | 80 | 413600.0 | 3179800.0 |
| 19 | 1.84502 | 1 | 58 | 412600.0 | 3179300.0 | 44 | 1.34584 | 1 | 1 | 413600.0 | 3179300.0 |
| 20 | 1.82216 | 1 | 56 | 412600.0 | 3178800.0 | 45 | 1.33460 | 1 | 56 | 413100.0 | 3178800.0 |
| 21 | 1.75284 | 1 | 255 | 413100.0 | 3179300.0 | 46 | 1.31028 | 1 | 58 | 413600.0 | 3178800.0 |
| 22 | 1.75172 | 1 | 125 | 412600.0 | 3179300.0 | 47 | 1.30525 | 1 | 85 | 413600.0 | 3178800.0 |
| 23 | 1.70723 | 1 | 6 | 413600.0 | 3178800.0 | 48 | 1.30132 | 1 | 328 | 412600.0 | 3179300.0 |
| 24 | 1.67633 | 1 | 164 | 413100.0 | 3179300.0 | 49 | 1.29610 | 1 | 255 | 413600.0 | 3179300.0 |
| 25 | 1.64768 | 1 | 163 | 413600.0 | 3179300.0 | 50 | 1.29365 | 1 | 139 | 412600.0 | 3179800.0 |

FORTRAN STOP
*EXIT:
\$COST/F

```

Username      AT21          Process BATCH_991
Buffered I/O  0.02
Direct I/O    0.31
Page Faults   0.04
CPU Time      3.55
Connect Time  0.00
Volumes mounted 0.00
Total Cost:   3.91          BATCH*LOW

```

*EXIT
AT21 job terminated at 27-FEB-1986 11:04:33.89

*** LAKE COUNTY, FLORIDA EXISTING SO2 EMISSION SOURCE ANALYSIS 1 ***

| | |
|---|----------------------|
| CALCULATE (CONCENTRATION=1, DEPOSITION=2) | ISW(1) = 1 |
| RECEPTOR GRID SYSTEM (RECTANGULAR=1 OR 3, POLAR=2 OR 4) | ISW(2) = 3 |
| DISCRETE RECEPTOR SYSTEM (RECTANGULAR=1, POLAR=2) | ISW(3) = 1 |
| TERRAIN ELEVATIONS ARE READ (YES=1, NO=0) | ISW(4) = 0 |
| CALCULATIONS ARE WRITTEN TO TAPE (YES=1, NO=0) | ISW(5) = 0 |
| LIST ALL INPUT DATA (NO=0, YES=1, MET DATA ALSO=2) | ISW(6) = 1 |
| | |
| COMPUTE AVERAGE CONCENTRATION (OR TOTAL DEPOSITION) | |
| WITH THE FOLLOWING TIME PERIODS: | |
| HOURLY (YES=1, NO=0) | ISW(7) = 0 |
| 2-HOUR (YES=1, NO=0) | ISW(8) = 0 |
| 3-HOUR (YES=1, NO=0) | ISW(9) = 1 |
| 4-HOUR (YES=1, NO=0) | ISW(10) = 0 |
| 6-HOUR (YES=1, NO=0) | ISW(11) = 0 |
| 8-HOUR (YES=1, NO=0) | ISW(12) = 0 |
| 12-HOUR (YES=1, NO=0) | ISW(13) = 0 |
| 24-HOUR (YES=1, NO=0) | ISW(14) = 1 |
| PRINT "N"-DAY TABLE(S) (YES=1, NO=0) | ISW(15) = 1 |
| | |
| PRINT THE FOLLOWING TYPES OF TABLES WHOSE TIME PERIODS ARE | |
| SPECIFIED BY ISW(7) THROUGH ISW(14): | |
| DAILY TABLES (YES=1, NO=0) | ISW(16) = 0 |
| HIGHEST & SECOND HIGHEST TABLES (YES=1, NO=0) | ISW(17) = 0 |
| MAXIMUM 50 TABLES (YES=1, NO=0) | ISW(18) = 1 |
| METEOROLOGICAL DATA INPUT METHOD (PRE-PROCESSED=1, CARD=2) | ISW(19) = 1 |
| RURAL-URBAN OPTION (RURAL=0, URBAN MODE 1=1, URBAN MODE 2=2) | ISW(20) = 0 |
| WIND PROFILE EXPONENT VALUES (DEFAULTS=1, USER ENTERS=2,3) | ISW(21) = 1 |
| VERTICAL POT TEMP. GRADIENT VALUES (DEFAULTS=1, USER ENTERS=2,3) | ISW(22) = 1 |
| SCALE EMISSION RATES FOR ALL SOURCES (NO=0, YES>0) | ISW(23) = 0 |
| PROGRAM CALCULATES FINAL PLUME RISE ONLY (YES=1, NO=2) | ISW(24) = 1 |
| PROGRAM ADJUSTS ALL STACK HEIGHTS FOR DOWNWASH (YES=2, NO=1) | ISW(25) = 1 |
| | |
| INPUT SPECIAL DIRECTION-DEPENDENT BUILDING DIMENSIONS (YES=1, NO=0) | ISW(26) = 0 |
| | |
| OMIT TABLES FOR HOURLY CONCENTRATIONS (YES=1, NO=0) | ISW(27) = 0 |
| | |
| USEPA ADJUSTMENT FOR CALM HOURS (YES=1, NO=0) | ISW(28) = 1 |
| | |
| NUMBER OF INPUT SOURCES | NSOURC = 1 |
| NUMBER OF SOURCE GROUPS (=0, ALL SOURCES) | NGROUP = 0 |
| TIME PERIOD INTERVAL TO BE PRINTED (=0, ALL INTERVALS) | IPERD = 0 |
| NUMBER OF X (RANGE) GRID VALUES | NXPNTS = 3 |
| NUMBER OF Y (THETA) GRID VALUES | NYPNTS = 3 |
| NUMBER OF DISCRETE RECEPTORS | NXWYPT = 0 |
| SOURCE EMISSION RATE UNITS CONVERSION FACTOR | TK = 10000E+07 |
| ENTRAINMENT COEFFICIENT FOR UNSTABLE ATMOSPHERE | BETA1 = 0.600 |
| ENTRAINMENT COEFFICIENT FOR STABLE ATMOSPHERE | BETA2 = 0.600 |
| HEIGHT ABOVE GROUND AT WHICH WIND SPEED WAS MEASURED | ZR = 10.00 METERS |
| LOGICAL UNIT NUMBER OF METEOROLOGICAL DATA | IMET = 9 |
| DECAY COEFFICIENT FOR PHYSICAL OR CHEMICAL DEPLETION | DECAY = 0.000000E+00 |
| SURFACE STATION NO. | IGS = 12815 |
| YEAR OF SURFACE DATA | IGY = 76 |
| UPPER AIR STATION NO. | IUS = 12842 |

IST-16

1976 - EXISTING SO2

*** LAKE COUNTY, FLORIDA EXISTING SO2 EMISSION SOURCE ANALYSIS 1 ***

*** X-COORDINATES OF RECTANGULAR GRID SYSTEM ***
(METERS)

412600.0, 413100.0, 413600.0,

*** Y-COORDINATES OF RECTANGULAR GRID SYSTEM ***
(METERS)

3179800.0, 3179300.0, 3179800.0,

*** LAKE COUNTY, FLORIDA EXISTING SO2 EMISSION SOURCE ANALYSIS 1 ***

*** SOURCE DATA ***

| SOURCE NUMBER | P E | K E | PART CATS. | T W Y A NUMBER | EMISSION RATE TYPE=0.1 (GRAMS/SEC) TYPE=2 (GRAMS/SEC) *PER METER**2 | X (METERS) | Y (METERS) | BASE ELEV. (METERS) | HEIGHT (METERS) | TEMP. | EXIT VEL. | | | BLDG HEIGHT (METERS) | BLDG LENGTH (METERS) | BLDG WIDTH (METERS) |
|---------------|-----|-----|------------|----------------|--|---------------|---------------|---------------------------|--------------------|--|---|--|------------------------------|----------------------------|----------------------------|---------------------------|
| | | | | | | | | | | TYPE=0 (DEG. K); VERT. DIM TYPE=1 (METERS) | TYPE=0 (M/SEC); HORZ. DIM TYPE=1.2 (METERS) | TYPE=0 DIAMETER TYPE=0 (METERS) | TYPE=0 HEIGHT (METERS) | | | |
| 321 | 0 | 0 | 0 | 0 | 25200E+01 | 407100.0 | 3180900.0 | 0.0 | 7.62 | 347.00 | 4.60 | 2.28 | 0.00 | 0.00 | 0.00 | |

*** LAKE COUNTY, FLORIDA EXISTING SO2 EMISSION SOURCE ANALYSIS 1 ***

* 365-DAY AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 0.13047 AND OCCURRED AT (412600.0, 3179300.0) *

| Y-AXIS (METERS) / | 412600.0 | 413100.0 | 413600.0 | X-AXIS (METERS) |
|----------------------|----------|----------|----------|-----------------|
| 3179800.0 / | 0.11054 | 0.09925 | 0.09170 | |
| 3179300.0 / | 0.13047 | 0.11355 | 0.09916 | |
| 3178800.0 / | 0.11969 | 0.11372 | 0.10896 | |

*** LAKE COUNTY, FLORIDA EXISTING SO2 EMISSION SOURCE ANALYSIS 1 ***

* 50 MAXIMUM 3-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) | RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) |
|------|----------|------|-----|------------------------------|---|------|---------|------|-----|------------------------------|---|
| 1 | 15.35714 | 1 | 41 | 413100.0 | 3178800.0 | 26 | 8.32706 | 8 | 103 | 413600.0 | 3178800.0 |
| 2 | 13.30590 | 7 | 291 | 412600.0 | 3178800.0 | 27 | 8.29971 | 1 | 41 | 412600.0 | 3179300.0 |
| 3 | 12.25856 | 8 | 139 | 413100.0 | 3179300.0 | 28 | 8.29318 | 2 | 113 | 413600.0 | 3178800.0 |
| 4 | 11.46322 | 1 | 41 | 412600.0 | 3178800.0 | 29 | 8.29158 | 7 | 291 | 413100.0 | 3178800.0 |
| 5 | 10.77491 | 8 | 276 | 413600.0 | 3179300.0 | 30 | 8.20918 | 2 | 4 | 413100.0 | 3179800.0 |
| 6 | 10.71945 | 1 | 41 | 413600.0 | 3178800.0 | 31 | 8.18354 | 7 | 259 | 413100.0 | 3179800.0 |
| 7 | 10.39730 | 1 | 88 | 412600.0 | 3179300.0 | 32 | 8.16457 | 1 | 88 | 419100.0 | 3179300.0 |
| 8 | 10.39462 | 7 | 294 | 412600.0 | 3179800.0 | 33 | 8.11322 | 1 | 235 | 413600.0 | 3179800.0 |
| 9 | 10.36553 | 8 | 139 | 412600.0 | 3179300.0 | 34 | 8.04350 | 2 | 289 | 413600.0 | 3178800.0 |
| 10 | 9.51273 | 8 | 103 | 412600.0 | 3179300.0 | 35 | 7.99202 | 8 | 95 | 412600.0 | 3178800.0 |
| 11 | 9.46448 | 2 | 113 | 412600.0 | 3179300.0 | 36 | 7.83083 | 1 | 314 | 412600.0 | 3179800.0 |
| 12 | 9.36413 | 1 | 124 | 412600.0 | 3179300.0 | 37 | 7.76325 | 2 | 275 | 413100.0 | 3179300.0 |
| 13 | 9.29060 | 8 | 139 | 413600.0 | 3179300.0 | 38 | 7.74778 | 1 | 40 | 413600.0 | 3179300.0 |
| 14 | 9.23043 | 8 | 276 | 413100.0 | 3179300.0 | 39 | 7.74229 | 8 | 17 | 413100.0 | 3178800.0 |
| 15 | 9.18274 | 2 | 40 | 412600.0 | 3178800.0 | 40 | 7.73098 | 7 | 259 | 412600.0 | 3179800.0 |
| 16 | 9.12977 | 2 | 289 | 412600.0 | 3179300.0 | 41 | 7.72436 | 8 | 364 | 413600.0 | 3178800.0 |
| 17 | 9.04634 | 8 | 210 | 413100.0 | 3179300.0 | 42 | 7.69072 | 2 | 353 | 412600.0 | 3179300.0 |
| 18 | 8.93865 | 2 | 4 | 412600.0 | 3179800.0 | 43 | 7.67282 | 1 | 118 | 413100.0 | 3179800.0 |
| 19 | 8.92036 | 1 | 124 | 413600.0 | 3178800.0 | 44 | 7.58794 | 1 | 272 | 412600.0 | 3179300.0 |
| 20 | 8.77551 | 2 | 151 | 412600.0 | 3179300.0 | 45 | 7.52643 | 1 | 30 | 413600.0 | 3178800.0 |
| 21 | 8.60202 | 8 | 17 | 413600.0 | 3178800.0 | 46 | 7.52402 | 1 | 41 | 413100.0 | 3179300.0 |
| 22 | 8.55294 | 1 | 353 | 412600.0 | 3179300.0 | 47 | 7.46998 | 2 | 151 | 413600.0 | 3178800.0 |
| 23 | 8.54892 | 2 | 260 | 412600.0 | 3178800.0 | 48 | 7.44325 | 2 | 235 | 412600.0 | 3179800.0 |
| 24 | 8.46884 | 1 | 124 | 413100.0 | 3178800.0 | 49 | 7.44266 | 2 | 124 | 412600.0 | 3178800.0 |
| 25 | 8.44252 | 1 | 30 | 412600.0 | 3179300.0 | 50 | 7.24366 | 2 | 124 | 413600.0 | 3179300.0 |

*** LAKE COUNTY, FLORIDA EXISTING SO2 EMISSION SOURCE ANALYSIS 1 ***

* 50 MAXIMUM 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) | RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) |
|------|---------|------|-----|------------------------------|---|------|---------|------|-----|------------------------------|---|
| 1 | 2.48033 | 1 | 257 | 412600.0 | 3179800.0 | 26 | 1.56317 | 1 | 41 | 412600.0 | 3178800.0 |
| 2 | 2.43655 | 1 | 353 | 412600.0 | 3179300.0 | 27 | 1.55425 | 1 | 353 | 413100.0 | 3179300.0 |
| 3 | 2.38577 | 1 | 276 | 413600.0 | 3179300.0 | 28 | 1.53220 | 1 | 300 | 413100.0 | 3179800.0 |
| 4 | 2.30337 | 1 | 259 | 413100.0 | 3179800.0 | 29 | 1.52890 | 1 | 73 | 413100.0 | 3178800.0 |
| 5 | 2.20408 | 1 | 276 | 412600.0 | 3179800.0 | 30 | 1.49699 | 1 | 17 | 413100.0 | 3178800.0 |
| 6 | 2.09416 | 1 | 41 | 413100.0 | 3178800.0 | 31 | 1.49400 | 1 | 300 | 412600.0 | 3179800.0 |
| 7 | 2.05812 | 1 | 124 | 412600.0 | 3178800.0 | 32 | 1.49372 | 1 | 124 | 413600.0 | 3179300.0 |
| 8 | 1.94755 | 1 | 259 | 413600.0 | 3179800.0 | 33 | 1.48911 | 1 | 103 | 412600.0 | 3179300.0 |
| 9 | 1.82424 | 1 | 276 | 413100.0 | 3179300.0 | 34 | 1.47478 | 1 | 17 | 413600.0 | 3178800.0 |
| 10 | 1.81296 | 1 | 124 | 412600.0 | 3179300.0 | 35 | 1.47130 | 1 | 364 | 413100.0 | 3178800.0 |
| 11 | 1.80455 | 1 | 300 | 412600.0 | 3179300.0 | 36 | 1.46557 | 1 | 272 | 413600.0 | 3178800.0 |
| 12 | 1.78759 | 1 | 260 | 412600.0 | 3178800.0 | 37 | 1.46174 | 1 | 41 | 413600.0 | 3178800.0 |
| 13 | 1.77934 | 1 | 124 | 413100.0 | 3179300.0 | 38 | 1.45752 | 1 | 294 | 412600.0 | 3179800.0 |
| 14 | 1.77916 | 1 | 235 | 413100.0 | 3179900.0 | 39 | 1.45576 | 1 | 272 | 412600.0 | 3179300.0 |
| 15 | 1.72760 | 1 | 291 | 412600.0 | 3178800.0 | 40 | 1.44228 | 1 | 73 | 412600.0 | 3178800.0 |
| 16 | 1.69912 | 1 | 235 | 413600.0 | 3179900.0 | 41 | 1.44216 | 1 | 289 | 412600.0 | 3179300.0 |
| 17 | 1.69093 | 1 | 364 | 413600.0 | 3178800.0 | 42 | 1.43851 | 1 | 139 | 412600.0 | 3179300.0 |
| 18 | 1.66928 | 1 | 139 | 413100.0 | 3179300.0 | 43 | 1.41050 | 1 | 151 | 412600.0 | 3179300.0 |
| 19 | 1.66159 | 1 | 93 | 412600.0 | 3179800.0 | 44 | 1.40962 | 1 | 30 | 413600.0 | 3178800.0 |
| 20 | 1.61192 | 1 | 235 | 412600.0 | 3179900.0 | 45 | 1.39430 | 1 | 247 | 412600.0 | 3179300.0 |
| 21 | 1.60890 | 1 | 300 | 413100.0 | 3179300.0 | 46 | 1.39081 | 1 | 124 | 413600.0 | 3178800.0 |
| 22 | 1.58281 | 1 | 353 | 413600.0 | 3178800.0 | 47 | 1.36471 | 1 | 89 | 412600.0 | 3179300.0 |
| 23 | 1.58231 | 1 | 95 | 412600.0 | 3178800.0 | 48 | 1.35999 | 1 | 113 | 412600.0 | 3179300.0 |
| 24 | 1.56975 | 1 | 124 | 413100.0 | 3178800.0 | 49 | 1.35973 | 1 | 276 | 413100.0 | 3179800.0 |
| 25 | 1.56594 | 1 | 300 | 413600.0 | 3179800.0 | 50 | 1.35695 | 1 | 210 | 413100.0 | 3179300.0 |

FORTRAN STOP
\$EXIT:
\$COST/F

| | | | |
|-----------------|------|------------|-----------|
| Username | AT21 | Process | BATCH_987 |
| Buffered I/O | 0.02 | | |
| Direct I/O | 0.28 | | |
| Page Faults | 0.04 | | |
| CPU Time | 3.64 | | |
| Connect Time | 0.00 | | |
| Volumes mounted | 0.00 | | |
| Total Cost: | 3.98 | BATCH\$LOW | |

\$EXIT
AT21 Job terminated at 27-FEB-1986 11:02:21.66

*** LAKE COUNTY, FLORIDA EXISTING SO2 EMISSION SOURCE ANALYSIS 1 ***

| | |
|---|------------|
| CALCULATE (CONCENTRATION=1, DEPOSITION=2) | ISW(1) = 1 |
| RECEPTOR GRID SYSTEM (RECTANGULAR=1 OR 3, POLAR=2 OR 4) | ISW(2) = 3 |
| DISCRETE RECEPTOR SYSTEM (RECTANGULAR=1, POLAR=2) | ISW(3) = 1 |
| TERRAIN ELEVATIONS ARE READ (YES=1, NO=0) | ISW(4) = 0 |
| CALCULATIONS ARE WRITTEN TO TAPE (YES=1, NO=0) | ISW(5) = 0 |
| LIST ALL INPUT DATA (NO=0, YES=1, MET DATA ALSO=2) | ISW(6) = 1 |

| | |
|---|-------------|
| COMPUTE AVERAGE CONCENTRATION (OR TOTAL DEPOSITION) | |
| WITH THE FOLLOWING TIME PERIODS. | |
| HOURLY (YES=1, NO=0) | ISW(7) = 0 |
| 2-HOUR (YES=1, NO=0) | ISW(8) = 0 |
| 3-HOUR (YES=1, NO=0) | ISW(9) = 1 |
| 4-HOUR (YES=1, NO=0) | ISW(10) = 0 |
| 6-HOUR (YES=1, NO=0) | ISW(11) = 0 |
| 8-HOUR (YES=1, NO=0) | ISW(12) = 0 |
| 12-HOUR (YES=1, NO=0) | ISW(13) = 0 |
| 24-HOUR (YES=1, NO=0) | ISW(14) = 1 |
| PRINT "N"-DAY TABLE(S) (YES=1, NO=0) | ISW(15) = 1 |

| | |
|---|-------------|
| PRINT THE FOLLOWING TYPES OF TABLES WHOSE TIME PERIODS ARE SPECIFIED BY ISW(7) THROUGH ISW(14): | |
| DAILY TABLES (YES=1, NO=0) | ISW(16) = 0 |
| HIGHEST & SECOND HIGHEST TABLES (YES=1, NO=0) | ISW(17) = 0 |
| MAXIMUM 50 TABLES (YES=1, NO=0) | ISW(18) = 1 |
| METEOROLOGICAL DATA INPUT METHOD (PRE-PROCESSED=1, CARD=2) | ISW(19) = 1 |
| RURAL-URBAN OPTION (RURAL=0, URBAN MODE 1=1, URBAN MODE 2=2) | ISW(20) = 0 |
| WIND PROFILE EXPONENT VALUES (DEFAULTS=1, USER ENTERS=2,3) | ISW(21) = 1 |
| VERTICAL POT. TEMP. GRADIENT VALUES (DEFAULTS=1, USER ENTERS=2,3) | ISW(22) = 1 |
| SCALE EMISSION RATES FOR ALL SOURCES (NO=0, YES>0) | ISW(23) = 0 |
| PROGRAM CALCULATES FINAL PLUME RISE ONLY (YES=1, NO=2) | ISW(24) = 1 |
| PROGRAM ADJUSTS ALL STACK HEIGHTS FOR DOWNWASH (YES=2, NO=1) | ISW(25) = 1 |

| | |
|---|-------------|
| INPUT SPECIAL DIRECTION-DEPENDENT BUILDING DIMENSIONS (YES=1, NO=0) | ISW(26) = 0 |
|---|-------------|

| | |
|---|-------------|
| OMIT TABLES FOR HOURLY CONCENTRATIONS (YES=1, NO=0) | ISW(27) = 0 |
|---|-------------|

| | |
|---|-------------|
| USEPA ADJUSTMENT FOR CALM HOURS (YES=1, NO=0) | ISW(28) = 1 |
|---|-------------|

| | |
|--|----------------------|
| NUMBER OF INPUT SOURCES | NSOURC = 1 |
| NUMBER OF SOURCE GROUPS (=0, ALL SOURCES) | NGROUP = 0 |
| TIME PERIOD INTERVAL TO BE PRINTED (=0, ALL INTERVALS) | IPERD = 0 |
| NUMBER OF X (RANGE) GRID VALUES | NXPNTS = 3 |
| NUMBER OF Y (THETA) GRID VALUES | NYPNTS = 3 |
| NUMBER OF DISCRETE RECEPTORS | NXWYPT = 0 |
| SOURCE EMISSION RATE UNITS CONVERSION FACTOR | TK = .10000E+07 |
| ENTRAINMENT COEFFICIENT FOR UNSTABLE ATMOSPHERE | BETA1 = 0.600 |
| ENTRAINMENT COEFFICIENT FOR STABLE ATMOSPHERE | BETA2 = 0.600 |
| HEIGHT ABOVE GROUND AT WHICH WIND SPEED WAS MEASURED | ZR = 10.00 METERS |
| LOGICAL UNIT NUMBER OF METEOROLOGICAL DATA | IMET = 9 |
| DECAY COEFFICIENT FOR PHYSICAL OR CHEMICAL DEPLETION | DECAY = 0.000000E+00 |
| SURFACE STATION NO. | ISS = 12815 |
| YEAR OF SURFACE DATA | ISY = 77 |
| UPPER AIR STATION NO. | IUS = 12842 |

IST-17

1977 - EXISTING SO2

*** LAKE COUNTY, FLORIDA EXISTING SO2 EMISSION SOURCE ANALYSIS 1 ***

*** X-COORDINATES OF RECTANGULAR GRID SYSTEM ***
(METERS)

412600.0, 413100.0, 413600.0,

*** Y-COORDINATES OF RECTANGULAR GRID SYSTEM ***
(METERS)

3178800.0, 3179300.0, 3179800.0,

*** LAKE COUNTY, FLORIDA EXISTING SO2 EMISSION SOURCE ANALYSIS 1 ***

*** SOURCE DATA ***

| SOURCE NUMBER | T W P K E E | Y A NUMBER PART. CATS. | EMISSION RATE | | X (METERS) | Y (METERS) | BASE ELEV. (METERS) | HEIGHT (METERS) | TEMP. | EXIT VEL. | BLDG. HEIGHT (METERS) | BLDG. LENGTH (METERS) | BLDG. WIDTH (METERS) |
|---------------|-------------------|---------------------------------|--------------------------|-----------------------|---------------|---------------|---------------------------|--------------------|--|--|-----------------------------|-----------------------------|----------------------------|
| | | | TYPE=0, 1 (GRAMS/SEC) | TYPE=2 (GRAMS/SEC) | | | | | TYPE=0 (DEG. K); VERT. DIM TYPE=1 (METERS) | TYPE=0 (M/SEC); HORZ. DIM DIAMETER TYPE=1, 2 TYPE=0 (METERS) | | | |
| 321 | 0 0 | 0 | 0.25200E+01 | 407100.0 | 3180900.0 | 0.0 | 7.62 | 347.00 | 4.60 | 2.28 | 0.00 | 0.00 | 0.00 |

*** LAKE COUNTY, FLORIDA EXISTING SO2 EMISSION SOURCE ANALYSIS 1 ***

* 365-DAY AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 0.08914 AND OCCURRED AT (412600.0, 3178900.0) *

| Y-AXIS (METERS) | X-AXIS (METERS) | 412600.0 | 413100.0 | 413600.0 |
|--------------------|-----------------|----------|----------|----------|
| 3179800.0 / | | 0.07896 | 0.07279 | 0.06916 |
| 3179300.0 / | | 0.08331 | 0.07295 | 0.06574 |
| 3178800.0 / | | 0.08914 | 0.07839 | 0.07010 |

*** LAKE COUNTY, FLORIDA EXISTING SO2 EMISSION SOURCE ANALYSIS 1 ***

* 50 MAXIMUM 3-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) | RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) |
|------|----------|------|-----|------------------------------|---|------|---------|------|-----|------------------------------|---|
| 1 | 13.31222 | 1 | 289 | 413600.0 | 3179300.0 | 26 | 6.67859 | 8 | 46 | 413100.0 | 3178800.0 |
| 2 | 10.08451 | 2 | 154 | 412600.0 | 3179800.0 | 27 | 6.65787 | 8 | 46 | 412600.0 | 3178800.0 |
| 3 | 10.03432 | 2 | 134 | 412600.0 | 3178800.0 | 28 | 6.64912 | 8 | 5 | 412600.0 | 3179800.0 |
| 4 | 10.02420 | 1 | 289 | 412600.0 | 3179800.0 | 29 | 6.63376 | 1 | 164 | 413600.0 | 3179300.0 |
| 5 | 9.42478 | 1 | 312 | 412600.0 | 3179300.0 | 30 | 6.51267 | 2 | 154 | 413100.0 | 3179900.0 |
| 6 | 9.01373 | 2 | 164 | 413100.0 | 3179800.0 | 31 | 6.49393 | 7 | 321 | 413600.0 | 3178800.0 |
| 7 | 8.93209 | 8 | 36 | 412600.0 | 3179300.0 | 32 | 6.36498 | 1 | 29 | 412600.0 | 3179300.0 |
| 8 | 8.83588 | 8 | 7 | 412600.0 | 3178800.0 | 33 | 6.29482 | 8 | 25 | 413100.0 | 3179800.0 |
| 9 | 8.54034 | 2 | 164 | 413600.0 | 3179800.0 | 34 | 6.18469 | 2 | 47 | 413100.0 | 3179800.0 |
| 10 | 8.46444 | 8 | 36 | 413100.0 | 3179300.0 | 35 | 6.17764 | 7 | 21 | 412600.0 | 3179300.0 |
| 11 | 8.44996 | 8 | 5 | 413100.0 | 3179800.0 | 36 | 6.16025 | 1 | 301 | 413600.0 | 3179800.0 |
| 12 | 8.40696 | 7 | 311 | 412600.0 | 3179300.0 | 37 | 6.01997 | 8 | 47 | 413600.0 | 3179300.0 |
| 13 | 8.26363 | 1 | 312 | 413600.0 | 3178800.0 | 38 | 6.01411 | 2 | 312 | 413600.0 | 3179800.0 |
| 14 | 8.04226 | 8 | 5 | 413600.0 | 3179800.0 | 39 | 5.94564 | 8 | 25 | 413600.0 | 3179800.0 |
| 15 | 7.91701 | 1 | 289 | 413100.0 | 3179300.0 | 40 | 5.85783 | 2 | 272 | 413600.0 | 3178800.0 |
| 16 | 7.66531 | 2 | 272 | 413100.0 | 3178800.0 | 41 | 5.70811 | 7 | 282 | 412600.0 | 3178800.0 |
| 17 | 7.61547 | 1 | 29 | 413100.0 | 3179300.0 | 42 | 5.69829 | 1 | 268 | 413600.0 | 3178800.0 |
| 18 | 7.17721 | 7 | 311 | 413600.0 | 3178800.0 | 43 | 5.64135 | 7 | 290 | 412600.0 | 3178800.0 |
| 19 | 7.13013 | 2 | 164 | 412600.0 | 3179800.0 | 44 | 5.59865 | 2 | 134 | 413100.0 | 3178800.0 |
| 20 | 7.04357 | 8 | 36 | 413600.0 | 3179300.0 | 45 | 5.52787 | 1 | 29 | 413600.0 | 3179300.0 |
| 21 | 6.95319 | 8 | 287 | 412600.0 | 3178800.0 | 46 | 5.50300 | 8 | 36 | 413600.0 | 3178800.0 |
| 22 | 6.90595 | 2 | 47 | 412600.0 | 3179800.0 | 47 | 5.43446 | 8 | 47 | 413100.0 | 3179300.0 |
| 23 | 6.86779 | 1 | 268 | 412600.0 | 3179300.0 | 48 | 5.31978 | 2 | 154 | 413600.0 | 3179300.0 |
| 24 | 6.71431 | 7 | 300 | 413100.0 | 3178800.0 | 49 | 5.18068 | 8 | 74 | 413600.0 | 3179800.0 |
| 25 | 6.68460 | 8 | 52 | 412600.0 | 3178800.0 | 50 | 5.16647 | 7 | 21 | 413100.0 | 3179300.0 |

*** LAKE COUNTY, FLORIDA EXISTING SO2 EMISSION SOURCE ANALYSIS 1 ***

* 50 MAXIMUM 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CON | PER. | DAY | X OR RANGE (METERS) | Y (METERS) OR DIRECTION (DEGREES) | RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y (METERS) OR DIRECTION (DEGREES) |
|------|---------|------|-----|------------------------------|--|------|---------|------|-----|------------------------------|--|
| 1 | 2.67513 | 1 | 47 | 413600.0 | 3179300.0 | 26 | 1.17142 | 1 | 75 | 412600.0 | 3179900.0 |
| 2 | 2.52967 | 1 | 47 | 413100.0 | 3179300.0 | 27 | 1.14996 | 1 | 7 | 413100.0 | 3178900.0 |
| 3 | 2.46776 | 1 | 47 | 412600.0 | 3179900.0 | 28 | 1.13409 | 1 | 311 | 413600.0 | 3178900.0 |
| 4 | 2.16274 | 1 | 289 | 413600.0 | 3179300.0 | 29 | 1.12135 | 1 | 25 | 413100.0 | 3179900.0 |
| 5 | 1.84033 | 1 | 47 | 412600.0 | 3179300.0 | 30 | 1.11241 | 1 | 36 | 412600.0 | 3179900.0 |
| 6 | 1.77813 | 1 | 47 | 413100.0 | 3179800.0 | 31 | 1.08606 | 1 | 272 | 413100.0 | 3178800.0 |
| 7 | 1.75172 | 1 | 7 | 412600.0 | 3178900.0 | 32 | 1.04282 | 1 | 52 | 412600.0 | 3178900.0 |
| 8 | 1.67228 | 1 | 5 | 413100.0 | 3179800.0 | 33 | 1.03703 | 1 | 25 | 413600.0 | 3179900.0 |
| 9 | 1.66518 | 1 | 289 | 412600.0 | 3179900.0 | 34 | 1.02044 | 1 | 75 | 413100.0 | 3179900.0 |
| 10 | 1.64727 | 1 | 134 | 412600.0 | 3178800.0 | 35 | 1.00853 | 1 | 21 | 413100.0 | 3179300.0 |
| 11 | 1.59381 | 1 | 5 | 413600.0 | 3179800.0 | 36 | 1.00271 | 1 | 250 | 412600.0 | 3178800.0 |
| 12 | 1.54021 | 1 | 289 | 413100.0 | 3179300.0 | 37 | 0.99332 | 1 | 29 | 413100.0 | 3179300.0 |
| 13 | 1.53234 | 1 | 164 | 412600.0 | 3179800.0 | 38 | 0.99303 | 1 | 25 | 412600.0 | 3179800.0 |
| 14 | 1.51268 | 1 | 154 | 412600.0 | 3179800.0 | 39 | 0.99130 | 1 | 76 | 412600.0 | 3178800.0 |
| 15 | 1.43834 | 1 | 312 | 412600.0 | 3179300.0 | 40 | 0.97764 | 1 | 36 | 413100.0 | 3179800.0 |
| 16 | 1.41269 | 1 | 164 | 413100.0 | 3179800.0 | 41 | 0.97690 | 1 | 154 | 413100.0 | 3179800.0 |
| 17 | 1.40309 | 1 | 36 | 413100.0 | 3179300.0 | 42 | 0.94565 | 1 | 287 | 412600.0 | 3178800.0 |
| 18 | 1.39110 | 1 | 36 | 412600.0 | 3179300.0 | 43 | 0.94463 | 1 | 268 | 412600.0 | 3179300.0 |
| 19 | 1.37959 | 1 | 5 | 412600.0 | 3179800.0 | 44 | 0.94087 | 1 | 46 | 413100.0 | 3178800.0 |
| 20 | 1.33757 | 1 | 312 | 413600.0 | 3178900.0 | 45 | 0.93923 | 1 | 45 | 412600.0 | 3178900.0 |
| 21 | 1.32793 | 1 | 311 | 412600.0 | 3179300.0 | 46 | 0.93348 | 1 | 36 | 413600.0 | 3179800.0 |
| 22 | 1.27916 | 1 | 36 | 413600.0 | 3179300.0 | 47 | 0.93000 | 1 | 268 | 412600.0 | 3178800.0 |
| 23 | 1.27712 | 1 | 21 | 412600.0 | 3179300.0 | 48 | 0.92814 | 1 | 10 | 412600.0 | 3179800.0 |
| 24 | 1.19011 | 1 | 47 | 413600.0 | 3179800.0 | 49 | 0.92694 | 1 | 134 | 413100.0 | 3178800.0 |
| 25 | 1.17606 | 1 | 164 | 413600.0 | 3179800.0 | 50 | 0.92093 | 1 | 268 | 413100.0 | 3178800.0 |

FORTRAN STDP

*EXIT:

*COST/F

```

Username          AT21          Process BATCH_985
Buffered I/O      0.02
Direct I/O        0.28
Page Faults      0.04
CPU Time          3.54
Connect Time      0.00
Volumes mounted   0.00
Total Cost:       3.89          BATCH*LOW

```

*EXIT

AT21 job terminated at 27-FEB-1986 11:00:22.12

*** LAKE COUNTY, FLORIDA EXISTING SO2 EMISSION SOURCE ANALYSIS 1 ***

| | |
|---|----------------------|
| CALCULATE (CONCENTRATION=1, DEPOSITION=2) | ISW(1) = 1 |
| RECEPTOR GRID SYSTEM (RECTANGULAR=1 OR 3, POLAR=2 OR 4) | ISW(2) = 3 |
| DISCRETE RECEPTOR SYSTEM (RECTANGULAR=1, POLAR=2) | ISW(3) = 1 |
| TERRAIN ELEVATIONS ARE READ (YES=1, NO=0) | ISW(4) = 0 |
| CALCULATIONS ARE WRITTEN TO TAPE (YES=1, NO=0) | ISW(5) = 0 |
| LIST ALL INPUT DATA (NO=0, YES=1, MET DATA ALSO=2) | ISW(6) = 1 |
| COMPUTE AVERAGE CONCENTRATION (OR TOTAL DEPOSITION) | |
| WITH THE FOLLOWING TIME PERIODS: | |
| HOURLY (YES=1, NO=0) | ISW(7) = 0 |
| 2-HOUR (YES=1, NO=0) | ISW(8) = 0 |
| 3-HOUR (YES=1, NO=0) | ISW(9) = 1 |
| 4-HOUR (YES=1, NO=0) | ISW(10) = 0 |
| 6-HOUR (YES=1, NO=0) | ISW(11) = 0 |
| 8-HOUR (YES=1, NO=0) | ISW(12) = 0 |
| 12-HOUR (YES=1, NO=0) | ISW(13) = 0 |
| 24-HOUR (YES=1, NO=0) | ISW(14) = 1 |
| PRINT "N"-DAY TABLE(S) (YES=1, NO=0) | ISW(15) = 1 |
| PRINT THE FOLLOWING TYPES OF TABLES WHOSE TIME PERIODS ARE SPECIFIED BY ISW(7) THROUGH ISW(14): | |
| DAILY TABLES (YES=1, NO=0) | ISW(16) = 0 |
| HIGHEST & SECOND HIGHEST TABLES (YES=1, NO=0) | ISW(17) = 1 |
| MAXIMUM 50 TABLES (YES=1, NO=0) | ISW(18) = 1 |
| METEOROLOGICAL DATA INPUT METHOD (PRE-PROCESSED=1, CARD=2) | ISW(19) = 1 |
| RURAL-URBAN OPTION (RURAL=0, URBAN MODE 1=1, URBAN MODE 2=2) | ISW(20) = 0 |
| WIND PROFILE EXPONENT VALUES (DEFAULTS=1, USER ENTERS=2, 3) | ISW(21) = 1 |
| VERTICAL POT. TEMP. GRADIENT VALUES (DEFAULTS=1, USER ENTERS=2, 3) | ISW(22) = 1 |
| SCALE EMISSION RATES FOR ALL SOURCES (NO=0, YES>0) | ISW(23) = 0 |
| PROGRAM CALCULATES FINAL PLUME RISE ONLY (YES=1, NO=2) | ISW(24) = 1 |
| PROGRAM ADJUSTS ALL STACK HEIGHTS FOR DOWNWASH (YES=2, NO=1) | ISW(25) = 1 |
| INPUT SPECIAL DIRECTION-DEPENDENT BUILDING DIMENSIONS (YES=1, NO=0) | ISW(26) = 0 |
| OMIT TABLES FOR HOURLY CONCENTRATIONS (YES=1, NO=0) | ISW(27) = 0 |
| USEPA ADJUSTMENT FOR CALM HOURS (YES=1, NO=0) | ISW(28) = 1 |
| NUMBER OF INPUT SOURCES | NSOURC = 1 |
| NUMBER OF SOURCE GROUPS (=0, ALL SOURCES) | NGROUP = 0 |
| TIME PERIOD INTERVAL TO BE PRINTED (=0, ALL INTERVALS) | IPERD = 0 |
| NUMBER OF X (RANGE) GRID VALUES | NXPNTS = 3 |
| NUMBER OF Y (THETA) GRID VALUES | NYPNTS = 3 |
| NUMBER OF DISCRETE RECEPTORS | NXWYPT = 0 |
| SOURCE EMISSION RATE UNITS CONVERSION FACTOR | TK = 100000E+07 |
| ENTRAINMENT COEFFICIENT FOR UNSTABLE ATMOSPHERE | BETA1 = 0.600 |
| ENTRAINMENT COEFFICIENT FOR STABLE ATMOSPHERE | BETA2 = 0.600 |
| HEIGHT ABOVE GROUND AT WHICH WIND SPEED WAS MEASURED | ZR = 10.00 METERS |
| LOGICAL UNIT NUMBER OF METEOROLOGICAL DATA | IMET = 9 |
| DECAY COEFFICIENT FOR PHYSICAL OR CHEMICAL DEPLETION | DECAY = 0.000000E+00 |
| SURFACE STATION NO. | ISS = 12815 |
| YEAR OF SURFACE DATA | ISY = 78 |
| UPPER AIR STATION NO. | IUS = 12842 |

IST-18

1978 - EXISTING SO2

*** LAKE COUNTY, FLORIDA EXISTING SO2 EMISSION SOURCE ANALYSIS 1 ***

*** X-COORDINATES OF RECTANGULAR GRID SYSTEM ***
(METERS)

412600.0, 413100.0, 413600.0,

*** Y-COORDINATES OF RECTANGULAR GRID SYSTEM ***
(METERS)

3178800.0, 3179300.0, 3179800.0,

*** LAKE COUNTY, FLORIDA EXISTING SO2 EMISSION SOURCE ANALYSIS 1 ***

*** SOURCE DATA ***

| SOURCE NUMBER | P K | T W Y A NUMBER PART. CATS. | EMISSION RATE | | X (METERS) | Y (METERS) | BASE ELEV. (METERS) | HEIGHT (METERS) | TEMP. | EXIT VEL. | BLDG. HEIGHT (METERS) | BLDG. LENGTH (METERS) | BLDG. WIDTH (METERS) | |
|---------------|-----|----------------------------------|--|--|---------------|---------------|---------------------------|--------------------|---|-----------|-----------------------------|-----------------------------|----------------------------|------|
| | | | TYPE=0.1 (GRAMS/SEC) TYPE=2 *PER METER**2 | TYPE=0 (DEG. K); VERT. DIM TYPE=1 (METERS) | | | | | TYPE=0 (M/SEC); HORZ. DIM DIAMETER TYPE=1.2 (METERS) | | | | | |
| 321 | 0 0 | 0 | 0.25200E+01 | | 407100.0 | 3180900.0 | 0.0 | 7.62 | 347.00 | 4.60 | 2.28 | 0.00 | 0.00 | 0.00 |

*** LAKE COUNTY, FLORIDA EXISTING SO2 EMISSION SOURCE ANALYSIS 1 ***

* 365-DAY AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 0.08815 AND OCCURRED AT (412600.0, 3178800.0) *

| Y-AXIS / (METERS) / | 412600.0 | 413100.0 | 413600.0 | X-AXIS (METERS) |
|------------------------|----------|----------|----------|-----------------|
| 3179800.0 / | 0.06520 | 0.06156 | 0.05773 | |
| 3179300.0 / | 0.06167 | 0.05314 | 0.04734 | |
| 3178800.0 / | 0.08815 | 0.07026 | 0.05554 | |

*** LAKE COUNTY, FLORIDA EXISTING SO2 EMISSION SOURCE ANALYSIS 1 ***

* HIGHEST 3-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *
* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 13.74659 AND OCCURRED AT (413100.0, 3179300.0) *

| Y-AXIS / (METERS) / | X-AXIS (METERS) | | |
|------------------------|-------------------|-------------------|-------------------|
| | 412600.0 | 413100.0 | 413600.0 |
| 3179800.0 / | 8.95309 (88, 8) | 8.10626 (88, 8) | 7.85887 (328, 1) |
| 3179300.0 / | 12.57872 (256, 3) | 13.74659 (256, 3) | 10.13215 (256, 3) |
| 3178800.0 / | 9.13710 (279, 2) | 10.33587 (280, 1) | 7.93815 (280, 1) |

*** LAKE COUNTY, FLORIDA EXISTING SO2 EMISSION SOURCE ANALYSIS 1 ***

* SECOND HIGHEST 3-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *
* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 9.28973 AND OCCURRED AT (413100.0, 3178800.0) *

| Y-AXIS / (METERS) / | X-AXIS (METERS) | | |
|------------------------|------------------|------------------|------------------|
| | 412600.0 | 413100.0 | 413600.0 |
| 3179800.0 / | 0.43192 (279, 8) | 6.17256 (320, 1) | 6.03212 (81, 2) |
| 3179300.0 / | 0.00485 (323, 1) | 6.17319 (323, 1) | 6.05212 (279, 8) |
| 3178800.0 / | 0.77784 (308, 2) | 9.28973 (279, 2) | 6.59699 (55, 8) |

*** LAKE COUNTY, FLORIDA EXISTING SO2 EMISSION SOURCE ANALYSIS 1 ***

* 50 MAXIMUM 3-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) | RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) |
|------|----------|------|-----|------------------------------|---|------|---------|------|-----|------------------------------|---|
| 1 | 13.74559 | 3 | 256 | 413100.0 | 3179300.0 | 26 | 6.59699 | 8 | 55 | 413600.0 | 3178800.0 |
| 2 | 12.57872 | 3 | 256 | 412600.0 | 3179300.0 | 27 | 6.58039 | 2 | 46 | 413600.0 | 3178800.0 |
| 3 | 10.33587 | 1 | 280 | 413100.0 | 3178800.0 | 28 | 6.17319 | 1 | 323 | 413100.0 | 3179300.0 |
| 4 | 10.13215 | 3 | 256 | 413600.0 | 3179300.0 | 29 | 6.17256 | 1 | 328 | 413100.0 | 3179800.0 |
| 5 | 9.28973 | 2 | 279 | 413100.0 | 3178900.0 | 30 | 6.12109 | 8 | 111 | 412600.0 | 3178900.0 |
| 6 | 9.13710 | 2 | 279 | 412600.0 | 3178800.0 | 31 | 6.10171 | 3 | 256 | 413600.0 | 3178800.0 |
| 7 | 8.95309 | 8 | 89 | 412600.0 | 3179800.0 | 32 | 6.09786 | 8 | 111 | 413100.0 | 3178900.0 |
| 8 | 8.77784 | 2 | 308 | 412600.0 | 3178800.0 | 33 | 6.06275 | 1 | 77 | 412600.0 | 3178800.0 |
| 9 | 8.76056 | 8 | 231 | 412600.0 | 3178800.0 | 34 | 6.05212 | 8 | 279 | 413600.0 | 3179300.0 |
| 10 | 8.71404 | 7 | 312 | 412600.0 | 3178800.0 | 35 | 6.03212 | 2 | 81 | 413600.0 | 3179800.0 |
| 11 | 8.43192 | 8 | 277 | 412600.0 | 3179800.0 | 36 | 5.92451 | 1 | 21 | 413600.0 | 3179800.0 |
| 12 | 8.13536 | 2 | 231 | 413100.0 | 3178800.0 | 37 | 5.89485 | 3 | 256 | 412600.0 | 3178800.0 |
| 13 | 8.10626 | 8 | 88 | 413100.0 | 3179800.0 | 38 | 5.72523 | 8 | 88 | 413600.0 | 3179800.0 |
| 14 | 8.09579 | 2 | 231 | 412600.0 | 3178800.0 | 39 | 5.68623 | 7 | 287 | 412600.0 | 3179800.0 |
| 15 | 8.07504 | 1 | 143 | 412600.0 | 3178800.0 | 40 | 5.66606 | 1 | 21 | 413100.0 | 3179800.0 |
| 16 | 8.00485 | 1 | 323 | 412600.0 | 3179300.0 | 41 | 5.58495 | 3 | 256 | 413100.0 | 3178800.0 |
| 17 | 7.93815 | 1 | 280 | 413600.0 | 3178800.0 | 42 | 5.50759 | 8 | 15 | 412600.0 | 3178800.0 |
| 18 | 7.85887 | 1 | 328 | 413600.0 | 3179800.0 | 43 | 5.36537 | 7 | 37 | 413600.0 | 3178800.0 |
| 19 | 7.62469 | 2 | 260 | 412600.0 | 3178800.0 | 44 | 5.19543 | 8 | 279 | 413100.0 | 3179800.0 |
| 20 | 7.61234 | 8 | 55 | 412600.0 | 3179300.0 | 45 | 4.78918 | 2 | 81 | 413100.0 | 3179800.0 |
| 21 | 7.58979 | 2 | 46 | 412600.0 | 3179300.0 | 46 | 4.71879 | 2 | 308 | 413100.0 | 3178800.0 |
| 22 | 6.97852 | 7 | 37 | 413100.0 | 3178900.0 | 47 | 4.70522 | 1 | 21 | 412600.0 | 3179800.0 |
| 23 | 6.76133 | 1 | 280 | 412600.0 | 3178800.0 | 48 | 4.69756 | 2 | 273 | 412600.0 | 3179800.0 |
| 24 | 6.69928 | 2 | 86 | 413100.0 | 3178900.0 | 49 | 4.67838 | 2 | 273 | 413600.0 | 3179300.0 |
| 25 | 6.68002 | 2 | 86 | 412600.0 | 3178800.0 | 50 | 4.66186 | 8 | 279 | 413100.0 | 3179300.0 |

*** LAKE COUNTY, FLORIDA EXISTING SO2 EMISSION SOURCE ANALYSIS 1 ***

* HIGHEST 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *
* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 2.59019 AND OCCURRED AT (412600.0, 3178900.0) *

| Y-AXIS / (METERS) / | X-AXIS (METERS) | | |
|------------------------|------------------|------------------|------------------|
| | 412600.0 | 413100.0 | 413600.0 |
| 3179800.0 / | 2.21201 (279, 1) | 1.75415 (279, 1) | 1.66280 (328, 1) |
| 3179300.0 / | 1.91226 (256, 1) | 2.07576 (256, 1) | 1.52730 (256, 1) |
| 3178900.0 / | 2.59019 (231, 1) | 1.65820 (231, 1) | 1.04419 (279, 1) |

*** LAKE COUNTY, FLORIDA EXISTING SO2 EMISSION SOURCE ANALYSIS 1 ***

* SECOND HIGHEST 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *
* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 1.62680 AND OCCURRED AT (413100.0, 3178900.0) *

| Y-AXIS / (METERS) / | 412600.0 | 413100.0 | X-AXIS (METERS) 413600.0 |
|------------------------|------------------|------------------|-----------------------------|
| 3179800.0 / | 1.25353 (328, 1) | 1.51295 (328, 1) | 1.35123 (279, 1) |
| 3179300.0 / | 1.14355 (323, 1) | 1.07413 (279, 1) | 1.41555 (279, 1) |
| 3178800.0 / | 1.49436 (312, 1) | 1.62680 (279, 1) | 0.99466 (280, 1) |

*** LAKE COUNTY, FLORIDA EXISTING SO2 EMISSION SOURCE ANALYSIS 1 ***

* 50 MAXIMUM 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CDN. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) | RANK | CDN. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) |
|------|---------|------|-----|------------------------------|---|------|---------|------|-----|------------------------------|---|
| 1 | 2.58019 | 1 | 231 | 412600.0 | 3178800.0 | 26 | 1.05005 | 1 | 15 | 413100.0 | 3178800.0 |
| 2 | 2.21201 | 1 | 279 | 412600.0 | 3179800.0 | 27 | 1.04419 | 1 | 279 | 413600.0 | 3178800.0 |
| 3 | 2.07576 | 1 | 256 | 413100.0 | 3179300.0 | 28 | 1.01328 | 1 | 89 | 413100.0 | 3179800.0 |
| 4 | 1.91226 | 1 | 256 | 412600.0 | 3179300.0 | 29 | 0.99466 | 1 | 280 | 413600.0 | 3178800.0 |
| 5 | 1.75415 | 1 | 279 | 413100.0 | 3179900.0 | 30 | 0.98289 | 1 | 81 | 413600.0 | 3179900.0 |
| 6 | 1.66280 | 1 | 328 | 413600.0 | 3179800.0 | 31 | 0.96987 | 1 | 15 | 412600.0 | 3179300.0 |
| 7 | 1.65920 | 1 | 231 | 413100.0 | 3178800.0 | 32 | 0.96352 | 1 | 351 | 413600.0 | 3179900.0 |
| 8 | 1.62680 | 1 | 279 | 413100.0 | 3178800.0 | 33 | 0.95192 | 1 | 86 | 412600.0 | 3178800.0 |
| 9 | 1.52730 | 1 | 256 | 413600.0 | 3179300.0 | 34 | 0.95139 | 1 | 256 | 412600.0 | 3178800.0 |
| 10 | 1.51295 | 1 | 328 | 413100.0 | 3179800.0 | 35 | 0.94872 | 1 | 46 | 412600.0 | 3179300.0 |
| 11 | 1.49436 | 1 | 312 | 412600.0 | 3178800.0 | 36 | 0.94413 | 1 | 256 | 413600.0 | 3178800.0 |
| 12 | 1.46588 | 1 | 279 | 412600.0 | 3178800.0 | 37 | 0.93950 | 1 | 287 | 412600.0 | 3179800.0 |
| 13 | 1.41555 | 1 | 279 | 413600.0 | 3179300.0 | 38 | 0.93786 | 1 | 20 | 413600.0 | 3179800.0 |
| 14 | 1.38262 | 1 | 15 | 412600.0 | 3178800.0 | 39 | 0.93742 | 1 | 86 | 413100.0 | 3178800.0 |
| 15 | 1.35123 | 1 | 279 | 413600.0 | 3179800.0 | 40 | 0.93091 | 1 | 279 | 412600.0 | 3179300.0 |
| 16 | 1.29723 | 1 | 280 | 413100.0 | 3178800.0 | 41 | 0.92279 | 1 | 351 | 413100.0 | 3179800.0 |
| 17 | 1.25353 | 1 | 328 | 412600.0 | 3179800.0 | 42 | 0.92171 | 1 | 225 | 412600.0 | 3179800.0 |
| 18 | 1.15358 | 1 | 143 | 412600.0 | 3178900.0 | 43 | 0.91699 | 1 | 50 | 412600.0 | 3179300.0 |
| 19 | 1.14747 | 1 | 308 | 412600.0 | 3178800.0 | 44 | 0.91474 | 1 | 351 | 412600.0 | 3179300.0 |
| 20 | 1.14355 | 1 | 323 | 412600.0 | 3179300.0 | 45 | 0.90105 | 1 | 15 | 413600.0 | 3178800.0 |
| 21 | 1.14194 | 1 | 55 | 412600.0 | 3179300.0 | 46 | 0.89172 | 1 | 50 | 413100.0 | 3178800.0 |
| 22 | 1.11914 | 1 | 88 | 412600.0 | 3179800.0 | 47 | 0.88439 | 1 | 21 | 413600.0 | 3179800.0 |
| 23 | 1.08924 | 1 | 268 | 412600.0 | 3178800.0 | 48 | 0.88291 | 1 | 256 | 413100.0 | 3178800.0 |
| 24 | 1.07413 | 1 | 279 | 413100.0 | 3179300.0 | 49 | 0.88278 | 1 | 55 | 413600.0 | 3178800.0 |
| 25 | 1.05068 | 1 | 37 | 413100.0 | 3178800.0 | 50 | 0.88188 | 1 | 323 | 413100.0 | 3179300.0 |

FORTRAN STOP

*EXIT:
*COST/F

| | | | |
|-----------------|------|-----------|-----------|
| Username | AT21 | Process | BATCH_112 |
| Buffered I/O | 0.02 | | |
| Direct I/O | 0.33 | | |
| Page Faults | 0.04 | | |
| CPU Time | 3.38 | | |
| Connect Time | 0.00 | | |
| Volumes mounted | 0.00 | | |
| Total Cost: | 3.77 | BATCH#LOW | |

*EXIT

AT21 job terminated at 13-FEB-1986 10:35:45.23

| | |
|---|----------------------|
| CALCULATE (CONCENTRATION=1, DEPOSITION=2) | ISW(1) = 1 |
| RECEPTOR GRID SYSTEM (RECTANGULAR=1 OR 3, POLAR=2 OR 4) | ISW(2) = 4 |
| DISCRETE RECEPTOR SYSTEM (RECTANGULAR=1, POLAR=2) | ISW(3) = 2 |
| TERRAIN ELEVATIONS ARE READ (YES=1, NO=0) | ISW(4) = 0 |
| CALCULATIONS ARE WRITTEN TO TAPE (YES=1, NO=0) | ISW(5) = 0 |
| LIST ALL INPUT DATA (NO=0, YES=1, MET DATA ALSO=2) | ISW(6) = 1 |
| | |
| COMPUTE AVERAGE CONCENTRATION (OR TOTAL DEPOSITION) | |
| WITH THE FOLLOWING TIME PERIODS: | |
| HOURLY (YES=1, NO=0) | ISW(7) = 0 |
| 2-HOUR (YES=1, NO=0) | ISW(8) = 0 |
| 3-HOUR (YES=1, NO=0) | ISW(9) = 1 |
| 4-HOUR (YES=1, NO=0) | ISW(10) = 0 |
| 6-HOUR (YES=1, NO=0) | ISW(11) = 0 |
| 8-HOUR (YES=1, NO=0) | ISW(12) = 0 |
| 12-HOUR (YES=1, NO=0) | ISW(13) = 0 |
| 24-HOUR (YES=1, NO=0) | ISW(14) = 1 |
| PRINT "N"-DAY TABLE(S) (YES=1, NO=0) | ISW(15) = 1 |
| | |
| PRINT THE FOLLOWING TYPES OF TABLES WHOSE TIME PERIODS ARE | |
| SPECIFIED BY ISW(7) THROUGH ISW(14): | |
| DAILY TABLES (YES=1, NO=0) | ISW(16) = 0 |
| HIGHEST & SECOND HIGHEST TABLES (YES=1, NO=0) | ISW(17) = 1 |
| MAXIMUM 50 TABLES (YES=1, NO=0) | ISW(18) = 1 |
| METEOROLOGICAL DATA INPUT METHOD (PRE-PROCESSED=1, CARD=2) | ISW(19) = 1 |
| RURAL-URBAN OPTION (RURAL=0, URBAN MODE 1=1, URBAN MODE 2=2) | ISW(20) = 0 |
| WIND PROFILE EXPONENT VALUES (DEFAULTS=1, USER ENTERS=2, 3) | ISW(21) = 1 |
| VERTICAL POT. TEMP. GRADIENT VALUES (DEFAULTS=1, USER ENTERS=2, 3) | ISW(22) = 1 |
| SCALE EMISSION RATES FOR ALL SOURCES (NO=0, YES=1) | ISW(23) = 0 |
| PROGRAM CALCULATES FINAL PLUME RISE ONLY (YES=1, NO=2) | ISW(24) = 2 |
| PROGRAM ADJUSTS ALL STACK HEIGHTS FOR DOWNWASH (YES=2, NO=1) | ISW(25) = 1 |
| | |
| INPUT SPECIAL DIRECTION-DEPENDENT BUILDING DIMENSIONS (YES=1, NO=0) | ISW(26) = 0 |
| | |
| OMIT TABLES FOR HOURLY CONCENTRATIONS (YES=1, NO=0) | ISW(27) = 0 |
| | |
| USEPA ADJUSTMENT FOR CALM HOURS (YES=1, NO=0) | ISW(28) = 1 |
| | |
| NUMBER OF INPUT SOURCES | NSOURC = 1 |
| NUMBER OF SOURCE GROUPS (=0, ALL SOURCES) | NGROUP = 0 |
| TIME PERIOD INTERVAL TO BE PRINTED (=0, ALL INTERVALS) | IPERD = 0 |
| NUMBER OF X (RANGE) GRID VALUES | NXPNTS = 1 |
| NUMBER OF Y (THETA) GRID VALUES | NYPNTS = 3 |
| NUMBER OF DISCRETE RECEPTORS | NXWYPT = 0 |
| SOURCE EMISSION RATE UNITS CONVERSION FACTOR | TK = 1.0000E+07 |
| ENTRAINMENT COEFFICIENT FOR UNSTABLE ATMOSPHERE | BETA1 = 0.600 |
| ENTRAINMENT COEFFICIENT FOR STABLE ATMOSPHERE | BETA2 = 0.600 |
| HEIGHT ABOVE GROUND AT WHICH WIND SPEED WAS MEASURED | ZR = 10.00 METERS |
| LOGICAL UNIT NUMBER OF METEOROLOGICAL DATA | IMET = 9 |
| DECAY COEFFICIENT FOR PHYSICAL OR CHEMICAL DEPLETION | DECAY = 0.000000E+00 |
| SURFACE STATION NO. | IGS = 12815 |
| YEAR OF SURFACE DATA | ISY = 74 |
| UPPER AIR STATION NO. | IUS = 12842 |
| YEAR OF UPPER AIR DATA | IUY = 74 |
| ALLOCATED DATA STORAGE | LIMIT = 43500 WORDS |

IST-19

1974-NRG ONLY-SO₂
Class I area Analysis

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09

*** RANGES OF POLAR GRID SYSTEM ***
(METERS)

70000.0.

*** RADIAL ANGLES OF POLAR GRID SYSTEM ***

(DEGREES)

260.0, 270.0, 280.0.

*** SOURCE DATA ***

| SOURCE NUMBER | T W P K E E | Y A NUMBER PART CATS. | EMISSION RATE | X (METERS) | Y (METERS) | BASE ELEV. (METERS) | HEIGHT (METERS) | TEMP. | EXIT VEL. | BLDG. HEIGHT (METERS) | BLDG. LENGTH (METERS) | BLDG. WIDTH (METERS) | |
|---------------|-------------------|-----------------------------|--|---------------|---------------|---------------------------|--------------------|---------------------------------|--|-----------------------------|-----------------------------|----------------------------|-------|
| | | | TYPE=0.1 (GRAMS/SEC) TYPE=2 *PER METER**2 | | | | | (DEG. K); TYPE=1 (METERS) | TYPE=0 (M/SEC); TYPE=1.2 (METERS) | | | | |
| 101 | 0 0 | 0 | 0.15800E+02 | 0.0 | 0.0 | 0.0 | 38.10 | 450.00 | 20.00 | 1.83 | 22.00 | 38.10 | 19.80 |

"N"-DAY
365 DAYS
SGROUP# 1

*** NRC/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* 365-DAY AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *
* FOR THE RECEPTOR GRID *

* MAXIMUM VALUE EQUALS 0.03711 AND OCCURRED AT (70000.0, 260.0) *

DIRECTION /
(DEGREES) /

70000.0

RANGE (METERS)

280.0 / 0.01977
270.0 / 0.03164
260.0 / 0.03711

*** NRO/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* 50 MAXIMUM 3-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) | RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y(METERS) OR DIRECTION (DEGREES) |
|------|---------|------|-----|------------------------------|---|------|---------|------|-----|------------------------------|---|
| 1 | 4.35912 | 8 | 111 | 70000.0 | 270.0 | 26 | 1.82223 | 8 | 364 | 70000.0 | 270.0 |
| 2 | 4.11209 | 2 | 142 | 70000.0 | 260.0 | 27 | 1.82108 | 8 | 301 | 70000.0 | 270.0 |
| 3 | 3.79464 | 2 | 112 | 70000.0 | 270.0 | 28 | 1.81021 | 1 | 308 | 70000.0 | 260.0 |
| 4 | 3.33014 | 7 | 67 | 70000.0 | 270.0 | 29 | 1.80521 | 2 | 357 | 70000.0 | 260.0 |
| 5 | 3.29230 | 2 | 137 | 70000.0 | 270.0 | 30 | 1.69161 | 7 | 255 | 70000.0 | 260.0 |
| 6 | 3.08970 | 7 | 60 | 70000.0 | 280.0 | 31 | 1.68629 | 1 | 142 | 70000.0 | 270.0 |
| 7 | 2.57027 | 1 | 160 | 70000.0 | 270.0 | 32 | 1.55804 | 7 | 242 | 70000.0 | 260.0 |
| 8 | 2.56101 | 8 | 257 | 70000.0 | 260.0 | 33 | 1.55532 | 7 | 288 | 70000.0 | 260.0 |
| 9 | 2.55018 | 2 | 153 | 70000.0 | 260.0 | 34 | 1.55474 | 8 | 129 | 70000.0 | 270.0 |
| 10 | 2.54155 | 1 | 112 | 70000.0 | 260.0 | 35 | 1.50630 | 7 | 148 | 70000.0 | 280.0 |
| 11 | 2.53730 | 1 | 358 | 70000.0 | 270.0 | 36 | 1.50372 | 7 | 163 | 70000.0 | 270.0 |
| 12 | 2.53461 | 1 | 65 | 70000.0 | 280.0 | 37 | 1.50299 | 8 | 239 | 70000.0 | 260.0 |
| 13 | 2.35151 | 7 | 238 | 70000.0 | 280.0 | 38 | 1.50299 | 8 | 171 | 70000.0 | 260.0 |
| 14 | 2.34405 | 8 | 205 | 70000.0 | 280.0 | 39 | 1.50130 | 8 | 225 | 70000.0 | 260.0 |
| 15 | 2.10975 | 7 | 235 | 70000.0 | 260.0 | 40 | 1.49910 | 1 | 139 | 70000.0 | 260.0 |
| 16 | 2.09744 | 3 | 242 | 70000.0 | 260.0 | 41 | 1.49535 | 2 | 134 | 70000.0 | 260.0 |
| 17 | 2.08601 | 8 | 65 | 70000.0 | 280.0 | 42 | 1.47732 | 7 | 117 | 70000.0 | 280.0 |
| 18 | 2.01582 | 2 | 184 | 70000.0 | 260.0 | 43 | 1.29706 | 7 | 36 | 70000.0 | 260.0 |
| 19 | 1.96766 | 7 | 67 | 70000.0 | 260.0 | 44 | 1.28206 | 7 | 140 | 70000.0 | 260.0 |
| 20 | 1.83069 | 8 | 261 | 70000.0 | 260.0 | 45 | 1.28063 | 7 | 244 | 70000.0 | 260.0 |
| 21 | 1.82971 | 1 | 171 | 70000.0 | 270.0 | 46 | 1.27766 | 8 | 166 | 70000.0 | 280.0 |
| 22 | 1.82970 | 8 | 188 | 70000.0 | 260.0 | 47 | 1.27576 | 3 | 142 | 70000.0 | 280.0 |
| 23 | 1.82968 | 2 | 242 | 70000.0 | 270.0 | 48 | 1.27427 | 7 | 300 | 70000.0 | 260.0 |
| 24 | 1.82966 | 8 | 216 | 70000.0 | 270.0 | 49 | 1.27216 | 1 | 358 | 70000.0 | 280.0 |
| 25 | 1.82951 | 1 | 187 | 70000.0 | 260.0 | 50 | 1.14525 | 7 | 220 | 70000.0 | 260.0 |

*** NRG/RECOVERY GROUP, LAKE COUNTY, FLORIDA - 14772-001-09 ***

* 50 MAXIMUM 24-HOUR AVERAGE CONCENTRATION (MICROGRAMS/CUBIC METER) *

* FROM ALL SOURCES *

| RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y (METERS) OR DIRECTION (DEGREES) | RANK | CON. | PER. | DAY | X OR RANGE (METERS) | Y (METERS) OR DIRECTION (DEGREES) |
|------|---------|------|-----|------------------------------|--|------|---------|------|-----|------------------------------|--|
| 1 | 0.81584 | 1 | 65 | 70000.0 | 280.0 | 26 | 0.29791 | 1 | 171 | 70000.0 | 270.0 |
| 2 | 0.70925 | 1 | 111 | 70000.0 | 270.0 | 27 | 0.29475 | 1 | 308 | 70000.0 | 260.0 |
| 3 | 0.66052 | 1 | 67 | 70000.0 | 270.0 | 28 | 0.28991 | 1 | 261 | 70000.0 | 260.0 |
| 4 | 0.62503 | 1 | 112 | 70000.0 | 270.0 | 29 | 0.28659 | 1 | 244 | 70000.0 | 260.0 |
| 5 | 0.57932 | 1 | 242 | 70000.0 | 260.0 | 30 | 0.27851 | 1 | 239 | 70000.0 | 260.0 |
| 6 | 0.51502 | 1 | 142 | 70000.0 | 260.0 | 31 | 0.26691 | 1 | 235 | 70000.0 | 260.0 |
| 7 | 0.51495 | 1 | 60 | 70000.0 | 280.0 | 32 | 0.26395 | 1 | 36 | 70000.0 | 260.0 |
| 8 | 0.47421 | 1 | 160 | 70000.0 | 270.0 | 33 | 0.25707 | 1 | 148 | 70000.0 | 280.0 |
| 9 | 0.44098 | 1 | 112 | 70000.0 | 260.0 | 34 | 0.25376 | 1 | 184 | 70000.0 | 260.0 |
| 10 | 0.43571 | 1 | 139 | 70000.0 | 270.0 | 35 | 0.24969 | 1 | 171 | 70000.0 | 260.0 |
| 11 | 0.40076 | 1 | 358 | 70000.0 | 270.0 | 36 | 0.24267 | 1 | 225 | 70000.0 | 260.0 |
| 12 | 0.39204 | 1 | 139 | 70000.0 | 260.0 | 37 | 0.23866 | 1 | 188 | 70000.0 | 260.0 |
| 13 | 0.37255 | 1 | 300 | 70000.0 | 260.0 | 38 | 0.23792 | 1 | 357 | 70000.0 | 260.0 |
| 14 | 0.35167 | 1 | 187 | 70000.0 | 260.0 | 39 | 0.23768 | 1 | 364 | 70000.0 | 270.0 |
| 15 | 0.34546 | 1 | 238 | 70000.0 | 280.0 | 40 | 0.23576 | 1 | 358 | 70000.0 | 280.0 |
| 16 | 0.33795 | 1 | 140 | 70000.0 | 260.0 | 41 | 0.22871 | 1 | 216 | 70000.0 | 270.0 |
| 17 | 0.33690 | 1 | 205 | 70000.0 | 280.0 | 42 | 0.22868 | 1 | 260 | 70000.0 | 270.0 |
| 18 | 0.33405 | 1 | 257 | 70000.0 | 260.0 | 43 | 0.22314 | 1 | 255 | 70000.0 | 260.0 |
| 19 | 0.33201 | 1 | 288 | 70000.0 | 260.0 | 44 | 0.22135 | 1 | 302 | 70000.0 | 260.0 |
| 20 | 0.32977 | 1 | 69 | 70000.0 | 260.0 | 45 | 0.21660 | 1 | 134 | 70000.0 | 260.0 |
| 21 | 0.31877 | 1 | 153 | 70000.0 | 260.0 | 46 | 0.21617 | 1 | 142 | 70000.0 | 270.0 |
| 22 | 0.31659 | 1 | 242 | 70000.0 | 270.0 | 47 | 0.21304 | 1 | 129 | 70000.0 | 270.0 |
| 23 | 0.31670 | 1 | 301 | 70000.0 | 270.0 | 48 | 0.19614 | 1 | 163 | 70000.0 | 270.0 |
| 24 | 0.31075 | 1 | 141 | 70000.0 | 260.0 | 49 | 0.19432 | 1 | 170 | 70000.0 | 260.0 |
| 25 | 0.30199 | 1 | 119 | 70000.0 | 280.0 | 50 | 0.18535 | 1 | 32 | 70000.0 | 280.0 |


APPENDIX B
BACT/LAER CLEARINGHOUSE REPORT

EPA-450/3-85-016a

BACT/LAER Clearinghouse—

A Compilation Of Control Technology Determinations

Volume I
Summary Tables and Appendices A-F



PROPERTY OF REGION 4 LIBRARY

June 1985


Developed As Part Of A Joint Effort
Between The U.S. Environmental Protection Agency
And State And Local Air Pollution Control Agencies

EPA-450/3-85-016b

BACT/LAER Clearinghouse—

A Compilation Of Control Technology Determinations

Volume IIA
Appendix G
Source Type Codes 1.0 - 4.0



PROPERTY OF REGION 4 LIBRARY

June 1985

Developed As Part Of A Joint Effort
Between The U.S. Environmental Protection Agency
And State And Local Air Pollution Control Agencies

TABLE 1. INDEX (CONTINUED).

REPORT DATE 05/22/1985

| SOURCE TYPE/COMPANY NAME | STATE | PERMIT ISSUED | AGENCY | NAME OF CONTACT | TELEPHONE | TABLE 2 INDEX |
|--|-------|------------------|--------------------|---------------------|----------------|------------------|
| POWER AUTHORITY STATE OF NEW YORK | NY | 02/22/82 | EPA REGION II | DENNIS SANTELLA | (212)-264-9628 | 1.5 |
| STONE CONTAINER CCRP. | LA | 06/02/83 | LAQD/EPA REGION VI | BHARAT CONTRACTOR | (504)-342-8940 | 1.5 |
| SOURCE TYPE -- EXTERNAL COMBUSTION - OTHER | | | | | | |
| AMERICAN PACKAGING CORP. | PA | 12/28/82 | PHILADELPHIA AMS | THOMAS ELLIOTT, JR. | (215)-686-7893 | 1.6 |
| CALIFORNIA POWER & LIGHT | CA | 01/01/84 | EPA REGION IX | MATT HABER | (415)-974-8209 | 1.6 |
| CONTINENTAL CARBON CO. | TX | 11/04/82 | TEXAS ACB | JAMES CROCKER | (512)-451-5711 | 1.6 |
| HOUSTON LIGHTING & POWER | TX | 09/10/81 | EPA REGION VI | JOHN BUNYAK | (214)-767-1594 | 1.6 |
| IMOTEK, INC. | CA | 09/01/83 | SACRAMENTO APCD | ROBERT KNIGHT | (916)-366-2107 | 1.6 |
| METROPOLITAN SERVICE DISTRICT | OR | | OREGON DEQ | LLOYD KOSTOW | (503)-229-5186 | 1.6 |
| OCCIDENTAL GEOTHERMAL - OXY #1 | CA | 05/10/82 | EPA REGION IX | MATT HABER | (415)-974-8209 | 1.6 |
| PACIFIC GAS & ELECTRIC CO., GEYSERS UNIM | CA | 07/27/82 | EPA REGION IX | MATT HABER | (415)-974-8209 | 1.6 |
| TEXAS UTILITIES GEN CO. | TX | 09/22/77 | EPA REGION VI | JOHN BUNYAK | (214)-767-1594 | 1.6 |
| TEXAS UTILITIES SERVICE, INC. | TX | 02/09/78 | EPA REGION VI | JOHN BUNYAK | (214)-767-1594 | 1.6 |
| TEXAS UTILITIES SERVICE, INC. | TX | 01/17/78 | EPA REGION VI | JOE WINKLER | (214)-767-1594 | 1.6 |
| U.S. SUGAR CORP. | FL | 01/11/85 | FLORIDA DER | WILLARD HANKS | (904)-488-1344 | 1.6 |
| WESTCHESTER COUNTY RESOURCE RECOVERY | NY | 02/22/82 | EPA REGION II | BARRY TORNIC | (212)-264-9579 | 1.6 |
| SOURCE TYPE -- REFUSE INCINERATION | | | | | | |
| ARLINGTON/ALEXANDRIA WASTE-TO-ENERGY PLT | VA | 10/04/84 | VIRGINIA APCB | KATHERINE MILLER | (804)-786-4867 | 2.1 |
| CE - RESOURCE RECOVERY SYSTEMS | MI | 11/09/84 | MICHIGAN DNR | RAHOAL TELESZ | (517)-322-1333 | 2.1 |
| CITY OF CLEBURNE | TX | 02/27/85 | TEXAS ACB | JAMES RANDALL | (512)-451-5711 | 2.1 |
| COMMERCE REFUSE-TO-ENERGY | CA | 05/08/84 | SOUTH COAST AQMD | T. HUNT | (818)-572-6203 | 2.1 |
| DUTCHESS COUNTY RESOURCE RECOVERY | NY | 10/14/83 | NEW YORK DEC | JAMES HARRINGTON | (516)-457-2018 | 2.1 |
| ENERGY ANSWERS CORP. | MA | 03/15/82 | EPA REGION I | JOHN COURCIER | (617)-223-4448 | 2.1 |
| HOOVER ENERGY CORP. | NY | 07/23/81 | EPA REGION II | BARRY TORNIC | (212)-264-9579 | 2.1 |
| KATY SEGHERS | UT | 02/24/84 | UTAH BAQ | DAVID KOPTA | (801)-533-6108 | 2.1 |
| MCKAY BAY REFUSE-TO-ENERGY PROJECT | FL | 04/25/82 | FLORIDA DER | JOHN SVEC | (904)-488-1344 | 2.1 |
| MCKAY BAY REFUSE-TO-ENERGY PROJECT | FL | 07/02/82 | FLORIDA DER | JOHN SVEC | (904)-488-1344 | 2.1 |
| MUNICIPAL INCINERATOR FULASKI NY | ND | 01/25/80 | EPA REGION III | ED VOLLBERG | (215)-597-8990 | 2.1 |
| NESHIC RESOURCE RECOVERY FACILITY | MA | 05/27/82 | EPA REGION I | JOHN COURCIER | (617)-223-4448 | 2.1 |
| NOFOLK NAVAL SHIPYARD | VA | 03/26/84 | VIRGINIA APCB | JAMES LEHAN | (804)-786-4867 | 2.1 |

* INDICATES DATUM IS TRUNCATED FOR THIS TABLE. SEE FULL LISTING IN APPENDIX.

TABLE 1. INDEX (CONTINUED).

REPORT DATE 05/22/1985

| SOURCE TYPE/COMPANY NAME | STATE | PERMIT ISSUED | AGENCY | NAME OF CONTACT | TELEPHONE | TABLE 2 INDEX |
|---|-------|---------------|---------------------|-------------------|----------------|---------------|
| N.E. MARYLAND WASTE DISPOSAL AUTHORITY | MD | 09/10/81 | EPA REGION III | BOB BLASZCZAK | (215)-597-8186 | 2.1 |
| OGDEN PROJECTS, INC. | OK | 06/21/84 | TULSA CITY-COUNTY * | J. VAN SAKOT | (918)-744-1000 | 2.1 |
| PUBLIC WORKS & UTILITIES | FL | 01/27/84 | FLORIDA DER | BOB KING | (904)-488-1344 | 2.1 |
| REDDY CREEK IMPROVEMENT DIST | FL | 02/11/81 | FLORIDA DER | ED PALAGYI | (904)-488-1344 | 2.1 |
| REFUSE FUELS, INC. | MA | 03/23/81 | EPA REGION I | JOHN COURCIER | (617)-223-4448 | 2.1 |
| RESOURCE RECOVERY DEVELOPMENT AUTHORITY* | GA | 04/05/84 | GEORGIA EPD | PAUL IZANT | (404)-656-4867 | 2.1 |
| RESOURCES AUTHORITY | TN | 08/01/80 | TENNESSEE APCD | MERVAT AHMED | (615)-741-3651 | 2.1 |
| TRANS ENERGY | OR | 12/19/83 | OREGON DEQ | WENDY SIMS | (503)-229-5259 | 2.1 |
| VICON RECOVERY SYSTEMS | VT | 03/20/84 | ENVIRONMENTAL CONS* | LARRY MILLER | (802)-828-3395 | 2.1 |
| SOURCE TYPE -- SEWAGE SLUDGE INCINERATION | | | | | | |
| CITY OF L.A., HYPERION, BUREAU OF ENGIN* | CA | 09/30/82 | EPA REGION IX | RICK SUGAREK | (415)-974-8224 | 2.2 |
| COUNTY SANITATION DISTRICTS OF L.A. COU* | CA | 02/13/84 | EPA REGION IX | JOE SLAMOVICH | (415)-974-8235 | 2.2 |
| SOURCE TYPE -- OTHER SOLID WASTE DISPOSAL | | | | | | |
| CREMATION SERVICES, INC. | OH | | CLEVELAND DAPC | IKE HABIB | (216)-664-3508 | 2.3 |
| DELAWARE SOLID WASTE AUTHORITY | DE | 03/14/80 | EPA REGION III | BOB BLASZCZAK | (215)-597-8186 | 2.3 |
| DELAWARE SOLID WASTE II | DE | 03/14/80 | EPA REGION III | BOB BLASZCZAK | (215)-597-8186 | 2.3 |
| GABRIEL POWER CO. | CA | 04/18/84 | FRESNO COUNTY APCD | C.E. MASKALL | (209)-445-3258 | 2.3 |
| LUSBOCK FEEDLOTS, INC. | TX | 02/16/83 | TEXAS ACB | RALPH BOHLER | (512)-451-5711 | 2.3 |
| RACK PROCESSING CO. | OH | | DAYTON RAPCA | DONNA GORBYLEE | (513)-225-5926 | 2.3 |
| WATSON ENERGY SYS, INC. | CA | 01/03/80 | EPA REGION IX | BOB BAKER | (415)-974-8220 | 2.3 |
| SOURCE TYPE -- NATURAL GAS TURBINES | | | | | | |
| AMCO CHEMICALS CORP. | TX | 03/01/84 | TEXAS ACB | RANDY HAMILTON | (512)-451-5711 | 3.1 |
| ANCHORAGE MUNICIPAL LIGHT & POWER | AK | 10/15/84 | ALASKA DEC | DAVE ESTES | (907)-465-2666 | 3.1 |
| APPLIED ENERGY SERVICES | LA | | LAQD/EPA REGION VI | NAN KILLEEN | (504)-342-8940 | 3.1 |
| BASF WYANDOTTE CO. | LA | 09/13/84 | LAQD/EPA REGION VI | BHARAT CONTRACTOR | (504)-342-8940 | 3.1 |
| CARDINAL COGEN | CA | 06/29/83 | EPA REGION IX | RICK SUGARECK | (415)-974-7631 | 3.1 |
| CHUGACH ELECTRIC ASSOCIATION, UNIT #4 | AK | 08/06/82 | EPA REGION X | PAUL BOYS | (206)-442-1567 | 3.1 |

* INDICATES DATUM IS TRUNCATED FOR THIS TABLE. SEE FULL LISTING IN APPENDIX.

TABLE 2. CONTROL TECHNOLOGY DETERMINATIONS BY TYPE OF SOURCE

SOURCE TYPE CODE: 1.6 EXTERNAL COMBUSTION - OTHER

REPORT DATE 05/22/1985

| COMPANY NAME | STATE & PERMIT | SOURCE SIZE | NEW/ MOD | PROCESS DESCRIPTION | EMISSION LIMITATIONS | & BASIS |
|---|----------------|------------------|-------------|-------------------------------|------------------------|---------|
| TEXAS UTILITIES SERVICE,* (CONTINUED) | | | | | | |
| U.S. SUGAR CORP. | FL AC 26-80930 | 545.50MMBTU HEA* | N | BOILER | SO2 1.20LB/MMBTU | |
| | | | | | PM .15GTU/MMBTU INPU* | |
| | | | | | .10BTU/MMBTU INPU* | |
| | | | | | SO2 .25BTU/MMBTU INPU* | |
| | | | | | 1.50% S OIL MAX | |
| | | | | | VE 20.00% OPACITY MAX | |
| WESTCHESTER COUNTY RESOU* NY | | 2250.00T/D | N | INCINERATORS, REFUSE FIRED, * | AS* .03GR/DSCF | B* |
| | | | | | BE .03GR/DSCF | B* |
| | | | | | CO .62LB/T REFUSE | B* |
| | | | | | HG .03GR/DSCF | B* |
| | | | | | NOX 3.00LB/T REFUSE | B* |
| | | | | | PB .03GR/DSCF | B* |
| | | | | | PM .03GR/DSCF | B* |
| SOURCE TYPE CODE -- 2.1 REFUSE INCINERATION | | | | | | |
| ARLINGTON/ALEXANDRIA WAS* VA 71895 | | 975.00T/D | | INCINERATOR, 3 | PM .03GR/DSCF AT 12%* | B* |
| | | | | | SO2 .12% S CONTENT OF* | B* |
| | | | | | VE 20.00% OPACITY | |
| CE - RESOURCE RECOVERY S* MI 468-83 | | 2200.00T/D | N | BOILER, 3, WATER WALL | CO .09LB/H | B* |
| | | | | | CH* 3.50LB/H | B* |
| | | | | | CH* .02LB/H | B* |
| | | | | | CO 249.00LB/H | L* |
| | | | | | DI* 4.30EE-3 LB/H | B* |
| | | | | | F 3.75LB/H | B* |
| | | | | | HCL 294.00LB/H | B* |
| | | | | | HG .07LB/H | B* |
| | | | | | NOX 226.00LB/H | B* |
| | | | | | PB 1.37LB/H | B* |

* INDICATES DATUM IS TRUNCATED FOR THIS TABLE -- SEE MORE COMPLETE LISTING IN APPENDIX.
 (R) INDICATES EPA REGION FILE NUMBER IN LIEU OF STATE/LOCAL PERMIT NUMBER. FOR EMISSION LIMITS ROUNDED TO 0.00, SEE APPENDIX.

TABLE 2. CONTROL TECHNOLOGY DETERMINATIONS BY TYPE OF SOURCE

SOURCE TYPE CODE: 2.1 REFUSE INCINERATION

REPORT DATE 05/22/1985

| COMPANY NAME | STATE & PERMIT | SOURCE SIZE | NEW/ MOD | PROCESS DESCRIPTION | EMISSION LIMITATIONS | & BASIS |
|--|----------------|----------------|-------------|-------------------------------|----------------------|------------------------|
| CE - RESOURCE RECOVERY S* (CONTINUED) | | | | | | |
| | | | | | PM | .03GR/DSCF AT 12%* L* |
| | | | | | | 40.30LB/H L* |
| | | | | | SO2 | 457.10LB/H, NOTE #2 B* |
| | | | | | VE | 20.00% OPACITY B* |
| | | | | | VOC | 20.50LB/H B* |
| CITY OF CLEBURNE | TX 9521 | 4.80T/H | N | INCINERATOR, 3 EA | CO | 29.00T/YR B* |
| | | | | | HCL | 4.20T/YR B* |
| | | | | | NOX | 17.08T/YR B* |
| | | | | | PB | .48T/YR B* |
| | | | | | PM | 22.21T/YR B* |
| | | | | | SO2 | 5.21T/YR B* |
| | | | | | VOC | 7.05T/YR B* |
| COMMERCE REFUSE-TO-ENERGY CA 103650 | | 330.00T/D | | INCINERATOR, MASS BURN, WATE* | NOX | 40.00LB/H L* |
| | | | | | | 966.00LB/D L* |
| | | | | | PM | 6.00LB/H L* |
| | | | | | | 74.00LB/D L* |
| | | | | | SOX | 11.00LB/H L* |
| | | | | | | 249.00LB/D L* |
| DUTCHESS COUNTY RESOURCE* NY 134601 0024 | | | N | ROTARY COMBUSTORS, 2, TOTAL | CO | 26.00LB/H B* |
| | | | | | HCL | 6.67LB/H, NOTE |
| | | | | | NOX | 50.00LB/H B* |
| | | | | | PM | .02GR/DSCF, NOTE B* |
| | | | | | SO2 | 50.00LB/H D* |
| ENERGY ANSWERS CORP. | MA 025-120MA14 | 1800.00T/D RDF | N | BOILER, WATER-COOLED, 3 EA. | NOX | .50LB/MMBTU B* |
| | | | | | PM | .05GR/DSCF 12% CO2 B* |
| | | | | | SO2 | .34LB/MMBTU P* |
| | | | | | | .30% S BY WT, OIL B* |
| HOOKEE ENERGY CORP. | NY NONE | 2360.00T/D | N | RDF/COAL FIRED BOILERS | NOX | .70LB/MMBTU COAL |
| | | | | | | .30LB/MMBTU OIL |

* INDICATES DATUM IS TRUNCATED FOR THIS TABLE -- SEE MORE COMPLETE LISTING IN APPENDIX.

(R) INDICATES EPA REGION FILE NUMBER IN LIEU OF STATE/LOCAL PERMIT NUMBER. FOR EMISSION LIMITS ROUNDED TO 0.00, SEE APPENDIX.

TABLE 2. CONTROL TECHNOLOGY DETERMINATIONS BY TYPE OF SOURCE

SOURCE TYPE CODE: 2.1 REFUSE INCINERATION

REPORT DATE 05/22/1985

| COMPANY NAME | STATE & PERMIT | SOURCE SIZE | NEW/ MOD | PROCESS DESCRIPTION | EMISSION LIMITATIONS | & BASIS | |
|---------------------------|------------------|-------------|----------|---------------------------------|----------------------|-------------------------|----|
| (CONTINUED) | | | | | | | |
| HOOKER ENERGY CORP. | | | | | PM | .10LB/MMBTU COAL | |
| | | | | | | .07LB/MMBTU OIL | |
| | | | | | PM | .03GR/DSCF REFUSE | |
| | | | | | SO2 | 1.20LB/MMBTU COAL | |
| | | | | | | .80LB/MMBTU OIL | |
| | | | | | VE | 20.00% OPACITY COAL B* | |
| | | | | | | 20.00% OPACITY OIL B* | |
| | | | | | VE | 20.00% OPACITY REFU* B* | |
| KATY SEGHERS | UT | | | N INCINERATOR & BOILER, WASTE * | CO | 35.50LB/H | B* |
| | | | | | F | 1.10LB/H | B* |
| | | | | | HCL | 31.80LB/H | B* |
| | | | | | HG | .12LB/H | B* |
| | | | | | NOX | 29.90LB/H | B* |
| | | | | | PB | .22LB/H | B* |
| | | | | | PM | .03GR/DSCF AT 12%* | B* |
| | | | | | SO2 | 22.40LB/H | B* |
| | | | | | VE | 20.00% OPACITY | B* |
| | | | | | | | |
| | | | | | | | |
| MCKAY BAY REFUSE-TO-ENER* | FL AC 29-47277 | 1000.00T/D | | N MASS BURN FURNACES | PM | .03GR/DSCF AT 12%* L* | |
| MCKAY BAY REFUSE-TO-ENER* | FL (R)PSD FL-086 | 1000.00T/D | | N MASS BURN FURNACES | BE | 5.00G/D | |
| | | | | | F | 6.00LB/H | |
| | | | | | HG | .60LB/H | |
| | | | | | NOX | 300.00LB/H | |
| | | | | | PB | 3.10LB/H | |
| | | | | | SO2 | 170.00LB/H | |
| | | | | | VOC | 9.00LB/H | |
| MUNICIPAL INCINERATOR PU* | MD 78MD-09 | 600.00T/D | | N MUNICIPAL INCINERATOR | CO | 30.00PPH | B* |
| | | | | | | 127.00T/YR | B* |
| | | | | | NOX | 2.60PPH | B* |
| | | | | | | 11.40T/YR | B* |
| | | | | | PM | .03GR/DSCF | S* |
| | | | | | | 61.60T/YR | S* |

* INDICATES DATUM IS TRUNCATED FOR THIS TABLE -- SEE MORE COMPLETE LISTING IN APPENDIX.
 (R) INDICATES EPA REGION FILE NUMBER IN LIEU OF STATE/LOCAL PERMIT NUMBER. FOR EMISSION LIMITS ROUNDED TO 0.00, SEE APPENDIX.

TABLE 2. CONTROL TECHNOLOGY DETERMINATIONS BY TYPE OF SOURCE

SOURCE TYPE CODE: 2.1 REFUSE INCINERATION

REPCRT DATE 05/22/1985

| COMPANY NAME | STATE & PERMIT | SOURCE SIZE | NEW/ MOD | PROCESS DESCRIPTION | EMISSION LIMITATIONS | & BASIS |
|--|----------------|-------------------|-------------|-------------------------------|-----------------------|---------|
| MUNICIPAL INCINERATOR PU* (CONTINUED) | | | | | | |
| | | | | | SO2 35.10PPH | B* |
| | | | | | 154.00T/YR | B* |
| | | | | | VOC 1.30PPH | B* |
| | | | | | 5.50T/YR | B* |
| NESHC RESOURCE RECOVERY * MA 029-121MA16 | | 62.50T/H WASTE | N | AUXILIARY BOILER, 1 | | |
| | | | | | CO .04LB/MMBTU | B* |
| | | | | | NOX .16LB/MMBTU | B* |
| | | | | | PM .10LB/MMBTU | B* |
| | | | | | SOX .02LB/MMBTU | B* |
| | | | | | SO2 .34LB/MMBTU | B* |
| | | | | STEAM GENERATING UNITS, 2 IN* | | |
| | | | | | CO .07LB/MMBTU | B* |
| | | | | | NOX .32LB/MMBTU | B* |
| | | | | | PM .05GR/DSCF AT 12%* | B* |
| | | | | | SOX .02LB/MMBTU | B* |
| | | | | | SO2 .34LB/MMBTU | B* |
| NOFOLK NAVAL SHIPYARD VA 60326 | | 180000.00LB/D | | BOILER, 4 | | |
| | | | | | CO .53LB/MMBTU | P* |
| | | | | | HCL 3.30LB/MMBTU | P* |
| | | | | | HFL 1.10LB/MMBTU | P* |
| | | | | | NOX .70LB/MMBTU | N* |
| | | | | | PM .07LB/MMBTU | P* |
| | | | | | SO2 1.20LB/MMBTU | N* |
| | | | | | VOC .07LB/MMBTU | P* |
| N.E. MARYLAND WASTE DISP* MD 81MD01 | | 2010.00T/D 3 UNI* | N | WATER WALL, 3 EA INCINERATOR | | |
| | | | | | CO 109.00LB/H | B* |
| | | | | | 406.00T/YR | B* |
| | | | | | F 4.20LB/H | B* |
| | | | | | 15.70T/YR | B* |
| | | | | | NOX 227.00LB/H | B* |
| | | | | | 999.00T/YR | B* |
| | | | | | SO2 335.00LB/H | B* |
| | | | | | 1259.00T/YR | B* |
| OGDEN PROJECTS, INC. OK T84-23 | | | | INCINERATOR, SOLID WASTE, 2 * | | |
| | | | | | CO 41.60LB/H | B* |

* INDICATES DATUM IS TRUNCATED FOR THIS TABLE -- SEE MORE COMPLETE LISTING IN APPENDIX.

(R) INDICATES EPA REGION FILE NUMBER IN LIEU OF STATE/LOCAL PERMIT NUMBER. FOR EMISSION LIMITS ROUNDED TO 0.00, SEE APPENDIX.

TABLE 2. CONTROL TECHNOLOGY DETERMINATIONS BY TYPE OF SOURCE

SOURCE TYPE CODE: 2.1 REFUSE INCINERATION

REPORT DATE 05/22/1985

| COMPANY NAME | STATE & PERMIT | SOURCE SIZE | NEW/ MOD | PROCESS DESCRIPTION | EMISSION LIMITATIONS | & BASIS |
|---------------------------|------------------|------------------|-------------|--------------------------------|--|--|
| OGDEN PROJECTS, INC. | (CONTINUED) | | | | HF 3.30LB/H HG .06LB/H NOX 103.10LB/H PM 34.20LB/H SO2 100.90LB/H VOC 4.60LB/H | B* B* B* B* B* B* |
| PUBLIC WORKS & UTILITIES | FL PA 83-18 | 1050.00T/D | M | COMBUSTION SYS., MASS BURN, * | CO 66.00LB/H NOX 132.00LB/H FB 1.30LB/H PM .03GR/DSCF CORR. * SO2 83.00LB/H VE 10.00% OPACITY | B* B* B* B* B* |
| REDDY CREEK IMPROVEMENT * | FL PSD-FL-044 | 100.00T/D SOLID* | M | SLAGGING PYROLYSIS INCIN. | CO 2.26LB/MMBTU 91.20LB/H | B* B* |
| REFUSE FUELS, INC. | MA 023-121MA12 | 960.00T/D RDF | M | FURNACE, WATER WALL, BALANCED* | NOX .70LB/MMBTU RDF .30LB/MMBTU OIL PM .03GR/DSCF S 1.00% S OIL 1.20LB/MMBTU RDF | B* B* L* B* B* |
| RESOURCE RECOVERY DEVELO* | GA 4953-025-8751 | 200.00MMBTU/H | N | INCINERATOR, 2 EA | CO 37.80LB/H HF 1.20LB/H HG .13LB/H NOX 32.00LB/H PB .20LB/H PM .05GR/DSCF AT 12%* SO2 48.00LB/H | N* N* N* N* N* T* N* |
| RESOURCES AUTHORITY | TN | 75.00T/D 2 EA | N | BOILERS, 2 MUNICIPAL REFUSE * | PM .04GR/SCF | N* |
| TRANS ENERGY | OR 24-5398 | 624.00T/D | N | | | |

* INDICATES DATUM IS TRUNCATED FOR THIS TABLE -- SEE MORE COMPLETE LISTING IN APPENDIX.
 (R) INDICATES EPA REGION FILE NUMBER IN LIEU OF STATE/LOCAL PERMIT NUMBER. FOR EMISSION LIMITS ROUNDED TO 0.00, SEE APPENDIX.

TABLE 2. CONTROL TECHNOLOGY DETERMINATIONS BY TYPE OF SOURCE

SOURCE TYPE CODE: 2.1 REFUSE INCINERATION

REPORT DATE 05/22/1985

| COMPANY NAME | STATE & PERMIT | SOURCE SIZE | NEW/ MOD | PROCESS DESCRIPTION | EMISSION LIMITATIONS | & BASIS |
|------------------------|----------------|-------------|-------------|----------------------------------|---------------------------------|---------|
| TRANS ENERGY | (CONTINUED) | | | INCINERATOR, SOLID WASTE, 2 * BE | 2.90EE-6 LB/H 8.80EE-6 T/YR | |
| | | | | CO | 55.00LB/H 170.00T/YR | |
| | | | | FL* | 1.60LB/H 4.80T/YR | |
| | | | | HCL | 23.00LB/H 69.00T/YR | |
| | | | | HG | .17LB/H .51T/YR | |
| | | | | NOX | 94.00LB/H 290.00T/YR | |
| | | | | PB | .52LB/H 1.60T/YR | |
| | | | | PM | .03GR/DSCF AT 12%* 61.00T/YR | |
| | | | | SO2 | 73.00LB/H 220.00T/YR | |
| | | | | TC* | 1.70EE-6 LB/H 5.10EE-6 T/YR | |
| | | | | VE | 10.00% OPACITY SEE * | |
| | | | | VOC | 3.10LB/H 9.60T/YR | |
| VICON RECOVERY SYSTEMS | VT | | | INCINERATOR, MUNICIPLE SOILD* | | |
| | | | | AS* | 2.70EE-4 LB/T | B* |
| | | | | BE | 2.10EE-5 LB/T | B* |
| | | | | HCL | 7.00LB/T | |
| | | | | HG | .02LB/T | |
| | | | | NOX | 3.60LB/T | |
| | | | | PB | .05LB/T | B* |
| | | | | PM | .02GR/DSCF | B* |
| | | | | SO2 | 2.40LB/T | |

SOURCE TYPE CODE -- 2.2 SEWAGE SLUDGE INCINERATION

CITY OF L.A., HYPERION, * CA (R)NSR-4-4-9 *

M

* INDICATES DATUM IS TRUNCATED FOR THIS TABLE -- SEE MORE COMPLETE LISTING IN APPENDIX.
(R) INDICATES EPA REGION FILE NUMBER IN LIEU OF STATE/LOCAL PERMIT NUMBER. FOR EMISSION LIMITS ROUNDED TO 0.00, SEE APPENDIX.

APPENDIX -- DETAILED SOURCE LISTING

05/21/1985

 SOURCE TYPE/SIZE REFUSE INCINERATION 4.80 T/H

 COMPANY NAME/SITE LOCATION CITY OF CLEBURNE CLEBURNE, TX

 JOHNSON COUNTY

 DETERMINATION IS BACT FOR A NEW SOURCE. DATE OF PERMIT ISSUANCE-- 02/27/85
 PERMIT NO. 9521 ESTIMATED DATE OF START-UP-- 1985
 DETERMINATION MADE BY TEXAS A&M (AGENCY) JAMES RANDALL (AGENCY CONTACT PERSON) (512)-451-5711 (PHONE)

| PROCESSES SUBJECT TO THIS PERMIT | THROUGHPUT CAPACITY | POLLUTANT EMITTED | EMISSION LIMITS CONTROL EQUIPMENT OR PROCESS MODIFICATION | ... & BASIS PCT EFF |
|----------------------------------|---------------------|-------------------|---|---------------------|
| INCINERATOR, 3 EA | 1.60 T/H | PM | 22.2100 T/YR ESP(S) | BACT 95.00 |
| | | NOX | 17.0500 T/YR | BACT |
| | | CO | 29.0000 T/YR | BACT |
| | | SO2 | 5.2100 T/YR | BACT |
| | | HCL | 4.2000 T/YR | BACT |
| | | FB | 0.4800 T/YR | BACT |
| | | VOC | 7.0500 T/YR | BACT |

(*1 INDICATES DATUM WAS TRUNCATED FOR THIS TABLE.
 PAGE G- 164

REVIEW STATUS: INITIAL REVIEW POST STARTUP
 ID NUMBER TX-0158 SOURCE TYPE CODE 3.1

APPENDIX -- DETAILED SOURCE LISTING

05/21/1985

 SOURCE TYPE/SIZE REFUSE INCINERATION 330.00 T/D

 COMPANY NAME/SITE LOCATION COMMERCE REFUSE-TO-ENERGY , CA

 DETERMINATION IS PERMIT NO. 103550 DATE OF PERMIT ISSUANCE-- 05/08/84
 DETERMINATION MADE BY SOUTH COAST AQMD (AGENCY) T. HUNT (AGENCY CONTACT PERSON) (818)-572-6293 (PHONE)
 ESTIMATED DATE OF START-UP-- 1985

| PROCESSES SUBJECT TO THIS PERMIT | THROUGHPUT CAPACITY | POLLUTANT EMITTED | EMISSION LIMITS CONTROL EQUIPMENT OR PROCESS MODIFICATION | ... & BASIS PCT EFF |
|----------------------------------|---------------------|-------------------|---|---------------------|
| INCINERATOR, MASS BURN, WATER W# | 330.00 T/D | SOX | 11.0000 LB/H 249.0000 LB/D | LAER |
| | | NOX | 40.0000 LB/H 966.0000 LB/D | 80.00 LAER |
| | | PM | 6.0000 LB/H 74.0000 LB/D BAGHOUSE COMBUSTION CONTROL | 50.00 LAER |

NOTES -----
 OPERATES 24 H/D, 365 D/YR

(*1 INDICATES DATUM WAS TRUNCATED FOR THIS TABLE.
 PAGE G- 165

REVIEW STATUS: INITIAL REVIEW POST STARTUP
 ID NUMBER CA-0107 SOURCE TYPE CODE 3.1

APPENDIX -- DETAILED SOURCE LISTING

05/21/1985

SOURCE TYPE/SIZE REFUSE INCINERATION

COMPANY NAME/SITE LOCATION DUTCHESS COUNTY RESOURCE RECOVERY POUGHKEEPSIE, NY

DETERMINATION IS BACT FOR A NEW SOURCE. DATE OF PERMIT ISSUANCE-- 10/14/83
 PERMIT NO. 134601 0024 ESTIMATED DATE OF START-UP-- 1987
 DETERMINATION MADE BY NEW YORK DEC (AGENCY) JAMES HARRINGTON (AGENCY CONTACT PERSON) (518)-457-2018 (PHONE)

| PROCESSES SUBJECT TO THIS PERMIT | THROUGHPUT CAPACITY | POLLUTANT EMITTED | EMISSION LIMITS CONTROL EQUIPMENT OR PROCESS MODIFICATION | ... & BASIS PCT EFF |
|----------------------------------|---------------------|-------------------|---|---------------------|
| ROTARY COMBUSTORS, 2, TOTAL | 400.00 T/D | PM | 0.0150 GR/DSCF, NOTE FABRIC FILTER | BACT 98.50 |
| | | SO2 | 50.0000 LB/M LCM S FUEL | BACT |
| | | NOX | 50.0000 LB/M PROPER BOILER DESIGN | BACT |
| | | CO | 26.0000 LB/M GOOD COMBUSTION CONTROL | BACT |
| | | HCL | 6.6700 LB/M, NOTE DRY VENTURI INJECTION LINE COATING FOR BAGHOUSE | 93.00 |

NOTES -----

APPLICANT'S ORIGINAL PROPOSAL FOR ESP AT 0.03 GR/DSCF WAS PRELIMINARILY ACCEPTED AS BACT. HOWEVER, DECISION TO USE DRY SCRUBBER /BAGHOUSE FOR ACID GAS CONTROL YIELDED ADDITIONAL PARTICULATE CONTROL. ACID GAS CONTROL WAS NOT A REQUIREMENT OF NYS DEC. PSD PERMIT HAS HELD UP BY ADMINISTRATIVE APPEAL. APPEAL WAS DENIED 12/4/84.

(*) INDICATES DATUM WAS TRUNCATED FOR THIS TABLE.

 INITIAL REVIEW POST STARTUP
 REVIEW STATUS: 01/17/1985

PAGE 6-100

ID NUMBER NY-0012

SOURCE TYPE CODE 2.1

APPENDIX -- DETAILED SOURCE LISTING

05/21/1985

SOURCE TYPE/SIZE REFUSE INCINERATION 1800.00 T/D RDF

COMPANY NAME/SITE LOCATION ENERGY ANSWERS CORP. ROCHESTER, MA
 SENASS PROJECT

DETERMINATION IS BACT FOR A NEW SOURCE. DATE OF PERMIT ISSUANCE-- 03/15/82
 PERMIT NO. 025-120M14 ESTIMATED DATE OF START-UP--
 DETERMINATION MADE BY EPA REGION I (AGENCY) JOHN COURCIER (AGENCY CONTACT PERSON) (617)-223-4448 (PHONE)

| PROCESSES SUBJECT TO THIS PERMIT | THROUGHPUT CAPACITY | POLLUTANT EMITTED | EMISSION LIMITS CONTROL EQUIPMENT OR PROCESS MODIFICATION | ... & BASIS PCT EFF |
|----------------------------------|---------------------|-------------------|---|---------------------|
| BOILER, WATER-COOLED, 3 EA. | 600.00 T/D RDF EA | PM | 0.0500 GR/DSCF 12% CO2 ESP, 3-STAGE | BACT 98.00 |
| | | SO2 | 0.3400 LB/100TU 0.3000 X S BY WT, OIL LCM S #2 FUEL OIL/LCM S RDF | BACT |
| | | NOX | 0.5000 LB/100TU BOILER DESIGN | BACT |

NOTES -----

ALL BACT LIMITS WERE DETERMINED SIMPLY BY TECHNOLOGY AVAILABLE AND THE ECONOMIC IMPACTS OF OTHER CONTROLS.

(*) INDICATES DATUM WAS TRUNCATED FOR THIS TABLE.

 INITIAL REVIEW POST STARTUP
 REVIEW STATUS: 04/01/1985

PAGE 6-167

ID NUMBER MA-0022

SOURCE TYPE CODE 2.1

APPENDIX -- DETAILED SOURCE LISTING

05/21/1985

 SOURCE TYPE/SIZE REFUSE INCINERATION 2360.00 T/D

 COMPANY NAME/SITE LOCATION HOOKER ENERGY CORP. NIAGARA FALLS, NY NIAGARA COUNTY

 DETERMINATION IS BACT FOR A NEW SOURCE. DATE OF PERMIT ISSUANCE-- 07/23/81
 PERMIT NO. NONE ESTIMATED DATE OF START-UP-- 1982
 DETERMINATION MADE BY EPA REGION II (AGENCY) BARRY TORNICK (AGENCY CONTACT PERSON) (812)-264-9579 (PHONE)

| PROCESSES SUBJECT TO THIS PERMIT | THROUGHPUT CAPACITY | POLLUTANT EMITTED | EMISSION LIMITS CONTROL EQUIPMENT OR PROCESS MODIFICATION | ... & BASIS PCT EFF |
|----------------------------------|---------------------|-------------------|--|---------------------|
| ROP/COAL FIRED BOILERS | 2360.00 T/D REFUSE | SO2 | 1.2000 LB/100TU COAL 0.8000 LB/100TU OIL CONTRL METHOD: FUEL S CONTENT | |
| | | NOX | 0.7000 LB/100TU COAL 0.3000 LB/100TU OIL CONTRL METHOD: TEMP & E.A. | |
| | | PM | 0.1000 LB/100TU COAL 0.0700 LB/100TU OIL | |
| | | PH | 0.0300 GR/DSCF REFUSE | |
| | | VE | 20.0000 % OPACITY COAL | BACT |
| | | VE | 20.0000 % OPACITY OIL | BACT |
| | | VE | 20.0000 % OPACITY REFUSE | BACT |

NOTES -----
 COAL USE LIMITED TO 30 DAYS PER YEAR. COMBUSTION FUEL EMISSION LIMITS INTERPOLATED BASED ON FUEL MIXTURE RATIO.

(*) INDICATES DATUM WAS TRUNCATED FOR THIS TABLE. INITIAL REVIEW POST STARTUP
 REVIEW STATUS: 04/01/1983
 PAGE 6- 163 ID NUMBER NY-0002 SOURCE TYPE CODE 2.1

APPENDIX -- DETAILED SOURCE LISTING

05/21/1985

 SOURCE TYPE/SIZE REFUSE INCINERATION

 COMPANY NAME/SITE LOCATION KATY SEGHERS CLEARFIELD, UT

 DETERMINATION IS BACT FOR A NEW SOURCE. DATE OF PERMIT ISSUANCE-- 02/24/84
 PERMIT NO. ESTIMATED DATE OF START-UP-- 1985
 DETERMINATION MADE BY UTAH BAQ (AGENCY) DAVID KOYTA (AGENCY CONTACT PERSON) (801)-533-6108 (PHONE)

| PROCESSES SUBJECT TO THIS PERMIT | THROUGHPUT CAPACITY | POLLUTANT EMITTED | EMISSION LIMITS CONTROL EQUIPMENT OR PROCESS MODIFICATION | ... & BASIS PCT EFF |
|----------------------------------|---------------------|-------------------|---|---------------------|
| INCINERATOR & BOILER, WASTE HEAT | 500.00 T/D | PM | 0.0250 GR/DSCF AT 12% CO2 ESP | BACT 98.00 |
| | | VE | 20.0000 % OPACITY ESP | BACT 3ACT |
| | | SO2 | 22.4000 LB/H LIME SCRUBBER/INJECTION | BACT 50.00 |
| | | HCL | 31.8000 LB/H LIME SCRUBBER/INJECTION | BACT 50.00 |
| | | NOX | 29.9000 LB/H COMBUSTION CONTROL | BACT |
| | | CO | 35.5000 LB/H COMBUSTION CONTROL | BACT |
| | | F | 1.1000 LB/H ESP | BACT |
| | | HG | 0.1200 LB/H | BACT |
| | | PB | 0.2200 LB/H ESP | BACT |

(*) INDICATES DATUM WAS TRUNCATED FOR THIS TABLE. INITIAL REVIEW POST STARTUP
 REVIEW STATUS:
 PAGE 6- 169 ID NUMBER UT-0032 SOURCE TYPE CODE 2.1

APPENDIX -- DETAILED SOURCE LISTING

05/21/1985

| | | |
|---|------------------------------------|---|
| SOURCE TYPE/SIZE | REFUSE INCINERATION | 1000.00 T/D |
| ----- | | |
| COMPANY NAME/SITE LOCATION | MCKAY BAY REFUSE-TO-ENERGY PROJECT | TAMPA, FL 33602 |
| ----- | | |
| DETERMINATION IS LAER FOR A NEW SOURCE. PERMIT NO. AC 29-47277 | | DATE OF PERMIT ISSUANCE-- 04/15/82 ESTIMATED DATE OF START-UP-- 1984 |
| DETERMINATION MADE BY | FLORIDA DER (AGENCY) | JOHN SVEC (AGENCY CONTACT PERSON) (904)-488-1344 (PHONE) |
| ----- | | |
| PROCESSES SUBJECT TO THIS PERMIT | THROUGHPUT CAPACITY | POLLUTANT EMITTED |
| ----- | ----- | ----- |
| MASS BURN FURNACES | 1000.00 T/D WASTE | PH VE |
| | | EMISSION LIMITS 0.0250 GR/DSCF AT 10% O2 ESP |
| | | CONTROL EQUIPMENT OR PROCESS MODIFICATION CONTINUOUS OPACITY MONITOR |
| | | ... & BASIS ... PCT EFF LAER 99.00 |

NOTES -----
CONTINUOUS OPACITY MONITOR LIMITS TO BE DETERMINED DURING PERFORMANCE TESTING. FACILITY TO INCLUDE WASTE HEAT BOILERS AND TURBINE ELECTRICAL GENERATORS.

(*) INDICATES DATUM WAS TRUNCATED FOR THIS TABLE. INITIAL REVIEW POST STARTUP
REVIEW STATUS: 04/21/1983

PAGE G-170 ID NUMBER FL-0030 SOURCE TYPE CODE 2.1

APPENDIX -- DETAILED SOURCE LISTING

05/21/1985

| | | |
|--|------------------------------------|--|
| SOURCE TYPE/SIZE | REFUSE INCINERATION | 1000.00 T/D |
| ----- | | |
| COMPANY NAME/SITE LOCATION | MCKAY BAY REFUSE-TO-ENERGY PROJECT | TAMPA, FL 33602 |
| ----- | | |
| DETERMINATION IS BACT FOR A NEW SOURCE. PERMIT NO. (REGION FILE NO.) PSD FL-086 | | DATE OF PERMIT ISSUANCE-- 07/02/82 ESTIMATED DATE OF START-UP-- 1984 |
| DETERMINATION MADE BY | FLORIDA DER (AGENCY) | JOHN SVEC (AGENCY CONTACT PERSON) (904)-488-1344 (PHONE) |
| ----- | | |
| PROCESSES SUBJECT TO THIS PERMIT | THROUGHPUT CAPACITY | POLLUTANT EMITTED |
| ----- | ----- | ----- |
| MASS BURN FURNACES | 1000.00 T/D WASTE | SO2 NOX VOC PB F HG BE |
| | | 170.0000 LB/H LOW SULFUR FUEL 300.0000 LB/H COMBUSTION TECHNIQUE 9.0000 LB/H COMBUSTION TECHNIQUE 3.1000 LB/H ESP 6.0000 LB/H NONE 0.6000 LB/H ESP 5.0000 G/D ESP |
| | | CONTROL EQUIPMENT OR PROCESS MODIFICATION CONTINUOUS OPACITY MONITOR |
| | | ... & BASIS ... PCT EFF 98.00 98.00 |

NOTES -----
FACILITY DESIGN ALLOWS FOR FUTURE INSTALLATION OF A SCRUBBER SYSTEM; NSPS APPLIES TO THIS FACILITY. FURNACES-FOUR 250 TPD USIN G VOLLUM TECHNOLOGY, WASTE HEAT BOILERS & TURBINE GENERATORS.

(*) INDICATES DATUM WAS TRUNCATED FOR THIS TABLE. INITIAL REVIEW POST STARTUP
REVIEW STATUS: 04/21/1983

PAGE G-171 ID NUMBER FL-0030 SOURCE TYPE CODE 2.1

APPENDIX -- DETAILED SOURCE LISTING

05/21/1985

SOURCE TYPE/SIZE REFUSE INCINERATION 600.00 T/D
 COMPANY NAME/SITE LOCATION MUNICIPAL INCINERATOR PULASKI HWY BALTIMORE, MD 21237
 PULASKI HIGHWAY BALTIMORE CITY COUNTY

DETERMINATION IS BACT FOR A NEW SOURCE. DATE OF PERMIT ISSUANCE-- 01/25/80
 PERMIT NO. 78MD-09 ESTIMATED DATE OF START-UP-- 1981
 DETERMINATION MADE BY EPA REGION III ED VOLLBERG (215)-597-8990
 (AGENCY) (AGENCY CONTACT PERSON) (PHONE)

| PROCESSES SUBJECT TO THIS PERMIT | THROUGHPUT CAPACITY | POLLUTANT EMITTED | EMISSION LIMITS CONTROL EQUIPMENT OR PROCESS MODIFICATION | ... & BASIS PCT EFF |
|----------------------------------|---------------------|-------------------|--|----------------------|
| MUNICIPAL INCINERATOR | 600.00 T/D MSH | PM | 0.0300 GR/DSCF 81.6000 T/YR ESP | SIP 98.00 BACT |
| | | SO2 | 35.1000 PPH 154.0000 T/YR PROPER COMBUSTION TECHNIQUES | BACT |
| | | CO | 30.0000 PPH 127.0000 T/YR PROPER COMBUSTION TECHNIQUES | BACT |
| | | VOC | 1.3000 PPH 5.5000 T/YR PROPER COMBUSTION TECHNIQUES | BACT |
| | | NOX | 2.6000 PPH 11.4000 T/YR PROPER COMBUSTION TECHNIQUES | BACT |

(*) INDICATES DATUM WAS TRUNCATED FOR THIS TABLE. INITIAL REVIEW POST STARTUP
 REVIEW STATUS: 04/01/1983
 PAGE G- 172 ID NUMBER MD-0000 SOURCE TYPE CODE 2.1

APPENDIX -- DETAILED SOURCE LISTING

05/21/1985

SOURCE TYPE/SIZE REFUSE INCINERATION 62.50 T/M WASTE
 COMPANY NAME/SITE LOCATION HESHC RESOURCE RECOVERY FACILITY NORTH ANDOVER, MA

DETERMINATION IS BACT FOR A NEW SOURCE. DATE OF PERMIT ISSUANCE-- 05/27/82
 PERMIT NO. 029-121MA16 ESTIMATED DATE OF START-UP-- 1983
 DETERMINATION MADE BY EPA REGION I JOHN COURCIER (617)-233-6668
 (AGENCY) (AGENCY CONTACT PERSON) (PHONE)

| PROCESSES SUBJECT TO THIS PERMIT | THROUGHPUT CAPACITY | POLLUTANT EMITTED | EMISSION LIMITS CONTROL EQUIPMENT OR PROCESS MODIFICATION | ... & BASIS PCT EFF |
|----------------------------------|---------------------|-------------------|---|-----------------------|
| STEAM GENERATING UNITS, 2 INCIN* | 750.00 T/D EA, WAS* | PM | 0.0500 GR/DSCF AT 12% CO2 ESP | B/S 98.66 BACT |
| | | SO2 | 0.3400 LB/MMBTU LCH S FUEL - 0.3% S #2 OIL | BACT |
| | | NOX | 0.3200 LB/MMBTU INCINERATOR DESIGN | BACT |
| | | CO | 0.0700 LB/MMBTU INCINERATOR DESIGN | BACT 98.00 BACT |
| | | SOX | 0.0200 LB/MMBTU INCINERATOR DESIGN | BACT |
| AUXILIARY BOILER, 1 | 19.60 MMBTU/H | NOX | 0.1550 LB/MMBTU BOILER DESIGN | BACT |
| | | CO | 0.0350 LB/MMBTU BOILER DESIGN | BACT 98.00 BACT |
| | | SOX | 0.0200 LB/MMBTU BOILER DESIGN | BACT |
| | | PM | 0.1000 LB/MMBTU | B/S |
| | | SO2 | 0.3400 LB/MMBTU LCH S FUEL - 0.3% S #2 OIL | BACT |

NOTES -----
 LIMITS ARE REDUCTION OVER AP-42 EMISSIONS

(*) INDICATES DATUM WAS TRUNCATED FOR THIS TABLE. INITIAL REVIEW POST STARTUP
 REVIEW STATUS: 04/01/1983
 PAGE G- 173 ID NUMBER MA-0004 SOURCE TYPE CODE 2.1

APPENDIX -- DETAILED SOURCE LISTING

05/21/1985

SOURCE TYPE/SIZE REFUSE INCINERATION 180000.00 LB/D
 COMPANY NAME/SITE LOCATION NORFOLK NAVAL SHIPYARD NORFOLK, VA
 DETERMINATION IS BACT PERMIT NO. 60326 DATE OF PERMIT ISSUANCE-- 03/26/84
 ESTIMATED DATE OF START-UP--
 DETERMINATION MADE BY VIRGINIA APCB JAMES LEHAN (1804)-786-4867
 (AGENCY) (AGENCY CONTACT PERSON) (PHONE)

| PROCESSES SUBJECT TO THIS PERMIT | THROUGHPUT CAPACITY | POLLUTANT EMITTED | EMISSION LIMITS CONTROL EQUIPMENT OR PROCESS MODIFICATION | ... & BASIS PCT EFF |
|----------------------------------|---------------------|-------------------|---|---------------------|
| BOILER, 4 | 180000.00 LB/D | PM | 0.0700 LB/100STU NOTE #1 | PSD 99.00 |
| | | SO2 | 1.2000 LB/100STU 0.83% SULFUR IN COAL | NSPS |
| | | NOX | 0.7000 LB/100STU NOTE #2 | NSPS |
| | | CO | 0.5300 LB/100STU NOTE #3 | PSD |
| | | VOC | 0.0700 LB/100STU COMBUSTION PARAMETERS | PSD |
| | | HFL | 1.1000 LB/100STU | PSD |
| | | HCL | 3.3000 LB/100STU | PSD |

NOTES -----
 NOTE #1 - CYCLONE & BAGHOUSE IN SERIES FOR A SYSTEM GRAIN LOADING OF 0.015 GR/CU FT. NOTE #2 - RCF HAS LOW SULFUR CONTENT, EACH UNIT IS DESIGNED TO MEET NSPS LIMITS WHEN BURNING COAL. NOTE #3 - EACH UNIT IS DESIGNED FOR LOW CO EMISSIONS.

(*1) INDICATES DATUM WAS TRUNCATED FOR THIS TABLE.

REVIEW STATUS: INITIAL REVIEW POST STARTUP

PAGE G- 174

ID NUMBER VA-0026

SOURCE TYPE CODE 0.1

APPENDIX -- DETAILED SOURCE LISTING

05/21/1985

SOURCE TYPE/SIZE REFUSE INCINERATION 2010.00 T/D 3 UNITS
 COMPANY NAME/SITE LOCATION N.E. MARYLAND WASTE DISPOSAL AUTHORITY BALTIMORE, MD 21230
 1801 OLD AIRFOLDS ROAD BALTIMORE CITY COUNTY
 DETERMINATION IS BACT FOR A MODIFIED SOURCE. DATE OF PERMIT ISSUANCE-- 09/10/81
 PERMIT NO. 81MD01 ESTIMATED DATE OF START-UP-- 1984
 DETERMINATION MADE BY EPA REGION III BOB BLASZCZAK (215)-597-6166
 (AGENCY) (AGENCY CONTACT PERSON) (PHONE)

| PROCESSES SUBJECT TO THIS PERMIT | THROUGHPUT CAPACITY | POLLUTANT EMITTED | EMISSION LIMITS CONTROL EQUIPMENT OR PROCESS MODIFICATION | ... & BASIS PCT EFF |
|----------------------------------|---------------------|-------------------|---|---------------------|
| WATER WALL, 3 EA INCINERATOR | 2010.00 T/D | SO2 | 335.0000 LB/H 1259.0000 T/YR | BACT |
| | | CO | 109.0000 LB/H 404.0000 T/YR | BACT |
| | | NOX | 227.0000 LB/H 999.0000 T/YR | BACT |
| | | F | 4.2000 LB/H 15.7000 T/YR | BACT |
| | | | | |

NOTES -----
 MARYLAND DEPT. OF HEALTH AND MENTAL HYGIENE PERFORMED LASER ANALYSIS FOR PARTICULATE MATTER. 0.019 GR/DSCF CORRECTED TO 12% CO IS BEING CONSIDERED (ESP).
 EMISSION RATES BASED ON REFUSE CHARACTERISTICS. PERMITTEE IS TO PROVIDE PROCEDURES TO ENSURE ACCEPTABLE WASTE BEFORE OPERATION

(*1) INDICATES DATUM WAS TRUNCATED FOR THIS TABLE.

REVIEW STATUS: INITIAL REVIEW POST STARTUP

PAGE G- 175

ID NUMBER MD-0005

SOURCE TYPE CODE 2.1

APPENDIX -- DETAILED SOURCE LISTING

05/21/1985

=====

SOURCE TYPE/SIZE REFUSE INCINERATION

COMPANY NAME/SITE LOCATION OGDEN PROJECTS, INC. , OK

DETERMINATION IS BACT PERMIT NO. T84-23 DATE OF PERMIT ISSUANCE-- 06/21/84
 DETERMINATION MADE BY TULSA CITY-COUNTY HEALTH DEPT J. VAN SANDT ESTIMATED DATE OF START-UP-- 1981
 (AGENCY) (AGENCY CONTACT PERSON) (PHONE)

=====

| PROCESSES SUBJECT TO THIS PERMIT | THROUGHPUT CAPACITY | POLLUTANT EMITTED | EMISSION LIMITS CONTROL EQUIPMENT OR PROCESS MODIFICATION | ... & BASIS PCT EFF |
|----------------------------------|---------------------|-------------------|---|---------------------|
| INCINERATOR, SOLID WASTE, 2 EA | 375.00 T/YR | PM | 34.2000 LB/H 2 ESPS, SEE NOTE 2 | BACT 98.00 |
| | | SO2 | 100.9000 LB/H | BACT |
| | | NOX | 103.1000 LB/H | BACT |
| | | VOC | 4.6000 LB/H | BACT |
| | | CO | 41.6000 LB/H | BACT |
| | | HG | 2.0600 LB/H | BACT |
| | | HF | 3.3000 LB/H | BACT |

NOTES -----

NOTE 1 - SIC CODES 4931 & 4941 ARE ALSO INVOLVED BECAUSE STEAM & ELECTRICITY WILL BE SOLD TO INDUSTRY. NOTE 2 - PERFORMANCE ST AND OPS OF 10% AVG. OPACITY PER CLOCK HOUR & 0.06 GR/DSCF CORRECTED TO 12% CO HAS BEEN IMPOSED.

NOTE - - UNITS SHOWN ARE FOR TWO INCINERATORS.

(*) INDICATES DATUM WAS TRUNCATED FOR THIS TABLE. INITIAL REVIEW POST STARTUP
 REVIEW STATUS: 05/15/1984

=====

PAGE 6- 176 ID NUMBER OK-0021 SOURCE TYPE CODE 2.1

APPENDIX -- DETAILED SOURCE LISTING

05/21/1985

=====

SOURCE TYPE/SIZE REFUSE INCINERATION 1050.00 T/D

COMPANY NAME/SITE LOCATION PUBLIC WORKS & UTILITIES , FL PINELLAS COUNTY

DETERMINATION IS BACT FOR A MODIFIED SOURCE. PERMIT NO. PA 83-18 DATE OF PERMIT ISSUANCE-- 01/27/84
 DETERMINATION MADE BY FLORIDA DER BOB KING ESTIMATED DATE OF START-UP-- 1986
 (AGENCY) (AGENCY CONTACT PERSON) (PHONE)

=====

| PROCESSES SUBJECT TO THIS PERMIT | THROUGHPUT CAPACITY | POLLUTANT EMITTED | EMISSION LIMITS CONTROL EQUIPMENT OR PROCESS MODIFICATION | ... & BASIS PCT EFF |
|----------------------------------|---------------------|-------------------|---|---------------------|
| CONDUCTION SYS., MASS ELRN, HAR* | 1050.00 T/D | PM | 0.0300 GR/DSCF CORR. TO 12% CO2 ESP | 99.00 |
| | | SO2 | 83.0000 LB/H MSW SULFUR CONTENT | |
| | | NOX | 132.0000 LB/H DESIGN | |
| | | CO | 66.0000 LB/H DESIGN | |
| | | PB | 1.3000 LB/H ESP | 99.00 |
| | | VE | 10.0000 % OPACITY | |

NOTES -----

THIS IS A NEW UNIT ADDED TO TWO EXISTING UNITS. TOTAL NOW 3150 T/D. SOURCE IS LOCATED IN THE INFLUENCE OF, BUT DOES NOT IMPACT A PARTICULATE NONATTAINMENT AREA.

(*) INDICATES DATUM WAS TRUNCATED FOR THIS TABLE. INITIAL REVIEW POST STARTUP
 REVIEW STATUS: 05/15/1984

=====

PAGE 6- 177 ID NUMBER FL-0033 SOURCE TYPE CODE 2.1

APPENDIX -- DETAILED SOURCE LISTING

05/21/1985

SOURCE TYPE/SIZE REFUSE INCINERATION 100.00 T/D SOLID WASTE

COMPANY NAME/SITE LOCATION REDDY CREEK IMPROVEMENT DIST LAKE BUENA VISTA, FL 32830
P.O. BOX 36 ORANGE COUNTY

DETERMINATION IS BACT FOR A MODIFIED SOURCE. DATE OF PERMIT ISSUANCE-- 02/11/81
PERMIT NO. PD-FL-044 ESTIMATED DATE OF START-UP-- 1982
DETERMINATION MADE BY FLORIDA DER ED PALAGYI
(AGENCY) (AGENCY CONTACT PERSON) (PHONE)

| PROCESSES SUBJECT TO THIS PERMIT | THROUGHPUT CAPACITY | POLLUTANT EMITTED | EMISSION LIMITS CONTROL EQUIPMENT OR PROCESS MODIFICATION | ... & BASIS PCT EFF |
|----------------------------------|---------------------|-------------------|---|---------------------|
| SLAGGING PYROLYSIS INCIN. | 100.00 T/D | CO | 2.2600 LB/MMSTU 91.2000 LB/H FLUE GAS MONITORING SYS. | BACT |

NOTES -----
SOURCE SHUT-DOWN 01/01/83 INDEFINITELY DUE TO OPERATIONAL ECONOMICS.

(*) INDICATES DATUM WAS TRUNCATED FOR THIS TABLE. INITIAL REVIEW POST STARTUP
REVIEW STATUS: 04/01/1983 01/25/1984
PAGE 6- 178 ID NUMBER FL-0007 SOURCE TYPE CODE 2.1

APPENDIX -- DETAILED SOURCE LISTING

05/21/1985

SOURCE TYPE/SIZE REFUSE INCINERATION 960.00 T/D RDF

COMPANY NAME/SITE LOCATION REFUSE FUELS, INC. LAURENCE, MA

DETERMINATION IS BACT FOR A MODIFIED SOURCE. DATE OF PERMIT ISSUANCE-- 03/27/81
PERMIT NO. 023-121MA12 ESTIMATED DATE OF START-UP-- 1982
DETERMINATION MADE BY EPA REGION I JOHN COURCIER
(AGENCY) (AGENCY CONTACT PERSON) (PHONE)

| PROCESSES SUBJECT TO THIS PERMIT | THROUGHPUT CAPACITY | POLLUTANT EMITTED | EMISSION LIMITS CONTROL EQUIPMENT OR PROCESS MODIFICATION | ... & BASIS PCT EFF |
|-----------------------------------|---------------------|-------------------|---|---------------------|
| FURNACE, WATER HALL, BALANCED CR* | 960.00 T/D RDF | PM | 0.0250 GR/DSCF ESP, S-FIELD, IN SERIES | LAER 98.00 |
| | | S | 1.0000 % S OIL 1.2000 LB/MMSTU RDF | BACT |
| | | NOX | LOW S #6 OIL/LOW S RDF 0.7000 LB/MMSTU RDF 0.3000 LB/MMSTU OIL BOILER DESIGN | BACT |

NOTES -----
LAER REQUIRED ON TSP FOR NONATTAINMENT AREA IN LAURENCE. BACT ON SO2 DETERMINED BY TECHNOLOGY AND ECONOMICS. BACT ON NO2 DETERMINED BY MEETING NSPS LIMITS FOR FOSSIL FUEL BOILERS.
1.2 LB/MMSTU EQUIV. TO 1.0 % S OIL.

(*) INDICATES DATUM WAS TRUNCATED FOR THIS TABLE. INITIAL REVIEW POST STARTUP
REVIEW STATUS: 04/01/1983
PAGE 6- 179 ID NUMBER MA-0001 SOURCE TYPE CODE 2.1

APPENDIX -- DETAILED SOURCE LISTING

05/21/1985

 SOURCE TYPE/SIZE REFUSE INCINERATION 200.00 MMBTU/H

 COMPANY NAME/SITE LOCATION RESOURCE RECOVERY DEVELOPMENT AUTHORITY SAVANNAH, GA

 DETERMINATION IS BACT FOR A NEW SOURCE. DATE OF PERMIT ISSUANCE-- 04/05/84
 PERMIT NO. 4953-025-8751 ESTIMATED DATE OF START-UP-- 1987
 DETERMINATION MADE BY GEORGIA EPO PAUL IZANT (404) 456-4267
 (AGENCY) (AGENCY CONTACT PERSON) (PHONE)

| PROCESSES SUBJECT TO THIS PERMIT | THROUGHPUT CAPACITY | POLLUTANT EMITTED | EMISSION LIMITS CONTROL EQUIPMENT OR PROCESS MODIFICATION | ... & BASIS PCT EFF |
|----------------------------------|---------------------|-------------------|---|---------------------|
| INCINERATOR, 2 EA | 100.00 MMBTU/H | PM | 0.0500 GR/SCF AT 12% CO2 ESP | TECH 99.00 |
| | | SO2 | 48.0000 LB/H WITHOUT CONTROL | NOTE |
| | | NOX | 32.0900 LB/H FURNACE DESIGN, OPER. PROCEDURES | NOTE |
| | | CO | 37.8000 LB/H FURNACE DESIGN, OPER. PROCEDURES | NOTE |
| | | PB | 0.2000 LB/H ESP | NOTE |
| | | HG | 0.1200 LB/H ESP | NOTE |
| | | HF | 1.2000 LB/H WITHOUT CONTROL | NOTE |

NOTES -----
 NOTE - BASED ON MUNICIPAL SOLID WASTE (MSW) CHARACTERISTICS.

(*) INDICATES DATUM WAS TRUNCATED FOR THIS TABLE. INITIAL REVIEW POST STARTUP
 REVIEW STATUS: 03/31/1984
 PAGE G- 180 ID NUMBER GA-0017 SOURCE TYPE CODE 2.1

APPENDIX -- DETAILED SOURCE LISTING

05/21/1985

 SOURCE TYPE/SIZE REFUSE INCINERATION 75.00 T/D 2 EA

 COMPANY NAME/SITE LOCATION RESOURCES AUTHORITY GALLATIN, TN SUMNER COUNTY

 DETERMINATION IS BACT FOR A NEW SOURCE. DATE OF PERMIT ISSUANCE-- 08/01/80
 PERMIT NO. ESTIMATED DATE OF START-UP--
 DETERMINATION MADE BY TENNESSEE APCD MERVAT AHMED (615) 741-3651
 (AGENCY) (AGENCY CONTACT PERSON) (PHONE)

| PROCESSES SUBJECT TO THIS PERMIT | THROUGHPUT CAPACITY | POLLUTANT EMITTED | EMISSION LIMITS CONTROL EQUIPMENT OR PROCESS MODIFICATION | ... & BASIS PCT EFF |
|----------------------------------|---------------------|-------------------|---|---------------------|
| BOILERS, 2 MUNICIPAL REFUSE BUR* | 75.00 T/D EA | PM | 0.0400 GR/SCF SCRUB.. & FABRIC FILTERS | NSPS 99.00 |

(*) INDICATES DATUM WAS TRUNCATED FOR THIS TABLE. INITIAL REVIEW POST STARTUP
 REVIEW STATUS: 04/01/1983
 PAGE G- 181 ID NUMBER TN-0012 SOURCE TYPE CODE 2.1

APPENDIX -- DETAILED SOURCE LISTING

05/21/1985

 SOURCE TYPE/SIZE REFUSE INCINERATION 624.00 T/D

 COMPANY NAME/SITE LOCATION TRANS ENERGY BROOKS, OR

 DETERMINATION IS BASED FOR A NEW SOURCE. DATE OF PERMIT ISSUANCE-- 12/19/83
 PERMIT NO. 24-5393 ESTIMATED DATE OF START-UP-- 1987
 DETERMINATION MADE BY OREGON DEQ WENDY JIMS (503)-629-5299
 (AGENCY) (AGENCY CONTACT PERSON) (PHONE)

| PROCESSES SUBJECT TO THIS PERMIT | THROUGHPUT CAPACITY | POLLUTANT EMITTED | EMISSION LIMITS CONTROL EQUIPMENT OR PROCESS MODIFICATION | ... & BASIS ... PCT EFF |
|----------------------------------|---------------------|-------------------|---|-------------------------|
| INCINERATOR, SOLID WASTE, 2 EA | 312.00 T/D | | | |
| | | PM | 0.0300 GR/DSCF AT 12% CO2 61.0000 T/YR BAGHOUSE, OR ESP | |
| | | NOX | 94.0000 LB/H 290.0000 T/YR EQUIPMENT DESIGN & OPERATION | |
| | | HCL | 13.0000 LB/H 69.0000 T/YR SCRUBBER | 60.00 |
| | | SO2 | 73.0000 LB/H 220.0000 T/YR EQUIPMENT DESIGN & OPERATION | |
| | | VE | 10.0000 % OPACITY SEE NOTE | |
| | | CO | 55.0000 LB/H 170.0000 T/YR EQUIPMENT DESIGN & OPERATION | |
| | | HG | 0.1700 LB/H 0.5100 T/YR EQUIPMENT DESIGN & OPERATION | |
| | | VOC | 3.1000 LB/H 9.6000 T/YR EQUIPMENT DESIGN & OPERATION | |
| | | PB | 0.5200 LB/H 1.6000 T/YR EQUIPMENT DESIGN & OPERATION | |

(*) INDICATES DATA WAS TRUNCATED FOR THIS TABLE.

INITIAL REVIEW POST STARTUP
 REVIEW STATUS: 04/19/1984

PAGE G- 162

ID NUMBER CR-0004

SOURCE TYPE CODE 2.1

(CONTINUED) TRANS ENERGY

| PROCESSES SUBJECT TO THIS PERMIT | THROUGHPUT CAPACITY | POLLUTANT EMITTED | EMISSION LIMITS CONTROL EQUIPMENT OR PROCESS MODIFICATION | ... & BASIS ... PCT EFF |
|----------------------------------|---------------------|-------------------|--|-------------------------|
| SAME PROCESS (CONTINUED) | | | | |
| | | FLUW | 1.6000 LB/H 4.8000 T/YR EQUIPMENT DESIGN & OPERATION | |
| | | BE | 2.9000 EE-6 LB/H 8.8000 EE-6 T/YR EQUIPMENT DESIGN & OPERATION | |
| | | TCOD | 1.7000 EE-6 LB/H 5.1000 EE-6 T/YR TEMPERATURE CONTROL | |

NOTES -----

NOT TO BE EXCEEDED FOR MORE THAN 3 MINUTES IN ANY ONE HOUR PERIOD.

(*) INDICATES DATA WAS TRUNCATED FOR THIS TABLE.

INITIAL REVIEW POST STARTUP
 REVIEW STATUS: 04/19/1984

PAGE G- 163

ID NUMBER CR-0004

SOURCE TYPE CODE 2.1

APPENDIX -- DETAILED SOURCE LISTING

05/01/1985

| SOURCE TYPE/SIZE | | REFUSE INCINERATION | |
|---|---------------------|--------------------------------------|---|
| COMPANY NAME/SITE LOCATION | | VICON RECOVERY SYSTEMS | |
| RUTLAND, VT | | | |
| DETERMINATION IS PERMIT NO. | | DATE OF PERMIT ISSUANCE-- 03/20/84 | |
| DETERMINATION MADE BY ENVIRONMENTAL CONSERVATION (AGENCY) | | LARRY MILLER (AGENCY CONTACT PERSON) | |
| | | ESTIMATED DATE OF START-UP-- 1987 | |
| | | (802)-803-3395 (PHONE) | |
| PROCESSES SUBJECT TO THIS PERMIT | THROUGHPUT CAPACITY | POLLUTANT EMITTED | EMISSION LIMITS CONTROL EQUIPMENT OR PROCESS MODIFICATION ... & BASIS PCT EFF |
| INCINERATOR, MUNICIPAL SOLID WA* | 240.00 T/D | PM | 0.0200 GR/DSCF ESP |
| | | PM | 0.0540 LB/T ESP |
| | | BE | 2.1000 EE-5 LB/T ESP |
| | | ASB* | 2.7000 EE-4 LB/T ESP |
| | | HCL | 7.0000 LB/T |
| | | SO2 | 2.4000 LB/T |
| | | NOX | 3.6000 LB/T |
| | | HG | 0.0150 LB/T |

(* INDICATES DATUM WAS TRUNCATED FOR THIS TABLE.

REVIEW STATUS: INITIAL REVIEW POST STARTUP

PAGE G- 184

ID NUMBER VT-0003

SOURCE TYPE CODE 2.1

APPENDIX -- DETAILED SOURCE LISTING

05/21/1985

| SOURCE TYPE/SIZE | | SEWAGE SLUDGE INCINERATION | |
|---|---------------------|---|---|
| COMPANY NAME/SITE LOCATION | | CITY OF L.A., HYPERION, BUREAU OF ENGINEERING CITY HALL | |
| LOS ANGELES, CA | | | |
| DETERMINATION IS BACT FOR A MODIFIED SOURCE. | | DATE OF PERMIT ISSUANCE-- 09/30/82 | |
| PERMIT NO. (REGION FILE NO.) NSP-4-4-9 LA-82-02 | | ESTIMATED DATE OF START-UP-- | |
| DETERMINATION MADE BY EPA REGION IX (AGENCY) | | RICK SUGAREK (AGENCY CONTACT PERSON) | |
| | | (415)-974-8224 (PHONE) | |
| PROCESSES SUBJECT TO THIS PERMIT | THROUGHPUT CAPACITY | POLLUTANT EMITTED | EMISSION LIMITS CONTROL EQUIPMENT OR PROCESS MODIFICATION ... & BASIS PCT EFF |
| GAS TURBINE, 4, DIGESTER GAS FI* | 6.00 MM EA | SO2 | 20.0000 PPM DRY BASIS WET SCRUBBER |
| THERMAL PROCESSING WASTE HEAT R* | | SO2 | 20.0000 PPM DRY BASIS 9.2000 LB/H 2 STAGE WET SCRUBBER/VENTURI SCRUB COUNTER CURRENT TRAY TOWER |
| | | HG | 0.2890 LB/H 2 STAGE WET SCRUBBER |
| | | BE | 0.0000 LB/H FABRIC FILTER/2 STAGE WET SCRUBBER |

(* INDICATES DATUM WAS TRUNCATED FOR THIS TABLE.

REVIEW STATUS: INITIAL REVIEW POST STARTUP

PAGE G- 185

ID NUMBER CA-0033

SOURCE TYPE CODE 2.2