

MEMORANDUM

TO: Scott Sheplak, P. E. *WMS*  
THRU: Jonathan Holtom, P.E.  
FROM: Wendy Alexander  
DATE: February 28, 2000

Re: Intent package for DRAFT Permit Revision No.: 0850001-007-AV

Florida Power and Light Company  
Martin Plant

**Permit Clock:** Title V Air Operation Permit Revision  
**Day 90:** December 28, 1999 (extended to March 1, 2000 by applicant waiver)

This permit revision is for the initial Title V Air Operation Permit for the Florida Power and Light Company's Martin Plant. This facility is regulated under the Acid Rain Program.

This facility was issued an initial Final Title V Air Operation Permit (Permit No. 0850001-004-AV) on June 29, 1998. The Department issued PSD permit modification PSD-FL-146G (also Air Construction (AC) Permit No. 0850001-005-AC) on July 20, 1999 to allow installation of inlet foggers on the four 385 MW General Electric PG7221 combined cycle combustion turbine-electrical generators (Emissions units 003 through 006). An administrative permit correction (Project No. 0850001-006-AV) was issued on October 25, 1999 to add "evaporation of boiler chemical cleaning waste" to Appendix I-1, List of Insignificant Emissions Units and Activities. This Title V Permit Revision incorporates the new inlet fogger conditions from PSD-FL-146G into the Title V Air Operation Permit and results in no increase of emissions.

This facility consists of two oil and natural gas fired conventional steam electric generating stations, and two oil and natural gas fired combined cycle units. In addition, the facility includes one auxiliary boiler, and two diesel generators (one unregulated).

The Title V Permit Revision application was received complete September 29, 1999. Compliance has been demonstrated with the requirements of the air construction permit.

I recommend that this Intent to Issue be sent out as attached.



Jeb Bush  
Governor

# Department of Environmental Protection

Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

David B. Struhs  
Secretary


## P.E. Certification Statement

**Permittee:**  
Florida Power & Light Company  
Martin Power Plant

**DRAFT Permit Revision No.:** 0850001-007-AV  
**Facility ID No.:** 0850001

**Project type:** Title V Air Operation Permit Revision

*I HEREBY CERTIFY that the engineering features described in the above referenced application and subject to the proposed permit conditions provide reasonable assurance of compliance with applicable provisions of Chapter 403, Florida Statutes, and Florida Administrative Code Chapters 62-4 and 62-204 through 62-297. However, I have not evaluated and I do not certify aspects of the proposal outside of my area of expertise (including but not limited to the electrical, mechanical, structural, hydrological, and geological features).*

  
Scott M. Sheplak 02/28/00  
Scott M. Sheplak, P.E. date  
Registration Number: 0048866

Permitting Authority:  
Department of Environmental Protection  
Bureau of Air Regulation  
111 South Magnolia Drive, Suite 4  
Tallahassee, Florida 32301  
Telephone: 850/921-9532  
Fax: 850/922-6979

# STATEMENT OF BASIS

Title V DRAFT permit revision No.: 0850001-007-AV  
Florida Power and Light Company  
Martin Plant  
Martin County

This facility was issued an initial Final Title V Air Operation Permit (Permit No. 0850001-004-AV) on June 29, 1998. The Department issued PSD permit modification PSD-FL-146G (also Air Construction (AC) Permit No. 0850001-005-AC) on July 20, 1999 to allow installation of inlet foggers on the four 385 MW General Electric PG7221 combined cycle combustion turbine-electrical generators (Emissions units 003 through 006). An administrative permit correction (Project No. 0850001-006-AV) was issued on October 25, 1999 to add "evaporation of boiler chemical cleaning waste" to Appendix I-1, List of Insignificant Emissions Units and Activities.

The permittee sent two letters on July 29, 1998 with three requested changes to the Initial Title V Air Operation Permit. The three requested changes are given below:

1. Specific Condition **B.23**. We request Method 20 be replaced with Method 7E as the test method. The cited method creates inaccuracies in the testing due to the span levels required.
2. Specific Condition **B.27**. Please add the following as the first sentence in this condition "It is not necessary to plan the firing of a fuel solely to complete the initial compliance test, instead, the initial test may be postponed until such time as the untested fuel is ready for service".
3. Specific Condition **B.23**. This condition states the NO<sub>x</sub> emissions shall be determined at each of the load conditions specified in 40 CFR 60.335(c)(2). This regulation requires testing at four different loads. Several years ago we negotiated with your Department that testing at only one load would be required. Therefore we request the permit language be revised to include this change.

The Department sent a response letter on September 29, 1998 which granted the second request and stated the third request was being evaluated. In this permit revision, the "new" first sentence from the second request is being added to Specific Condition **B.27**, the third request is being granted, and new language related to the third request is being added to Specific Condition **B.23**. The first request is being pursued through an Alternate Sampling Procedure.

This Title V Permit Revision also incorporates the new inlet fogger conditions from PSD-FL-146G into the Title V Air Operation Permit. This revision is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, 62-213, and 62-214. The above named permittee is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans, and other documents, attached hereto or on file with the permitting authority, in accordance with the terms and conditions of this permit revision.

This facility consists of two oil and natural gas fired conventional steam electric generating stations, and two oil and natural gas fired combined cycle units. In addition, the facility includes one auxiliary boiler, and two diesel generators (one unregulated).

Proposed revisions to the Initial Final Title V Permit No. 0850001-004-AV for the Florida Power and Light Company Martin Plant are described below.



# Department of Environmental Protection

Jeb Bush  
Governor

Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

David B. Struhs  
Secretary

February 28, 2000

John M. Lindsay  
Plant Manager  
Florida Power and Light Company Martin Plant  
P.O. Box 176  
Indiantown, Florida 34956-0176

Re: DRAFT Title V Operation Permit Revision No.: 0850001-007-AV  
Martin Plant

Dear Mr. Lindsay:

One copy of the DRAFT Title V Air Operation Permit Revision for the Florida Power and Light Company Martin Plant located 7 miles North of Indiantown on State Road 710, Indiantown, Martin County, is enclosed. The permitting authority's "INTENT TO ISSUE TITLE V AIR OPERATION PERMIT REVISION" and the "PUBLIC NOTICE OF INTENT TO ISSUE TITLE V AIR OPERATION PERMIT REVISION" are also included. This permit revision incorporates conditions from PSD-FL-146(G) permit modification (also Air Construction Permit No. 0850001-005-AC) and was initiated by submission of a Title V Air Operation Permit Application for Revision to DEP on September 29, 1999 by the Florida Power and Light Company.

An electronic version of the DRAFT Title V Air Operation Permit Revision has been posted on the Division of Air Resources Management's world wide web site for the United States Environmental Protection Agency (USEPA) Region 4 office's review. The web site address is <http://www.dep.state.fl.us/air>.

The "PUBLIC NOTICE OF INTENT TO ISSUE TITLE V AIR OPERATION PERMIT REVISION" must be published as soon as possible upon receipt of this letter. Proof of publication, i.e., newspaper affidavit, must be provided to the permitting authority's office within 7 (seven) days of publication. Failure to publish the notice and provide proof of publication within the allotted time may result in the denial of the permit revision.

Please submit any written comments you wish to have considered concerning the permitting authority's proposed action to Scott M. Sheplak, P.E., at the above letterhead address. If you have any other questions, please contact Wendy Alexander, at 850/921-9527.

Sincerely,

C. H. Fancy, P.E.  
Chief  
Bureau of Air Regulation

CHF/wa

Enclosures

"More Protection, Less Process"

Printed on recycled paper.

In the Matter of an  
Application for Permit Revision by:

Florida Power and Light Company  
P.O. Box 176  
Indiantown, Florida 34956

DRAFT Title V Permit Revision No.: 0850001-007-AV  
Martin Plant  
Martin County

**INTENT TO ISSUE TITLE V AIR OPERATION PERMIT REVISION**

The Department of Environmental Protection (permitting authority) gives notice of its intent to issue a Title V air operation permit revision (copy of DRAFT Title V Operation Permit Revision attached) for the Title V source detailed in the application specified above, for the reasons stated below.

The applicant, Florida Power and Light Company, applied on September 29, 1999, to the permitting authority for a Title V air operation permit revision for the Martin Plant located 7 miles North of Indiantown on State Road 710, Indiantown, Martin County.

The requested permit revision allows for an alternate method of operation resulting in no increase of emissions. Based on the application, one specific condition is being revised and one specific condition is being added in Subsection B (Emissions Units -003 to -006, Combustion Turbines with HRSGs) of Initial Final Title V Permit No. 0850001-004-AV. These conditions incorporate requirements from PSD permit modification PSD-FL-146(G) (also Air Construction Permit No. 0850001-005-AC) for inlet foggers installed on the four combined cycle combustion turbines.

The permitting authority has permitting jurisdiction under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, 62-213 and 62-214. This source is not exempt from Title V permitting procedures. The permitting authority has determined that a Title V air operation permit revision is required to commence or continue operations at the described facility.

The permitting authority intends to issue this Title V air operation permit revision based on the belief that reasonable assurances have been provided to indicate that operation of the source will not adversely impact air quality, and the source will comply with all appropriate provisions of Chapters 62-4, 62-204, 62-210, 62-212, 62-213, 62-214, 62-256, 62-257, 62-281, 62-296, and 62-297, F.A.C.

Pursuant to Sections 403.815 and 403.087, F.S., and Rules 62-110.106 and 62-210.350(3), F.A.C., you (the applicant) are required to publish at your own expense the enclosed "PUBLIC NOTICE OF INTENT TO ISSUE TITLE V AIR OPERATION PERMIT REVISION." The notice shall be published one time only as soon as possible in the legal advertisement section of a newspaper of general circulation in the area affected. For the purpose of these rules, "publication in a newspaper of general circulation in the area affected" means publication in a newspaper meeting the requirements of Sections 50.011 and 50.031, F.S., in the county where the activity is to take place. Where there is more than one newspaper of general circulation in the county, the newspaper used must be one with significant circulation in the area that may be affected by the permit revision. If you are uncertain that a newspaper meets these requirements, please contact the permitting authority at the address or telephone number listed below. The applicant shall provide proof of publication to the Department's Bureau of Air Regulation, 2600 Blair Stone Road, Mail Station #5505, Tallahassee, Florida 32399-2400 (Telephone: 850/488-0114; Fax: 850/922-6979), within 7 (seven) days of publication. Failure to publish the notice

and provide proof of publication within the allotted time may result in the denial of the permit revision pursuant to Rule 62-110.106, F.A.C.

The permitting authority will issue the PROPOSED Title V Operation Permit Revision, and subsequent FINAL Title V Operation Permit Revision, in accordance with the conditions of the attached DRAFT Title V Operation Permit Revision unless a response received in accordance with the following procedures results in a different decision or significant change of terms or conditions.

The permitting authority will accept written comments concerning the proposed permit revision issuance action for a period of 30 (thirty) days from the date of publication of the "PUBLIC NOTICE OF INTENT TO ISSUE TITLE V AIR OPERATION PERMIT REVISION." Written comments should be provided to the permitting authority office. Any written comments filed shall be made available for public inspection. If written comments received result in a significant change in this DRAFT Title V Operation Permit Revision, the permitting authority shall issue a Revised DRAFT Title V Operation Permit Revision and require, if applicable, another Public Notice.

A person whose substantial interests are affected by the proposed permitting decision may petition for an administrative hearing in accordance with Sections 120.569 and 120.57, F.S. The petition must contain the information set forth below and must be filed (received) in the Office of General Counsel of the Department of Environmental Protection, 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida 32399-3000 (Telephone: 850/488-9730; Fax: 850/487-4938). Petitions filed by the permit revision applicant or any of the parties listed below must be filed within fourteen days of receipt of this notice of intent. Petitions filed by any persons other than those entitled to written notice under Section 120.60(3), F.S., must be filed within fourteen days of publication of the public notice or within fourteen days of receipt of this notice of intent, whichever occurs first. Under Section 120.60(3), F.S., however, any person who asked the permitting authority for notice of agency action may file a petition within fourteen days of receipt of that notice, regardless of the date of publication. A petitioner shall mail a copy of the petition to the applicant at the address indicated above, at the time of filing. The failure of any person to file a petition within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under Sections 120.569 and 120.57, F.S., or to intervene in this proceeding and participate as a party to it. Any subsequent intervention will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205, F.A.C.

A petition that disputes the material facts on which the permitting authority's action is based must contain the following information:

(a) The name and address of each agency affected and each agency's file or identification number, if known;

(b) The name, address, and telephone number of the petitioner; the name, address and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how the petitioner's substantial interests will be affected by the agency determination;

(c) A statement of how and when each petitioner received notice of the agency action or proposed action;

(d) A statement of all disputed issues of material fact. If there are none, the petition must so indicate;

(e) A concise statement of the ultimate facts alleged, as well as the rules and statutes which entitle the petitioner to relief;

(f) A statement of the specific rules or statutes the petitioner contends require reversal or modification of the agency's proposed action; and,

(g) A statement of the relief sought by the petitioner, stating precisely the action petitioner wishes the agency to take with respect to the agency's proposed action.

A petition that does not dispute the material facts upon which the permitting authority's action is based shall state that no such facts are in dispute and otherwise shall contain the same information as set forth above, as required by Rule 28-106.301, F.A.C.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the permitting authority's final action may be different from the position taken by it in this notice of intent. Persons whose substantial interests will be affected by any such final decision of the permitting authority on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

Mediation will not be available in this proceeding.

In addition to the above, a person subject to regulation has a right to apply to the Department of Environmental Protection for a variance from or waiver of the requirements of particular rules, on certain conditions, under Section 120.542, F.S. The relief provided by this state statute applies only to state rules, not statutes, and not to any federal regulatory requirements. Applying for a variance or waiver does not substitute or extend the time for filing a petition for an administrative hearing or exercising any other right that a person may have in relation to the action proposed in this notice of intent.

The application for a variance or waiver is made by filing a petition with the Office of General Counsel of the Department of Environmental Protection, 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida 32399-3000. The petition must specify the following information:

- (a) The name, address, and telephone number of the petitioner;
- (b) The name, address, and telephone number of the attorney or qualified representative of the petitioner, if any;
- (c) Each rule or portion of a rule from which a variance or waiver is requested;
- (d) The citation to the statute underlying (implemented by) the rule identified in (c) above;
- (e) The type of action requested;
- (f) The specific facts that would justify a variance or waiver for the petitioner;
- (g) The reason why the variance or waiver would serve the purposes of the underlying statute (implemented by the rule); and,

(h) A statement whether the variance or waiver is permanent or temporary and, if temporary, a statement of the dates showing the duration of the variance or waiver requested.

The Department will grant a variance or waiver when the petition demonstrates both that the application of the rule would create a substantial hardship or violate principles of fairness, as each of those terms is defined in Section 120.542(2), F.S., and that the purpose of the underlying statute will be or has been achieved by other means by the petitioner.

Persons subject to regulation pursuant to any federally delegated or approved air program should be aware that Florida is specifically not authorized to issue variances or waivers from any requirements of any such federally delegated or approved program. The requirements of the program remain fully enforceable by the Administrator of the United States Environmental Protection Agency and by any person under the Clean Air Act unless and until the Administrator separately approves any variance or waiver in accordance with the procedures of the federal program.

**CERTIFICATE OF SERVICE**

The undersigned duly designated deputy agency clerk hereby certifies that this INTENT TO ISSUE TITLE V AIR OPERATION PERMIT REVISION (including the PUBLIC NOTICE and the DRAFT Title V operation permit revision) and all copies were sent by certified mail before the close of business on 3/1/00 to the person(s) listed:

John M. Lindsay, Florida Power and Light Company

In addition, the undersigned duly designated deputy agency clerk hereby certifies that copies of this INTENT TO ISSUE TITLE V AIR OPERATION PERMIT REVISION (including the PUBLIC NOTICE and Statement of Basis) were sent by U.S. mail on the same date to the person(s) listed or as otherwise noted:

Richard G. Piper, Florida Power and Light Company  
Kennard F. Kosky, P.E., Golder Associates, Inc.

In addition, the undersigned duly designated deputy agency clerk hereby certifies that copies of this INTENT TO ISSUE TITLE V AIR OPERATION PERMIT REVISION (including the DRAFT Title V operation permit revision package) were sent by INTERNET E-mail on the same date to the person(s) listed:

Isidore Goldman, P.E., DEP, Southeast District Office  
Hamilton S. Oven, Jr., P.E., DEP, Siting Coordination Office  
Gregg Worley, U.S. EPA, Region 4  
Elizabeth Bartlett, U.S. EPA, Region 4

Clerk Stamp

**FILING AND ACKNOWLEDGMENT FILED**, on this date, pursuant to Section 120.52(7), Florida Statutes, with the designated agency Clerk, receipt of which is hereby acknowledged.

*Barbara J. Powell* 3/1/00  
(Clerk) (Date)

3/1/00 cc: *Wendy Alexander*  
*Reading File*



Is your RETURN ADDRESS completed on the reverse side?

**SENDER:**

- Complete items 1 and/or 2 for additional services.
- Complete items 3, 4a, and 4b.
- Print your name and address on the reverse of this form so that we can return this card to you.
- Attach this form to the front of the mailpiece, or on the back if space does not permit.
- Write "Return Receipt Requested" on the mailpiece below the article number.
- The Return Receipt will show to whom the article was delivered and the date delivered.

I also wish to receive the following services (for an extra fee):

1.  Addressee's Address

2.  Restricted Delivery

Consult postmaster for fee.

3. Article Addressed to:

Mr. John M. Lindsay  
 Plant Manager  
 Florida Power and Light Company  
 Martin Plant  
 P.O. Box 176  
 Indiantown, Florida 34956-0176  
 MICHAEL ROKIC

4a. Article Number  
 Z 094 212 821

4b. Service Type

Registered  Certified

Express Mail  Insured

Return Receipt for Merchandise  COD

7. Date of Delivery  
 3-3-00

5. Received By: (Print Name)  
 Michael Rode

8. Addressee's Address (Only if requested and fee is paid)

6. Signature: (Addressee or Agent)  
 X

Thank you for using Return Receipt Service.

PS Form 3800, April 1995 Domestic Return Receipt

Z 094 212 821

US Postal Service  
**Receipt for Certified Mail**  
 No Insurance Coverage Provided.  
 Do not use for International Mail (See reverse)


|   |           |
|---|-----------|
| Sent to<br>Mr. John M. Lindsay  |           |
| Street & Number<br>P.O. Box 176   |           |
| Post Office, State, & ZIP Code<br>Indiantown, FL 34956-0176               |           |
| Postage   | \$        |
| Certified Fee   |           |
| Special Delivery Fee  |           |
| Restricted Delivery Fee   |           |
| Return Receipt Showing to Whom & Date Delivered                           |           |
| Return Receipt Showing to Whom, Date, & Addressee's Address               |           |
| <b>TOTAL Postage &amp; Fees</b>   | <b>\$</b> |
| Postmark or Date  | 3/1/00    |
| DRAFT Title V Permit Revision<br>No. :0850001-007-AV<br>FP&L-Martin Plant |           |

PS Form 3800, April 1995

Finally, pursuant to 42 United States Code (U.S.C.) Section 7661d(b)(2), any person may petition the Administrator of the EPA within 60 (sixty) days of the expiration of the Administrator's 45 (forty-five) day review period as established at 42 U.S.C. Section 7661d(b)(1), to object to issuance of any permit revision. Any petition shall be based only on objections to the permit revision that were raised with reasonable specificity during the 30 (thirty) day public comment period provided in this notice, unless the petitioner demonstrates to the Administrator of the EPA that it was impracticable to raise such objections within the comment period or unless the grounds for such objection arose after the comment period. Filing of a petition with the Administrator of the EPA does not stay the effective date of any permit properly issued pursuant to the provisions of Chapter 62-213, F.A.C. Petitions filed with the Administrator of EPA must meet the requirements of 42 U.S.C. Section 7661d(b)(2) and must be filed with the Administrator of the EPA at: U.S. EPA, 401 M Street, S.W., Washington, D.C. 20460.

Executed in Tallahassee, Florida.

**STATE OF FLORIDA DEPARTMENT  
OF ENVIRONMENTAL PROTECTION**

  
for C. H. Fancy, P.E.  
Chief  
Bureau of Air Regulation

**PUBLIC NOTICE OF INTENT TO ISSUE TITLE V AIR OPERATION PERMIT REVISION**

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION

DRAFT Title V Operation Permit Revision No.: 0850001-007-AV  
Martin Plant  
Martin County

The Department of Environmental Protection (permitting authority) gives notice of its intent to issue a Title V air operation permit revision to Florida Power and Light Company for the Martin Plant located 7 miles North of Indiantown on State Road 710, Indiantown, Martin County. The applicant's name and address are: Florida Power and Light Company, Environmental Services Department, P.O. Box 14000, Juno Beach, Florida 33408.

The applicant applied on September 29, 1999, to the permitting authority for a Title V air operation permit revision. The requested permit revision allows for an alternate method of operation resulting in no increase of emissions. Based on the application, one specific condition is being revised and one specific condition is being added in Subsection B (Emissions Units -003 to -006, Combustion Turbines with HRSGs) of Initial Final Title V Permit No. 0850001-004-AV. These conditions incorporate requirements from PSD permit modification PSD-FL-146(G) (also Air Construction Permit No. 0850001-005-AC) for inlet foggers installed on the four combined cycle combustion turbines.

The permitting authority will issue the PROPOSED Title V Operation Permit Revision, and subsequent FINAL Title V Operation Permit Revision, in accordance with the conditions of the DRAFT Title V Operation Permit Revision unless a response received in accordance with the following procedures results in a different decision or significant change of terms or conditions.

The permitting authority will accept written comments concerning the proposed DRAFT Title V Operation Permit Revision issuance action for a period of 30 (thirty) days from the date of publication of this Notice. Written comments should be provided to the Department's Bureau of Air Regulation, 2600 Blair Stone Road, Mail Station #5505, Tallahassee, Florida 32399-2400. Any written comments filed shall be made available for public inspection. If written comments received result in a significant change in this DRAFT Title V Operation Permit Revision, the permitting authority shall issue a Revised DRAFT Title V Operation Permit Revision and require, if applicable, another Public Notice.

A person whose substantial interests are affected by the proposed permitting decision may petition for an administrative hearing in accordance with Sections 120.569 and 120.57 of the Florida Statutes (F.S.). The petition must contain the information set forth below and must be filed (received) in the Office of General Counsel of the Department of Environmental Protection, 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida 32399-3000 (Telephone: 850/488-9730; Fax: 850/487-4938). Petitions filed by any persons other than those entitled to written notice under Section 120.60(3), F.S., must be filed within fourteen days of publication of the public notice or within fourteen days of receipt of the notice of intent, whichever occurs first. Under Section 120.60(3), F.S., however, any person who asked the permitting authority for notice of agency action may file a petition within fourteen days of receipt of that notice, regardless of the date of publication. A petitioner shall mail a copy of the petition to the applicant at the address indicated above, at the time of filing. The failure of any person to file a petition within the applicable time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under Sections 120.569 and 120.57, F.S., or to intervene in this proceeding and participate as a party to it. Any subsequent intervention will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205 of the Florida Administrative Code (F.A.C.).

A petition that disputes the material facts on which the permitting authority's action is based must contain the following information:

(a) The name and address of each agency affected and each agency's file or identification number, if known;

(b) The name, address and telephone number of the petitioner; name address and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how petitioner's substantial rights will be affected by the agency determination;

(c) A statement of how and when the petitioner received notice of the agency action or proposed action;

(d) A statement of all disputed issues of material fact. If there are none, the petition must so state;

(e) A concise statement of the ultimate facts alleged, as well as the rules and statutes which entitle petitioner to relief;

(f) A statement of the specific rules or statutes the petitioner contends require reversal or modification of the agency's proposed action; and,

(g) A statement of the relief sought by the petitioner, stating precisely the action petitioner wishes the agency to take with respect to the agency's proposed action.

A petition that does not dispute the material facts upon which the permitting authority's action is based shall state that no such facts are in dispute and otherwise shall contain the same information as set forth above, as required by Rule 28-106.301, F.A.C.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the permitting authority's final action may be different from the position taken by it in this notice of intent. Persons whose substantial interests will be affected by any such final decision of the permitting authority on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

Mediation is not available for this proceeding.

In addition to the above, pursuant to 42 United States Code (U.S.C.) Section 7661d(b)(2), any person may petition the Administrator of the EPA within 60 (sixty) days of the expiration of the Administrator's 45 (forty-five) day review period as established at 42 U.S.C. Section 7661d(b)(1), to object to issuance of any permit revision. Any petition shall be based only on objections to the permit revision that were raised with reasonable specificity during the 30 (thirty) day public comment period provided in this notice, unless the petitioner demonstrates to the Administrator of the EPA that it was impracticable to raise such objections within the comment period or unless the grounds for such objection arose after the comment period. Filing of a petition with the Administrator of the EPA does not stay the effective date of any permit properly issued pursuant to the provisions of Chapter 62-213, F.A.C. Petitions filed with the Administrator of EPA must meet the requirements of 42 U.S.C. Section 7661d(b)(2) and must be filed with the Administrator of the EPA at: U.S. EPA, 401 M Street, S.W., Washington, D.C. 20460.

A complete project file is available for public inspection during normal business hours, 8:00 a.m. to 5:00 p.m., Monday through Friday, except legal holidays, at:

Permitting Authority:

Department of Environmental Protection  
Bureau of Air Regulation  
111 South Magnolia Drive, Suite 4  
Tallahassee, Florida 32301  
Telephone: 850/488-0114  
Fax: 850/922-6979

Affected District Program:

Department of Environmental Protection  
Southeast District Office  
400 North Congress Avenue  
West Palm Beach, Florida 33416-5425  
Telephone: 561/681-6600  
Fax: 561/681-6755

The complete project file includes the DRAFT Title V Operation Permit Revision, the application, and the information submitted by the responsible official, exclusive of confidential records under Section 403.111, F.S. Interested persons may contact Scott M. Sheplak, P.E., at the above address, or call 850/921-9532, for additional information.

**1. The following information will be added to Subsection C., Relevant Documents:**

These documents are on file with the permitting authority:

Initial Title V Air Operation Permit 0850001-004-AV issued June 29, 1998.

Florida Power & Light Permit Change Request received July 31, 1998.

DEP Response to Florida Power & Light Permit Change Request sent September 29, 1998.

Title V Permit Revision Application received September 29, 1999.

Florida Power & Light Administrative Permit Correction Request received October 20, 1999.

Administrative Permit Correction to Initial Title V Air Operation Permit issued October 25, 1999.

**2. Specific Condition B.4. (Subsection B., Emission Units -003 to -006, Combustion Turbines with HRSGs) will be changed as follows:**

**FROM:**

**B.4. Fuels.** Only natural gas or No. 2 fuel oil shall be fired in the CTs.  
[PSD-FL-146, Specific Condition No. 3]

**TO:**

**B.4. Methods of Operation.**

a. **Fuels.** Only natural gas or No. 2 fuel oil shall be fired in the CTs.

b. **Inlet Foggers.** Operation of the foggers on each unit may not exceed the following limits: 181,661 degree F-hours in aggregate firing natural gas fuel if no distillate fuel is fired. If distillate oil is fired in any of the CTs during a calendar year, the allowable degree F-hours for natural gas shall be decreased by 2.77 degree F-hours for every hour operated on distillate oil fuel. No CT may exceed 4,000 degree F-hours per year firing distillate oil fuel.

{Permitting Note: The permittee shall monitor both the hours of operation for the inlet foggers and the degrees of cooling afforded by the inlet foggers. Computation of the degree-hour will be performed as follows:

Degree-hours = # hours inlet fogger operating time X degrees F of cooling

Degrees of Cooling shall be calculated by subtracting the fogged compressor inlet air temperature from the unfogged compressor inlet temperature (upstream of the fogger). The above calculation shall be performed for each hour of fogger operation. Calculation records shall be maintained on the plant site and made available for inspection upon request.}

The temperature drop across the inlet foggers shall be monitored whenever water is injected at the foggers and hourly average temperature drops shall be calculated and recorded along with hours of operation automatically using a computer system. The product of each hour of fogger operation and the average temperature depression for that hour (degree F-hours) shall be summed for each calendar year and shall be submitted to the DEP SE District Office with the Annual Operating Report. The temperature monitoring system shall be calibrated annually (see specific condition B.52.).

[PSD-FL-146, Specific Condition No. 3; PSD-FL-146(G); and, 0850001-005-AC]

**3. Specific Condition B.23. (Subsection B., Emission Units -003 to -006, Combustion Turbines with HRSGs) will be changed as follows:**

**FROM:**

**B.23.** The owner or operator shall determine compliance with the nitrogen oxides and sulfur dioxide standards in 40 CFR 60.332 as follows:

c. U.S. EPA. Method 20 (40 CFR 60, Appendix A) shall be used to determine the nitrogen oxides, sulfur dioxide, and oxygen concentrations. The span values shall be 300 ppm of nitrogen oxide and 21 percent oxygen. The NO<sub>x</sub> emissions shall be determined at each of the load conditions specified in 40 CFR 60.335(c)(2). See specific condition **B.20.** that describes the approved Custom Fuel Monitoring Schedule for Natural Gas for this facility.  
[40 CFR 60.335(c)(3)]

**TO:**

**B.23.** The owner or operator shall determine compliance with the nitrogen oxides and sulfur dioxide standards in 40 CFR 60.332 as follows:

c. U.S. EPA. Method 20 (40 CFR 60, Appendix A) shall be used to determine the nitrogen oxides, sulfur dioxide, and oxygen concentrations. The span values shall be 300 ppm of nitrogen oxide and 21 percent oxygen. The NO<sub>x</sub> emissions shall be determined at each of the load conditions specified in 40 CFR 60.335(c)(2). See specific condition **B.20.** that describes the approved Custom Fuel Monitoring Schedule for Natural Gas for this facility. After initial testing, subsequent annual NO<sub>x</sub> compliance tests for NO<sub>x</sub> limits that are more stringent than 40 CFR 60, Subpart GG, shall not require an ISO correction or testing at four load points; rather, the testing shall be done at capacity (see specific condition **B.3.**). However, when testing shows that NO<sub>x</sub> emissions exceed the standard when operating at capacity, the permittee shall recalibrate the NO<sub>x</sub> emission control system using emission testing at four load points.

[40 CFR 60.335(c)(3); and applicant request letter dated July 29, 1998]

**4. Specific Condition B.27. (Subsection B., Emission Units -003 to -006, Combustion Turbines with HRSGs) will be changed as follows:**

**FROM:**

**B.27.** Initial (I) compliance tests shall be performed on each Combustion Turbine using both fuels. The stack test for each turbine shall be performed within 10% of the maximum heat rate input for the tested operating temperature. Annual (A) compliance tests shall be performed on each Combustion Turbine with the fuel(s) used for more than 400 hours in the preceding 12-month period. Tests shall be conducted using EPA reference methods, or equivalent, in accordance with the July 1, 1996 version of 40 CFR 60 Appendix A. (Note: based on information provided in the Title V Permit Application, initial testing using distillate oil has **not been done.**) See specific condition **B.3** for utilization of ambient temperature versus heat input curves during compliance testing.

[PSD-FL-146, Specific Condition No. 10]

**TO:**

**B.27.** It is not necessary to plan the firing of a fuel solely to complete the initial compliance test, instead, the initial test may be postponed until such time as the untested fuel is ready for service. Initial (I) compliance tests shall be performed on each Combustion Turbine using both fuels. The stack test for each turbine shall be performed within 10% of the maximum heat rate input for the tested operating temperature. Annual (A) compliance tests shall be performed on each Combustion Turbine with the fuel(s) used for more than 400 hours in the preceding 12-month period. Tests shall be conducted using EPA reference methods, or equivalent, in accordance with the July 1, 1996 version of 40 CFR 60 Appendix A. (Note: based on information provided in the Title V Permit Application, initial testing using distillate oil has **not been done.**) See specific condition **B.3** for utilization of ambient temperature versus heat input curves during compliance testing.

[PSD-FL-146, Specific Condition No. 10; and, applicant request letter dated July 28, 1998]

**5. The following "new" specific condition will be added to Subsection B., Emission Units -003 to -006, Combustion Turbines with HRSGs:**

**NEW:**

**B.52. Temperature Monitoring System Calibration.** The temperature monitoring system shall be calibrated annually from 10 percent below to 10 percent above its normal operation range by the procedures recommended by the manufacturer. The temperature monitoring system generally consists of a thermocouple, a temperature indicator, and a recorder. The purpose of the calibration is to provide reasonable assurance that the temperature being recorded by the monitoring system is the actual temperature of the inlet air.

If the manufacturer has provided recommended calibration procedures, those procedures should be followed. If the manufacturer has not provided recommended calibration procedures, the following general calibration procedures should be used:

**THERMOCOUPLE:** The calibration points should bracket the temperature range over which the thermocouple is to be used. The thermocouple should be calibrated against a NIST (National Institute of Standards and Technology) traceable reference thermocouple. The thermocouple may be calibrated using ASTM E 220, Method B. Alternatively, the thermocouple can be replaced each year with a new thermocouple certified by the manufacturer to be accurate to within 0.9% of the temperatures being measured. A certificate of conformance from the manufacturer (certifying that the new thermocouple conforms to published specifications) will satisfy the annual calibration requirements.

**TEMPERATURE INDICATOR:** The instrument, which converts voltage output from the thermocouple to a temperature reading, can be calibrated by applying known voltages (mv), and reading the reported temperatures. The voltage values should correspond to the voltages generated by the thermocouple for temperatures over a range from 10% below to 10% above the inlet air temperatures to be used. The reference voltage supply should be accurate to within 0.1% of the reading.

**RECORDER:** The strip chart recorder or digital data acquisition system should be connected to the temperature indicator during its calibration and can be calibrated at the same time. The recorder should be adjusted to reproduce the readings of the temperature indicator.

The temperature monitoring system calibration error should not exceed 1% of the temperature reading.

[PSD-FL-146(G); 0850001-005-AC; and, Rule 62-297.310(5)(b)]

**6. Appendix TV-1, Title V Conditions, is hereby updated to Appendix TV-3. TV-3 incorporates Rule changes promulgated since the Initial Title V Air Operation Permit was issued. All references to TV-1 are changed to TV-3 as follows:**

a. Placard Page

**FROM:**

**Referenced attachments made a part of this permit revision:**

Appendix I-1, List of Insignificant Emissions Units and/or Activities

Appendix U-1, List of Unregulated Emissions Units and/or Activities

APPENDIX TV-1, TITLE V CONDITIONS (version dated 12/02/97)

**TO:**

**Referenced attachments made a part of this permit revision:**

Appendix I-1, List of Insignificant Emissions Units and/or Activities

Appendix U-1, List of Unregulated Emissions Units and/or Activities

APPENDIX TV-3, TITLE V CONDITIONS (version dated 04/30/99)

b. Section II. Facility-Wide Conditions.

**FROM:**

1. APPENDIX TV-1, TITLE V CONDITIONS, is a part of this permit.

{Permitting note: Appendix TV-1, Title V Conditions is distributed to the permittee only. Other persons requesting copies of these conditions shall be provided one copy when requested or otherwise appropriate.}

**TO:**

1. APPENDIX TV-3, TITLE V CONDITIONS, is a part of this permit.

{Permitting note: APPENDIX TV-3, TITLE V CONDITIONS, is distributed to the permittee only. Other persons requesting copies of these conditions shall be provided a copy when requested or otherwise appropriate.}

**FROM:**

13. Statement of Compliance. The annual statement of compliance pursuant to Rule 62-213.440(3), F.A.C., shall be submitted within 60 (sixty) days after the end of the calendar year.

{See condition No. 52., Appendix TV-1, Title V Conditions.}

[Rule 62-214.420(11), F.A.C.]

**TO:**

13. Statement of Compliance. The annual statement of compliance pursuant to Rule 62-213.440(3), F.A.C., shall be submitted within 60 (sixty) days after the end of the calendar year.

{See condition No. 51., Appendix TV-3, Title V Conditions}

[Rule 62-214.420(11), F.A.C.]

{Permitting Note: The annual statement of compliance must reflect the facility's operation and compliance prior to a "Permit Revision's effective date" and the facility's operation and compliance including and after a "Permit Revision's effective date".}

7. Facility-Wide Condition 3. is hereby changed to the "revised" Risk Management Plan language as follows:

**FROM:**

3. Prevention of Accidental Releases (Section 112(r) of CAA). If required by 40 CFR 68, the permittee shall submit to the implementing agency:

- a. a risk management plan (RMP) when, and if, such requirement becomes applicable, and
- b. certification forms and/or RMPs according to the promulgated rule schedule.

[40 CFR 68]



**TO:**

**3. Prevention of Accidental Releases (Section 112(r) of CAA).**

- a. The permittee shall submit its Risk Management Plan (RMP) to the Chemical Emergency Preparedness and Prevention Office (CEPPO) RMP Reporting Center when, and if, such requirement becomes applicable ; and
- b. The permittee shall submit to the permitting authority Title V certification forms or a compliance schedule in accordance with Rule 62-213.440(2), F.A.C.

[40 CFR 68]

Florida Power & Light Company  
Martin Plant  
**Facility ID No.: 0850001**  
Martin County

Title V Air Operation Permit Revision  
**DRAFT Permit Revision No.: 0850001-007-AV**

Permitting Authority:

State of Florida  
Department of Environmental Protection  
Division of Air Resources Management  
Bureau of Air Regulation  
Title V Section

Mail Station #5505  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400  
Telephone: 850/488-1344  
Fax: 850/922-6979


Compliance Authority:

Department of Environmental Protection  
Southeast District  
400 North Congress Avenue  
West Palm Beach, Florida 33416-5425  
Telephone: 407/681-6600  
Fax: 407/681-6755

Title V Air Operation Permit Revision  
DRAFT Permit Revision No.: 0850001-007-AV

**Table of Contents**

| <u>Section</u>   | <u>Page Number</u> |
|--|--------------------|
| Placard Page.....  | 1                  |
| I. Facility Information.....   | 2                  |
| A. Facility Description.   |                    |
| B. Summary of Emissions Unit ID Nos. and Brief Descriptions.               |                    |
| C. Relevant Documents  |                    |
| II. Facility-wide Conditions.....  | 4                  |
| III. Emissions Units and Conditions  |                    |
| A. Emissions Units -001 and -002, Fossil Fuel Fired Steam Generators.....  | 6                  |
| B. Emissions Units -003 to -006, Combustion Turbines with HRSGs.....       | 22                 |
| C. Emissions Unit -007, Auxiliary Boiler.....                              | 38                 |
| D. Emissions Unit -009, Diesel Generator.....                              | 45                 |
| E. Common Conditions.....  | 46                 |
| IV. Acid Rain Part   |                    |
| A. Acid Rain, Phase II.....  | 53                 |
| Appendix I-1. List of Insignificant Emissions Units and/or Activities..... | 55                 |
| Appendix U-1. List of Unregulated Emissions Units and/or Activities.....   | 57                 |
| Appendix H-1. Permit History/ID Number Changes.....                        | 58                 |



Jeb Bush  
Governor

# Department of Environmental Protection

Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

David B. Struhs  
Secretary

**Permittee:**  
Florida Power & Light Company  
P.O. Box 176  
Indiantown, FL 34956-0176

**DRAFT Permit Revision No.:** 0850001-007-AV  
**Facility ID No.:** 0850001  
**SIC Nos.:** 49, 4911  
**Project:** Title V Air Operation Permit Revision

This permit revision is for the operation of the Martin Plant. This facility is located 7 miles North of Indiantown on State Road 710, Indiantown, Martin County; UTM Coordinates: Zone 17, 543.2 km East and 2993.0 km North; Latitude: 27° 03' 29" North and Longitude: 80° 33' 54" West.

**STATEMENT OF BASIS:** This Title V air operation permit revision is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, 62-213, and 62-214. The above named permittee is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans, and other documents, attached hereto or on file with the permitting authority, in accordance with the terms and conditions of this permit revision.

**Referenced attachments made a part of this permit revision:**

Appendix I-1, List of Insignificant Emissions Units and/or Activities  
Appendix U-1, List of Unregulated Emissions Units and/or Activities  
APPENDIX TV-3, TITLE V CONDITIONS (version dated 04/30/99)  
APPENDIX SS-1, STACK SAMPLING FACILITIES (version dated 10/27/96)  
FIGURE 1- SUMMARY REPORT - GASEOUS AND OPACITY EXCESS EMISSIONS AND  
MONITORING SYSTEMS PERFORMANCE REPORT  
Phase II Acid Rain Application/Compliance Plan received December 6, 1995  
NSPS Custom Fuel Monitoring Schedule dated October 14, 1997  
Order Extending Permit Expiration Date dated 10/30/97

**Title V/IV Permit Effective Date:** January 1, 1999  
**Permit Revision Effective Date:**  
**Renewal Application Due Date:** July 5, 2003  
**Expiration Date:** December 31, 2003

\_\_\_\_\_  
Howard L. Rhodes, Director,  
Division of Air Resources Management

HLR/sms/wa

*"More Protection. Less Process"*

*Printed on recycled paper.*

**Section I. Facility Information.**

**Subsection A. Facility Description.**

This facility consists of two oil and natural gas fired conventional steam electric generating stations, and two oil and natural gas fired combined cycle units. Each conventional steam unit has the maximum capacity of 863.3 megawatts (MW) and consists of a boiler/steam generator which drives a single reheat turbine generator, and is equipped with low NOx dual fuel firing burners to reduce emissions of nitrogen oxides; and, multicyclones, with fly ash reinjection, to control particulate matter emissions.

Each combined cycle unit has the net capability of 430 MW, at 95 degrees F, and consists of two combustion turbines (CTs), each nominally rated at 204 MW, which exhaust through a separate unfired heat recovery steam generator (HRSG). Inlet foggers installed at the compressor inlet to each of the four CTs reduce the turbine inlet air temperature. The temperature reduction improves the heat rate and increases power due to the cooler/denser inlet air. Nitrogen oxide emissions are controlled by using dry low NOx combustors for natural gas with steam injection for fuel oil firing. Steam injection is also used for power augmentation. In addition, the facility includes one auxiliary boiler, and two diesel generators (one unregulated). Also included in this permit are two unregulated emissions units identified as facility-wide particulate matter emissions and facility-wide VOC emissions.

Based on the initial Title V permit application received June 12, 1996 and the Title V permit revision application received September 29, 1999, this facility is a major source of hazardous air pollutants (HAPs).

**Subsection B. Summary of Emissions Unit ID Nos. and Brief Descriptions.**

E.U. ID

| <u>No.</u> | <u>Brief Description</u>                                      |
|------------|---|
| -001       | Fossil Fuel Fired Steam Generator #1                          |
| -002       | Fossil Fuel Fired Steam Generator #2                          |
| -003       | Combustion Turbine with Heat Recovery Steam Generator (CT 3A) |
| -004       | Combustion Turbine with Heat Recovery Steam Generator (CT 3B) |
| -005       | Combustion Turbine with Heat Recovery Steam Generator (CT 4A) |
| -006       | Combustion Turbine with Heat Recovery Steam Generator (CT 4B) |
| -007       | Auxiliary Boiler (for Units -003 to -006)                     |
| -009       | Diesel Generator (0.718 MW, for Units -003 to -006)           |

Unregulated Emissions Units and/or Activities

|      |  |
|------|--|
| -xxx | Diesel Generator (for Units -001 and -002) |
| -xxx | Facility-wide Fugitive Emissions for PM    |
| -xxx | Facility-wide Fugitive Emissions for VOC's |

*Please reference the Permit No., Facility ID No., and appropriate Emissions Units ID Nos. on all correspondence, test report submittals, applications, etc.*

**Subsection C. Relevant Documents.**

The documents listed below are not a part of this permit, however they are specifically related to this permitting action.

These documents are provided to the permittee for information purposes only:

Table 1-1, Summary of Air Pollution Standards and Terms

Table 2-1, Summary of Compliance Requirements

Appendix A-1, Abbreviations, Acronyms, Citations, and Identification Numbers

Appendix H-1, Permit History/ID Number Changes

These documents are on file with the permitting authority:

Initial Title V Permit Application received June 12, 1996.

Additional Information Request dated September 30, 1996.

Additional Information Response received December 23, 1996.

Additional Information Request dated January 13, 1996.

Additional Information Response received January 29, 1997.

Additional Information Request dated February 13, 1997.

Additional Information Response received May 20, 1997.

Comments from Florida Power & Light received by fax on September 17, 1997.

Electronic mail memorandum from Mr. Richard Piper received September 18, 1997.

USEPA Region 4 letter to DEP received March 25, 1998.

DEP letter to USEPA dated March 10, 1998.

Initial Title V Air Operation Permit 0850001-004-AV issued June 29, 1998.

Florida Power & Light Permit Change Request received July 31, 1998.

DEP Response to Florida Power & Light Permit Change Request sent September 29, 1998.

Title V Permit Revision Application received September 29, 1999.

Florida Power & Light Administrative Permit Correction Request received October 20, 1999.

Administrative Permit Correction to Initial Title V Air Operation Permit issued October 25, 1999.

## Section II. Facility-wide Conditions.

### The following conditions apply facility-wide:

1. APPENDIX TV-3, TITLE V CONDITIONS, is a part of this permit.  
{Permitting note: Appendix TV-3, Title V Conditions is distributed to the permittee only. Other persons requesting copies of these conditions shall be provided one copy when requested or otherwise appropriate.}
2. **Not federally enforceable.** General Pollutant Emission Limiting Standards. Objectionable Odor Prohibited. The permittee shall not cause, suffer, allow, or permit the discharge of air pollutants which cause or contribute to an objectionable odor.  
[Rule 62-296.320(2), F.A.C.]
3. Prevention of Accidental Releases (Section 112(r) of CAA).
  - a. The permittee shall submit its Risk Management Plan (RMP) to the Chemical Emergency Preparedness and Prevention Office (CEPPO) RMP Reporting Center when, and if, such requirement becomes applicable ; and
  - b. The permittee shall submit to the permitting authority Title V certification forms or a compliance schedule in accordance with Rule 62-213.440(2), F.A.C.  
[40 CFR 68]
4. Insignificant Emissions Units and/or Activities. Appendix I-1, List of Insignificant Emissions Units and/or Activities, is a part of this permit.  
[Rules 62-213.440(1), 62-213.430(6), and 62-4.040(1)(b), F.A.C.]
5. Unregulated Emissions Units and/or Activities. Appendix U-1, List of Unregulated Emissions Units and/or Activities, is a part of this permit.  
[Rule 62-213.440(1), F.A.C.]
6. General Particulate Emission Limiting Standards. General Visible Emissions Standard. Except for emissions units that are subject to a particulate matter or opacity limit set forth or established by rule and reflected by conditions of this permit, no person shall cause, let, permit, suffer or allow to be discharged into the atmosphere the emissions of air pollutants from any activity, the density of which is equal to or greater than that designated as Number 1 on the Ringelmann Chart (20 percent opacity). EPA Method 9 is the method of compliance pursuant to Chapter 62-297, F.A.C.  
[Rules 62-296.320(4)(b)1. & 4., F.A.C.]
7. **Not federally enforceable.** Reasonable precautions to prevent emissions of unconfined particulate matter at this facility include the following:
  - a. In order to perform sandblasting on fixed plant equipment, sandblasting enclosures are constructed and operated as necessary. Hoods, fans, and filters are used to contain and capture the sand.
  - b. Maintenance of paved areas is performed as needed.
  - c. Mowing of grass and care of vegetation are done on a regular basis.
  - d. Access to plant property by unnecessary vehicles is controlled and limited.
  - e. Bagged chemical products are stored in concrete block buildings until they are used. Spills of powdered chemical products are cleaned up as soon as practical.  
[Rule 62-296.320(4)(c)2., F.A.C.; Proposed by applicant in the initial Title V permit application received June 12, 1996.]

8. All fugitive dust generated at this site shall be adequately controlled. This includes, but is not limited to, roadway dust.

[Rule 62-296.320(4)(c)2, F.A.C.; AC43-4037; AC43-4038]

9. When appropriate, any recording, monitoring, or reporting requirements that are time-specific shall be in accordance with the effective date of the permit, which defines day one.

[Rule 62-213.440, F.A.C.]

10. The permittee shall submit all compliance related notifications and reports required of this permit to the Department's Southeast District office:

Department of Environmental Protection  
Southeast District  
400 North Congress Avenue  
West Palm Beach, Florida 33416-5425  
Telephone: 407/681-6600  
Fax: 407/681-6755

11. Please be advised that the Department does not condone nor authorize the permittee to bypass waste materials from either air or wastewater facilities at any time that would result in a violation of the rules and regulations of the Department. In case of breakdown or lack of proper functioning of the facility causing or likely to cause discharge of improperly treated sewage or air emissions, it shall be the duty of the owner of the facility to promptly notify the Department. In addition to notifying this Department, the permittee shall notify the local County Health Officer. The owner of the impaired facility causing the violation shall be responsible for any and all damages which may result. If violations of State standards occur, enforcement actions may be initiated.

[AC43-4037; AC43-4038]

12. Any reports, data, notifications, certifications, and requests required to be sent to the United States Environmental Protection Agency, Region 4, should be sent to:

United States Environmental Protection Agency  
Region 4  
Air, Pesticides & Toxics Management Division  
Operating Permits Section  
61 Forsyth Street  
Atlanta, Georgia 30303  
Telephone: 404/562-9099  
Fax: 404/562-9095

13. Statement of Compliance. The annual statement of compliance pursuant to Rule 62-213.440(3), F.A.C., shall be submitted within 60 (sixty) days after the end of the calendar year.

{See condition No. 51., Appendix TV-3, Title V Conditions.}

[Rule 62-214.420(11), F.A.C.]

{Permitting Note: The annual statement of compliance must reflect the facility's operation and compliance prior to a "Permit Revision's effective date" and the facility's operation and compliance including and after a "Permit Revision's effective date".}



### Section III. Emissions Units and Conditions.

#### Subsection A. This section addresses the following emissions units.

##### E.U. ID

| <u>No.</u> | <u>Brief Description</u>             |
|------------|--------------------------------------|
| -001       | Fossil Fuel Fired Steam Generator #1 |
| -002       | Fossil Fuel Fired Steam Generator #2 |

Both emissions units are identical in configuration and each one is an 863.3 MW maximum capacity fossil fuel fired steam generator unit, equipped with low NOx dual fuel firing burners to reduce emissions of nitrogen oxides; and, multicyclones, with fly ash reinjection, to control particulate matter emissions. In addition, the units have a continuous emission monitoring system for measuring opacity, NOx, and sulfur dioxide. Unit #1 commenced commercial operation in December, 1980. Unit #2 commenced commercial operation in June, 1981.

{Permitting note: The emissions units are regulated under Acid Rain, Phase II and NSPS - 40 CFR 60, Subpart D, Standards of Performance for Fossil-Fuel-Fired Steam Generators; adopted and incorporated by reference in Rule 62-204.800(7)(b)1., F.A.C.}

#### The following conditions apply to the emissions units listed above:

##### General

**A.1. Definitions.** For the purposes of Rule 62-204.800(7), F.A.C., the definitions contained in the various provisions of 40 CFR 60, shall apply except that the term "Administrator" when used in 40 CFR 60, shall mean the Secretary or the Secretary's designee.

[40 CFR 60.2; Rule 62-204.800(7)(a), F.A.C.]

##### Essential Potential to Emit (PTE) Parameters

**A.2. Permitted Capacity.** Each boiler's maximum heat input is 8,650 MMBtu/hr on oil and 9,040 MMBtu/hr on natural gas. When a blend of fuel oil and natural gas is burned, the heat input is prorated based on the percent heat input of each fuel.

[Rules 62-4.160(2) and 62-210.200(PTE), F.A.C.; AC43-4037; AC43-4038]

{Permitting note: The heat input limitations have been placed in each permit to identify the capacity of each unit for the purposes of confirming that emissions testing is conducted within 90 to 100 percent of the unit's rated capacity (or to limit future operation to 110 percent of the test load), to establish appropriate emission limits and to aid in determining future rule applicability.}

**A.3. Methods of Operation. Fuels.** The only fuels allowed to be burned are low sulfur fuel oil containing a maximum of 0.7% sulfur content, by weight; natural gas; or, a mixture of low sulfur fuel oil containing a maximum of 1.0% sulfur content, by weight, and natural gas in a ratio that shall not exceed the sulfur dioxide emission limiting standard of 0.80 pounds per million Btu heat input.

[Rule 62-213.410, F.A.C.; AC43-4037; AC43-4038]

**A.4. Hours of Operation.** The emissions units may operate continuously, i.e., 8760 hours/year.

[Rule 62-210.200(PTE), F.A.C.]

**Emission Limitations and Standards**

{Permitting note: Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

**A.5. Particulate Matter.** No owner or operator shall cause to be discharged into the atmosphere from each of these emissions units any gases which:

(1) Contain particulate matter in excess of 43 nanograms per joule heat input (0.10 lb per million Btu) derived from fossil fuel.

(2) In addition, emissions shall not exceed 865 pounds per hour when firing 100 percent oil.  
[40 CFR 60.42(a)(1); AO43-170568 and AO43-170567]

**A.6. Particulate Matter - Soot Blowing and Load Change.** Particulate matter emissions shall not exceed an average of 0.3 pound per million Btu heat input during the 3-hours in any 24-hour period of excess emissions allowed for boiler cleaning (soot blowing) and load change.

[Rule 62-210.700(3), F.A.C.]

**A.7. Opacity.** The opacity standards set forth in 40 CFR 60 shall apply at all times except during periods of startup, shutdown, malfunction, and as otherwise provided in the applicable standard.

[40 CFR 60.11(c)]

**A.8. Visible Emissions.** No owner or operator shall cause to be discharged into the atmosphere from each of these emissions units any gases which exhibit greater than 20 percent opacity except for one six-minute period per hour of not more than 27 percent opacity.

[40 CFR 60.42(a)(2)]

**A.9. Sulfur Dioxide.** (a) No owner or operator shall cause to be discharged into the atmosphere from each of these emissions units any gases which contain sulfur dioxide in excess of:

(1) 340 nanograms per joule heat input (0.80 lb per million Btu) derived from liquid fossil fuel.

(2) In addition, emissions shall not exceed 6,920 pounds per hour when firing 100 percent oil.

(c) Compliance shall be based on the total heat input from all fossil fuels burned, including gaseous fuels.

[40 CFR 60.43(a)(1) and (c); AO43-170568 and AO43-170567]

**A.10. Nitrogen Oxides.** (a) No owner or operator shall cause to be discharged into the atmosphere from each of these emissions units any gases which contain nitrogen oxides, expressed as NO<sub>2</sub> in excess of:

- (1) 86 nanograms per joule heat input (0.20 lb per million Btu) derived from gaseous fossil fuel. In addition, emissions shall not exceed 1,808 pounds per hour.
- (2) 129 nanograms per joule heat input (0.30 lb per million Btu) derived from liquid fossil fuel. In addition, emissions shall not exceed 2,595 pounds per hour.

(b) When different fossil fuels are burned simultaneously in any combination, the applicable standard (in lb/MMBtu) is determined by proration using the following formula:

$$PS_{NOx} = [x(.20)+y(.30)] / (x + y)$$

where:

PS<sub>NOx</sub> = is the prorated standard for nitrogen oxides when burning different fuels simultaneously, in lb/MMBtu heat input derived from all fossil fuels fired;

x = is the percentage of total heat input derived from gaseous fossil fuel;

y = is the percentage of total heat input derived from liquid fossil fuel.

[40 CFR 60.44(a)(1)and (2); 40 CFR 60.44(b); AO43-170568 and AO43-170567]

**A.11. "On-Specification" Used Oil.** Only "on-specification" used oil generated by the Florida Power and Light Company in the production and distribution of electricity shall be fired in these emissions units. The total combined quantity allowed to be fired at these emissions units shall not exceed 1,500,000 gallons per calendar year. "On-specification" used oil is defined as each used oil delivery that meets the 40 CFR 279 (Standards for the Management of Used Oil) specifications listed below. Used oil that does not meet all of the following specifications is considered "off-specification" used oil and shall not be fired. See specific conditions **A.21.**, **A.42.** and **A.43.**

| CONSTITUENT/PROPERTY* | ALLOWABLE LEVEL       |
|-----------------------|-----------------------|
| Arsenic               | 5 ppm maximum         |
| Cadmium               | 2 ppm maximum         |
| Chromium              | 10 ppm maximum        |
| Lead                  | 100 ppm maximum       |
| Total Halogens        | 1000 ppm maximum      |
| Flashpoint            | 100 degrees F minimum |
| PCBs                  | less than 50 ppm      |

\* As determined by approved methods specified in EPA Publication SW-846 (Test Methods for Evaluating Solid Waste, Physical/Chemical Methods).

[40 CFR 279.11; and AO43-170568, AO43-170567]

**Excess Emissions**

**A.12.** At all times, including periods of startup, shutdown, and malfunction, owners and operators shall, to the extent practicable, maintain and operate any affected facility including associated air pollution control equipment in a manner consistent with good air pollution control practice for minimizing emissions. Determination of whether acceptable operating and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, opacity observations, review of operating and maintenance procedures, and inspection of the source.  
[40 CFR 60.11(d)]

**A.13.** In order to minimize excess emissions during startup/shutdown/malfunction the following general procedures shall be followed:

Excess emissions resulting from startup, shutdown or malfunction of any emissions unit shall be permitted providing (1) best operational practices to minimize emissions are adhered to and (2) the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration.  
[Rules 62-210.700(1) & (2), F.A.C.; AO43-170568, Specific Condition No.9; AO43-170567, Specific Condition No.9]

**A.14.** Excess emission and monitoring system performance reports shall be submitted to the Administrator for every calendar quarter. All quarterly reports shall be postmarked by the 30th day following the end of each calendar quarter. Each excess emission and MSP report shall include the information required in 40 CFR 60.7(c). Periods of excess emissions and monitoring systems (MS) downtime that shall be reported are defined as follows:

(1) Opacity. Excess emissions are defined as any six-minute period during which the average opacity of emissions exceeds 20 percent opacity, except that one six-minute average per hour of up to 27 percent opacity need not be reported.

(2) Sulfur dioxide. Excess emissions for affected facilities are defined as:

(i) Any three-hour period during which the average emissions (arithmetic average of three contiguous one-hour periods) of sulfur dioxide as measured by a continuous monitoring system exceed the applicable standard under 40 CFR 60.43.

(3) Nitrogen oxides. Excess emissions for affected facilities using a continuous monitoring system for measuring nitrogen oxides are defined as any three-hour period during which the average emissions (arithmetic average of three contiguous one-hour periods) exceed the applicable standards under 40 CFR 60.44.

[40 CFR 60.45(g)(1), (2), & (3)]

### Test Methods and Procedures

{Permitting note: Table 2-1, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

**A.15. Opacity.** Compliance with opacity standards in 40 CFR 60 shall be determined by conducting observations in accordance with Reference Method 9 in Appendix A of 40 CFR 60, any alternative method that is approved by the Administrator, or as provided in 40 CFR 60.11(e)(5).

[40 CFR 60.11(b)]

**A.16.** Compliance with standards in 40 CFR 60, other than opacity standards, shall be determined only by performance tests established by 40 CFR 60.8, unless otherwise specified in the applicable standard.

[40 CFR 60.11(a)]

**A.17.** Performance tests shall be conducted under such conditions as the Administrator shall specify to the plant operator based on representative performance of the affected facility. The owner or operator shall make available to the Administrator such records as may be necessary to determine the conditions of the performance tests. Operations during periods of startup, shutdown, and malfunction shall not constitute representative conditions for the purpose of a performance test nor shall emissions in excess of the level of the applicable emission limit during periods of startup, shutdown, and malfunction be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard.

[40 CFR 60.8(c)]

**A.18. (b)** The owner or operator shall determine compliance with the particulate matter, SO<sub>2</sub>, and NO<sub>x</sub> standards in 40 CFR 60.42, 60.43, and 60.44 as follows:

(1) The emission rate (E) of particulate matter, SO<sub>2</sub>, or NO<sub>x</sub> shall be computed for each run using the following equation:

$$E = C F_d (20.9)/(20.9 - \% O_2)$$

E = emission rate of pollutant, ng/J (1b/million Btu).

C = concentration of pollutant, ng/dscm (1b/dscf).

% O<sub>2</sub> = oxygen concentration, percent dry basis.

F<sub>d</sub> = factor as determined from Method 19.

(2) Method 5 shall be used to determine the particulate matter concentration (C) at affected facilities without wet flue-gas-desulfurization (FGD) systems and Method 5B shall be used to determine the particulate matter concentration (C) after FGD systems.

(i) The sampling time and sample volume for each run shall be at least 60 minutes and 0.85 dscm (30 dscf). The probe and filter holder heating systems in the sampling train may be set to provide a gas temperature no greater than 160 ± 14 °C (320 ± 25 °F).

(ii) The emission rate correction factor, integrated or grab sampling and analysis procedure of Method 3B shall be used to determine the O<sub>2</sub> concentration (%O<sub>2</sub>). The O<sub>2</sub> sample shall be obtained simultaneously with, and at the same traverse points as, the particulate sample.

- If the grab sampling procedure is used, the O<sub>2</sub> concentration for the run shall be the arithmetic mean of all the individual O<sub>2</sub> sample concentrations at each traverse point.
- (iii) If the particulate run has more than 12 traverse points, the O<sub>2</sub> traverse points may be reduced to 12 provided that Method 1 is used to locate the 12 O<sub>2</sub> traverse points.
- (3) Method 9 and the procedures in 40 CFR 60.11 shall be used to determine opacity.
- (4) Method 6 shall be used to determine the SO<sub>2</sub> concentration.
- (i) The sampling site shall be the same as that selected for the particulate sample. The sampling location in the duct shall be at the centroid of the cross section or at a point no closer to the walls than 1 m (3.28 ft). The sampling time and sample volume for each sample run shall be at least 20 minutes and 0.020 dscm (0.71 dscf). Two samples shall be taken during a 1-hour period, with each sample taken within a 30-minute interval.
- (ii) The emission rate correction factor, integrated sampling and analysis procedure of Method 3B shall be used to determine the O<sub>2</sub> concentration (%O<sub>2</sub>). The O<sub>2</sub> sample shall be taken simultaneously with, and at the same point as, the SO<sub>2</sub> sample. The SO<sub>2</sub> emission rate shall be computed for each pair of SO<sub>2</sub> and O<sub>2</sub> samples. The SO<sub>2</sub> emission rate (E) for each run shall be the arithmetic mean of the results of the two pairs of samples.
- (5) Method 7 shall be used to determine the NO<sub>x</sub> concentration.
- (i) The sampling site and location shall be the same as for the SO<sub>2</sub> sample. Each run shall consist of four grab samples, with each sample taken at about 15-minute intervals.
- (ii) For each NO<sub>x</sub> sample, the emission rate correction factor, grab sampling and analysis procedure of Method 3B shall be used to determine the O<sub>2</sub> concentration (%O<sub>2</sub>). The sample shall be taken simultaneously with, and at the same point as, the NO<sub>x</sub> sample.
- (iii) The NO<sub>x</sub> emission rate shall be computed for each pair of NO<sub>x</sub> and O<sub>2</sub> samples. The NO<sub>x</sub> emission rate (E) for each run shall be the arithmetic mean of the results of the four pairs of samples.
- (c) When combinations of fossil fuels are fired, the owner or operator (in order to compute the prorated standard as shown in 40 CFR 60.43(b) and 60.44(b)) shall determine the percentage (x or y) of the total heat input derived from each type of fuel as follows:
- (1) The heat input rate of each fuel shall be determined by multiplying the gross calorific value of each fuel fired by the rate of each fuel burned.
- (2) ASTM Methods D 240-76 (liquid fuels), or D 1826-77 (gaseous fuels) (incorporated by reference-see 40 CFR 60.17) shall be used to determine the gross calorific values of the fuels.
- (3) Suitable methods shall be used to determine the rate of each fuel burned during each test period, and a material balance over the steam generating system shall be used to confirm the rate.
- (d) The owner or operator may use the following as alternatives to the reference methods and procedures in 40 CFR 60.46 or in other sections as specified:
- (1) The emission rate (E) of particulate matter, SO<sub>2</sub> and NO<sub>x</sub> may be determined by using the F<sub>c</sub> factor, provided that the following procedure is used:
- (i) The emission rate (E) shall be computed using the following equation:
- $$E = C F_c (100 / \%CO_2)$$
- where:
- E = emission rate of pollutant, ng/J (lb/million Btu).
- C = concentration of pollutant, ng/dscm (lb/dscf).
- %CO<sub>2</sub> = carbon dioxide concentration, percent dry basis.
- F<sub>c</sub> = factor as determined in appropriate sections of Method 19.

(ii) If and only if the average  $F_c$  factor in Method 19 is used to calculate E and either E is from 0.97 to 1.00 of the emission standard or the relative accuracy of a continuous emission monitoring system is from 17 to 20 percent, then three runs of Method 3B shall be used to determine the  $O_2$  and  $CO_2$  concentration according to the procedures in 40 CFR 60.46(b) (2)(ii), (4)(ii), or (5)(ii). Then if  $F_o$  (average of three runs), as calculated from the equation in Method 3B, is more than  $\pm 3$  percent than the average  $F_o$  value, as determined from the average values of  $F_d$  and  $F_c$  in Method 19, i.e.,  $F_{oa} = 0.209 (F_{da} / F_{ca})$ , then the following procedure shall be followed:

(A) When  $F_o$  is less than  $0.97 F_{oa}$ , then E shall be increased by that proportion under  $0.97 F_{oa}$ , e.g., if  $F_o$  is  $0.95 F_{oa}$ , E shall be increased by 2 percent. This recalculated value shall be used to determine compliance with the emission standard.

(B) When  $F_o$  is less than  $0.97 F_{oa}$  and when the average difference ( $\bar{d}$ ) between the continuous monitor minus the reference methods is negative, then E shall be increased by that proportion under  $0.97 F_{oa}$ , e.g., if  $F_o$  is  $0.95 F_{oa}$ , E shall be increased by 2 percent. This recalculated value shall be used to determine compliance with the relative accuracy specification.

(C) When  $F_o$  is greater than  $1.03 F_{oa}$  and when  $\bar{d}$  is positive, then E shall be decreased by that proportion over  $1.03 F_{oa}$ , e.g., if  $F_o$  is  $1.05 F_{oa}$ , E shall be decreased by 2 percent. This recalculated value shall be used to determine compliance with the relative accuracy specification.

(2) For Method 5 or 5B, Method 17 may be used at facilities with or without wet FGD systems if the stack gas temperature at the sampling location does not exceed an average temperature of  $160^\circ C$  ( $320^\circ F$ ). The procedures of sections 2.1 and 2.3 of Method 5B may be used with Method 17 only if it is used after wet FGD systems. Method 17 shall not be used after wet FGD systems if the effluent gas is saturated or laden with water droplets.

(3) Particulate matter and  $SO_2$  may be determined simultaneously with the Method 5 train provided that the following changes are made:

(i) The filter and impinger apparatus in sections 2.1.5 and 2.1.6 of Method 8 is used in place of the condenser (section 2.1.7) of Method 5.

(ii) All applicable procedures in method 8 for the determination of  $SO_2$  (including moisture) are used:

(4) For Method 6, Method 6C may be used. Method 6A may also be used whenever Methods 6 and 3B data are specified to determine the  $SO_2$  emission rate, under the conditions in 40 CFR 60.46(d)(1).

(5) For Method 7, Method 7A, 7C, 7D, or 7E may be used. If Method 7C, 7D, or 7E is used, the sampling time for each run shall be at least 1 hour and the integrated sampling approach shall be used to determine the  $O_2$  concentration ( $\%O_2$ ) for the emission rate correction factor.

(6) For Method 3, Method 3A or 3B may be used.

(7) For Method 3B, Method 3A may be used.

[40 CFR 60.46(b), (c) and (d)]

**A.19. Operating Rate During Testing.** Unless otherwise stated in the applicable emission limiting standard rule, testing of emissions shall be conducted with the emissions unit operation at permitted capacity, which is defined as 90 to 100 percent of the maximum operation rate at the permitted capacity. If it is impracticable to test at permitted capacity, an emissions unit may be tested at less than the minimum permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test load until a new test is conducted. Once the unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity.

[Rules 62-297.310(2) & (2)(b), F.A.C.; AO43-170568, Specific Condition No.1; AO43-170567, Specific Condition No. 1]

**A.20.** All compliance tests shall be performed using reference test methods as given in 40 CFR 60, Appendix A, as adopted by reference in Rule 62-297.400, F.A.C. Any deviations from the test methodology in order to facilitate "representative" testing shall be approved by the Department pursuant to Rule 62-297.620, F.A.C., prior to conducting the tests.

[40 CFR 60, Appendix A; Rule 62-297.400, F.A.C.; Rule 62-297.620, F.A.C.; AO43-170568, Specific Condition No. 3; AO43-170567, Specific Condition No. 3]

**A.21.** Compliance with the "on-specification" used oil requirements will be determined from a sample collected from each batch delivered for firing. See specific conditions **A.11.**, **A.42.** and **A.43.**

[Rules 62-4.070 and 62-213.440; and, 40 CFR 279]

**A.22. Testing While Injecting Additives.** The owner or operator shall conduct emission tests while injecting additives consistent with normal operating practices.

[Rule 62-213.440, F.A.C., applicant agreement with EPA on March 3, 1998]

### **Continuous Monitoring Requirements**

**A.23.** The permittee has installed and shall continue to calibrate, maintain, and operate continuous monitoring systems for measuring the opacity of emissions, sulfur dioxide emissions, nitrogen oxides emissions, and carbon dioxide emissions.

[40 CFR 60.45(a)]

**A.24.** For the purposes of 40 CFR 60.13, all continuous monitoring systems required under applicable subparts shall be subject to the provisions of 40 CFR 60.13 upon promulgation of performance specifications for continuous monitoring systems under Appendix B of 40 CFR 60 and, if the continuous monitoring system is used to demonstrate compliance with emission limits on a continuous basis, Appendix F of 40 CFR 60, unless otherwise specified in an applicable subpart or by the Administrator. Appendix F is applicable December 4, 1987.

[40 CFR 60.13(a)]

**A.25.** If the owner or operator of an affected facility elects to submit continuous opacity monitoring system (COMS) data for compliance with the opacity standard as provided under 40 CFR 60.11(e)(5), he shall conduct a performance evaluation of the COMS as specified in Performance Specification 1, Appendix B, of 40 CFR 60 before the performance test required under 40 CFR 60.8 is conducted. Otherwise, the owner or operator of an affected facility shall conduct a performance evaluation of the COMS or continuous emission monitoring system



(CEMS) during any performance test required under 40 CFR 60.8 or within 30 days thereafter in accordance with the applicable performance specification in Appendix B of 40 CFR 60. The owner or operator of an affected facility shall conduct COMS or CEMS performance evaluations at such other times as may be required by the Administrator under section 114 of the Act.  
[40 CFR 60.13(c)]

**A.26.** The owner or operator of an affected facility subject to an opacity standard may submit, for compliance purposes, continuous opacity monitoring system (COMS) data results produced during any performance test required under 40 CFR 60.8 in lieu of Method 9 observation data. If an owner or operator elects to submit COMS data for compliance with the opacity standard, he shall notify the Administrator of that decision, in writing, at least 30 days before any performance test required under 40 CFR 60.8 is conducted. Once the owner or operator of an affected facility has notified the Administrator to that effect, the COMS data results will be used to determine opacity compliance during subsequent tests required under 40 CFR 60.8 until the owner or operator notifies the Administrator, in writing, to the contrary. For the purpose of determining compliance with the opacity standard during a performance test required under 40 CFR 60.8 using COMS data, the minimum total time of COMS data collection shall be averages of all 6-minute continuous periods within the duration of the mass emission performance test. Results of the COMS opacity determinations shall be submitted along with the results of the performance test required under 60.8. The owner or operator of an affected facility using a COMS for compliance purposes is responsible for demonstrating that the COMS meets the requirements specified in 40 CFR 60.13(c), that the COMS has been properly maintained and operated, and that the resulting data have not been altered in any way. If COMS data results are submitted for compliance with the opacity standard for a period of time during which Method 9 data indicates noncompliance, the Method 9 data will be used to determine opacity compliance.  
[40 CFR 60.11(e)(5)]

**A.27.** (1) Owners and operators of all continuous emission monitoring systems (CEMS) installed in accordance with the provisions of this part shall check the zero (or low-level value between 0 and 20 percent of span value) and span (50 to 100 percent of span value) calibration drifts at least once daily in accordance with a written procedure. The zero and span shall, as a minimum, be adjusted whenever the 24-hour zero drift or 24-hour span drift exceeds two times the limits of the applicable performance specifications in Appendix B. The system must allow the amount of excess zero and span drift measured at the 24-hour interval checks to be recorded and quantified, whenever specified. For continuous monitoring systems measuring opacity of emissions, the optical surfaces exposed to the effluent gases shall be cleaned prior to performing the zero and span drift adjustments except that for systems using automatic zero adjustments. The optical surfaces shall be cleaned when the cumulative automatic zero compensation exceeds 4 percent opacity.

(2) Unless otherwise approved by the Administrator, the following procedures shall be followed for continuous monitoring systems measuring opacity of emissions. Minimum procedures shall include a method for producing a simulated zero opacity condition and an upscale (span) opacity condition using a certified neutral density filter or other related technique to produce a known obscuration of the light beam. Such procedures shall provide a system check of the analyzer internal optical surfaces and all electronic circuitry including the lamp and photo detector assembly.

[40 CFR 60.13(d)(1) and (2)]

**A.28.** Except for system breakdowns, repairs, calibration checks, and zero and span adjustments required under 40 CFR 60.13(d), all continuous monitoring systems (CMS) shall be in continuous operation and shall meet minimum frequency of operation requirements as follows:

(1) All continuous monitoring systems referenced by 40 CFR 60.13(c) for measuring opacity of emissions shall complete a minimum of one cycle of sampling and analyzing for each successive 10-second period and one cycle of data recording for each successive 6-minute period.

(2) All continuous monitoring systems referenced by 40 CFR 60.13(c) for measuring emissions, except opacity, shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period.

[40 CFR 60.13(e)(1) and (2)]

**A.29.** All continuous monitoring systems (CMS) or monitoring devices shall be installed such that representative measurements of emissions or process parameters from the affected facility are obtained. Additional procedures for location of continuous monitoring systems contained in the applicable Performance Specifications of Appendix B of 40 CFR 60 shall be used.

[40 CFR 60.13(f)]

**A.30.** When the effluents from a single affected facility or two or more affected facilities subject to the same emission standards are combined before being released to the atmosphere, the owner or operator may install applicable continuous monitoring systems (CMS) on each effluent or on the combined effluent. When the affected facilities are not subject to the same emission standards, separate continuous monitoring systems shall be installed on each effluent. When the effluent from one affected facility is released to the atmosphere through more than one point, the owner or operator shall install an applicable continuous monitoring system on each separate effluent unless the installation of fewer systems is approved by the Administrator. When more than one continuous monitoring system is used to measure the emissions from one affected facility (e.g., multiple breechings, multiple outlets), the owner or operator shall report the results as required from each continuous monitoring system.

[40 CFR 60.13(g)]

**A.31.** Owners or operators of all continuous monitoring systems for measurement of opacity shall reduce all data to 6-minute averages and for continuous monitoring systems other than opacity to 1-hour averages for time periods as defined in 40 CFR 60.2. Six-minute opacity averages shall be calculated from 36 or more data points equally spaced over each 6-minute period. For continuous monitoring systems other than opacity, 1-hour averages shall be computed from four or more data points equally spaced over each 1-hour period. Data recorded during periods of continuous monitoring system breakdowns, repairs, calibration checks, and zero and span adjustments shall not be included in the data averages computed under this paragraph. An arithmetic or integrated average of all data may be used. The data may be recorded in reduced or non reduced form (e.g., ppm pollutant and percent O<sub>2</sub> or ng/J of pollutant). All excess emissions shall be converted into units of the standard using the applicable conversion procedures specified in subparts. After conversion into units of the standard, the data may be rounded to the same number of significant digits as used in the applicable subparts to specify the emission limit (e.g., rounded to the nearest 1 percent opacity).

[40 CFR 60.13(h)]

A.32. For performance evaluations under 40 CFR 60.13(c) and calibration checks under 40 CFR 60.13(d), the following procedures shall be used:

(1) Methods 6, 7, and 3B, as applicable, shall be used for the performance evaluations of sulfur dioxide and nitrogen oxides continuous monitoring systems. Acceptable alternative methods for Methods 6, 7, and 3B are given in 40 CFR 60.46(d).

(2) Sulfur dioxide or nitric oxide, as applicable, shall be used for preparing calibration gas mixtures under Performance Specification 2 of Appendix B to 40 CFR 60.

(3) For affected facilities burning fossil fuel(s), the span value for a continuous monitoring system measuring the opacity of emissions shall be 80, 90, or 100 percent and for a continuous monitoring system measuring sulfur oxides or nitrogen oxides the span value shall be determined as follows:

[In parts per million]

| Fossil fuel       | Span value for sulfur dioxide | Span value for nitrogen oxides |
|-------------------|-------------------------------|--------------------------------|
| Gas.....          | {1}                           | 500                            |
| Liquid.....       | 1,000                         | 500                            |
| Combinations..... | 1,000y                        | 500(x+y)                       |

{1} Not applicable.

where:

x = the fraction of total heat input derived from gaseous fossil fuel, and

y = the fraction of total heat input derived from liquid fossil fuel.

(4) All span values computed under 40 CFR 60.45(c)(3) for burning combinations of fossil fuels shall be rounded to the nearest 500 ppm.

(5) For a fossil fuel-fired steam generator that simultaneously burns fossil fuel and nonfossil fuel, the span value of all continuous monitoring systems shall be subject to the Administrator's approval.

[40 CFR 60.45(c)]

A.33. For any continuous monitoring system installed under 40 CFR 60.45(a), the following conversion procedures shall be used to convert the continuous monitoring data into units of the applicable standards (ng/J, lb/million Btu):

(1) When a continuous monitoring system for measuring oxygen is selected, the measurement of the pollutant concentration and oxygen concentration shall each be on a consistent basis (wet or dry). Alternative procedures approved by the Administrator shall be used when measurements are on a wet basis. When measurements are on a dry basis, the following conversion procedure shall be used:

$$E = CF[20.9/(20.9 - \text{percent } O_2)]$$

where:

E, C, F, and % O<sub>2</sub> are determined under 40 CFR 60.45(f).

(2) When a continuous monitoring system for measuring carbon dioxide is selected, the measurement of the pollutant concentration and carbon dioxide concentration shall each be on a consistent basis (wet or dry) and the following conversion procedure shall be used:

$$E = CF_c [100/\text{percent CO}_2]$$

where:

E, C,  $F_c$  and %CO<sub>2</sub> are determined under 40 CFR 60.45(f).  
[40 CFR 60.45(e)]

**A.34.** The values used in the equations under 40 CFR 60.45(e) (1) and (2) are derived as follows:

- (1) E = pollutant emissions, ng/J (lb/million Btu).
- (2) C = pollutant concentration, ng/dscm (lb/dscf), determined by multiplying the average concentration (ppm) for each one-hour period by  $4.15 \times 10^4$  M ng/dscm per ppm ( $2.59 \times 10^{-9}$  M lb/dscf per ppm) where M = pollutant molecular weight, g/g-mole (lb/lb-mole). M = 64.07 for sulfur dioxide and 46.01 for nitrogen oxides.
- (3) % O<sub>2</sub>, %CO<sub>2</sub> = oxygen or carbon dioxide volume (expressed as percent), determined with equipment specified under 40 CFR 60.45(a).
- (4) F,  $F_c$  = a factor representing a ratio of the volume of dry flue gases generated to the calorific value of the fuel combusted (F), and a factor representing a ratio of the volume of carbon dioxide generated to the calorific value of the fuel combusted ( $F_c$ ), respectively. Values of F and  $F_c$  are given as follows:

(iii) For liquid fossil fuels including crude, residual, and distillate oils,  $F = 2.476 \times 10^{-7}$  dscm/J (9,220 dscf/million Btu) and  $F_c = 0.384 \times 10^{-7}$  scm CO<sub>2</sub> /J (1,430 scf CO<sub>2</sub> /million Btu).

(iv) For gaseous fossil fuels,  $F = 2.347 \times 10^{-7}$  dscm/J (8,740 dscf/million Btu). For natural gas, propane, and butane fuels,  $F_c = 0.279 \times 10^{-7}$  scm CO<sub>2</sub> /J (1,040 scf CO<sub>2</sub> /million Btu) for

natural gas,  $0.322 \times 10^{-7}$  scm CO<sub>2</sub> /J (1,200 scf CO<sub>2</sub> /million Btu) for propane, and  $0.338 \times 10^{-7}$  scm CO<sub>2</sub> /J (1,260 scf CO<sub>2</sub> /million Btu) for butane.

(5) The owner or operator may use the following equation to determine an F factor (dscm/J or dscf/million Btu) on a dry basis (if it is desired to calculate F on a wet basis, consult the Administrator) or  $F_c$  factor (scm CO<sub>2</sub> /J, or scf CO<sub>2</sub> /million Btu) on either basis in lieu of the F or  $F_c$  factors specified in 40 CFR 60.45(f)(4):

$$F = 10^{-6} \frac{[227.2 (\text{pct. II}) + 95.5 (\text{pct. C}) + 35.6 (\text{pct. S}) + 8.7 (\text{pct. N}) - 28.7 (\text{pct. O})]}{\text{GCV}}$$

$$F_c = \frac{2.0 \times 10^{-5} (\text{pct. C})}{\text{GCV}}$$

(SI units)

$$F = 10^6 \frac{3.64(\%H) + 1.53(\%C) + 0.57(\%S) + 0.14(\%N) - 0.46(\%O)}{\text{GCV}}$$

(English units)

$$F_c = \frac{20.0(\%C)}{\text{GCV}}$$

(SI units)

$$F_c = \frac{321 \times 10^3 (\%C)}{\text{GCV}}$$

(English units)

- (i) H, C, S, N, and O are content by weight of hydrogen, carbon, sulfur, nitrogen, and oxygen (expressed as percent), respectively, as determined on the same basis as GCV by ultimate analysis of the fuel fired, or computed from results using ASTM method D1137-53(75), D1945-64(76), or D1946-77 (gaseous fuels) as applicable. (These three methods are incorporated by reference-see 40 CFR 60.17.)
- (ii) GCV is the gross calorific value (kJ/kg, Btu/lb) of the fuel combusted determined by the ASTM test method D1826-77 for gaseous fuels as applicable. (This method is incorporated by reference-see 40 CFR 60.17.)
- (iii) For affected facilities which fire both fossil fuels and nonfossil fuels, the F or F<sub>c</sub> value shall be subject to the Administrator's approval.
- (6) For affected facilities firing combinations of fossil fuels, the F or F<sub>c</sub> factors determined by paragraphs 40 CFR 60.45(f)(4) or (f)(5) shall be prorated in accordance with the applicable formula as follows:

$$F = \sum_{i=1}^n X_i F_i \quad \text{or} \quad F_c = \sum_{i=1}^n X_i (F_c)_i$$

where:

X<sub>i</sub> = the fraction of total heat input derived from each type of fuel (e.g. natural gas, etc.)

F<sub>i</sub> or (F<sub>c</sub>)<sub>i</sub> = the applicable F or F<sub>c</sub> factor for each fuel type determined in accordance with paragraphs (f)(4) and (f)(5) of this section.

n = the number of fuels being burned in combination.

[40 CFR 60.45(f)]

**A.35.** Operation and maintenance of continuous emissions monitoring (CEM) systems shall be carried out according to the requirements of 40 CFR 60; reports thereof shall be submitted to the Department's Southeast District Office within thirty (30) days following each calendar quarter and will include information required under 40 CFR 60.7(c). The Department reserves the right to modify the format of the reports. For any periods of excess emissions, as defined in 40 CFR 60.45(g), the reports shall specify the cause and corrective actions taken as well as the specific operational conditions existing (i.e., steady-state output, load charging rate; sootblowing, limiting, or air preheated steam cleaning sequences), during the period of excess emissions.  
[AO43-170568, Specific Condition No. 4; AO43-170567, Specific Condition No. 4]

**Recordkeeping and Reporting Requirements**

**A.36.** The owner or operator subject to the provisions of 40 CFR 60 shall furnish the Administrator written notification as follows:

(4) A notification of any physical or operational change to an existing facility which may increase the emission rate of any air pollutant to which a standard applies, unless that change is specifically exempted under an applicable subpart or in 40 CFR 60.14(e). This notice shall be postmarked 60 days or as soon as practicable before the change is commenced and shall include information describing the precise nature of the change, present and proposed emission control systems, productive capacity of the facility before and after the change, and the expected completion date of the change. The Administrator may request additional relevant information subsequent to this notice.

[40 CFR 60.7(a)(4)]

**A.37.** The owner or operator subject to the provisions of 40 CFR 60 shall maintain records of the occurrence and duration of any startup, shutdown, or malfunction in the operation of an affected facility; any malfunction of the air pollution control equipment; or, any periods during which a continuous monitoring system or monitoring device is inoperative.

[40 CFR 60.7(b)]

**A.38.** The owner or operator required to install a continuous monitoring system (CMS) or monitoring device shall submit an excess emissions and monitoring systems performance report (excess emissions are defined in applicable subparts) and/or a summary report form [see 40 CFR 60.7(d)] to the Administrator semiannually, except when: more frequent reporting is specifically required by an applicable subpart; or, the CMS data are to be used directly for compliance determination, in which case quarterly reports shall be submitted; or, the Administrator, on a case-by-case basis, determines that more frequent reporting is necessary to accurately assess the compliance status of the source. All reports shall be postmarked by the 30th day following the end of each calendar half (or quarter, as appropriate). Written reports of excess emissions shall include the following information:

(1) The magnitude of excess emissions computed in accordance with 40 CFR 60.13(h), any conversion factor(s) used, and the date and time of commencement and completion of each time period of excess emissions. The process operating time during the reporting period.

(2) Specific identification of each period of excess emissions that occurs during startups, shutdowns, and malfunctions of the affected facility. The nature and cause of any malfunction (if known), the corrective action taken or preventative measures adopted.

(3) The date and time identifying each period during which the continuous monitoring system was inoperative except for zero and span checks and the nature of the system repairs or adjustments.

(4) When no excess emissions have occurred or the continuous monitoring system(s) have not been inoperative, repaired, or adjusted, such information shall be stated in the report.

[40 CFR 60.7(c)(1), (2), (3), and (4)]

**A.39.** The summary report form shall contain the information and be in the format shown in Figure 1 (attached) unless otherwise specified by the Administrator. One summary report form shall be submitted for each pollutant monitored at each affected facility.

(1) If the total duration of excess emissions for the reporting period is less than 1 percent of the total operating time for the reporting period and CMS downtime for the reporting period is less than 5 percent of the total operating time for the reporting period, only the summary report form

shall be submitted and the excess emission report described in 40 CFR 60.7(c) need not be submitted unless requested by the Administrator.

(2) If the total duration of excess emissions for the reporting period is 1 percent or greater of the total operating time for the reporting period or the total CMS downtime for the reporting period is 5 percent or greater of the total operating time for the reporting period, the summary report form and the excess emission report described in 40 CFR 60.7(c) shall both be submitted.

*{See attached Figure 1: Summary Report-Gaseous and Opacity Excess Emission and Monitoring System Performance}*

[40 CFR 60.7(d)(1) and (2)]

**A.40.** (1) Notwithstanding the frequency of reporting requirements specified in 40 CFR 60.7(c), an owner or operator who is required by an applicable subpart to submit excess emissions and monitoring systems performance reports (and summary reports) on a quarterly (or more frequent) basis may reduce the frequency of reporting for that standard to semiannual if the following conditions are met:

- (i) For 1 full year (e.g., 4 quarterly or 12 monthly reporting periods) the affected facility's excess emissions and monitoring systems reports submitted to comply with a standard under this part continually demonstrate that the facility is in compliance with the applicable standard;
- (ii) The owner or operator continues to comply with all recordkeeping and monitoring requirements specified in 40 CFR 60, Subpart A, and the applicable standard; and
- (iii) The Administrator does not object to a reduced frequency of reporting for the affected facility, as provided in 40 CFR 60.7(e)(2).

(2) The frequency of reporting of excess emissions and monitoring systems performance (and summary) reports may be reduced only after the owner or operator notifies the Administrator in writing of his or her intention to make such a change and the Administrator does not object to the intended change. In deciding whether to approve a reduced frequency of reporting, the Administrator may review information concerning the source's entire previous performance history during the required recordkeeping period prior to the intended change, including performance test results, monitoring data, and evaluations of an owner or operator's conformance with operation and maintenance requirements. Such information may be used by the Administrator to make a judgment about the source's potential for noncompliance in the future. If the Administrator disapproves the owner or operator's request to reduce the frequency of reporting, the Administrator will notify the owner or operator in writing within 45 days after receiving notice of the owner or operator's intention. The notification from the Administrator to the owner or operator will specify the grounds on which the disapproval is based. In the absence of a notice of disapproval within 45 days, approval is automatically granted.

(3) As soon as monitoring data indicate that the affected facility is not in compliance with any emission limitation or operating parameter specified in the applicable standard, the frequency of reporting shall revert to the frequency specified in the applicable standard, and the owner or operator shall submit an excess emissions and monitoring systems performance report (and summary report, if required) at the next appropriate reporting period following the noncomplying event. After demonstrating compliance with the applicable standard for another full year, the owner or operator may again request approval from the Administrator to reduce the frequency of reporting for that standard as provided for in 40 CFR 60.7(e)(1) and (e)(2).

[40 CFR 60.7(e)(1)]

**A.41.** The owner or operator subject to the provisions of 40 CFR 60 shall maintain a file of all measurements, including continuous monitoring system, monitoring device, and performance testing measurements; all continuous monitoring system performance evaluations; all continuous

monitoring system or monitoring device calibration checks; adjustments and maintenance performed on these systems or devices; and, all other information required by 40 CFR 60 recorded in a permanent form suitable for inspection. The file shall be retained for at least 5 (five) years following the date of such measurements, maintenance, reports, and records. [40 CFR 60.7(f); Rule 62-213.440(1)(b)2.b., F.A.C.]

**A.42.** Records shall be kept of each delivery of “on-specification” used oil with a statement of the origin of the used oil and the quantity delivered/stored for firing. In addition, monthly records shall be kept of the quantity of “on-specification” used oil fired in these emissions units. The above records shall be maintained in a form suitable for inspection, retained for a minimum of five years, and be made available upon request. See specific conditions **A.11.**, **A.21.** and **A.43.**

[Rule 62-213.440(1)(b)2.b., F.A.C.; and, 40 CFR 279.61 and 761.20(e)]

**A.43.** The permittee shall include in the “Annual Operating Report for Air Pollutant Emitting Facility” a summary of the “on-specification” used oil analyses for the calendar year and a statement of the total quantity of “on-specification” used oil fired in Fossil Fuel Fired Steam Generators Nos. 1 and 2 during the calendar year. See specific conditions **A.11.**, **A.21.** and **A.42.** [Rule 62-213.440(1)(b)2.b., F.A.C.]

**A.44.** Until such time when the Environmental Protection Agency (EPA) promulgates final rules regarding fuel sampling and test methods, the Department will accept the current fuel sampling and analysis program, provided that daily as fired fuel oil samples are composited and analyzed for sulfur content on a monthly basis to demonstrate compliance with fuel oil sulfur content limits. Quarterly reports containing the results of the monthly fuel oil sampling and analysis shall be submitted to the Department no later than thirty (30) days after the end of each quarter.

The permittee shall be allowed 90 days after promulgation of fuel sampling and analysis methods to implement an EPA approved method of monitoring sulfur dioxide emissions either by fuel sampling and analysis methods or continuous in-stack monitoring or other methods as approved under the provisions of 40 CFR 60.45.

[AO43-170568, Specific Condition No. 5; AO43-170567, Specific Condition No. 5]

**A.45.** COMS for Periodic Monitoring. The owner or operator is required to install continuous opacity monitoring systems (COMS) pursuant to 40 CFR Part 75. The owner or operator shall maintain and operate COMS and shall make and maintain records of opacity measured by the COMS, for purposes of periodic monitoring.

[Rule 62-213.440, F.A.C., and applicant agreement with EPA on March 3, 1998]

### Miscellaneous

**A.46.** Circumvention. No owner or operator subject to the provisions of 40 CFR 60 shall build, erect, install, or use any article, machine, equipment or process, the use of which conceals an emission which would otherwise constitute a violation of an applicable standard. Such concealment includes, but is not limited to, the use of gaseous diluents to achieve compliance with an opacity standard or with a standard which is based on the concentration of a pollutant in the gases discharged to the atmosphere.

[40 CFR 60.12]

**A.47.** The emissions units are also subject to the conditions contained in **Subsection E. Common Conditions.**



**Subsection B. This section addresses the following emissions units.**

**E.U. ID**

| <b><u>No.</u></b> | <b><u>Brief Description</u></b>                               |
|-------------------|---|
| -003              | Combustion Turbine with Heat Recovery Steam Generator (CT 3A) |
| -004              | Combustion Turbine with Heat Recovery Steam Generator (CT 3B) |
| -005              | Combustion Turbine with Heat Recovery Steam Generator (CT 4A) |
| -006              | Combustion Turbine with Heat Recovery Steam Generator (CT 4B) |

All four combined cycle units are identical in configuration. Nitrogen oxide emissions are controlled by using dry low NOx combustors for natural gas with steam injection for fuel oil firing. Steam injection is also used for power augmentation. Inlet foggers installed at the compressor inlet to each of the four CTs reduce the turbine inlet air temperature. The temperature reduction improves the heat rate and increases power due to the cooler/denser inlet air. Duct modules suitable for future installation of selective catalytic reduction (SCR) equipment have been installed on each combined cycle generating unit. Based on information contained in the Title V Permit Application, only natural gas has been fired in the units to date. Units #3 and #4 commenced commercial operation in February, 1994. Units #5 and #6 commenced commercial operation in April, 1994.

{Permitting notes: the emissions units are regulated under Acid Rain, Phase II and NSPS - 40 CFR 60, Subpart GG, Standards of Performance for Stationary Gas Turbines; adopted and incorporated by reference in Rule 62-204.800(7)(b)38., F.A.C; PSD-FL-146, Prevention of Significant Deterioration (PSD), in Rule 62-212.400, F.A.C.; and Best Available Control Technology (BACT), in Rule 62-212.410, F.A.C.}

**The following conditions apply to the emissions units listed above:**

**General**

**B.1. Definitions.** For the purposes of Rule 62-204.800(7), F.A.C., the definitions contained in the various provisions of 40 CFR 60, shall apply except that the term "Administrator" when used in 40 CFR 60, shall mean the Secretary or the Secretary's designee.

[40 CFR 60.2; Rule 62-204.800(7)(a), F.A.C.]

**B.2. Circumvention.** No owner or operator subject to the provisions of 40 CFR 60 shall build, erect, install, or use any article, machine, equipment or process, the use of which conceals an emission which would otherwise constitute a violation of an applicable standard. Such concealment includes, but is not limited to, the use of gaseous diluents to achieve compliance with an opacity standard or with a standard which is based on the concentration of a pollutant in the gases discharged to the atmosphere.

[40 CFR 60.12]

**Essential Potential to Emit (PTE) Parameters**

**B.3. Permitted Capacity.** The maximum heat input to each Combustion Turbine (CT) shall neither exceed 1966 MMBtu/hr while firing natural gas, nor 1846 MMBtu/hr while firing fuel oil @40 degrees F. These heat input limitations are subject to change. Any changes shall be provided at least 90 days before commercial operation for each fuel available to the site which a unit is capable of firing, at which time this condition may be modified to reflect those parameters. Each combined cycle's fuel consumption shall be continuously determined and recorded. Testing of emissions shall be conducted with the units operating at capacity. Capacity is defined as 95-100 percent of the manufacturer's rated heat input achievable for the average ambient (or conditioned) air temperature during the test. If it is impractical to test at capacity, then the units may be tested at less than capacity. In such cases, the entire heat input versus inlet temperature curves will be adjusted by the increment equal to the difference between the design heat input value and 105 percent of the value reached during the test. Data, curves, and calculations necessary to demonstrate the heat input rate correction at both design and test conditions shall be submitted to the Department with the compliance test report.  
[Rules 62-4.160(2) and 62-210.200(PTE), F.A.C.; PSD-FL-146, Specific Condition No. 1]

{Permitting note: The heat input limitations have been placed in each permit to identify the capacity of each unit for the purposes of confirming that emissions testing is conducted within 90 to 100 percent of the unit's rated capacity (or to limit future operation to 110 percent of the test load), to establish appropriate emission limits and to aid in determining future rule applicability.}

**B.4. Methods of Operation.**

- a. Fuels. Only natural gas or No. 2 fuel oil shall be fired in the CTs.
- b. Inlet Foggers. Operation of the foggers on each unit may not exceed the following limits: 181,661 degree F-hours in aggregate firing natural gas fuel if no distillate fuel is fired. If distillate oil is fired in any of the CTs during a calendar year, the allowable degree F-hours for natural gas shall be decreased by 2.77 degree F-hours for every hour operated on distillate oil fuel. No CT may exceed 4,000 degree F-hours per year firing distillate oil fuel.

{Permitting Note: The permittee shall monitor both the hours of operation for the inlet foggers and the degrees of cooling afforded by the inlet foggers. Computation of the degree-hour will be performed as follows:

Degree-hours = # hours inlet fogger operating time X degrees F of cooling

Degrees of Cooling shall be calculated by subtracting the fogged compressor inlet air temperature from the unfogged compressor inlet temperature (upstream of the fogger). The above calculation shall be performed for each hour of fogger operation. Calculation records shall be maintained on the plant site and made available for inspection upon request.}

The temperature drop across the inlet foggers shall be monitored whenever water is injected at the foggers and hourly average temperature drops shall be calculated and recorded along with hours of operation automatically using a computer system. The product of each hour of fogger operation and the average temperature depression for that hour (degree F-hours) shall be summed for each calendar year and shall be submitted to the DEP SE District Office with the Annual Operating Report. The temperature monitoring system shall be calibrated annually (see specific condition **B.52.**).

[PSD-FL-146, Specific Condition No. 3; PSD-FL-146(G); and, 0850001-005-AC]

**B.5. Hours of Operation.** The emissions units may operate continuously, i.e., 8760 hours/year/CT.

[Rule 62-210.200(PTE), F.A.C.]

**Emission Limitations and Standards**

{Permitting note: Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

**B.6.** The maximum allowable emissions from each CT, in accordance with the BACT determination, shall not exceed the following, at 40 degrees F, except during periods of startup and shutdown:

| Pollutant           | Fuel             | Emission Limitations <sup>d</sup> |            |                                    |
|---------------------|------------------|-----------------------------------|------------|------------------------------------|
|                     |                  | Concentration                     | lb/hr/CT   | TPY/CT <sup>a</sup>                |
| NOx                 | Gas              | 25 ppmvd @ 15% O <sub>2</sub>     | 177        | 3108 (combined gas and oil total)  |
|                     | Oil              | 65 ppmvd @ 15% O <sub>2</sub>     | 461        |                                    |
| VOC <sup>b</sup>    | Gas              | 1.6 ppmvd                         | 3          | 57 (combined gas and oil total)    |
|                     | Oil              | 6 ppmvd                           | 11.0       |                                    |
| CO                  | Gas              | 30 ppmvd                          | 94.3       | 871 (combined gas and oil total)   |
|                     | Oil              | 33 ppmvd                          | 105.8      |                                    |
| PM/PM <sub>10</sub> | Gas              |                                   | 18         | 100 (combined gas and oil total)   |
|                     | Oil              |                                   | 60.6       |                                    |
| Pb                  | Gas              |                                   | negligible | 0.015 (combined gas and oil total) |
|                     | Oil              |                                   | 0.015      |                                    |
| SO <sub>2</sub>     | Gas              |                                   | 91.5       | 568 (combined gas and oil total)   |
|                     | Oil <sup>c</sup> |                                   | 920        |                                    |

Notes:

<sup>a</sup> Tons per year (TPY) emission limits listed for natural gas and oil combined apply as an emissions cap based on limiting oil firing to an annual aggregate of 2,000 hours for the 4 CT's, with compliance to be demonstrated in annual operation reports.

<sup>b</sup> Exclusive of background concentrations.

<sup>c</sup> Sulfur dioxide emissions based on a maximum of 0.5 percent sulfur content, by weight, in oil for hourly emissions and an average sulfur content of 0.3 percent, by weight, for annual emissions. These sulfur content limitations are subject to change based on the analysis required in PSD Specific Condition No. 12. (See specific condition **B.49.**)

<sup>d</sup> These limitations for Units 5 and 6 shall not be binding for subsequent BACT determinations.

[PSD-FL-146, Specific Condition No. 4]

B.7. The following emissions, determined by BACT, are tabulated for PSD and inventory purposes:

| Pollutant   | Fuel | Maximum Allowable Emissions (@40 ° F) |                                   |
|---|------|---------------------------------------|-----------------------------------|
|   |      | lb/hr/CT                              | TPY/CT <sup>a</sup>               |
| H <sub>2</sub> SO <sub>4</sub> Acid Mist <sup>b</sup> | Gas  | 11.2                                  | 70 (combined gas and oil total)   |
|   | Oil  | 113                                   |                                   |
| Mercury   | Gas  | 0.021                                 | 0.34 (combined gas and oil total) |
|   | Oil  | 0.0052                                |                                   |
| Fluoride  | Oil  | 0.055                                 | 0.055                             |
| Beryllium   | Oil  | 0.004                                 | 0.004                             |

Notes:

<sup>a</sup> Tons per year (TPY) emission limits for natural gas and oil combined apply as an emissions cap based on limiting oil firing to an annual aggregate of 2,000 hours for the 4 CT's, with compliance to be demonstrated in annual operation reports.

<sup>b</sup> Sulfuric acid mist emissions assume a maximum of 0.5 percent sulfur content, by weight, in fuel oil for hourly emissions and an average sulfur content of 0.3 percent, by weight, for annual emissions.

[PSD-FL-146, Specific Condition No. 5]

**B.8. Opacity.** Visible emissions shall neither exceed 10% opacity while burning natural gas, nor 20% opacity while burning distillate oil.

[PSD-FL-146, Specific Condition No. 8]

**B.9. Opacity.** Compliance with standards in 40 CFR 60, other than opacity standards, shall be determined only by performance tests established by 40 CFR 60.8, unless otherwise specified in the applicable standard.

[40 CFR 60.11(a)]

**B.10. Opacity.** The opacity standards set forth in 40 CFR 60 shall apply at all times except during periods of startup, shutdown, malfunction, and as otherwise provided in the applicable standard.

[40 CFR 60.11(c)]

**B.11. Nitrogen Oxides.** Nitrogen oxide emissions from each gas turbine/heat recovery steam generator unit shall be controlled by using dry low NOx combustors for natural gas with steam injection for fuel oil firing. The permittee has installed duct modules suitable for future installation of SCR equipment on each combined cycle generating unit.

[PSD-FL-146, Specific Condition No. 9]

**Excess Emissions**

**B.12.** Excess emissions resulting from malfunction shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration.

[Rule 62-210.700(1), F.A.C.]

**B.13.** Excess emissions resulting from startup or shutdown shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized.

[Rule 62-210.700(2), F.A.C.]

**B.14.** Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown or malfunction shall be prohibited.

[Rule 62-210.700(4), F.A.C.]

**B.15.** The excess emissions authorized under Rule 62-210.700(1), F.A.C., shall be extended an additional two hours (four hours total) for a cold steam turbine start for the first CT of a unit. The second CT of each unit shall comply with established emission limits in accordance with Rule 62-210.700(1), F.A.C.

[PSD-FL-146, Specific Condition No. 4]

**B.16.** At all times, including periods of startup, shutdown, and malfunction, owners and operators shall, to the extent practicable, maintain and operate any affected facility including associated air pollution control equipment in a manner consistent with good air pollution control practice for minimizing emissions. Determination of whether acceptable operating and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, opacity observations, review of operating and maintenance procedures, and inspection of the source.

[40 CFR 60.11(d)]

**Monitoring of Operations**

**B.17.** At all times, including periods of startup, shutdown and malfunction, owners and operators shall, to the extent practicable, maintain and operate any affected facility including associated pollution control equipment in a manner consistent with good air pollution control practice for minimizing emissions. Determination of whether acceptable operating and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, opacity observations, review of operating and maintenance procedures, and inspection of the source.  
[40 CFR 60.11(d)]

**B.18.** The owner or operator of any stationary gas turbine subject to the provisions of 40 CFR 60, Subpart GG and using water injection to control NO<sub>x</sub> emissions shall install and operate a continuous monitoring system to monitor and record the fuel consumption and the ratio of water to fuel being fired in the turbine. This system shall be accurate to within  $\pm 5.0$  percent and shall be approved by the Administrator. This specific condition does **not apply** if only natural gas is fired in the turbine.  
[40 CFR 60.334(a)]

**B.19.** The owner or operator of any stationary gas turbine subject to the provisions of 40 CFR 60, Subpart GG shall monitor sulfur content and nitrogen content of the fuel being fired in the turbine. The frequency of determination of these values shall be as follows:

- (1) If the turbine is supplied its fuel from a bulk storage tank, the values shall be determined on each occasion that fuel is transferred to the storage tank from any other source.
- (2) If the turbine is supplied its fuel without intermediate bulk storage, the values shall be determined and recorded daily. Owners, operators or fuel vendors may develop custom schedules for determination of the values based on the design and operation of the affected facility and the characteristics of the fuel supply. These custom schedules shall be substantiated with data and must be approved by the Administrator before they can be used to comply with 40 CFR 60.334(b).  
[40 CFR 60.334(b)(1) and (2)]

**B.20.** The Martin Plant facility requested approval for and was granted approval to utilize a customized fuel monitoring schedule for natural gas firing, pursuant to 40 CFR 60.334(b). See specific condition **B.19**. The schedule is as follows:

Custom Fuel Monitoring Schedule for Natural Gas (NG)

1. Monitoring of fuel nitrogen content shall not be required if NG is the only fuel being fired in the gas turbines.
2. Sulfur Monitoring
  - a. Analysis for fuel sulfur content of the natural gas shall be conducted using one of the approved ASTM reference methods for the measurement of sulfur in gaseous fuels, or an approved alternative method. The reference methods are ASTM D1072-80, ASTM D3031-81, ASTM D3246-81, and ASTM D4084-82, as referenced in 40 CFR 60.335(b)(2), or the latest edition(s).
  - b. This custom fuel monitoring schedule shall become effective on the date this permit becomes valid. Effective the date of this custom schedule, sulfur monitoring shall be conducted twice monthly for six

months. If this monitoring shows little variability in the fuel sulfur content, and indicates consistent compliance with 40 CFR 60.333, then sulfur monitoring shall be conducted once per quarter for six quarters. If monitoring data is provided by the applicant which demonstrates consistent compliance with the requirements herein the applicant may begin monitoring as per the requirements of 2(c).

- c. If after the monitoring required in item 2(b) above, or herein, the sulfur content of the fuel shows little variability and, calculated as sulfur dioxide, represents consistent compliance with the sulfur dioxide emission limits specified under 40 CFR 60.333, sample analysis shall be conducted twice per annum. This monitoring shall be conducted during the first and third quarters of each calendar year.
  - d. Should any sulfur analysis as required in items 2(b) or 2(c) above indicate noncompliance with 40 CFR 60.333, the owner or operator shall notify the Department of such excess emissions and the custom schedule shall be re-examined by the Environmental Protection Agency. Sulfur monitoring shall be conducted weekly during the interim period when this custom schedule is being re-examined.
3. If there is a change in fuel supply, the owner or operator must notify the Department of such change for re-examination of this custom schedule. A substantial change in fuel quality shall be considered as a change in fuel supply. Sulfur monitoring shall be conducted weekly during the interim period when this custom schedule is being re-examined.
  4. Records of sample analysis and fuel supply pertinent to this custom schedule shall be retained for a period of five years, and be available for inspection by personnel of federal, state, and local air pollution control agencies.

[PSD-FL-146; NSPS Custom Fuel Monitoring Schedule dated 10/14/97]

### **Test Methods and Procedures**

{Permitting note: Table 2-1, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

**B.21.** To compute the nitrogen oxides emissions, the owner or operator shall use analytical methods and procedures that are accurate to within 5 percent and are approved by the Department to determine the nitrogen content of the fuel being fired. This specific condition does **not apply** if only natural gas is fired in the turbine.

[40 CFR 60.335(a)]

**B.22.** The monitoring device of 40 CFR 60.334(a) shall be used to determine the fuel consumption and the water-to-fuel ratio necessary to comply with the permitted NO<sub>x</sub> standard at 30, 50, 75, and 100 percent of peak load or at four points in the normal operating range of the gas turbine, including the minimum point in the range and peak load. All loads shall be corrected to ISO conditions using the appropriate equations supplied by the manufacturer. This specific condition does **not apply** if only natural gas is fired in the turbine.

[40 CFR 60.335(c)(2)]

**B.23.** The owner or operator shall determine compliance with the nitrogen oxides and sulfur dioxide standards in 40 CFR 60.332 as follows:

c. U.S. EPA. Method 20 (40 CFR 60, Appendix A) shall be used to determine the nitrogen oxides, sulfur dioxide, and oxygen concentrations. The span values shall be 300 ppm of nitrogen oxide and 21 percent oxygen. The NO<sub>x</sub> emissions shall be determined at each of the load conditions specified in 40 CFR 60.335(c)(2). See specific condition **B.20.** that describes the approved Custom Fuel Monitoring Schedule for Natural Gas for this facility. After initial testing, subsequent annual NO<sub>x</sub> compliance tests for NO<sub>x</sub> limits that are more stringent than 40 CFR 60, Subpart GG, shall not require an ISO correction or testing at four load points; rather, the testing shall be done at capacity (see specific condition **B.3.**). However, when testing shows that NO<sub>x</sub> emissions exceed the standard when operating at capacity, the permittee shall recalibrate the NO<sub>x</sub> emission control system using emission testing at four load points. [40 CFR 60.335(c)(3); and applicant request letter dated July 29, 1998]

**B.24.** The owner or operator shall determine compliance with the sulfur content standard of 0.5 percent, by weight, as follows: ASTM D 2880-96 shall be used to determine the sulfur content of liquid fuels and ASTM D 1072-90(94)E-1, D 3031-81(86), D 4084-94, or D 3246-92 shall be used for the sulfur content of gaseous fuels (incorporated by reference-see 40 CFR 60.17). The applicable ranges of some ASTM methods mentioned above are not adequate to measure the levels of sulfur in some fuel gases. Dilution of samples before analysis (with verification of the dilution ratio) may be used, subject to the approval of the Administrator. See specific condition **B.20** that describes the approved Custom Fuel Monitoring Schedule for Natural Gas for this facility. [40 CFR 60.335(d)]

**B.25.** To meet the requirements of 40 CFR 60.334(b), the owner or operator shall use the methods specified in 40 CFR 60.335 (a) and 40 CFR 60.335(d) of 40 CFR 60.335 to determine the nitrogen and sulfur contents of the fuel being burned. The analysis may be performed by the owner or operator, a service contractor retained by the owner or operator, the fuel vendor, or any other qualified agency. See specific condition **B.20** that describes the approved Custom Fuel Monitoring Schedule for Natural Gas for this facility. [40 CFR 60.335(e)]

**B.26.** The owner or operator shall provide, or cause to be provided, stack sampling and performance testing facilities as follows:

- (1) Sampling ports adequate for test methods applicable to such facilities.
- (2) Safe sampling platform(s).
- (3) Safe access to sampling platform(s).
- (4) Utilities for sampling and testing equipment.

[40 CFR 60.8; PSD-FL-146, Specific Condition No. 21]



**B.27.** It is not necessary to plan the firing of a fuel solely to complete the initial compliance test, instead, the initial test may be postponed until such time as the untested fuel is ready for service. Initial (I) compliance tests shall be performed on each Combustion Turbine using both fuels. The stack test for each turbine shall be performed within 10% of the maximum heat rate input for the tested operating temperature. Annual (A) compliance tests shall be performed on each Combustion Turbine with the fuel(s) used for more than 400 hours in the preceding 12-month period. Tests shall be conducted using EPA reference methods, or equivalent, in accordance with the July 1, 1996 version of 40 CFR 60 Appendix A. (Note: based on information provided in the Title V Permit Application, initial testing using distillate oil has **not been done.**) See specific condition **B.3** for utilization of ambient temperature versus heat input curves during compliance testing.

| Pollutant                  | EPA Reference Method  | Initial testing |     | Annual testing |     |
|----------------------------|---|-----------------|-----|----------------|-----|
|                            |   | Gas             | Oil | Gas            | Oil |
| Particulate Matter         | 5 or 17   |                 | X   |                | X   |
| Sulfuric Acid Mist         | 8   |                 | X   |                |     |
| Visible Emissions          | 9   | X               | X   | X              | X   |
| Carbon Monoxide            | 10  | X               | X   | X              | X   |
| Nitrogen Oxides            | 20  | X               | X   | X              | X   |
| Volatile Organic Compounds | 18  | X               | X   |                |     |
|                            | <b>Test Method</b>  |                 |     |                |     |
| Lead                       | EMTIC Test Method, or Method 7090, or 7091*                                   |                 | X   |                |     |
| Beryllium                  | EMTIC Test Method, or Method 104, or Method 7090, or 7091*                    |                 | X   |                |     |
| Sulfur content             | ASTM D 2880-96  |                 | X   |                | X   |
|                            | ASTM D 1072-90(94) E-1, ASTM D 3031-81(86), ASTM D 4084-94, or ASTM D 3246-92 | X               |     | X              |     |
| Mercury                    | 40 CFR 61, Appendix B EPA Method 101  | X               | X   |                |     |

\*Method 3040 sample extraction shall be used as described in the EPA solid waste regulations SW 846.

[PSD-FL-146, Specific Condition No. 10; and, applicant request letter dated July 28, 1998]

**B.28.** The average sulfur content of the light distillate oil shall not exceed 0.3%, by weight, during any consecutive 12-month period. The maximum sulfur content of the light distillate fuel oil shall not exceed 0.5%, by weight. The 12-month average sulfur content shall be calculated as a weighted average based upon the sulfur content of the oil and the amount burned on a daily basis. Compliance shall be demonstrated in accordance with the requirements of 40 CFR 60.334 by testing for sulfur content, for nitrogen content, and for heating value of oil storage tanks once per day when firing oil using ASTM D 2880-96.  
[Rule 62-213.440, F.A.C., applicant agreement with EPA on March 3, 1998, and PSD-FL-146, Specific Condition No. 11]

**B.29. Opacity.** Compliance with opacity standards in 40 CFR 60 shall be determined by conducting observations in accordance with Reference Method 9 in Appendix A of 40 CFR 60, any alternative method that is approved by the Administrator, or as provided in 40 CFR 60.11(e)(5).  
[40 CFR 60.11(b)]

**B.30.** Performance tests shall be conducted under such conditions as the Administrator shall specify to the plant operator based on representative performance of the affected facility. The owner or operator shall make available to the Administrator such records as may be necessary to determine the conditions of the performance tests. Operations during periods of startup, shutdown, and malfunction shall not constitute representative conditions for the purpose of a performance test nor shall emissions in excess of the level of the applicable emission limit during periods of startup, shutdown, and malfunction be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard.  
[40 CFR 60.8(c)]

### **Continuous Monitoring Requirements**

**B.31.** Continuous emissions monitoring shall be installed, operated, and maintained in accordance with 40 CFR 75 for each combined cycle unit to monitor nitrogen oxides.

- (a) Each continuous emissions monitoring system (CEMS) shall meet performance specifications of 40 CFR 75, Appendices A, B, and F.
- (b) CEMS data shall be recorded and reported in accordance with 40 CFR 75 and 40 CFR 60.7. The excess emissions report shall include periods of startup, shutdown, and malfunction and shall be based on NO<sub>x</sub> data corrected to 15 % O<sub>2</sub> and 40 degrees F.
- (c) A malfunction means any sudden and unavoidable failure of air pollution equipment or process equipment to operate in a normal or usual manner. Failures that are caused entirely or in part by poor maintenance, careless operation or any other preventable upset condition or preventable equipment breakdown shall not be considered malfunctions.
- (d) For purposes of reports required under this permit, excess emissions are defined as any calculated average emission concentration which exceeds the applicable emission limits in specific condition **B.6**. See specific condition **B.39**.  
[PSD-FL-146, Specific Condition No. 13]

**B.32.** For the purposes of 40 CFR 60.13, all continuous monitoring systems required under applicable subparts shall be subject to the provisions of 40 CFR 60.13 upon promulgation of performance specifications for continuous monitoring systems under Appendix B of 40 CFR 60 and, if the continuous monitoring system is used to demonstrate compliance with emission limits on a continuous basis, Appendix F of 40 CFR 60, unless otherwise specified in an applicable subpart or by the Administrator. Appendix F is applicable December 4, 1987.  
[40 CFR 60.13(a)]

**B.33.** If the owner or operator of an affected facility elects to submit continuous opacity monitoring system (COMS) data for compliance with the opacity standard as provided under 40 CFR 60.11(e)(5), he shall conduct a performance evaluation of the COMS as specified in Performance Specification 1, Appendix B, of 40 CFR 60 before the performance test required under 40 CFR 60.8 is conducted. Otherwise, the owner or operator of an affected facility shall conduct a performance evaluation of the COMS or continuous emission monitoring system (CEMS) during any performance test required under 40 CFR 60.8 or within 30 days thereafter in accordance with the applicable performance specification in Appendix B of 40 CFR 60. The owner or operator of an affected facility shall conduct COMS or CEMS performance evaluations at such other times as may be required by the Administrator under section 114 of the Act.  
[40 CFR 60.13(c)]

**B.34.** The owner or operator of an affected facility subject to an opacity standard may submit, for compliance purposes, continuous opacity monitoring system (COMS) data results produced during any performance test required under 40 CFR 60.8 in lieu of Method 9 observation data. If an owner or operator elects to submit COMS data for compliance with the opacity standard, he shall notify the Administrator of that decision, in writing, at least 30 days before any performance test required under 40 CFR 60.8 is conducted. Once the owner or operator of an affected facility has notified the Administrator to that effect, the COMS data results will be used to determine opacity compliance during subsequent tests required under 40 CFR 60.8 until the owner or operator notifies the Administrator, in writing, to the contrary. For the purpose of determining compliance with the opacity standard during a performance test required under 40 CFR 60.8 using COMS data, the minimum total time of COMS data collection shall be averages of all 6-minute continuous periods within the duration of the mass emission performance test. Results of the COMS opacity determinations shall be submitted along with the results of the performance test required under 60.8. The owner or operator of an affected facility using a COMS for compliance purposes is responsible for demonstrating that the COMS meets the requirements specified in 40 CFR 60.13(c), that the COMS has been properly maintained and operated, and that the resulting data have not been altered in any way. If COMS data results are submitted for compliance with the opacity standard for a period of time during which Method 9 data indicates noncompliance, the Method 9 data will be used to determine opacity compliance.  
[40 CFR 60.11(e)(5)]

**B.35.** (1) Owners and operators of all continuous emission monitoring systems (CEMS) installed in accordance with the provisions of this part shall check the zero (or low-level value between 0 and 20 percent of span value) and span (50 to 100 percent of span value) calibration drifts at least once daily in accordance with a written procedure. The zero and span shall, as a minimum, be adjusted whenever the 24-hour zero drift or 24-hour span drift exceeds two times the limits of the applicable performance specifications in Appendix B. The system must allow the amount of excess zero and span drift measured at the 24-hour interval checks to be recorded and quantified, whenever specified. For continuous monitoring systems measuring opacity of emissions, the optical surfaces exposed to the effluent gases shall be cleaned prior to performing the zero and span drift adjustments except that for systems using automatic zero adjustments. The optical surfaces shall be cleaned when the cumulative automatic zero compensation exceeds 4 percent opacity.

(2) Unless otherwise approved by the Administrator, the following procedures shall be followed for continuous monitoring systems measuring opacity of emissions. Minimum procedures shall include a method for producing a simulated zero opacity condition and an upscale (span) opacity condition using a certified neutral density filter or other related technique to produce a known obscuration of the light beam. Such procedures shall provide a system check of the analyzer internal optical surfaces and all electronic circuitry including the lamp and photo detector assembly.

[40 CFR 60.13(d)(1) and (2)]

**B.36.** Except for system breakdowns, repairs, calibration checks, and zero and span adjustments required under 40 CFR 60.13(d), all continuous monitoring systems (CMS) shall be in continuous operation and shall meet minimum frequency of operation requirements as follows:

(1) All continuous monitoring systems referenced by 40 CFR 60.13(c) for measuring opacity of emissions shall complete a minimum of one cycle of sampling and analyzing for each successive 10-second period and one cycle of data recording for each successive 6-minute period.

(2) All continuous monitoring systems referenced by 40 CFR 60.13(c) for measuring emissions, except opacity, shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period.

[40 CFR 60.13(e)(1) and (2)]

**B.37.** All continuous monitoring systems (CMS) or monitoring devices shall be installed such that representative measurements of emissions or process parameters from the affected facility are obtained. Additional procedures for location of continuous monitoring systems contained in the applicable Performance Specifications of Appendix B of 40 CFR 60 shall be used.

[40 CFR 60.13(f)]

**B.38.** When the effluents from a single affected facility or two or more affected facilities subject to the same emission standards are combined before being released to the atmosphere, the owner or operator may install applicable continuous monitoring systems (CMS) on each effluent or on the combined effluent. When the affected facilities are not subject to the same emission standards, separate continuous monitoring systems shall be installed on each effluent. When the effluent from one affected facility is released to the atmosphere through more than one point, the owner or operator shall install an applicable continuous monitoring system on each separate effluent unless the installation of fewer systems is approved by the Administrator. When more than one continuous monitoring system is used to measure the emissions from one affected facility (e.g., multiple breechings, multiple outlets), the owner or operator shall report the results as required from each continuous monitoring system.

[40 CFR 60.13(g)]

**B.39.** Owners or operators of all continuous monitoring systems for measurement of opacity shall reduce all data to 6-minute averages and for continuous monitoring systems other than opacity to 1-hour averages for time periods as defined in 40 CFR 60.2. Six-minute opacity averages shall be calculated from 36 or more data points equally spaced over each 6-minute period. For continuous monitoring systems other than opacity, 1-hour averages shall be computed from four or more data points equally spaced over each 1-hour period. Data recorded during periods of continuous monitoring system breakdowns, repairs, calibration checks, and zero and span adjustments shall not be included in the data averages computed under this paragraph. An arithmetic or integrated average of all data may be used. The data may be recorded in reduced or non reduced form (e.g., ppm pollutant and percent O<sub>2</sub> or ng/J of pollutant). All excess emissions shall be converted into units of the standard using the applicable conversion procedures specified in subparts. After conversion into units of the standard, the data may be rounded to the same number of significant digits as used in the applicable subparts to specify the emission limit (e.g., rounded to the nearest 1 percent opacity).

[40 CFR 60.13(h)]

#### **Recordkeeping and Reporting Requirements**

**B.40.** To determine compliance with the oil firing heat input limitation, the permittee shall maintain daily records of fuel oil consumption and hourly usage for each turbine and heating value for each fuel. All records shall be maintained for a minimum of five (5) years after the date of each record and shall be made available to representatives of the Department upon request.

[PSD-FL-146, Specific Condition No. 14]

**B.41.** The permittee shall have required sampling tests of the emissions performed within 60 after achieving the maximum turbine firing rate, but not later than 180 days from the start of operations. Thirty (30) days notice prior to the initial sampling test and fifteen (15) days notice before subsequent annual testing shall be provided to the Southeast District Office. Written reports of the tests shall be submitted to the Southeast District Office within 45 days of test completion.

[PSD-FL-146, Specific Condition No. 17]

**B.42.** Quarterly excess emission reports, in accordance with the July 1, 1996, version of 40 CFR 60.7(c) and 60.334(c), shall be submitted to the Department's Southeast District Office.

Annual reports shall be submitted to the District office in accordance with Rule 62-2.700(7), F.A.C.

[PSD-FL-146, Specific Condition No. 19]

**B.43.** For the purpose of reports required under 40 CFR 60.7(c), periods of excess emissions that shall be reported are defined as follows:

a. *Nitrogen oxides.* Any one-hour period during which the average water-to-fuel ratio, as measured by the continuous monitoring system, falls below the water-to-fuel ratio determined to demonstrate compliance with the permitted nitrogen oxide standard by the initial performance test required in 40 CFR 60.8 or any period during which the fuel-bound nitrogen of the fuel is greater than the maximum nitrogen content allowed by the fuel-bound nitrogen allowance used during the initial performance test. Each report shall include the average water-to-fuel ratio, average fuel consumption, ambient conditions, gas turbine load, and nitrogen content of the fuel during the period of excess emissions, and the graphs or figures developed under 40 CFR 60.335(a).

[Rule 62-296.800, F.A.C.; 40 CFR 60.334(c)(1)]

**B.44.** The owner or operator subject to the provisions of 40 CFR 60 shall furnish the Administrator written notification as follows:

(4) A notification of any physical or operational change to an existing facility which may increase the emission rate of any air pollutant to which a standard applies, unless that change is specifically exempted under an applicable subpart or in 40 CFR 60.14(e). This notice shall be postmarked 60 days or as soon as practicable before the change is commenced and shall include information describing the precise nature of the change, present and proposed emission control systems, productive capacity of the facility before and after the change, and the expected completion date of the change. The Administrator may request additional relevant information subsequent to this notice.

[40 CFR 60.7(a)(4)]

**B.45.** The owner or operator subject to the provisions of 40 CFR 60 shall maintain records of the occurrence and duration of any startup, shutdown, or malfunction in the operation of an affected facility; any malfunction of the air pollution control equipment; or, any periods during which a continuous monitoring system or monitoring device is inoperative.

[40 CFR 60.7(b)]

**B.46.** The owner or operator required to install a continuous monitoring system (CMS) or monitoring device shall submit an excess emissions and monitoring systems performance report and/or a summary report form [see 40 CFR 60.7(d)] to the Administrator semiannually, except when: more frequent reporting is specifically required by an applicable subpart; or, the CMS data are to be used directly for compliance determination, in which case quarterly reports shall be submitted; or, the Administrator, on a case-by-case basis, determines that more frequent reporting is necessary to accurately assess the compliance status of the source. All reports shall be postmarked by the 30th day following the end of each calendar half (or quarter, as appropriate). Written reports of excess emissions shall include the following information:

(1) The magnitude of excess emissions computed in accordance with 40 CFR 60.13(h), any conversion factor(s) used, and the date and time of commencement and completion of each time period of excess emissions. The process operating time during the reporting period.

(2) Specific identification of each period of excess emissions that occurs during startups, shutdowns, and malfunctions of the affected facility. The nature and cause of any malfunction (if known), the corrective action taken or preventative measures adopted.

(3) The date and time identifying each period during which the continuous monitoring system was inoperative except for zero and span checks and the nature of the system repairs or adjustments.

(4) When no excess emissions have occurred or the continuous monitoring system(s) have not been inoperative, repaired, or adjusted, such information shall be stated in the report.

[40 CFR 60.7(c)(1), (2), (3), and (4)]

**B.47.** The summary report form shall contain the information and be in the format shown in Figure 1 (attached) unless otherwise specified by the Administrator. One summary report form shall be submitted for each pollutant monitored at each affected facility.

(1) If the total duration of excess emissions for the reporting period is less than 1 percent of the total operating time for the reporting period and CMS downtime for the reporting period is less than 5 percent of the total operating time for the reporting period, only the summary report form shall be submitted and the excess emission report described in 40 CFR 60.7(c) need not be submitted unless requested by the Administrator.

(2) If the total duration of excess emissions for the reporting period is 1 percent or greater of the total operating time for the reporting period or the total CMS downtime for the reporting period

is 5 percent or greater of the total operating time for the reporting period, the summary report form and the excess emission report described in 40 CFR 60.7(c) shall both be submitted.

*{See attached Figure 1: Summary Report-Gaseous and Opacity Excess Emission and Monitoring System Performance}*

[40 CFR 60.7(d)(1) and (2)]

**B.48.** (1) Notwithstanding the frequency of reporting requirements specified in 40 CFR 60.7(c), an owner or operator who is required by an applicable subpart to submit excess emissions and monitoring systems performance reports (and summary reports) on a quarterly (or more frequent) basis may reduce the frequency of reporting for that standard to semiannual if the following conditions are met:

- (i) For 1 full year (e.g., 4 quarterly or 12 monthly reporting periods) the affected facility's excess emissions and monitoring systems reports submitted to comply with a standard under this part continually demonstrate that the facility is in compliance with the applicable standard;
- (ii) The owner or operator continues to comply with all recordkeeping and monitoring requirements specified in 40 CFR 60, Subpart A, and the applicable standard; and
- (iii) The Administrator does not object to a reduced frequency of reporting for the affected facility, as provided in 40 CFR 60.7(e)(2).

(2) The frequency of reporting of excess emissions and monitoring systems performance (and summary) reports may be reduced only after the owner or operator notifies the Administrator in writing of his or her intention to make such a change and the Administrator does not object to the intended change. In deciding whether to approve a reduced frequency of reporting, the Administrator may review information concerning the source's entire previous performance history during the required recordkeeping period prior to the intended change, including performance test results, monitoring data, and evaluations of an owner or operator's conformance with operation and maintenance requirements. Such information may be used by the Administrator to make a judgment about the source's potential for noncompliance in the future. If the Administrator disapproves the owner or operator's request to reduce the frequency of reporting, the Administrator will notify the owner or operator in writing within 45 days after receiving notice of the owner or operator's intention. The notification from the Administrator to the owner or operator will specify the grounds on which the disapproval is based. In the absence of a notice of disapproval within 45 days, approval is automatically granted.

(3) As soon as monitoring data indicate that the affected facility is not in compliance with any emission limitation or operating parameter specified in the applicable standard, the frequency of reporting shall revert to the frequency specified in the applicable standard, and the owner or operator shall submit an excess emissions and monitoring systems performance report (and summary report, if required) at the next appropriate reporting period following the noncomplying event. After demonstrating compliance with the applicable standard for another full year, the owner or operator may again request approval from the Administrator to reduce the frequency of reporting for that standard as provided for in 40 CFR 60.7(e)(1) and (e)(2).

[40 CFR 60.7(e)(1)]

**B.49.** The owner or operator subject to the provisions of 40 CFR 60 shall maintain a file of all measurements, including continuous monitoring system, monitoring device, and performance testing measurements; all continuous monitoring system performance evaluations; all continuous monitoring system or monitoring device calibration checks; adjustments and maintenance performed on these systems or devices; and, all other information required by 40 CFR 60 recorded in a permanent form suitable for inspection. The file shall be retained for at least 5 (five) years following the date of such measurements, maintenance, reports, and records.

[40 CFR 60.7(f); Rule 62-213.440(1)(b)2.b., F.A.C.]

Miscellaneous

**B.50.** In the supplemental application for approval of Phase II of the Project, the applicant shall include a cumulative air quality impact analysis and a PSD increment consumption analysis for the Everglades National Park Class I area.  
[PSD-FL-146, Specific Condition No. 12]

**B.51.** The emissions units are also subject to the conditions contained in **Subsection E. Common Conditions.**

**B.52. Temperature Monitoring System Calibration.** The temperature monitoring system shall be calibrated annually from 10 percent below to 10 percent above its normal operation range by the procedures recommended by the manufacturer. The temperature monitoring system generally consists of a thermocouple, a temperature indicator, and a recorder. The purpose of the calibration is to provide reasonable assurance that the temperature being recorded by the monitoring system is the actual temperature of the inlet air.

If the manufacturer has provided recommended calibration procedures, those procedures should be followed. If the manufacturer has not provided recommended calibration procedures, the following general calibration procedures should be used:

**THERMOCOUPLE:** The calibration points should bracket the temperature range over which the thermocouple is to be used. The thermocouple should be calibrated against a NIST (National Institute of Standards and Technology) traceable reference thermocouple. The thermocouple may be calibrated using ASTM E 220, Method B. Alternatively, the thermocouple can be replaced each year with a new thermocouple certified by the manufacturer to be accurate to within 0.9% of the temperatures being measured. A certificate of conformance from the manufacturer (certifying that the new thermocouple conforms to published specifications) will satisfy the annual calibration requirements.

**TEMPERATURE INDICATOR:** The instrument, which converts voltage output from the thermocouple to a temperature reading, can be calibrated by applying known voltages (mv), and reading the reported temperatures. The voltage values should correspond to the voltages generated by the thermocouple for temperatures over a range from 10% below to 10% above the inlet air temperatures to be used. The reference voltage supply should be accurate to within 0.1% of the reading.

**RECORDER:** The strip chart recorder or digital data acquisition system should be connected to the temperature indicator during its calibration and can be calibrated at the same time. The recorder should be adjusted to reproduce the readings of the temperature indicator.

The temperature monitoring system calibration error should not exceed 1% of the temperature reading.

[PSD-FL-146(G); 0850001-005-AC; and, Rule 62-297.310(5)(b)]



**Subsection C. This section addresses the following emissions unit.**

**E.U. ID**

| <b><u>No.</u></b> | <b><u>Brief Description</u></b> |
|-------------------|---------------------------------|
| -007              | Auxiliary Boiler                |

This unit is used to produce steam to actuate the steam seals on the steam turbine components of the combined-cycle units (Emissions Units -003 to -006) during cold starts when steam is not otherwise available for this purpose. Initial startup of the unit was on July 15, 1993.

{Permitting notes: The emissions unit is regulated under NSPS - 40 CFR 60.40c, Subpart Dc, Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units; adopted and incorporated by reference in Rule 62-204.800(7)(b)4, F.A.C.; PSD-FL-146, NSR - BACT.}

**The following conditions apply to the emissions unit listed above:**

**General**

**C.1. Definitions.** For the purposes of Rule 62-204.800(7), F.A.C., the definitions contained in the various provisions of 40 CFR 60, shall apply except that the term "Administrator" when used in 40 CFR 60, shall mean the Secretary or the Secretary's designee.  
[40 CFR 60.2; Rule 62-204.800(7)(a), F.A.C.]

**C.2. Circumvention.** No owner or operator subject to the provisions of 40 CFR 60 shall build, erect, install, or use any article, machine, equipment or process, the use of which conceals an emission which would otherwise constitute a violation of an applicable standard. Such concealment includes, but is not limited to, the use of gaseous diluents to achieve compliance with an opacity standard or with a standard which is based on the concentration of a pollutant in the gases discharged to the atmosphere.  
[40 CFR 60.12]

**Essential Potential to Emit (PTE) Parameters**

**C.3. Hours of Operation.** The auxiliary boiler shall operate only during startup and shutdown of the combined-cycle units, and for periodic maintenance testing.  
[Rule 62-210.200(PTE), F.A.C.; PSD-FL-146, revised 7/19/93]

**C.4. Fuels.** Only natural gas or No. 2 light distillate fuel oil shall be fired in the auxiliary boiler. Based on the Title V Permit Application, the unit is currently only capable of firing natural gas.  
[PSD-FL-146, Specific Condition No.3]

**Emission Limitations and Standards**

{Permitting note: Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

**C.5. Visible Emissions.** Visible emissions shall not exceed twenty (20) percent opacity (6-minute average), except for one six-minute period per hour of not more than twenty seven (27) percent opacity. This standard applies at all times, except during periods of startup, shutdown, or malfunction.

[40 CFR 60.43c(c) & (d)]

**C.6. Opacity.** Compliance with standards in 40 CFR 60, other than opacity standards, shall be determined only by performance tests established by 40 CFR 60.8, unless otherwise specified in the applicable standard.

[40 CFR 60.11(a)]

**C.7. Opacity.** The opacity standards set forth in 40 CFR 60 shall apply at all times except during periods of startup, shutdown, malfunction, and as otherwise provided in the applicable standard.

[40 CFR 60.11(c)]

**C.8. Sulfur Dioxide.** Sulfur dioxide emissions limitations for the auxiliary steam boiler are established by firing natural gas or limiting the light distillate fuel oil's average sulfur content to 0.3%, by weight, during any consecutive 12-month period. The 12-month average sulfur content shall be calculated as a weighted average based upon the sulfur content of the oil and the amount burned on a daily basis.

[Rule 62-213.440, F.A.C., applicant agreement with EPA on March 3, 1998, and PSD-FL-146, revised 7/19/93]

**C.9.** For units listed under 40 CFR 60.42c(h)(1), compliance with the emission limits or fuel oil sulfur limits under this section may be determined based on a certification from the fuel supplier, as described under 40 CFR 60.48c(f)(1), as applicable.

(1) Distillate oil-fired units with heat input capacities between 2.9 and 29 MW (10 and 100 million Btu/hr).

[40 CFR 60.42c(h)(1)]

**C.10. Nitrogen Oxides.** NOx emissions for the auxiliary steam boiler shall not exceed 0.3 lb/MMBtu for natural gas firing or oil firing.

[PSD-FL-146, revised 7/19/93]

### Test Methods and Procedures

{Permitting note: Table 2-1, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

#### C.11. Compliance and performance test methods and procedures for sulfur dioxide.

Compliance with the percent reduction requirements and SO<sub>2</sub> emission limits under 40 CFR 60.42c is based on the average percent reduction and the average SO<sub>2</sub> emission rates for 30 consecutive steam generating unit operating days. A separate performance test is completed at the end of each steam generating unit operating day, and a new 30-day average percent reduction and SO<sub>2</sub> emission rate are calculated to show compliance with the standard. **Note:** no annual testing is required if operational hours are less than 400 hours per year on oil. However, testing is required for permit renewal purposes.  
[40 CFR 60.44c(c); and, Rule 62-297.310(7), F.A.C.]

**C.12.** If only oil is combusted in a unit, the procedures in Method 19 are used to determine the hourly SO<sub>2</sub> emission rate ( $E_h$ ) and the 30-day average SO<sub>2</sub> emission rate ( $E_a$ ). The hourly averages used to compute the 30-day averages are obtained from the continuous emission monitoring system (CEMS). Method 19 shall be used to calculate  $E_a$  when using daily fuel sampling or Method 6B.

$E_h$  is defined as the hourly average pollutant rate, in ng/J (lb/million Btu heat input), and  $E_a$ , defined as the average pollutant rate for the specified performance test period, in ng/J (lb/million Btu heat input), is computed using the following equation:

$$E_a = (1/H) \sum_{j=1}^n E_{hj}$$

where H = total number of operating hours for which pollutant rates are determined in the performance test period.

[40 CFR 60.44c(d) & 40 CFR 60, Appendix A]

**C.13.** EPA Method 9 shall be used for determining the opacity of stack emissions.  
[40 CFR 60.45c(a)(7)]

**C.14.** Testing for the sulfur content, for the nitrogen content, and for the heating value of oil storage tanks shall be conducted once per day when firing oil using ASTM D 2880-96.  
[PSD-FL-146, Specific Condition No. 11]

**C.15. Opacity.** Compliance with opacity standards in 40 CFR 60 shall be determined by conducting observations in accordance with Reference Method 9 in Appendix A of 40 CFR 60, any alternative method that is approved by the Administrator, or as provided in 40 CFR 60.11(e)(5).

[40 CFR 60.11(b)]

**C.16.** Performance tests shall be conducted under such conditions as the Administrator shall specify to the plant operator based on representative performance of the affected facility. The owner or operator shall make available to the Administrator such records as may be necessary to determine the conditions of the performance tests. Operations during periods of startup, shutdown, and malfunction shall not constitute representative conditions for the purpose of a performance test nor shall emissions in excess of the level of the applicable emission limit during periods of startup, shutdown, and malfunction be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard.

[40 CFR 60.8(c)]

### **Recordkeeping and Reporting Requirements**

**C.17. (b)** The owner or operator of each unit subject to the SO<sub>2</sub> emission limits of 40 CFR 60.42c, or the PM or opacity limits of 40 CFR 60.43c, shall submit to the Administrator the performance test data from the initial and any subsequent performance tests.

(d) The owner or operator of each unit subject to the SO<sub>2</sub> emission limits, fuel oil sulfur limits, or percent reduction requirements under 40 CFR 60.42c shall submit quarterly reports to the Administrator. The initial quarterly report shall be postmarked by the 30th day of the third month following the completion of the initial performance test. Each subsequent quarterly report shall be postmarked by the 30th day following the end of the reporting period.

(e) The owner or operator of each unit subject to the SO<sub>2</sub> emission limits, fuel oil sulfur limits, or percent reduction requirements under 40 CFR 60.42c shall keep records and submit quarterly reports as required under 40 CFR 60.48c(d), including the following information, as applicable.

(1) Calendar dates covered in the reporting period.

(2) Each 30-day average SO<sub>2</sub> emission rate (ng/J or lb/million Btu), or 30-day average sulfur content (weight percent), calculated during the reporting period, ending with the last 30-day period in the quarter; reasons for any noncompliance with the emission standards; and a description of corrective actions taken.

(3) Each 30-day average percent of potential SO<sub>2</sub> emission rate calculated during the reporting period, ending with the last 30-day period in the quarter; reasons for any noncompliance with the emission standards; and a description of corrective actions taken.

(4) Identification of any steam generating unit operating days for which SO<sub>2</sub> or diluent (oxygen or carbon dioxide) data have not been obtained by an approved method for at least 75 percent of the operating hours; justification for not obtaining sufficient data; and a description of corrective actions taken.

(5) Identification of any times when emissions data have been excluded from the calculation of average emission rates; justification for excluding data; and a description of corrective actions taken if data have been excluded for periods other than those during which coal or oil were not combusted in the steam generating unit.

- (6) Identification of the F factor used in calculations, method of determination, and type of fuel combusted.
- (7) Identification of whether averages have been obtained based on CEMS rather than manual sampling methods.
- (11) If fuel supplier certification is used to demonstrate compliance, records of fuel supplier certification as described under 40 CFR 60.48c(f)(1), (2), or (3), as applicable. In addition to records of fuel supplier certifications, the quarterly report shall include a certified statement signed by the owner or operator of the unit that the records of fuel supplier certifications submitted represent all of the fuel combusted during the quarter.
- (f) Fuel supplier certification shall include the following information:
  - (1) For distillate oil:
    - (i) The name of the oil supplier; and
    - (ii) A statement from the oil supplier that the oil complies with the specifications under the following definition of distillate oil:

"Distillate oil means fuel oil that complies with the specifications for fuel oil numbers 1 or 2, as defined by the American Society for Testing and Materials in ASTM D396-78, "Standard Specification for Fuel Oils" ."
  - (g) The owner or operator of each unit shall record and maintain records of the amounts of each fuel combusted during each day.
  - (h) The owner or operator of each unit subject to a Federally enforceable requirement limiting the annual capacity factor for any fuel or mixture of fuels under 40 CFR 60.42c or 40 CFR 60.43c shall calculate the annual capacity factor individually for each fuel combusted. The annual capacity factor is determined on a 12-month rolling average basis with a new annual capacity factor calculated at the end of the calendar month.
  - (i) All records required under this section shall be maintained by the owner or operator of the affected facility for a period of 5 (five) years following the date of such record. **Note:** As long as the auxiliary boiler operates only during startup and shutdown and for periodic maintenance testing, C.17(d) and (e) requirements under this specific condition are not applicable. See specific condition C.3.

**C.18.** The owner or operator subject to the provisions of 40 CFR 60 shall furnish the Administrator written notification as follows:

(4) A notification of any physical or operational change to an existing facility which may increase the emission rate of any air pollutant to which a standard applies, unless that change is specifically exempted under an applicable subpart or in 40 CFR 60.14(e). This notice shall be postmarked 60 days or as soon as practicable before the change is commenced and shall include information describing the precise nature of the change, present and proposed emission control systems, productive capacity of the facility before and after the change, and the expected completion date of the change. The Administrator may request additional relevant information subsequent to this notice.

[40 CFR 60.7(a)(4)]

C.19. The owner or operator subject to the provisions of 40 CFR 60 shall maintain records of the occurrence and duration of any startup, shutdown, or malfunction in the operation of an affected facility; any malfunction of the air pollution control equipment; or, any periods during which a continuous monitoring system or monitoring device is inoperative.

[40 CFR 60.7(b)]

C.20. (1) Notwithstanding the frequency of reporting requirements specified in 40 CFR 60.7(c), an owner or operator who is required by an applicable subpart to submit excess emissions and monitoring systems performance reports (and summary reports) on a quarterly (or more frequent) basis may reduce the frequency of reporting for that standard to semiannual if the following conditions are met:

- (i) For 1 full year (e.g., 4 quarterly or 12 monthly reporting periods) the affected facility's excess emissions and monitoring systems reports submitted to comply with a standard under this part continually demonstrate that the facility is in compliance with the applicable standard;
- (ii) The owner or operator continues to comply with all recordkeeping and monitoring requirements specified in 40 CFR 60, Subpart A, and the applicable standard; and
- (iii) The Administrator does not object to a reduced frequency of reporting for the affected facility, as provided in 40 CFR 60.7(e)(2).

(2) The frequency of reporting of excess emissions and monitoring systems performance (and summary) reports may be reduced only after the owner or operator notifies the Administrator in writing of his or her intention to make such a change and the Administrator does not object to the intended change. In deciding whether to approve a reduced frequency of reporting, the Administrator may review information concerning the source's entire previous performance history during the required recordkeeping period prior to the intended change, including performance test results, monitoring data, and evaluations of an owner or operator's conformance with operation and maintenance requirements. Such information may be used by the Administrator to make a judgment about the source's potential for noncompliance in the future. If the Administrator disapproves the owner or operator's request to reduce the frequency of reporting, the Administrator will notify the owner or operator in writing within 45 days after receiving notice of the owner or operator's intention. The notification from the Administrator to the owner or operator will specify the grounds on which the disapproval is based. In the absence of a notice of disapproval within 45 days, approval is automatically granted.

(3) As soon as monitoring data indicate that the affected facility is not in compliance with any emission limitation or operating parameter specified in the applicable standard, the frequency of reporting shall revert to the frequency specified in the applicable standard, and the owner or operator shall submit an excess emissions and monitoring systems performance report (and summary report, if required) at the next appropriate reporting period following the noncomplying event. After demonstrating compliance with the applicable standard for another full year, the owner or operator may again request approval from the Administrator to reduce the frequency of reporting for that standard as provided for in 40 CFR 60.7(e)(1) and (e)(2). **Note:** As long as the auxiliary boiler operates only during startup and shutdown and for periodic maintenance testing, requirements under this specific condition are not applicable. See specific condition C.3. [40 CFR 60.7(e)(1)]

**C.21.** The owner or operator subject to the provisions of 40 CFR 60 shall maintain a file of all measurements, including continuous monitoring system, monitoring device, and performance testing measurements; all continuous monitoring system performance evaluations; all continuous monitoring system or monitoring device calibration checks; adjustments and maintenance performed on these systems or devices; and, all other information required by 40 CFR 60 recorded in a permanent form suitable for inspection. The file shall be retained for at least 5 (five) years following the date of such measurements, maintenance, reports, and records. [40 CFR 60.7(f); Rule 62-213.440(1)(b)2.b., F.A.C.]

**C.22.** This emissions unit is also subject to the conditions contained in **Subsection E. Common Conditions.**

**Subsection D. This section addresses the following emissions unit.**

**E.U. ID**

| <b><u>No.</u></b> | <b><u>Brief Description</u></b> |
|-------------------|---------------------------------|
| -009              | Diesel Generator                |

This unit is used to supply power to Emissions Units -003 to -006 during power outages. The nameplate rating is 0.718 MW. Emissions are uncontrolled.

**The following specific conditions apply to the emissions unit listed above:**

**Essential Potential to Emit (PTE) Parameters**

**D.1. Hours of Operation.** The diesel generator shall operate only for emergency power generation or periodic operational testing.

[Rule 62-210.200(PTE), F.A.C.; PSD-FL-146, revised 7/19/93]

**Emission Limitations and Standards**

{Permitting note: Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

**D.2. Nitrogen Oxides.** NOx emissions for the diesel generator shall not exceed 15.0 grams/hp-hr.

[PSD-FL-146, revised 7/19/93]

**D.3. Sulfur Dioxide.** Sulfur dioxide emissions limitations for the diesel generator are established by limiting the light distillate fuel oil's average sulfur content to 0.3%, by weight, during any consecutive 12-month period. The 12-month average sulfur content shall be calculated as a weighted average based upon the sulfur content of the oil and the amount burned on a daily basis.

[Rule 62-213.440, F.A.C., applicant agreement with EPA on March 3, 1998, and PSD-FL-146, revised 7/19/93]

**Test Methods and Procedures**

{Permitting note: Table 2-1, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

**D.4.** Distillate fuel oil fired in the emergency diesel generator shall meet the specifications for fuel oil numbers 1 or 2, as defined by the American Society for Testing and Materials in ASTM D 396-78 (or the latest edition). "Standard Specifications for Fuel Oils." Compliance with these specifications shall be verified with a fuel analysis provided by the vendor upon each fuel delivery.

[Requested by the applicant in electronic memorandum dated 09/18/97]



**Subsection E. Common Conditions.**

**E.U. ID**

| <b><u>No.</u></b> | <b><u>Brief Description</u></b>                               |
|-------------------|---|
| -001              | Fossil Fuel Fired Steam Generator #1                          |
| -002              | Fossil Fuel Fired Steam Generator #2                          |
| -003              | Combustion Turbine with Heat Recovery Steam Generator (CT 3A) |
| -004              | Combustion Turbine with Heat Recovery Steam Generator (CT 3B) |
| -005              | Combustion Turbine with Heat Recovery Steam Generator (CT 4A) |
| -006              | Combustion Turbine with Heat Recovery Steam Generator (CT 4B) |
| -007              | Auxiliary Boiler  |

**The following conditions apply to the emissions units listed above:**

**Test Methods and Procedures**

**E.1. Required Number of Test Runs.** For mass emission limitations, a compliance test shall consist of three complete and separate determinations of the total air pollutant emission rate through the test section of the stack or duct and three complete and separate determinations of any applicable process variables corresponding to the three distinct time periods during which the stack emission rate was measured provided, however, that three complete and separate determinations shall not be required if the process variables are not subject to variation during a compliance test, or if three determinations are not necessary in order to calculate the unit's emission rate. The three required test runs shall be completed within one consecutive five day period. In the event that a sample is lost or one of the three runs must be discontinued because of circumstances beyond the control of the owner or operator, and a valid third run cannot be obtained within the five day period allowed for the test, the Secretary or his or her designee may accept the results of the two complete runs as proof of compliance, provided that the arithmetic mean of the results of the two complete runs is at least 20 percent below the allowable emission limiting standards.

[Rule 62-297.310(1), F.A.C.]

**E.2. Applicable Test Procedures.**

**(a) Required Sampling Time.**

1. Unless otherwise specified in the applicable rule, the required sampling time for each test run shall be no less than one hour and no greater than four hours, and the sampling time at each sampling point shall be of equal intervals of at least two minutes.

2. Opacity Compliance Tests. When either EPA Method 9 or DEP Method 9 is specified as the applicable opacity test method, the required minimum period of observation for a compliance test shall be sixty (60) minutes for emissions units which emit or have the potential to emit 100 tons per year or more of particulate matter, and thirty (30) minutes for emissions units which have potential emissions less than 100 tons per year of particulate matter and are not subject to a multiple-valued opacity standard. The opacity test observation period shall include the period during which the highest opacity emissions can reasonably be expected to occur. Exceptions to these requirements are as follows:

- a. For batch, cyclical processes, or other operations which are normally completed within less than the minimum observation period and do not recur within that time, the period of observation shall be equal to the duration of the batch cycle or operation completion time.
  - b. The observation period for special opacity tests that are conducted to provide data to establish a surrogate standard pursuant to Rule 62-297.310(5)(k), F.A.C., Waiver of Compliance Test Requirements, shall be established as necessary to properly establish the relationship between a proposed surrogate standard and an existing mass emission limiting standard.
  - c. The minimum observation period for opacity tests conducted by employees or agents of the Department to verify the day-to-day continuing compliance of a unit or activity with an applicable opacity standard shall be twelve minutes.
- (b) Minimum Sample Volume. Unless otherwise specified in the applicable rule, the minimum sample volume per run shall be 25 dry standard cubic feet.
- (c) Required Flow Rate Range. For EPA Method 5 particulate sampling, acid mist/sulfur dioxide, and fluoride sampling which uses Greenburg Smith type impingers, the sampling nozzle and sampling time shall be selected such that the average sampling rate will be between 0.5 and 1.0 actual cubic feet per minute, and the required minimum sampling volume will be obtained.
- (d) Calibration of Sampling Equipment. Calibration of the sampling train equipment shall be conducted in accordance with the schedule shown in Table 297.310-1.

TABLE 297.310-1  
 CALIBRATION SCHEDULE

| ITEM                            | MINIMUM CALIBRATION FREQUENCY  | REFERENCE INSTRUMENT  | TOLERANCE  |
|---------------------------------|--|---|--|
| Liquid in glass thermometer     | Annually   | ASTM Hg in glass ref. thermometer or equivalent, or thermometric points                   | +/-2%  |
| Bimetallic thermometer          | Quarterly  | Calib. liq. in glass thermometer  | 5 degrees F  |
| Thermocouple                    | Annually   | ASTM Hg in glass ref. thermometer, NBS calibrated reference and potentiometer             | 5 degrees F  |
| Barometer                       | Monthly  | Hg barometer or NOAA station  | +/-1% scale  |
| Pitot Tube                      | When required or when damaged  | By construction or measurements in wind tunnel D greater than 16" and standard pitot tube | See EPA Method 2, Fig. 2-2 & 2-3   |
| Probe Nozzles                   | Before each test or when nicked, dented, or corroded   | Micrometer  | +/-0.001" mean of at least three readings<br>Max. deviation between readings .004" |
| Dry Gas Meter and Orifice Meter | 1. Full Scale:<br>When received,<br>When 5% change observed,<br>Annually<br>2. One Point:<br>Semiannually<br>3. Check after each test series | Spirometer or calibrated wet test or dry gas test meter                                   | 2%   |
|                                 |  | Comparison check  | 5%   |

(e) Allowed Modification to EPA Method 5. When EPA Method 5 is required, the following modification is allowed: the heated filter may be separated from the impingers by a flexible tube. [Rule 62-297.310(4), F.A.C.]

**E.3. Determination of Process Variables.**

(a) Required Equipment. The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.

(b) Accuracy of Equipment. Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value.

[Rule 62-297.310(5), F.A.C.]

**E.4.** The permittee shall comply with the requirements contained in APPENDIX SS-1, Stack Sampling Facilities, attached to this permit.

[Rule 62-297.310(6), F.A.C.]

**E.5. Frequency of Compliance Tests.** The following provisions apply only to those emissions units that are subject to an emissions limiting standard for which compliance testing is required.

(a) General Compliance Testing.

3. The owner or operator of an emissions unit that is subject to any emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining a renewed operation permit. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy the requirements of this provision. In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of emission compliance test results for any emissions unit that, during the year prior to renewal:

- a. Did not operate; or
- b. In the case of a fuel burning emissions unit, burned liquid and/or solid fuel for a total of no more than 400 hours.

4. During each federal fiscal year (October 1 -- September 30), unless otherwise specified by rule, order, or permit, the owner or operator of each emissions unit shall have a formal compliance test conducted for:

- a. Visible emissions, if there is an applicable standard;
- b. Each of the following pollutants, if there is an applicable standard, and if the emissions unit emits or has the potential to emit: 5 tons per year or more of lead or lead compounds measured as elemental lead; 30 tons per year or more of acrylonitrile; or 100 tons per year or more of any other regulated air pollutant; and
- c. Each NESHAP pollutant, if there is an applicable emission standard.

5. An annual compliance test for particulate matter emissions shall not be required for any fuel burning emissions unit that, in a federal fiscal year, does not burn liquid and/or solid fuel, other than during startup, for a total of more than 400 hours.

9. The owner or operator shall notify the Department, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator.

10. An annual compliance test conducted for visible emissions shall not be required for units exempted from permitting at Rule 62-210.300(3)(a), F.A.C., or units permitted under the General Permit provisions at Rule 62-210.300(4), F.A.C.

(b) Special Compliance Tests. When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it may require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department.

(c) Waiver of Compliance Test Requirements. If the owner or operator of an emissions unit that is subject to a compliance test requirement demonstrates to the Department, pursuant to the procedure established in Rule 62-297.620, F.A.C., that the compliance of the emissions unit with an applicable weight emission limiting standard can be adequately determined by means other than the designated test procedure, such as specifying a surrogate standard of no visible emissions for particulate matter sources equipped with a bag house or specifying a fuel analysis for sulfur dioxide emissions, the Department shall waive the compliance test requirements for such emissions units and order that the alternate means of determining compliance be used, provided, however, the provisions of Rule 62-297.310(7)(b), F.A.C., shall apply.  
[Rule 62-297.310(7), F.A.C.; SIP approved]

### **Recordkeeping and Reporting Requirements**

**E.6. Malfunction Reporting**. In the case of excess emissions resulting from malfunctions, each owner or operator shall notify the Department in accordance with Rule 62-4.130, F.A.C. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department.

[Rule 62-210.700(6), F.A.C.]

**E.7. Calculation of Emission Rate**. The indicated emission rate or concentration shall be the arithmetic average of the emission rate or concentration determined by each of the three separate test runs unless otherwise specified in a particular test method or applicable rule.

[Rule 62-297.310(3), F.A.C.]

**E.8. Test Reports.**

(a) The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Department on the results of each such test.

(b) The required test report shall be filed with the Department as soon as practical but no later than 45 days after the last sampling run of each test is completed.

(c) The test report shall provide sufficient detail on the emissions unit tested and the test procedures used to allow the Department to determine if the test was properly conducted and the test results properly computed. As a minimum, the test report, other than for an EPA or DEP Method 9 test, shall provide the following information:

1. The type, location, and designation of the emissions unit tested.
2. The facility at which the emissions unit is located.
3. The owner or operator of the emissions unit.
4. The normal type and amount of fuels used and materials processed, and the types and amounts of fuels used and material processed during each test run.
5. The means, raw data and computations used to determine the amount of fuels used and materials processed, if necessary to determine compliance with an applicable emission limiting standard.
6. The type of air pollution control devices installed on the emissions unit, their general condition, their normal operating parameters (pressure drops, total operating current and GPM scrubber water), and their operating parameters during each test run.
7. A sketch of the duct within 8 stack diameters upstream and 2 stack diameters downstream of the sampling ports, including the distance to any upstream and downstream bends or other flow disturbances.
8. The date, starting time and duration of each sampling run.
9. The test procedures used, including any alternative procedures authorized pursuant to Rule 62-297.620, F.A.C. Where optional procedures are authorized in this chapter, indicate which option was used.
10. The number of points sampled and configuration and location of the sampling plane.
11. For each sampling point for each run, the dry gas meter reading, velocity head, pressure drop across the stack, temperatures, average meter temperatures and sample time per point.
12. The type, manufacturer and configuration of the sampling equipment used.
13. Data related to the required calibration of the test equipment.
14. Data on the identification, processing and weights of all filters used.
15. Data on the types and amounts of any chemical solutions used.
16. Data on the amount of pollutant collected from each sampling probe, the filters, and the impingers, are reported separately for the compliance test.
17. The names of individuals who furnished the process variable data, conducted the test, analyzed the samples and prepared the report.
18. All measured and calculated data required to be determined by each applicable test procedure for each run.
19. The detailed calculations for one run that relate the collected data to the calculated emission rate.
20. The applicable emission standard, and the resulting maximum allowable emission rate for the emissions unit, plus the test result in the same form and unit of measure.

21. A certification that, to the knowledge of the owner or his authorized agent, all data submitted are true and correct. When a compliance test is conducted for the Department or its agent, the person who conducts the test shall provide the certification with respect to the test procedures used. The owner or his authorized agent shall certify that all data required and provided to the person conducting the test are true and correct to his knowledge.

[Rule 62-297.310(8), F.A.C.]

**Section IV. This section is the Acid Rain Part.**

**Operated by: Florida Power and Light Company**  
**ORIS code: 6043**

**Subsection A. This subsection addresses Acid Rain, Phase II.**

The emissions units listed below are regulated under Acid Rain Part, Phase II.

| <u>E.U. ID No.</u> | <u>EPA ID</u> | <u>Brief Description</u>                                      |
|--------------------|---------------|---|
| -001               | PMR1          | Fossil Fuel Fired Steam Generator #1                          |
| -002               | PMR2          | Fossil Fuel Fired Steam Generator #2                          |
| -003               | HRSG3A        | Combustion Turbine with Heat Recovery Steam Generator (CT 3A) |
| -004               | HRSG3B        | Combustion Turbine with Heat Recovery Steam Generator (CT 3B) |
| -005               | HRSG4A        | Combustion Turbine with Heat Recovery Steam Generator (CT 4A) |
| -006               | HRSG4B        | Combustion Turbine with Heat Recovery Steam Generator (CT 4B) |

1. The Phase II permit application submitted for this facility, as approved by the Department, is a part of this permit. The owners and operators of these Phase II acid rain units must comply with the standard requirements and special provisions set forth in the application listed below:

- a. DEP Form No. 62-210.900(1)(a), dated July 1, 1995.  
 [Chapter 62-213, F.A.C. and Rule 62-214.320, F.A.C.]

2. Sulfur dioxide (SO<sub>2</sub>) allowance allocations for each Acid Rain unit are as follows:

| <u>E.U. ID No.</u> | <u>EPA ID</u> | <u>Year</u>  | <u>2000</u> | <u>2001</u> | <u>2002</u> | <u>2003</u> |
|--------------------|---------------|--|-------------|-------------|-------------|-------------|
| -001               | PMR1          | SO <sub>2</sub> allowances, under Table 2 or 3 of 40 CFR Part 73 | 5044*       | 5044*       | 5044*       | 5044*       |
| -002               | PMR2          | SO <sub>2</sub> allowances, under Table 2 or 3 of 40 CFR Part 73 | 5982*       | 5982*       | 5982*       | 5982*       |



|      |        |  |       |       |       |       |
|------|--------|--|-------|-------|-------|-------|
| -003 | HRSG3A | SO2 allowances, under Table 2 or 3 of 40 CFR Part 73 | 1265* | 1265* | 1265* | 1265* |
| -004 | HRSG3B | SO2 allowances, under Table 2 or 3 of 40 CFR Part 73 | 1265* | 1265* | 1265* | 1265* |
| -005 | HRSG4A | SO2 allowances, under Table 2 or 3 of 40 CFR Part 73 | 1265* | 1265* | 1265* | 1265* |
| -006 | HRSG4B | SO2 allowances, under Table 2 or 3 of 40 CFR Part 73 | 1265* | 1265* | 1265* | 1265* |

\*The number of allowances held by an Acid Rain source in a unit account may differ from the number allocated by the USEPA under Table 2 or 3 of 40 CFR 73.

3. Emission Allowances. Emissions from sources subject to the Federal Acid Rain Program (Title IV) shall not exceed any allowances that the source lawfully holds under the Federal Acid Rain Program. Allowances shall not be used to demonstrate compliance with a non-Title IV applicable requirement of the Act.

1. No permit revision shall be required for increases in emissions that are authorized by allowances acquired pursuant to the Federal Acid Rain Program, provided that such increases do not require a permit revision pursuant to Rule 62-213.400(3), F.A.C.
2. No limit shall be placed on the number of allowances held by the source under the Federal Acid Rain Program.
3. Allowances shall be accounted for under the Federal Acid Rain Program.

[Rule 62-213.440(1)(c), F.A.C.]

4. Fast-Track Revisions of Acid Rain Parts. Those Acid Rain sources making a change described at Rule 62-214.370(4), F.A.C., may request such change as provided in Rule 62-213.413, Fast-Track Revisions of Acid Rain Parts.

[Rule 62-213.413, F.A.C.]

5. Comments, notes, and justifications: None.

**Appendix I-1. List of Insignificant Emissions Units and/or Activities.**

The facilities, emissions units, or pollutant-emitting activities listed in Rule 62-210.300(3)(a), F.A.C., Categorical Exemptions, are exempt from the permitting requirements of Chapters 62-210 and 62-4, F.A.C.; provided, however, that exempt emissions units shall be subject to any applicable emission limiting standards and the emissions from exempt emissions units or activities shall be considered in determining the potential emissions of the facility containing such emissions units. Emissions units and pollutant-emitting activities exempt from permitting under Rule 62-210.300(3)(a), F.A.C., shall not be exempt from the permitting requirements of Chapter 62-213, F.A.C., if they are contained within a Title V source; however, such emissions units and activities shall be considered insignificant for Title V purposes provided they also meet the criteria of Rule 62-213.430(6)(b), F.A.C. No emissions unit shall be entitled to an exemption from permitting under Rule 62.210.300(3)(a), F.A.C., if its emissions, in combination with the emissions of other units and activities at the facility, would cause the facility to emit or have the potential to emit any pollutant in such amount as to make the facility a Title V source.

The below listed emissions units and/or activities are considered insignificant pursuant to Rule 62-213.430(6), F.A.C.

|   | <u>Brief Description of Emissions Units and/or Activities</u>  |
|---|--|
| 1 | <b>Chemical Feed Skid</b> , consisting of:<br>Ammonia Feed Tanks Vent<br>Hydrazine Feed Tanks Vent<br>H. P. Phosphate Feed Tanks Vent<br>I. P. Phosphate Feed Tanks Vent   |
| 2 | <b>Fire Protection Equipment</b> with:<br>.75" Vents to Atmosphere<br>Diesel Engine Exhaust<br>2" Diesel Day Tank Vent<br><u>CT Lube Seal Trip. and Hydraulic Oil</u><br>3" Bearing Drain Enlargement Exhausters Vent to Atmosphere<br><b>Auxiliary Buildings H.V.A.C.</b><br>Vent/Exhaust System for,<br>Switchgear Rooms<br>Chemical Storage Room<br>Water Chemistry Lab<br>Fume Hoods |
| 3 | <b>Main Liquid Fuel</b><br>.75" Vents to Atmosphere<br>2" Liquid Fuel Drain Tank Vent (235 gallon)<br>8" Vent with Filter for Units 3 and 4 Liquid Fuel Storage Tank (2,000,000 gallon)  |
| 4 | <b>Auxiliary Steam, Chemical Feed, Chlorine and Gas Purging</b> , comprised of:<br>Ash Pit<br><u>Potable Water</u><br>Bleach Tank 2" Vent (2,000 gallons)  |

|          |  |
|----------|--|
|          | <p><u>Lube Oil</u><br/>                 Lube Oil Storage Tanks Vent<br/> <u>B.F.P. Lube Oil</u><br/>                 B.F.P. Lube Oil Reservoir Vent Fan 4"<br/>                 B.F.P. Lube Oil Batch Tank 3" Vent and Filter<br/>                 B.F.P. Lube Oil Conditioner Vent Fan 4"<br/> <u>Light Oil System</u><br/>                 Light Oil Tank 6" Vent (2,000 bbl)<br/>                 Water Draw-Off Sump<br/>                 Diesel Day Tank .75" Vent - (550 gallon)<br/>                 Chemical Feed Tank Vent<br/> <u>Turbine Gland Seal Steam and Drain</u><br/>                 Gland Steam Condenser Exhauster 6" Vent to Atmosphere<br/> <u>Fuel Oil at Burners</u><br/>                 1" Vents to Atmosphere<br/>                 Natural Gas<br/>                 2" Vent to Atmosphere<br/>                 6" Vent to Atmosphere<br/> <u>Ignition (LP) Gas</u><br/>                 1" Control Vent to Atmosphere<br/>                 L.P. Gas Tanks Relief Valve<br/> <u>Fuel Oil at Heaters</u><br/>                 1" Vents to Atmosphere<br/>                 M.C.C. Areas Exhaust Fans<br/>                 Lab Exhaust Hood<br/> <u>Turbine Generator Lube Oil</u><br/>                 Generator Loop Seal Tank Exhauster 4" Vent to Atmosphere<br/>                 Turbine Lube Oil Reservoir Vapor Extractor 6" Vent<br/>                 Turbine Generator Lube Oil Batch Tank 4" Vent with Filter<br/>                 Turbine Generator Lube Oil Conditioner Vapor Extractor 4" Vent<br/>                 1" Polishing Filter Vent<br/>                 1" Air Educator Vent<br/>                 Electrically Heated Equipment Used for Heat Treating, Tracing, Drying,<br/>                 Soaking, Case Hardening or Surface Conditioning</p> |
| <b>5</b> | <p><b>Gas Metering Area (for Units 1 and 2)</b><br/>                 Gas Oil Separator Tank 8" Exhaust Vent<br/>                 Gas Oil Separator Tank 1.5" Vent<br/>                 Relief Valve<br/>                 6" Blowdown Valve<br/>                 Gas Scrubber Relief Valve<br/>                 Condensate Tank with Filter</p>   |
| <b>6</b> | <p><b>Sand Blast Booth</b></p>   |
| <b>7</b> | <p><b>Evaporation of Non-Hazardous Boiler Chemical Cleaning Waste</b></p>  |

**Appendix U-1. List of Unregulated Emissions Units and/or Activities.**

Unregulated Emissions Units and/or Activities. An emissions unit which emits no “emissions-limited pollutant” and which is subject to no unit-specific work practice standard, though it may be subject to regulations applied on a facility-wide basis (e.g., unconfined emissions, odor, general opacity) or to regulations that require only that it be able to prove exemption from unit-specific emissions or work practice standards.

The below listed emissions units and/or activities are neither ‘regulated emissions units’ nor ‘insignificant emissions units’.

| <b><u>E.U. ID No.</u></b> | <b><u>Brief Description of Emissions Units and/or Activities</u></b> |
|---------------------------|--|
| -xxx                      | Diesel Generator (for Units -001 and -002)                           |
| -xxx                      | Facility-wide Fugitive Emissions for PM                              |
| -xxx                      | Facility-wide Fugitive Emissions for VOC's                           |

### Appendix H-1. Permit History/ID Number Changes

**Permit History (for tracking purposes):**

| <u>E.U. ID No</u> | <u>Description</u>                | <u>Permit No.</u> | <u>Issue Date</u> | <u>Expiration Date</u> | <u>Extended Date<sup>1,2</sup></u> | <u>Revised Date(s)</u>                    |
|-------------------|-----------------------------------|-------------------|-------------------|------------------------|------------------------------------|---|
| -001              | Fossil Fuel Fired Steam Generator | AC-73044          | 3/20/73           |                        |                                    |   |
|                   |                                   | AC43-4037         | 6/30/77           |                        |                                    |   |
|                   |                                   | AO43-170568       | 2/23/90           | 11/29/94               |                                    | 2/16/93                                   |
| -002              | Fossil Fuel Fired Steam Generator | AC-73045          | 3/20/73           |                        |                                    |   |
|                   |                                   | AC43-4038         | 6/30/77           |                        |                                    |   |
|                   |                                   | AO43-170567       | 2/20/90           | 11/29/94               |                                    | 2/16/93                                   |
| -003 to<br>-006   | Combustion Turbines with HRSGs    | PSD-FL-146        | 6/05/91           |                        |                                    | 7/19/93<br>9/16/94<br>9/06/96<br>10/14/97 |
|                   |                                   | 0850001-002-AC    |                   |                        |                                    | 9/06/96                                   |
|                   |                                   | 0850001-003-AC    |                   |                        |                                    | 9/06/96                                   |
|                   |                                   | 0850001-005-AC    |                   |                        |                                    | 7/20/99                                   |
|                   |                                   | PA89-27           | 2/20/91           |                        |                                    | 9/28/94                                   |
|                   |                                   | 0850001-004-AV    | 6/29/98           | 12/31/03               |                                    |   |
|                   |                                   |                   |                   |                        |                                    |   |
| -007              | Auxiliary Boiler                  | PSD-FL-146        | 6/05/91           |                        |                                    | 7/19/93<br>9/06/96                        |
|                   |                                   | PA89-27           | 2/20/91           |                        |                                    | 9/28/94                                   |
| -009              | Diesel Generator                  | PSD-FL-146        | 6/05/91           |                        |                                    | 7/19/93<br>9/06/96                        |
|                   |                                   | PA89-27           | 2/20/91           |                        |                                    | 9/28/94                                   |

**ID Number Changes (for tracking purposes):**

From: **Facility ID No.:** 50WPB430001; To: **Facility ID No.:** 0850001

Notes:

1 - AO permit(s) automatic extension(s) in Rule 62-210.300(2)(a)3.a., F.A.C., effective 03/21/96.

2 - AC permit(s) automatic extension(s) in Rule 62-213.420(1)(a)4., F.A.C., effective 03/20/96.

{Rule 62-213.420(1)(b)2., F.A.C., effective 03/20/96, allows Title V Sources to operate under existing valid permits}

**Table 1-1, Air Pollutant Standards and Terms**

Florida Power & Light Company  
Martin Plant

Permit No.: 0850001-007-AV  
Facility ID No.: 0850001

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

| E.U. ID No(s).               | Brief Description                   | Pollutant Name | Fuel(s) | Hours/Year   | Allowable Emissions |            |       | Equivalent Emissions*   |                         | Regulatory Citations    | See Permit Conditions |
|------------------------------|-------------------------------------|----------------|---------|--------------|---------------------|------------|-------|-------------------------|-------------------------|-------------------------|-----------------------|
|                              |                                     |                |         |              | Standard(s)         | lbs./hour  | TPY   | lbs./hour               | TPY                     |                         |                       |
| -001<br>-002                 | Fossil Fuel Fired Steam Generators  | PM             | Oil     | 8760         | 0.1 lb/MMBtu        |            |       | 865                     | 3788.7                  | 40 CFR 60.42            | A.5                   |
|                              |                                     |                | Gas     | 8760         | 0.1 lb/MMBtu        |            |       |                         |                         |                         |                       |
|                              |                                     | SO2            | Oil     | 8760         | 0.8 lb/MMBtu        |            |       | 6920                    | 30309                   | 40 CFR 60.43            | A.9                   |
|                              |                                     | NOx            | Oil     | 8760         | 0.3 lb/MMBtu        |            |       | 2595                    | 11366.1                 | 40 CFR 60.44            | A.10                  |
|                              |                                     | Gas            | 8760    | 0.2 lb/MMBtu |                     |            | 1808  | 7919.04                 |                         |                         |                       |
|                              |                                     | Opacity        | Oil     | 8760         | Not > 20%           |            |       |                         |                         |                         | A.8                   |
| -003<br>-004<br>-005<br>-006 | Combustion Turbines with HRSGs      | PM/PM10        | Oil     | 2000         |                     | 60.6       | 100   |                         |                         | Rule 62-212.410, F.A.C. | B.6                   |
|                              |                                     |                | Gas     | 8760         |                     | 18         |       |                         |                         |                         |                       |
|                              |                                     | SO2            | Oil     | 2000         | 0.5% sulfur         | 920        | 568   |                         |                         | 40 CFR 60.333           | B.6                   |
|                              |                                     |                | Gas     | 8760         |                     | 91.5       |       |                         |                         |                         |                       |
|                              |                                     | NOx            | Oil     | 2000         | 65 ppmvd @ 15% O2   | 461        | 3108  |                         |                         | 40 CFR 60.332           | B.6                   |
|                              |                                     |                | Gas     | 8760         | 25 ppmvd @ 15% O2   | 177        |       |                         |                         |                         |                       |
|                              |                                     | VOC            | Oil     | 2000         | 6 ppmvd             | 11         | 57    |                         |                         | Rule 62-212.410, F.A.C. | B.6                   |
|                              |                                     |                | Gas     | 8760         | 1.6 ppmvd           | 3          |       |                         |                         |                         |                       |
|                              |                                     | CO             | Oil     | 2000         | 33 ppmvd            | 105.8      | 871   |                         |                         | Rule 62-212.410, F.A.C. | B.6                   |
|                              |                                     |                | Gas     | 8760         | 30 ppmvd            | 94.3       |       |                         |                         |                         |                       |
|                              |                                     | PB             | Oil     | 2000         |                     | 0.015      | 0.015 |                         |                         | Rule 62-212.410, F.A.C. | B.6                   |
|                              |                                     |                | Gas     | 8760         |                     | Negligible |       |                         |                         |                         |                       |
|                              |                                     | SAM            | Oil     | 2000         |                     | 113        | 70    |                         |                         | Rule 62-212.410, F.A.C. | B.7                   |
|                              | Gas                                 | 8760           |         | 11.2         |                     |            |       |                         |                         |                         |                       |
| H114                         | Oil                                 | 2000           |         | 0.0052       | 0.34                |            |       | Rule 62-212.410, F.A.C. | B.7                     |                         |                       |
|                              | Gas                                 | 8760           |         | 0.021        |                     |            |       |                         |                         |                         |                       |
| FL                           | Oil                                 | 2000           |         | 0.055        | 0.055               |            |       | Rule 62-212.410, F.A.C. | B.7                     |                         |                       |
| H021                         | Oil                                 | 2000           |         | 0.004        | 0.004               |            |       | Rule 62-212.410, F.A.C. | B.7                     |                         |                       |
| Opacity                      | Oil                                 | 2000           |         | Not > 20%    |                     |            |       |                         | Rule 62-212.410, F.A.C. | B.8                     |                       |
|                              | Gas                                 | 8760           |         | Not > 10%    |                     |            |       |                         |                         |                         |                       |
| -007                         | Auxiliary Boiler                    | Opacity        | Oil     | 8760         | Not > 20%           |            |       |                         |                         | 40 CFR 60.43c           | C.5                   |
|                              |                                     | NOx            | Gas/Oil | 8760         | 0.3 lb/MMBtu        |            |       | 4.89                    | 21.37                   | Rule 62-212.410, F.A.C. | C.10                  |
|                              |                                     | SO2            | Gas/Oil | 8760         | 0.3% Sulfur in Oil  |            |       |                         |                         | Rule 62-212.410, F.A.C. | C.8                   |
| -009                         | Diesel Generator (for -003 to -006) | NOx            | Oil     | 400          | 15 gm./hp-hr.       |            |       |                         |                         | Rule 62-212.410, F.A.C. | D.2                   |
|                              |                                     | SO2            | Oil     | 400          | 0.3% Sulfur in Oil  |            |       |                         |                         | Rule 62-212.410, F.A.C. | D.3                   |

\*The "Equivalent Emissions" listed are for informational purposes only.

**Table 2-1. Compliance Requirements**

| Florida Power & Light Company<br>Martin Plant   |         |  | Permit No.: 0850001-007-AV<br>Facility ID No.: 0850001 |                           |                           |                                  |       |                          |
|---|---------|--|--|---------------------------|---------------------------|----------------------------------|-------|--------------------------|
| This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit. |         |  |  |                           |                           |                                  |       |                          |
| E.U. ID Nos.  |         | Brief Description  |  | Testing Time<br>Frequency | Frequency Base<br>Date ** | Min. Compliance Test<br>Duration | CMS * | See Permit<br>Conditions |
| -001  |         | Fossil Fuel Fired Steam Generator  |  |                           |                           |                                  |       |                          |
| -002  |         | Fossil Fuel Fired Steam Generator  |  |                           |                           |                                  |       |                          |
| Pollutant Name<br>or parameter  | Fuel(s) | Compliance Method  |  | Testing Time<br>Frequency | Frequency Base<br>Date ** | Min. Compliance Test<br>Duration | CMS * | See Permit<br>Conditions |
|   | VE      | Oil  | DEP Method 9   |                           |                           |                                  |       |                          |
| PM  | Oil     | EPA Method 5   |  | Annual                    | 1-Oct                     | 3 Hours                          |       | A.18                     |
|   | Gas     | EPA Method 5   |  | Annual                    | 1-Oct                     | 3 Hours                          |       | A.18                     |
| SO2   | Oil     | EPA Method 6C  |  | Annual                    | 1-Oct                     |                                  | Yes   | A.18                     |
|   | Gas     | EPA Method 6C  |  | Annual                    | 1-Oct                     |                                  | Yes   | A.18                     |
| NOx   | Oil     | EPA Method 7E  |  | Annual                    | 1-Oct                     |                                  | Yes   | A.18                     |
|   | Gas     | EPA Method 7E  |  | Annual                    | 1-Oct                     |                                  | Yes   | A.18                     |
| CO2 (Diluent Gas)   |         |  |  |                           |                           |                                  | Yes   | A.23                     |
| Volumetric Flow   |         |  |  |                           |                           |                                  | Yes   | A.23                     |
| Opacity   |         |  |  |                           |                           |                                  | Yes   | A.23                     |
| E.U. ID Nos.  |         | Brief Description  |  | Testing Time<br>Frequency | Frequency Base<br>Date ** | Min. Compliance Test<br>Duration | CMS * | See Permit<br>Conditions |
| -003  |         | Combustion Turbine with HRSG   |  |                           |                           |                                  |       |                          |
| -004  |         | Combustion Turbine with HRSG   |  |                           |                           |                                  |       |                          |
| -005  |         | Combustion Turbine with HRSG   |  |                           |                           |                                  |       |                          |
| -006  |         | Combustion Turbine with HRSG   |  |                           |                           |                                  |       |                          |
| Pollutant Name<br>or Parameter  | Fuel(s) | Compliance Method  |  | Testing Time<br>Frequency | Frequency Base<br>Date ** | Min. Compliance Test<br>Duration | CMS * | See Permit<br>Conditions |
|   | VE      | Oil  | DEP Method 9   |                           |                           |                                  |       |                          |
|   | Gas     | DEP Method 9   |  | Annual                    | 1-Oct                     | 1 Hour                           |       | B.27                     |
| PM/PM10   | Oil     | EPA Method 5 or 17   |  | Annual                    | 1-Oct                     | 3 Hours                          |       | B.27                     |
| SO2<br>(Sulfur Content of Fuel)   | Oil     | ASTM D 2880-96   |  | Daily                     |                           |                                  |       | B.24                     |
|   | Gas     | ASTM D 1072-90(94)E-1<br>or D 3031--81(86) or<br>D 4084-94 or<br>D 3246-92 |  | Annual                    | 1-Oct                     |                                  |       | B.24                     |
| NOx   | Oil     | EPA Method 20  |  | Annual                    | 1-Oct                     |                                  | Yes   | B.27                     |
|   | Gas     | EPA Method 20  |  | Annual                    | 1-Oct                     |                                  | Yes   | B.27                     |
| CO  | Oil     | EPA Method 10  |  | Annual                    | 1-Oct                     |                                  |       | B.27                     |
|   | Gas     | EPA Method 10  |  | Annual                    | 1-Oct                     |                                  |       | B.27                     |
| CO2   |         |  |  |                           |                           |                                  | Yes   |                          |

|   |         |                                       |                 |  |                                     |      |                             |
|---|---------|---------------------------------------|-----------------|--|-------------------------------------|------|-----------------------------|
| Florida Power & Light Company<br>Martin Plant   |         |                                       |                 | Permit No.: 0850001-007-AV<br>Facility ID No.: 0850001 |                                     |      |                             |
| E.U. ID No.<br>-007   |         | Brief Description<br>Auxiliary Boiler |                 |  |                                     |      |                             |
| Pollutant Name<br>or Parameter  | Fuel(s) | Compliance<br>Method                  | Testing<br>Time | Frequency<br>Base<br>Date **                           | Min. Compliance<br>Test<br>Duration | CMS* | See<br>Permit<br>Conditions |
|   |         |                                       | Frequency       |  |                                     |      |                             |
| VE  | Oil     | DEP Method 9                          | Annual          | 1-Oct  | 1 Hour                              |      | C.13                        |
| SO2   | Oil     | ASTM D 2880-96                        | Daily           |  |                                     |      | C.11                        |
|   | Gas     | ASTM D 1072-90(94)E-1                 | Annual          | 1-Oct  |                                     |      |                             |
| E.U. ID No.<br>-009   |         | Brief Description<br>Diesel Generator |                 |  |                                     |      |                             |
| Pollutant Name<br>or Parameter  | Fuel(s) | Compliance<br>Method                  | Testing<br>Time | Frequency<br>Base<br>Date **                           | Min. Compliance<br>Test<br>Duration | CMS* | See<br>Permit<br>Conditions |
|   |         |                                       | Frequency       |  |                                     |      |                             |
| SO2   | Oil     | Verification by vendor receipts       | On delivery     |  |                                     |      | D.4                         |
| <b>Notes:</b><br>*CMS [=] Continuous Monitoring System<br>**Frequency base date established for planning purposes only; see Rule 62-297.310, F.A.C. |         |                                       |                 |  |                                     |      |                             |



## APPENDIX TV-3, TITLE V CONDITIONS (version dated 04/30/99)

[Note: This attachment includes "canned conditions" developed from the "Title V Core List."]

{Permitting note: APPENDIX TV-3, TITLE V CONDITIONS, is distributed to the permittee only. Other persons requesting copies of these conditions shall be provided one copy when requested or otherwise appropriate.}

### Chapter 62-4, F.A.C.

1. **Not federally enforceable. General Prohibition.** Any stationary installation which will reasonably be expected to be a source of pollution shall not be operated, maintained, or modified without the appropriate and valid permits issued by the Department, unless the source is exempted by Department rule. The Department may issue a permit only after it receives reasonable assurance that the installation will not cause pollution in violation of any of the provisions of Chapter 403, F.S., or the rules promulgated thereunder. A permitted installation may only be operated, maintained, constructed, expanded or modified in a manner that is consistent with the terms of the permit.

[Rule 62-4.030, Florida Administrative Code (F.A.C.); Section 403.087, Florida Statute (F.S.)]

### 2. **Not federally enforceable. Procedure to Obtain Permits: Application.**

- (1) Any person desiring to obtain a permit from the Department shall apply on forms prescribed by the Department and shall submit such additional information as the Department by law may require.
- (2) All applications and supporting documents shall be filed in quadruplicate with the Department.
- (3) To ensure protection of public health, safety, and welfare, any construction, modification, or operation of an installation which may be a source of pollution shall be in accordance with sound professional engineering practices pursuant to Chapter 471, F.S. All applications for a Department permit shall be certified by a professional engineer registered in the State of Florida except when the application is for renewal of an air pollution operation permit at a minor facility as defined in Rule 62-210.200, F.A.C., or where professional engineering is not required by Chapter 471, F.S. Where required by Chapter 471 or 492, F.S., applicable portions of permit applications and supporting documents which are submitted to the Department for public record shall be signed and sealed by the professional(s) who prepared or approved them.
- (4) Processing fees for air construction permits shall be in accordance with Rule 62-4.050(4), F.A.C.
- (5)(a) To be considered by the Department, each application must be accompanied by the proper processing fee. The fee shall be paid by check, payable to the Department of Environmental Protection. The fee is non-refundable except as provided in Section 120.60, F.S., and in this section.
  - (c) Upon receipt of the proper application fee, the permit processing time requirements of Sections 120.60(2) and 403.0876, F.S., shall begin.
  - (d) If the applicant does not submit the required fee within ten days of receipt of written notification, the Department shall either return the unprocessed application or arrange with the applicant for the pick up of the application.
  - (e) If an applicant submits an application fee in excess of the required fee, the permit processing time requirements of Sections 120.60(2) and 403.0876, F.S., shall begin upon receipt, and the Department shall refund to the applicant the amount received in excess of the required fee.
- (6) Any substantial modification to a complete application shall require an additional processing fee determined pursuant to the schedule set forth in Rule 62-4.050, F.A.C., and shall restart the time requirements of Sections 120.60 and 403.0876, F.S. For purposes of this Subsection, the term "substantial modification" shall mean a modification which is reasonably expected to lead to substantially different environmental impacts which require a detailed review.
- (7) Modifications to existing permits proposed by the permittee which require substantial changes in the existing permit or require substantial evaluation by the Department of potential impacts of the proposed modifications shall require the same fee as a new application.

[Rule 62-4.050, F.A.C.]

3. **Standards for Issuing or Denying Permits.** Except as provided at Rule 62-213.460, F.A.C., the issuance of a permit does not relieve any person from complying with the requirements of Chapter 403, F.S., or Department rules.

[Rule 62-4.070(7), F.A.C.]

4. Modification of Permit Conditions.

(1) For good cause and after notice and an administrative hearing, if requested, the Department may require the permittee to conform to new or additional conditions. The Department shall allow the permittee a reasonable time to conform to the new or additional conditions and on application of the permittee the Department may grant additional time. For the purpose of this section, good cause shall include, but not be limited to, any of the following: (also, see Condition No. 38)

- (a) A showing that an improvement in effluent or emission quality or quantity can be accomplished because of technological advances without unreasonable hardship.
- (b) A showing that a higher degree of treatment is necessary to effect the intent and purpose of Chapter 403, F.S.
- (c) A showing of any change in the environment or surrounding conditions that requires a modification to conform to applicable air or water quality standards.
- (e) Adoption or revision of Florida Statutes, rules, or standards which require the modification of a permit condition for compliance.

(2) A permittee may request a modification of a permit by applying to the Department.

(3) A permittee may request that a permit be extended as a modification of the permit. Such a request must be submitted to the Department in writing before the expiration of the permit. Upon timely submittal of a request for extension, unless the permit automatically expires by statute or rule, the permit will remain in effect until final agency action is taken on the request. For construction permits, an extension shall be granted if the applicant can demonstrate reasonable assurances that, upon completion, the extended permit will comply with the standards and conditions required by applicable regulation. For all other permits, an extension shall be granted if the applicant can demonstrate reasonable assurances that the extended permit will comply with the standards and conditions applicable to the original permit. A permit for which the permit application fee was prorated in accordance with Rule 62-4.050(4)(1), F.A.C., shall not be extended. In no event shall a permit be extended or remain in effect longer than the time limits established by statute or rule.

[Rule 62-4.080, F.A.C.]

5. Renewals. Prior to one hundred eighty (180) days before the expiration of a permit issued pursuant to Chapter 62-213, F.A.C., the permittee shall apply for a renewal of a permit using forms incorporated by reference in the specific rule chapter for that kind of permit. A renewal application shall be timely and sufficient. If the application is submitted prior to 180 days before expiration of the permit, it will be considered timely and sufficient. If the renewal application is submitted at a later date, it will not be considered timely and sufficient unless it is submitted and made complete prior to the expiration of the operation permit. When the application for renewal is timely and sufficient, the existing permit shall remain in effect until the renewal application has been finally acted upon by the Department or, if there is court review of the Department's final agency action, until a later date is required by Section 120.60, F.S., provided that, for renewal of a permit issued pursuant to Chapter 62-213, F.A.C., the applicant complies with the requirements of Rules 62-213.420(1)(b)3. and 4., F.A.C.

[Rule 62-4.090(1), F.A.C.]

6. Suspension and Revocation.

(1) Permits shall be effective until suspended, revoked, surrendered, or expired and shall be subject to the provisions of Chapter 403, F.S., and rules of the Department.

(2) Failure to comply with pollution control laws and rules shall be grounds for suspension or revocation.

(3) A permit issued pursuant to Chapter 62-4, F.A.C., shall not become a vested property right in the permittee. The Department may revoke any permit issued by it if it finds that the permit holder or the permit holder's agent:

- (a) Submitted false or inaccurate information in application or operational reports.
- (b) Has violated law, Department orders, rules or permit conditions.
- (c) Has failed to submit operational reports or other information required by Department rules.
- (d) Has refused lawful inspection under Section 403.091, F.S.

[Rule 62-4.100, F.A.C.]

7. Not federally enforceable. Financial Responsibility. The Department may require an applicant to submit proof of financial responsibility and may require the applicant to post an appropriate bond to guarantee compliance with the law and Department rules.

[Rule 62-4.110, F.A.C.]

8. Transfer of Permits.

(1) Within 30 days after the sale or legal transfer of a permitted facility, an "Application for Transfer of Permit" (DEP Form 62-1.201(1)) must be submitted to the Department. This form must be completed with the notarized signatures of both the permittee and the proposed new permittee.

(2) The Department shall approve the transfer of a permit unless it determines that the proposed new permittee cannot provide reasonable assurances that conditions of the permit will be met. The determination shall be limited solely to the ability of the new permittee to comply with the conditions of the existing permit, and it shall not concern the adequacy of these permit conditions. If the Department proposes to deny the transfer, it shall provide both the permittee and the proposed new permittee a written objection to such transfer together with notice of a right to request a Chapter 120, F.S., proceeding on such determination.

(3) Within 30 days of receiving a properly completed Application for Transfer of Permit form, the Department shall issue a final determination. The Department may toll the time for making a determination on the transfer by notifying both the permittee and the proposed new permittee that additional information is required to adequately review the transfer request. Such notification shall be served within 30 days of receipt of an Application for Transfer of Permit form, completed pursuant to Rule 62-4.120(1), F.A.C. If the Department fails to take action to approve or deny the transfer within 30 days of receipt of the completed Application for Transfer of Permit form, or within 30 days of receipt of the last item of timely requested additional information, the transfer shall be deemed approved.

(4) The permittee is encouraged to apply for a permit transfer prior to the sale or legal transfer of a permitted facility. However, the transfer shall not be effective prior to the sale or legal transfer.

(5) Until this transfer is approved by the Department, the permittee and any other person constructing, operating, or maintaining the permitted facility shall be liable for compliance with the terms of the permit. The permittee transferring the permit shall remain liable for corrective actions that may be required as a result of any violations occurring prior to the sale or legal transfer of the facility.

[Rule 62-4.120, F.A.C.]

9. Plant Operation-Problems. If the permittee is temporarily unable to comply with any of the conditions of the permit due to breakdown of equipment or destruction by hazard of fire, wind or by other cause, the permittee shall immediately notify the Department. Notification shall include pertinent information as to the cause of the problem, and what steps are being taken to correct the problem and to prevent its recurrence, and where applicable, the owner's intent toward reconstruction of destroyed facilities. Such notification does not release the permittee from any liability for failure to comply with Department rules. (also, see Condition No. 10)

[Rule 62-4.130, F.A.C.]

10. For purposes of notification to the Department pursuant to Condition No. 9, Condition No. 12(8), and Rule 62-4.130, F.A.C., Plant Operation-Problems, "immediately" shall mean the same day, if during a workday (i.e., 8:00 a.m. - 5:00 p.m.), or the first business day after the incident, excluding weekends and holidays; and, for purposes of 40 CFR 70.6(a)(3)(iii)(B), "prompt" shall have the same meaning as "immediately". [also, see Conditions Nos. 9 and 12(8)]

[40 CFR 70.6(a)(3)(iii)(B)]

11. **Not federally enforceable.** Review. Failure to request a hearing within 14 days of receipt of notice of proposed or final agency action on a permit application or as otherwise required in Chapter 62-103, F.A.C., shall be deemed a waiver of the right to an administrative hearing.

[Rule 62-4.150, F.A.C.]

12. Permit Conditions. All permits issued by the Department shall include the following general conditions:

(1) The terms, conditions, requirements, limitations and restrictions set forth in this permit, are "permit conditions" and are binding and enforceable pursuant to Sections 403.141, 403.727, or 403.859 through 403.861, F.S. The permittee is placed on notice that the Department will review this permit periodically and may initiate enforcement action for any violation of these conditions.

(2) This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviation from the approved drawings, exhibits, specifications, or conditions of this permit may constitute grounds for revocation and enforcement action by the Department.

(3) As provided in subsections 403.087(6) and 403.722(5), F.S., the issuance of this permit does not convey any vested rights or any exclusive privileges. Neither does it authorize any injury to public or private property or any invasion of personal rights, nor any infringement of federal, state, or local laws or regulations. This permit is not a waiver of or approval of any other Department permit that may be required for other aspects of the total project which are not addressed in this permit.

- (4) This permit conveys no title to land or water, does not constitute State recognition or acknowledgment of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the State. Only the Trustees of the Internal Improvement Trust Fund may express State opinion as to title.
- (5) This permit does not relieve the permittee from liability for harm or injury to human health or welfare, animal, or plant life, or property caused by the construction or operation of this permitted source, or from penalties therefore; nor does it allow the permittee to cause pollution in contravention of F.S. and Department rules, unless specifically authorized by an order from the Department.
- (6) The permittee shall properly operate and maintain the facility and systems of treatment and control (and related appurtenances) that are installed and used by the permittee to achieve compliance with the conditions of this permit, as required by Department rules. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to achieve compliance with the conditions of the permit and when required by Department rules.
- (7) The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, upon presentation of credentials or other documents as may be required by law and at reasonable times, access to the premises where the permitted activity is located or conducted to:
- (a) Have access to and copy any records that must be kept under conditions of the permit;
  - (b) Inspect the facility, equipment, practices, or operations regulated or required under this permit; and,
  - (c) Sample or monitor any substances or parameters at any location reasonable necessary to assure compliance with this permit or Department rules. Reasonable time may depend on the nature of the concern being investigated.
- (8) If, for any reason, the permittee does not comply with or will be unable to comply with any condition or limitation specified in this permit, the permittee shall immediately provide the Department with the following information: (also, see Condition No. 10)
- (a) A description of and cause of noncompliance; and,
  - (b) The period of noncompliance, including dates and times; or, if not corrected, the anticipated time the noncompliance is expected to continue, and steps being taken to reduce, eliminate, and prevent recurrence of the noncompliance. The permittee shall be responsible for any and all damages which may result and may be subject to enforcement action by the Department for penalties or for revocation of this permit.
- (9) In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the F.S. or Department rules, except where such use is prescribed by Sections 403.111 and 403.73, F.S. Such evidence shall only be used to the extent it is consistent with the Florida Rules of Civil Procedure and appropriate evidentiary rules.
- (10) The permittee agrees to comply with changes in Department rules and F.S. after a reasonable time for compliance; provided, however, the permittee does not waive any other rights granted by F.S. or Department rules.
- (11) This permit is transferable only upon Department approval in accordance with Rule 62-4.120, F.A.C., as applicable. The permittee shall be liable for any non-compliance of the permitted activity until the transfer is approved by the Department.
- (12) This permit or a copy thereof shall be kept at the work site of the permitted activity.
- (14) The permittee shall comply with the following:
- (a) Upon request, the permittee shall furnish all records and plans required under Department rules. During enforcement actions, the retention period for all records will be extended automatically unless otherwise stipulated by the Department.
  - (b) The permittee shall hold at the facility or other location designated by this permit records of all monitoring information (including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation) required by the permit, copies of all reports required by this permit, and records of all data used to complete the application for this permit. These materials shall be retained at least five (5) years from the date of the sample, measurement, report, or application unless otherwise specified by Department rule.
  - (c) Records of monitoring information shall include:
    - 1. the date, exact place, and time of sampling or measurements;
    - 2. the person responsible for performing the sampling or measurements;
    - 3. the dates analyses were performed;
    - 4. the person responsible for performing the analyses;
    - 5. the analytical techniques or methods used; and,
    - 6. the results of such analyses.
- (15) When requested by the Department, the permittee shall within a reasonable time furnish any information required by law which is needed to determine compliance with the permit. If the permittee becomes aware the relevant facts were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be corrected promptly.
- [Rules 62-4.160 and 62-213.440(1)(b), F.A.C.]

13. Construction Permits.

(1) No person shall construct any installation or facility which will reasonably be expected to be a source of air or water pollution without first applying for and receiving a construction permit from the Department unless exempted by statute or Department rule. In addition to the requirements of Chapter 62-4, F.A.C., applicants for a Department Construction Permit shall submit the following as applicable:

- (a) A completed application on forms furnished by the Department.
- (b) An engineering report covering:
  1. plant description and operations.
  2. types and quantities of all waste material to be generated whether liquid, gaseous or solid.
  3. proposed waste control facilities.
  4. the treatment objectives.
  5. the design criteria on which the control facilities are based, and.
  6. other information deemed relevant.

Design criteria submitted pursuant to Rule 62-4.210(1)(b)5., F.A.C., shall be based on the results of laboratory and pilot-plant scale studies whenever such studies are warranted. The design efficiencies of the proposed waste treatment facilities and the quantities and types of pollutants in the treated effluents or emissions shall be indicated. Work of this nature shall be subject to the requirements of Chapter 471, F.S. Where confidential records are involved, certain information may be kept confidential pursuant to Section 403.111, F.S.

(c) The owners' written guarantee to meet the design criteria as accepted by the Department and to abide by Chapter 403, F.S. and the rules of the Department as to the quantities and types of materials to be discharged from the installation. The owner may be required to post an appropriate bond or other equivalent evidence of financial responsibility to guarantee compliance with such conditions in instances where the owner's financial resources are inadequate or proposed control facilities are experimental in nature.

(2) The construction permit may contain conditions and an expiration date as determined by the Secretary or the Secretary's designee.

(3) When the Department issues a permit to construct, the permittee shall be allowed a period of time, specified in the permit, to construct, and to operate and test to determine compliance with Chapter 403, F.S., and the rules of the Department and, where applicable, to apply for and receive an operation permit. The Department may require tests and evaluations of the treatment facilities by the permittee at his/her expense.

[Rule 62-4 210, F.A.C.]

14. **Not federally enforceable.** Operation Permit for New Sources. To properly apply for an operation permit for new sources, the applicant shall submit certification that construction was completed noting any deviations from the conditions in the construction permit and test results where appropriate.

[Rule 62-4.220, F.A.C.]

Chapters 28-106 and 62-110, F.A.C.

15. Public Notice, Public Participation, and Proposed Agency Action. The permittee shall comply with all of the requirements for public notice, public participation, and proposed agency action pursuant to Rule 62-110.106 and Rule 62-210.350, F.A.C.

[Rules 62-110.106, 62-210.350 and 62-213.430(1)(b), F.A.C.]

16. Administrative Hearing. The permittee shall comply with all of the requirements for a petition for administrative hearing or waiver of right to administrative proceeding pursuant to Rules 28-106.201, 28-106.301 and 62-110.106, F.A.C.

[Rules 28-106.201, 28-106.301 and 62-110.106, F.A.C.]

Chapter 62-204, F.A.C.

17. Asbestos. This permit does not authorize any demolition or renovation of the facility or its parts or components which involves asbestos removal. This permit does not constitute a waiver of any of the requirements of Chapter 62-257, F.A.C., and 40 CFR Part 61, Subpart M, National Emission Standard for Asbestos, adopted and incorporated by reference in Rule 62-204.800, F.A.C.

Compliance with Chapter 62-257, F.A.C., and 40 CFR 61, Subpart M, Section 61.145, is required for any asbestos demolition or renovation at the source.

[40 CFR 61; Rule 62-204 800, F.A.C., and Chapter 62-257, F.A.C.]

Chapter 62-210, F.A.C.

18. Permits Required. The owner or operator of any emissions unit which emits or can reasonably be expected to emit any air pollutant shall obtain an appropriate permit from the Department prior to beginning construction, modification, or initial or continued operation of the emissions unit unless exempted pursuant to Department rule or statute. All emissions limitations, controls, and other requirements imposed by such permits shall be at least as stringent as any applicable limitations and requirements contained in or enforceable under the State Implementation Plan (SIP) or that are otherwise federally enforceable. Except as provided at Rule 62-213.460, F.A.C., issuance of a permit does not relieve the owner or operator of an emissions unit from complying with any applicable requirements, any emission limiting standards or other requirements of the air pollution rules of the Department or any other such requirements under federal, state, or local law.

(1) Air Construction Permits.

(a) Unless exempt from permitting pursuant to Rule 62-210.300(3)(a) or (b), F.A.C., or Rule 62-4.040, F.A.C., an air construction permit shall be obtained by the owner or operator of any proposed new or modified facility or emissions unit prior to the beginning of construction or modification, in accordance with all applicable provisions of this chapter, Chapter 62-212, F.A.C., and Chapter 62-4, F.A.C. Except as provided under Rule 62-213.415, F.A.C., the owner or operator of any facility seeking to create or change an air emissions bubble shall obtain an air construction permit in accordance with all the applicable provisions of this chapter, Chapter 62-212, F.A.C., and Chapter 62-4, F.A.C. The construction permit shall be issued for a period of time sufficient to allow construction or modification of the facility or emissions unit and operation while the new or modified facility or emissions unit is conducting tests or otherwise demonstrating initial compliance with the conditions of the construction permit.

(b) Notwithstanding the expiration of an air construction permit, all limitations and requirements of such permit that are applicable to the design and operation of the permitted facility or emissions unit shall remain in effect until the facility or emissions unit is permanently shut down, except for any such limitation or requirement that is obsolete by its nature (such as a requirement for initial compliance testing) or any such limitation or requirement that is changed in accordance with the provisions of Rule 62-210.300(1)(b)1., F.A.C. Either the applicant or the Department can propose that certain conditions be considered obsolete. Any conditions or language in an air construction permit that are included for informational purposes only, if they are transferred to the air operation permit, shall be transferred for informational purposes only and shall not become enforceable conditions unless voluntarily agreed to by the permittee or otherwise required under Department rules.

1. Except for those limitations or requirements that are obsolete, all limitations and requirements of an air construction permit shall be included and identified in any air operation permit for the facility or emissions unit. The limitations and requirements included in the air operation permit can be changed, and thereby superseded, through the issuance of an air construction permit, federally enforceable state air operation permit, federally enforceable air general permit, or Title V air operation permit; provided, however, that:

a. Any change that would constitute an administrative correction may be made pursuant to Rule 62-210.360, F.A.C.;

b. Any change that would constitute a modification, as defined at Rule 62-210.200, F.A.C., shall be accomplished only through the issuance of an air construction permit; and

c. Any change in a permit limitation or requirement that originates from a permit issued pursuant to 40 CFR 52.21, Rule 62-204.800(10)(d)2., F.A.C., Rule 62-212.400, F.A.C., Rule 62-212.500, F.A.C., or any former codification of Rule 62-212.400 or 62-212.500, F.A.C., shall be accomplished only through the issuance of a new or revised air construction permit under Rule 62-204.800(10)(d)2., F.A.C., 62-212.400 or 62-212.500, F.A.C., as appropriate.

2. The force and effect of any change in a permit limitation or requirement made in accordance with the provisions of Rule 62-210.300(1)(b)1, F.A.C., shall be the same as if such change were made to the original air construction permit.

3. Nothing in Rule 62-210.300(1)(b), F.A.C., shall be construed as to allow operation of a facility or emissions unit without a valid air operation permit.

(2) Air Operation Permits. Upon expiration of the air operation permit for any existing facility or emissions unit, subsequent to construction or modification and demonstration of initial compliance with the conditions of the construction permit for any new or modified facility or emissions unit, or as otherwise provided in Chapter 62-210 or Chapter 62-213, the owner or operator of such facility or emissions unit shall obtain a renewal air operation permit, an initial air operation permit, or an administrative correction or revision of an existing air operation permit, whichever is appropriate, in accordance with all applicable provisions of Chapter 62-210, Chapter 62-213, and Chapter 62-4, F.A.C.

(a) Minimum Requirements for All Air Operation Permits. At a minimum, a permit issued pursuant to this subsection shall:

1. Specify the manner, nature, volume and frequency of the emissions permitted, and the applicable emission limiting standards or performance standards, if any;

2. Require proper operation and maintenance of any pollution control equipment by qualified personnel, where applicable in accordance with the provisions of any operation and maintenance plan required by the air pollution rules of the Department.

3. Contain an effective date stated in the permit which shall not be earlier than the date final action is taken on the application and be issued for a period, beginning on the effective date, as provided below.
- a. The operation permit for an emissions unit which is in compliance with all applicable rules and in operational condition, and which the owner or operator intends to continue operating, shall be issued or renewed for a five-year period, except that, for Title V sources subject to Rule 62-213.420(1)(a)1., F.A.C., operation permits shall be extended until 60 days after the due date for submittal of the facility's Title V permit application as specified in Rule 62-213.420(1)(a)1., F.A.C.
  - b. Except as provided in Rule 62-210.300(2)(a)3.d., F.A.C., the operation permit for an emissions unit which has been shut down for six months or more prior to the expiration date of the current operation permit, shall be renewed for a period not to exceed five years from the date of shutdown, even if the emissions unit is not maintained in operational condition, provided:
    - (i) the owner or operator of the emissions unit demonstrates to the Department that the emissions unit may need to be reactivated and used, or that it is the owner's or operator's intent to apply to the Department for a permit to construct a new emissions unit at the facility before the end of the extension period; and,
    - (ii) the owner or operator of the emissions unit agrees to and is legally prohibited from providing the allowable emission permitted by the renewed permit as an emissions offset to any other person under Rule 62-212.500, F.A.C.; and,
    - (iii) the emissions unit was operating in compliance with all applicable rules as of the time the source was shut down.
  - c. Except as provided in Rule 62-210.300(2)(a)3.d., F.A.C., the operation permit for an emissions unit which has been shut down for five years or more prior to the expiration date of the current operation permit shall be renewed for a maximum period not to exceed ten years from the date of shutdown, even if the emissions unit is not maintained in operational condition, provided the conditions given in Rule 62-210.300(2)(a)3.b., F.A.C., are met and the owner or operator demonstrates to the Department that failure to renew the permit would constitute a hardship, which may include economic hardship.
  - d. The operation permit for an electric utility generating unit on cold standby or long-term reserve shutdown shall be renewed for a five-year period, and additional five-year periods, even if the unit is not maintained in operational condition, provided the conditions given in Rules 62-210.300(2)(a)3.b.(i) through (iii), F.A.C., are met.
4. In the case of an emissions unit permitted pursuant to Rules 62-210.300(2)(a)3.b., c., and d., F.A.C., include reasonable notification and compliance testing requirements for reactivation of such emissions unit and provide that the owner or operator demonstrate to the Department prior to reactivation that such reactivation would not constitute reconstruction pursuant to Rule 62-204.800(7), F.A.C.

[Rules 62-210.300(1) & (2), F.A.C.]

19. **Not federally enforceable. Notification of Startup.** The owner or operator of any emissions unit or facility which has a valid air operation permit and which has been shut down more than one (1) year, shall notify the Department in writing of the intent to start up such emissions unit or facility, a minimum of sixty (60) days prior to the intended startup date.

(a) The notification shall include the planned startup date, anticipated emission rates or pollutants released, changes to processes or control devices which will result in changes to emission rates, and any other conditions which may differ from the valid outstanding operation permit.

(b) If, due to an emergency, a startup date is not known 60 days prior thereto, the owner shall notify the Department as soon as possible after the date of such startup is ascertained.

[Rule 62-210.300(5), F.A.C.]

20. **Emissions Unit Reclassification.**

(a) Any emissions unit whose operation permit has been revoked as provided for in Chapter 62-4, F.A.C., shall be deemed permanently shut down for purposes of Rule 62-212.500, F.A.C. Any emissions unit whose permit to operate has expired without timely renewal or transfer may be deemed permanently shut down, provided, however, that no such emissions unit shall be deemed permanently shut down if, within 20 days after receipt of written notice from the Department, the emissions unit owner or operator demonstrates that the permit expiration resulted from inadvertent failure to comply with the requirements of Rule 62-4.090, F.A.C., and that the owner or operator intends to continue the emissions unit in operation, and either submits an application for an air operation permit or complies with permit transfer requirements, if applicable.

APPENDIX TV-3, TITLE V CONDITIONS (version dated 04/30/99) (continued)

(b) If the owner or operator of an emissions unit which is so permanently shut down, applies to the Department for a permit to reactivate or operate such emissions unit, the emissions unit will be reviewed and permitted as a new emissions unit.  
[Rule 62-210.300(6), F.A.C.]

21. Public Notice and Comment.

(1) Public Notice of Proposed Agency Action.

(a) A notice of proposed agency action on permit application, where the proposed agency action is to issue the permit, shall be published by any applicant for:

1. An air construction permit;
2. An air operation permit, permit renewal or permit revision subject to Rule 62-210.300(2)(b), F.A.C., (i.e., a FESOP), except as provided in Rule 62-210.300(2)(b)1.b., F.A.C.; or
3. An air operation permit, permit renewal, or permit revision subject to Chapter 62-213, F.A.C., except those permit revisions meeting the requirements of Rule 62-213.412(1), F.A.C.

(b) The notice required by Rule 62-210.350(1)(a), F.A.C., shall be published in accordance with all otherwise applicable provisions of Rule 62-110.106, F.A.C. A public notice under Rule 62-210.350(1)(a)1., F.A.C., for an air construction permit may be combined with any required public notice under Rule 62-210.350(1)(a)2. or 3., F.A.C., for air operation permits. If such notices are combined, the public notice must comply with the requirements for both notices.

(c) Except as otherwise provided at Rules 62-210.350(2) and (5), F.A.C., each notice of intent to issue an air construction permit shall provide a 14-day period for submittal of public comments.

(2) Additional Public Notice Requirements for Emissions Units Subject to Prevention of Significant Deterioration or Nonattainment - Area Preconstruction Review.

(a) Before taking final agency action on a construction permit application for any proposed new or modified facility or emissions unit subject to the preconstruction review requirements of Rule 62-212.400 or 62-212.500, F.A.C., the Department shall comply with all applicable provisions of Rule 62-110.106, F.A.C., and provide an opportunity for public comment which shall include as a minimum the following:

1. A complete file available for public inspection in at least one location in the district affected which includes the information submitted by the owner or operator, exclusive of confidential records under Section 403.111, F.S., and the Department's analysis of the effect of the proposed construction or modification on ambient air quality, including the Department's preliminary determination of whether the permit should be approved or disapproved;
2. A 30-day period for submittal of public comments; and
3. A notice, by advertisement in a newspaper of general circulation in the county affected, specifying the nature and location of the proposed facility or emissions unit, whether BACT or LAER has been determined, the degree of PSD increment consumption expected, if applicable, and the location of the information specified in paragraph 1. above; and notifying the public of the opportunity for submitting comments and requesting a public hearing.

(b) The notice provided for in Rule 62-210.350(2)(a)3., F.A.C., shall be prepared by the Department and published by the applicant in accordance with all applicable provisions of Rule 62-110.106, F.A.C., except that the applicant shall cause the notice to be published no later than thirty (30) days prior to final agency action.

(c) A copy of the notice provided for in Rule 62-210.350(2)(a)3., F.A.C., shall also be sent by the Department to the Regional Office of the U. S. Environmental Protection Agency and to all other state and local officials or agencies having cognizance over the location of such new or modified facility or emissions unit, including local air pollution control agencies, chief executives of city or county government, regional land use planning agencies, and any other state, Federal Land Manager, or Indian Governing Body whose lands may be affected by emissions from the new or modified facility or emissions unit.

(d) A copy of the notice provided for in Rule 62-210.350(2)(a)3., F.A.C., shall be displayed in the appropriate district, branch and local program offices.

(e) An opportunity for public hearing shall be provided in accordance with Chapter 120, F.S., and Rule 62-110.106, F.A.C.

(f) Any public comments received shall be made available for public inspection in the location where the information specified in Rule 62-210.350(2)(a)1., F.A.C., is available and shall be considered by the Department in making a final determination to approve or deny the permit.

(g) The final determination shall be made available for public inspection at the same location where the information specified in Rule 62-210.350(2)(a)1., F.A.C., was made available.



(h) For a proposed new or modified emissions unit which would be located within 100 kilometers of any Federal Class I area or whose emissions may affect any Federal Class I area, and which would be subject to the preconstruction review requirements of Rule 62-212.400, F.A.C., or Rule 62-212.500, F.A.C.:

1. The Department shall mail or transmit to the Administrator a copy of the initial application for an air construction permit and notice of every action related to the consideration of the permit application.
2. The Department shall mail or transmit to the Federal Land Manager of each affected Class I area a copy of any written notice of intent to apply for an air construction permit; the initial application for an air construction permit, including all required analyses and demonstrations; any subsequently submitted information related to the application; the preliminary determination and notice of proposed agency action on the permit application; and any petition for an administrative hearing regarding the application or the Department's proposed action. Each such document shall be mailed or transmitted to the Federal Land Manager within fourteen (14) days after its receipt by the Department.

(3) Additional Public Notice Requirements for Facilities Subject to Operation Permits for Title V Sources.

(a) Before taking final agency action to issue a new, renewed, or revised air operation permit subject to Chapter 62-213, F.A.C., the Department shall comply with all applicable provisions of Rule 62-110.106, F.A.C., and provide an opportunity for public comment which shall include as a minimum the following:

1. A complete file available for public inspection in at least one location in the district affected which includes the information submitted by the owner or operator, exclusive of confidential records under Section 403.111, F.S.; and
2. A 30-day period for submittal of public comments.

(b) The notice provided for in Rule 62-210.350(3)(a), F.A.C., shall be prepared by the Department and published by the applicant in accordance with all applicable provisions of Rule 62-110.106, F.A.C., except that the applicant shall cause the notice to be published no later than thirty (30) days prior to final agency action.

(c) The notice shall identify:

1. The facility;
2. The name and address of the office at which processing of the permit occurs;
3. The activity or activities involved in the permit action;
4. The emissions change involved in any permit revision;
5. The name, address, and telephone number of a Department representative from whom interested persons may obtain additional information, including copies of the permit draft, the application, and all relevant supporting materials, including any permit application, compliance plan, permit, monitoring report, and compliance statement required pursuant to Chapter 62-213, F.A.C. (except for information entitled to confidential treatment pursuant to Section 403.111, F.S.), and all other materials available to the Department that are relevant to the permit decision;
6. A brief description of the comment procedures required by Rule 62-210.350(3), F.A.C.;
7. The time and place of any hearing that may be held, including a statement of procedure to request a hearing (unless a hearing has already been scheduled); and
8. The procedures by which persons may petition the Administrator to object to the issuance of the proposed permit after expiration of the Administrator's 45-day review period.

[Rule 62-210.350, F.A.C.]

## 22. Administrative Permit Corrections.

(1) A facility owner shall notify the Department by letter of minor corrections to information contained in a permit. Such notifications shall include:

- (a) Typographical errors noted in the permit;
- (b) Name, address or phone number change from that in the permit;
- (c) A change requiring more frequent monitoring or reporting by the permittee;
- (d) Changes listed at 40 CFR 72.83(a)(1), (2), (6), (9) and (10), hereby adopted and incorporated by reference, to Title V sources subject to emissions limitations or reductions pursuant to 42 USC ss. 7651-7651o;
- (e) Changes listed at 40 CFR 72.83(a)(11), hereby adopted and incorporated by reference, to Title V sources subject to emissions limitations or reductions pursuant to 42 USC ss. 7651-7651o, provided the notification is accompanied by a copy of any EPA determination concerning the similarity of the change to those listed at Rule 62-210.360(1)(d), F.A.C.; and
- (f) Any other similar minor administrative change at the source.

(2) Upon receipt of any such notification the Department shall within 60 days correct the permit and provide a corrected copy to the owner.

(3) After first notifying the owner, the Department shall correct any permit in which it discovers errors of the types listed at Rule 62-210.360(1)(a) and (b), F.A.C., and provide a corrected copy to the owner.

(4) For Title V source permits, other than general permits, a copy of the corrected permit shall be provided to EPA and any approved local air program in the county where the facility or any part of the facility is located.

(5) The Department shall incorporate requirements resulting from issuance of a new or revised construction permit into an existing Title V source permit, if the construction permit or permit revision incorporates requirements of federally enforceable preconstruction review, and if the applicant requests at the time of application that all of the requirements of Rule 62-213.430(1), F.A.C., be complied with in conjunction with the processing of the construction permit application.  
[Rule 62-210.360, F.A.C.]

23. Reports.

(3) Annual Operating Report for Air Pollutant Emitting Facility.

- (a) The Annual Operating Report for Air Pollutant Emitting Facility (DEP Form No. 62-210.900(5)) shall be completed each year.
- (c) The annual operating report shall be submitted to the appropriate Department District or Department approved local air pollution control program office by March 1 of the following year unless otherwise indicated by permit condition or Department request.

[Rule 62-210.370(3), F.A.C.]

24. Circumvention. No person shall circumvent any air pollution control device, or allow the emission of air pollutants without the applicable air pollution control device operating properly.

[Rule 62-210.650, F.A.C.]

25. Forms and Instructions. The forms used by the Department in the stationary source control program are adopted and incorporated by reference in this section. The forms are listed by rule number, which is also the form number, with the subject, title and effective date. Forms 62-210.900(1),(3),(4) and (5), F.A.C., including instructions, are available from the Department as hard-copy documents or executable files on computer diskettes. Copies of forms (hard-copy or diskette) may be obtained by writing to the Department of Environmental Protection, Division of Air Resources Management, 2600 Blair Stone Road, Tallahassee, Florida 32399-2400. Notwithstanding the requirement of Rule 62-4.050(2), F.A.C., to file application forms in quadruplicate, if an air permit application is submitted using the Department's electronic application form, only one copy of the diskette and signature pages is required to be submitted.

(1) Application for Air Permit - Title V Source, Form and Instructions (Effective 2-11-99).

- (a) Acid Rain Part (Phase II), Form and Instructions (Effective 7-1-95).
  - 1. Repowering Extension Plan, Form and Instructions (Effective 7-1-95).
  - 2. New Unit Exemption, Form and Instructions (Effective 7-1-95).
  - 3. Retired Unit Exemption, Form and Instructions (Effective 7-1-95).
  - 4. Phase II NO<sub>x</sub> Compliance Plan, Form and Instructions (Effective 1-6-98).
  - 5. Phase II NO<sub>x</sub> Averaging Plan, Form (Effective 1-6-98).
- (b) Reserved.

(5) Annual Operating Report for Air Pollutant Emitting Facility, Form and Instructions (Effective 2-11-99).

[Rule 62-210.900, F.A.C.]

Chapter 62-213, F.A.C.

26. Annual Emissions Fee. Each Title V source permitted to operate in Florida must pay between January 15 and March 1 of each year, upon written notice from the Department, an annual emissions fee in accordance with Rule 62-213.205, F.A.C., and the appropriate form and associated instructions.

[Rules 62-213.205 and 62-213.900(1), F.A.C.]

27. Annual Emissions Fee. Failure to pay timely any required annual emissions fee, penalty, or interest constitutes grounds for permit revocation pursuant to Rule 62-4.100, F.A.C.

[Rule 62-213.205(1)(g), F.A.C.]

28. Annual Emissions Fee. Any documentation of actual hours of operation, actual material or heat input, actual production amount, or actual emissions used to calculate the annual emissions fee shall be retained by the owner for a minimum of five (5) years and shall be made available to the Department upon request.

[Rule 62-213.205(1)(j), F.A.C.]

29. Annual Emissions Fee. A completed DEP Form 62-213.900(1), F.A.C., "Major Air Pollution Source Annual Emissions Fee Form", must be submitted by the responsible official with the annual emissions fee.

[Rule 62-213.205(1)(k), F.A.C.]

30. Air Operation Permit Fees. After December 31, 1992, no permit application processing fee, renewal fee, modification fee or amendment fee is required for an operation permit for a Title V source.

[Rule 62-213.205(4), F.A.C.]

31. Permits and Permit Revisions Required. All Title V sources are subject to the permit requirements of Chapter 62-213, F.A.C.

(1) No Title V source may operate except in compliance with Chapter 62-213, F.A.C.

(2) Except as provided in Rule 62-213.410, F.A.C., no source with a permit issued under the provisions of this chapter shall make any changes in its operation without first applying for and receiving a permit revision if the change meets any of the following:

- (a) Constitutes a modification;
- (b) Violates any applicable requirement;
- (c) Exceeds the allowable emissions of any air pollutant from any unit within the source;
- (d) Contravenes any permit term or condition for monitoring, testing, recordkeeping, reporting or of a compliance certification requirement;
- (e) Requires a case-by-case determination of an emission limitation or other standard or a source specific determination of ambient impacts, or a visibility or increment analysis under the provisions of Chapters 62-212 or 62-296, F.A.C.;
- (f) Violates a permit term or condition which the source has assumed for which there is no corresponding underlying applicable requirement to which the source would otherwise be subject;
- (g) Results in the trading of emissions among units within a source except as specifically authorized pursuant to Rule 62-213.415, F.A.C.
- (h) Results in the change of location of any relocatable facility identified as a Title V source pursuant to paragraph (a)-(e), (g) or (h) of the definition of "major source of air pollution" at Rule 62-210.200, F.A.C.
- (i) Constitutes a change at an Acid Rain Source under the provisions of 40 CFR 72.81(a)(1),(2), or (3), (b)(1) or (b)(3), hereby incorporated by reference;
- (j) Constitutes a change in a repowering plan, nitrogen oxides averaging plan, or nitrogen oxides compliance deadline extension at an Acid Rain Source.
- (k) Is a request for exemption pursuant to Rule 62-214.340, F.A.C.

[Rule 62-213.400(1) & (2), F.A.C.]

32. Changes Without Permit Revision. Title V sources having a valid permit issued pursuant to Chapter 62-213, F.A.C., may make the following changes without permit revision, provided that sources shall maintain source logs or records to verify periods of operation in each alternative method of operation:

- (1) Permitted sources may change among those alternative methods of operation allowed by the source's permit as provided by the terms of the permit;
  - (2) Permitted sources may implement the terms or conditions of a new or revised construction permit if:
    - (a) The application for construction permit complied with the requirements of Rule 62-213.420(3) and (4), F.A.C.;
    - (b) The terms or conditions were subject to federally enforceable preconstruction review pursuant to Chapter 62-212, F.A.C.; and
    - (c) The new or revised construction permit was issued after the Department and the applicant complied with all the requirements of Rule 62-213.430(1), F.A.C.;
  - (3) A permitted source may implement operating changes after the source submits any forms required by any applicable requirement and provides the Department and EPA with at least 7 days written notice prior to implementation. The source and the Department shall attach each notice to the relevant permit:
    - (a) The written notice shall include the date on which the change will occur, and a description of the change within the permitted source, the pollutants emitted and any change in emissions, and any term or condition becoming applicable or no longer applicable as a result of the change;
    - (b) The permit shield described in Rule 62-213.460, F.A.C., shall not apply to such changes;
  - (4) Permitted sources may implement changes involving modes of operation only in accordance with Rule 62-213.415, F.A.C.
- [Rule 62-213.410, F.A.C.]

33. Immediate Implementation Pending Revision Process.

(1) Those permitted Title V sources making any change that constitutes a modification pursuant to the definition of modification at Rule 62-210.200, F.A.C., but which would not constitute a modification pursuant to 42 USC 7412(a) or to 40 CFR 52.01, 60.2, or 61.15, adopted and incorporated by reference at Rule 62-204.800, F.A.C., may implement such change prior to final issuance of a permit revision in accordance with this section, provided the change:

- (a) Does not violate any applicable requirement;
- (b) Does not contravene any permit term or condition for monitoring, testing, recordkeeping or reporting, or any compliance certification requirement;

(c) Does not require or change a case-by-case determination of an emission limitation or other standard, or a source-specific determination of ambient impacts, or a visibility or increment analysis under the provisions of Chapter 62-212 or 62-296.

F.A.C.;

(d) Does not seek to establish or change a permit term or condition for which there is no corresponding underlying applicable requirement and that the source has assumed to avoid an applicable requirement to which the source would otherwise be subject including any federally enforceable emissions cap or federally enforceable alternative emissions limit.

(2) A Title V source may immediately implement such changes after they have been incorporated into the terms and conditions of a new or revised construction permit issued pursuant to Chapter 62-212, F.A.C., and after the source provides to EPA, the Department, each affected state and any approved local air program having geographic jurisdiction over the source, a copy of the source's application for operation permit revision. The Title V source may conform its application for construction permit to include all information required by Rule 62-213.420, F.A.C., in lieu of submitting separate application forms.

(3) The Department shall process the application for operation permit revision in accordance with the provisions of Chapter 62-213, F.A.C., except that the Department shall issue a draft permit revision or a determination to deny the revision within 60 days of receipt of a complete application for operation permit revision or, if the Title V source has submitted a construction permit application conforming to the requirements of Rule 62-213.420, F.A.C., the Department shall issue a draft permit or a determination to deny the revision at the same time the Department issues its determination on issuance or denial of the construction permit application. The Department shall not take final action until all the requirements of Rule 62-213.430(1)(a), (c), (d), and (e), F.A.C., have been complied with.

(4) Pending final action on the operation permit revision application, the source shall implement the changes in accordance with the terms and conditions of the source's new or revised construction permit.

(5) The permit shield described in Rule 62-213.460, F.A.C., shall not apply to such changes until after the Department takes final action to issue the operation permit revision.

(6) If the Department denies the source's application for operation permit revision, the source shall cease implementation of the proposed changes.

[Rule 62-213.412, F.A.C.]

#### 34. Permit Applications.

(1) Duty to Apply. For each Title V source, the owner or operator shall submit a timely and complete permit application in compliance with the requirements of Rules 62-213.420, 62-4.050(1) & (2), and 62-210.900, F.A.C.

(a) Timely Application.

3. For purposes of permit renewal, a timely application is one that is submitted in accordance with Rule 62-4.090, F.A.C.

(b) Complete Application.

1. Any applicant for a Title V permit, permit revision or permit renewal must submit an application on DEP Form No. 62-210.900(1), which must include all the information specified by Rule 62-213.420(3), F.A.C., except that an application for permit revision must contain only that information related to the proposed change. The applicant shall include information concerning fugitive emissions and stack emissions in the application. Each application for permit, permit revision or permit renewal shall be certified by a responsible official in accordance with Rule 62-213.420(4), F.A.C.

2. For those applicants submitting initial permit applications pursuant to Rule 62-213.420(1)(a)1., F.A.C., a complete application shall be an application that substantially addresses all the information required by the application form number 62-210.900(1), and such applications shall be deemed complete within sixty days of receipt of a signed and certified application unless the Department notifies the applicant of incompleteness within that time. For all other applicants, the applications shall be deemed complete sixty days after receipt, unless the Department, within sixty days after receipt of a signed application for permit, permit revision or permit renewal, requests additional documentation or information needed to process the application. An applicant making timely and complete application for permit, or timely application for permit renewal as described by Rule 62-4.090(1), F.A.C., shall continue to operate the source under the authority and provisions of any existing valid permit or Florida Electrical Power Plant Siting Certification, provided the applicant complies with all the provisions of Rules 62-213.420(1)(b)3. and 4. F.A.C. Failure of the Department to request additional information within sixty days of receipt of a properly signed application shall not impair the Department's ability to request additional information pursuant to Rules 62-213.420(1)(b)3. and 4., F.A.C.

3. For those permit applications submitted pursuant to the provisions of Rule 62-213.420(1)(a)1., F.A.C., the Department shall notify the applicant if the Department becomes aware at any time during processing of the application that the application contains incorrect or incomplete information. The applicant shall submit the corrected or supplementary information to the Department within ninety days unless the applicant has requested and been granted additional time to submit the information. Failure of an applicant to submit corrected or supplementary information requested by the Department within ninety days or such additional time as requested and granted shall render the application incomplete.

4. For all applications other than those addressed at Rule 62-213.420(1)(b)3., F.A.C., should the Department become aware, during processing of any application that the application contains incorrect information, or should the Department become aware, as a result of comment from an affected State, an approved local air program, EPA, or the public that additional information is needed to evaluate the application, the Department shall notify the applicant within 30 days. When an applicant becomes aware that an application contains incorrect or incomplete information, the applicant shall submit the corrected or supplementary information to the Department. If the Department notifies an applicant that corrected or supplementary information is necessary to process the permit, and requests a response, the applicant shall provide the information to the Department within ninety days of the Department request unless the applicant has requested and been granted additional time to submit the information or, the applicant shall, within ninety days, submit a written request that the Department process the application without the information. Failure of an applicant to submit corrected or supplementary information requested by the Department within ninety days, or such additional time as requested and granted, or to demand in writing within ninety days that the application be processed without the information shall render the application incomplete. Nothing in this section shall limit any other remedies available to the Department.

[Rules 62-213.420(1)(a)3. and 62-213.420(1)(b)1., 2., 3. & 4., F.A.C.]

35. Confidential Information. Whenever an applicant submits information under a claim of confidentiality pursuant to Section 403.111, F.S., the applicant shall also submit a copy of all such information and claim directly to EPA. (also, see Condition No. 50.)

[Rule 62-213.420(2), F.A.C.]

36. Standard Application Form and Required Information. Applications shall be submitted under Chapter 62-213, F.A.C., on forms provided by the Department and adopted by reference in Rule 62-210.900(1), F.A.C. The information as described in Rule 62-210.900(1), F.A.C., shall be included for the Title V source and each emissions unit. An application must include information sufficient to determine all applicable requirements for the Title V source and each emissions unit and to evaluate a fee amount pursuant to Rule 62-213.205, F.A.C.

[Rule 62-213.420(3), F.A.C.]

37. Certification by Responsible Official (RO). In addition to the professional engineering certification required for applications by Rule 62-4.050(3), F.A.C., any application form, report, compliance statement, compliance plan and compliance schedule submitted pursuant to Chapter 62-213, F.A.C., shall contain a certification signed by a responsible official that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

[Rule 62-213.420(4), F.A.C.]

38. a. Permit Renewal and Expiration. Permits being renewed are subject to the same requirements that apply to permit issuance at the time of application for renewal. Permit renewal applications shall contain that information identified in Rules 62-210.900(1) and 62-213.420(3), F.A.C. Unless a Title V source submits a timely application for permit renewal in accordance with the requirements of Rule 62-4.090(1), F.A.C., the existing permit shall expire and the source's right to operate shall terminate.

b. Permit Revision Procedures. Permit revisions shall meet all requirements of Chapter 62-213, F.A.C., including those for content of applications, public participation, review by approved local programs and affected states, and review by EPA, as they apply to permit issuance and renewal, except that permit revisions for those activities implemented pursuant to Rule 62-213.412, F.A.C., need not meet the requirements of Rule 62-213.430(1)(b), F.A.C. The Department shall require permit revision in accordance with the provisions of Rule 62-4.080, F.A.C., and 40 CFR 70.7(f), whenever any source becomes subject to any condition listed at 40 CFR 70.7(f)(1), hereby adopted and incorporated by reference. The below requirements from 40 CFR 70.7(f) are adopted and incorporated by reference in Rule 62-213.430(4), F.A.C.:

o 40 CFR 70.7(f): Reopening for Cause. (also, see Condition No. 4)

(1) This section contains provisions from 40 CFR 70.7(f) that specify the conditions under which a Title V permit shall be reopened prior to the expiration of the permit. A Title V permit shall be reopened and revised under any of the following circumstances:

(i) Additional applicable requirements under the Act become applicable to a major Part 70 source with a remaining permit term of 3 or more years. Such a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which the permit is due to expire, unless the original permit or any of its terms and conditions has been extended pursuant to 40 CFR 70.4(b)(10)(i) or (ii).

(ii) Additional requirements (including excess emissions requirements) become applicable to an affected source under the acid rain program. Upon approved by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

(iii) The permitting authority or EPA determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.

(iv) The Administrator or the permitting authority determines that the permit must be revised or revoked to assure compliance with the applicable requirements.

(2) Proceedings to reopen and issue a permit shall follow the same procedures as apply to initial permit issuance and shall affect only those parts of the permit for which cause to reopen exists. Such reopening shall be made as expeditiously as practicable.

(3) Reopenings under 40 CFR 70.7(f)(1) shall not be initiated before a notice of such intent is provided to the Part 70 source by the permitting authority at least 30 days in advance of the date that the permit is to be reopened, except that the permitting authority may provide a shorter time period in the case of an emergency.

[Rules 62-213.430(3) & (4), F.A.C.; and, 40 CFR 70.7(f)]

39. Insignificant Emissions Units or Pollutant-Emitting Activities.

(a) All requests for determination of insignificant emissions units or activities made pursuant to Rule 62-213.420(3)(m), F.A.C., shall be processed in conjunction with the permit, permit renewal or permit revision application submitted pursuant to Chapter 62-213, F.A.C. Insignificant emissions units or activities shall be approved by the Department consistent with the provisions of Rule 62-4.040(1)(b), F.A.C. Emissions units or activities which are added to a Title V source after issuance of a permit under Chapter 62-213, F.A.C., shall be incorporated into the permit at its next renewal, provided such emissions units or activities have been exempted from the requirement to obtain an air construction permit and also qualify as insignificant pursuant to Rule 62-213.430(6), F.A.C.

(b) An emissions unit or activity shall be considered insignificant if:

1. Such unit or activity would be subject to no unit-specific applicable requirement;
2. Such unit or activity, in combination with other units or activities proposed as insignificant, would not cause the facility to exceed any major source threshold(s) as defined in Rule 62-213.420(3)(c)1., F.A.C., unless it is acknowledged in the permit application that such units or activities would cause the facility to exceed such threshold(s); and
3. Such unit or activity would not emit or have the potential to emit:
  - a. 500 pounds per year or more of lead and lead compounds expressed as lead;
  - b. 1,000 pounds per year or more of any hazardous air pollutant;
  - c. 2,500 pounds per year or more of total hazardous air pollutants; or
  - d. 5.0 tons per year or more of any other regulated pollutant.

[Rule 62-213.430(6), F.A.C.]

40. Permit Duration. Operation permits for Title V sources may not be extended as provided in Rule 62-4.080(3), F.A.C., if such extension will result in a permit term greater than five (5) years.

[Rule 62-213.440(1)(a), F.A.C.]

41. Monitoring Information. All records of monitoring information shall specify the date, place, and time of sampling or measurement and the operating conditions at the time of sampling or measurement, the date(s) analyses were performed, the company or entity that performed the analyses, the analytical techniques or methods used, and the results of such analyses.  
[Rule 62-213.440(1)(b)2.a., F.A.C.]

42. Retention of Records. Retention of records of all monitoring data and support information shall be for a period of at least 5 years from the date of the monitoring sample, measurement, report, or application. Support information includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.  
[Rule 62-213.440(1)(b)2.b., F.A.C.]

43. Monitoring Reports. The permittee shall submit reports of any required monitoring at least every six (6) months. All instances of deviations from permit requirements must be clearly identified in such reports.  
[Rule 62-213.440(1)(b)3.a., F.A.C.]

44. Deviation from Permit Requirements Reports. The permittee shall report in accordance with the requirements of Rules 62-210.700(6) and 62-4.130, F.A.C., any deviations from permit requirements, including those attributable to upset conditions as defined in the permit. Reports shall include the probable cause of such deviations, and any corrective actions or preventive measures taken.  
[Rule 62-213.440(1)(b)3.b., F.A.C.]

45. Reports. All reports shall be accompanied by a certification by a responsible official, pursuant to Rule 62-213.420(4), F.A.C.  
[Rule 62-213.440(1)(b)3.c., F.A.C.]

46. If any portion of the final permit is invalidated, the remainder of the permit shall remain in effect.  
[Rule 62-213.440(1)(d)1., F.A.C.]

47. It shall not be a defense for a permittee in an enforcement action that maintaining compliance with any permit condition would necessitate halting or reduction of the source activity.  
[Rule 62-213.440(1)(d)3., F.A.C.]

48. A Title V source shall comply with all the terms and conditions of the existing permit until the Department has taken final action on any permit renewal or any requested permit revision, except as provided at Rule 62-213.412(2), F.A.C.  
[Rule 62-213.440(1)(d)4., F.A.C.]

49. A situation arising from sudden and unforeseeable events beyond the control of the source which causes an exceedance of a technology-based emissions limitation because of unavoidable increases in emissions attributable to the situation and which requires immediate corrective action to restore normal operation, shall be an affirmative defense to an enforcement action in accordance with the provisions and requirements of 40 CFR 70.6(g)(2) and (3), hereby adopted and incorporated by reference.  
[Rule 62-213.440(1)(d)5., F.A.C.]

50. Confidentiality Claims. Any permittee may claim confidentiality of any data or other information by complying with Rule 62-213.420(2), F.A.C. (also, see Condition No. 35.)  
[Rule 62-213.440(1)(d)6., F.A.C.]

51. Statement of Compliance. The permittee shall submit a statement of compliance with all terms and conditions of the permit. Such statements shall be submitted to the Department and EPA annually, or more frequently if specified by Rule 62-213.440(2), F.A.C., or by any other applicable requirement. Such statements shall be accompanied by a certification in accordance with Rule 62-213.420(4), F.A.C. The statement of compliance shall include all the provisions of 40 CFR 70.6(c)(5)(iii), incorporated by reference at Rule 62-204.800, F.A.C.

o 40 CFR 70.6(c)(5)(iii). The compliance certification shall include all of the following (provided that the identification of applicable information may cross-reference the permit or previous reports, as applicable):

(A) The identification of each term or condition of the permit that is the basis of the certification:

(B) The identification of the method(s) or other means used by the owner or operator for determining the compliance status with each term and condition during the certification period, and whether such methods or other means provide continuous or intermittent data. Such methods and other means shall include, at a minimum, the methods and means required under 40 CFR 70.6(a)(3). If necessary, the owner or operator also shall identify any other material information that must be included in the certification to comply with section 113(c)(2) of the Act, which prohibits knowingly making a false certification or omitting material information;

(C) The status of compliance with the terms and conditions of the permit for the period covered by the certification, based on the method or means designated in paragraph (c)(5)(iii)(B) of this section. The certification shall identify each deviation and take it into account in the compliance certification. The certification shall also identify as possible exceptions to compliance any periods during which compliance is required and in which an excursion or exceedance as defined under part 64 of this chapter occurred; and

(D) Such other facts as the permitting authority may require to determine the compliance status of the source.

The statement shall be accompanied by a certification by a responsible official, in accordance with Rule 62-213.420(4), F.A.C. The responsible official may treat compliance with all other applicable requirements as a surrogate for compliance with Rule 62-296.320(2), Objectionable Odor Prohibited.

[Rule 62-213.440(3), F.A.C.]

52. Permit Shield. Except as provided in Chapter 62-213, F.A.C., compliance with the terms and conditions of a permit issued pursuant to Chapter 62-213, F.A.C., shall be deemed compliance with any applicable requirements in effect as of the date of permit issuance, provided that the source included such applicable requirements in the permit application. Nothing in Rule 62-213.460, F.A.C., or in any permit shall alter or affect the ability of EPA or the Department to deal with an emergency, the liability of an owner or operator of a source for any violation of applicable requirements prior to or at the time of permit issuance, or the requirements of the Federal Acid Rain Program.

{Permitting note: The permit shield is not in effect until the effective date of the permit.}

[Rule 62-213.460, F.A.C.]

53. Forms and Instructions. The forms used by the Department in the Title V source operation program are adopted and incorporated by reference in Rule 62-213.900, F.A.C. The form is listed by rule number, which is also the form number, and with the subject, title, and effective date. Copies of forms may be obtained by writing to the Department of Environmental Protection, Division of Air Resources Management, 2600 Blair Stone Road, Tallahassee, Florida 32399-2400, or by contacting the appropriate permitting authority.

(1) Major Air Pollution Source Annual Emissions Fee (AEF) Form.

[Rule 62-213.900(1), F.A.C.]

#### Chapter 62-256, F.A.C.

54. Not federally enforceable. Open Burning. This permit does not authorize any open burning nor does it constitute any waiver of the requirements of Chapter 62-256, F.A.C. Source shall comply with Chapter 62-256, F.A.C., for any open burning at the source.

[Chapter 62-256, F.A.C.]

#### Chapter 62-281, F.A.C.

55. Refrigerant Requirements. Any facility having refrigeration equipment, including air conditioning equipment, which uses a Class I or II substance (listed at 40 CFR 82, Subpart A, Appendices A and B), and any facility which maintains, services, or repairs motor vehicles using a Class I or Class II substance as refrigerant must comply with all requirements of 40 CFR 82, Subparts B and F, and with Rule 62-281.100, F.A.C. Those requirements include the following restrictions:

(1) Any facility having any refrigeration equipment normally containing 50 (fifty) pounds of refrigerant, or more, must keep servicing records documenting the date and type of all service and the quantity of any refrigerant added pursuant to 40 CFR 82.166:



- (2) No person repairing or servicing a motor vehicle may perform any service on a motor vehicle air conditioner (MVAC) involving the refrigerant for such air conditioner unless the person has been properly trained and certified as provided at 40 CFR 82.34 and 40 CFR 82.40, and properly uses equipment approved pursuant to 40 CFR 82.36 and 40 CFR 82.38, and complies with 40 CFR 82.42;
- (3) No person may sell or distribute, or offer for sale or distribution, any substance listed as a Class I or Class II substance at 40 CFR 82, Subpart A, Appendices A and B, except in compliance with Rule 62-281.100, F.A.C., and 40 CFR 82.34(b), 40 CFR 82.42, and/or 40 CFR 82.166;
- (4) No person maintaining, servicing, repairing, or disposing of appliances may knowingly vent or otherwise release into the atmosphere any Class I or Class II substance used as a refrigerant in such equipment and no other person may open appliances (except MVACs as defined at 40 CFR 82.152) for service, maintenance or repair unless the person has been properly trained and certified pursuant to 40 CFR 82.161 and unless the person uses equipment certified for that type of appliance pursuant to 40 CFR 82.158 and unless the person observes the practices set forth at 40 CFR 82.156 and 40 CFR 82.166;
- (5) No person may dispose of appliances (except small appliances, as defined at 40 CFR 82.152) without using equipment certified for that type of appliance pursuant to 40 CFR 82.158 and without observing the practices set forth at 40 CFR 82.156 and 40 CFR 82.166;
- (6) No person may recover refrigerant from small appliances, MVACs and MVAC-like appliances (as defined at 40 CFR 82.152), except in compliance with the requirements of 40 CFR 82, Subpart F.  
[40 CFR 82; and, Chapter 62-281, F.A.C. (Chapter 62-281, F.A.C., is not federally enforceable)]

Chapter 62-296, F.A.C.

56. Industrial, Commercial, and Municipal Open Burning Prohibited. Open burning in connection with industrial, commercial, or municipal operations is prohibited, except when:

- (a) Open burning is determined by the Department to be the only feasible method of operation and is authorized by an air permit issued pursuant to Chapter 62-210 or 62-213, F.A.C.; or
- (b) An emergency exists which requires immediate action to protect human health and safety; or
- (c) A county or municipality would use a portable air curtain incinerator to burn yard trash generated by a hurricane, tornado, fire or other disaster and the air curtain incinerator would otherwise be operated in accordance with the permitting exemption criteria of Rule 62-210.300(3), F.A.C.

[Rule 62-296.320(3), F.A.C.]

57. Unconfined Emissions of Particulate Matter.

(4)(c)1. No person shall cause, let, permit, suffer or allow the emissions of unconfined particulate matter from any emissions unit whatsoever, including, but not limited to, vehicular movement, transportation of materials, construction, alteration, demolition or wrecking, or industrially related activities such as loading, unloading, storing or handling, without taking reasonable precautions to prevent such emission.

3. Reasonable precautions may include, but shall not be limited to the following:

- a. Paving and maintenance of roads, parking areas and yards.
- b. Application of water or chemicals to control emissions from such activities as demolition of buildings, grading roads, construction, and land clearing.
- c. Application of asphalt, water, oil, chemicals or other dust suppressants to unpaved roads, yards, open stock piles and similar emissions units.
- d. Removal of particulate matter from roads and other paved areas under the control of the owner or operator of the emissions unit to prevent reentrainment, and from buildings or work areas to prevent particulate from becoming airborne.
- e. Landscaping or planting of vegetation.
- f. Use of hoods, fans, filters, and similar equipment to contain, capture and/or vent particulate matter.
- g. Confining abrasive blasting where possible.
- h. Enclosure or covering of conveyer systems.

4. In determining what constitutes reasonable precautions for a particular facility, the Department shall consider the cost of the control technique or work practice, the environmental impacts of the technique or practice, and the degree of reduction of emissions expected from a particular technique or practice.

[Rules 62-296.320(4)(c)1., 3., & 4, F.A.C.]

[electronic file name: tv-3.doc]

## APPENDIX SS-1, STACK SAMPLING FACILITIES (version dated 10/07/96)

Stack Sampling Facilities Provided by the Owner of an Emissions Unit. This section describes the minimum requirements for stack sampling facilities that are necessary to sample point emissions units. Sampling facilities include sampling ports, work platforms, access to work platforms, electrical power, and sampling equipment support. Emissions units must provide these facilities at their expense. All stack sampling facilities must meet any Occupational Safety and Health Administration (OSHA) Safety and Health Standards described in 29 CFR Part 1910, Subparts D and E.

(a) Permanent Test Facilities. The owner or operator of an emissions unit for which a compliance test, other than a visible emissions test, is required on at least an annual basis, shall install and maintain permanent stack sampling facilities.

(b) Temporary Test Facilities. The owner or operator of an emissions unit that is not required to conduct a compliance test on at least an annual basis may use permanent or temporary stack sampling facilities. If the owner chooses to use temporary sampling facilities on an emissions unit, and the Department elects to test the unit, such temporary facilities shall be installed on the emissions unit within 5 days of a request by the Department and remain on the emissions unit until the test is completed.

(c) Sampling Ports.

1. All sampling ports shall have a minimum inside diameter of 3 inches.
2. The ports shall be capable of being sealed when not in use.
3. The sampling ports shall be located in the stack at least 2 stack diameters or equivalent diameters downstream and at least 0.5 stack diameter or equivalent diameter upstream from any fan, bend, constriction or other flow disturbance.
4. For emissions units for which a complete application to construct has been filed prior to December 1, 1980, at least two sampling ports, 90 degrees apart, shall be installed at each sampling location on all circular stacks that have an outside diameter of 15 feet or less. For stacks with a larger diameter, four sampling ports, each 90 degrees apart, shall be installed. For emissions units for which a complete application to construct is filed on or after December 1, 1980, at least two sampling ports, 90 degrees apart, shall be installed at each sampling location on all circular stacks that have an outside diameter of 10 feet or less. For stacks with larger diameters, four sampling ports, each 90 degrees apart, shall be installed. On horizontal circular ducts, the ports shall be located so that the probe can enter the stack vertically, horizontally or at a 45 degree angle.

5. On rectangular ducts, the cross sectional area shall be divided into the number of equal areas in accordance with EPA Method 1. Sampling ports shall be provided which allow access to each sampling point. The ports shall be located so that the probe can be inserted perpendicular to the gas flow.

(d) Work Platforms.

1. Minimum size of the working platform shall be 24 square feet in area. Platforms shall be at least 3 feet wide.
2. On circular stacks with 2 sampling ports, the platform shall extend at least 110 degrees around the stack.
3. On circular stacks with more than two sampling ports, the work platform shall extend 360 degrees around the stack.
4. All platforms shall be equipped with an adequate safety rail (ropes are not acceptable), toeboard, and hinged floor-opening cover if ladder access is used to reach the platform. The safety rail directly in line with the sampling ports shall be removable so that no obstruction exists in an area 14 inches below each sample port and 6 inches on either side of the sampling port.

(e) Access to Work Platform.

APPENDIX 55-1, STACK SAMPLING FACILITIES (version dated 10/07/96)  
(continued)

---

1. Ladders to the work platform exceeding 15 feet in length shall have safety cages or fall arresters with a minimum of 3 compatible safety belts available for use by sampling personnel.

2. Walkways over free-fall areas shall be equipped with safety rails and toeboards.

(f) Electrical Power.

1. A minimum of two 120-volt AC, 20-amp outlets shall be provided at the sampling platform within 20 feet of each sampling port.

2. If extension cords are used to provide the electrical power, they shall be kept on the plant's property and be available immediately upon request by sampling personnel.

(g) Sampling Equipment Support.

1. A three-quarter inch eyebolt and an angle bracket shall be attached directly above each port on vertical stacks and above each row of sampling ports on the sides of horizontal ducts.

a. The bracket shall be a standard 3 inch x 3 inch x one-quarter inch equal-legs bracket which is 1 and one-half inches wide. A hole that is one-half inch in diameter shall be drilled through the exact center of the horizontal portion of the bracket. The horizontal portion of the bracket shall be located 14 inches above the centerline of the sampling port.

b. A three-eighth inch bolt which protrudes 2 inches from the stack may be substituted for the required bracket. The bolt shall be located 15 and one-half inches above the centerline of the sampling port.

c. The three-quarter inch eyebolt shall be capable of supporting a 500 pound working load. For stacks that are less than 12 feet in diameter, the eyebolt shall be located 48 inches above the horizontal portion of the angle bracket. For stacks that are greater than or equal to 12 feet in diameter, the eyebolt shall be located 60 inches above the horizontal portion of the angle bracket. If the eyebolt is more than 120 inches above the platform, a length of chain shall be attached to it to bring the free end of the chain to within safe reach from the platform.

2. A complete monorail or dualrail arrangement may be substituted for the eyebolt and bracket.

3. When the sample ports are located in the top of a horizontal duct, a frame shall be provided above the port to allow the sample probe to be secured during the test.

[Rule 62-297.310(6), F.A.C.]

**FIGURE 1--SUMMARY REPORT--GASEOUS AND OPACITY EXCESS EMISSION AND MONITORING SYSTEM PERFORMANCE (version dated 7/96)**

[Note: This form is referenced in 40 CFR 60.7, Subpart A-General Provisions]

Pollutant (Circle One):    SO<sub>2</sub>    NO<sub>x</sub>    TRS    H<sub>2</sub>S    CO    Opacity

Reporting period dates: From \_\_\_\_\_ to \_\_\_\_\_

Company: \_\_\_\_\_

Emission Limitation: \_\_\_\_\_

Address: \_\_\_\_\_

Monitor Manufacturer: \_\_\_\_\_

Model No.: \_\_\_\_\_

Date of Latest CMS Certification or Audit: \_\_\_\_\_

Process Unit(s) Description: \_\_\_\_\_

Total source operating time in reporting period <sup>1</sup>: \_\_\_\_\_

| Emission data summary <sup>1</sup>  | CMS performance summary <sup>1</sup>                                  |
|---|---|
| 1. Duration of excess emissions in reporting period due to:                         | 1. CMS downtime in reporting period due to:                           |
| a. Startup/shutdown .....   | a. Monitor equipment malfunctions .....                               |
| b. Control equipment problems .....   | b. Non-Monitor equipment malfunctions .....                           |
| c. Process problems .....   | c. Quality assurance calibration .....                                |
| d. Other known causes .....   | d. Other known causes .....   |
| e. Unknown causes .....   | e. Unknown causes .....   |
| 2. Total duration of excess emissions .....   | 2. Total CMS Downtime .....   |
| 3. Total duration of excess emissions x (100) / [Total source operating time] ..... | 3. [Total CMS Downtime] x (100) / [Total source operating time] ..... |
| _____ % <sup>2</sup>  | _____ % <sup>2</sup>  |

<sup>1</sup> For opacity, record all times in minutes. For gases, record all times in hours.

<sup>2</sup> For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in 40 CFR 60.7(c) shall be submitted.

*Note: On a separate page, describe any changes since last quarter in CMS, process or controls.*

I certify that the information contained in this report is true, accurate, and complete.

Name: \_\_\_\_\_

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

Title: \_\_\_\_\_

# Phase II Permit Application

For more information, see instructions and refer to 40 CFR 72.30 and 72.31 and Chapter 62-214, F.A.C.

This submission is:  New  Revised

**STEP 1**  
Identify the source by plant name, State, and ORIS code from NADB

|                  |       |           |
|------------------|-------|-----------|
| FPL Martin Plant | FL    | 6043      |
| Plant Name       | State | ORIS Code |

**STEP 2**  
Enter the boiler ID# from NADB for each affected unit, and indicate whether a repowering plan is being submitted for the unit by entering "yes" or "no" at column c. For new units, enter the requested information in columns d and e

| Compliance Plan |  |                 |  |   |
|-----------------|--|-----------------|--|---|
| a               | b  | c               | d  | e   |
| Boiler ID#      | Unit Will Hold Allowances in Accordance with 40 CFR 72.9(c)(1) | Repowering Plan | New Units<br><br>Commence Operation Date | New Units<br><br>Monitor Certification Deadline |
| PMR1            | Yes  | No              | N/A                                      | N/A   |
| PMR2            | Yes  | No              | N/A                                      | N/A   |
| HRS3A           | Yes  | No              | 2/16/94                                  | 1/1/96  |
| HRS3B           | Yes  | No              | 2/16/94                                  | 1/1/96  |
| HRS4A           | Yes  | No              | 4/15/94                                  | 1/1/96  |
| HRS4B           | Yes  | No              | 4/15/94                                  | 1/1/96  |
|                 | Yes  |                 |  |   |
|                 | Yes  |                 |  |   |
|                 | Yes  |                 |  |   |
|                 | Yes  |                 |  |   |
|                 | Yes  |                 |  |   |
|                 | Yes  |                 |  |   |

For each unit that will be repowered, the Repowering Extension Plan form is included and the Repowering Technology Petition form has been submitted or will be submitted by June 1, 1997.

**STEP 3**  
Check the box if the response in column c of Step 2 is "Yes" for any unit

Plant Name (from Step 1)

**STEP 4**

and the standard requirements and certification, enter the name of the designated representative, and sign and date

**Standard Requirements****Permit Requirements.**

- (1) The designated representative of each Acid Rain source and each Acid Rain unit at the source shall:
  - (i) Submit a complete Acid Rain part application (including a compliance plan) under 40 CFR part 72, Rules 62-214.320 and 330, F.A.C. in accordance with the deadlines specified in Rule 62-214.320, F.A.C.; and
  - (ii) Submit in a timely manner any supplemental information that the permitting authority determines is necessary in order to review an Acid Rain part application and issue or deny an Acid Rain permit;
- (2) The owners and operators of each Acid Rain source and each Acid Rain unit at the source shall:
  - (i) Operate the unit in compliance with a complete Acid Rain part application or a superseding Acid Rain part issued by the permitting authority; and
  - (ii) Have an Acid Rain Part.

**Monitoring Requirements.**

- (1) The owners and operators and, to the extent applicable, designated representative of each Acid Rain source and each Acid Rain unit at the source shall comply with the monitoring requirements as provided in 40 CFR part 75, and Rule 62-214.420, F.A.C.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program.
- (3) The requirements of 40 CFR part 75 shall not affect the responsibility of the owners and operators to monitor emissions of other pollutants or other emissions characteristics at the unit under other applicable requirements of the Act and other provisions of the operating permit for the source.

**Sulfur Dioxide Requirements.**

- (1) The owners and operators of each source and each Acid Rain unit at the source shall:
  - (i) Hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)) not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and
  - (ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide.
- (2) Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act.
- (3) An Acid Rain unit shall be subject to the requirements under paragraph (1) of the sulfur dioxide requirements as follows:
  - (i) Starting January 1, 2000, an Acid Rain unit under 40 CFR 72.6(a)(2); or
  - (ii) Starting on the later of January 1, 2000 or the deadline for monitor certification under 40 CFR part 75, an Acid Rain unit under 40 CFR 72.6(a)(3).
- (4) Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program.
- (5) An allowance shall not be deducted in order to comply with the requirements under paragraph (1)(i) of the sulfur dioxide requirements prior to the calendar year for which the allowance was allocated.
- (6) An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain permit application, the Acid Rain permit, or the written exemption under 40 CFR 72.7 and 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization.
- (7) An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right.

**Nitrogen Oxides Requirements.** The owners and operators of the source and each Acid Rain unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides.

**Excess Emissions Requirements.**

- (1) The designated representative of an Acid Rain unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR part 77.
- (2) The owners and operators of an Acid Rain unit that has excess emissions in any calendar year shall:
  - (i) Pay without demand the penalty required, and pay upon demand the interest on that penalty, as required by 40 CFR part 77; and
  - (ii) Comply with the terms of an approved offset plan, as required by 40 CFR part 77.

**Recordkeeping and Reporting Requirements.**

- (1) Unless otherwise provided, the owners and operators of the source and each Acid Rain unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 5 years, in writing by the Administrator or permitting authority:
  - (i) The certificate of representation for the source and each Acid Rain unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with Rule 62-214.350, F.A.C.; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative;
  - (ii) All emissions monitoring information, in accordance with 40 CFR part 75;
  - (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the Acid Rain Program; and,

Plant Name (from Step 1)

Recordkeeping and Reporting Requirements (cont.)

(iv) Copies of all documents used to complete an Acid Rain part application and any other submission under the Acid Rain Program or to demonstrate compliance with the requirements of the Acid Rain Program.

(2) The designated representative of an Acid Rain source and each Acid Rain unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR part 72 subpart I and 40 CFR part 75.

Liability.

- (1) Any person who knowingly violates any requirement or prohibition of the Acid Rain Program, a complete Acid Rain part application, an Acid Rain part, or a written exemption under 40 CFR 72.7 or 72.8, including any requirement for the payment of any penalty owed to the United States, shall be subject to enforcement pursuant to section 113(c) of the Act.
- (2) Any person who knowingly makes a false, material statement in any record, submission, or report under the Acid Rain Program shall be subject to criminal enforcement pursuant to section 113(c) of the Act and 18 U.S.C. 1001.
- (3) No permit revision shall excuse any violation of the requirements of the Acid Rain Program that occurs prior to the date that the revision takes effect.
- (4) Each Acid Rain source and each Acid Rain unit shall meet the requirements of the Acid Rain Program.
- (5) Any provision of the Acid Rain Program that applies to an Acid Rain source (including a provision applicable to the designated representative of an Acid Rain source) shall also apply to the owners and operators of such source and of the Acid Rain units at the source.
- (6) Any provision of the Acid Rain Program that applies to an Acid Rain unit (including a provision applicable to the designated representative of an Acid Rain unit) shall also apply to the owners and operators of such unit. Except as provided under 40 CFR 72.44 (Phase II repowering extension plans), and except with regard to the requirements applicable to units with a common stack under 40 CFR part 75 (including 40 CFR 75.16, 75.17, and 75.18), the owners and operators and the designated representative of one Acid Rain unit shall not be liable for any violation by any other Acid Rain unit of which they are not owners or operators or the designated representative and that is located at a source of which they are not owners or operators or the designated representative.
- (7) Each violation of a provision of 40 CFR parts 72, 73, 75, 77, and 78 by an Acid Rain source or Acid Rain unit, or by an owner or operator or designated representative of such source or unit, shall be a separate violation of the Act.

Effect on Other Authorities. No provision of the Acid Rain Program, an Acid Rain part application, an Acid Rain part, or a written exemption under 40 CFR 72.7 or 72.8 shall be construed as:

- (1) Except as expressly provided in title IV of the Act, exempting or excluding the owners and operators and, to the extent applicable, the designated representative of an Acid Rain source or Acid Rain unit from compliance with any other provision of the Act, including the provisions of title I of the Act relating to applicable National Ambient Air Quality Standards or State Implementation Plans;
- (2) Limiting the number of allowances a unit can hold; *provided*, that the number of allowances held by the unit shall not affect the source's obligation to comply with any other provisions of the Act;
- (3) Requiring a change of any kind in any State law regulating electric utility rates and charges, affecting any State law regarding such State regulation, or limiting such State regulation, including any prudence review requirements under such State law;
- (4) Modifying the Federal Power Act or affecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act; or,
- (5) Interfering with or impairing any program for competitive bidding for power supply in a State in which such program is established.

Certification

I am authorized to make this submission on behalf of the owners and operators of the Acid Rain source or Acid Rain units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.


(There are no attachments to this document)

|           |                    |                    |
|-----------|--------------------|--------------------|
| Name      |                    | William M. Reichel |
| Signature | William M. Reichel | Date 12/4/95       |

STEP 5 (optional)  
Enter the source AIRS  
and FINDS Identification  
numbers, if known

|       |
|-------|
| AIRS  |
| FINDS |





# Department of Environmental Protection

Lawton Chiles  
Governor

Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

Virginia B. Wetherell  
Secretary

October 14, 1997

CERTIFIED MAIL - RETURN RECEIPT REQUESTED

Mr. Richard Piper  
Senior Environmental Specialist  
Florida Power and Light Company  
Post Office Box 14000  
Juno Beach, Florida 33408

RE: Amendment to PA 89-27, PSD-FL-146(A) Permit  
NSPS Custom Fuel Monitoring Schedule  
Florida Power & Light Company  
Martin Plant

Dear Mr. Piper:

The Department has reviewed your April 28, 1993 letter with supporting data submitted to EPA and additional data submitted by Fax to the Department on October 1, 1997, requesting an NSPS Custom Fuel Monitoring Schedule. The schedule would only apply to a monitoring schedule for sulfur dioxide (SO<sub>2</sub>) and nitrogen oxide (NO<sub>x</sub>) when natural gas is being fired at the subject facility (refer to Attachments No. 1 & 2). The facility is required by the permit to comply with Subpart GG of the New Source Performance Standards (NSPS) 40 CFR 60. For sources utilizing pipeline quality natural gas, 40 CFR 60.334(b) and 60.334(b)(2) state that a custom fuel monitoring schedule, if supported by data which demonstrates compliance with NSPS emission limits, may be approved by the Administrator of EPA. This authority has been delegated to EPA's regional offices and, as stated in the letter from EPA on June 2, 1993, the EPA Region IV will provide their determination of this request to the Department. The Department received a letter, dated June 8, 1993, from EPA on October 1, 1997, stating that a custom fuel monitoring schedule for this facility was acceptable, since it complied with all items of the attachment to the custom fuel monitoring guidance memo issued by EPA Headquarters on August 14, 1987 (Refer to attachment No. 3). The results from a minimum of one sampling event each quarter for six quarters were provided by the permittee, which demonstrated consistent compliance with the allowable SO<sub>2</sub> emissions limits specified under 40 CFR 60.333 and this permit. Therefore, upon issuance of the amended permit, the permittee shall begin monitoring the sulfur content of natural gas as specified in 2.c. of the Custom Fuel Monitoring Schedule for Natural Gas. In accordance with the EPA and Department determination, the permit specific condition will be amended as follows:

Mr. Richard Piper  
PA 89-27, PSD-FL-146  
Permit Amendment  
October 14, 1997  
Page 2 of 5

**A. Specific Condition Number;**

**From**

15. This project shall comply with all the applicable requirements of Chapter 17-2, Florida Administrative Code (F.A.C.) and the June 27, 1989 version of 40 CFR Subpart GG, Gas Turbines.

**To**

15. This source shall be in compliance with all requirements of 40 CFR 60, Subpart GG (Standards of Performance for Stationary Gas Turbines) and Rule 62-204.800(7), F.A.C. (Standards of Performance for New Stationary Sources (NSPS)).

**A. Natural Gas**

Pursuant to 40 CFR 60.334(b)(2), a custom fuel monitoring schedule shall be followed for the natural gas fired at this facility and shall be as follows:

**Custom Fuel Monitoring Schedule for Natural Gas (NG)**

1. Monitoring of fuel nitrogen content shall not be required if NG is the only fuel being fired in the gas turbines.
2. Sulfur Monitoring
  - a. Analysis for fuel sulfur content of the natural gas shall be conducted using one of the approved ASTM reference methods for the measurement of sulfur in gaseous fuels, or an approved alternative method. The reference methods are ASTM D1072-80, ASTM D3031-81, ASTM D3246-81, and ASTM D4084-82 as referenced in 40 CFR 60.335(b)(2), or the latest edition(s).
  - b. This custom fuel monitoring schedule shall become effective on the date this permit becomes valid. Effective the date of this custom schedule, sulfur monitoring shall be conducted twice monthly for six months. If this monitoring shows little variability in the fuel sulfur content, and indicates consistent compliance with 40 CFR 60.333, then sulfur monitoring shall be conducted once per quarter for six quarters. If monitoring data is provided by the applicant which demonstrates consistent compliance with the requirements herein the applicant may begin monitoring as per the requirements of 2(c).

Mr. Richard Piper  
PA 89-27, PSD-FL-146  
Permit Amendment  
October 14, 1997  
Page 3 of 5

- c. If after the monitoring required in item 2(b) above, or herein, the sulfur content of the fuel shows little variability and, calculated as sulfur dioxide, represents consistent compliance with the sulfur dioxide emission limits specified under 40 CFR 60.333, sample analysis shall be conducted twice per annum. This monitoring shall be conducted during the first and third quarters of each calendar year.
  - d. Should any sulfur analysis as required in items 2(b) or 2(c) above indicate noncompliance with 40 CFR 60.333, the owner or operator shall notify the Department of such excess emissions and the custom schedule shall be re-examined by the Environmental Protection Agency. Sulfur monitoring shall be conducted weekly during the interim period when this custom schedule is being re-examined.
3. If there is a change in fuel supply, the owner or operator must notify the Department of such change for re-examination of this custom schedule. A substantial change in fuel quality shall be considered as a change in fuel supply. Sulfur monitoring shall be conducted weekly during the interim period when this custom schedule is being re-examined.
  4. Records of sample analysis and fuel supply pertinent to this custom schedule shall be retained for a period of five years, and be available for inspection by personnel of federal, state, and local air pollution control agencies.

**B. New No. 2 Fuel Oil**

The records of new No. 2 fuel oil usage shall be kept by the company for a five year period for regulatory agency inspection purposes. For sulfur dioxide, periods of excess emissions shall be reported if the fuel oil being fired in the gas turbine exceeds 0.5 percent sulfur content and 0.3 percent sulfur content, by weight, for hourly and annual emissions, respectively.

**B. Attachments to be Incorporated:**

- FPL letter dated April 28, 1993
- EPA letter dated June 2, 1993
- EPA letter dated June 8, 1993
- FPL fax dated October 1, 1997

Mr. Richard Piper  
PA 89-27, PSD-FL-146  
Permit Amendment  
October 14, 1997  
Page 4 of 5

A person whose substantial interests are affected by the Department's proposed permitting decision may petition for an administrative proceeding (hearing) in accordance with Section 120.57, Florida Statutes (F.S.). The petition must contain the information set forth below and must be filed (received) in the Office of General Counsel of the Department at 2600 Blair Stone Road, Tallahassee, Florida 32399-2400. Petitions filed by the applicant of the amendment request/application and the parties listed below must be filed within 14 days of receipt of this amendment. Petitions filed by other persons must be filed within 14 days of the amendment issuance or within 14 days of their receipt of this amendment, whichever occurs first. Petitioner shall mail a copy of the petition to the applicant at the address indicated above at the time of filing. Failure to file a petition within this time period shall constitute a waiver of any right such person may have to request an administrative determination (hearing) under Section 120.57, F.S.

The Petition shall contain the following information:

- (a) The name, address and telephone number of each petitioner, the applicant's name and address, the Department Permit File Number and the county in which the project is proposed;
- (b) A statement of how and when each petitioner received notice of the Department's action or proposed action;
- (c) A statement of how each petitioner's substantial interests are affected by the Department's action or proposed action;
- (d) A statement of the material facts disputed by Petitioner, if any;
- (e) A statement of facts which petitioner contends warrant reversal or modification of the Department's action or proposed action;
- (f) A statement of which rules or statutes petitioner contends require reversal or modification of the Department's action or proposed action;
- (g) A statement of the relief sought by petitioner, stating precisely the action the petitioner wants the Department to take with respect to the Department's action or proposed action.

If a petition is filed, the administrative hearing process is designed to formulate agency action. Accordingly, the Department's final action may be different from the position taken by it in this amendment. Persons whose substantial interests will be affected by any decision of the Department with regard to the request/application have the right to petition to become a party to the proceeding. The petition must conform to the requirements specified above and be filed (received) within 14 days of receipt of this amendment in the Office of General Counsel at the above address of the Department. Failure to petition within the allowed time frame constitutes a waiver of any right such person has to request a hearing under Section 120.57, F.S., and to participate as a party to this proceeding. Any subsequent intervention will only be at the approval of the presiding officer upon motion filed pursuant to Rule 28-5.207, Florida Administrative Code.

Mr. Richard Piper  
PA 89-27, PSD-FL-146  
Permit Amendment  
October 14, 1997  
Page 5 of 5

This letter amendment must be attached to PA 89-27, PSD-FL-146(A) Permit and shall become part of the permit.

Sincerely,



Howard L. Rhodes  
Director  
Division of Air Resources  
Management

HLR/CSL

Attachments


cc: H. Oven, DEP  
I. Goldman, SED  
A. Linero, DEP  
J. Harper, EPA  
J. Lindsay, FPL  
J. Bunyak, NPS  
K. Kosky, KBN

**CERTIFICATE OF SERVICE**

The undersigned duly designated deputy agency clerk hereby certifies that this AMENDMENT and all copies were sent by certified mail before the close of business on 10/14/97 to the person(s) listed:

Clerk Stamp

**FILED AND ACKNOWLEDGMENT FILED,**  
on this date, pursuant to Section 120.52(7),  
Florida Statutes, with the designated agency  
Clerk. receipt of which is hereby acknowledged.

  
Barbara J. Pentell 10/14/97  
(Clerk) (Date)



# Department of Environmental Protection

Lawton Chiles  
Governor

Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

Virginia B. Wetherell  
Secretary

## STATE OF FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Mr. John M. Lindsay  
Plant General Manager  
Florida Power & Light Company  
Environmental Services Department  
P.O. Box 14000  
Juno Beach, FL 33408

### ORDER EXTENDING PERMIT EXPIRATION DATE Martin Plant, Facility ID No.: 0850001

Section 403.0872(2)(b), Florida Statutes (F.S.), specifies that any facility which submits to the Department of Environmental Protection (Department) a timely and complete application for a Title V permit "is entitled to operate in compliance with its existing air permit pending the conclusion of proceedings associated with its application."

Section 403.0872(6), F.S., provides that a proposed Title V permit which is not objected to by the United States Environmental Protection Agency (EPA) "must become final no later than fifty-five (55) days after the date on which the proposed permit was mailed" to the EPA.

Pursuant to the Federal Acid Rain Program as defined in rule 62-210.200, Florida Administrative Code (F.A.C.), all Acid Rain permitting must become effective on January 1 of a given year.

This facility which will be permitted pursuant to section 403.0872, F.S., (Title V permit) will be required to have a permit effective date subsequent to the final processing date of the facility's Title V permit.

To prevent misunderstanding and to assure that the above identified facility continues to comply with existing permit terms and conditions until its Title V permit becomes effective, it is necessary to extend the expiration date(s) of its existing valid permit(s) until the effective date of its Title V permit. Therefore, under the authority granted to the Department by section 403.061(8), F.S., **IT IS ORDERED:**

1. The expiration date(s) of the existing valid permit(s) under which the above identified facility is currently operating is (are) hereby extended until the effective date of its permit issued pursuant to section 403.0872, F.S., (Title V permit);

2. The facility shall comply with all terms and conditions of its existing valid permit(s) until the effective date of its Title V permit;

3. The facility will continue to comply with the requirements of Chapter 62-214, F.A.C., and the Federal Acid Rain Program, as defined in rule 62-210.200, F.A.C., pending final issuance of its Title V permit.

### PETITION FOR ADMINISTRATIVE REVIEW

The Department will take the action described in this Order unless a timely petition for an administrative hearing is filed pursuant to sections 120.569 and 120.57 of the Florida Statutes (F.S.). Mediation under Section 120.573, F.S., will not be available for this proposed action.

A person whose substantial interests are affected by the Department's proposed decision may petition for an administrative hearing in accordance with sections 120.569 and 120.57 of the Florida Statutes. The petition must contain the information set forth below and must be filed (received) in the Office of General Counsel of the Department at 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida 32399-3000. Petitions must be filed within 21 days of receipt of this Order. A petitioner must mail a copy of the petition to the applicant at the address indicated above, at the time of filing. The failure of any person to file a petition within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under sections 120.569 and 120.57 of the Florida Statutes, or to intervene in this proceeding and participate as a party to it. Any subsequent intervention will be only at the approval of the presiding officer upon the filing of a motion in compliance with rule 28-5.207 of the Florida Administrative Code.

A petition must contain the following information:

- (a) The name, address, and telephone number of each petitioner, the applicant's name and address, the Department File Number, and the county in which the project is proposed;
- (b) A statement of how and when each petitioner received notice of the Department's action or proposed action;
- (c) A statement of how each petitioner's substantial interests are affected by the Department's action or proposed action;
- (d) A statement of the material facts disputed by the petitioner, if any;
- (e) A statement of the facts that the petitioner contends warrant reversal or modification of the Department's action or proposed action;
- (f) A statement identifying the rules or statutes that the petitioner contends require reversal or modification of the Department's action or proposed action; and
- (g) A statement of the relief sought by the petitioner, stating precisely the action that the petitioner wants the Department to take with respect to the action or proposed action addressed in this notice of intent.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Department's final action may be different from the position taken by it in this Order. Persons whose substantial interests will be affected by any such final decision of the Department on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

In addition to the above, a person subject to regulation has a right to apply for a variance from or waiver of the requirements of particular rules, on certain conditions, under section 120.542 of the Florida Statutes. The relief provided by this state statute applies only to state rules, not statutes, and not to any federal regulatory requirements. Applying for a variance or waiver does not substitute or extend the time for filing a petition for an administrative hearing or exercising any other right that a person may have in relation to the action proposed in this notice of intent.

The application for a variance or waiver is made by filing a petition with the Office of General Counsel of the Department, 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida 32399-3000. The petition must specify the following information:

- (a) The name, address, and telephone number of the petitioner;
- (b) The name, address, and telephone number of the attorney or qualified representative of the petitioner, if any;
- (c) Each rule or portion of a rule from which a variance or waiver is requested;
- (d) The citation to the statute underlying (implemented by) the rule identified in (c) above;
- (e) The type of action requested;
- (f) The specific facts that would justify a variance or waiver for the petitioner;
- (g) The reason why the variance or waiver would serve the purposes of the underlying statute (implemented by the rule); and
- (h) A statement whether the variance or waiver is permanent or temporary and, if temporary, a statement of the dates showing the duration of the variance or waiver requested.

The Department will grant a variance or waiver when the petition demonstrates both that the application of the rule would create a substantial hardship or violate principles of fairness, as each of those terms is defined in section 120.542(2) of the Florida Statutes, and that the purpose of the underlying statute will be or has been achieved by other means by the petitioner.

Persons subject to regulation pursuant to any federally delegated or approved air program should be aware that Florida is specifically not authorized to issue variances or waivers from any requirements of any such federally delegated or approved program. The requirements of the program remain fully enforceable by the Administrator of EPA and by any person under the Clean Air Act unless and until the Administrator separately approves any variance or waiver in accordance with the procedures of the federal program.

This Order constitutes final agency action unless a petition is filed in accordance with the above paragraphs.




RIGHT TO APPEAL

Any party to this Order has the right to seek judicial review of the Order pursuant to Section 120.68, F.S., by the filing of a Notice of Appeal pursuant to Rule 9.110, Florida Rules of Appellate Procedure, with the Clerk of the Department in the Office of General Counsel, 3900 Commonwealth Boulevard, Tallahassee, Florida 32399-3000; and, by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The Notice of Appeal must be filed within 30 days from the date the Notice of Agency Action is filed with the Clerk of the Department.

DONE AND ORDERED this 30 day of Oct, 1997 in Tallahassee, Florida.

STATE OF FLORIDA DEPARTMENT  
OF ENVIRONMENTAL PROTECTION



HOWARD L. RHODES, Director  
Division of Air Resources Management

Twin Towers Office Building  
Mail Station 5500  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400  
850/488-0114


CERTIFICATE OF SERVICE

The undersigned duly designated deputy agency clerk hereby certifies that this order and all copies were sent by certified mail before the close of business on 10/30/97 to the person(s) listed:

Mr. John M. Lindsay, Florida Power & Light Company  
Mr. Isidore Goldman, Southeast District Office

Clerk Stamp

**FILING AND ACKNOWLEDGMENT FILED**, on this date, pursuant to Section 120.52(7), Florida Statutes, with the designated agency Clerk, receipt of which is hereby acknowledged.

  
(Clerk) 10/30/97 (Date)