Scearce, Lynn

From:

Scearce, Lynn

Sent:

Monday, October 03, 2011 10:51 AM

To:

Anderson, Lennon; dee morse@nps.gov; john bunyak@nps.gov

Cc:

Cascio, Tom; Holtom, Jonathan; Wong, Robert; Friday, Barbara; Scearce, Lynn

Subject:

New Application - 0850001-027-AC, Martin Power Plant

Lennon,

A new <u>Permit Application</u> has been received at FL Department of Environmental Protection Div. of Air Resource Management and is currently under review and can be viewed at http://arm-permit2k.dep.state.fl.us/psd/0850001/U00000148.pdf.

ARMS PA Project ID:	0850001-027-AC	
Facility Name:	Martin Power Plant	
Florida County:	Martin	
Project Description:	Permit Mod for testing	
Permit Application Processor:	Tom Cascio	
Processor Phone:	(850) 717-9077	
Processor Email Address:	tom.cascio@dep.state.fl.us	
Received in-house:	9/30/11	

Please direct any questions regarding this permit application to the permit application processor. If you have any problems accessing these documents please let me know.

Thanks,

Lynn Scearce

Office of Permitting and Compliance (OPC)
Division of Air Resource Management – DEP
2600 Blair Stone Road, Mail Stop 5505

Phone: 850-717-9025

Please take a few minutes to share your comments on the service you received from the department by clicking on this link <u>DEP Customer Survey</u>.

Scearce, Lynn

From:

Holtom, Jonathan

Sent:

Monday, October 03, 2011 9:01 AM

To:

Cascio, Tom

Cc:

Koerner, Jeff; Scearce, Lynn; Wong, Robert

Subject:

FW: Request for Permit Modification

Attachments:

SKMBT C36011093015560.pdf

Tom,

Please process a letter of authorization for the requested excess emissions. Use projects 0850001-023 and 025-AC as templates. Make sure this time the part that suggests FPL revise their AC permit to allow for these excess emissions due to tuning is highlighted or bolded so they will go ahead and schedule a revision to the AC permits for all of their units.

Looks like we will not have to do this for the Unit 8 upgrade project when they finish it, the permit already allows for CEMS exemptions due to tuning:

E.15. <u>DLN Tuning.</u> CEMS data collected during initial or other major DLN tuning sessions shall be excluded from the CEMS compliance demonstration provided the tuning session is performed in accordance with the manufacturer's specifications. A "major tuning session" would occur after completion of initial construction, a combustor change-out, a major repair or maintenance to a combustor, or other similar circumstances. Prior to performing any major tuning session, the permittee shall provide the Compliance Authority with an advance notice that details the activity and proposed tuning schedule. The notice may be by telephone, facsimile transmittal, or electronic mail. [0850001-010-AC; and Rule 62-4.070(3), F.A.C.]

Robert, please check the excess emissions provisions in Sanford's permit. If it does not allow for tuning, please add the above condition to your current project and all future projects of this sort.

Lynn, please log this AC project for Tom and let him know what the number is.

Thanks!

Jon

From: Koerner, Jeff

Sent: Friday, September 30, 2011 5:10 PM

To: Holtom, Jonathan **Cc:** Scearce, Lynn

Subject: FW: Request for Permit Modification

Jon, please read and let Lynn know what to do.

Jeff

From: Anderson, Lennon

Sent: Friday, September 30, 2011 4:05 PM

To: Koerner, Jeff **Cc:** Delosantos, Manuel

Subject: Request for Permit Modification

Hi Jeff!

SED received the attached request for permit modification. Since the Division has permit jurisdiction on power plants, it is being forwarded for processing.

If there are any questions or comments, please let me know.

Thanks!

From: Barbara.Jones@dep.state.fl.us [mailto:Barbara.Jones@dep.state.fl.us]

Sent: Friday, September 30, 2011 4:57 PM

To: Anderson, Lennon

Subject: Message from KMBT_C360