



MEMORANDUM

TO: Scott M. Sheplak, P.E.

FROM: Tom Cascio 

THROUGH: Bruce Mitchell 

DATE: October 23, 1997

Re: PROPOSED Permit Determination and
PROPOSED Title V Permit No. 0850001-004-AV
Florida Power & Light Company
Martin Plant

This permit is for the initial Title V air operation permit for the subject facility.

The DRAFT Title V Permit was revised based on written comments received from Rich Piper of the Florida Power and Light Company, and subsequent clarifying phone conversations with him. I believe all concerns have been satisfactorily addressed, and recommend that the PROPOSED Permit Determination and PROPOSED Title V Permit be sent out as attached.



Department of Environmental Protection

Lawton Chiles
Governor

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400
October 24, 1997

Virginia B. Wetherell
Secretary

Mr. John M. Lindsay
Plant General Manager
Florida Power & Light Company
Environmental Services Department
P.O. Box 14000
Juno Beach, FL 33408

Re: PROPOSED Title V Permit No.: 0850001-004-AV
Martin Plant


Dear Mr. Lindsay:

One copy of the "PROPOSED PERMIT DETERMINATION" for the Martin Plant, located 7 miles North of Indiantown on State Road 710, Indiantown, Martin County, is enclosed. This letter is only a courtesy to inform you that the DRAFT permit has become a PROPOSED permit.

An electronic version of this determination has been posted on the Division of Air Resource Management's world wide web site for the United States Environmental Protection Agency (USEPA) Region 4 office's review. The web site address is <http://www.dep.state.fl.us/air>.

Pursuant to Section 403.0872(6), Florida Statutes, if no objection to the PROPOSED permit is made by the USEPA within 45 days, the PROPOSED permit will become a FINAL permit no later than 55 days after the date on which the PROPOSED permit was mailed (posted) to USEPA. If USEPA has an objection to the PROPOSED permit, the FINAL permit will not be issued until the permitting authority receives written notice that the objection is resolved or withdrawn. If you have any questions, please contact Tom Cascio at 850/488-1344.

Sincerely,

for 
C. H. Fancy, P.E.
Chief
Bureau of Air Regulation

CHF/c

Enclosures

copy furnished to:

Mr. William Muly Reichel, Florida Power & Light Company
Mr. Kennard F. Kosky, P.E., Golder Associates
Mr. Richard Piper, Florida Power & Light Company
Mr. Isidore Goldman, Southeast District Office
Ms. Carla E. Pierce, USEPA, Region 4 (INTERNET E-mail Memorandum)
Ms. Yolanda Adams, USEPA, Region 4 (INTERNET E-mail Memorandum)

"Protect, Conserve and Manage Florida's Environment and Natural Resources"

PROPOSED PERMIT DETERMINATION

PROPOSED Permit No.: 0850001-004-AV

Page 1 of 11

I. Public Notice.

An "INTENT TO ISSUE TITLE V AIR OPERATION PERMIT" to the Florida Power and Light Company for the Martin Plant, located 7 miles North of Indiantown on State Road 710, Indiantown, Martin County, was clerked on August 13, 1997. The "PUBLIC NOTICE OF INTENT TO ISSUE TITLE V AIR OPERATION PERMIT" was published in the Palm Beach Post on August 18, 1997. The DRAFT Title V Air Operation Permit was available for public inspection at the Department's Southeast District office in West Palm Beach and the permitting authority's office in Tallahassee. Proof of publication of the "PUBLIC NOTICE OF INTENT TO ISSUE TITLE V AIR OPERATION PERMIT" was received on August 22, 1997.

II. Public Comment(s).

Comments were received and the DRAFT Title V Operation Permit was changed. The comments were not considered significant enough to reissue the DRAFT Title V Permit and require another Public Notice. Comments were received from one respondent during the 30 (thirty) day public comment period. Listed below is a response to each comment in the letter in the same order as the comment was listed. The comments are not restated.

A. Letter from Mr. Richard Piper dated September 17, 1997, and received by fax on September 17, 1997.

Facility Description

1. Comment # 1:

Response: The Department agrees with the recommended clarifying language revision to the Facility Description.

As a result of this comment, **Section I, Subsection A's** second paragraph is hereby changed:

From:

Each combined cycle unit has the net capability of 385 MW and consists of two combustion turbines (CT), each nominally rated at 204 MW, which each exhaust through a separate unfired heat recovery steam generator (HRSG). Nitrogen oxide emissions are controlled by using dry low NOx combustors for natural gas with steam injection for fuel oil firing. In addition, the facility includes one auxiliary boiler, and two diesel generators (one unregulated). Also included in this permit are two unregulated emissions units identified as facility-wide particulate matter emissions and facility-wide VOC emissions.

To:

Each combined cycle unit has the net capability of 430 MW, at 95 degrees F, and consists of two combustion turbines (CTs), each nominally rated at 204 MW, which exhaust through a separate unfired heat recovery steam generator (HRSG). Nitrogen oxide emissions are controlled by using dry low NO_x combustors for natural gas with steam injection for fuel oil firing. Steam injection is also used for power augmentation. In addition, the facility includes one auxiliary boiler, and two diesel generators (one unregulated). Also included in this permit are two unregulated emissions units identified as facility-wide particulate matter emissions and facility-wide VOC emissions.

Fossil Fuel Fired Steam Generators

2. Comment # 2:

Response: The Department agrees that specific condition **A.10** does not apply to these emissions units. The condition has been removed from the PROPOSED permit and subsequent conditions renumbered.

3. Comment # 3:

Response: The Department agrees to express the NO_x prorated standard in terms of lb/MMBtu in place of ng/J.

As a result of this comment, specific condition **A.12** is hereby changed (renumbered to **A.11**):

From: Nitrogen Oxides. (a) No owner or operator shall cause to be discharged into the atmosphere from each of these emissions units any gases which contain nitrogen oxides, expressed as NO₂ in excess of:

(1) 86 nanograms per joule heat input (0.20 lb per million Btu) derived from gaseous fossil fuel. In addition, emissions shall not exceed 1,808 pounds per hour.

(2) 129 nanograms per joule heat input (0.30 lb per million Btu) derived from liquid fossil fuel. In addition, emissions shall not exceed 2,595 pounds per hour.

(b) When different fossil fuels are burned simultaneously in any combination, the applicable standard (in ng/J) is determined by proration using the following formula:

$$PS_{NO_x} = [x(86)+y(130)] / (x + y)$$

where:

PS_{NO_x} = is the prorated standard for nitrogen oxides when burning different fuels simultaneously, in nanograms per joule heat input derived from all fossil fuels fired;

x = is the percentage of total heat input derived from gaseous fossil fuel;

y = is the percentage of total heat input derived from liquid fossil fuel.

[40 CFR 60.44(a)(1)and (2); 40 CFR 60.44(b); AO43-170568 and AO43-170567]

To: Nitrogen Oxides. (a) No owner or operator shall cause to be discharged into the atmosphere from each of these emissions units any gases which contain nitrogen oxides, expressed as NO₂ in excess of:

(1) 86 nanograms per joule heat input (0.20-lb per million Btu) derived from gaseous fossil fuel. In addition, emissions shall not exceed 1,808 pounds per hour.

(2) 129 nanograms per joule heat input (0.30 lb per million Btu) derived from liquid fossil fuel. In addition, emissions shall not exceed 2,595 pounds per hour.

(b) When different fossil fuels are burned simultaneously in any combination, the applicable standard (in lb/MMBtu) is determined by proration using the following formula:

$$PS_{NO_x} = [x(.20)+y(.30)] / (x + y)$$

where:

PS_{NO_x} = is the prorated standard for nitrogen oxides when burning different fuels simultaneously, in lb/MMBtu heat input derived from all fossil fuels fired;

x = is the percentage of total heat input derived from gaseous fossil fuel;

y = is the percentage of total heat input derived from liquid fossil fuel.

[40 CFR 60.44(a)(1)and (2); 40 CFR 60.44(b); AO43-170568 and AO43-170567]

4. Comment # 4:

Response: The Department agrees that the three sub-conditions should be deleted.

As a result of this comment, specific condition **A.16** is hereby changed (renumbered to **A.15**):

From:

Excess emission and monitoring system performance reports shall be submitted to the Administrator for every calendar quarter. All quarterly reports shall be postmarked by the 30th day following the end of each calendar quarter. Each excess emission and MSP report shall include the information required in 40 CFR 60.7(c). Periods of excess emissions and monitoring systems (MS) downtime that shall be reported are defined as follows:

(1) Opacity. Excess emissions are defined as any six-minute period during which the average opacity of emissions exceeds 20 percent opacity, except that one six-minute average per hour of up to 27 percent opacity need not be reported.

(i) For sources subject to the opacity standard of 40 CFR 60.42(b)(1), excess emissions are defined as any six-minute period during which the average opacity of emissions exceeds 35 percent opacity, except that one six-minute average per hour of up to 42 percent opacity need not be reported.

(ii) For sources subject to the opacity standard of 40 CFR 60.42(b)(2), excess emissions are defined as any six-minute period during which the average opacity of emissions exceeds 32 percent opacity, except that one six-minute average per hour of up to 39 percent opacity need not be reported.

(iii) For sources subject to the opacity standard of 40 CFR 60.42(b)(3), excess emissions are defined as any six-minute period during which the average opacity of emissions exceeds 30 percent opacity, except that one six-minute average per hour of up to 37 percent opacity need not be reported.

(2) Sulfur dioxide. Excess emissions for affected facilities are defined as:

(i) Any three-hour period during which the average emissions (arithmetic average of three contiguous one-hour periods) of sulfur dioxide as measured by a continuous monitoring system exceed the applicable standard under 40 CFR 60.43.

(3) Nitrogen oxides. Excess emissions for affected facilities using a continuous monitoring system for measuring nitrogen oxides are defined as any three-hour period during which the average emissions (arithmetic average of three contiguous one-hour periods) exceed the applicable standards under 40 CFR 60.44.

[40 CFR 60.45(g)(1), (2), & (3)]

To:

Excess emission and monitoring system performance reports shall be submitted to the Administrator for every calendar quarter. All quarterly reports shall be postmarked by the 30th day following the end of each calendar quarter. Each excess emission and MSP report shall include the information required in 40 CFR 60.7(c). Periods of excess emissions and monitoring systems (MS) downtime that shall be reported are defined as follows:

(1) Opacity. Excess emissions are defined as any six-minute period during which the average opacity of emissions exceeds 20 percent opacity, except that one six-minute average per hour of up to 27 percent opacity need not be reported.

(2) Sulfur dioxide. Excess emissions for affected facilities are defined as:

(i) Any three-hour period during which the average emissions (arithmetic average of three contiguous one-hour periods) of sulfur dioxide as measured by a continuous monitoring system exceed the applicable standard under 40 CFR 60.43.

(3) Nitrogen oxides. Excess emissions for affected facilities using a continuous monitoring system for measuring nitrogen oxides are defined as any three-hour period during which the average emissions (arithmetic average of three contiguous one-hour periods) exceed the applicable standards under 40 CFR 60.44.

[40 CFR 60.45(g)(1), (2), & (3)]

Combustion Turbines with Heat Recovery Steam Generators

5. Comment # 5:

Response: The Department agrees to add power augmentation as a use for steam injection in the Description of these emissions units.

6. Comment # 6:

Response: The Department agrees with the requested change.

As a result of this comment, specific condition **B.3** is hereby revised:

From: Permitted Capacity. The maximum heat input to each Combustion Turbine (CT) shall neither exceed 1966 MMBtu/hr while firing natural gas, nor 1846 MMBtu/hr while firing fuel oil @40 degrees F. These heat input limitations are subject to change. Any changes shall be provided at least 90 days before commercial operation for each fuel available to the site which a unit is capable of firing, at which time this condition may be modified to reflect those parameters. Each combined cycle's fuel consumption shall be continuously determined and recorded.

[Rules 62-4.160(2) and 62-210.200(PTE), F.A.C.; PSD-FL-146, Specific Condition No. 1]

To: Permitted Capacity. The maximum heat input to each Combustion Turbine (CT) shall neither exceed 1966 MMBtu/hr while firing natural gas, nor 1846 MMBtu/hr while firing fuel oil @40 degrees F. These heat input limitations are subject to change. Any changes shall be provided at least 90 days before commercial operation for each fuel available to the site which a unit is capable of firing, at which time this condition may be modified to reflect those parameters. Each combined cycle's fuel consumption shall be continuously determined and recorded. Testing of emissions shall be conducted with the units operating at capacity. Capacity is defined as 95-100 percent of the manufacturer's rated heat input achievable for the average ambient (or conditioned) air temperature during the test. If it is impractical to test at capacity, then the units may be tested at less than capacity. In such cases, the entire heat input versus inlet temperature curves will be adjusted by the increment equal to the difference between the design heat input value and 105 percent of the value reached during the test. Data, curves, and calculations necessary to demonstrate the heat input rate correction at both design and test conditions shall be submitted to the Department with the compliance test report.

[Rules 62-4.160(2) and 62-210.200(PTE), F.A.C.; PSD-FL-146, Specific Condition No. 1]

7. Comment # 7:

Response: We have added the clarifying sentence to the specific condition **B.18**, "This specific condition does **not apply** if only natural gas is fired in the turbine."

8. Comment # 8:

Response: The Department agrees that the Customized Fuel Monitoring Schedule should be referenced.

As a result of this comment, new specific condition **B.20** is hereby added and subsequent conditions are renumbered:

B.20. The Florida Power and Light Company requested approval for and was granted approval to utilize a customized fuel monitoring schedule for natural gas firing, pursuant to 40 CFR 60.334(b), at the Martin Plant. See specific condition **B.19**. The schedule is as follows:

Custom Fuel Monitoring Schedule for Natural Gas (NG)

1. Monitoring of fuel nitrogen content shall not be required if NG gas is the only fuel being fired in the gas turbines.

2. Sulfur Monitoring

- a. Analysis for fuel sulfur content of the natural gas shall be conducted using one of the approved ASTM reference methods for the measurement of sulfur in gaseous fuels, or an approved alternative method. The reference methods are ASTM D1072-80, ASTM D3031-81, ASTM D3246-81, and ASTM D4084-82 as referenced in 40 CFR 60.335(b)(2), or the latest editions.
- b. This custom fuel monitoring schedule shall become effective on the date this permit becomes valid. Effective the date of this custom schedule, sulfur monitoring shall be conducted twice monthly for six months. If this monitoring shows little variability in the fuel sulfur content, and indicates consistent compliance with 40 CFR 60.333, then sulfur monitoring shall be conducted once per quarter for six quarters. If monitoring data is provided by the applicant which demonstrates consistent compliance with the requirements herein the applicant may begin monitoring as per the requirements of 2(c).
- c. If after the monitoring required in item 2(b) above, or herein, the sulfur content of the fuel shows little variability and, calculated as sulfur dioxide, represents consistent compliance with the sulfur dioxide emission limits specified under 40 CFR 60.333, sample analysis shall be conducted twice per annum. This monitoring shall be conducted during the first and third quarters of each calendar year.
- d. Should any sulfur analysis as required in items 2(b) or 2(c) above indicate noncompliance with 40 CFR 60.333, the owner or operator shall notify the Department of such excess emissions and the custom schedule shall be re-examined by the Environmental Protection Agency. Sulfur monitoring shall be conducted weekly during the interim period when this custom schedule is being re-examined.

3. If there is a change in fuel supply, the owner or operator must notify the Department of such change for re-examination of this custom schedule. A substantial change in fuel quality shall be considered as a change in fuel supply. Sulfur monitoring shall be conducted weekly during the interim period when this custom schedule is being re-examined.

4. Records of sample analysis and fuel supply pertinent to this custom schedule shall be retained for a period of five years, and be available for inspection by personnel of federal, state, and local air pollution control agencies.

[PSD-FL-146; NSPS Custom Fuel Monitoring Schedule dated 10/14/97]

9. Comments # 9 and # 10:

Response: The Department agrees to add the clarifying sentence, "This specific condition does **not** apply if only natural gas is fired in the turbine," to specific conditions **B.20** and **B.21** (renumbered **B.21** and **B.22**, respectively, in the PROPOSED Permit).

10. Comments # 11, # 12, and # 13:

Response: The Department agrees to add the clarifying sentence, "See specific condition **B.20** that describes the approved Custom Fuel Monitoring Schedule for Natural Gas for this facility," to specific conditions **B.22, B.23, and B.24** (renumbered **B.23, B.24, and B.25**, respectively, in the PROPOSED Permit).

11. Comment # 14:

Response: The Department believes that specific condition **B.25**, dealing with stack testing facilities, should properly be included in the PROPOSED Permit. It is renumbered **B.26**.

12. Comments # 15 and # 16:

Response: The Department agrees to add the clarifying sentence, "See specific condition **B.3** for utilization of ambient temperature versus heat input curves during compliance testing," to specific condition **B.26** (renumbered **B.27** in the PROPOSED Permit). Also, the requirement for annual VOC testing has been removed to correspond with the PSD permit amendment dated September 6, 1996.

13. Comment # 17:

Response: The Department agrees to adopt the appropriate language of the permit amendment noted.

As a result of this comment, specific condition **B.30** (renumbered **B.31**) is hereby changed:

From:

Continuous emissions monitoring shall be installed, operated, and maintained in accordance with 40 CFR 60, Appendix F, for each combined cycle unit to monitor nitrogen oxides.

(a) Each continuous emissions monitoring system (CEMS) shall meet performance specifications of 40 CFR 60, Appendix B.

(b) CEMS data shall be recorded and reported in accordance with 40 CFR 60. The record shall include periods of startup, shutdown, and malfunction.

(c) A malfunction means any sudden and unavoidable failure of air pollution equipment or process equipment to operate in a normal or usual manner. Failures that are caused entirely or in part by poor maintenance, careless operation or any other preventable upset condition or preventable equipment breakdown shall not be considered malfunctions.

(d) The procedures under 40 CFR 60.13 shall be followed for installation, evaluation and operation of all CEMS.

(e) For purposes of reports required under this permit, excess emissions are defined as any calculated average emission concentration which exceeds the applicable emission limits in specific condition **B.6**. [PSD-FL-146, Specific Condition No. 13]

To:

Continuous emissions monitoring shall be installed, operated, and maintained in accordance with 40 CFR 75 for each combined cycle unit to monitor nitrogen oxides.

(a) Each continuous emissions monitoring system (CEMS) shall meet performance specifications of 40 CFR 75, Appendices A, B, and F.

(b) CEMS data shall be recorded and reported in accordance with 40 CFR 75 and 40 CFR 60.7. The excess emissions report shall include periods of startup, shutdown, and malfunction and shall be based on NO_x data corrected to 15% O₂ and 40 degrees F.

(c) A malfunction means any sudden and unavoidable failure of air pollution equipment or process equipment to operate in a normal or usual manner. Failures that are caused entirely or in part by poor maintenance, careless operation or any other preventable upset condition or preventable equipment breakdown shall not be considered malfunctions.

(d) For purposes of reports required under this permit, excess emissions are defined as any calculated average emission concentration which exceeds the applicable emission limits in specific condition **B.6**. See specific condition **B.39**.

[PSD-FL-146, Specific Condition No. 13]

Auxiliary Boiler

14. Comment # 18:

Response: The Department agrees that specific condition **C.9** is superfluous and thus it has been deleted from the PROPOSED Permit and subsequent conditions renumbered.

15. Comment # 19:

Response: The Department agrees that specific condition **C.10** does not apply, since the boiler is only used for startup, shutdown, and periodic maintenance testing purposes. It has been deleted from the PROPOSED Permit and subsequent conditions renumbered.

16. Comment # 20:

Response: The Department agrees that the reference to fuels other than natural gas and distillate fuel oil should be deleted from specific condition **C.11** (renumbered **C.9**).

17. Comment # 21:

Response: The Department agrees that annual testing is not required if operational hours of the boiler are less than 400 hours per year using oil. However, testing is required for permit renewal. Specific condition **C.13** has been changed in the PROPOSED Permit to reflect this (renumbered **C.11**):

From:

Compliance and performance test methods and procedures for sulfur dioxide. Compliance with the percent reduction requirements and SO₂ emission limits under 40 CFR 60.42c is based on the average percent reduction and the average SO₂ emission rates for 30 consecutive steam generating unit operating days. A separate performance test is completed at the end of each steam generating unit operating day, and a new 30-day average percent reduction and SO₂ emission rate are calculated to show compliance with the standard.

[40 CFR 60.44c(c)]

To:

Compliance and performance test methods and procedures for sulfur dioxide. Compliance with the percent reduction requirements and SO₂ emission limits under 40 CFR 60.42c is based on the average percent reduction and the average SO₂ emission rates for 30 consecutive steam generating unit operating days. A separate performance test is completed at the end of each steam generating unit operating day, and a new 30-day average percent reduction and SO₂ emission rate are calculated to show compliance with the standard. **Note:** no annual testing is required if operational hours are less than 400 hours per year on oil. However, testing is required for permit renewal purposes.

[40 CFR 60.44c(c); and, Rule 62-297.310(7), F.A.C.]

18. Comment # 22:

Response: The Department believes that specific condition **C.14** is valid and it has been retained in the PROPOSED Permit and renumbered as **C.12**.

19. Comment # 23:

Response: The Department agrees that specific condition **C.19(a)** does not apply. It has been deleted from the PROPOSED Permit and renumbered as **C.17**.

20. Comment # 24:

Response: The Department agrees that reference to CEMs should be deleted. The specific condition was renumbered and rewritten as **C.17(b)**.

21. Comments # 25 and # 26:

Response: The Department agrees that as long as the boiler is only operated for startup, shutdown, and periodic maintenance testing purposes, specific conditions C.19(d) and (e) are not applicable. Renumbered specific condition C.17 reflects this case.

22. Comment # 27:

Response: The Department agrees that as long as the boiler is only operated for startup, shutdown, and periodic maintenance testing purposes, specific condition C.22 is not applicable. Renumbered specific condition C.20 reflects this case.

Diesel Generator

23. Comment # 28:

Response: The Department agrees to add the language “or for periodic operational testing” to specific condition D.1.

B. Electronic mail memorandum from Mr. Richard Piper dated September 18, 1997, and received on September 18, 1997.

Diesel Generator

24. Comment # 29:

Response: The Department agrees to the requested change concerning testing of fuel oil fired in the diesel generator.

As a result of this comment, specific condition **D.4** is hereby changed:

From:

Testing for the sulfur content, for the nitrogen content, and for the heating value of oil storage tanks shall be conducted once per day when firing oil using ASTM D 2880-96.
[PSD-FL-146, Specific Condition No. 11]

To:

Distillate fuel oil fired in the emergency diesel generator shall meet the specifications for fuel oil numbers 1 or 2, as defined by the American Society for Testing and Materials in ASTM D 396-78 (or the latest edition), “Standard Specifications for Fuel Oils.” Compliance with these specifications shall be verified with a fuel analysis provided by the vendor upon each fuel delivery.
[Requested by the applicant in electronic memorandum dated 09/18/97]

The enclosed PROPOSED Title V Air Operation Permit includes the aforementioned changes to the DRAFT Title V Air Operation Permit.

C. Documents on file with the permitting authority:

- Letter from Mr. Richard Piper dated September 17, 1997, and received by fax on September 17, 1997.
- Electronic mail memorandum from Mr. Richard Piper dated September 18, 1997, and received on September 18, 1997.

III. Conclusion.

The permitting authority will issue the PROPOSED Permit No.: 0850001-004-AV, with any changes noted above.

Florida Power & Light Company
Martin Plant
Facility ID No.: 0850001
Martin County

Initial Title V Air Operation Permit
PROPOSED Permit No.: 0850001-004-AV

Permitting Authority:

State of Florida
Department of Environmental Protection
Division of Air Resources Management
Bureau of Air Regulation
Title V Section

Mail Station #5505
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Telephone: 850/488-1344
Fax: 850/922-6979

October 24, 1997

Compliance Authority:

Department of Environmental Protection
Southeast District

400 North Congress Avenue
West Palm Beach, Florida 33416-5425

Telephone: 407/681-6600
Fax: 407/681-6755

Initial Title V Air Operation Permit
PROPOSED Permit No.: 0850001-004-AV

Table of Contents

<u>Section</u>	<u>Page Number</u>
Placard Page.....	1
I. Facility Information.....	2
A. Facility Description.	
B. Summary of Emissions Unit ID Nos. and Brief Descriptions.	
C. Relevant Documents	
II. Facility-wide Conditions.....	4
III. Emissions Units and Conditions	
A. Emissions Units -001 and -002, Fossil Fuel Fired Steam Generators.....	7
B. Emissions Units -003 to -006, Combustion Turbines with HRSGs.....	24
C. Emissions Unit -007, Auxiliary Boiler.....	41
D. Emissions Unit -009, Diesel Generator.....	48
E. Common Conditions.....	49
IV. Acid Rain Part	
A. Acid Rain, Phase II.....	56
Appendix E-1. List of Exempt Emissions Units and/or Activities.....	58
Appendix U-1. List of Unregulated Emissions Units and/or Activities.....	60
Appendix H-1. Permit History/ID Number Changes.....	61



Department of Environmental Protection

Lawton Chiles
Governor

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Virginia B. Wetherell
Secretary

Permittee:

Florida Power & Light Company
P.O. Box 176
Indiantown, FL 34956-0176

PROPOSED Permit No.: 0850001-004-AV

Facility ID No.: 0850001

SIC Nos.: 49, 4911

Project: Initial Title V Air Operation Permit

This permit is for the operation of the Martin Plant. This facility is located 7 miles North of Indiantown on State Road 710, Indiantown, Martin County; UTM Coordinates: Zone 17, 543.2 km East and 2993.0 km North; Latitude: 27° 03' 29" North and Longitude: 80° 33' 54" West.

STATEMENT OF BASIS: This Title V air operation permit is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, 62-213, and 62-214. The above named permittee is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans, and other documents, attached hereto or on file with the permitting authority, in accordance with the terms and conditions of this permit.

Referenced attachments made a part of this permit:

Appendix E-1, List of Exempt Emissions Units and/or Activities

Appendix U-1, List of Unregulated Emissions Units and/or Activities

APPENDIX TV-1, TITLE V CONDITIONS (version dated 08/11/97)

APPENDIX SS-1, STACK SAMPLING FACILITIES (version dated 10/27/96)

FIGURE 1- SUMMARY REPORT - GASEOUS AND OPACITY EXCESS EMISSIONS AND
MONITORING SYSTEMS PERFORMANCE REPORT

Phase II Acid Rain Application/Compliance Plan received December 6, 1995

NSPS Custom Fuel Monitoring Schedule dated October 14, 1997

Order Extending Permit Expiration Date

Effective Date: January 1, 1998

Renewal Application Due Date: July 5, 2002

Expiration Date: January 1, 2003

Howard L. Rhodes, Director,
Division of Air Resources
Management

HLR/sms/tbc

Section I. Facility Information.

Subsection A. Facility Description.

This facility consists of two oil and natural gas fired conventional steam electric generating stations, and two oil and natural gas fired combined cycle units. Each conventional steam unit has the maximum capacity of 863.3 megawatts (MW) and consists of a boiler/steam generator which drives a single reheat turbine generator, and is equipped with low NOx dual fuel firing burners to reduce emissions of nitrogen oxides; and, multicyclones, with fly ash reinjection, to control particulate matter emissions.

Each combined cycle unit has the net capability of 430 MW, at 95 degrees F, and consists of two combustion turbines (CTs), each nominally rated at 204 MW, which exhaust through a separate unfired heat recovery steam generator (HRSG). Nitrogen oxide emissions are controlled by using dry low NOx combustors for natural gas with steam injection for fuel oil firing. Steam injection is also used for power augmentation. In addition, the facility includes one auxiliary boiler, and two diesel generators (one unregulated). Also included in this permit are two unregulated emissions units identified as facility-wide particulate matter emissions and facility-wide VOC emissions.

Based on the initial Title V permit application received June 12, 1996, this facility is a major source of hazardous air pollutants (HAPs).

Subsection B. Summary of Emissions Unit ID Nos. and Brief Descriptions.

E.U. ID

<u>No.</u>	<u>Brief Description</u>
-001	Fossil Fuel Fired Steam Generator #1
-002	Fossil Fuel Fired Steam Generator #2
-003	Combustion Turbine with Heat Recovery Steam Generator (CT 3A)
-004	Combustion Turbine with Heat Recovery Steam Generator (CT 3B)
-005	Combustion Turbine with Heat Recovery Steam Generator (CT 4A)
-006	Combustion Turbine with Heat Recovery Steam Generator (CT 4B)
-007	Auxiliary Boiler (for Units -003 to -006)
-009	Diesel Generator (0.718 MW, for Units -003 to -006)

Unregulated Emissions Units and/or Activities

-xxx	Diesel Generator (for Units -001 and -002)
-xxx	Facility-wide Fugitive Emissions for PM
-xxx	Facility-wide Fugitive Emissions for VOC's

Please reference the Permit No., Facility ID No., and appropriate Emissions Units ID Nos. on all correspondence, test report submittals, applications, etc.

Subsection C. Relevant Documents.

The documents listed below are not a part of this permit, however they are specifically related to this permitting action.

These documents are provided to the permittee for information purposes only:

Table 1-1, Summary of Air Pollution Standards and Terms

Table 2-1, Summary of Compliance Requirements

Appendix A-1, Abbreviations, Acronyms, Citations, and Identification Numbers

Appendix H-1, Permit History/ID Number Changes

These documents are on file with the permitting authority:

Initial Title V Permit Application received June 12, 1996.

Additional Information Request dated September 30, 1996.

Additional Information Response received December 23, 1996.

Additional Information Request dated January 13, 1996.

Additional Information Response received January 29, 1997.

Additional Information Request dated February 13, 1997.

Additional Information Response received May 20, 1997.

Comments from Florida Power & Light received by fax on September 17, 1997.

Electronic mail memorandum from Mr. Richard Piper received September 18, 1997.

Section II. Facility-wide Conditions.

The following conditions apply facility-wide:

1. APPENDIX TV-1, TITLE V CONDITIONS, is a part of this permit.
{Permitting note: Appendix TV-1, Title V Conditions is distributed to the permittee only. Other persons requesting copies of these conditions shall be provided one copy when requested or otherwise appropriate.}
2. **Not federally enforceable.** General Pollutant Emission Limiting Standards. Objectionable Odor Prohibited. The permittee shall not cause, suffer, allow, or permit the discharge of air pollutants which cause or contribute to an objectionable odor.
[Rule 62-296.320(2), F.A.C.]
3. Prevention of Accidental Releases (Section 112(r) of CAA). If required by 40 CFR 68, the permittee shall submit to the implementing agency:
 - a. a risk management plan (RMP) when, and if, such requirement becomes applicable, and
 - b. certification forms and/or RMPs according to the promulgated rule schedule.[40 CFR 68]
4. Exempt Emissions Units and/or Activities. Appendix E-1, List of Exempt Emissions Units and/or Activities, is a part of this permit.
[Rules 62-213.440(1), 62-213.430(6), and 62-4.040(1)(b), F.A.C.]
5. Unregulated Emissions Units and/or Activities. Appendix U-1, List of Unregulated Emissions Units and/or Activities, is a part of this permit.
[Rule 62-213.440(1), F.A.C.]
6. General Particulate Emission Limiting Standards. General Visible Emissions Standard. Except for emissions units that are subject to a particulate matter or opacity limit set forth or established by rule and reflected by conditions of this permit, no person shall cause, let, permit, suffer or allow to be discharged into the atmosphere the emissions of air pollutants from any activity, the density of which is equal to or greater than that designated as Number 1 on the Ringelmann Chart (20 percent opacity). EPA Method 9 is the method of compliance pursuant to Chapter 62-297, F.A.C.
[Rules 62-296.320(4)(b)1. & 4., F.A.C.]
7. **Not federally enforceable.** Reasonable precautions to prevent emissions of unconfined particulate matter at this facility include the following:
 - a. In order to perform sandblasting on fixed plant equipment, sandblasting enclosures are constructed and operated as necessary. Hoods, fans, and filters are used to contain and capture the sand.

- b. Maintenance of paved areas is performed as needed.
- c. Mowing of grass and care of vegetation are done on a regular basis.
- d. Access to plant property by unnecessary vehicles is controlled and limited.
- e. Bagged chemical products are stored in concrete block buildings until they are used. Spills of powdered chemical products are cleaned up as soon as practical.

[Rule 62-296.320(4)(c)2., F.A.C.; Proposed by applicant in the initial Title V permit application received June 12, 1996.]

- 8. All fugitive dust generated at this site shall be adequately controlled. This includes, but is not limited to, roadway dust.

[Rule 62-296.320(4)(c)2, F.A.C.; AC43-4037; AC43-4038]

- 9. When appropriate, any recording, monitoring, or reporting requirements that are time-specific shall be in accordance with the effective date of the permit, which defines day one.

[Rule 62-213.440, F.A.C.]

- 10. The permittee shall submit all compliance related notifications and reports required of this permit to the Department's Southeast District office:

Department of Environmental Protection
Southeast District
400 North Congress Avenue
West Palm Beach, Florida 33416-5425
Telephone: 407/681-6600
Fax: 407/681-6755

- 11. Please be advised that the Department does not condone nor authorize the permittee to bypass waste materials from either air or wastewater facilities at any time that would result in a violation of the rules and regulations of the Department. In case of breakdown or lack of proper functioning of the facility causing or likely to cause discharge of improperly treated sewage or air emissions, it shall be the duty of the owner of the facility to promptly notify the Department. In addition to notifying this Department, the permittee shall notify the local County Health Officer. The owner of the impaired facility causing the violation shall be responsible for any and all damages which may result. If violations of State standards occur, enforcement actions may be initiated.

[AC43-4037; AC43-4038]

12. Any reports, data, notifications, certifications, and requests required to be sent to the United States Environmental Protection Agency, Region 4, should be sent to:

United States Environmental Protection Agency
Region 4
Air, Pesticides & Toxics Management Division
Operating Permits Section
61 Forsyth Street
Atlanta, Georgia 30303
Telephone: 404/562-9099
Fax: 404/562-9095

13. Statement of Compliance. The annual statement of compliance pursuant to Rule 62-213.440(3), F.A.C., shall be submitted within 60 (sixty) days after the end of the calendar year. {See condition No. 51., Appendix TV-1, Title V Conditions.}
[Rule 62-214.420(11), F.A.C.]

Section III. Emissions Units and Conditions.

Subsection A. This section addresses the following emissions units.

E.U. ID

<u>No.</u>	<u>Brief Description</u>
-001	Fossil Fuel Fired Steam Generator #1
-002	Fossil Fuel Fired Steam Generator #2

Both emissions units are identical in configuration and each one is an 863.3 MW maximum capacity fossil fuel fired steam generator unit, equipped with low NOx dual fuel firing burners to reduce emissions of nitrogen oxides; and, multicyclones, with fly ash reinjection, to control particulate matter emissions. In addition, the units have a continuous emission monitoring system for measuring opacity, NOx, and sulfur dioxide. Unit #1 commenced commercial operation in December, 1980. Unit #2 commenced commercial operation in June, 1981.

{Permitting note: The emissions units are regulated under Acid Rain, Phase II and NSPS - 40 CFR 60, Subpart D, Standards of Performance for Fossil-Fuel-Fired Steam Generators; adopted and incorporated by reference in Rule 62-204.800(7)(b)1., F.A.C.}

The following conditions apply to the emissions units listed above:

General

A.1. Definitions. For the purposes of Rule 62-204.800(7), F.A.C., the definitions contained in the various provisions of 40 CFR 60, shall apply except that the term "Administrator" when used in 40 CFR 60, shall mean the Secretary or the Secretary's designee.

[40 CFR 60.2; Rule 62-204.800(7)(a), F.A.C.]

Essential Potential to Emit (PTE) Parameters

A.2. Permitted Capacity. Each boiler's maximum heat input is 8,650 MMBtu/hr on oil and 9,040 MMBtu/hr on natural gas. When a blend of fuel oil and natural gas is burned, the heat input is prorated based on the percent heat input of each fuel.

[Rules 62-4.160(2) and 62-210.200(PTE), F.A.C.; AC43-4037; AC43-4038]

A.3. Methods of Operation. Fuels. The only fuels allowed to be burned are low sulfur fuel oil containing a maximum of 0.7% sulfur content, by weight; natural gas; or, a mixture of low sulfur fuel oil containing a maximum of 1.0% sulfur content, by weight, and natural gas in a ratio that shall not exceed the sulfur dioxide emission limiting standard of 0.80 pounds per million Btu heat input.

[Rule 62-213.410, F.A.C.; AC43-4037; AC43-4038]

A.4. Hours of Operation. The emissions units may operate continuously, i.e., 8760 hours/year.

[Rule 62-210.200(PTE), F.A.C.]

Emission Limitations and Standards

{Permitting note: Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

A.5. Particulate Matter. No owner or operator shall cause to be discharged into the atmosphere from each of these emissions units any gases which:

(1) Contain particulate matter in excess of 43 nanograms per joule heat input (0.10 lb per million Btu) derived from fossil fuel.

(2) In addition, emissions shall not exceed 865 pounds per hour when firing 100 percent oil.
[40 CFR 60.42(a)(1); AO43-170568 and AO43-170567]

A.6. Particulate Matter - Soot Blowing and Load Change. Particulate matter emissions shall not exceed an average of 0.3 pound per million Btu heat input during the 3-hours in any 24-hour period of excess emissions allowed for boiler cleaning (soot blowing) and load change.

[Rule 62-210.700(3), F.A.C.]

A.7. Opacity. Compliance with standards in 40 CFR 60, other than opacity standards, shall be determined only by performance tests established by 40 CFR 60.8, unless otherwise specified in the applicable standard.

[40 CFR 60.11(a)]

A.8. Opacity. The opacity standards set forth in 40 CFR 60 shall apply at all times except during periods of startup, shutdown, malfunction, and as otherwise provided in the applicable standard.

[40 CFR 60.11(c)]

A.9. Visible Emissions. No owner or operator shall cause to be discharged into the atmosphere from each of these emissions units any gases which exhibit greater than 20 percent opacity except for one six-minute period per hour of not more than 27 percent opacity.

[40 CFR 60.42(a)(2)]

A.10. Sulfur Dioxide. (a) No owner or operator shall cause to be discharged into the atmosphere from each of these emissions units any gases which contain sulfur dioxide in excess of:

(1) 340 nanograms per joule heat input (0.80 lb per million Btu) derived from liquid fossil fuel.

(2) In addition, emissions shall not exceed 6,920 pounds per hour when firing 100 percent oil.

(c) Compliance shall be based on the total heat input from all fossil fuels burned, including gaseous fuels.

[40 CFR 60.43(a)(1) and (c); AO43-170568 and AO43-170567]

A.11. Nitrogen Oxides. (a) No owner or operator shall cause to be discharged into the atmosphere from each of these emissions units any gases which contain nitrogen oxides, expressed as NO₂ in excess of:

- (1) 86 nanograms per joule heat input (0.20 lb per million Btu) derived from gaseous fossil fuel. In addition, emissions shall not exceed 1,808 pounds per hour.
- (2) 129 nanograms per joule heat input (0.30 lb per million Btu) derived from liquid fossil fuel. In addition, emissions shall not exceed 2,595 pounds per hour.

(b) When different fossil fuels are burned simultaneously in any combination, the applicable standard (in lb/MMBtu) is determined by proration using the following formula:

$$PS_{NOx} = [x(.20)+y(.30)] / (x + y)$$

where:

PS_{NOx} = is the prorated standard for nitrogen oxides when burning different fuels simultaneously, in lb/MMBtu heat input derived from all fossil fuels fired;

x = is the percentage of total heat input derived from gaseous fossil fuel;
y = is the percentage of total heat input derived from liquid fossil fuel.

[40 CFR 60.44(a)(1)and (2); 40 CFR 60.44(b); AO43-170568 and AO43-170567]

A.12. "On-Specification" Used Oil. Only "on-specification" used oil generated by the Florida Power and Light Company in the production and distribution of electricity shall be fired in these emissions units. The total combined quantity allowed to be fired at these emissions units shall not exceed 1,500,000 gallons per calendar year. "On-specification" used oil is defined as each used oil delivery that meets the 40 CFR 279 (Standards for the Management of Used Oil) specifications listed below. Used oil that does not meet all of the following specifications is considered "off-specification" used oil and shall not be fired. See specific conditions **A.21.**, **A.42.** and **A.43.**

CONSTITUENT/PROPERTY*	ALLOWABLE LEVEL
Arsenic	5 ppm maximum
Cadmium	2 ppm maximum
Chromium	10 ppm maximum
Lead	100 ppm maximum
Total Halogens	1000 ppm maximum
Flashpoint	100 degrees F minimum
PCBs	less than 50 ppm

* As determined by approved methods specified in EPA Publication SW-846 (Test Methods for Evaluating Solid Waste, Physical/Chemical Methods).

[40 CFR 279.11; and AO43-170568, AO43-170567]

Excess Emissions

A.13. At all times, including periods of startup, shutdown, and malfunction, owners and operators shall, to the extent practicable, maintain and operate any affected facility including associated air pollution control equipment in a manner consistent with good air pollution control practice for minimizing emissions. Determination of whether acceptable operating and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, opacity observations, review of operating and maintenance procedures, and inspection of the source.
[40 CFR 60.11(d)]

A.14. In order to minimize excess emissions during startup/shutdown/malfunction the following general procedures shall be followed:

Excess emissions resulting from startup, shutdown or malfunction of any emissions unit shall be permitted providing (1) best operational practices to minimize emissions are adhered to and (2) the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration.
[Rules 62-210.700(1) & (2), F.A.C.; AO43-170568, Specific Condition No.9; AO43-170567, Specific Condition No.9]

A.15. Excess emission and monitoring system performance reports shall be submitted to the Administrator for every calendar quarter. All quarterly reports shall be postmarked by the 30th day following the end of each calendar quarter. Each excess emission and MSP report shall include the information required in 40 CFR 60.7(c). Periods of excess emissions and monitoring systems (MS) downtime that shall be reported are defined as follows:

(1) Opacity. Excess emissions are defined as any six-minute period during which the average opacity of emissions exceeds 20 percent opacity, except that one six-minute average per hour of up to 27 percent opacity need not be reported.

(2) Sulfur dioxide. Excess emissions for affected facilities are defined as:

(i) Any three-hour period during which the average emissions (arithmetic average of three contiguous one-hour periods) of sulfur dioxide as measured by a continuous monitoring system exceed the applicable standard under 40 CFR 60.43.

(3) Nitrogen oxides. Excess emissions for affected facilities using a continuous monitoring system for measuring nitrogen oxides are defined as any three-hour period during which the average emissions (arithmetic average of three contiguous one-hour periods) exceed the applicable standards under 40 CFR 60.44.

[40 CFR 60.45(g)(1), (2), & (3)]

Test Methods and Procedures

{Permitting note: Table 2-1, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

A.16. Opacity. Compliance with opacity standards in 40 CFR 60 shall be determined by conducting observations in accordance with Reference Method 9 in Appendix A of 40 CFR 60, any alternative method that is approved by the Administrator, or as provided in 40 CFR 60.11(e)(5).

[40 CFR 60.11(b)]

A.17. Performance tests shall be conducted under such conditions as the Administrator shall specify to the plant operator based on representative performance of the affected facility. The owner or operator shall make available to the Administrator such records as may be necessary to determine the conditions of the performance tests. Operations during periods of startup, shutdown, and malfunction shall not constitute representative conditions for the purpose of a performance test nor shall emissions in excess of the level of the applicable emission limit during periods of startup, shutdown, and malfunction be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard.

[40 CFR 60.8(c)]

A.18. (b) The owner or operator shall determine compliance with the particulate matter, SO₂, and NO_x standards in 40 CFR 60.42, 60.43, and 60.44 as follows:

(1) The emission rate (E) of particulate matter, SO₂, or NO_x shall be computed for each run using the following equation:

$$E = C F_d (20.9)/(20.9 - \% O_2)$$

E = emission rate of pollutant, ng/J (1b/million Btu).

C = concentration of pollutant, ng/dscm (1b/dscf).

% O₂ = oxygen concentration, percent dry basis.

F_d = factor as determined from Method 19.

(2) Method 5 shall be used to determine the particulate matter concentration (C) at affected facilities without wet flue-gas-desulfurization (FGD) systems and Method 5B shall be used to determine the particulate matter concentration (C) after FGD systems.

(i) The sampling time and sample volume for each run shall be at least 60 minutes and 0.85 dscm (30 dscf). The probe and filter holder heating systems in the sampling train may be set to provide a gas temperature no greater than 160 ± 14 °C (320 ± 25 °F).

(ii) The emission rate correction factor, integrated or grab sampling and analysis procedure of Method 3B shall be used to determine the O₂ concentration (%O₂). The O₂ sample shall be obtained simultaneously with, and at the same traverse points as, the particulate sample. If the grab sampling procedure is used, the O₂ concentration for the run shall be the arithmetic mean of all the individual O₂ sample concentrations at each traverse point.

(iii) If the particulate run has more than 12 traverse points, the O₂ traverse points may be reduced to 12 provided that Method 1 is used to locate the 12 O₂ traverse points.

- (3) Method 9 and the procedures in 40 CFR 60.11 shall be used to determine opacity.
- (4) Method 6 shall be used to determine the SO₂ concentration.
- (i) The sampling site shall be the same as that selected for the particulate sample. The sampling location in the duct shall be at the centroid of the cross section or at a point no closer to the walls than 1 m (3.28 ft). The sampling time and sample volume for each sample run shall be at least 20 minutes and 0.020 dscm (0.71 dscf). Two samples shall be taken during a 1-hour period, with each sample taken within a 30-minute interval.
- (ii) The emission rate correction factor, integrated sampling and analysis procedure of Method 3B shall be used to determine the O₂ concentration (%O₂). The O₂ sample shall be taken simultaneously with, and at the same point as, the SO₂ sample. The SO₂ emission rate shall be computed for each pair of SO₂ and O₂ samples. The SO₂ emission rate (E) for each run shall be the arithmetic mean of the results of the two pairs of samples.
- (5) Method 7 shall be used to determine the NO_x concentration.
- (i) The sampling site and location shall be the same as for the SO₂ sample. Each run shall consist of four grab samples, with each sample taken at about 15-minute intervals.
- (ii) For each NO_x sample, the emission rate correction factor, grab sampling and analysis procedure of Method 3B shall be used to determine the O₂ concentration (%O₂). The sample shall be taken simultaneously with, and at the same point as, the NO_x sample.
- (iii) The NO_x emission rate shall be computed for each pair of NO_x and O₂ samples. The NO_x emission rate (E) for each run shall be the arithmetic mean of the results of the four pairs of samples.
- (c) When combinations of fossil fuels are fired, the owner or operator (in order to compute the prorated standard as shown in 40 CFR 60.43(b) and 60.44(b)) shall determine the percentage (x or y) of the total heat input derived from each type of fuel as follows:
- (1) The heat input rate of each fuel shall be determined by multiplying the gross calorific value of each fuel fired by the rate of each fuel burned.
- (2) ASTM Methods D 240-76 (liquid fuels), or D 1826-77 (gaseous fuels) (incorporated by reference-see 40 CFR 60.17) shall be used to determine the gross calorific values of the fuels.
- (3) Suitable methods shall be used to determine the rate of each fuel burned during each test period, and a material balance over the steam generating system shall be used to confirm the rate.
- (d) The owner or operator may use the following as alternatives to the reference methods and procedures in 40 CFR 60.46 or in other sections as specified:
- (1) The emission rate (E) of particulate matter, SO₂ and NO_x may be determined by using the F_c factor, provided that the following procedure is used:
- (i) The emission rate (E) shall be computed using the following equation:

$$E = C F_c (100 / \%CO_2)$$

where:

E = emission rate of pollutant, ng/J (lb/million Btu).

C = concentration of pollutant, ng/dscm (lb/dscf).

%CO₂ = carbon dioxide concentration, percent dry basis.

F_c = factor as determined in appropriate sections of Method 19.

(ii) If and only if the average F_c factor in Method 19 is used to calculate E and either E is from 0.97 to 1.00 of the emission standard or the relative accuracy of a continuous emission monitoring system is from 17 to 20 percent, then three runs of Method 3B shall be used to determine the O_2 and CO_2 concentration according to the procedures in 40 CFR 60.46(b)(2)(ii), (4)(ii), or (5)(ii). Then if F_o (average of three runs), as calculated from the equation in Method 3B, is more than ± 3 percent than the average F_o value, as determined from the average values of F_d and F_c in Method 19, i.e., $F_{oa} = 0.209 (F_{da} / F_{ca})$, then the following procedure shall be followed:

(A) When F_o is less than $0.97 F_{oa}$, then E shall be increased by that proportion under $0.97 F_{oa}$, e.g., if F_o is $0.95 F_{oa}$, E shall be increased by 2 percent. This recalculated value shall be used to determine compliance with the emission standard.

(B) When F_o is less than $0.97 F_{oa}$ and when the average difference (\bar{d}) between the continuous monitor minus the reference methods is negative, then E shall be increased by that proportion under $0.97 F_{oa}$, e.g., if F_o is $0.95 F_{oa}$, E shall be increased by 2 percent. This recalculated value shall be used to determine compliance with the relative accuracy specification.

(C) When F_o is greater than $1.03 F_{oa}$ and when \bar{d} is positive, then E shall be decreased by that proportion over $1.03 F_{oa}$, e.g., if F_o is $1.05 F_{oa}$, E shall be decreased by 2 percent. This recalculated value shall be used to determine compliance with the relative accuracy specification.

(2) For Method 5 or 5B, Method 17 may be used at facilities with or without wet FGD systems if the stack gas temperature at the sampling location does not exceed an average temperature of $160^\circ C$ ($320^\circ F$). The procedures of sections 2.1 and 2.3 of Method 5B may be used with Method 17 only if it is used after wet FGD systems. Method 17 shall not be used after wet FGD systems if the effluent gas is saturated or laden with water droplets.

(3) Particulate matter and SO_2 may be determined simultaneously with the Method 5 train provided that the following changes are made:

(i) The filter and impinger apparatus in sections 2.1.5 and 2.1.6 of Method 8 is used in place of the condenser (section 2.1.7) of Method 5.

(ii) All applicable procedures in method 8 for the determination of SO_2 including moisture) are used:

(4) For Method 6, Method 6C may be used. Method 6A may also be used whenever Methods 6 and 3B data are specified to determine the SO_2 emission rate, under the conditions in 40 CFR 60.46(d)(1).

(5) For Method 7, Method 7A, 7C, 7D, or 7E may be used. If Method 7C, 7D, or 7E is used, the sampling time for each run shall be at least 1 hour and the integrated sampling approach shall be used to determine the O_2 concentration ($\%O_2$) for the emission rate correction factor.

(6) For Method 3, Method 3A or 3B may be used.

(7) For Method 3B, Method 3A may be used.

[40 CFR 60.46(b), (c) and (d)]

A.19. Operating Rate During Testing. Unless otherwise stated in the applicable emission limiting standard rule, testing of emissions shall be conducted with the emissions unit operation at permitted capacity, which is defined as 90 to 100 percent of the maximum operation rate at the permitted capacity. If it is impracticable to test at permitted capacity, an emissions unit may be tested at less than the minimum permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test load until a new test is conducted. Once the unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity.

[Rules 62-297.310(2) & (2)(b), F.A.C.; AO43-170568, Specific Condition No.1; AO43-170567, Specific Condition No. 1]

A.20. All compliance tests shall be performed using reference test methods as given in 40 CFR 60, Appendix A, as adopted by reference in Rule 62-297.400, F.A.C. Any deviations from the test methodology in order to facilitate "representative" testing shall be approved by the Department pursuant to Rule 62-297.620, F.A.C., prior to conducting the tests.

[40 CFR 60, Appendix A; Rule 62-297.400, F.A.C.; Rule 62-297.620, F.A.C.; AO43-170568, Specific Condition No. 3; AO43-170567, Specific Condition No. 3]

A.21. Compliance with the "on-specification" used oil requirements will be determined from a sample collected from each batch delivered for firing. See specific conditions **A.12.**, **A.42.** and **A.43.**

[Rules 62-4.070 and 62-213.440; and, 40 CFR 279]

Continuous Monitoring Requirements

A.22. The permittee has installed and shall continue to calibrate, maintain, and operate continuous monitoring systems for measuring the opacity of emissions, sulfur dioxide emissions, nitrogen oxides emissions, and carbon dioxide emissions.

[40 CFR 60.45(a)]

A.23. For the purposes of 40 CFR 60.13, all continuous monitoring systems required under applicable subparts shall be subject to the provisions of 40 CFR 60.13 upon promulgation of performance specifications for continuous monitoring systems under Appendix B of 40 CFR 60 and, if the continuous monitoring system is used to demonstrate compliance with emission limits on a continuous basis, Appendix F of 40 CFR 60, unless otherwise specified in an applicable subpart or by the Administrator. Appendix F is applicable December 4, 1987.

[40 CFR 60.13(a)]

A.24. If the owner or operator of an affected facility elects to submit continuous opacity monitoring system (COMS) data for compliance with the opacity standard as provided under 40 CFR 60.11(e)(5), he shall conduct a performance evaluation of the COMS as specified in Performance Specification 1, Appendix B, of 40 CFR 60 before the performance test required under 40 CFR 60.8 is conducted. Otherwise, the owner or operator of an affected facility shall conduct a performance evaluation of the COMS or continuous emission monitoring system (CEMS) during any performance test required under 40 CFR 60.8 or within 30 days thereafter in accordance with the applicable performance specification in Appendix B of 40 CFR 60. The

owner or operator of an affected facility shall conduct COMS or CEMS performance evaluations at such other times as may be required by the Administrator under section 114 of the Act.

[40 CFR 60.13(c)]

A.25. The owner or operator of an affected facility subject to an opacity standard may submit, for compliance purposes, continuous opacity monitoring system (COMS) data results produced during any performance test required under 40 CFR 60.8 in lieu of Method 9 observation data. If an owner or operator elects to submit COMS data for compliance with the opacity standard, he shall notify the Administrator of that decision, in writing, at least 30 days before any performance test required under 40 CFR 60.8 is conducted. Once the owner or operator of an affected facility has notified the Administrator to that effect, the COMS data results will be used to determine opacity compliance during subsequent tests required under 40 CFR 60.8 until the owner or operator notifies the Administrator, in writing, to the contrary. For the purpose of determining compliance with the opacity standard during a performance test required under 40 CFR 60.8 using COMS data, the minimum total time of COMS data collection shall be averages of all 6-minute continuous periods within the duration of the mass emission performance test. Results of the COMS opacity determinations shall be submitted along with the results of the performance test required under 60.8. The owner or operator of an affected facility using a COMS for compliance purposes is responsible for demonstrating that the COMS meets the requirements specified in 40 CFR 60.13(c), that the COMS has been properly maintained and operated, and that the resulting data have not been altered in any way. If COMS data results are submitted for compliance with the opacity standard for a period of time during which Method 9 data indicates noncompliance, the Method 9 data will be used to determine opacity compliance.
[40 CFR 60.11(e)(5)]

A.26. (1) Owners and operators of all continuous emission monitoring systems (CEMS) installed in accordance with the provisions of this part shall check the zero (or low-level value between 0 and 20 percent of span value) and span (50 to 100 percent of span value) calibration drifts at least once daily in accordance with a written procedure. The zero and span shall, as a minimum, be adjusted whenever the 24-hour zero drift or 24-hour span drift exceeds two times the limits of the applicable performance specifications in Appendix B. The system must allow the amount of excess zero and span drift measured at the 24-hour interval checks to be recorded and quantified, whenever specified. For continuous monitoring systems measuring opacity of emissions, the optical surfaces exposed to the effluent gases shall be cleaned prior to performing the zero and span drift adjustments except that for systems using automatic zero adjustments. The optical surfaces shall be cleaned when the cumulative automatic zero compensation exceeds 4 percent opacity.

(2) Unless otherwise approved by the Administrator, the following procedures shall be followed for continuous monitoring systems measuring opacity of emissions. Minimum procedures shall include a method for producing a simulated zero opacity condition and an upscale (span) opacity condition using a certified neutral density filter or other related technique to produce a known obscuration of the light beam. Such procedures shall provide a system check of the analyzer internal optical surfaces and all electronic circuitry including the lamp and photo detector assembly.

[40 CFR 60.13(d)(1) and (2)]

A.27. Except for system breakdowns, repairs, calibration checks, and zero and span adjustments required under 40 CFR 60.13(d), all continuous monitoring systems (CMS) shall be in continuous operation and shall meet minimum frequency of operation requirements as follows:

(1) All continuous monitoring systems referenced by 40 CFR 60.13(c) for measuring opacity of emissions shall complete a minimum of one cycle of sampling and analyzing for each successive 10-second period and one cycle of data recording for each successive 6-minute period.

(2) All continuous monitoring systems referenced by 40 CFR 60.13(c) for measuring emissions, except opacity, shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period.

[40 CFR 60.13(e)(1) and (2)]

A.28. All continuous monitoring systems (CMS) or monitoring devices shall be installed such that representative measurements of emissions or process parameters from the affected facility are obtained. Additional procedures for location of continuous monitoring systems contained in the applicable Performance Specifications of Appendix B of 40 CFR 60 shall be used.

[40 CFR 60.13(f)]

A.29. When the effluents from a single affected facility or two or more affected facilities subject to the same emission standards are combined before being released to the atmosphere, the owner or operator may install applicable continuous monitoring systems (CMS) on each effluent or on the combined effluent. When the affected facilities are not subject to the same emission standards, separate continuous monitoring systems shall be installed on each effluent. When the effluent from one affected facility is released to the atmosphere through more than one point, the owner or operator shall install an applicable continuous monitoring system on each separate effluent unless the installation of fewer systems is approved by the Administrator. When more than one continuous monitoring system is used to measure the emissions from one affected facility (e.g., multiple breechings, multiple outlets), the owner or operator shall report the results as required from each continuous monitoring system.

[40 CFR 60.13(g)]

A.30. Owners or operators of all continuous monitoring systems for measurement of opacity shall reduce all data to 6-minute averages and for continuous monitoring systems other than opacity to 1-hour averages for time periods as defined in 40 CFR 60.2. Six-minute opacity averages shall be calculated from 36 or more data points equally spaced over each 6-minute period. For continuous monitoring systems other than opacity, 1-hour averages shall be computed from four or more data points equally spaced over each 1-hour period. Data recorded during periods of continuous monitoring system breakdowns, repairs, calibration checks, and zero and span adjustments shall not be included in the data averages computed under this paragraph. An arithmetic or integrated average of all data may be used. The data may be recorded in reduced or non reduced form (e.g., ppm pollutant and percent O₂ or ng/J of pollutant). All excess emissions shall be converted into units of the standard using the applicable conversion procedures specified in subparts. After conversion into units of the standard, the data may be rounded to the same number of significant digits as used in the applicable subparts to specify the emission limit (e.g., rounded to the nearest 1 percent opacity).

[40 CFR 60.13(h)]

A.31. For performance evaluations under 40 CFR 60.13(c) and calibration checks under 40 CFR 60.13(d), the following procedures shall be used:

(1) Methods 6, 7, and 3B, as applicable, shall be used for the performance evaluations of sulfur dioxide and nitrogen oxides continuous monitoring systems. Acceptable alternative methods for Methods 6, 7, and 3B are given in 40 CFR 60.46(d).

(2) Sulfur dioxide or nitric oxide, as applicable, shall be used for preparing calibration gas mixtures under Performance Specification 2 of Appendix B to 40 CFR 60.

(3) For affected facilities burning fossil fuel(s), the span value for a continuous monitoring system measuring the opacity of emissions shall be 80, 90, or 100 percent and for a continuous monitoring system measuring sulfur oxides or nitrogen oxides the span value shall be determined as follows:

[In parts per million]

Fossil fuel	Span value for sulfur dioxide	Span value for nitrogen oxides
Gas.....	{1}	500
Liquid.....	1,000	500
Combinations.....	1,000y	500(x+y)

{1} Not applicable.

where:

x = the fraction of total heat input derived from gaseous fossil fuel, and

y = the fraction of total heat input derived from liquid fossil fuel.

(4) All span values computed under 40 CFR 60.45(c)(3) for burning combinations of fossil fuels shall be rounded to the nearest 500 ppm.

(5) For a fossil fuel-fired steam generator that simultaneously burns fossil fuel and nonfossil fuel, the span value of all continuous monitoring systems shall be subject to the Administrator's approval.

[40 CFR 60.45(c)]

A.32. For any continuous monitoring system installed under 40 CFR 60.45(a), the following conversion procedures shall be used to convert the continuous monitoring data into units of the applicable standards (ng/J, lb/million Btu):

(1) When a continuous monitoring system for measuring oxygen is selected, the measurement of the pollutant concentration and oxygen concentration shall each be on a consistent basis (wet or dry). Alternative procedures approved by the Administrator shall be used when measurements are on a wet basis. When measurements are on a dry basis, the following conversion procedure shall be used:

$$E = CF[20.9/(20.9 - \text{percent } O_2)]$$

where:

E, C, F, and % O₂ are determined under 40 CFR 60.45(f).

(2) When a continuous monitoring system for measuring carbon dioxide is selected, the measurement of the pollutant concentration and carbon dioxide concentration shall each be on a consistent basis (wet or dry) and the following conversion procedure shall be used:

$$E = CF_c [100/\text{percent CO}_2]$$

where:

E, C, F_c and %CO₂ are determined under 40 CFR 60.45(f).
[40 CFR 60.45(e)]

A.33. The values used in the equations under 40 CFR 60.45(e) (1) and (2) are derived as follows:

- (1) E = pollutant emissions, ng/J (lb/million Btu).
- (2) C = pollutant concentration, ng/dscm (lb/dscf), determined by multiplying the average concentration (ppm) for each one-hour period by 4.15×10^4 M ng/dscm per ppm (2.59×10^{-9} M lb/dscf per ppm) where M = pollutant molecular weight, g/g-mole (lb/lb-mole). M = 64.07 for sulfur dioxide and 46.01 for nitrogen oxides.
- (3) % O₂, %CO₂ = oxygen or carbon dioxide volume (expressed as percent), determined with equipment specified under 40 CFR 60.45(a).
- (4) F, F_c = a factor representing a ratio of the volume of dry flue gases generated to the calorific value of the fuel combusted (F), and a factor representing a ratio of the volume of carbon dioxide generated to the calorific value of the fuel combusted (F_c), respectively. Values of F and F_c are given as follows:
 - (iii) For liquid fossil fuels including crude, residual, and distillate oils, $F = 2.476 \times 10^{-7}$ dscm/J (9,220 dscf/million Btu) and $F_c = 0.384 \times 10^{-7}$ scm CO₂ /J (1,430 scf CO₂ /million Btu).
 - (iv) For gaseous fossil fuels, $F = 2.347 \times 10^{-7}$ dscm/J (8,740 dscf/million Btu). For natural gas, propane, and butane fuels, $F_c = 0.279 \times 10^{-7}$ scm CO₂ /J (1,040 scf CO₂ /million Btu) for natural gas, 0.322×10^{-7} scm CO₂ /J (1,200 scf CO₂ /million Btu) for propane, and 0.338×10^{-7} scm CO₂ /J (1,260 scf CO₂ /million Btu) for butane.
- (5) The owner or operator may use the following equation to determine an F factor (dscm/J or dscf/million Btu) on a dry basis (if it is desired to calculate F on a wet basis, consult the Administrator) or F_c factor (scm CO₂ /J, or scf CO₂ /million Btu) on either basis in lieu of the F or F_c factors specified in 40 CFR 60.45(f)(4):

$$F = 10^{-6} \frac{[227.2 (\text{pct. II}) + 95.5 (\text{pct. C}) + 35.6 (\text{pct. S}) + 8.7 (\text{pct. N}) - 28.7 (\text{pct. O})]}{\text{GCV}}$$

$$F_c = \frac{2.0 \times 10^{-5} (\text{pct. C})}{\text{GCV}}$$

(SI units)

$$F = 10^6 \frac{3.64(\%H) + 1.53(\%C) + 0.57(\%S) + 0.14(\%N) - 0.46(\%O)}{GCV}$$

(English units)

$$F_c = \frac{20.0(\%C)}{GCV}$$

(SI units)

$$F_c = \frac{321 \times 10^3 (\%C)}{GCV}$$

(English units)

(i) H, C, S, N, and O are content by weight of hydrogen, carbon, sulfur, nitrogen, and oxygen (expressed as percent), respectively, as determined on the same basis as GCV by ultimate analysis of the fuel fired, or computed from results using ASTM method D1137-53(75), D1945-64(76), or D1946-77 (gaseous fuels) as applicable. (These three methods are incorporated by reference-see 40 CFR 60.17.)

(ii) GCV is the gross calorific value (kJ/kg, Btu/lb) of the fuel combusted determined by the ASTM test method D1826-77 for gaseous fuels as applicable. (This method is incorporated by reference-see 40 CFR 60.17.)

(iii) For affected facilities which fire both fossil fuels and nonfossil fuels, the F or F_c value shall be subject to the Administrator's approval.

(6) For affected facilities firing combinations of fossil fuels, the F or F_c factors determined by paragraphs 40 CFR 60.45(f)(4) or (f)(5) shall be prorated in accordance with the applicable formula as follows:

$$F = \sum_{i=1}^n X_i F_i \quad \text{or} \quad F_c = \sum_{i=1}^n X_i (F_c)_i$$

where:

X_i = the fraction of total heat input derived from each type of fuel (e.g. natural gas, etc.)

F_i or $(F_c)_i$ = the applicable F or F_c factor for each fuel type determined in accordance with paragraphs (f)(4) and (f)(5) of this section.

n = the number of fuels being burned in combination.

[40 CFR 60.45(f)]

A.34. Operation and maintenance of continuous emissions monitoring (CEM) systems shall be carried out according to the requirements of 40 CFR 60; reports thereof shall be submitted to the Department's Southeast District Office within thirty (30) days following each calendar quarter and will include information required under 40 CFR 60.7(c). The Department reserves the right to modify the format of the reports. For any periods of excess emissions, as defined in 40 CFR 60.45(g), the reports shall specify the cause and corrective actions taken as well as the specific operational conditions existing (i.e., steady-state output, load charging rate; sootblowing, limiting, or air preheated steam cleaning sequences), during the period of excess emissions.

[AO43-170568, Specific Condition No. 4; AO43-170567, Specific Condition No. 4]

Recordkeeping and Reporting Requirements

A.35. The owner or operator subject to the provisions of 40 CFR 60 shall furnish the Administrator written notification as follows:

(4) A notification of any physical or operational change to an existing facility which may increase the emission rate of any air pollutant to which a standard applies, unless that change is specifically exempted under an applicable subpart or in 40 CFR 60.14(e). This notice shall be postmarked 60 days or as soon as practicable before the change is commenced and shall include information describing the precise nature of the change, present and proposed emission control systems, productive capacity of the facility before and after the change, and the expected completion date of the change. The Administrator may request additional relevant information subsequent to this notice.

[40 CFR 60.7(a)(4)]

A.36. The owner or operator subject to the provisions of 40 CFR 60 shall maintain records of the occurrence and duration of any startup, shutdown, or malfunction in the operation of an affected facility; any malfunction of the air pollution control equipment; or, any periods during which a continuous monitoring system or monitoring device is inoperative.

[40 CFR 60.7(b)]

A.37. The owner or operator required to install a continuous monitoring system (CMS) or monitoring device shall submit an excess emissions and monitoring systems performance report (excess emissions are defined in applicable subparts) and/or a summary report form [see 40 CFR 60.7(d)] to the Administrator semiannually, except when: more frequent reporting is specifically required by an applicable subpart; or, the CMS data are to be used directly for compliance determination, in which case quarterly reports shall be submitted; or, the Administrator, on a case-by-case basis, determines that more frequent reporting is necessary to accurately assess the compliance status of the source. All reports shall be postmarked by the 30th day following the end of each calendar half (or quarter, as appropriate). Written reports of excess emissions shall include the following information:

(1) The magnitude of excess emissions computed in accordance with 40 CFR 60.13(h), any conversion factor(s) used, and the date and time of commencement and completion of each time period of excess emissions. The process operating time during the reporting period.

(2) Specific identification of each period of excess emissions that occurs during startups, shutdowns, and malfunctions of the affected facility. The nature and cause of any malfunction (if known), the corrective action taken or preventative measures adopted.

(3) The date and time identifying each period during which the continuous monitoring system was inoperative except for zero and span checks and the nature of the system repairs or adjustments.

(4) When no excess emissions have occurred or the continuous monitoring system(s) have not been inoperative, repaired, or adjusted, such information shall be stated in the report.

[40 CFR 60.7(c)(1), (2), (3), and (4)]

A.38. The summary report form shall contain the information and be in the format shown in Figure 1 (attached) unless otherwise specified by the Administrator. One summary report form shall be submitted for each pollutant monitored at each affected facility.

(1) If the total duration of excess emissions for the reporting period is less than 1 percent of the total operating time for the reporting period and CMS downtime for the reporting period is less than 5 percent of the total operating time for the reporting period, only the summary report form shall be submitted and the excess emission report described in 40 CFR 60.7(c) need not be submitted unless requested by the Administrator.

(2) If the total duration of excess emissions for the reporting period is 1 percent or greater of the total operating time for the reporting period or the total CMS downtime for the reporting period is 5 percent or greater of the total operating time for the reporting period, the summary report form and the excess emission report described in 40 CFR 60.7(c) shall both be submitted.

[40 CFR 60.7(d)(1) and (2)]

{See attached Figure 1: Summary Report-Gaseous and Opacity Excess Emission and Monitoring System Performance} (electronic file name: figure1.doc)

A.39. (1) Notwithstanding the frequency of reporting requirements specified in 40 CFR 60.7(c), an owner or operator who is required by an applicable subpart to submit excess emissions and monitoring systems performance reports (and summary reports) on a quarterly (or more frequent) basis may reduce the frequency of reporting for that standard to semiannual if the following conditions are met:

(i) For 1 full year (e.g., 4 quarterly or 12 monthly reporting periods) the affected facility's excess emissions and monitoring systems reports submitted to comply with a standard under this part continually demonstrate that the facility is in compliance with the applicable standard;

(ii) The owner or operator continues to comply with all recordkeeping and monitoring requirements specified in 40 CFR 60, Subpart A, and the applicable standard; and

(iii) The Administrator does not object to a reduced frequency of reporting for the affected facility, as provided in 40 CFR 60.7(e)(2).

(2) The frequency of reporting of excess emissions and monitoring systems performance (and summary) reports may be reduced only after the owner or operator notifies the Administrator in writing of his or her intention to make such a change and the Administrator does not object to the intended change. In deciding whether to approve a reduced frequency of reporting, the Administrator may review information concerning the source's entire previous performance history during the required recordkeeping period prior to the intended change, including performance test results, monitoring data, and evaluations of an owner or operator's conformance with operation and maintenance requirements. Such information may be used by the Administrator to make a judgment about the source's potential for noncompliance in the future. If the Administrator disapproves the owner or operator's request to reduce the frequency of reporting, the Administrator will notify the owner or operator in writing within 45 days after receiving notice of the owner or operator's intention. The notification from the Administrator to the owner or operator will specify the grounds on which the disapproval is based. In the absence of a notice of disapproval within 45 days, approval is automatically granted.

(3) As soon as monitoring data indicate that the affected facility is not in compliance with any emission limitation or operating parameter specified in the applicable standard, the frequency of reporting shall revert to the frequency specified in the applicable standard, and the owner or operator shall submit an excess emissions and monitoring systems performance report (and summary report, if required) at the next appropriate reporting period following the noncomplying event. After demonstrating compliance with the applicable standard for another full year, the owner or operator may again request approval from the Administrator to reduce the frequency of reporting for that standard as provided for in 40 CFR 60.7(e)(1) and (e)(2).

[40 CFR 60.7(e)(1)]

A.40. The owner or operator subject to the provisions of 40 CFR 60 shall maintain a file of all measurements, including continuous monitoring system, monitoring device, and performance testing measurements; all continuous monitoring system performance evaluations; all continuous monitoring system or monitoring device calibration checks; adjustments and maintenance performed on these systems or devices; and, all other information required by 40 CFR 60 recorded in a permanent form suitable for inspection. The file shall be retained for at least **5 (five)** years following the date of such measurements, maintenance, reports, and records.

[40 CFR 60.7(f); Rule 62-213.440(1)(b)2.b., F.A.C.]

A.41. Records shall be kept of each delivery of “on-specification” used oil with a statement of the origin of the used oil and the quantity delivered/stored for firing. In addition, monthly records shall be kept of the quantity of “on-specification” used oil fired in these emissions units. The above records shall be maintained in a form suitable for inspection, retained for a minimum of five years, and be made available upon request. See specific conditions **A.13.**, **A.22.** and **A.43.**

[Rule 62-213.440(1)(b)2.b., F.A.C.; and, 40 CFR 279.61 and 761.20(e)]

A.42. The permittee shall include in the “Annual Operating Report for Air Pollutant Emitting Facility” a summary of the “on-specification” used oil analyses for the calendar year and a statement of the total quantity of “on-specification” used oil fired in Fossil Fuel Fired Steam Generators Nos. 1 and 2 during the calendar year. See specific conditions **A.13.**, **A.22.** and **A.42.**

[Rule 62-213.440(1)(b)2.b., F.A.C.]

A.43. Until such time when the Environmental Protection Agency (EPA) promulgates final rules regarding fuel sampling and test methods, the Department will accept the current fuel sampling and analysis program, provided that daily as fired fuel oil samples are composited and analyzed for sulfur content on a monthly basis to demonstrate compliance with fuel oil sulfur content limits. Quarterly reports containing the results of the monthly fuel oil sampling and analysis shall be submitted to the Department no later than thirty (30) days after the end of each quarter.

The permittee shall be allowed 90 days after promulgation of fuel sampling and analysis methods to implement an EPA approved method of monitoring sulfur dioxide emissions either by fuel sampling and analysis methods or continuous in-stack monitoring or other methods as approved under the provisions of 40 CFR 60.45.

[AO43-170568, Specific Condition No. 5; AO43-170567, Specific Condition No. 5]

Miscellaneous

A.44. Circumvention. No owner or operator subject to the provisions of 40 CFR 60 shall build, erect, install, or use any article, machine, equipment or process, the use of which conceals an emission which would otherwise constitute a violation of an applicable standard. Such concealment includes, but is not limited to, the use of gaseous diluents to achieve compliance with an opacity standard or with a standard which is based on the concentration of a pollutant in the gases discharged to the atmosphere.

[40 CFR 60.12]

A.45. The emissions units are also subject to the conditions contained in **Subsection E. Common Conditions.**

Subsection B. This section addresses the following emissions units.

E.U. ID

<u>No.</u>	<u>Brief Description</u>
-003	Combustion Turbine with Heat Recovery Steam Generator (CT 3A)
-004	Combustion Turbine with Heat Recovery Steam Generator (CT 3B)
-005	Combustion Turbine with Heat Recovery Steam Generator (CT 4A)
-006	Combustion Turbine with Heat Recovery Steam Generator (CT 4B)

All four combined cycle units are identical in configuration. Nitrogen oxide emissions are controlled by using dry low NOx combustors for natural gas with steam injection for fuel oil firing. Steam injection is also used for power augmentation. Duct modules suitable for future installation of selective catalytic reduction (SCR) equipment have been installed on each combined cycle generating unit. Based on information contained in the Title V Permit Application, only natural gas has been fired in the units to date. Units #3 and #4 commenced commercial operation in February, 1994. Units #5 and #6 commenced commercial operation in April, 1994.

{Permitting notes: the emissions units are regulated under Acid Rain, Phase II and NSPS - 40 CFR 60, Subpart GG, Standards of Performance for Stationary Gas Turbines; adopted and incorporated by reference in Rule 62-204.800(7)(b)38., F.A.C.; PSD-FL-146, Prevention of Significant Deterioration (PSD), in Rule 62-212.400, F.A.C.; and Best Available Control Technology (BACT), in Rule 62-212.410, F.A.C.}

The following conditions apply to the emissions units listed above:

General

B.1. Definitions. For the purposes of Rule 62-204.800(7), F.A.C., the definitions contained in the various provisions of 40 CFR 60, shall apply except that the term "Administrator" when used in 40 CFR 60, shall mean the Secretary or the Secretary's designee.

[40 CFR 60.2; Rule 62-204.800(7)(a), F.A.C.]

B.2. Circumvention. No owner or operator subject to the provisions of 40 CFR 60 shall build, erect, install, or use any article, machine, equipment or process, the use of which conceals an emission which would otherwise constitute a violation of an applicable standard. Such concealment includes, but is not limited to, the use of gaseous diluents to achieve compliance with an opacity standard or with a standard which is based on the concentration of a pollutant in the gases discharged to the atmosphere.

[40 CFR 60.12]

Essential Potential to Emit (PTE) Parameters

B.3. Permitted Capacity. The maximum heat input to each Combustion Turbine (CT) shall neither exceed 1966 MMBtu/hr while firing natural gas, nor 1846 MMBtu/hr while firing fuel oil @40 degrees F. These heat input limitations are subject to change. Any changes shall be provided at least 90 days before commercial operation for each fuel available to the site which a unit is capable of firing, at which time this condition may be modified to reflect those parameters. Each combined cycle's fuel consumption shall be continuously determined and recorded. Testing of emissions shall be conducted with the units operating at capacity. Capacity is defined as 95-100 percent of the manufacturer's rated heat input achievable for the average ambient (or conditioned) air temperature during the test. If it is impractical to test at capacity, then the units may be tested at less than capacity. In such cases, the entire heat input versus inlet temperature curves will be adjusted by the increment equal to the difference between the design heat input value and 105 percent of the value reached during the test. Data, curves, and calculations necessary to demonstrate the heat input rate correction at both design and test conditions shall be submitted to the Department with the compliance test report.
[Rules 62-4.160(2) and 62-210.200(PTE), F.A.C.; PSD-FL-146, Specific Condition No. 1]

B.4. Fuels. Only natural gas or No. 2 fuel oil shall be fired in the CTs.
[PSD-FL-146, Specific Condition No. 3]

B.5. Hours of Operation. The emissions units may operate continuously, i.e., 8760 hours/year/CT.
[Rule 62-210.200(PTE), F.A.C.]

Emission Limitations and Standards

{Permitting note: Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

B.6. The maximum allowable emissions from each CT, in accordance with the BACT determination, shall not exceed the following, at 40 degrees F, except during periods of startup and shutdown:

Pollutant	Fuel	Emission Limitations ^d		
		Concentration	lb/hr/CT	TPY/CT ^a
NO _x	Gas	25 ppmvd @ 15% O ₂	177	3108 (combined gas and oil total)
	Oil	65 ppmvd @ 15% O ₂	461	
VOC ^b	Gas	1.6 ppmvd	3	57 (combined gas and oil total)
	Oil	6 ppmvd	11.0	
CO	Gas	30 ppmvd	94.3	871 (combined gas and oil total)
	Oil	33 ppmvd	105.8	
PM/PM ₁₀	Gas		18	100 (combined gas and oil total)
	Oil		60.6	
Pb	Gas		negligible	0.015 (combined gas and oil total)
	Oil		0.015	
SO ₂	Gas		91.5	568 (combined gas and oil total)
	Oil ^c		920	

Notes:

^a Tons per year (TPY) emission limits listed for natural gas and oil combined apply as an emissions cap based on limiting oil firing to an annual aggregate of 2,000 hours for the 4 CT's, with compliance to be demonstrated in annual operation reports.

^b Exclusive of background concentrations.

^c Sulfur dioxide emissions based on a maximum of 0.5 percent sulfur content, by weight, in oil for hourly emissions and an average sulfur content of 0.3 percent, by weight, for annual emissions. These sulfur content limitations are subject to change based on the analysis required in PSD Specific Condition No. 12. (See specific condition B.49.)

^d These limitations for Units 5 and 6 shall not be binding for subsequent BACT determinations.

[PSD-FL-146, Specific Condition No. 4]

B.7. The following emissions, determined by BACT, are tabulated for PSD and inventory purposes:

Pollutant	Fuel	Maximum Allowable Emissions (@40 ° F)	
		lb/hr/CT	TPY/CT ^a
H ₂ SO ₄ Acid Mist ^b	Gas	11.2	70 (combined gas and oil total)
	Oil	113	
Mercury	Gas	0.021	0.34 (combined gas and oil total)
	Oil	0.0052	
Fluoride	Oil	0.055	0.055
Beryllium	Oil	0.004	0.004

Notes:

^a Tons per year (TPY) emission limits for natural gas and oil combined apply as an emissions cap based on limiting oil firing to an annual aggregate of 2,000 hours for the 4 CT's, with compliance to be demonstrated in annual operation reports.

^b Sulfuric acid mist emissions assume a maximum of 0.5 percent sulfur content, by weight, in fuel oil for hourly emissions and an average sulfur content of 0.3 percent, by weight, for annual emissions.

[PSD-FL-146, Specific Condition No. 5]

B.8. Opacity. Visible emissions shall neither exceed 10% opacity while burning natural gas, nor 20% opacity while burning distillate oil.

[PSD-FL-146, Specific Condition No. 8]

B.9. Opacity. Compliance with standards in 40 CFR 60, other than opacity standards, shall be determined only by performance tests established by 40 CFR 60.8, unless otherwise specified in the applicable standard.

[40 CFR 60.11(a)]

B.10. Opacity. The opacity standards set forth in 40 CFR 60 shall apply at all times except during periods of startup, shutdown, malfunction, and as otherwise provided in the applicable standard.

[40 CFR 60.11(c)]

B.11. Nitrogen Oxides. Nitrogen oxide emissions from each gas turbine/heat recovery steam generator unit shall be controlled by using dry low NOx combustors for natural gas with steam injection for fuel oil firing. The permittee has installed duct modules suitable for future installation of SCR equipment on each combined cycle generating unit.

[PSD-FL-146, Specific Condition No. 9]

Excess Emissions

B.12. Excess emissions resulting from malfunction shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration.

[Rule 62-210.700(1), F.A.C.]

B.13. Excess emissions resulting from startup or shutdown shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized.

[Rule 62-210.700(2), F.A.C.]

B.14. Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown or malfunction shall be prohibited.

[Rule 62-210.700(4), F.A.C.]

B.15. The excess emissions authorized under Rule 62-210.700(1), F.A.C., shall be extended an additional two hours (four hours total) for a cold steam turbine start for the first CT of a unit. The second CT of each unit shall comply with established emission limits in accordance with Rule 62-210.700(1), F.A.C.

[PSD-FL-146, Specific Condition No. 4]

B.16. At all times, including periods of startup, shutdown, and malfunction, owners and operators shall, to the extent practicable, maintain and operate any affected facility including associated air pollution control equipment in a manner consistent with good air pollution control practice for minimizing emissions. Determination of whether acceptable operating and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, opacity observations, review of operating and maintenance procedures, and inspection of the source.

[40 CFR 60.11(d)]

Monitoring of Operations

B.17. At all times, including periods of startup, shutdown and malfunction, owners and operators shall, to the extent practicable, maintain and operate any affected facility including associated pollution control equipment in a manner consistent with good air pollution control practice for minimizing emissions. Determination of whether acceptable operating and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, opacity observations, review of operating and maintenance procedures, and inspection of the source.
[40 CFR 60.11(d)]

B.18. The owner or operator of any stationary gas turbine subject to the provisions of 40 CFR 60, Subpart GG and using water injection to control NO_x emissions shall install and operate a continuous monitoring system to monitor and record the fuel consumption and the ratio of water to fuel being fired in the turbine. This system shall be accurate to within ± 5.0 percent and shall be approved by the Administrator. This specific condition does **not apply** if only natural gas is fired in the turbine.
[40 CFR 60.334(a)]

B.19. The owner or operator of any stationary gas turbine subject to the provisions of 40 CFR 60, Subpart GG shall monitor sulfur content and nitrogen content of the fuel being fired in the turbine. The frequency of determination of these values shall be as follows:

- (1) If the turbine is supplied its fuel from a bulk storage tank, the values shall be determined on each occasion that fuel is transferred to the storage tank from any other source.
- (2) If the turbine is supplied its fuel without intermediate bulk storage, the values shall be determined and recorded daily. Owners, operators or fuel vendors may develop custom schedules for determination of the values based on the design and operation of the affected facility and the characteristics of the fuel supply. These custom schedules shall be substantiated with data and must be approved by the Administrator before they can be used to comply with 40 CFR 60.334(b).

[40 CFR 60.334(b)(1) and (2)]

B.20. The Martin Plant facility requested approval for and was granted approval to utilize a customized fuel monitoring schedule for natural gas firing, pursuant to 40 CFR 60.334(b). See specific condition **B.19**. The schedule is as follows:

Custom Fuel Monitoring Schedule for Natural Gas (NG)

1. Monitoring of fuel nitrogen content shall not be required if NG is the only fuel being fired in the gas turbines.
2. Sulfur Monitoring
 - a. Analysis for fuel sulfur content of the natural gas shall be conducted using one of the approved ASTM reference methods for the measurement of sulfur in gaseous fuels, or an approved alternative method. The reference methods are ASTM D1072-80, ASTM D3031-81, ASTM D3246-81, and ASTM D4084-82, as referenced in 40 CFR 60.335(b)(2), or the latest edition(s).

- b. This custom fuel monitoring schedule shall become effective on the date this permit becomes valid. Effective the date of this custom schedule, sulfur monitoring shall be conducted twice monthly for six months. If this monitoring shows little variability in the fuel sulfur content, and indicates consistent compliance with 40 CFR 60.333, then sulfur monitoring shall be conducted once per quarter for six quarters. If monitoring data is provided by the applicant which demonstrates consistent compliance with the requirements herein the applicant may begin monitoring as per the requirements of 2(c).
 - c. If after the monitoring required in item 2(b) above, or herein, the sulfur content of the fuel shows little variability and, calculated as sulfur dioxide, represents consistent compliance with the sulfur dioxide emission limits specified under 40 CFR 60.333, sample analysis shall be conducted twice per annum. This monitoring shall be conducted during the first and third quarters of each calendar year.
 - d. Should any sulfur analysis as required in items 2(b) or 2(c) above indicate noncompliance with 40 CFR 60.333, the owner or operator shall notify the Department of such excess emissions and the custom schedule shall be re-examined by the Environmental Protection Agency. Sulfur monitoring shall be conducted weekly during the interim period when this custom schedule is being re-examined.
3. If there is a change in fuel supply, the owner or operator must notify the Department of such change for re-examination of this custom schedule. A substantial change in fuel quality shall be considered as a change in fuel supply. Sulfur monitoring shall be conducted weekly during the interim period when this custom schedule is being re-examined.
 4. Records of sample analysis and fuel supply pertinent to this custom schedule shall be retained for a period of five years, and be available for inspection by personnel of federal, state, and local air pollution control agencies.

[PSD-FL-146; NSPS Custom Fuel Monitoring Schedule dated 10/14/97]

Test Methods and Procedures

{Permitting note: Table 2-1, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

B.21. To compute the nitrogen oxides emissions, the owner or operator shall use analytical methods and procedures that are accurate to within 5 percent and are approved by the Department to determine the nitrogen content of the fuel being fired. This specific condition does **not apply** if only natural gas is fired in the turbine.

[40 CFR 60.335(a)]

B.22. The monitoring device of 40 CFR 60.334(a) shall be used to determine the fuel consumption and the water-to-fuel ratio necessary to comply with the permitted NO_x standard at 30, 50, 75, and 100 percent of peak load or at four points in the normal operating range of the gas turbine, including the minimum point in the range and peak load. All loads shall be corrected to ISO conditions using the appropriate equations supplied by the manufacturer. This specific condition does **not apply** if only natural gas is fired in the turbine.
[40 CFR 60.335(c)(2)]

B.23. The owner or operator shall determine compliance with the nitrogen oxides and sulfur dioxide standards in 40 CFR 60.332 as follows:
c. U.S. EPA. Method 20 (40 CFR 60, Appendix A) shall be used to determine the nitrogen oxides, sulfur dioxide, and oxygen concentrations. The span values shall be 300 ppm of nitrogen oxide and 21 percent oxygen. The NO_x emissions shall be determined at each of the load conditions specified in 40 CFR 60.335(c)(2). See specific condition **B.20** that describes the approved Custom Fuel Monitoring Schedule for Natural Gas for this facility.
[40 CFR 60.335(c)(3)]

B.24. The owner or operator shall determine compliance with the sulfur content standard of 0.5 percent, by weight, as follows: ASTM D 2880-96 shall be used to determine the sulfur content of liquid fuels and ASTM D 1072-90(94)E-1, D 3031-81(86), D 4084-94, or D 3246-92 shall be used for the sulfur content of gaseous fuels (incorporated by reference-see 40 CFR 60.17). The applicable ranges of some ASTM methods mentioned above are not adequate to measure the levels of sulfur in some fuel gases. Dilution of samples before analysis (with verification of the dilution ratio) may be used, subject to the approval of the Administrator. See specific condition **B.20** that describes the approved Custom Fuel Monitoring Schedule for Natural Gas for this facility.
[40 CFR 60.335(d)]

B.25. To meet the requirements of 40 CFR 60.334(b), the owner or operator shall use the methods specified in 40 CFR 60.335 (a) and 40 CFR 60.335(d) of 40 CFR 60.335 to determine the nitrogen and sulfur contents of the fuel being burned. The analysis may be performed by the owner or operator, a service contractor retained by the owner or operator, the fuel vendor, or any other qualified agency. See specific condition **B.20** that describes the approved Custom Fuel Monitoring Schedule for Natural Gas for this facility.
[40 CFR 60.335(e)]

B.26. The owner or operator shall provide, or cause to be provided, stack sampling and performance testing facilities as follows:
(1) Sampling ports adequate for test methods applicable to such facilities.
(2) Safe sampling platform(s).
(3) Safe access to sampling platform(s).
(4) Utilities for sampling and testing equipment.
[40 CFR 60.8; PSD-FL-146, Specific Condition No. 21]

B.27. Initial (I) compliance tests shall be performed on each Combustion Turbine using both fuels. The stack test for each turbine shall be performed within 10% of the maximum heat rate input for the tested operating temperature. Annual (A) compliance tests shall be performed on each Combustion Turbine with the fuel(s) used for more than 400 hours in the preceding 12-month period. Tests shall be conducted using EPA reference methods, or equivalent, in accordance with the July 1, 1996 version of 40 CFR 60 Appendix A. (Note: based on information provided in the Title V Permit Application, initial testing using distillate oil has **not been done.**) See specific condition **B.3** for utilization of ambient temperature versus heat input curves during compliance testing.

Pollutant	EPA Reference Method	Initial testing		Annual testing	
		Gas	Oil	Gas	Oil
Particulate Matter	5 or 17		X		X
Sulfuric Acid Mist	8		X		
Visible Emissions	9	X	X	X	X
Carbon Monoxide	10	X	X	X	X
Nitrogen Oxides	20	X	X	X	X
Volatile Organic Compounds	18	X	X		
	Test Method				
Lead	EMTIC Test Method, or Method 7090, or 7091*		X		
Beryllium	EMTIC Test Method, or Method 104, or Method 7090, or 7091*		X		
Sulfur content	ASTM D 2880-96		X		X
	ASTM D 1072-90(94) E-1, ASTM D 3031-81(86), ASTM D 4084-94, or ASTM D 3246-92	X		X	
Mercury	40 CFR 61, Appendix B EPA Method 101	X	X		

*Method 3040 sample extraction shall be used as described in the EPA solid waste regulations SW 846.

[PSD-FL-146, Specific Condition No. 10]

B.28. The average annual sulfur content of the light distillate oil shall not exceed 0.3%, by weight. The maximum sulfur content of the light distillate fuel oil shall not exceed 0.5%, by weight. Compliance shall be demonstrated in accordance with the requirements of 40 CFR 60.334 by testing for sulfur content, for nitrogen content, and for heating value of oil storage tanks once per day when firing oil using ASTM D 2880-96.

[PSD-FL-146, Specific Condition No. 11]

B.29. Opacity. Compliance with opacity standards in 40 CFR 60 shall be determined by conducting observations in accordance with Reference Method 9 in Appendix A of 40 CFR 60, any alternative method that is approved by the Administrator, or as provided in 40 CFR 60.11(e)(5).

[40 CFR 60.11(b)]

B.30. Performance tests shall be conducted under such conditions as the Administrator shall specify to the plant operator based on representative performance of the affected facility. The owner or operator shall make available to the Administrator such records as may be necessary to determine the conditions of the performance tests. Operations during periods of startup, shutdown, and malfunction shall not constitute representative conditions for the purpose of a performance test nor shall emissions in excess of the level of the applicable emission limit during periods of startup, shutdown, and malfunction be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard.

[40 CFR 60.8(c)]

Continuous Monitoring Requirements

B.31. Continuous emissions monitoring shall be installed, operated, and maintained in accordance with 40 CFR 75 for each combined cycle unit to monitor nitrogen oxides.

(a) Each continuous emissions monitoring system (CEMS) shall meet performance specifications of 40 CFR 75, Appendices A, B, and F.

(b) CEMS data shall be recorded and reported in accordance with 40 CFR 75 and 40 CFR 60.7. The excess emissions report shall include periods of startup, shutdown, and malfunction and shall be based on NO_x data corrected to 15 % O₂ and 40 degrees F.

(c) A malfunction means any sudden and unavoidable failure of air pollution equipment or process equipment to operate in a normal or usual manner. Failures that are caused entirely or in part by poor maintenance, careless operation or any other preventable upset condition or preventable equipment breakdown shall not be considered malfunctions.

(d) For purposes of reports required under this permit, excess emissions are defined as any calculated average emission concentration which exceeds the applicable emission limits in specific condition B.6. See specific condition B.39.

[PSD-FL-146, Specific Condition No. 13]

B.32. For the purposes of 40 CFR 60.13, all continuous monitoring systems required under applicable subparts shall be subject to the provisions of 40 CFR 60.13 upon promulgation of performance specifications for continuous monitoring systems under Appendix B of 40 CFR 60 and, if the continuous monitoring system is used to demonstrate compliance with emission limits on a continuous basis, Appendix F of 40 CFR 60, unless otherwise specified in an applicable subpart or by the Administrator. Appendix F is applicable December 4, 1987.
[40 CFR 60.13(a)]

B.33. If the owner or operator of an affected facility elects to submit continuous opacity monitoring system (COMS) data for compliance with the opacity standard as provided under 40 CFR 60.11(e)(5), he shall conduct a performance evaluation of the COMS as specified in Performance Specification 1, Appendix B, of 40 CFR 60 before the performance test required under 40 CFR 60.8 is conducted. Otherwise, the owner or operator of an affected facility shall conduct a performance evaluation of the COMS or continuous emission monitoring system (CEMS) during any performance test required under 40 CFR 60.8 or within 30 days thereafter in accordance with the applicable performance specification in Appendix B of 40 CFR 60. The owner or operator of an affected facility shall conduct COMS or CEMS performance evaluations at such other times as may be required by the Administrator under section 114 of the Act.
[40 CFR 60.13(c)]

B.34. The owner or operator of an affected facility subject to an opacity standard may submit, for compliance purposes, continuous opacity monitoring system (COMS) data results produced during any performance test required under 40 CFR 60.8 in lieu of Method 9 observation data. If an owner or operator elects to submit COMS data for compliance with the opacity standard, he shall notify the Administrator of that decision, in writing, at least 30 days before any performance test required under 40 CFR 60.8 is conducted. Once the owner or operator of an affected facility has notified the Administrator to that effect, the COMS data results will be used to determine opacity compliance during subsequent tests required under 40 CFR 60.8 until the owner or operator notifies the Administrator, in writing, to the contrary. For the purpose of determining compliance with the opacity standard during a performance test required under 40 CFR 60.8 using COMS data, the minimum total time of COMS data collection shall be averages of all 6-minute continuous periods within the duration of the mass emission performance test. Results of the COMS opacity determinations shall be submitted along with the results of the performance test required under 60.8. The owner or operator of an affected facility using a COMS for compliance purposes is responsible for demonstrating that the COMS meets the requirements specified in 40 CFR 60.13(c), that the COMS has been properly maintained and operated, and that the resulting data have not been altered in any way. If COMS data results are submitted for compliance with the opacity standard for a period of time during which Method 9 data indicates noncompliance, the Method 9 data will be used to determine opacity compliance.
[40 CFR 60.11(e)(5)]

B.35. (1) Owners and operators of all continuous emission monitoring systems (CEMS) installed in accordance with the provisions of this part shall check the zero (or low-level value between 0 and 20 percent of span value) and span (50 to 100 percent of span value) calibration drifts at least once daily in accordance with a written procedure. The zero and span shall, as a minimum, be adjusted whenever the 24-hour zero drift or 24-hour span drift exceeds two times the limits of the applicable performance specifications in Appendix B. The system must allow the amount of excess zero and span drift measured at the 24-hour interval checks to be recorded and quantified, whenever specified. For continuous monitoring systems measuring opacity of emissions, the optical surfaces exposed to the effluent gases shall be cleaned prior to performing the zero and span drift adjustments except that for systems using automatic zero adjustments. The optical surfaces shall be cleaned when the cumulative automatic zero compensation exceeds 4 percent opacity.

(2) Unless otherwise approved by the Administrator, the following procedures shall be followed for continuous monitoring systems measuring opacity of emissions. Minimum procedures shall include a method for producing a simulated zero opacity condition and an upscale (span) opacity condition using a certified neutral density filter or other related technique to produce a known obscuration of the light beam. Such procedures shall provide a system check of the analyzer internal optical surfaces and all electronic circuitry including the lamp and photo detector assembly.

[40 CFR 60.13(d)(1) and (2)]

B.36. Except for system breakdowns, repairs, calibration checks, and zero and span adjustments required under 40 CFR 60.13(d), all continuous monitoring systems (CMS) shall be in continuous operation and shall meet minimum frequency of operation requirements as follows:

(1) All continuous monitoring systems referenced by 40 CFR 60.13(c) for measuring opacity of emissions shall complete a minimum of one cycle of sampling and analyzing for each successive 10-second period and one cycle of data recording for each successive 6-minute period.

(2) All continuous monitoring systems referenced by 40 CFR 60.13(c) for measuring emissions, except opacity, shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period.

[40 CFR 60.13(e)(1) and (2)]

B.37. All continuous monitoring systems (CMS) or monitoring devices shall be installed such that representative measurements of emissions or process parameters from the affected facility are obtained. Additional procedures for location of continuous monitoring systems contained in the applicable Performance Specifications of Appendix B of 40 CFR 60 shall be used.

[40 CFR 60.13(f)]

B.38. When the effluents from a single affected facility or two or more affected facilities subject to the same emission standards are combined before being released to the atmosphere, the owner or operator may install applicable continuous monitoring systems (CMS) on each effluent or on the combined effluent. When the affected facilities are not subject to the same emission standards, separate continuous monitoring systems shall be installed on each effluent. When the effluent from one affected facility is released to the atmosphere through more than one point, the owner or operator shall install an applicable continuous monitoring system on each separate effluent unless the installation of fewer systems is approved by the Administrator. When more than one continuous monitoring system is used to measure the emissions from one affected facility (e.g., multiple breechings, multiple outlets), the owner or operator shall report the results as required from each continuous monitoring system.

[40 CFR 60.13(g)]

B.39. Owners or operators of all continuous monitoring systems for measurement of opacity shall reduce all data to 6-minute averages and for continuous monitoring systems other than opacity to 1-hour averages for time periods as defined in 40 CFR 60.2. Six-minute opacity averages shall be calculated from 36 or more data points equally spaced over each 6-minute period. For continuous monitoring systems other than opacity, 1-hour averages shall be computed from four or more data points equally spaced over each 1-hour period. Data recorded during periods of continuous monitoring system breakdowns, repairs, calibration checks, and zero and span adjustments shall not be included in the data averages computed under this paragraph. An arithmetic or integrated average of all data may be used. The data may be recorded in reduced or non reduced form (e.g., ppm pollutant and percent O₂ or ng/J of pollutant). All excess emissions shall be converted into units of the standard using the applicable conversion procedures specified in subparts. After conversion into units of the standard, the data may be rounded to the same number of significant digits as used in the applicable subparts to specify the emission limit (e.g., rounded to the nearest 1 percent opacity).

[40 CFR 60.13(h)]

Recordkeeping and Reporting Requirements

B.40. To determine compliance with the oil firing heat input limitation, the permittee shall maintain daily records of fuel oil consumption and hourly usage for each turbine and heating value for each fuel. All records shall be maintained for a minimum of five (5) years after the date of each record and shall be made available to representatives of the Department upon request.

[PSD-FL-146, Specific Condition No. 14]

B.41. The permittee shall have required sampling tests of the emissions performed within 60 after achieving the maximum turbine firing rate, but not later than 180 days from the start of operations. Thirty (30) days notice prior to the initial sampling test and fifteen (15) days notice before subsequent annual testing shall be provided to the Southeast District Office. Written reports of the tests shall be submitted to the Southeast District Office within 45 days of test completion.

[PSD-FL-146, Specific Condition No. 17]

B.42. Quarterly excess emission reports, in accordance with the July 1, 1996, version of 40 CFR 60.7(c) and 60.334(c), shall be submitted to the Department's Southeast District Office. Annual reports shall be submitted to the District office in accordance with Rule 62-2.700(7), F.A.C.

[PSD-FL-146, Specific Condition No. 19]

B.43. For the purpose of reports required under 40 CFR 60.7(c), periods of excess emissions that shall be reported are defined as follows:

a. *Nitrogen oxides.* Any one-hour period during which the average water-to-fuel ratio, as measured by the continuous monitoring system, falls below the water-to-fuel ratio determined to demonstrate compliance with the permitted nitrogen oxide standard by the initial performance test required in 40 CFR 60.8 or any period during which the fuel-bound nitrogen of the fuel is greater than the maximum nitrogen content allowed by the fuel-bound nitrogen allowance used during the initial performance test. Each report shall include the average water-to-fuel ratio, average fuel consumption, ambient conditions, gas turbine load, and nitrogen content of the fuel during the period of excess emissions, and the graphs or figures developed under 40 CFR 60.335(a).

[Rule 62-296.800, F.A.C.; 40 CFR 60.334(c)(1)]

B.44. The owner or operator subject to the provisions of 40 CFR 60 shall furnish the Administrator written notification as follows:

(4) A notification of any physical or operational change to an existing facility which may increase the emission rate of any air pollutant to which a standard applies, unless that change is specifically exempted under an applicable subpart or in 40 CFR 60.14(e). This notice shall be postmarked 60 days or as soon as practicable before the change is commenced and shall include information describing the precise nature of the change, present and proposed emission control systems, productive capacity of the facility before and after the change, and the expected completion date of the change. The Administrator may request additional relevant information subsequent to this notice.

[40 CFR 60.7(a)(4)]

B.45. The owner or operator subject to the provisions of 40 CFR 60 shall maintain records of the occurrence and duration of any startup, shutdown, or malfunction in the operation of an affected facility; any malfunction of the air pollution control equipment; or, any periods during which a continuous monitoring system or monitoring device is inoperative.

[40 CFR 60.7(b)]

B.46. The owner or operator required to install a continuous monitoring system (CMS) or monitoring device shall submit an excess emissions and monitoring systems performance report and/or a summary report form [see 40 CFR 60.7(d)] to the Administrator semiannually, except when: more frequent reporting is specifically required by an applicable subpart; or, the CMS data are to be used directly for compliance determination, in which case quarterly reports shall be submitted; or, the Administrator, on a case-by-case basis, determines that more frequent reporting is necessary to accurately assess the compliance status of the source. All reports shall be postmarked by the 30th day following the end of each calendar half (or quarter, as appropriate). Written reports of excess emissions shall include the following information:

(1) The magnitude of excess emissions computed in accordance with 40 CFR 60.13(h), any conversion factor(s) used, and the date and time of commencement and completion of each time period of excess emissions. The process operating time during the reporting period.

(2) Specific identification of each period of excess emissions that occurs during startups, shutdowns, and malfunctions of the affected facility. The nature and cause of any malfunction (if known), the corrective action taken or preventative measures adopted.

(3) The date and time identifying each period during which the continuous monitoring system was inoperative except for zero and span checks and the nature of the system repairs or adjustments.

(4) When no excess emissions have occurred or the continuous monitoring system(s) have not been inoperative, repaired, or adjusted, such information shall be stated in the report.

[40 CFR 60.7(c)(1), (2), (3), and (4)]

B.47. The summary report form shall contain the information and be in the format shown in Figure 1 (attached) unless otherwise specified by the Administrator. One summary report form shall be submitted for each pollutant monitored at each affected facility.

(1) If the total duration of excess emissions for the reporting period is less than 1 percent of the total operating time for the reporting period and CMS downtime for the reporting period is less than 5 percent of the total operating time for the reporting period, only the summary report form shall be submitted and the excess emission report described in 40 CFR 60.7(c) need not be submitted unless requested by the Administrator.

(2) If the total duration of excess emissions for the reporting period is 1 percent or greater of the total operating time for the reporting period or the total CMS downtime for the reporting period is 5 percent or greater of the total operating time for the reporting period, the summary report form and the excess emission report described in 40 CFR 60.7(c) shall both be submitted.

[40 CFR 60.7(d)(1) and (2)]

{See attached Figure 1: Summary Report-Gaseous and Opacity Excess Emission and Monitoring System Performance} (electronic file name: figure1.doc)

B.48. (1) Notwithstanding the frequency of reporting requirements specified in 40 CFR 60.7(c), an owner or operator who is required by an applicable subpart to submit excess emissions and monitoring systems performance reports (and summary reports) on a quarterly (or more frequent) basis may reduce the frequency of reporting for that standard to semiannual if the following conditions are met:

- (i) For 1 full year (e.g., 4 quarterly or 12 monthly reporting periods) the affected facility's excess emissions and monitoring systems reports submitted to comply with a standard under this part continually demonstrate that the facility is in compliance with the applicable standard;
- (ii) The owner or operator continues to comply with all recordkeeping and monitoring requirements specified in 40 CFR 60, Subpart A, and the applicable standard; and
- (iii) The Administrator does not object to a reduced frequency of reporting for the affected facility, as provided in 40 CFR 60.7(e)(2).

(2) The frequency of reporting of excess emissions and monitoring systems performance (and summary) reports may be reduced only after the owner or operator notifies the Administrator in writing of his or her intention to make such a change and the Administrator does not object to the intended change. In deciding whether to approve a reduced frequency of reporting, the Administrator may review information concerning the source's entire previous performance history during the required recordkeeping period prior to the intended change, including performance test results, monitoring data, and evaluations of an owner or operator's conformance with operation and maintenance requirements. Such information may be used by the Administrator to make a judgment about the source's potential for noncompliance in the future. If the Administrator disapproves the owner or operator's request to reduce the frequency of reporting, the Administrator will notify the owner or operator in writing within 45 days after receiving notice of the owner or operator's intention. The notification from the Administrator to the owner or operator will specify the grounds on which the disapproval is based. In the absence of a notice of disapproval within 45 days, approval is automatically granted.

(3) As soon as monitoring data indicate that the affected facility is not in compliance with any emission limitation or operating parameter specified in the applicable standard, the frequency of reporting shall revert to the frequency specified in the applicable standard, and the owner or operator shall submit an excess emissions and monitoring systems performance report (and summary report, if required) at the next appropriate reporting period following the noncomplying event. After demonstrating compliance with the applicable standard for another full year, the owner or operator may again request approval from the Administrator to reduce the frequency of reporting for that standard as provided for in 40 CFR 60.7(e)(1) and (e)(2).

[40 CFR 60.7(e)(1)]

B.49. The owner or operator subject to the provisions of 40 CFR 60 shall maintain a file of all measurements, including continuous monitoring system, monitoring device, and performance testing measurements; all continuous monitoring system performance evaluations; all continuous monitoring system or monitoring device calibration checks; adjustments and maintenance performed on these systems or devices; and, all other information required by 40 CFR 60 recorded in a permanent form suitable for inspection. The file shall be retained for at least 5 (five) years following the date of such measurements, maintenance, reports, and records.

[40 CFR 60.7(f); Rule 62-213.440(1)(b)2.b., F.A.C.]

Miscellaneous

B.50. In the supplemental application for approval of Phase II of the Project, the applicant shall include a cumulative air quality impact analysis and a PSD increment consumption analysis for the Everglades National Park Class I area.
[PSD-FL-146, Specific Condition No. 12]

B.51. The emissions units are also subject to the conditions contained in **Subsection E. Common Conditions.**

Subsection C. This section addresses the following emissions unit.

E.U. ID

<u>No.</u>	<u>Brief Description</u>
-007	Auxiliary Boiler

This unit is used to produce steam to actuate the steam seals on the steam turbine components of the combined-cycle units (Emissions Units -003 to -006) during cold starts when steam is not otherwise available for this purpose. Initial startup of the unit was on July 15, 1993.

{Permitting notes: The emissions unit is regulated under NSPS - 40 CFR 60.40c, Subpart Dc, Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units; adopted and incorporated by reference in Rule 62-204.800(7)(b)4, F.A.C.; PSD-FL-146, NSR - BACT.}

The following conditions apply to the emissions unit listed above:

General

C.1. Definitions. For the purposes of Rule 62-204.800(7), F.A.C., the definitions contained in the various provisions of 40 CFR 60, shall apply except that the term "Administrator" when used in 40 CFR 60, shall mean the Secretary or the Secretary's designee.
[40 CFR 60.2; Rule 62-204.800(7)(a), F.A.C.]

C.2. Circumvention. No owner or operator subject to the provisions of 40 CFR 60 shall build, erect, install, or use any article, machine, equipment or process, the use of which conceals an emission which would otherwise constitute a violation of an applicable standard. Such concealment includes, but is not limited to, the use of gaseous diluents to achieve compliance with an opacity standard or with a standard which is based on the concentration of a pollutant in the gases discharged to the atmosphere.
[40 CFR 60.12]

Essential Potential to Emit (PTE) Parameters

C.3. Hours of Operation. The auxiliary boiler shall operate only during startup and shutdown of the combined-cycle units, and for periodic maintenance testing.
[Rule 62-210.200(PTE), F.A.C.; PSD-FL-146, revised 7/19/93]

C.4. Fuels. Only natural gas or No. 2 light distillate fuel oil shall be fired in the auxiliary boiler. Based on the Title V Permit Application, the unit is currently only capable of firing natural gas.
[PSD-FL-146, Specific Condition No.3]

Emission Limitations and Standards

{Permitting note: Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

C.5. Visible Emissions. Visible emissions shall not exceed twenty (20) percent opacity (6-minute average), except for one six-minute period per hour of not more than twenty seven (27) percent opacity. This standard applies at all times, except during periods of startup, shutdown, or malfunction.

[40 CFR 60.43c(c) & (d)]

C.6. Opacity. Compliance with standards in 40 CFR 60, other than opacity standards, shall be determined only by performance tests established by 40 CFR 60.8, unless otherwise specified in the applicable standard.

[40 CFR 60.11(a)]

C.7. Opacity. The opacity standards set forth in 40 CFR 60 shall apply at all times except during periods of startup, shutdown, malfunction, and as otherwise provided in the applicable standard.

[40 CFR 60.11(c)]

C.8. Sulfur Dioxide. Sulfur dioxide emissions limitations for the auxiliary steam boiler are established by firing natural gas or limiting the light distillate fuel oil's sulfur content to 0.3%, by weight, on an annual basis.

[PSD-FL-146, revised 7/19/93]

C.9. For units listed under 40 CFR 60.42c(h)(1), compliance with the emission limits or fuel oil sulfur limits under this section may be determined based on a certification from the fuel supplier, as described under 40 CFR 60.48c(f)(1), as applicable.

(1) Distillate oil-fired units with heat input capacities between 2.9 and 29 MW (10 and 100 million Btu/hr).

[40 CFR 60.42c(h)(1)]

C.10. Nitrogen Oxides. NOx emissions for the auxiliary steam boiler shall not exceed 0.3 lb/MMBtu for natural gas firing or oil firing.

[PSD-FL-146, revised 7/19/93]

Test Methods and Procedures

{Permitting note: Table 2-1, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

C.11. Compliance and performance test methods and procedures for sulfur dioxide.

Compliance with the percent reduction requirements and SO₂ emission limits under 40 CFR 60.42c is based on the average percent reduction and the average SO₂ emission rates for 30 consecutive steam generating unit operating days. A separate performance test is completed at the end of each steam generating unit operating day, and a new 30-day average percent reduction and SO₂ emission rate are calculated to show compliance with the standard. **Note:** no annual testing is required if operational hours are less than 400 hours per year on oil. However, testing is required for permit renewal purposes.

[40 CFR 60.44c(c); and, Rule 62-297.310(7), F.A.C.]

C.12. If only oil is combusted in a unit, the procedures in Method 19 are used to determine the hourly SO₂ emission rate (E_h) and the 30-day average SO₂ emission rate (E_a). The hourly averages used to compute the 30-day averages are obtained from the continuous emission monitoring system (CEMS). Method 19 shall be used to calculate E_a when using daily fuel sampling or Method 6B.

E_h is defined as the hourly average pollutant rate, in ng/J (lb/million Btu heat input), and E_a , defined as the average pollutant rate for the specified performance test period, in ng/J (lb/million Btu heat input), is computed using the following equation:

$$E_a = (1 / H) \sum_{j=1}^n E_{hj}$$

where H = total number of operating hours for which pollutant rates are determined in the performance test period.

[40 CFR 60.44c(d) & 40 CFR 60, Appendix A]

C.13. EPA Method 9 shall be used for determining the opacity of stack emissions.

[40 CFR 60.45c(a)(7)]

C.14. Testing for the sulfur content, for the nitrogen content, and for the heating value of oil storage tanks shall be conducted once per day when firing oil using ASTM D 2880-96.

[PSD-FL-146, Specific Condition No. 11]

C.15. Opacity. Compliance with opacity standards in 40 CFR 60 shall be determined by conducting observations in accordance with Reference Method 9 in Appendix A of 40 CFR 60, any alternative method that is approved by the Administrator, or as provided in 40 CFR 60.11(e)(5).
[40 CFR 60.11(b)]

C.16. Performance tests shall be conducted under such conditions as the Administrator shall specify to the plant operator based on representative performance of the affected facility. The owner or operator shall make available to the Administrator such records as may be necessary to determine the conditions of the performance tests. Operations during periods of startup, shutdown, and malfunction shall not constitute representative conditions for the purpose of a performance test nor shall emissions in excess of the level of the applicable emission limit during periods of startup, shutdown, and malfunction be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard.
[40 CFR 60.8(c)]

Recordkeeping and Reporting Requirements

C.17. (b) The owner or operator of each unit subject to the SO₂ emission limits of 40 CFR 60.42c, or the PM or opacity limits of 40 CFR 60.43c, shall submit to the Administrator the performance test data from the initial and any subsequent performance tests.

(d) The owner or operator of each unit subject to the SO₂ emission limits, fuel oil sulfur limits, or percent reduction requirements under 40 CFR 60.42c shall submit quarterly reports to the Administrator. The initial quarterly report shall be postmarked by the 30th day of the third month following the completion of the initial performance test. Each subsequent quarterly report shall be postmarked by the 30th day following the end of the reporting period.

(e) The owner or operator of each unit subject to the SO₂ emission limits, fuel oil sulfur limits, or percent reduction requirements under 40 CFR 60.42c shall keep records and submit quarterly reports as required under 40 CFR 60.48c(d), including the following information, as applicable.

- (1) Calendar dates covered in the reporting period.
- (2) Each 30-day average SO₂ emission rate (ng/J or lb/million Btu), or 30-day average sulfur content (weight percent), calculated during the reporting period, ending with the last 30-day period in the quarter; reasons for any noncompliance with the emission standards; and a description of corrective actions taken.
- (3) Each 30-day average percent of potential SO₂ emission rate calculated during the reporting period, ending with the last 30-day period in the quarter; reasons for any noncompliance with the emission standards; and a description of corrective actions taken.
- (4) Identification of any steam generating unit operating days for which SO₂ or diluent (oxygen or carbon dioxide) data have not been obtained by an approved method for at least 75 percent of the operating hours; justification for not obtaining sufficient data; and a description of corrective actions taken.
- (5) Identification of any times when emissions data have been excluded from the calculation of average emission rates; justification for excluding data; and a description of corrective actions taken if data have been excluded for periods other than those during which coal or oil were not combusted in the steam generating unit.

- (6) Identification of the F factor used in calculations, method of determination, and type of fuel combusted.
- (7) Identification of whether averages have been obtained based on CEMS rather than manual sampling methods.
- (11) If fuel supplier certification is used to demonstrate compliance, records of fuel supplier certification as described under 40 CFR 60.48c(f)(1), (2), or (3), as applicable. In addition to records of fuel supplier certifications, the quarterly report shall include a certified statement signed by the owner or operator of the unit that the records of fuel supplier certifications submitted represent all of the fuel combusted during the quarter.
- (f) Fuel supplier certification shall include the following information:
 - (1) For distillate oil:
 - (i) The name of the oil supplier; and
 - (ii) A statement from the oil supplier that the oil complies with the specifications under the following definition of distillate oil:

"Distillate oil means fuel oil that complies with the specifications for fuel oil numbers 1 or 2, as defined by the American Society for Testing and Materials in ASTM D396-78, "Standard Specification for Fuel Oils"."
 - (g) The owner or operator of each unit shall record and maintain records of the amounts of each fuel combusted during each day.
 - (h) The owner or operator of each unit subject to a Federally enforceable requirement limiting the annual capacity factor for any fuel or mixture of fuels under 40 CFR 60.42c or 40 CFR 60.43c shall calculate the annual capacity factor individually for each fuel combusted. The annual capacity factor is determined on a 12-month rolling average basis with a new annual capacity factor calculated at the end of the calendar month.
 - (i) All records required under this section shall be maintained by the owner or operator of the affected facility for a period of 5 (five) years following the date of such record. **Note:** As long as the auxiliary boiler operates only during startup and shutdown and for periodic maintenance testing, C.17(d) and (e) requirements under this specific condition are not applicable. See specific condition C.3.

[40 CFR 60.48c]

C.18. The owner or operator subject to the provisions of 40 CFR 60 shall furnish the Administrator written notification as follows:

- (4) A notification of any physical or operational change to an existing facility which may increase the emission rate of any air pollutant to which a standard applies, unless that change is specifically exempted under an applicable subpart or in 40 CFR 60.14(e). This notice shall be postmarked 60 days or as soon as practicable before the change is commenced and shall include information describing the precise nature of the change, present and proposed emission control systems, productive capacity of the facility before and after the change, and the expected completion date of the change. The Administrator may request additional relevant information subsequent to this notice.

[40 CFR 60.7(a)(4)]

C.19. The owner or operator subject to the provisions of 40 CFR 60 shall maintain records of the occurrence and duration of any startup, shutdown, or malfunction in the operation of an affected facility; any malfunction of the air pollution control equipment; or, any periods during which a continuous monitoring system or monitoring device is inoperative.
[40 CFR 60.7(b)]

C.20. (1) Notwithstanding the frequency of reporting requirements specified in 40 CFR 60.7(c), an owner or operator who is required by an applicable subpart to submit excess emissions and monitoring systems performance reports (and summary reports) on a quarterly (or more frequent) basis may reduce the frequency of reporting for that standard to semiannual if the following conditions are met:

- (i) For 1 full year (e.g., 4 quarterly or 12 monthly reporting periods) the affected facility's excess emissions and monitoring systems reports submitted to comply with a standard under this part continually demonstrate that the facility is in compliance with the applicable standard;
- (ii) The owner or operator continues to comply with all recordkeeping and monitoring requirements specified in 40 CFR 60, Subpart A, and the applicable standard; and
- (iii) The Administrator does not object to a reduced frequency of reporting for the affected facility, as provided in 40 CFR 60.7(e)(2).

(2) The frequency of reporting of excess emissions and monitoring systems performance (and summary) reports may be reduced only after the owner or operator notifies the Administrator in writing of his or her intention to make such a change and the Administrator does not object to the intended change. In deciding whether to approve a reduced frequency of reporting, the Administrator may review information concerning the source's entire previous performance history during the required recordkeeping period prior to the intended change, including performance test results, monitoring data, and evaluations of an owner or operator's conformance with operation and maintenance requirements. Such information may be used by the Administrator to make a judgment about the source's potential for noncompliance in the future. If the Administrator disapproves the owner or operator's request to reduce the frequency of reporting, the Administrator will notify the owner or operator in writing within 45 days after receiving notice of the owner or operator's intention. The notification from the Administrator to the owner or operator will specify the grounds on which the disapproval is based. In the absence of a notice of disapproval within 45 days, approval is automatically granted.

(3) As soon as monitoring data indicate that the affected facility is not in compliance with any emission limitation or operating parameter specified in the applicable standard, the frequency of reporting shall revert to the frequency specified in the applicable standard, and the owner or operator shall submit an excess emissions and monitoring systems performance report (and summary report, if required) at the next appropriate reporting period following the noncomplying event. After demonstrating compliance with the applicable standard for another full year, the owner or operator may again request approval from the Administrator to reduce the frequency of reporting for that standard as provided for in 40 CFR 60.7(e)(1) and (e)(2). **Note:** As long as the auxiliary boiler operates only during startup and shutdown and for periodic maintenance testing, requirements under this specific condition are not applicable. See specific condition C.3.
[40 CFR 60.7(e)(1)]

C.21. The owner or operator subject to the provisions of 40 CFR 60 shall maintain a file of all measurements, including continuous monitoring system, monitoring device, and performance testing measurements; all continuous monitoring system performance evaluations; all continuous monitoring system or monitoring device calibration checks; adjustments and maintenance performed on these systems or devices; and, all other information required by 40 CFR 60 recorded in a permanent form suitable for inspection. The file shall be retained for at least **5 (five)** years following the date of such measurements, maintenance, reports, and records. [40 CFR 60.7(f); Rule 62-213.440(1)(b)2.b., F.A.C.]

C.22. This emissions unit is also subject to the conditions contained in **Subsection E. Common Conditions.**

Subsection D. This section addresses the following emissions unit.

E.U. ID

<u>No.</u>	<u>Brief Description</u>
-009	Diesel Generator

This unit is used to supply power to Emissions Units -003 to -006 during power outages. The nameplate rating is 0.718 MW. Emissions are uncontrolled.

The following specific conditions apply to the emissions unit listed above:

Essential Potential to Emit (PTE) Parameters

D.1. Hours of Operation. The diesel generator shall operate only for emergency power generation or periodic operational testing.

[Rule 62-210.200(PTE), F.A.C.; PSD-FL-146, revised 7/19/93]

Emission Limitations and Standards

{Permitting note: Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

D.2. Nitrogen Oxides. NO_x emissions for the diesel generator shall not exceed 15.0 grams/hp-hr.

[PSD-FL-146, revised 7/19/93]

D.3. Sulfur Dioxide. SO₂ emissions limitations for the diesel generator are established by limiting the light distillate fuel oil's sulfur content to 0.3%, by weight, on an annual basis.

[PSD-FL-146, revised 7/19/93]

Test Methods and Procedures

{Permitting note: Table 2-1, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

D.4. Distillate fuel oil fired in the emergency diesel generator shall meet the specifications for fuel oil numbers 1 or 2, as defined by the American Society for Testing and Materials in ASTM D 396-78 (or the latest edition), "Standard Specifications for Fuel Oils." Compliance with these specifications shall be verified with a fuel analysis provided by the vendor upon each fuel delivery.

[Requested by the applicant in electronic memorandum dated 09/18/97]

Subsection E. Common Conditions.

E.U. ID

<u>No.</u>	<u>Brief Description</u>
-001	Fossil Fuel Fired Steam Generator #1
-002	Fossil Fuel Fired Steam Generator #2
-003	Combustion Turbine with Heat Recovery Steam Generator (CT 3A)
-004	Combustion Turbine with Heat Recovery Steam Generator (CT 3B)
-005	Combustion Turbine with Heat Recovery Steam Generator (CT 4A)
-006	Combustion Turbine with Heat Recovery Steam Generator (CT 4B)
-007	Auxiliary Boiler

The following conditions apply to the emissions units listed above:

Test Methods and Procedures

E.1. Required Number of Test Runs. For mass emission limitations, a compliance test shall consist of three complete and separate determinations of the total air pollutant emission rate through the test section of the stack or duct and three complete and separate determinations of any applicable process variables corresponding to the three distinct time periods during which the stack emission rate was measured provided, however, that three complete and separate determinations shall not be required if the process variables are not subject to variation during a compliance test, or if three determinations are not necessary in order to calculate the unit's emission rate. The three required test runs shall be completed within one consecutive five day period. In the event that a sample is lost or one of the three runs must be discontinued because of circumstances beyond the control of the owner or operator, and a valid third run cannot be obtained within the five day period allowed for the test, the Secretary or his or her designee may accept the results of the two complete runs as proof of compliance, provided that the arithmetic mean of the results of the two complete runs is at least 20 percent below the allowable emission limiting standards.

[Rule 62-297.310(1), F.A.C.]

E.2. Applicable Test Procedures.

(a) Required Sampling Time.

1. Unless otherwise specified in the applicable rule, the required sampling time for each test run shall be no less than one hour and no greater than four hours, and the sampling time at each sampling point shall be of equal intervals of at least two minutes.

2. Opacity Compliance Tests. When either EPA Method 9 or DEP Method 9 is specified as the applicable opacity test method, the required minimum period of observation for a compliance test shall be sixty (60) minutes for emissions units which emit or have the potential to emit 100 tons per year or more of particulate matter, and thirty (30) minutes for emissions units which have potential emissions less than 100 tons per year of particulate matter and are not subject to a multiple-valued opacity standard. The opacity test observation period shall include the period during which the highest opacity emissions can reasonably be expected to occur. Exceptions to these requirements are as follows:

- a. For batch, cyclical processes, or other operations which are normally completed within less than the minimum observation period and do not recur within that time, the period of observation shall be equal to the duration of the batch cycle or operation completion time.
- b. The observation period for special opacity tests that are conducted to provide data to establish a surrogate standard pursuant to Rule 62-297.310(5)(k), F.A.C., Waiver of Compliance Test Requirements, shall be established as necessary to properly establish the relationship between a proposed surrogate standard and an existing mass emission limiting standard.
- c. The minimum observation period for opacity tests conducted by employees or agents of the Department to verify the day-to-day continuing compliance of a unit or activity with an applicable opacity standard shall be twelve minutes.

(b) Minimum Sample Volume. Unless otherwise specified in the applicable rule, the minimum sample volume per run shall be 25 dry standard cubic feet.

(c) Required Flow Rate Range. For EPA Method 5 particulate sampling, acid mist/sulfur dioxide, and fluoride sampling which uses Greenburg Smith type impingers, the sampling nozzle and sampling time shall be selected such that the average sampling rate will be between 0.5 and 1.0 actual cubic feet per minute, and the required minimum sampling volume will be obtained.

(d) Calibration of Sampling Equipment. Calibration of the sampling train equipment shall be conducted in accordance with the schedule shown in Table 297.310-1.

TABLE 297.310-1
 CALIBRATION SCHEDULE

ITEM	MINIMUM CALIBRATION FREQUENCY	REFERENCE INSTRUMENT	TOLERANCE
Liquid in glass thermometer	Annually	ASTM Hg in glass ref. thermometer or equivalent, or thermometric points	+/-2%
Bimetallic thermometer	Quarterly	Calib. liq. in glass thermometer	5 degrees F
Thermocouple	Annually	ASTM Hg in glass ref. thermometer, NBS calibrated reference and potentiometer	5 degrees F
Barometer	Monthly	Hg barometer or NOAA station	+/-1% scale
Pitot Tube	When required or when damaged	By construction or measurements in wind tunnel D greater than 16" and standard pitot tube	See EPA Method 2, Fig. 2-2 & 2-3
Probe Nozzles	Before each test or when nicked, dented, or corroded	Micrometer	+/-0.001" mean of at least three readings Max. deviation between readings .004"
Dry Gas Meter and Orifice Meter	1. Full Scale: When received, When 5% change observed, Annually 2. One Point: Semiannually 3. Check after each test series	Spirometer or calibrated wet test or dry gas test meter	2%
		Comparison check	5%

(e) Allowed Modification to EPA Method 5. When EPA Method 5 is required, the following modification is allowed: the heated filter may be separated from the impingers by a flexible tube. [Rule 62-297.310(4), F.A.C.]

E.3. Determination of Process Variables.

(a) Required Equipment. The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.

(b) Accuracy of Equipment. Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value.

[Rule 62-297.310(5), F.A.C.]

E.4. The permittee shall comply with the requirements contained in APPENDIX SS-1, Stack Sampling Facilities, attached to this permit.

[Rule 62-297.310(6), F.A.C.]

E.5. Frequency of Compliance Tests. The following provisions apply only to those emissions units that are subject to an emissions limiting standard for which compliance testing is required.

(a) General Compliance Testing.

3. The owner or operator of an emissions unit that is subject to any emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining a renewed operation permit. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy the requirements of this provision. In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of emission compliance test results for any emissions unit that, during the year prior to renewal:

a. Did not operate; or

b. In the case of a fuel burning emissions unit, burned liquid and/or solid fuel for a total of no more than 400 hours.

4. During each federal fiscal year (October 1 -- September 30), unless otherwise specified by rule, order, or permit, the owner or operator of each emissions unit shall have a formal compliance test conducted for:

a. Visible emissions, if there is an applicable standard;

b. Each of the following pollutants, if there is an applicable standard, and if the emissions unit emits or has the potential to emit: 5 tons per year or more of lead or lead compounds measured as elemental lead; 30 tons per year or more of acrylonitrile; or 100 tons per year or more of any other regulated air pollutant; and

c. Each NESHAP pollutant, if there is an applicable emission standard.

5. An annual compliance test for particulate matter emissions shall not be required for any fuel burning emissions unit that, in a federal fiscal year, does not burn liquid and/or solid fuel, other than during startup, for a total of more than 400 hours.

9. The owner or operator shall notify the Department, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator.

10. An annual compliance test conducted for visible emissions shall not be required for units exempted from permitting at Rule 62-210.300(3)(a), F.A.C., or units permitted under the General Permit provisions at Rule 62-210.300(4), F.A.C.

(b) Special Compliance Tests. When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it may require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department.

(c) Waiver of Compliance Test Requirements. If the owner or operator of an emissions unit that is subject to a compliance test requirement demonstrates to the Department, pursuant to the procedure established in Rule 62-297.620, F.A.C., that the compliance of the emissions unit with an applicable weight emission limiting standard can be adequately determined by means other than the designated test procedure, such as specifying a surrogate standard of no visible emissions for particulate matter sources equipped with a bag house or specifying a fuel analysis for sulfur dioxide emissions, the Department shall waive the compliance test requirements for such emissions units and order that the alternate means of determining compliance be used, provided, however, the provisions of Rule 62-297.310(7)(b), F.A.C., shall apply.
[Rule 62-297.310(7), F.A.C.; SIP approved]

Recordkeeping and Reporting Requirements

E.6. Malfunction Reporting. In the case of excess emissions resulting from malfunctions, each owner or operator shall notify the Department in accordance with Rule 62-4.130, F.A.C. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department.

[Rule 62-210.700(6), F.A.C.]

E.7. Calculation of Emission Rate. The indicated emission rate or concentration shall be the arithmetic average of the emission rate or concentration determined by each of the three separate test runs unless otherwise specified in a particular test method or applicable rule.

[Rule 62-297.310(3), F.A.C.]

E.8. Test Reports.

(a) The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Department on the results of each such test.

(b) The required test report shall be filed with the Department as soon as practical but no later than 45 days after the last sampling run of each test is completed.

(c) The test report shall provide sufficient detail on the emissions unit tested and the test procedures used to allow the Department to determine if the test was properly conducted and the test results properly computed. As a minimum, the test report, other than for an EPA or DEP Method 9 test, shall provide the following information:

1. The type, location, and designation of the emissions unit tested.
2. The facility at which the emissions unit is located.
3. The owner or operator of the emissions unit.
4. The normal type and amount of fuels used and materials processed, and the types and amounts of fuels used and material processed during each test run.
5. The means, raw data and computations used to determine the amount of fuels used and materials processed, if necessary to determine compliance with an applicable emission limiting standard.
6. The type of air pollution control devices installed on the emissions unit, their general condition, their normal operating parameters (pressure drops, total operating current and GPM scrubber water), and their operating parameters during each test run.
7. A sketch of the duct within 8 stack diameters upstream and 2 stack diameters downstream of the sampling ports, including the distance to any upstream and downstream bends or other flow disturbances.
8. The date, starting time and duration of each sampling run.
9. The test procedures used, including any alternative procedures authorized pursuant to Rule 62-297.620, F.A.C. Where optional procedures are authorized in this chapter, indicate which option was used.
10. The number of points sampled and configuration and location of the sampling plane.
11. For each sampling point for each run, the dry gas meter reading, velocity head, pressure drop across the stack, temperatures, average meter temperatures and sample time per point.
12. The type, manufacturer and configuration of the sampling equipment used.
13. Data related to the required calibration of the test equipment.
14. Data on the identification, processing and weights of all filters used.
15. Data on the types and amounts of any chemical solutions used.
16. Data on the amount of pollutant collected from each sampling probe, the filters, and the impingers, are reported separately for the compliance test.
17. The names of individuals who furnished the process variable data, conducted the test, analyzed the samples and prepared the report.
18. All measured and calculated data required to be determined by each applicable test procedure for each run.
19. The detailed calculations for one run that relate the collected data to the calculated emission rate.
20. The applicable emission standard, and the resulting maximum allowable emission rate for the emissions unit, plus the test result in the same form and unit of measure.

21. A certification that, to the knowledge of the owner or his authorized agent, all data submitted are true and correct. When a compliance test is conducted for the Department or its agent, the person who conducts the test shall provide the certification with respect to the test procedures used. The owner or his authorized agent shall certify that all data required and provided to the person conducting the test are true and correct to his knowledge.

[Rule 62-297.310(8), F.A.C.]

Section IV. This section is the Acid Rain Part.

Operated by: Florida Power and Light Company
ORIS code: 6043

Subsection A. This subsection addresses Acid Rain, Phase II.

The emissions units listed below are regulated under Acid Rain Part, Phase II.

<u>E.U. ID No.</u>	<u>EPA ID</u>	<u>Brief Description</u>
-001	PMR1	Fossil Fuel Fired Steam Generator #1
-002	PMR2	Fossil Fuel Fired Steam Generator #2
-003	HRSG3A	Combustion Turbine with Heat Recovery Steam Generator (CT 3A)
-004	HRSG3B	Combustion Turbine with Heat Recovery Steam Generator (CT 3B)
-005	HRSG4A	Combustion Turbine with Heat Recovery Steam Generator (CT 4A)
-006	HRSG4B	Combustion Turbine with Heat Recovery Steam Generator (CT 4B)

1. The Phase II permit application submitted for this facility, as approved by the Department, is a part of this permit. The owners and operators of these Phase II acid rain units must comply with the standard requirements and special provisions set forth in the application listed below:

- a. DEP Form No. 62-210.900(1)(a), dated July 1, 1995.
 [Chapter 62-213, F.A.C. and Rule 62-214.320, F.A.C.]

2. Sulfur dioxide (SO₂) allowance allocations for each Acid Rain unit are as follows:

<u>E.U. ID No.</u>	<u>EPA ID</u>	<u>Year</u>	<u>2000</u>	<u>2001</u>	<u>2002</u>
-001	PMR1	SO ₂ allowances, under Table 2 or 3 of 40 CFR Part 73	5044*	5044*	5044*
-002	PMR2	SO ₂ allowances, under Table 2 or 3 of 40 CFR Part 73	5982*	5982*	5982*

-003	HRSG3A	SO2 allowances, under Table 2 or 3 of 40 CFR Part 73	1265*	1265*	1265*
-004	HRSG3B	SO2 allowances, under Table 2 or 3 of 40 CFR Part 73	1265*	1265*	1265*
-005	HRSG4A	SO2 allowances, under Table 2 or 3 of 40 CFR Part 73	1265*	1265*	1265*
-006	HRSG4B	SO2 allowances, under Table 2 or 3 of 40 CFR Part 73	1265*	1265*	1265*

*The number of allowances held by an Acid Rain source in a unit account may differ from the number allocated by the USEPA under Table 2 or 3 of 40 CFR 73.

3. Emission Allowances. Emissions from sources subject to the Federal Acid Rain Program (Title IV) shall not exceed any allowances that the source lawfully holds under the Federal Acid Rain Program. Allowances shall not be used to demonstrate compliance with a non-Title IV applicable requirement of the Act.

1. No permit revision shall be required for increases in emissions that are authorized by allowances acquired pursuant to the Federal Acid Rain Program, provided that such increases do not require a permit revision pursuant to Rule 62-213.400(3), F.A.C.

2. No limit shall be placed on the number of allowances held by the source under the Federal Acid Rain Program.

3. Allowances shall be accounted for under the Federal Acid Rain Program.

[Rule 62-213.440(1)(c), F.A.C.]

4. Comments, notes, and justifications: None.

Appendix E-1. List of Exempt Emissions Units and/or Activities.

The facilities, emissions units, or pollutant-emitting activities listed in Rule 62-210.300(3)(a), F.A.C., Full Exemptions, are exempt from the permitting requirements of Chapters 62-210 and 62-4, F.A.C.; provided, however, that exempt emissions units shall be subject to any applicable emission limiting standards and the emissions from exempt emissions units or activities shall be considered in determining whether a facility containing such emissions units or activities would be subject to any applicable requirements. Emissions units and pollutant-emitting activities exempt from permitting under Rule 62-210.300(3)(a), F.A.C., are also exempt from the permitting requirements of Chapter 62-213, F.A.C., provided such emissions units and activities also meet the exemption criteria of Rule 62-213.430(6)(b), F.A.C. The below listed emissions units and/or activities are hereby exempt pursuant to Rule 62-213.430(6), F.A.C.

1	Chemical Feed Skid , consisting of: Ammonia Feed Tanks Vent Hydrazine Feed Tanks Vent H. P. Phosphate Feed Tanks Vent I. P. Phosphate Feed Tanks Vent
2	Fire Protection Equipment with: .75" Vents to Atmosphere Diesel Engine Exhaust 2" Diesel Day Tank Vent <u>CT Lube Seal Trip, and Hydraulic Oil</u> 3" Bearing Drain Enlargement Exhausters Vent to Atmosphere Auxiliary Buildings H.V.A.C. Vent/Exhaust System for, Switchgear Rooms Chemical Storage Room Water Chemistry Lab Fume Hoods
3	Main Liquid Fuel .75" Vents to Atmosphere 2" Liquid Fuel Drain Tank Vent (235 gallon) 8" Vent with Filter for Units 3 and 4 Liquid Fuel Storage Tank (2,000,000 gallon)
4	Auxiliary Steam, Chemical Feed, Chlorine and Gas Purging , comprised of: Ash Pit <u>Potable Water</u> Bleach Tank 2" Vent (2,000 gallons)

	<p><u>Lube Oil</u> Lube Oil Storage Tanks Vent <u>B.F.P. Lube Oil</u> B.F.P. Lube Oil Reservoir Vent Fan 4" B.F.P. Lube Oil Batch Tank 3" Vent and Filter B.F.P. Lube Oil Conditioner Vent Fan 4" <u>Light Oil System</u> Light Oil Tank 6" Vent (2,000 bbl) Water Draw-Off Sump Diesel Day Tank .75" Vent - (550 gallon) Chemical Feed Tank Vent <u>Turbine Gland Seal Steam and Drain</u> Gland Steam Condenser Exhauster 6" Vent to Atmosphere <u>Fuel Oil at Burners</u> 1" Vents to Atmosphere Natural Gas 2" Vent to Atmosphere 6" Vent to Atmosphere <u>Ignition (LP) Gas</u> 1" Control Vent to Atmosphere L.P. Gas Tanks Relief Valve <u>Fuel Oil at Heaters</u> 1" Vents to Atmosphere M.C.C. Areas Exhaust Fans Lab Exhaust Hood <u>Turbine Generator Lube Oil</u> Generator Loop Seal Tank Exhauster 4" Vent to Atmosphere Turbine Lube Oil Reservoir Vapor Extractor 6" Vent Turbine Generator Lube Oil Batch Tank 4" Vent with Filter Turbine Generator Lube Oil Conditioner Vapor Extractor 4" Vent 1" Polishing Filter Vent 1" Air Educator Vent Electrically Heated Equipment Used for Heat Treating, Tracing, Drying, Soaking, Case Hardening or Surface Conditioning</p>
5	<p>Gas Metering Area (for Units 1 and 2) Gas Oil Separator Tank 8" Exhaust Vent Gas Oil Separator Tank 1.5" Vent Relief Valve 6" Blowdown Valve Gas Scrubber Relief Valve Condensate Tank with Filter</p>
6	<p>Sand Blast Booth</p>

Appendix U-1. List of Unregulated Emissions Units and/or Activities.

Unregulated Emissions Units and/or Activities. An emissions unit which emits no “emissions-limited pollutant” and which is subject to no unit-specific work practice standard, though it may be subject to regulations applied on a facility-wide basis (e.g., unconfined emissions, odor, general opacity) or to regulations that require only that it be able to prove exemption from unit-specific emissions or work practice standards.

The below listed emissions units and/or activities are neither ‘regulated emissions units’ nor ‘exempt emissions units’.

Emissions Unit	Description
-xxx	Diesel Generator (for Units -001 and -002)
-xxx	Facility-wide Fugitive Emissions for PM
-xxx	Facility-wide Fugitive Emissions for VOC's

Appendix H-1. Permit History/ID Number Changes

Permit History (for tracking purposes):

<u>E.U. ID No</u>	<u>Description</u>	<u>Permit No.</u>	<u>Issue Date</u>	<u>Expiration Date</u>	<u>Extended Date^{1,2}</u>	<u>Revised Date(s)</u>
-001	Fossil Fuel Fired Steam Generator	AC-73044	3/20/73			
		AC43-4037	6/30/77			
		AO43-170568	2/23/90	11/29/94		2/16/93
-002	Fossil Fuel Fired Steam Generator	AC-73045	3/20/73			
		AC43-4038	6/30/77			
		AO43-170567	2/20/90	11/29/94		2/16/93
-003 to -006	Combustion Turbines with HRSGs	PSD-FL-146	6/05/91			7/19/93
						9/16/94
						9/06/96
						10/14/97
		0850001-002-AC				9/06/96
				9/06/96		
		PA89-27	2/20/91			9/28/94
-007	Auxiliary Boiler	PSD-FL-146	6/05/91			7/19/93
						9/06/96
		PA89-27	2/20/91			9/28/94
-009	Diesel Generator	PSD-FL-146	6/05/91			7/19/93
						9/06/96
		PA89-27	2/20/91			9/28/94

ID Number Changes (for tracking purposes):

From: Facility ID No.: 50WPB430001; To: Facility ID No.: 0850001

Notes:

- 1 - AO permit(s) automatic extension(s) in Rule 62-210.300(2)(a)3.a., F.A.C., effective 03/21/96.
- 2 - AC permit(s) automatic extension(s) in Rule 62-213.420(1)(a)4., F.A.C., effective 03/20/96.
- {Rule 62-213.420(1)(b)2., F.A.C., effective 03/20/96, allows Title V Sources to operate under existing valid permits}

Table 1-1, Air Pollutant Standards and Terms

Florida Power & Light Company
Martin Plant

PROPOSED Permit No.: 0850001-004-AV
Facility ID No.: 0850001

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No(s).	Brief Description				Allowable Emissions			Equivalent Emissions*		Regulatory Citations	See Permit Conditions
		Pollutant Name	Fuel(s)	Hours/Year	Standard(s)	lbs./hour	TPY	lbs./hour	TPY		
-001 -002	Fossil Fuel Fired Steam Generators	PM	Oil	8760	0.1 lb/MMBtu			865	3788.7	40 CFR 60.42	A.5
			Gas	8760	0.1 lb/MMBtu						
		SO2	Oil	8760	0.8 lb/MMBtu			6920	30309	40 CFR 60.43	A.10
			Oil	8760	0.3 lb/MMBtu			2595	11366.1	40 CFR 60.44	A.11
		Gas	8760	0.2 lb/MMBtu			1808	7919.04			
		Opacity	Oil	8760	Not > 20%						A.9
-003 -004 -005 -006	Combustion Turbines with HRSGs	PM/PM10	Oil	2000		60.6	100			Rule 62-212.410, F.A.C.	B.6
			Gas	8760		18					
		SO2	Oil	2000	0.5% sulfur	920	568			40 CFR 60.333	B.6
			Gas	8760		91.5					
		NOx	Oil	2000	65 ppmvd @ 15% O2	461	3108			40 CFR 60.332	B.6
			Gas	8760	25 ppmvd @ 15% O2	177					
		VOC	Oil	2000	6 ppmvd	11	57			Rule 62-212.410, F.A.C.	B.6
			Gas	8760	1.6 ppmvd	3					
		CO	Oil	2000	33 ppmvd	105.8	871			Rule 62-212.410, F.A.C.	B.6
			Gas	8760	30 ppmvd	94.3					
		PB	Oil	2000		0.015	0.015			Rule 62-212.410, F.A.C.	B.6
			Gas	8760		Negligible					
		SAM	Oil	2000		113	70			Rule 62-212.410, F.A.C.	B.7
	Gas	8760		11.2							
H114	Oil	2000		0.0052	0.34			Rule 62-212.410, F.A.C.	B.7		
	Gas	8760		0.021							
FL	Oil	2000		0.055	0.055			Rule 62-212.410, F.A.C.	B.7		
H021	Oil	2000		0.004	0.004			Rule 62-212.410, F.A.C.	B.7		
Opacity	Oil	2000	Not > 20%					Rule 62-212.410, F.A.C.	B.8		
	Gas	8760	Not > 10%								
-007	Auxiliary Boiler	Opacity	Oil	8760	Not > 20%					40 CFR 60.43c	C.5
		NOx	Gas/Oil	8760	0.3 lb/MMBtu			4.88	21.37	Rule 62-212.410, F.A.C.	C.10
		SO2	Gas/Oil	8760	0.3% Sulfur in Oil					Rule 62-212.410, F.A.C.	C.8
-009	Diesel Generator (for -003 to -006)	NOx	Oil	400	15 gm./hp-hr.					Rule 62-212.410, F.A.C.	D.2
		SO2	Oil	400	0.3% Sulfur in Oil					Rule 62-212.410, F.A.C.	D.3

*The "Equivalent Emissions" listed are for informational purposes only.

Table 2-1, Compliance Requirements

Florida Power & Light Company Martin Plant			PROPOSED Permit No.: 0850001-004-AV Facility ID No.: 0850001					
This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.								
E.U. ID Nos.		Brief Description		Testing Time Frequency	Frequency Base Date **	Min. Compliance Test Duration	CMS*	See Permit Conditions
-001		Fossil Fuel Fired Steam Generator						
-002		Fossil Fuel Fired Steam Generator						
Pollutant Name or parameter	Compliance Method		Testing Time Frequency	Frequency Base Date **	Min. Compliance Test Duration	CMS*	See Permit Conditions	
	Fuel(s)	Method						
VE	Oil	DEP Method 9	Annual	1-Oct	1 Hour		A.16	
PM	Oil	EPA Method 5	Annual	1-Oct	3 Hours		A.18	
	Gas	EPA Method 5	Annual	1-Oct	3 Hours		A.18	
SO2	Oil	EPA Method 6C	Annual	1-Oct		Yes	A.18	
	Gas	EPA Method 6C	Annual	1-Oct		Yes	A.18	
NOx	Oil	EPA Method 7E	Annual	1-Oct		Yes	A.18	
	Gas	EPA Method 7E	Annual	1-Oct		Yes	A.18	
CO2 (Diluent Gas)						Yes	A.22	
Volumetric Flow						Yes	A.22	
Opacity						Yes	A.22	
E.U. ID Nos.		Brief Description		Testing Time Frequency	Frequency Base Date **	Min. Compliance Test Duration	CMS*	See Permit Conditions
-003		Combustion Turbine with HRSG						
-004		Combustion Turbine with HRSG						
-005		Combustion Turbine with HRSG						
-006		Combustion Turbine with HRSG						
Pollutant Name or Parameter	Compliance Method		Testing Time Frequency	Frequency Base Date **	Min. Compliance Test Duration	CMS*	See Permit Conditions	
	Fuel(s)	Method						
VE	Oil	DEP Method 9	Annual	1-Oct	1 Hour		B.27	
	Gas	DEP Method 9	Annual	1-Oct	1 Hour		B.27	
PM/PM10	Oil	EPA Method 5 or 17	Annual	1-Oct	3 Hours		B.27	
SO2 (Sulfur Content of Fuel)	Oil	ASTM D 2880-96	Daily				B.24	
	Gas	ASTM D 1072-90(94)E-1 or D 3031--81(86) or D 4084-94 or D 3246-92	Annual	1-Oct			B.24	
NOx	Oil	EPA Method 20	Annual	1-Oct		Yes	B.27	
	Gas	EPA Method 20	Annual	1-Oct		Yes	B.27	
CO	Oil	EPA Method 10	Annual	1-Oct			B.27	
	Gas	EPA Method 10	Annual	1-Oct			B.27	
CO2						Yes		

Florida Power & Light Company Martin Plant				PROPOSED Permit No.: 0850001-004-AV Facility ID No.: 0850001			
E.U. ID No. -007		Brief Description Auxiliary Boiler					
Pollutant Name or Parameter		Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date **	Min. Compliance Test Duration	See Permit Conditions
VE		Oil	DEP Method 9	Annual	1-Oct	1 Hour	C.13
SO2		Oil	ASTM D 2880-96	Daily			C.11
		Gas	ASTM D 1072-90(94)E-1	Annual	1-Oct		
E.U. ID No. -009		Brief Description Diesel Generator					
Pollutant Name or Parameter		Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date **	Min. Compliance Test Duration	See Permit Conditions
SO2		Oil	Verification by vendor receipts	On delivery			D.4
Notes: * CMS [=] Continuous Monitoring System ** Frequency base date established for planning purposes only; see Rule 62-297.310, F.A.C.							

Phase II Permit Application

For more information, see instructions and refer to 40 CFR 72.30 and 72.31 and Chapter 62-214, F.A.C.

This submission is: New Revised

STEP 1
Identify the source by plant name, State, and ORIS code from NADB

FPL Martin Plant	FL	6043
Plant Name	State	ORIS Code

STEP 2
Enter the boiler ID# from NADB for each affected unit, and indicate whether a repowering plan is being submitted for the unit by entering "yes" or "no" at column c. For new units, enter the requested information in columns d and e

a Boiler ID#	Compliance Plan		d New Units Commence Operation Date	e New Units Monitor Certification Deadline
	b Unit Will Hold Allowances in Accordance with 40 CFR 72.9(c)(1)	c Repowering Plan		
PMR1	Yes	No	N/A	N/A
PMR2	Yes	No	N/A	N/A
HRSG3A	Yes	No	2/16/94	1/1/96
HRSG3B	Yes	No	2/16/94	1/1/96
HRSG4A	Yes	No	4/15/94	1/1/96
HRSG4B	Yes	No	4/15/94	1/1/96
	Yes			
	Yes			
	Yes			
	Yes			
	Yes			
	Yes			

STEP 3
Check the box if the response in column c of Step 2 is "Yes" for any unit

For each unit that will be repowered, the Repowering Extension Plan form is included and the Repowering Technology Petition form has been submitted or will be submitted by June 1, 1997.

Plant Name (from Step 1)

STEP 4

and the standard requirements and certification, enter the name of the designated representative, and sign and date

Standard RequirementsPermit Requirements.

- (1) The designated representative of each Acid Rain source and each Acid Rain unit at the source shall:
 - (i) Submit a complete Acid Rain part application (including a compliance plan) under 40 CFR part 72, Rules 62-214.320 and 330, F.A.C. in accordance with the deadlines specified in Rule 62-214.320, F.A.C.; and
 - (ii) Submit in a timely manner any supplemental information that the permitting authority determines is necessary in order to review an Acid Rain part application and issue or deny an Acid Rain permit;
- (2) The owners and operators of each Acid Rain source and each Acid Rain unit at the source shall:
 - (i) Operate the unit in compliance with a complete Acid Rain part application or a superseding Acid Rain part issued by the permitting authority; and
 - (ii) Have an Acid Rain Part.

Monitoring Requirements.

- (1) The owners and operators and, to the extent applicable, designated representative of each Acid Rain source and each Acid Rain unit at the source shall comply with the monitoring requirements as provided in 40 CFR part 75, and Rule 62-214.420, F.A.C.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program.
- (3) The requirements of 40 CFR part 75 shall not affect the responsibility of the owners and operators to monitor emissions of other pollutants or other emissions characteristics at the unit under other applicable requirements of the Act and other provisions of the operating permit for the source.

Sulfur Dioxide Requirements.

- (1) The owners and operators of each source and each Acid Rain unit at the source shall:
 - (i) Hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)) not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and
 - (ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide.
- (2) Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act.
- (3) An Acid Rain unit shall be subject to the requirements under paragraph (1) of the sulfur dioxide requirements as follows:
 - (i) Starting January 1, 2000, an Acid Rain unit under 40 CFR 72.6(a)(2); or
 - (ii) Starting on the later of January 1, 2000 or the deadline for monitor certification under 40 CFR part 75, an Acid Rain unit under 40 CFR 72.6(a)(3).
- (4) Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program.
- (5) An allowance shall not be deducted in order to comply with the requirements under paragraph (1)(i) of the sulfur dioxide requirements prior to the calendar year for which the allowance was allocated.
- (6) An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain permit application, the Acid Rain permit, or the written exemption under 40 CFR 72.7 and 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization.
- (7) An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right.

Nitrogen Oxides Requirements. The owners and operators of the source and each Acid Rain unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides.

Excess Emissions Requirements.

- (1) The designated representative of an Acid Rain unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR part 77.
- (2) The owners and operators of an Acid Rain unit that has excess emissions in any calendar year shall:
 - (i) Pay without demand the penalty required, and pay upon demand the interest on that penalty, as required by 40 CFR part 77; and
 - (ii) Comply with the terms of an approved offset plan, as required by 40 CFR part 77.

Recordkeeping and Reporting Requirements.

- (1) Unless otherwise provided, the owners and operators of the source and each Acid Rain unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 5 years, in writing by the Administrator or permitting authority:
 - (i) The certificate of representation for the designated representative for the source and each Acid Rain unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with Rule 62-214.350, F.A.C.; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative;
 - (ii) All emissions monitoring information, in accordance with 40 CFR part 75;
 - (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the Acid Rain Program; and,

Plant Name (from Step 1)

Recordkeeping and Reporting Requirements (cont.)

(iv) Copies of all documents used to complete an Acid Rain part application and any other submission under the Acid Rain Program or to demonstrate compliance with the requirements of the Acid Rain Program.

(2) The designated representative of an Acid Rain source and each Acid Rain unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR part 72 subpart I and 40 CFR part 75.

Liability.

- (1) Any person who knowingly violates any requirement or prohibition of the Acid Rain Program, a complete Acid Rain part application, an Acid Rain part, or a written exemption under 40 CFR 72.7 or 72.8, including any requirement for the payment of any penalty owed to the United States, shall be subject to enforcement pursuant to section 113(c) of the Act.
- (2) Any person who knowingly makes a false, material statement in any record, submission, or report under the Acid Rain Program shall be subject to criminal enforcement pursuant to section 113(c) of the Act and 18 U.S.C. 1001.
- (3) No permit revision shall excuse any violation of the requirements of the Acid Rain Program that occurs prior to the date that the revision takes effect.
- (4) Each Acid Rain source and each Acid Rain unit shall meet the requirements of the Acid Rain Program.
- (5) Any provision of the Acid Rain Program that applies to an Acid Rain source (including a provision applicable to the designated representative of an Acid Rain source) shall also apply to the owners and operators of such source and of the Acid Rain units at the source.
- (6) Any provision of the Acid Rain Program that applies to an Acid Rain unit (including a provision applicable to the designated representative of an Acid Rain unit) shall also apply to the owners and operators of such unit. Except as provided under 40 CFR 72.44 (Phase II repowering extension plans), and except with regard to the requirements applicable to units with a common stack under 40 CFR part 75 (including 40 CFR 75.16, 75.17, and 75.18), the owners and operators and the designated representative of one Acid Rain unit shall not be liable for any violation by any other Acid Rain unit of which they are not owners or operators or the designated representative and that is located at a source of which they are not owners or operators or the designated representative.
- (7) Each violation of a provision of 40 CFR parts 72, 73, 75, 77, and 78 by an Acid Rain source or Acid Rain unit, or by an owner or operator or designated representative of such source or unit, shall be a separate violation of the Act.

Effect on Other Authorities. No provision of the Acid Rain Program, an Acid Rain part application, an Acid Rain part, or a written exemption under 40 CFR 72.7 or 72.8 shall be construed as:

- (1) Except as expressly provided in title IV of the Act, exempting or excluding the owners and operators and, to the extent applicable, the designated representative of an Acid Rain source or Acid Rain unit from compliance with any other provision of the Act, including the provisions of title I of the Act relating to applicable National Ambient Air Quality Standards or State Implementation Plans;
- (2) Limiting the number of allowances a unit can hold; *provided*, that the number of allowances held by the unit shall not affect the source's obligation to comply with any other provisions of the Act;
- (3) Requiring a change of any kind in any State law regulating electric utility rates and charges, affecting any State law regarding such State regulation, or limiting such State regulation, including any prudence review requirements under such State law;
- (4) Modifying the Federal Power Act or affecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act; or,
- (5) Interfering with or impairing any program for competitive bidding for power supply in a State in which such program is established.

Certification

I am authorized to make this submission on behalf of the owners and operators of the Acid Rain source or Acid Rain units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment. (There are no attachments to this document)

Name		William M. Reichel	
Signature	William M. Reichel		Date
			12/4/95

BEST AVAILABLE COPY

STEP 5 (optional)
Enter the source AIRS
and FINDS identification
numbers, if known

AIRS

FINDS