Environmental Protection



TO:

Howard L. Rhodes

THROUGH:

Clair Fancy

FROM:

A. A. Linero aa La 9/20

DATE:

September 20, 1995

SUBJECT:

Approval of Permit

Key West City Electric System

Attached for your approval is an air construction permit and BACT determination for Key West City Electric System. BACT for this unit was determined to be water injection for NOx control and low sulfur fuel oil use for SO₂ control.

The project is for relocation of a 23.5 MW simple cycle gas turbine generator from the Key West Power Plant to the existing Stock Island Power Plant only three miles away. There are no outstanding issues.

AAL/sa/t