## **MEMORANDUM**

To:

Joseph Kahn

From:

Trina L. Vielhauer

Subject:

Walt Disney World Company

Date:

August 14, 2006

Attached is the Final Air Construction Permit 0950111-026-AC for the subject facility. This permit modifies Section 3, Condition No. 6 of Air Construction Permit No. 0950111-025-AC to allow a maximum heat input of 505 mmBtu/hr, HHV at 30°F and full load operation, and replaces the existing Section 3, Condition 20(e) with a condition that addresses NOx four-hour rolling average calculations and recording. No other changes were requested or made.

The Department distributed an "Intent to Issue Permit" package on July 14, 2006. The applicant published the "Public Notice of Intent to Issue" in the Orlando Sentinel on July 21, 2006. No petitions for administrative hearings or extensions of time to petition for an administrative hearing were filed. No comments were received on the draft permit.

I recommend your signature.