



Reedy Creek Energy Services

July 26, 2006

RECEIVED

JUL 27 2006

BUREAU OF AIR REGULATION

Mr. Al Linero, P.E.
Florida Department of Environmental Protection
Division of Air Resource Management
111 South Magnolia Drive, Suite 23
Tallahassee, Florida 32301

Re: Reedy Creek Improvement District
LM6000 Repowering Project
FDEP Air Permit No. 0950111-026-AC

Dear Mr. Linero:

The Department issued Air Construction Permit No. 0950111-026-AC dated July 14, 2006 to the Walt Disney World Company, Reedy Creek Improvement District (RCID) authorizing certain modifications to Air Construction Permit 0950111-025-AC. Public Notice of the proposed modification was required. Please find enclosed Proof of Publication from the Orlando Sentinel newspaper indicating that the requisite one-day public notice appeared in the Orlando Sentinel legal notices on Friday, July 21, 2006.

Please contact me at (407) 824-4943 if you have any questions regarding this submission.

Sincerely,

Edward Godwin, P.E.
Chief Mechanical Engineer
Reedy Creek Energy Services

Attachments

cc: Mr. Leonard Kozlov
Program Administrator
Air Resources Management
Florida Department of Environmental Protection
3319 Maguire Boulevard, Suite 232
Orlando, Florida 32803-3767

**ndo
inel**

Daily

of Florida } S.S.
OF ORANGE }

The undersigned authority personally appeared BEVERLYC. SIMMONS

who on oath says
is the Legal Advertising Representative of Orlando Sentinel, a daily
published at ORLANDO, FLORIDA in

County, Florida,
held copy of advertisement, being a COMBINED CYCLE GAS
TURBINE REPLACEMENT PROJECT COMPANY

of ORLANDO, FLORIDA Court,
and in said newspaper in the issue; of ORLANDO SENTINEL

It further says that the said Orlando Sentinel is a newspaper published at
ORLANDO, FLORIDA in said

County, Florida,
said newspaper has heretofore been continuously published in

County, Florida,
Day and has been entered as second-class mail matter at the post

office at ORLANDO, FLORIDA in said
County, Florida,

for one year next preceding the first publication of the attached
advertisement; and affiant further says that he/she has neither paid
nor any person, firm or corporation any discount, rebate,
or refund for the purpose of securing this advertisement for
in the said newspaper.

This instrument was acknowledged before me this 21st day of
JULY, 20 06 by BEVERLYC. SIMMONS

personally known to me and who did take an oath.

DEBORAH M. TONEY
Comm# 000482759
Expires 11/18/2009
Bonded thru 1000432-4254
Florida Notary Public, Inc.

PUBLIC NOTICE OF INTENT TO ISSUE AIR PERMIT

Florida Department of Environmental Protection
Draft Air Permit No. 0950111-025-AC
Modification to Air Permit No. 0950111-025-AC
Walt Disney World Resort Complex -
Reedy Creek Improvement District (RCID)
Reedy Creek Energy Services -
Gas Turbine Replacement Project
Lake Buena Vista, Florida

Applicant: The applicant for this project is the Walt Disney World Company. The applicant's authorized representative and mailing address is: Mr. Lee Schmudde, Vice President; Walt Disney World Company; Reedy Creek Improvement District; Reedy Creek Energy Services; 1375 Buena Vista Drive; Lake Buena Vista, Florida 32830-4402.

Facility Location: Reedy Creek Energy Services, Inc. (RCES) operates an electrical generation and distribution system on behalf of the Reedy Creek Improvement District for the Walt Disney World Resort Complex, which is located in both Orange and Osceola counties. The address is 1375 Buena Vista Drive in Lake Buena Vista, Florida.

Project: On behalf of the Reedy Creek Improvement District, Reedy Creek Energy Services operates a combined cycle gas turbine for the Walt Disney World Resort Complex. Air construction permit 0950111-025-AC, issued by the Department on June 13, 2005, authorized the applicant to replace the existing LM 5000 gas turbine with an LM 6000PC gas turbine with SPRINT. The new gas turbine uses water injection to reduce emissions of nitrogen oxides. An oxidation catalyst will reduce emissions of carbon monoxide and volatile organic compounds. Emissions of particulate matter and sulfur dioxide will be minimized by the efficient combustion and use of natural gas and distillate oil.

On June 2, 2006, RCID requested that Section 3, Condition No. 6 of Air Construction Permit No. 0950111-025-AC be modified to allow a maximum heat input of 505 mmBtu/hr, HHV at 300F and full load operation, and to replace the existing Section 3, Condition 20(e) with a proposed Condition 20(e) that addresses NOx four hour rolling average calculations and recording. Air Construction Permit 0950111-025-AC implements these changes. No other changes to Air Construction Permit No. 0950111-025-AC were requested or made.

The existing facility is considered a "major facility" in accordance with Rule 62-212.400, F.A.C., which is the new source preconstruction review program for the Prevention of Significant Deterioration (PSD) of Air Quality in areas currently in attainment with the Ambient Air Quality Standards. However, based on the past actual emissions from the existing combined cycle gas turbine, the project will not result in a significant increase of any PSD-regulated pollutants. Therefore, the project is not subject to PSD preconstruction review.

Permitting Authority: Applications for air construction permits are subject to review in accordance with the provisions of Chapter 403, Florida Statutes (F.S.) and Chapters 62-4, 62-210, and 62-212 of the Florida Administrative Code (F.A.C.). The proposed project is not exempt from air permitting requirements and an air permit is required to perform the proposed work. The Bureau of Air Regulation is the Permitting Authority responsible for making a permit determination for this project. The Permitting Authority's physical address is: 111 South Magnolia Drive, Suite #4, Tallahassee, Florida. The Permitting Authority's mailing address is: 2600 Blair Stone Road, MS #5505, Tallahassee, Florida 32399-2400. The Permitting Authority's telephone number is 850-488-0114.

Project File: A complete project file is available for public inspection during the normal business hours of 8:00 a.m. to 5:00 p.m., Monday through Friday (except legal holidays), at address indicated above for the Permitting Authority. The complete project file includes the Draft Permit, the Technical Evaluation and Preliminary Determination, the application, and the information submitted by the applicant, exclusive of confidential records under Section 403.111, F.S. Interested persons may contact the Permitting Authority's project review engineer for additional information at the address or phone number listed above. A copy of the complete project file is also available at the Air Resource Section of the Department's Central District Office at 3319 Maguire Boulevard, Suite 232, Orlando, Florida 32803-1767. The telephone number is 407/894-7555. Notice of Intent to Issue Air Permit: The Permitting Authority gives notice of its intent to issue an air permit to the applicant for the project described above. The applicant has provided reasonable assurance that operation of proposed equipment will not adversely impact air quality and that the project will comply with appropriate provisions of Chapters 62-4, 62-204, 62-210, 62-212, 62-296, and 62-297, F.A.C. The Permitting Authority will issue a Final Permit in accordance with the conditions of the proposed Draft Permit unless a timely petition for an administrative hearing is filed under Sections 120.569 and 120.57, F.S. or unless public comment received in accordance with this notice results in a different decision or a significant change of terms or conditions.

Comments: The Permitting Authority will accept written comments concerning the proposed Draft Permit for a period of fourteen (14) days from the date of publication of this Public Notice. Written comments must be provided to the Permitting Authority at the above address. Any written comments filed will be made available for public inspection. If written comments received result in a significant change to the Draft Permit, the Permitting Authority shall revise the Draft Permit and require, if applicable, another Public Notice.