

STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL REGULATION

TWIN TOWERS OFFICE BUILDING
2600 BLAIR STONE ROAD
TALLAHASSEE, FLORIDA 32301



BOB GRAHAM
GOVERNOR
VICTORIA J. TSCHINKEL
SECRETARY

May 19, 1982

Mr. James T. Wilburn, Chief
Air Management Branch
Region IV EPA
345 Courtland Street, N.E.
Atlanta, Georgia 30365

Dear Mr. Wilburn:

On May 17, 1982, the Bureau received a comment, postmarked May 14, from Mr. B. E. Shoup, Director of Environmental Division, Orlando Utilities Commission, about a Specific Condition of the Final Determination of the Federal PSD Permit, PSD-FL-084 (letter is attached). The only comment they addressed was Specific Condition No. 10.d., stating that the limestone handling receiving hopper would be controlled with a water spray and will not be under a negative pressure.


The Bureau agrees with the comment and has revised Specific Condition No. 10.d. to read:

- 10.d. The limestone transfer conveyors and day silos will be maintained at negative pressures while operating with the exhaust vented to a control system. Water sprays shall be used to control particulate matter emissions from coal and limestone receiving hoppers.

Since the Final Determination was mailed to your office on May 14, 1982, the Bureau requests that you accept this revision of the original Final Determination.

If there are any questions please write me at the above address or call me at (904) 488-1344.

Sincerely,


C. H. Fancy, P.E.
Deputy Bureau Chief
Bureau of Air Quality Management

CHF/BM/jf

cc: Mr. B. E. Shoup, OUC
Mr. H. S. Oven, DER
Mr. C. M. Collins, DER



ORLANDO UTILITIES COMMISSION

500 SOUTH ORANGE AVENUE • P. O. BOX 3193 • ORLANDO, FLORIDA 32802 • 305/423-9100

GRACE C. LINDBLOM
President

May 14, 1982

Bill

W. M. SANDERLIN
First Vice President

Mr. C. H. Fancy
Bureau of Air Quality Management
Department of Environmental Regulation
2600 Blair Stone Road
Tallahassee, Florida 32301

MAY 17 1982
BAQM
DEF

I. RICHARD WEINER
Second Vice President

RE: Orlando Utilities Commission Curtis H. Stanton
Power Plant Proposed Prevention of Significant
Deterioration Permit

Dear Mr. Fancy:

BILL FREDERICK
Mayor

In our review of the proposed PSD permit conditions, Item 10.d. Page 30 of the Technical Evaluation and Preliminary Determination (PSD-FL-084), we discovered that the limestone receiving hopper had been included in a list of items to be maintained at negative pressure and vented to a control system. However, our proposed design is for train unloading of limestone where maintenance of negative pressure is not feasible. The proposed method of dust control for the bottom dump limestone unloading is water sprays and building enclosure. The building enclosure will, of course, be open at each end where the train enters and leaves the building. Of course, the limestone conveyor system and the day silo will be under negative pressure.

CHARLES J. HAWKINS
Immediate Past President

CURTIS H. STANTON
Executive Vice President
& General Manager

Please advise if you require any additional information.

Sincerely yours,

B. E. Shoup
Director
Environmental Division

BES/jh

cc: Mr. C. H. Stanton
Mr. L. E. Stone
Mr. T. B. Tart
Mr. W. H. Herrington
Mr. E. C. Windisch
Mr. S. M. Day
Mr. H. S. Oven

GURNEY, GURNEY &
HANDLEY, P.A.
General Counsel

J. THOMAS GURNEY, SR.
P.O. Box 1273
Orlando, FL 32802
305/843-9500