



VIA AIRBORNE EXPRESS

June 10, 1996

Clair H. Fancy, P.E., Chief  
Bureau of Air Regulation  
State of Florida  
Department of Environmental Protection  
2600 Blair Stone Road  
Tallahassee, FL 32399-2400

**RECEIVED**

JUN 12 1996

BUREAU OF  
AIR REGULATION

**Re: Submittal of FPL Riviera Plant Title V Application**

Dear Mr. Fancy:

Enclosed, pursuant to DEP Rules 62-210.300(2), F.A.C., and 62-213.420(1)(a)1.a., F.A.C., please find four (4) hard copies of the subject Title V permit application. Due to the recent FDEP recall of the ELSA program, the diskettes containing the electronic application are not included at this time. FPL has worked diligently to prepare an electronic submittal and will submit diskettes containing the electronic application at a later date (when the ELSA program deficiencies have been resolved).

If you have any questions regarding this application, please do not hesitate to contact me at (561) 625-7661.

Very truly yours,

A handwritten signature in cursive script that reads "Richard Piper".

Richard Piper  
Environmental Specialist  
Florida Power & Light Company

cc: DEP Southeast District Office (w/o att)



March 31, 1997

Ms. Virginia B. Wetherell, Secretary  
State of Florida  
Department of Environmental Protection  
2600 Blair Stone Road  
Tallahassee, FL 32399-2400

**Re: Change of Responsible Official Designation  
Title V Program**

Dear Ms. Wetherell:

This correspondence is to certify that Ms. Jay Asaibene has replaced Mr. John Lindsay as Plant General Manager of the FPL Riviera Plant. As Plant General Manager, Ms. Asaibene is authorized to act as the "Responsible Official" for that facility, pursuant to State Rule 62-216.200, F.A.C.. Ms. Asaibene is hereby authorized to act on behalf of Florida Power & Light Company on all Title V permit related activities for the Riviera plant.

Sincerely,

A handwritten signature in cursive script that reads "Adalberto Alfonso".

Adalberto Alfonso  
Vice President,  
Power Generation Business Unit  
Florida Power & Light Company

cc: Scott Sheplak  
Tom Tittle

FDEP DARM  
FDEP Southeast District

**RECEIVED**

APR 07 1997

BUREAU OF  
AIR REGULATION

**TABLE OF CONTENTS**  
**RIVIERA PLANT TITLE V APPLICATION**

Section 1 - Application Information

Section 2 - Facility Information

Section 3 - Emission Unit Information

(includes Emission Unit description, applicable regulations, emission point information, segment information, pollutant information, visible emission information, continuous monitor information, and supplemental information.)

Emission Unit 1 = Unit 3 Boiler

Emission Unit 2 = Unit 4 Boiler

Emission Unit 3 = Unregulated Trivial & De Minimis Emission Units

HD

FPL RIVIERA PLANT  
TITLE V APPLICATION  
IN THE ELSA FORMAT

BYB 10/3/96 - Virus Scan

HD

FPL RIVIERA PLANT  
TITLE V APPLICATION  
IN THE ELSA FORMAT

BYB 10/3/96 - Virus Scan

HD

FPL RIVIERA PLANT  
TITLE V APPLICATION  
IN THE ELSA FORMAT

BYB 10/3/96 - Virus Scan

HD

FPL RIVIERA PLANT  
TITLE V APPLICATION  
IN THE ELSA FORMAT

BYB 10/3/96 - Virus Scan

DEPARTMENT OF ENVIRONMENTAL PROTECTION  
DIVISION OF AIR RESOURCES MANAGEMENT

APPLICATION FOR AIR PERMIT - LONG FORM

See Instructions for Form No. 62-210.900(1)

**I. APPLICATION INFORMATION**

This section of the Application for Air Permit form identifies the facility and provides general information on the scope and purpose of this application. This section also includes information on the owner or authorized representative of the facility (or the responsible official in the case of a Title V source) and the necessary statements for the applicant and professional engineer, where required, to sign and date for formal submittal of the Application for Air Permit to the Department. If the application form is submitted to the Department using ELSA, this section of the Application for Air Permit must also be submitted in hard-copy form.

**Identification of Facility Addressed in This Application**

Enter the name of the corporation, business, governmental entity, or individual that has ownership or control of the facility; the facility site name, if any; and a brief reference to the facility's physical location. If known, also enter the facility identification number.

1. Facility Owner/Company Name: Florida Power & Light Company	
2. Site Name: Riviera Plant	
3. Facility Identification Number : 0990042	
4. Facility Location Information: Facility Street Address: 200-300 Broadway City: Riviera Beach                      County: Palm Beach                      Zip Code: 33404	
5. Relocatable Facility? (Y/N): N	6. Existing Permitted Facility?(Y/N): Y

**Application Processing Information (DEP Use)**

1. Date of Receipt of Application:	
2. Permit Number:	
3. PSD Number (if applicable):	
4. Siting Number (if applicable):	



**Scope of Application**

This Application for Air Permit addresses the following emissions unit(s) at the facility (or Title V source). An Emissions Unit Information Section (a Section III of the form) must be included for each emissions unit listed.

<b>Emission s Unit Id</b>	<b>Description of Emissions Unit</b>	<b>Permit Type</b>
01	Fossil Fuel Steam Generator, Unit 3 (ARMS ID # 50PMB500042003)	
02	Fossil Fuel Steam Generator, Unit 4 (ARMS ID # 50PMB500042004)	
03	Unregulated Emission Units	

**Purpose of Application and Category**

Enter the Letter that applies and related information (except as otherwise indicated):

**Category I: All Air Operation Permit Applications Subject to Processing Under Chapter 17-213, F.A.C.**

This Application for Air Permit is submitted to obtain (A,B,C,D,E,F): A

[ A ] Initial air operation permit under Chapter 17-213, F.A.C., for an existing facility which is classified as a Title V source.

[ B ] Initial air operation permit under Chapter 17-213, F.A.C., for a facility which, upon start up of one or more newly constructed or modified emissions units addressed in this application, would become classified as a Title V source.

Current construction permit number:

[ C ] Air operation permit renewal under Chapter 17-213, F.A.C., for a Title V source.

Operation permit to be renewed:

[ D ] Air operation permit revision for a Title V source to address one or more newly constructed or modified emissions units addressed in this application.

Current construction permit number:

Operation permit to be revised:

[ E ] Air operation permit revision or administrative correction for a Title V source to address one or more proposed new or modified emissions units and to be processed concurrently with the air construction permit application for such emissions unit(s). Also check appropriate item under Category III.

Operation permit to be revised/corrected:

[ F ] Air operation permit revision for a Title V source for reasons other than construction or modification of an emissions unit. Give reason for the revision; e.g., to comply with a new applicable requirement or to request approval of an "Early Reductions" proposal.

Operation permit to be revised:

Reason for Revision:



**Category II: All Air Operation Permit Applications Subject to Processing Under Rule 17-210.300(2)(b), F.A.C.**

This Application for Air Permit is submitted to obtain (A,B,C):

- [ A ] Initial air operation permit under Rule 17-210.300(2)(b), F.A.C., for an existing facility seeking classification as a synthetic non-Title V source.

Current operation/construction permit number(s):

- [ B ] Renewal air operation permit under Rule 17-210.300(2)(b), F.A.C., for a synthetic non-Title V source.

Operation permit to be renewed:

- [ C ] Air operation permit revision for a synthetic non-Title V source. Give reason for revision; e.g., to address one or more newly constructed or modified emissions units addressed herein.

Operation permit to be revised:

Reason for revision:

**Category III: All Air Construction Permit Applications for All Facilities and Emissions Units**

This Application for Air Permit is submitted to obtain (A,B,C):

- [ A ] Air construction permit to construct or modify one or more emissions units within a facility (including any facility classified as a Title V source).

Current operation permit number(s), if any:

- [ B ] Air construction permit to make federally enforceable an assumed restriction on the potential emissions of one or more existing permitted emissions units.

Current operation permit number(s):

- [ C ] Air construction permit for one or more existing, but unpermitted, emissions units.

**Application Processing Fee**

Check one:

[ N ] Applicable (Y/N)                      Attached - Amount: \$

**Construction/Modification Information**

1. Description of Proposed Project or Alterations : N/A
2. Projected or Actual Date of Commencement of Construction (DD-MON-YYYY):
3. Projected Dates of Completion of Construction (DD-MON-YYYY):

**Professional Engineer Certification**

1. Professional Engineer Name: Kennard F. Kosky Registration Number: 14996
2. Professional Engineer Mailing Address:  Organization/Firm: KBN Engineering & Appl Sciences Street Address: 6241 NW 23rd Street City: Gainesville    State: FL Zip Code: 326531500
3. Professional Engineer Telephone Numbers: Telephone: 3523365600    Fax: 3523366603

RIVIERA PLANT

4. Professional Engineer Statement:

*I, the undersigned, hereby certify, except as particularly noted herein\*, that:*

*(1) To the best of my knowledge, there is reasonable assurance that the air pollutant emissions unit(s) and the air pollution control equipment described in this Application for Air Permit, when properly operated and maintained, will comply with all applicable standards for control of air pollutant emissions found in the Florida Statutes and rules of the Department of Environmental Protection; and*

*(2) To the best of my knowledge, any emission estimates reported or relied on in this application are true, accurate, and complete and are either based upon reasonable techniques available for calculating emissions or, for emission estimates of hazardous air pollutants not regulated for a emission unit addressed in this application, based solely upon the materials, information and calculations submitted with this application.*

*If the purpose of this application is to obtain a Title V source air operation permit (check her [X] if so), I further certify that each emissions unit described in this Application for Air Permit, when properly operated and maintained, will comply with the applicable requirements identified in this application to which the unit is subject, except those emissions units for which a compliance schedule is submitted with this application.*

*If the purpose of this application is to obtain an air construction permit for one or more proposed new or modified emission units (check here [ ] if so), I further certify that the engineering features of each such emissions unit described in this application have been designed or examined by me or individuals under my direct supervision and found to be in conformity with sound engineering principles applicable to the control of emissions of the air pollutants characterized in this application.*

*If the purpose of this application is to obtain an initial air operation permit or operation permit revision for one or more newly constructed or modified emissions units (check here [ ] if so), I further certify that, with the exception of any changes detailed as part of this application, each such emissions unit has been constructed or modified in substantial accordance with the information given in the corresponding application for air construction permit and with all provisions contained in such permit.*

*Thomas A. King*

*6/5/96*

Signature

Date

(seal)

\*Attach any exception to certification statement.

**Application Contact Information**

1. Name and Title of Application Contact: Name: Richard G. Piper Title: Environmental Specialist
2. Application Contact Mailing Address:  Organization/Firm: FPL Environmental Services Department Street Address: P.O. Box 088801 City: North Palm Beach                      State: FL                      Zip Code: 33408
3. Application Contact Telephone Numbers: Telephone: 5616257661                      Fax: 5616257251

**Application Comment**

<p>This application is for the FPL Riviera Power Plant, which is located at 200 - 300 Broadway, Riviera Beach, Palm Beach County, Florida on the Intracoastal Waterway.</p> <p>The plant consists of two conventional steam electric generating stations, designated as units 3 and 4, four residual fuel oil storage tanks, and a 500 kilowatt diesel engine generator. The facility had at one time operated a 75 MW steam generating unit (Unit 2, permit #AO50-174444); however, this unit is no longer in service.</p> <p>Units 3 &amp; 4 are each comprised of a Foster-Wheeler outdoor-type boiler/steam generator and a General Electric steam turbine which drives an oil and hydrogen-cooled 300 MW class generator with gross capability of 315 megawatts.</p>
---



**Facility Regulatory Classifications**

1. Small Business Stationary Source? (Yes/No/Unknown)(Y/N/U) : N
2. Title V Source? (Yes/No) (Y/N) : Y
3. Synthetic Non-Title V Source? (Yes/No) (Y/N) : N
4. Major Source of Pollutants Other than Hazardous Air Pollutants (HAPs)? (Yes/No) (Y/N) : Y
5. Synthetic Minor Source of Pollutants Other than HAPs? (Yes/No) (Y/N) : N
6. Major Source of HAPs? (Yes/No/Possible) (Y/N/P) : Y
7. Synthetic Minor Source of HAPs? (Yes/No) (Y/N) : N
8. One or More Emissions Units Subject to NSPS? (Yes/No) (Y/N) : N
9. One or More Emissions Units Subject to NESHAP? (Yes/No) (Y/N) : Y
10. Title V Source by EPA Designation? (Yes/No) (Y/N) : N
11. Facility Regulatory Classifications Comment (limit to 200 characters): The facility is located in a former non-attainment area for ozone (recently redesignated to an air quality maintenance area) therefore the generating units are subject to NOx-RACT.

## B. FACILITY REGULATIONS

**Rule Applicability Discussion** (Required for Category II applications and Category III applications involving non Title-V sources. See Instructions.)

Not Applicable

**List of Applicable Regulations** (Required for Category I applications and Category III applications involving Title-V sources. See Instructions.)

Information for Facility-Id : 1

<p>40 CFR 61.05  40 CFR 61.12(b)  40 CFR 61.145  40 CFR 61.148  40 CFR 61.150  40 CFR 61.19  F.A.C. 62-204.800(8)(b)8.  (state only)  F.A.C. 62-204.800(8)(d)  (state only)  F.A.C. 62-210.300(2)  (except (b))  F.A.C. 62-210.300(3)(a)10.  F.A.C. 62-210.300(3)(a)11.  F.A.C. 62-210.300(3)(a)12.  F.A.C. 62-210.300(3)(a)15.  F.A.C. 62-210.300(3)(a)16.  F.A.C. 62-210.300(3)(a)17.  F.A.C. 62-210.300(3)(a)20.  F.A.C. 62-210.300(3)(a)21.</p>	<p>F.A.C. 62-210.300(3)(a)22.  F.A.C. 62-210.300(3)(a)23.  F.A.C. 62-210.300(3)(a)24.  F.A.C. 62-210.300(3)(a)4.  F.A.C. 62-210.300(3)(a)5.  F.A.C. 62-210.300(3)(a)7.  F.A.C. 62-210.300(3)(a)8.  F.A.C. 62-210.300(3)(a)9.  F.A.C. 62-210.300(3)(b)  F.A.C. 62-210.370(3)  F.A.C. 62-210.900(5)  F.A.C. 62-213.205(1)(a)  F.A.C. 62-213.205(1)(b)  F.A.C. 62-213.205(1)(c)  F.A.C. 62-213.205(1)(e)  F.A.C. 62-213.205(1)(f)  F.A.C. 62-213.205(1)(g)</p>	<p>F.A.C. 62-213.205(1)(i)  F.A.C. 62-213.205(1)(j)  F.A.C. 62-213.205(4)  F.A.C. 62-213.205(5)  F.A.C. 62-213.400  F.A.C. 62-213.410  F.A.C. 62-213.420(1)(b)2.  F.A.C. 62-213.420(1)(b)3.  F.A.C. 62-213.430(3)  F.A.C. 62-213.460  F.A.C. 62-256.300(1)  F.A.C. 62-256.300(2)  F.A.C. 62-256.300(3)  F.A.C. 62-256.300(4)  F.A.C. 62-256.300(7)  F.A.C. 62-256.300(8)  F.A.C. 62-256.300(9)</p>	<p>F.A.C. 62-256.500  F.A.C. 62-256.600  F.A.C. 62-256.700  F.A.C. 62-257.300  F.A.C. 62-257.301  F.A.C. 62-257.350  F.A.C. 62-257.400  F.A.C. 62-257.401  F.A.C. 62-257.900  F.A.C. 62-296.320(2)  (state only)  F.A.C. 62-296.320(3)(b)  (state only)  F.A.C. 62-296.320(4)(b)  F.A.C. 62-296.320(4)(c)  F.A.C. 62-297.310(7)(a)10.  F.A.C. 62-4.030  F.A.C. 62-4.040(1)(a)  F.A.C. 62-4.040(1)(b)  F.A.C. 62-4.100  F.A.C. 62-4.130  Palm Beach County  Ordinance 78-5 Section 2  (state only)</p>
---	---	--	---



### C. FACILITY POLLUTANTS

**Facility Pollutant Information :**

1. Pollutant Emitted:	2. Pollutant Classification
SO2	A
NOX	A
CO	A
VOC	A
PM	A
PM10	A
H133	A
H106	A
H107	A
SAM	A
HAP	A

## E. FACILITY SUPPLEMENTAL INFORMATION

### Supplemental Requirements for All Applications For Facility :/

1. Area Map Showing Facility Location: PRVFS-1.bmp (Enter the Attached Document ID, NA - Not Applicable or WaiverRequested)
2. Facility Plot Plan: PRVFS-2.bmp (Enter the Attached Document ID, NA - Not Applicable or WaiverRequested)
3. Process Flow Diagram(s): PRVFS-3.bmp (Enter the Attached Document ID, NA - Not Applicable or WaiverRequested)
4. Precautions to Prevent Emissions of Unconfined Particulate Matter: PRVFS-4.txt (Enter the Attached Document ID, NA - Not Applicable or WaiverRequested)
5. Fugitive Emissions Identification : PRVFS-5.txt (Enter the Attached Document ID, NA - Not Applicable or WaiverRequested)
6. Supplemental Information for Construction Permit Application: NA (Enter the Attached Document ID, NA - Not Applicable)

### Additional Supplemental Requirements for Category I Applications Only

7. List of Proposed Exempt Activities: Not Applicable (Enter the Attached Document ID, NA - Not Applicable)
8. List of Equipment/Activities Regulated under Title VI: PRVFS-8.txt (Enter the Attached Document ID, Equipment/Activities Onsite but not Required to be Individually Listed, NA - Not Applicable)
9. Alternative Methods of Operation: PRVFS-9.txt (Enter the Attached Document ID, NA - Not Applicable)
10. Alternative Modes of Operation (Emissions Trading): NA (Enter the Attached Document ID, NA - Not Applicable)
11. Identification of Additional Applicable Requirements: PRVFS_11. txt (Enter the Attached Document ID, NA - Not Applicable)
12. Compliance Assurance Monitoring Plan: NA (Enter the Attached Document ID, NA - Not Applicable)

13. Risk Management Plan Verification: PLANNED

Plan Submitted to Implementing Agency - Verification Attached(Attached Document ID)

Plan to be Submitted to Implementing Agency by Required Date

Not Applicable (NA)


14. Compliance Report and Plan: PRVFS-13.txt  
(Enter the Attached Document ID, NA - Not Applicable)

15. Compliance Statement (Hard-copy Required): PRVFS-14.txt  
(Enter the Attached Document ID, NA - Not Applicable)

# TITLE V PERMIT APPLICATION



Riviera Plant





Attachment: prvfs\_1.bmp






# Riviera Plant Area Map


## Palm Beach County



Environmental  
**FPL Affairs**



-  Riviera Plant
-  Water
-  Residential
-  Major Roads
-  Railroads





Source: Landuse data provided by South Florida Water Management District (1993)

No expressed or implied warranties including, but not limited to the implied warranties of MERCHANTABILITY OF FITNESS FOR A PARTICULAR PURPOSE are made. The materials contained herein are provided 'as is' and may contain inaccuracies and user is warned to utilize the material's accuracy independently and assumes the risk of any and all loss.

/export/home/ron/prv-site.map (6-95)



TECHNICAL ACCEPTANCE	
CHK BY	DATE
ENGINEERING	
ORGANIZATION	
WALDOORN INFORMATION	
CHK BY	DATE
AS-BUILT INFORMATION	



N 885,000

E-W BASELINE S 88° 28' 28" E

N 884,500

N 884,000  
SOUTH CITY LIMIT LINE OF RIVIERA  
NORTH CITY LIMIT LINE OF WEST PALM BEACH

BROADWAY AVE. (US-1)

59th STREET

LAKE WORTH

REV	DATE	ISSUED FOR TITLE V PERMITS	REVISION DESCRIPTION
0	7/24/23	ISSUED FOR TITLE V PERMITS	


DRN	PWB	CSP	CSP	ETS
BY	CH	CDR	APR	ORC

**FPL**

SYSTEM	YY	DISCIPLINE	PLANT/UNIT	RIVIERA PLANT-UNIT 3 & 4
SCALE	E(30" X 42")	CD FILE NAME	RY002854	TITLE
DRAWING SIZE	E(30" X 42")	PL ARCHIVE NAME	RY002854	FACILITY PLOT PLAN ATTACHMENT FS-2 TITLE V
DRAWING NUMBER	PRV3-M0002-YY	SHEET	1 OF 1	REV
			0	

NEW ACQUIRED PROPERTY, CAD ENTRY NOT UPDATED FROM AERIAL PHOTOGRAPH

TECHNICAL ACCEPTANCE		
ORG	BY	DATE
WALKDOWN INFORMATION		
ORG	BY	DATE
AS-BUILT INFORMATION		
ORG	BY	DATE



SCALE 3/8" = 1'-0"

SCALE 1/4" = 1'-0"

- NOTES:
- ACRONYMS:  
 EU-EMISSION UNIT  
 FO-FUEL OIL  
 LP-LIQUID PROPANE
  - EMISSION UNITS ARE IDENTIFIED WITH A RECTANGULAR BOX:  
 EMISSION UNIT NUMBER

TANK LEGEND:  
 T - STORAGE TANK (TA,B,C&D)  
 LO - LIGHT OIL TANK

	SYSTEM YY	DISCIPLINE M	PLANT/UNIT RIVIERA PLANT-UNIT 3 & 4	BAR CODE
	SCALE N/A	CAD FILE NAME RV002855	TITLE FACILITY SOURCE FLOW DIAGRAM ATTACHMENT NO. FS-3 TITLE V	
	DRAWING SIZE B(11"X17")	FPL ARCHIVE NAME RV002855		
	DRAWING NUMBER PRV3-M0105-YY		SHEET 1 OF 1	

0	7/25/95	ISSUED FOR TITLE V PERMIT	PWB	PWB	CSP	CSP	ETS
REV	DATE	REVISION DESCRIPTION	BY	CH	COR	APR	ORG

**Attachment PRVFS\_4.txt**  
**Precautions to Prevent Emissions of Unconfined Particulate Matter**

The facility has negligible amounts of unconfined particulate matter as a result of the operation of the facility. Potential examples of particulate matter include:

- fugitive dust from unpaved roads
- sandblasting abrasive material from plant maintenance activities
- fugitive particulates from the use of bagged chemical products (soda ash, di-, tri- and monosodium phosphate, and other chemicals as needed)

Several precautions were taken to prevent emissions of particulate matter in the *original design* of the facility. These include:

- Paving of roads, parking areas and equipment yards
- Landscaping and planting of vegetation

*Operational measures* are undertaken at the facility which also minimize particulate emissions, in accordance with 62-296.310 F.A.C.:

- The facility constructs temporary sandblasting enclosures when necessary, in order to perform sandblasting on fixed plant equipment.
- Maintenance of paved areas as needed
- Regular mowing of grass and care of vegetation
- Limiting access to plant property by unnecessary vehicles.
- Bagged chemical products are stored in weather-tight buildings until they are used. Spills of powdered chemical products are cleaned up as soon as practicable.
- Vehicles are restricted to slow speeds on the plant site



**Attachment PRVFS\_5.txt  
Fugitive Emission Identification**

***Criteria and Precursor Air Pollutants***

Fugitive particulate emissions are addressed in Attachment PRVFS\_4.DOC. FPL is not aware of fugitive emissions of sulfur dioxide, nitrogen oxides, carbon monoxide or lead compounds which would exceed the reporting thresholds defined in the permit application instructions.

***Fugitive HAPs Emissions***

FPL is not aware of fugitive emissions of HAP pollutants which would exceed the reporting thresholds defined in the permit application instructions.

**Attachment PRVFS\_8.txt**

**EQUIPMENT / ACTIVITIES REGULATED UNDER TITLE VI**

The Riviera facility has many refrigeration and air-conditioning units on the plant site. Of these, there are no units which currently meet the 50-pound threshold established by 40 CFR 82 for regulated Class 1 and Class 2 substances.

**Attachment PRVFS\_9.txt**  
**Alternative Methods of Operation**

There are no known methods of operation at the current time at Riviera plant which would simultaneously affect emissions at more than one emissions unit but would not constitute emissions trading.

**Attachment PRVFS\_13.txt  
Riviera Plant  
Compliance Report and Plan**

The facility and emissions units identified in this application are in compliance with the Applicable Requirements identified in Sections II.B. and III.D. of the application form and attachments referenced in Section III.L. 12 (if included). Compliance is certified as of the date this application is submitted to the Florida Department of Environmental Regulation as required in Rule 62-213.420(1)(a) F.A.C..

Attachment PRVFS\_14.txt  
Riviera Plant  
Compliance Statement

I, the undersigned, am the responsible official as defined in Chapter 62-213, F.A.C., of the Title V source for which this report is being submitted. I hereby certify, based on information and belief formed after reasonable inquiry, that the statements made and data contained in this report are true, accurate, and complete.

  
\_\_\_\_\_  
Signature, Responsible Official

  
\_\_\_\_\_  
Date

Proposed Schedule for submittal of periodic compliance statements to the Department:

FPL will submit an annual compliance statement to the Department's Southeast District Office concurrently with the submittal of the Annual Operating Report for this facility.

III. EMISSIONS UNIT INFORMATION

Information for Facility - ID : 1 Emission Unit # : 1

A separate Emissions Unit Information Section (including subsections A through L as required) must be completed for each emissions unit addressed in this Application for Air Permit. If submitting the application form in hard copy, indicate, in the space provided at the top of each page, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application. Some of the subsections comprising the Emissions Unit Information Section of the form are intended for regulated emissions units only. Others are intended for both regulated and unregulated emissions units. Each subsection is appropriately marked.

A. TYPE OF EMISSIONS UNIT (Regulated and Unregulated Emissions Units)

Type of Emissions Unit Addressed in This Section

1. Regulated or Unregulated Emissions Units? Check one:

- [ X ] The emissions unit addressed in this Emissions Unit Information Section is a regulated emissions unit.
[ ] The emissions unit addressed in this Emissions Unit Information Section is a unregulated emissions unit.

2. Single Process, Group Processes, or Fugitive Only?

Enter The Number (1-3): 1

- [ 1 ] This Emissions Unit Information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).
[ 2 ] This Emissions Unit Information Section addresses, as a single emissions unit, a group of process or production units and activities which has at least one definable emission point(stack or vent) but may also produce fugitive emissions.
[ 3 ] This Emissions Unit Information Section addresses, as a single emissions unit, one or more process or production units and activities which produce fugitive emissions only.

**B. GENERAL EMISSIONS UNIT INFORMATION  
(Regulated and Unregulated Emissions Units)**

**Emissions Unit Description and Status**

1. Description of Emissions Unit Addressed in This Section (limit to 60 characters): Fossil Fuel Steam Generator, Unit 3
2. Emissions Unit Identification Number: 003 (No Corresponding ID or Unknown)
3. Emission Unit Status Code: (A or C) : A
4. Acid Rain Unit? (Y/N): Y
5. Emissions Unit Major Group SIC Code: 49
6. Emissions Unit Comment (limit to 500 characters): The generator nameplate rating given is taken from data provided to the Florida Public Service Commission (PSC) in the 10-Year Site Plan. Actual generator output may exceed the value given, due to changes in unit efficiency, or with fluctuations in system load demand.

**Emissions Unit Control Equipment**

**A. Control Equipment # : 1**

1. Description (limit to 200 characters): Multiple cyclone with fly Ash Reinjection
2. Control Device or Method Code: Multiple Cyclone w/Fly Ash Reinjection

**B. Control Equipment # : 2**

1. Description (limit to 200 characters): Low Nox Burners
2. Control Device or Method Code: Modified Furnace or Burner Design

**C. Control Equipment # :**

1. Description (limit to 200 characters):
2. Control Device or Method Code:



**C. EMISSIONS UNIT DETAIL INFORMATION  
(Regulated Emissions Units)**

**Emissions Unit Details**

1. Initial Startup Date (DD-MON-YYYY): 05/01/62
2. Long-term Reserve Shutdown Date (DD-MON-YYYY):
3. Package Unit: <div style="display: flex; justify-content: space-between;"> <span>Manufacturer: Foster-Wheeler</span> <span>Model Number: NA</span> </div>
4. Generator Nameplate Rating: 310 MW
5. Incinerator Information: <div style="margin-left: 40px;">Dwell Temperature: °F</div> <div style="margin-left: 40px;">Dwell Time: seconds</div> <div style="margin-left: 40px;">Incinerator Afterburner Temperature: °F</div>

**Emissions Unit Operating Capacity**

1. Maximum Heat Input Rate: 3260 mmBtu/hr
2. Maximum Incineration Rate: lbs/hr <div style="margin-left: 100px;">tons/day</div>
3. Maximum Process or Throughput Rate: Units:
4. Maximum Production Rate: Units:
5. Operating Capacity Comment (limit to 200 characters): Maximum Heat Input Rate is based on firing 100% Natural Gas. The Heat Input Rate for #6 fuel oil is 3050 mmBtu/hr. The method of compliance for determining heat input is fuel sampling and analysis.

**Emissions Unit Operating Schedule**

Requested Maximum Operating Schedule:	
hours/day	days/week
weeks/yr	8760 hours/yr

**D. EMISSIONS UNIT REGULATIONS  
(Regulated Emissions Units Only)**

**Rule Applicability Analysis** (Required for Category II applications and Category III applications involving non Title-V sources. See Instructions.)

Not Applicable

**List of Applicable Regulations** (Required for Category I applications and Category III applications involving Title-V sources. See Instructions.)

## Emissions Unit ID 1

40 C.F.R. 279.72	40 C.F.R. 75 Appendix C-1	40 C.F.R. 75.4(a)(4)(ii)	F.A.C. 62-214.350 (3)
40 C.F.R. 72.20(a)	40 C.F.R. 75 Appendix C-2	40 C.F.R. 75.5	F.A.C. 62-214.350 (5)
40 C.F.R. 72.20(b)	40 C.F.R. 75 Appendix D	40 C.F.R. 75.51(c)	F.A.C. 62-214.350 (6)
40 C.F.R. 72.20(c)	40 C.F.R. 75 Appendix F	40 C.F.R. 75.53(a)	F.A.C. 62-214.370 (1)
40 C.F.R. 72.21(a)	40 C.F.R. 75 Appendix G-2	40 C.F.R. 75.53(b)	F.A.C. 62-214.370 (3)
40 C.F.R. 72.21(b)	40 C.F.R. 75 Appendix G-4	40 C.F.R. 75.53(c)	F.A.C. 62-214.370 (4)
40 C.F.R. 72.21(d)	40 C.F.R. 75 Appendix H	40 C.F.R. 75.53(d)(1)	F.A.C. 62-214.370 (7)
40 C.F.R. 72.22(a)	40 C.F.R. 75.10(a)(1)	40 C.F.R. 75.54	F.A.C. 62-214.430
40 C.F.R. 72.22(c)	40 C.F.R. 75.10(a)(2)	40 C.F.R. 75.55(c)	F.A.C. 62-296.405(1)(a)
40 C.F.R. 72.23	40 C.F.R. 75.10(a)(3)(i)	40 C.F.R. 75.55(e)	paragraph 2
40 C.F.R. 72.24(a)	40 C.F.R. 75.10(a)(4)	40 C.F.R. 75.56	F.A.C. 62-296.405(1)(b)
40 C.F.R. 72.30(a)	40 C.F.R. 75.10(b)	40 C.F.R. 75.60(a)	F.A.C. 62-296.405(1)(c)1. j.
40 C.F.R. 72.30(b)(2)	40 C.F.R. 75.10(c)	40 C.F.R. 75.60(b)	F.A.C. 62-296.405(1)(e)(1)
40 C.F.R. 72.30(c)	40 C.F.R. 75.10(d)	40 C.F.R. 75.60(c)(3)	F.A.C. 62-296.405(1)(e)(2)
40 C.F.R. 72.30(d)	40 C.F.R. 75.10(f)	40 C.F.R. 75.61(a)(1)	F.A.C. 62-296.405(1)(e)(3)
40 C.F.R. 72.32	40 C.F.R. 75.10(g)	40 C.F.R. 75.61(a)(5)	F.A.C.
40 C.F.R. 72.33(b)	40 C.F.R. 75.11(b)(1)	40 C.F.R. 75.61(b)	62-296.405(1)(f)1.a.(i)
40 C.F.R. 72.33(c)	40 C.F.R. 75.11(c)(3)	40 C.F.R. 75.62	F.A.C. 62-296.405(1)(f)1.b.
40 C.F.R. 72.33(d)	40 C.F.R. 75.11(d)	40 C.F.R. 75.63	F.A.C. 62-296.500(2)(a)1.
40 C.F.R. 72.40(a)	40 C.F.R. 75.12(a)	40 C.F.R. 75.64(a)	F.A.C. 62-296.500(2)(c)
40 C.F.R. 72.40(b)	40 C.F.R. 75.12(b)	40 C.F.R. 75.64(b)	F.A.C. 62-296.570(4)(a)3.
40 C.F.R. 72.40(c)	40 C.F.R. 75.13(a)	40 C.F.R. 75.64(c)	F.A.C. 62-296.570(4)(a)4.
40 C.F.R. 72.40(d)	40 C.F.R. 75.13(b)	40 C.F.R. 75.64(d)	F.A.C. 62-296.570(4)(b)3.
40 C.F.R. 72.51	40 C.F.R. 75.14(a)	40 C.F.R. 75.65	F.A.C. 62-296.570(4)(c)
40 C.F.R. 72.90	40 C.F.R. 75.20(a)(5)	40 C.F.R. 75.66(a)	F.A.C. 62-297.310(1)
40 C.F.R. 72.9(a)(1)(iii)	40 C.F.R. 75.20(b)	40 C.F.R. 75.66(b)	F.A.C. 62-297.310(2)(b)
40 C.F.R. 72.9(a)(1)(i)	40 C.F.R. 75.20(c)	40 C.F.R. 75.66(c)	F.A.C. 62-297.310(3)
40 C.F.R. 72.9(a)(2)	40 C.F.R. 75.20(d)	40 C.F.R. 75.66(d)	F.A.C. 62-297.310(4)(a)1.
40 C.F.R. 72.9(b)	40 C.F.R. 75.20(f)	40 C.F.R. 75.66(g)	F.A.C. 62-297.310(4)(a)2.c.
40 C.F.R. 72.9(c)(1)(iii)	40 C.F.R. 75.20(g)	40 C.F.R. 75.66(h)	F.A.C. 62-297.310(4)(b)
40 C.F.R. 72.9(c)(2)	40 C.F.R. 75.21(a)	40 C.F.R. 76.13	F.A.C. 62-297.310(4)(c)
40 C.F.R. 72.9(c)(4)	40 C.F.R. 75.21(b)	40 C.F.R. 77.3	F.A.C. 62-297.310(4)(d)
40 C.F.R. 72.9(c)(5)	40 C.F.R. 75.21(c)	40 C.F.R. 77.5(b)	F.A.C. 62-297.310(4)(e)
40 C.F.R. 72.9(d)	40 C.F.R. 75.21(d)	40 C.F.R. 77.6	F.A.C. 62-297.310(5)
40 C.F.R. 72.9(e)	40 C.F.R. 75.21(e)	F.A.C. 62-204.800(12)	F.A.C. 62-297.310(6)(a)
40 C.F.R. 72.9(f)	40 C.F.R. 75.21(f)	(state only)	F.A.C. 62-297.310(6)(c)
40 C.F.R. 72.9(g)(4)	40 C.F.R. 75.22	F.A.C. 62-204.800(13)	F.A.C. 62-297.310(6)(d)
40 C.F.R. 73.33	40 C.F.R. 75.24	(state only)	F.A.C. 62-297.310(6)(e)
40 C.F.R. 73.35	40 C.F.R. 75.30(a)(1)	F.A.C. 62-204.800(14)	F.A.C. 62-297.310(6)(f)
40 C.F.R. 75 Appendix A-1	40 C.F.R. 75.30(a)(2)	(state only)	F.A.C. 62-297.310(6)(g)
40 C.F.R. 75 Appendix A-2	40 C.F.R. 75.30(a)(3)	F.A.C. 62-210.650	F.A.C. 62-297.310(7)(a)1.
40 C.F.R. 75 Appendix A-3	40 C.F.R. 75.31	F.A.C. 62-210.700 (1)	F.A.C. 62-297.310(7)(a)2.
40 C.F.R. 75 Appendix A-4	40 C.F.R. 75.32	F.A.C. 62-210.700 (2)	F.A.C. 62-297.310(7)(a)3.
40 C.F.R. 75 Appendix A-5	40 C.F.R. 75.33	F.A.C. 62-210.700 (3)	F.A.C. 62-297.310(7)(a)4.
40 C.F.R. 75 Appendix A-6	40 C.F.R. 75.35	F.A.C. 62-210.700 (4)	F.A.C. 62-297.310(7)(a)5.
40 C.F.R. 75 Appendix B	40 C.F.R. 75.36	F.A.C. 62-210.700 (6)	F.A.C. 62-297.310(7)(a)9.
		F.A.C. 62-214.300	F.A.C. 62-297.310(7)(c)
		F.A.C. 62-214.330	F.A.C. 62-297.310(8)
		F.A.C. 62-214.350 (2)	Table 62-297.310-1

**E. EMISSION POINT (STACK/VENT) INFORMATION  
(Regulated Emissions Units Only)**

**Emission Point Description and Type**

Information for Facility-ID    Emission Unit # :  

1. Identification of Point on Plot Plan or Flow Diagram: Unit 3 boiler
2. Emission Point Type Code (1,2,3,4) : 1
3. Descriptions of Emissions Points Comprising this Emissions Unit (limit to 100 characters): Unit 3 boiler has one emission point which is the stack.
4. ID Numbers or Descriptions of Emission Units with this Emission Point in Common: Emission unit 1, Riviera Unit 3 boiler.
5. Discharge Type Code (D, F, H, P, R, V, W) : v
6. Stack Height: 298 ft
7. Exit Diameter: 16 ft
8. Exit Temperature: 263 °F
9. Actual Volumetric Flow Rate: 1063401.3 acfm
10. Percent Water Vapor: %
11. Maximum Dry Standard Flow Rate: dscfm
12. Nonstack Emission Point Height: ft
13. Emission Point UTM Coordinates: Zone: 17 East: 594.24 North: 2960.801
14. Emission Point Comment (limit to 200 characters): Information in items 8 & 9 was collected during the February 1994 particulate test for this unit. Temp was taken @ mid-stack @ ~ 90% of max heat input. Flow rates & temps at other times may vary.

**F. SEGMENT (PROCESS/FUEL) INFORMATION  
(Regulated and Unregulated Emissions Units)**

**Segment Description and Rate:**

Information for Facility\_ID : / Emission Unit #: / Segment #: /

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Unit 3 boiler firing number 6 oil
2. Source Classification Code (SCC): 1-01-004-01
3. SCC Units: thousand gallons burned
4. Maximum Hourly Rate: 20.07
5. Maximum Annual Rate: 175776.3
6. Estimated Annual Activity Factor:
7. Maximum Percent Sulfur: 2.5
8. Maximum Percent Ash: 0.1
9. Million Btu per SCC Unit: 152
10. Segment Comment (limit to 200 characters): The unit is currently permitted to burn a variable combination of No. 6 residual oil, natural gas, No. 2 fuel oil, propane gas, or on-specification used oil from FPL operations.

**F. SEGMENT (PROCESS/FUEL) INFORMATION  
(Regulated and Unregulated Emissions Units)**

**Segment Description and Rate:**

Information for Facility\_ID :1 Emission Unit #: 1 Segment #: 2

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Unit 3 boiler firing natural gas
2. Source Classification Code (SCC): 1-01-006-01
3. SCC Units: Million cubic feet burned
4. Maximum Hourly Rate: 3.1
5. Maximum Annual Rate: 27197.7
6. Estimated Annual Activity Factor:
7. Maximum Percent Sulfur: 0.0031
8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 1050
10. Segment Comment (limit to 200 characters): The unit is currently permitted to burn a variable combination of No. 6 residual oil, natural gas, No. 2 fuel oil, propane gas or on-specification used oil from FPL operations.

**F. SEGMENT (PROCESS/FUEL) INFORMATION  
(Regulated and Unregulated Emissions Units)**

**Segment Description and Rate:**

Information for Facility\_ID :/ Emission Unit #: / Segment #: 3

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Unit 3 boiler firing on-specification used oil
2. Source Classification Code (SCC): 1-01-013-02
3. SCC Units: thousand gallons burned
4. Maximum Hourly Rate: 22.43
5. Maximum Annual Rate: 100
6. Estimated Annual Activity Factor:
7. Maximum Percent Sulfur: 2.5
8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 136
10. Segment Comment (limit to 200 characters): The maximum annual rate of on-specification used oil burned in the Riviera boiler unit 3 is based on historical data.

**F. SEGMENT (PROCESS/FUEL) INFORMATION  
(Regulated and Unregulated Emissions Units)**

**Segment Description and Rate:**

Information for Facility\_ID :1 Emission Unit #: 1 Segment #: 4

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Unit 3 Boiler burning Number 2 fuel oil
2. Source Classification Code (SCC): 1-01-005-01
3. SCC Units: thousand gallons burned
4. Maximum Hourly Rate: 22.43
5. Maximum Annual Rate: 196455.9
6. Estimated Annual Activity Factor:
7. Maximum Percent Sulfur: 0.5
8. Maximum Percent Ash: 0.01
9. Million Btu per SCC Unit: 136
10. Segment Comment (limit to 200 characters): The unit is currently permitted to burn a variable combination of No. 6 residual oil, natural gas, No. 2 fuel oil, propane gas or on-specification used oil from FPL operations.



**F. SEGMENT (PROCESS/FUEL) INFORMATION  
(Regulated and Unregulated Emissions Units)**

**Segment Description and Rate:**

Information for Facility\_ID :1 Emission Unit #: 1 Segment #: 5

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Unit 3 boiler firing propane
2. Source Classification Code (SCC): 1-01-006-01
3. SCC Units: Million cubic feet burned
4. Maximum Hourly Rate: 3.26
5. Maximum Annual Rate: 28557.6
6. Estimated Annual Activity Factor:
7. Maximum Percent Sulfur:
8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 1000
10. Segment Comment (limit to 200 characters): The unit is currently permitted to burn a variable combination of No. 6 residual oil, natural gas, No. 2 fuel oil, propane gas, or on-specification used oil from FPL operations.

**F. SEGMENT (PROCESS/FUEL) INFORMATION  
(Regulated and Unregulated Emissions Units)**

**Segment Description and Rate:**

Information for Facility\_ID :1 Emission Unit #: 1 Segment #: 6

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Unit 3 Boiler co-firing all possible combinations of natural gas, No. 6 fuel oil, No. 2 fuel oil, propane, on specification used oil and landfill-derived methane gas.
2. Source Classification Code (SCC): 1-01-006-01
3. SCC Units: thousand gallons
4. Maximum Hourly Rate: 20.07
5. Maximum Annual Rate: 175776.3
6. Estimated Annual Activity Factor:
7. Maximum Percent Sulfur: 2.5
8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 152
10. Segment Comment (limit to 200 characters): This segment information page represents cofiring. The data provided is based on the #6 oil equivalent values for each field.

**F. SEGMENT (PROCESS/FUEL) INFORMATION  
(Regulated and Unregulated Emissions Units)**

**Segment Description and Rate:**

Information for Facility\_ID :/ Emission Unit #: / Segment #: 7

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Unit 3 Boiler chemical cleaning waste evaporation
2. Source Classification Code (SCC): 1-01-013-01
3. SCC Units: thousand gallons burned
4. Maximum Hourly Rate: 3
5. Maximum Annual Rate: 500
6. Estimated Annual Activity Factor:
7. Maximum Percent Sulfur:
8. Maximum Percent Ash:
9. Million Btu per SCC Unit:
10. Segment Comment (limit to 200 characters): Items 6,7,8 & 9 do not apply. This activity to be undertaken on a periodic basis in accordance with DARM guidance, and EPA waste rules (40 CFR 279.72).

**F. SEGMENT (PROCESS/FUEL) INFORMATION  
(Regulated and Unregulated Emissions Units)**

**Segment Description and Rate:**

Information for Facility\_ID :/ Emission Unit #: / Segment #: 8

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Unit 3 boiler firing methane gas
2. Source Classification Code (SCC): 1-01-006-01
3. SCC Units: Million cubic feet burned
4. Maximum Hourly Rate: 3.1
5. Maximum Annual Rate: 27197.7
6. Estimated Annual Activity Factor:
7. Maximum Percent Sulfur: 0.0031
8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 1050
10. Segment Comment (limit to 200 characters): The plant is exploring the possibility of firing landfill-derived methane gas as a supplemental fuel. Information given is based on natural gas characteristics.

**G. EMISSIONS UNIT POLLUTANTS  
(Regulated Emissions Units Only)**

Information for Facility\_ID: / Emission Unit #: /

1. Pollutant Emitted	2. Primary Control Device Code	3. Secondary Control Device Code	4. Pollutant Regulatory Code
SO2	NA	NA	EL
NOX	024	NA	EL
CO	NA	NA	NS
VOC	NA	NA	NS
PM	077	NA	EL
PM10	077	NA	NS
H133	NA	NA	NS
H106	NA	NA	NS
H107	NA	NA	NS
SAM	NA	NA	NS
HAP	NA	NA	NS

**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION  
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**

Information for Facility\_ID: / Emission Unit #: / Pollutant #: /

**Pollutant Detail Information**

1. Pollutant Emitted:	Sulfur Dioxide
2. Total Percent Efficiency of Control:	%
3. Potential Emissions:	8387.5 lbs/hr                      36737.25 tons/yr
4. Synthetically Limited? (Yes/No):	No
5. Range of Estimated Fugitive/Other Emissions: (1, 2, 3):	to    tons/yr
6. Emission Factor:	2.75                      Units    lb/mmBtu
Reference:	DEP Rule 62-296.405(1)(c)1.j.
7. Emissions Method Code: (0, 1, 2, 3, 4, 5):	0
	<input type="checkbox"/> 0 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input type="checkbox"/> 5
8. Calculation of Emissions (limit to 600 characters):	2.75 lb/mmBtu * 3050mmBtu/hr = 8387.5 lb/hr  (8387.5 lb/hr * 8760 hr/yr) / 2000 lb/ton = 36737.25 tons/yr
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters):	SO2 emissions are limited by Rule 62-296.405(1)(c)1.j. Equivalent allowable emissions are for liquid fuel.

**Information for Facility\_ID: / Emission Unit #: / Pollutant #: /  
Basis For Allowable Emission #: 1**

**Allowable Emissions** (Pollutant identified on front page)

1. Basis for Allowable Emissions Code: Required or assumed by permittee for other reasons.
2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 2.75 Units : lb/mmBtu
4. Equivalent Allowable Emissions: 8387.5 lbs/hr 36737.25 tons/yr
5. Method of Compliance: Fuel sampling & analysis
6. Pollutant Allowable Emissions Comment ( <b>Desc. of Related Operating Method/Mode</b> ) (limit to 200 characters): 156 2.75 lb/mmBtu is the current regulatory limit on SO2 emissions [Rule 62-295.405(1)(c)1.j.]. Equivalent allowable emissions are given for liquid fuel firing.

**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION  
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**

Information for Facility\_ID: / Emission Unit #: / Pollutant #: 2

**Pollutant Detail Information**

1. Pollutant Emitted:	Nitrogen Oxides		
2. Total Percent Efficiency of Control:	%		
3. Potential Emissions:	1891 lbs/hr	8282.58 tons/yr	
4. Synthetically Limited? (Yes/No):	No		
5. Range of Estimated Fugitive/Other Emissions: (1, 2, 3) :	to tons/yr		
6. Emission Factor:	0.62	Units	lb/mmBtu
Reference:	DEP Rule 62-296.570(4)(b)3.		
7. Emissions Method Code: (0, 1, 2, 3, 4, 5):	0		
	<input type="checkbox"/> 0	<input type="checkbox"/> 1	<input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input type="checkbox"/> 5
8. Calculation of Emissions (limit to 600 characters):	0.62 lb/mmBtu * 3050 mmBtu/hr = 1891.0 lb/hr		
	(1891 lb/hr * 8760 hr/yr) / 2000 lb/ton = 8282.58 tons/yr		
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters):	Riviera plant is currently conducting an 18-month program to attempt to achieve the following target limits [30-day rolling average]:		
		Natural Gas	Fuel Oil
lb/mmBtu		0.43	0.55
lb/hr		1,402	1,678



**Information for Facility\_ID: / Emission Unit #: / Pollutant #: 2**  
**Basis For Allowable Emission #: 1**

**Allowable Emissions** (Pollutant identified on front page)

1. Basis for Allowable Emissions Code: Required or assumed by permittee for other reasons.
2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 0.62 Units : lb/mmBtu
4. Equivalent Allowable Emissions: 1891 lbs/hr 8282.58 tons/yr
5. Method of Compliance: Continuous Emissions Monitor
6. Pollutant Allowable Emissions Comment ( <b>Desc. of Related Operating Method/Mode</b> ) (limit to 200 characters): <b>194</b> 0.62 lb/mmBtu is the current reg. limit [Rule 62-296.570(4)(b)3] on NOx emissions [30-day rolling avg - Rule 62-296.570(4)(a)4.]. Equivalent allowable emissions are given for liquid fuel firing.

**Information for Facility\_ID: 1 Emission Unit #: 1 Pollutant #: 2  
Basis For Allowable Emission #: 2**

**Allowable Emissions** (Pollutant identified on front page)

1. Basis for Allowable Emissions Code: Required or assumed by permittee for other reasons.
2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 0.5 Units : lb/mmBtu
4. Equivalent Allowable Emissions: 1630 lbs/hr 7139.4 tons/yr
5. Method of Compliance: Continuous Emissions Monitor
6. Pollutant Allowable Emissions Comment ( <b>Desc. of Related Operating Method/Mode</b> ) (limit to 200 characters): <b>194</b> 0.50 lb/mmBtu is the current reg. limit [Rule 62-296.570(4)(b)3] on NOx emissions [30-day rolling avg - Rule 62-296.570(4)(a)4.]. Equivalent allowable emissions are given for natural gas firing.

**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION  
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**

Information for Facility\_ID: / Emission Unit #: / Pollutant #: 4

**Pollutant Detail Information**

1. Pollutant Emitted:	Particulate Matter - Total	
2. Total Percent Efficiency of Control:		%
3. Potential Emissions:	381.25 lbs/hr	1669.88 tons/yr
4. Synthetically Limited? (Yes/No):	No	
5. Range of Estimated Fugitive/Other Emissions: (1, 2, 3):	to tons/yr	
6. Emission Factor:	0.125	Units lb/mmBtu
Reference:	DEP Rule 62-296.405(1)(b) and Rule 62-210.700(3)	
7. Emissions Method Code: (0,1, 2, 3, 4, 5):	0	
	[ ] 1	[ ] 2 [ ] 3 [ ] 4 [ ] 5
8. Calculation of Emissions (limit to 600 characters):	0.125 lb/mmBtu * 3050 mmBtu/hr =381.25 lb/hr  (381.25 lb/hr * 8760 hr/yr) / 2000 lb/ton = 1669.88 tons/yr	
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters):	A particulate matter emissions limit of 3 hours /24 hours at 0.3 lb/mmBtu and 21 hours/24 hours at 0.1 lb/mmBtu is equivalent to an average of 0.125 lb/mmBtu	

**Allowable Emissions** (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code:
2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units:        Units :

**Information for Facility\_ID: / Emission Unit #: / Pollutant #: 4**  
**Basis For Allowable Emission #: 1 1**

**Allowable Emissions** (Pollutant identified on front page)

1. Basis for Allowable Emissions Code: Required or assumed by permittee for other reasons.
2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 0.1 Units : lb/mmBtu
4. Equivalent Allowable Emissions: 305 lbs/hr 1168.9 tons/yr
5. Method of Compliance: DEP Rule 62-296.405(1)(e)2.
6. Pollutant Allowable Emissions Comment ( <b>Desc. of Related Operating Method/Mode</b> ) (limit to 200 characters): <b>167</b> Data is for steady-state conditions firing liquid fuel. The equivalent allowable emissions given above are based on steady-state operation 21 hours per 24-hour period.

**Information for Facility\_ID: 1 Emission Unit #: 1 Pollutant #: 4  
Basis For Allowable Emission #: 2 2**

**Allowable Emissions** (Pollutant identified on front page)

1. Basis for Allowable Emissions Code: Required or assumed by permittee for other reasons.
2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 0.3 Units : lb/mmBtu
4. Equivalent Allowable Emissions: 915 lbs/hr 501 tons/yr
5. Method of Compliance: DEP Rule 62-296.405(1)(e)2.
6. Pollutant Allowable Emissions Comment ( <b>Desc. of Related Operating Method/Mode</b> ) (limit to 200 characters): 178 Data is for soot-blowing and load-changing conditions firing fuel oil. Equivalent allowable emissions based on 3 hours of sootblowing per 24-hour period [DEP Rule 62-210.700(3)].

**I. VISIBLE EMISSIONS INFORMATION  
(Regulated Emissions Units Only)**

Information for Facility-ID : 1 Emission Unit #: 1  
Visible Emissions Limitation #: 1

1. Visible Emissions Subtype: VE40
2. Basis for Allowable Opacity Code(R/O): RULE <input type="checkbox"/> Rule <input type="checkbox"/> Other
3. Allowable Opacity: Normal Conditions: 40                                  % Exceptional Conditions:      % Maximum Period of Excess Opacity Allowed:      min/hr
4. Method of Compliance Code: EPA Method 9
5. Visible Emissions Comment (limit to 200 characters): DEP Rule 62-296.405(1)(a) and (1)(e)1., F.A.C. Visible Emissions limited to 40% opacity, except for allowed excess emissions. Compliance testing is performed annually using EPA Method 9.

**I. VISIBLE EMISSIONS INFORMATION  
(Regulated Emissions Units Only)**

Information for Facility-ID : 1 Emission Unit #: 1  
Visible Emissions Limitation #: 2

1. Visible Emissions Subtype: VE60
2. Basis for Allowable Opacity Code(R/O):   RULE       [ ] Rule       [ ] Other
3. Allowable Opacity: Normal Conditions: 60                           % Exceptional Conditions: 100    % Maximum Period of Excess Opacity Allowed: 24   min/hr
4. Method of Compliance Code:   EPA Method 9
5. Visible Emissions Comment (limit to 200 characters): Rule 62-210.700(3), F.A.C. limits soot blowing & load changing to 60% opacity for up to 3 hrs/24 hrs, with < 4, 6-minute pds of up to 100% opac. if unit has an operational CEM.

### I. VISIBLE EMISSIONS INFORMATION (Regulated Emissions Units Only)

Information for Facility-ID : 1 Emission Unit #: 1

Visible Emissions Limitation #: 3

1. Visible Emissions Subtype: VE100	
2. Basis for Allowable Opacity Code(R/O):	RULE <input type="checkbox"/> Rule <input type="checkbox"/> Other
3. Allowable Opacity:	
Normal Conditions:	% Exceptional Conditions: 100 %
Maximum Period of Excess Opacity Allowed:	60 min/hr
4. Method of Compliance Code:	EPA Method 9
5. Visible Emissions Comment (limit to 200 characters): Rules 62-210.700(1) and (2), F.A.C. allow up to 100% opacity for an unlimited time during startup and shutdown, and up to 2 hrs/24 hrs for malfunctions.	



**J. CONTINUOUS MONITOR INFORMATION  
(Regulated Emissions Units Only)**

Information for Facility-ID : / Emission Unit #: /  
Continuous Monitor #: /

**Continuous Monitoring System**

1. Parameter Code:			
2. Pollutant(s):		Sulfur Dioxide	
3. CMS Requirement Code(R/O):		RULE	Rule / Other
4. Monitor Information:			
Manufacturer:		TECO	
Model Number:		43B	Serial Number: 43B-45443-273
5. Installation Date (DD-MON-YYYY): 01/31/94			
6. Performance Specification Test Date (DD-MON-YYYY): 07/12/94			
7. Continuous Monitor Comment (limit to 200 characters): Required by 40 CFR 75.10(a)(1)			

**J. CONTINUOUS MONITOR INFORMATION  
(Regulated Emissions Units Only)**

Information for Facility-ID : 1 Emission Unit #: 1  
Continuous Monitor #: 2

**Continuous Monitoring System**

1. Parameter Code:			
2. Pollutant(s):		Nitrogen Oxides	
3. CMS Requirement Code(R/O):		RULE	Rule / Other
4. Monitor Information:			
Manufacturer:		TECO	
Model Number:		42 Serial Number: 42-44841-272	
5. Installation Date (DD-MON-YYYY): 01/31/94			
6. Performance Specification Test Date (DD-MON-YYYY): 07/12/94			
7. Continuous Monitor Comment (limit to 200 characters): Required by 40 CFR 75.10(a)(2)			

**J. CONTINUOUS MONITOR INFORMATION  
(Regulated Emissions Units Only)**

Information for Facility-ID : 1 Emission Unit #: 1  
Continuous Monitor #: 3

**Continuous Monitoring System**

1. Parameter Code:			
2. Pollutant(s):	Carbon dioxide		
3. CMS Requirement Code(R/O):	RULE	Rule	/ Other
4. Monitor Information:			
Manufacturer: Milton Roy		Serial Number: N3H8174T	
Model Number: 3300			
5. Installation Date (DD-MON-YYYY): 01/31/94			
6. Performance Specification Test Date (DD-MON-YYYY): 07/12/94			
7. Continuous Monitor Comment (limit to 200 characters): Required by 40 CFR 75.10(a)(3)(i)			

**J. CONTINUOUS MONITOR INFORMATION  
(Regulated Emissions Units Only)**

Information for Facility-ID : 1 Emission Unit #: 1  
Continuous Monitor #: 4

**Continuous Monitoring System**

1. Parameter Code:			
2. Pollutant(s):	Volumetric flow rate		
3. CMS Requirement Code(R/O):	RULE	Rule	/ Other
4. Monitor Information:			
Manufacturer: Air Monitor		Serial Number: 5590D	
Model Number: MASSTRON			
5. Installation Date (DD-MON-YYYY): 01/31/94			
6. Performance Specification Test Date (DD-MON-YYYY): 07/12/94			
7. Continuous Monitor Comment (limit to 200 characters): Required by 40 CFR 75.10(a)(1)			

**J. CONTINUOUS MONITOR INFORMATION  
(Regulated Emissions Units Only)**

Information for Facility-ID : 1 Emission Unit #: 1  
Continuous Monitor #: 5

**Continuous Monitoring System**

1. Parameter Code:		
2. Pollutant(s):	Visible emissions (opacity)	
3. CMS Requirement Code(R/O):	RULE	Rule / Other
4. Monitor Information:		
Manufacturer:	Lear Siegler	
Model Number:	RM41	Serial Number: 1660
5. Installation Date (DD-MON-YYYY):	01/31/94	
6. Performance Specification Test Date (DD-MON-YYYY):	12/08/94	
7. Continuous Monitor Comment (limit to 200 characters): Required by 40 CFR 70.10(a)(4)		

**K. PREVENTION OF SIGNIFICANT DETERIORATION (PSD) INCREMENT  
TRACKING INFORMATION  
(Regulated and Unregulated Emissions Units)**

Information for Facility-ID : / Emission Unit # : /

**PSD Increment Consumption Determination**

1. Increment Consuming for Particulate Matter or Sulfur Dioxide?

If the emissions unit addressed in this section emits particulate matter or sulfur dioxide, answer the following series of questions to make a preliminary determination as to whether or not the emissions unit consumes PSD increment for particulate matter or sulfur dioxide. Check the first statement, if any, that applies and skip remaining statements.

Select (1-5) : 5

- [ 1 ] The emissions unit is undergoing PSD review as part of this application, or has undergone PSD review previously, for particulate matter or sulfur dioxide. Final determination is that emissions unit consumes increment.
- [ 2 ] The facility addressed in this application is classified as an EPA major source pursuant to paragraph (c) of the definition of "major source of air pollution" in Chapter 17-213, F.A.C., and the emissions unit addressed in this section commenced (or will commence) construction after January 6, 1975. Preliminary determination is that baseline emissions are zero, and emissions unit consumes increment.
- [ 3 ] The facility addressed in this application is classified as an EPA major source, and the emissions unit began initial operation after January 6, 1975, but before December 27, 1977. Preliminary determination is that baseline emissions are zero, and emissions unit consumes increment.
- [ 4 ] For any facility, the emissions unit began (or will begin) initial operation after December 27, 1977. Preliminary determination is that baseline emissions are zero, and emissions unit consumes increment.
- [ 5 ] None of the above apply. If so, the baseline emissions of the emissions unit are nonzero. In such case, additional analysis, beyond the scope of this application, is needed to determine whether changes in emissions have occurred (or will occur) after the baseline date that may consume or expand increment.

2. Increment Consuming for Nitrogen Dioxide?

If the emissions unit addressed in this section emits nitrogen oxides, answer the following series of questions to make a preliminary determination as to whether or not the emissions unit consumes PSD increment for nitrogen dioxide. Check first statement, if any, that applies and skip remaining statements.

Select (1-5) : 5

- [ 1 ] The emissions unit addressed in this section is undergoing PSD review as part of this application, or has undergone PSD review previously, for nitrogen dioxide. Final determination is that emissions unit consumes increment.
  
- [ 2 ] The facility addressed in this application is classified as an EPA major source pursuant to paragraph (c) of the definition of "major source of air pollution" in Chapter 17-213, F.A.C., and the emissions unit addressed in this section commenced (or will commence) construction after February 8, 1988. Preliminary determination is that baseline emissions are zero, and emissions unit consumes increment.
  
- [ 3 ] The facility addressed in this application is classified as an EPA major source, and the emissions unit began initial operation after February 8, 1988, but before March 28, 1988. Preliminary determination is that baseline emissions are zero, and emissions unit consumes increment.
  
- [ 4 ] For any facility, the emissions unit began (or will begin) initial operation after March 28, 1988. Preliminary determination is that baseline emissions are zero, and emissions unit consumes increment.
  
- [ 5 ] None of the above apply. If so, the baseline emissions of the emissions unit are nonzero. In such case, additional analysis, beyond the scope of this application, is needed to determine whether changes in emissions have occurred (or will occur) after the baseline date that may consume or expand increment.

3. Increment Consuming/Expanding Code: (C, E, U- unkown):

PM	U
SO2	U
NO2	U

4. Baseline Emissions:

PM	lbs/hr	tons/yr
SO2	lbs/hr	tons/yr
NO2	tons/yr	

5. PSD Comment (limit to 200 characters):  
Riviera Unit 3 was constructed in 1962 which pre-dates the major source PSD baseline date of 1/5/75.



**L. EMISSIONS UNIT SUPPLEMENTAL INFORMATION  
(Regulated Emissions Units Only)**

Information for Facility-ID : 1 Emission Unit # : 1


**Supplemental Requirements for All Applications**

1. Process Flow Diagram : PRVU1_1.bmp Attached Document ID / Not Applicable / Waiver Requested
2. Fuel Analysis or Specification: PRVU1_2.txt Attached Document ID / Not Applicable / Waiver Requested
3. Detailed Description of Control Equipment : PRVU1_3.txt Attached Document ID / Not Applicable / Waiver Requested
4. Description of Stack Sampling Facilities : PRVU1_4.bmp Attached Document ID / Not Applicable / Waiver Requested
5. Compliance Test Report : NA Attached Document ID / Previously submitted, Date / Not Applicable
6. Procedures for Startup and Shutdown : PRVU1_6.txt Attached Document ID / Not Applicable
7. Operation and Maintenance Plan : NA Attached Document ID / Not Applicable
8. Supplemental Information for Construction Permit Application : NA Attached Document ID / Not Applicable
9. Other Information Required by Rule or Statute : NA Attached Document ID / Not Applicable

**Additional Supplemental Requirements for Category I Applications Only**

10. Alternative Methods of Operation : PRVU1_10.txt Attached Document ID / Not Applicable
11. Alternative Modes of Operation (Emissions Trading) : NA Attached Document ID / Not Applicable
12. Identification of Additional Applicable Requirements : PRVU1_12.txt Attached Document ID / Not Applicable
13. Enhanced Monitoring Plan : NA Attached Document ID / Not Applicable
14. Acid Rain Permit Application  Acid Rain Application - Phase II (Form No. 17-210.900(1)(a)) Attached Document ID: Not Applicable  Repowering Extension Plan (Form No. 17-210.900(1)(b)) Attached Document ID: NA  New Unit Exemption (Form No. 17-210.900(1)(c)) Attached Document ID: NA  Retired Unit Exemption (Form No. 17-210.900(1)(c)) Attached Document ID: NA  Not Applicable

WALKDOWN INFORMATION			TECHNICAL ACCEPTANCE		
ORG	BY	DATE	ORG	BY	DATE
AS-BUILT INFORMATION			ENGINEERING ORGANIZATION		
ORG	BY	DATE			



BAR CODE

0	7/24/95	ISSUED FOR TITLE V PERMIT	PWB	PWB	CSP	CSP	ETS
REV	DATE	REVISION DESCRIPTION	BY	CH	COR	APR	ORG

	SYSTEM	YY	DISCIPLINE	M	PLANT/UNIT	RIVIERA PLANT		
	SCALE	N/A	CAD FILE NAME	RV002856	TITLE	EMISSION UNIT PROCESS FLOW DIAGRAM STEAM GENERATOR/BOILER ATTACHMENT NO. EU1		
	DRAWING SIZE	A (8.5X11)	FPL ARCHIVE NAME	RV002856	DRAWING NUMBER			
					PRV3-M0106-YY		SHEET	REV
							1 OF 1	0

FLORIDA POWER & LIGHT CO.  
 STACK SAMPLING FACILITIES  
 RIVIERA

PRVU1\_1.BMP



FOSSIL FUEL STEAM GENERATORS  
 UNITS 3 & 4

STACK SPECIFICATIONS

SAMPLING DIAMETER: 216 1/4 in.  
 SAMPLING AREA: 255.1 sq. ft.  
 SAMPLING PORT DEPTH: 50 1/2 in.  
 No. OF PORTS: 4  
 No. OF POINTS PER TRAVERSE: 8  
 TOTAL No. OF POINTS : 24  
 SAMPLING TIME PER POINT: 2.5 min.  
 TOTAL SAMPLING TIME: 60.0 min.  
 NOTE: DRAWING IS NOT TO SCALE

STACK DIAGRAM

PARTICULATE SAMPLING  
 PROBE DIAGRAM



Access to the sampling ports is provided by a ladder. Channel iron with a trolley system is above each port for probe support. AC power is available on the platform and at the base of the stack.

## Attachment PRVU1\_2.txt

Fuel Analysis  
Natural Gas Analysis (typical)<sup>2</sup>

<u>Parameter</u>	<u>Typical value</u>	<u>Max value</u>
Specific gravity(@ 60° F)	0.887	none
Heat content (Btu/cu ft)	950 - 1124	none
% sulfur (grains/CCF)	0.43 <sup>1</sup>	1 grain / ccf
% nitrogen (by volume)	0.8	none
% ash	negligible	none

\*Note: The values listed are "typical" values based upon information supplied to FPL by Florida Gas Transmission (FGT). However, analytical results from grab samples of fuel taken at any given point in time may vary from those listed.

(1) Data from laboratory analysis

(2) The values are "typical" based upon the following:

- Information gathered by FPL through laboratory analysis, and
- FPL's fuel purchasing specifications. It should be noted that the analytical results obtained from grab samples taken at any given time may vary from those listed.

**Attachment PRVU1\_2.txt****Fuel Analysis  
No.6 Oil Analysis (typical)<sup>4</sup>**

<u>Parameter</u>	<u>Typical value</u>	<u>Specifications</u>
API gravity (@ 60° F)	6 - 12	none
Heat content(MBtu/bbl)	6,310 - 6420	6,340 <sup>1</sup>
% Sulfur	2.0 - 2.4	2.5 max <sup>3</sup>
% Nitrogen	0.2 - 0.5 <sup>2</sup>	none
% Ash	0.06 - 0.09 <sup>2</sup>	0.10 max <sup>1</sup>

**Footnotes:**

- (1) Data taken from FPL fuel specifications.
- (2) Data taken from laboratory analysis.
- (3) Maximum permitted from current air operation permit.
- (4) The values are "typical" based upon the following:
  - Information gathered by FPL through laboratory analysis, and
  - FPL's fuel purchasing specifications. It should be noted that the analytical results obtained from grab samples taken at any given time may vary from those listed.

## Attachment PRVU1\_2.txt

Fuel Analysis  
No. 2 Distillate oil (typical)<sup>3</sup>

<u>Parameter</u>	<u>Typical value</u>	<u>Specifications</u>
API gravity (@ 60 F)	35.0 <sup>2</sup>	30 - 40 <sup>1</sup>
Heat content (MBtu/bbl)	5,700 - 5,800 <sup>2</sup>	none
% sulfur	0.3 - 0.5 <sup>1</sup>	0.5 maximum <sup>1</sup>
% nitrogen	no specification	none
% ash	<0.01 <sup>2</sup>	0.01 <sup>1</sup>

Footnotes:

(1) Data taken from FPL fuel specifications.

(2) Data taken from laboratory analysis.

(3) The values are "typical" based upon the following:

- Information gathered by FPL through laboratory analysis, and
- FPL's fuel purchasing specifications. It should be noted that the analytical results obtained from grab samples taken at any given time may vary from those listed.

**Attachment PRVU1\_2.txt****Fuel Analysis  
Propane (typical)<sup>1</sup>**

Emission unit #1 may occasionally light off (start up) on propane fuel, then switch to another fuel, such as No.6 residual oil. The propane fuel is supplied by a commercial vendor and is stored in small tanks located at the bottom of the boiler area. The chemical formula for propane is C<sub>3</sub>H<sub>8</sub>.

<u>Parameter</u>	<u>Typical value</u>	<u>Specifications</u>
Specific gravity (@ 60 F)	0.51 <sup>1</sup>	none
Heat content (MBtu/bbl)	600 - 1,000	none
% sulfur	<0.01	none
% nitrogen	no specification	none
% ash	no specification	none

**Footnotes:**

- (1) The values are "typical" based upon the following:
- Information gathered by FPL through laboratory analysis, and
  - FPL's fuel purchasing specifications. It should be noted that the analytical results obtained from grab samples taken at any given time may vary from those listed.



**Attachment PRVU1\_2.txt****Fuel Analysis  
On Specification Used Oil**

The boiler may occasionally burn used oil during normal operation. All used oil fired in the unit meets the specifications mandated by 40 CFR 279.11. Used oil fired by this boiler is typically derived from plant maintenance activities, and may include used lube oils, transformer oils, etc. that meet the analytical specifications. Criteria for used oil follows:

<u>Parameter</u>	<u>Typical value</u>	<u>Specifications</u>
API gravity (@ 60 F)	30.0 <sup>1</sup>	none
Heat content (MBtu/bbl)	6,000 <sup>1</sup>	none
% sulfur	0.3 <sup>1</sup>	none
% nitrogen	negligible	none
% ash	0.01 <sup>1</sup>	0.01

**Footnotes:**

(1) The values are "typical" based upon the following:

- Information gathered by FPL through laboratory analysis, and
- FPL's fuel purchasing specifications. It should be noted that the analytical results obtained from grab samples taken at any given time may vary from those listed.

**Attachment PRVU1\_3.txt**  
**Detailed Description of Control Equipment**

**A. Cyclone Separator** - This steam generator (boiler) is supplied with two 543-C10 Research Cottrell series 14" tubular mechanical dust collectors with side inlet and universal outlet. Each dust collector consists of 543 tubes and three dust collection hoppers. The control efficiency specified by the boiler design documents is as follows:

"The dust separator shall have a collection efficiency of not less than 88% at a steam output of 2,000,000 lb / hour when burning oil fuel under the conditions specified, with a draft loss not to exceed 2.5 inches of water".

However, it has been FPL's experience that the cyclone separators efficiency is largely dependent upon the particle size of the particulate matter. The following data represents representative collection efficiency for a similar cyclone separator at 2.55 inches of water @ peak load:

Particle Range (micron)	Mean Diameter (micron)	Estimated Efficiency (percent)
0 - 5	2.5	30.3
5 - 10	7.5	66.2
10 - 20	15	88.6
20 - 45	32.5	99.1
45 +	45	99.5

**B. Low Nox Burners** - Because of ozone nonattainment problems in southern Florida, the Riviera plant installed Low NOx burners on the 2 boilers. The plant is performing an 18 month program of testing to demonstrate that the NOx emission reductions achieved by the new burners are the lowest limits achievable by that technology for the Riviera units. The reductions achieved from the baseline are approximately 31% on natural gas, and 33% on residual oil (lb / mmBtu).

## Attachment PRVU1\_6.txt

### Startup & Shutdown Procedures - Minimizing Excess Emissions

Startup of the fossil-fuel boiler begins when fuel (either natural gas or oil) is introduced into one or more burners within the boiler and lighted (commencement of combustion). Startup is complete and steady-state operation begins when the combustion process has stabilized and the megawatt load on the unit is stable.

Shutdown of the fossil-fuel boilers begins when unit megawatt load is decreased to below 10% of maximum and continues until the final burner gun is removed from service and the final Induced-draft or Forced-draft fan is removed from service.

Excess emissions may be detected during all modes of boiler operation by any one of several continuous emissions monitors. Continuous emission monitors are currently in place for NO<sub>x</sub>, SO<sub>2</sub> and opacity. An audible and visual alarm are activated whenever permitted values for any of the above parameters are approached.

Countermeasures which may be taken in the event of excess emissions include, but are not limited to:

- proper excess air adjustments
- recognizing and removal of faulty burners
- fuel oil temperature adjustments
- proper and timely operation of boiler cleaning devices
- removal of the unit from system-dispatch mode
- reduction of unit megawatt load
- stopping and restarting of boiler cleaning devices
- lowering load rate
- pressure rate changes

Best Operational Practices to prevent excess emissions, and knowledge of the appropriate countermeasures to take if an excess emissions condition exists, are taught during routine operator training.

**Attachment PRVU1\_10.txt**  
**Alternative Methods of Operation**

Operation at Various Capacities and Heat Input Rates

The Riviera Unit 3 and Unit 4 boilers may each be operated up to 8760 hours per year at heat input rates from zero to 3050 mmBtu per hour on No.#6 oil, and from zero to 3260 mmBtu per hour on natural gas. When a blend of fuel oil and natural gas are burned, the heat input is prorated based upon the percent heat input of each fuel.

Different Fuel Types

The units may be fired with a variable combination of No. 6 residual fuel oil, natural gas, or No. 2 fuel oil. The units utilize propane fuel for ignition of the above-listed main fuels. The unit may also burn on-specification used oil meeting EPA specifications under 40 CFR 279.11, or expired fuel oil samples from FPL's Central Laboratory facility.

Current emissions limitations are as follows:

<u>Pollutant</u>	<u>Emission Limit</u>
Particulate matter	0.1 lb/mmBtu
Sulfur dioxide	2.75 lb/mmBtu
Nitrogen oxide	0.62 lb/mmBtu on oil (1891 lb/hr, 30-day rolling avg) 0.50 lb/mmBtu on gas (1630 lb/hr, 30-day rolling avg))

Oil and Gas Co-firing

These emission units may co-fire natural gas with residual oil. When combusting both fuels simultaneously, the percentage of natural gas will be adjusted to ensure that the applicable SO<sub>2</sub> emission limit and visible emission limits are complied with.

Soot blowing

The units may each blow soot for up to 24 hours per day, so long as excess emissions are limited to 60% opacity for 3 hours in 24 hours with up to four 6-minute periods of up to 100% opacity.

Utilization of Additives

When residual oil is fired, additives such as Magnesium hydroxide Mg(OH)<sub>2</sub> are added to the boilers on a continuous basis. This material is typically added to the fuel oil just prior to its being fed into the furnace, but it may also be injected into the boiler via the I.K. soot blower lances and through manual hand lances on a batch basis, rather than continuously. The dosage rate is based on the quantity of fuel burned and the amount of ash in the fuel. FPL reserves the right to use other additives if they are suitable.

Landfill-Derived Methane Gas

The plant is exploring the possibility of firing landfill-derived methane gas as a supplemental fuel. The characteristics of this fuel are expected to be substantially similar to natural gas, which is typically over 80% methane, and which the units are already currently permitted to fire.

**Attachment PRVU1\_10.txt  
Alternative Methods of Operation**

Evaporation of Spent Boiler Chemical Cleaning Chemicals

On a periodic basis, as part of routine maintenance, the inside of the steam generator tubes (boiler tubes) are cleaned using a series of chemical solutions that remove deposited scale which adversely affects the efficiency and reliability of the generating units.

After the second stage treatment, three or more rinses are performed, in order to wash the cleaning solution from the inside of the boiler tubes. The solutions and rinsewaters are collected in large mobile tanks ("frac tanks") pursuant to guidance issued by the Department. Upon completion of the cleaning process and prior to disposal of the spent cleaning solution and rinses, representative sampling of the liquids collected in the "frac tanks" is conducted as per 40 CFR 261, Appendix I, to determine the hazardous waste status of the accumulated wastewater, using Toxicity Characteristic Leaching Procedure (TCLP) analysis.

If the spent cleaning solution and rinses are determined to be non-hazardous, they are then disposed of by evaporation in one of the facility's boilers. Introduction into the boiler will occur at a rate that will not cause an exceedence of the opacity limit of the unit in which evaporation is occurring (in this case, 40 percent opacity).

If the wastewater is determined to be hazardous, it will be managed as such in accordance with 40 CFR 262.34, 40 CFR 265 Subpart I, and 40 CFR 268 with respect to generators accumulating and treating waste in containers and tanks. An appropriate waste analysis plan will be developed to determine and document the pre- and post-treatment characteristics of the wastewater. Hazardous waste may also be transported to an approved offsite hazardous waste facility for the appropriate disposal.

## Attachment PRVU1\_12.txt

### Identification of Additional Applicable Requirements

Applicable Requirements as defined in Rule 62-210.200(29) not identified in Section D of this emission unit section are included in this attachment of the application. Any air operation permit issued by the Department (or local program designee) and included in this attachment is provided for information purposes. The specific conditions of the operating permit are not Applicable Requirements as defined in Rule 62-210.200(29) unless implementing a specific Applicable Requirement of the Department's rules (e.g. emission limitations and consent orders).

A0 50-206721 Permit contains the following conditions:

1. The permitted heat input rates for this boiler is 3,050 mmBtu/hour on fuel oil and 3,260 mmBtu/hour on natural gas (8760 hours per year allowed). FPL uses fuel sampling and analysis plus measurement of fuel flow to calculate the heat input rate to the boiler. FPL fires the fuels as specified, and maintains records to demonstrate this.
2. This boiler shall be fired with a variable combination of no.6 residual oil, natural gas, no.2 fuel oil, propane gas, used oil from FPL operations, landfill-derived methane gas, and expired fuel oil samples from the FPL's central laboratory. FPL maintains records to demonstrate this.
3. The maximum allowable emissions from each boiler shall not exceed the following emission limitations.

#### MAXIMUM ALLOWABLE EMISSION LIMITS

Pollutant	Fuel	lb/mmBtu	Test Method
Particulate Matter <sup>(1)</sup> Steady state	Oil	0.1	EPA Method 5 or 17
sootblowing	Oil	0.3 (max. 3 hours)	EPA Method 5 or 17
SO <sub>2</sub>	Oil	2.75	Monthly fuel analysis
NO <sub>x</sub> -RACT <sup>(3)</sup> NO <sub>x</sub> <sup>(2)</sup>	Oil	0.62 or 1,891lbs/hr	CEM
NO <sub>x</sub> <sup>(2)</sup>	Gas	0.50 or 1,630 lbs/hr	CEM

For compliance with each of these emission limits, FPL uses annual stack tests.

(2) These limits, based on a 30-day rolling average, apply at all times except during periods of startup, shutdown, or malfunction as provided by F.A.C rule 17-210.700.

(3) At the end of an 18 month study, the Department may revise the NO<sub>x</sub> limits. See item 6.

4. To determine compliance with the oil firing heat input limitation, the Permittee shall maintain daily records of fuel consumption for each boiler and monthly records of heating value for such fuel. All records shall be maintained for a minimum of three years after the date of each record and shall be made available to representatives of DER upon request.

*FPL has the records required by the above permit condition and such records are available to the Department for review.*

5. Any significant change in the method of operation, fuels or equipment shall be submitted for approval to DER's bureau of Air Regulation. *FPL will notify the Department as specified regarding significant changes.*

6. Following the installation of low NOx burners designed to achieve a 40 percent reduction in NOx emissions (from the 1990 baseline) an 18 month study will be completed during which the plant will strive to obtain the target limits of: 0.43 lbs/mmBtu or 1,402 lbs/hr for natural gas and 0.55 lbs/mmBtu or 1,678 lbs/hr for fuel oil. Quarterly status reports will be submitted summarizing the progress. At the end of the period, the Department may revise the NOx limits.

*FPL is nearing completion of the 18-month test program, and will submit a final report to the Department shortly. The quarterly reports required to be submitted by the specific condition have been submitted. **This item is expected to have been completed by the time the Title V permit is issued, and thus will become at that time an obsolete permit condition. Therefore FPL requests that it be deleted from the permit.***

7-11-83

In Matter of )  
 )  
Petition for Reduction in Quarterly )  
Particulate Emissions Compliance )  
Testing; )  
FLORIDA POWER AND LIGHT COMPANY, )  
 )  
Petitioner. )

OGC Case Nos.: 83-0578  
83-0577, 83-0576,  
83-0585, 83-0586,  
83-0587, 83-0588  
83-0581, 83-0580

ED

ORDER GRANTING PETITION FOR REDUCED  
FREQUENCY OF PARTICULATE TESTING

On September 16, 1983, the Petitioner, FLORIDA POWER AND LIGHT COMPANY, filed a Petition for Reduction in Quarterly Particulate Emissions Compliance Testing pursuant to Florida Administrative Code Rule 17-2.600(5)(b)1 for the following fossil fuel steam generating units:

- Port Everglades Plant Unit No. 2
- Port Everglades Plant Unit No. 3
- Port Everglades Plant Unit No. 4
- Turkey Point Plant Unit No. 1
- Turkey Point Plant Unit No. 2
- Riveria Plant Unit No. 3
- Riveria Plant Unit No. 4
- Manatee Plant Unit No. 1
- Manatee Plant Unit No. 2

Each of the units has a heat input exceeding 250 million Btu per hour.

The petition and supporting documentation submitted by the Petitioner indicate that between August 1979 and July 21, 1983, these units were afforded relief from the particulate standard contained in Florida Administrative Code Rule 17-2.600(5)(b)2 under the terms of a Department-issued variance. During the same period of time the Company elected to test quarterly as permitted under Rule 17-2.600(5)(b)1. Despite the existence of the variance, the tests results submitted during the last two years reveal that each of the above-listed units met the particulate emissions limitations contained in Rule 17-2.600(5)(b)2 of 0.1 pounds per million Btu heat input.

Florida Administrative Code Rule 17-2.600(5)(b)1 specifically provides that I may reduce the frequency of particulate testing




upon a demonstration that the particulate standard has been regularly met. The particulate standard referred to is the general standard found in the rule--0.1 parts per million Btu heat input--not a relaxed emission limit established by a variance.

The intent of Rule 17-2.600(5)(b)1 is to ensure that before the frequency of particulate testing is reduced, the source has established a record of complying with the requirements of Florida Administrative Code Chapter 17-2 relating to particulate matter emissions. Petitioner has documented that each of these units has a history of regulary complying with the particulate matter standard applicable to them.

IT IS ORDERED that the present petition is GRANTED. Under the terms of Rule 17-2.600(5)(b)1, Petitioner may reduce the frequency of particulate testing to an annual basis for each of the units named in this Order. If, however, any of the units fails to comply with the applicable particulate or visible emission standard, this Order will terminate upon written notice by the Department.


The Petitioner may request a hearing in accordance with Section 120.57, Florida Statutes, and Florida Administrative Code Chapters 17-1 and 28-5. The request for hearing must be filed (received) in the Office of General Counsel of the Department, 2600 Blair Stone Road, Twin Towers Office Building, Tallahassee, Florida 32301, within (14) days of receipt of this Order. Failure to file a request for hearing within this time shall constitute a waiver of Petitioner's right to request a hearing under Section 120.57, Florida Statutes.

DONE and ORDERED this 24 day of April, 1984.

  
VICTORIA J. TSCHINKEL  
Secretary

STATE OF FLORIDA DEPARTMENT  
OF ENVIRONMENTAL REGULATION  
2600 Blair Stone Road  
Tallahassee, Florida 32301  
(904)488-4805

DEPARTMENT OF ENVIRONMENTAL REGULATION  
Pursuant to §120.52 (9),  
Florida Statutes, with the designated Department  
Clerk, receipt of which is hereby acknowledged.

 \_\_\_\_\_  
Clerk Date

00037

CERTIFICATE OF SERVICE

I HEREBY CERTIFY that a copy of the foregoing Order Denying  
Petition for Reduced Frequency of Particulate Testing and the  
Order Granting Petition for Reduced Frequency of Particulate  
Testing have been furnished by U.S. Mail to Peter C. Cunningham,  
Esquire, Hop, ing Boyd Green and Sams, Post Office Box 6326,  
Tallahassee, Florida 32314 this 25th day of April, 1984.

*Nancy E. Wright*  
\_\_\_\_\_  
NANCY E. WRIGHT  
Assistant General Counsel

State of Florida Department  
of Environmental Regulation  
2600 Blair Stone Road  
Tallahassee, Florida 32301  
904/488-9730

In the Matter of: )  
Florida Power and Light )  
Co., Inc. )  
Petitioner )  
\_\_\_\_\_ )

ASP-86-E01

SEP 8 1986  
EPA. S. W. GARDNER

ORDER APPROVING REQUEST FOR ALTERNATIVE  
PROCEDURES AND REQUIREMENTS

Pursuant to Section 17-2.700 (3), Florida Administrative Code, Petitioner Florida Power and Light Company ("Petitioner") submitted to the Department a request for approval of alternate source sampling procedures and requirements. Having considered the written request, a copy of which is attached hereto as Exhibit 1, and supporting documentation, the following Findings of Fact, Conclusions of Law and Order are entered:

FINDINGS OF FACT

1. On May 30, 1986, Petitioner submitted a written request for approval of alternative procedures and requirements for Manatee Plant Units 1 and 2.

2. The petition requested that the Department grant Petitioner the authority to use EPA Reference Method 7E as an alternate procedure for measuring nitrogen oxides (NO<sub>x</sub>) emissions from the facility.

3. As grounds for the request, Petitioner has stated that using EPA Reference Method 7E in place of the existing EPA Reference Method 7, would allow the testing to be done quicker and would save Petitioner about \$4000 per test. The Petitioner also stated that Reference Method 7E would soon be certified by the Federal government as an adequate procedure for demonstrating compliance with NO<sub>x</sub> emissions. EPA Reference Method 7E was subsequently promulgated in the Federal Register as an approved method on June 11, 1986.

4. After review of the petition and supporting documentation, the Department finds that the alternate procedures and requirements would be adequate for the affected air pollution sources to demonstrate compliance with applicable emission limiting standards.

CONCLUSIONS OF LAW

5. The relief requested is within the scope of relief which can be granted by the Department pursuant to Section 403.061, Florida Statutes, and Section 17-2.700 (3), Florida Administrative Code. Such relief does not relieve Petitioner of the responsibility to comply with all applicable emission limiting standards, ambient air quality standards, or other permit conditions.

ORDER

6. Having considered the petition and supporting documentation, it is hereby ORDERED that:

The relief requested by Petitioner is granted. Therefore, specific condition No. 1 of permit No. A041-51630 and specific condition 1 of permit No. A041-64792 are hereby amended to reflect that Petitioner, Florida Power and Light Company is authorized to utilize EPA Reference Method 7E to demonstrate compliance at Manatee Plant Units 1 and 2.

This order shall constitute final agency action by the Department pursuant to Section 120.52 (9), Florida Statutes. The Petitioner may file a petition for an administrative hearing on this order within twenty-one (21) days of receipt of the order. The petition shall be filed with the Department of Environmental Regulation, Office of General Counsel, Twin Towers Office Building, 2600 Blair Stone Road, Tallahassee, Florida 32301, and shall be in the form required by Chapters 17-103 and 28-5, Florida Administrative Code. Failure to file a petition within the time specified above shall constitute a waiver by the Petitioner to an administrative hearing under Chapter 120, Florida Statutes.

Done and ordered this 5 day of September, 1986 in Tallahassee, Florida.

  
Victoria J. Tschinkel  
Secretary

FILING AND ACKNOWLEDGEMENT  
FILED, on this date, pursuant to S120.52 (9), Florida Statutes, with the designated Department Clerk, receipt of which is hereby acknowledged.

C. A. Hutchins      9-5-86  
Clerk                      Date

STATE OF FLORIDA DEPARTMENT  
OF ENVIRONMENTAL REGULATION  
2600 Blair Stone Road  
Tallahassee, Florida 32301

Telephone: (904) 488-4805

17-2.700(3) EXCEPTIONS AND APPROVAL OF ALTERNATE  
PROCEDURES AND REQUIREMENTS

Florida Power and Light Co., Incorporation

REQUEST FOR EXCEPTION

UNIT: Oil Fired Steam PERMIT NO: A041-51630 (Unit 1)  
Electric and A041-64792 (Unit 2)  
Generating - EMISSION LIMITING STANDARD:  
850 megawatts NO<sub>x</sub> - 0.30 pounds per  
million BTU heat input

PLANT: Manatee

DESCRIPTION: Compliance Testing for NO<sub>x</sub> for Manatee Plants  
Units No. 1 and No. 2.

PROVISION TO BE EXCEPTED: Section 17-2.700(2)(a), F.A.C. and  
Specific Condition 1 of the Air  
Permits A041-51630 and A041-64792

EXCEPTION REQUESTED: Use of EPA Reference Method 7E  
in lieu of EPA Reference Method 7

BASIS OF REQUEST: EPA Reference Method 7E has been promulgated  
in the Federal Register; will allow quicker  
testing; and will save the petitioner  
approximately \$4000 per each test.

III. EMISSIONS UNIT INFORMATION

Information for Facility - ID : 1 Emission Unit # : 2

A separate Emissions Unit Information Section (including subsections A through L as required) must be completed for each emissions unit addressed in this Application for Air Permit. If submitting the application form in hard copy, indicate, in the space provided at the top of each page, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application. Some of the subsections comprising the Emissions Unit Information Section of the form are intended for regulated emissions units only. Others are intended for both regulated and unregulated emissions units. Each subsection is appropriately marked.

A. TYPE OF EMISSIONS UNIT  
(Regulated and Unregulated Emissions Units)

Type of Emissions Unit Addressed in This Section

1. Regulated or Unregulated Emissions Units? Check one:

- The emissions unit addressed in this Emissions Unit Information Section is a regulated emissions unit.
- The emissions unit addressed in this Emissions Unit Information Section is a unregulated emissions unit.

2. Single Process, Group Processes, or Fugitive Only?

Enter The Number (1-3): 1

- [ 1 ] This Emissions Unit Information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).
- [ 2 ] This Emissions Unit Information Section addresses, as a single emissions unit, a group of process or production units and activities which has at least one definable emission point(stack or vent) but may also produce fugitive emissions.
- [ 3 ] This Emissions Unit Information Section addresses, as a single emissions unit, one or more process or production units and activities which produce fugitive emissions only.

**B. GENERAL EMISSIONS UNIT INFORMATION  
(Regulated and Unregulated Emissions Units)**

**Emissions Unit Description and Status**

1. Description of Emissions Unit Addressed in This Section (limit to 60 characters): Fossil Fuel Steam Generator, Unit 4
2. Emissions Unit Identification Number: 004 (No Corresponding ID or Unknown)
3. Emission Unit Status Code: (A or C) : A
4. Acid Rain Unit? (Y/N): Y
5. Emissions Unit Major Group SIC Code: 49
6. Emissions Unit Comment (limit to 500 characters): The generator nameplate rating given is taken from data provided to the Florida Public Service Commission (PSC) in the 10-Year Site Plan. Actual generator output may exceed the value given, due to changes in unit efficiency, or with fluctuations in system load demand.

**Emissions Unit Control Equipment**

**A. Control Equipment # : 1**

1. Description (limit to 200 characters): Multiple Cyclone with Fly Ash Reinjection
2. Control Device or Method Code: Multiple Cyclone w/Fly Ash Reinjection

**B. Control Equipment # : 2**

1. Description (limit to 200 characters): Low Nox Burners
2. Control Device or Method Code: Modified Furnace or Burner Design

**C. Control Equipment # :**

1. Description (limit to 200 characters):
2. Control Device or Method Code:



### C. EMISSIONS UNIT DETAIL INFORMATION (Regulated Emissions Units)

#### Emissions Unit Details

1. Initial Startup Date (DD-MON-YYYY): 03/01/63	
2. Long-term Reserve Shutdown Date (DD-MON-YYYY):	
3. Package Unit: Manufacturer: Foster-Wheeler	Model Number: NA
4. Generator Nameplate Rating: 310 MW	
5. Incinerator Information: Dwell Temperature: °F Dwell Time: seconds Incinerator Afterburner Temperature: °F	

#### Emissions Unit Operating Capacity

1. Maximum Heat Input Rate: 3260 mmBtu/hr	
2. Maximum Incineration Rate: lbs/hr tons/day	
3. Maximum Process or Throughput Rate: Units:	
4. Maximum Production Rate: Units:	
5. Operating Capacity Comment (limit to 200 characters): Maximum Heat Input Rate is based on firing 100% Natural Gas. The Heat Input Rate for #6 fuel oil is 3050 mmBtu/hr. The method of compliance for determining heat input is fuel sampling and analysis.	

#### Emissions Unit Operating Schedule

Requested Maximum Operating Schedule:	
hours/day	days/week
weeks/yr	8760 hours/yr

**D. EMISSIONS UNIT REGULATIONS  
(Regulated Emissions Units Only)**

**Rule Applicability Analysis** (Required for Category II applications and Category III applications involving non Title-V sources. See Instructions.)

Not Applicable

**List of Applicable Regulations** (Required for Category I applications and Category III applications involving Title-V sources. See Instructions.)

Emissions Unit ID 2

<p>40 C.F.R. 279.72                  40 C.F.R. 72.20(a)                  40 C.F.R. 72.20(b)                  40 C.F.R. 72.20(c)                  40 C.F.R. 72.21(a)                  40 C.F.R. 72.21(b)                  40 C.F.R. 72.21(d)                  40 C.F.R. 72.22(a)                  40 C.F.R. 72.22(c)                  40 C.F.R. 72.23                  40 C.F.R. 72.24(a)                  40 C.F.R. 72.30(a)                  40 C.F.R. 72.30(b)(2)                  40 C.F.R. 72.30(c)                  40 C.F.R. 72.30(d)                  40 C.F.R. 72.32                  40 C.F.R. 72.33(b)                  40 C.F.R. 72.33(c)                  40 C.F.R. 72.33(d)                  40 C.F.R. 72.40(a)                  40 C.F.R. 72.40(b)                  40 C.F.R. 72.40(c)                  40 C.F.R. 72.40(d)                  40 C.F.R. 72.51                  40 C.F.R. 72.90                  40 C.F.R. 72.9(a)(1)(iii)                  40 C.F.R. 72.9(a)(1)(i)                  40 C.F.R. 72.9(a)(2)                  40 C.F.R. 72.9(b)                  40 C.F.R. 72.9(c)(1)(iii)                  40 C.F.R. 72.9(c)(2)                  40 C.F.R. 72.9(c)(4)                  40 C.F.R. 72.9(c)(5)                  40 C.F.R. 72.9(d)                  40 C.F.R. 72.9(e)                  40 C.F.R. 72.9(f)                  40 C.F.R. 72.9(g)(4)                  40 C.F.R. 73.33                  40 C.F.R. 73.35                  40 C.F.R. 75 Appendix A-1                  40 C.F.R. 75 Appendix A-2                  40 C.F.R. 75 Appendix A-3                  40 C.F.R. 75 Appendix A-4                  40 C.F.R. 75 Appendix A-5                  40 C.F.R. 75 Appendix A-6                  40 C.F.R. 75 Appendix B</p>	<p>40 C.F.R. 75 Appendix C-1                  40 C.F.R. 75 Appendix C-2                  40 C.F.R. 75 Appendix D                  40 C.F.R. 75 Appendix F                  40 C.F.R. 75 Appendix G-2                  40 C.F.R. 75 Appendix G-4                  40 C.F.R. 75 Appendix H                  40 C.F.R. 75.10(a)(1)                  40 C.F.R. 75.10(a)(2)                  40 C.F.R. 75.10(a)(3)(i)                  40 C.F.R. 75.10(a)(4)                  40 C.F.R. 75.10(b)                  40 C.F.R. 75.10(c)                  40 C.F.R. 75.10(d)                  40 C.F.R. 75.10(f)                  40 C.F.R. 75.10(g)                  40 C.F.R. 75.11(b)(1)                  40 C.F.R. 75.11(c)(3)                  40 C.F.R. 75.11(d)                  40 C.F.R. 75.12(a)                  40 C.F.R. 75.12(b)                  40 C.F.R. 75.13(a)                  40 C.F.R. 75.13(b)                  40 C.F.R. 75.14(a)                  40 C.F.R. 75.20(a)(5)                  40 C.F.R. 75.20(b)                  40 C.F.R. 75.20(c)                  40 C.F.R. 75.20(d)                  40 C.F.R. 75.20(f)                  40 C.F.R. 75.20(g)                  40 C.F.R. 75.21(a)                  40 C.F.R. 75.21(b)                  40 C.F.R. 75.21(c)                  40 C.F.R. 75.21(d)                  40 C.F.R. 75.21(e)                  40 C.F.R. 75.21(f)                  40 C.F.R. 75.22                  40 C.F.R. 75.24                  40 C.F.R. 75.30(a)(1)                  40 C.F.R. 75.30(a)(2)                  40 C.F.R. 75.30(a)(3)                  40 C.F.R. 75.31                  40 C.F.R. 75.32                  40 C.F.R. 75.33                  40 C.F.R. 75.35                  40 C.F.R. 75.36</p>	<p>40 C.F.R. 75.4(a)(4)(ii)                  40 C.F.R. 75.5                  40 C.F.R. 75.51(c)                  40 C.F.R. 75.53(a)                  40 C.F.R. 75.53(b)                  40 C.F.R. 75.53(c)                  40 C.F.R. 75.53(d)(1)                  40 C.F.R. 75.54                  40 C.F.R. 75.55(c)                  40 C.F.R. 75.55(e)                  40 C.F.R. 75.56                  40 C.F.R. 75.60(a)                  40 C.F.R. 75.60(b)                  40 C.F.R. 75.60(c)(3)                  40 C.F.R. 75.61(a)(1)                  40 C.F.R. 75.61(a)(5)                  40 C.F.R. 75.61(b)                  40 C.F.R. 75.62                  40 C.F.R. 75.63                  40 C.F.R. 75.64(a)                  40 C.F.R. 75.64(b)                  40 C.F.R. 75.64(c)                  40 C.F.R. 75.64(d)                  40 C.F.R. 75.65                  40 C.F.R. 75.66(a)                  40 C.F.R. 75.66(b)                  40 C.F.R. 75.66(c)                  40 C.F.R. 75.66(d)                  40 C.F.R. 75.66(g)                  40 C.F.R. 75.66(h)                  40 C.F.R. 76.13                  40 C.F.R. 77.3                  40 C.F.R. 77.5(b)                  40 C.F.R. 77.6                  F.A.C. 62-204.800(12)                  (state only)                  F.A.C. 62-204.800(13)                  (state only)                  F.A.C. 62-204.800(14)                  (state only)                  F.A.C. 62-210.650                  F.A.C. 62-210.700 (1)                  F.A.C. 62-210.700 (2)                  F.A.C. 62-210.700 (3)                  F.A.C. 62-210.700 (4)                  F.A.C. 62-210.700 (6)                  F.A.C. 62-214.300                  F.A.C. 62-214.330                  F.A.C. 62-214.350 (2)</p>	<p>F.A.C. 62-214.350 (3)                  F.A.C. 62-214.350 (5)                  F.A.C. 62-214.350 (6)                  F.A.C. 62-214.370 (1)                  F.A.C. 62-214.370 (3)                  F.A.C. 62-214.370 (4)                  F.A.C. 62-214.370 (7)                  F.A.C. 62-214.430                  F.A.C. 62-296.405(1)(a)                  paragraph 2                  F.A.C. 62-296.405(1)(b)                  F.A.C. 62-296.405(1)(c)1.j.                  F.A.C. 62-296.405(1)(e)(1)                  F.A.C. 62-296.405(1)(e)(2)                  F.A.C. 62-296.405(1)(e)(3)                  F.A.C.                  62-296.405(1)(f)1.a.(i)                  F.A.C. 62-296.405(1)(f)1.b.                  F.A.C. 62-296.500(2)(a)1.                  F.A.C. 62-296.500(2)(c)                  F.A.C. 62-296.570(4)(a)3.                  F.A.C. 62-296.570(4)(a)4.                  F.A.C. 62-296.570(4)(b)3.                  F.A.C. 62-296.570(4)(c)                  F.A.C. 62-297.310(1)                  F.A.C. 62-297.310(2)(b)                  F.A.C. 62-297.310(3)                  F.A.C. 62-297.310(4)(a)1.                  F.A.C. 62-297.310(4)(a)2.c.                  F.A.C. 62-297.310(4)(b)                  F.A.C. 62-297.310(4)(c)                  F.A.C. 62-297.310(4)(d)                  F.A.C. 62-297.310(4)(e)                  F.A.C. 62-297.310(5)                  F.A.C. 62-297.310(6)(a)                  F.A.C. 62-297.310(6)(c)                  F.A.C. 62-297.310(6)(d)                  F.A.C. 62-297.310(6)(e)                  F.A.C. 62-297.310(6)(f)                  F.A.C. 62-297.310(6)(g)                  F.A.C. 62-297.310(7)(a)1.                  F.A.C. 62-297.310(7)(a)2.                  F.A.C. 62-297.310(7)(a)3.                  F.A.C. 62-297.310(7)(a)4.                  F.A.C. 62-297.310(7)(a)5.                  F.A.C. 62-297.310(7)(a)9.                  F.A.C. 62-297.310(7)(c)                  F.A.C. 62-297.310(8)                  Table 62-297.310-1</p>
--	--	--	---

**E. EMISSION POINT (STACK/VENT) INFORMATION  
(Regulated Emissions Units Only)**

**Emission Point Description and Type**

Information for Facility-ID 1 Emission Unit # :2

1. Identification of Point on Plot Plan or Flow Diagram: Unit 4 boiler
2. Emission Point Type Code (1,2,3,4) : 1
3. Descriptions of Emissions Points Comprising this Emissions Unit (limit to 100 characters): The EU-2 emission unit (Unit 4 boiler) has one emission point which is the stack.
4. ID Numbers or Descriptions of Emission Units with this Emission Point in Common: Emission unit 2, Riviera Unit 4 boiler.
5. Discharge Type Code (D, F, H, P, R, V, W) : v
6. Stack Height: 298 ft
7. Exit Diameter: 16 ft
8. Exit Temperature: 263 °F
9. Actual Volumetric Flow Rate: 1052646.3 acfm
10. Percent Water Vapor: %
11. Maximum Dry Standard Flow Rate: dscfm
12. Nonstack Emission Point Height: ft
13. Emission Point UTM Coordinates: Zone: 17 East: 594.187 North: 2960.803
14. Emission Point Comment (limit to 200 characters): Information in items 8 & 9 was collected during the February 1994 particulate test for this unit. Temp was taken @ mid-stack @ ~ 90% of max heat input. Flow rates & temps at other times may vary.

**F. SEGMENT (PROCESS/FUEL) INFORMATION  
(Regulated and Unregulated Emissions Units)**

**Segment Description and Rate:**

Information for Facility\_ID :/ Emission Unit #: 2 Segment #: 1

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Unit 4 boiler firing number 6 oil
2. Source Classification Code (SCC): 1-01-004-01
3. SCC Units: thousand gallons burned
4. Maximum Hourly Rate: 20.07
5. Maximum Annual Rate: 175776.3
6. Estimated Annual Activity Factor:
7. Maximum Percent Sulfur: 2.5
8. Maximum Percent Ash: 0.1
9. Million Btu per SCC Unit: 152
10. Segment Comment (limit to 200 characters): The unit is currently permitted to burn a variable combination of No. 6 residual oil, natural gas, No. 2 fuel oil, propane gas, or on-specification used oil from FPL operations.

**F. SEGMENT (PROCESS/FUEL) INFORMATION  
(Regulated and Unregulated Emissions Units)**

**Segment Description and Rate:**

Information for Facility\_ID :/ Emission Unit #: 2 Segment #: 2

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Unit 4 boiler firing natural gas
2. Source Classification Code (SCC): 1-01-006-01
3. SCC Units: Million cubic feet burned
4. Maximum Hourly Rate: 3.1
5. Maximum Annual Rate: 27197.7
6. Estimated Annual Activity Factor:
7. Maximum Percent Sulfur: 0.0031
8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 1050
10. Segment Comment (limit to 200 characters): The unit is currently permitted to burn a variable combination of No. 6 residual oil, natural gas, No. 2 fuel oil, propane gas or on-specification used oil from FPL operations.

**F. SEGMENT (PROCESS/FUEL) INFORMATION  
(Regulated and Unregulated Emissions Units)**

**Segment Description and Rate:**

Information for Facility\_ID :1 Emission Unit #: 2 Segment #: 3

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Unit 4 boiler firing on-specification used oil
2. Source Classification Code (SCC): 1-01-013-02
3. SCC Units: thousand gallons burned
4. Maximum Hourly Rate: 22.43
5. Maximum Annual Rate: 100
6. Estimated Annual Activity Factor:
7. Maximum Percent Sulfur: 2.5
8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 136
10. Segment Comment (limit to 200 characters): The maximum annual rate of on-specification used oil burned in the Riviera boiler unit 4 is based on historical data.

**F. SEGMENT (PROCESS/FUEL) INFORMATION  
(Regulated and Unregulated Emissions Units)**

**Segment Description and Rate:**

Information for Facility\_ID :1 Emission Unit #: 2 Segment #: 4

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Unit 4 Boiler burning Number 2 fuel oil
2. Source Classification Code (SCC): 1-01-005-01
3. SCC Units: thousand gallons burned
4. Maximum Hourly Rate: 22.43
5. Maximum Annual Rate: 196455.9
6. Estimated Annual Activity Factor:
7. Maximum Percent Sulfur: 0.5
8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 136
10. Segment Comment (limit to 200 characters): The unit is currently permitted to burn a variable combination of No. 6 residual oil, natural gas, No. 2 fuel oil, propane gas or on-specification used oil from FPL operations.



**F. SEGMENT (PROCESS/FUEL) INFORMATION  
(Regulated and Unregulated Emissions Units)**

**Segment Description and Rate:**

Information for Facility\_ID :/ Emission Unit #: 2 Segment #: 5

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Unit 4 boiler firing propane
2. Source Classification Code (SCC): 1-01-006-01
3. SCC Units: Million cubic feet burned
4. Maximum Hourly Rate: 3.26
5. Maximum Annual Rate: 28557.6
6. Estimated Annual Activity Factor:
7. Maximum Percent Sulfur:
8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 1000
10. Segment Comment (limit to 200 characters): The unit is currently permitted to burn a variable combination of No. 6 residual oil, natural gas, No. 2 fuel oil, propane gas, or on-specification used oil from FPL operations.

**F. SEGMENT (PROCESS/FUEL) INFORMATION  
(Regulated and Unregulated Emissions Units)**

**Segment Description and Rate:**

Information for Facility\_ID :1 Emission Unit #: 2 Segment #: 6

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Unit 4 Boiler co-firing all possible combinations of natural gas, No. 6 fuel oil, No. 2 fuel oil, propane, on specification used oil and landfill-derived methane gas.
2. Source Classification Code (SCC): 1-01-006-01
3. SCC Units: thousand gallons
4. Maximum Hourly Rate: 20.07
5. Maximum Annual Rate: 175776.3
6. Estimated Annual Activity Factor:
7. Maximum Percent Sulfur: 2.5
8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 152
10. Segment Comment (limit to 200 characters): This segment information page represents cofiring. The data provided is based on the #6 oil equivalent values for each field.

**F. SEGMENT (PROCESS/FUEL) INFORMATION  
(Regulated and Unregulated Emissions Units)**

**Segment Description and Rate:**

Information for Facility\_ID :1 Emission Unit #: 2 Segment #: 7

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Unit 4 Boiler chemical cleaning waste evaporation
2. Source Classification Code (SCC): 1-01-013-01
3. SCC Units: thousand gallons burned
4. Maximum Hourly Rate: 3
5. Maximum Annual Rate: 500
6. Estimated Annual Activity Factor:
7. Maximum Percent Sulfur:
8. Maximum Percent Ash:
9. Million Btu per SCC Unit:
10. Segment Comment (limit to 200 characters): Items 6,7,8 & 9 do not apply. This activity to be undertaken on a periodic basis in accordance with DARM guidance, and EPA waste rules (40 CFR 279.72).

**F. SEGMENT (PROCESS/FUEL) INFORMATION  
(Regulated and Unregulated Emissions Units)**

**Segment Description and Rate:**

Information for Facility\_ID :1 Emission Unit #: 4 Segment #: 8

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Unit 4 boiler firing methane gas
2. Source Classification Code (SCC): 1-01-006-01
3. SCC Units: Million cubic feet burned
4. Maximum Hourly Rate: 3.1
5. Maximum Annual Rate: 27197.7
6. Estimated Annual Activity Factor:
7. Maximum Percent Sulfur: 0.0031
8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 1050
10. Segment Comment (limit to 200 characters): The plant is exploring the possibility of firing landfill-derived methane gas as a supplemental fuel. Information given is based on natural gas characteristics.

**G. EMISSIONS UNIT POLLUTANTS  
(Regulated Emissions Units Only)**

Information for Facility\_ID: 1 Emission Unit #: 2

1. Pollutant Emitted	2. Primary Control Device Code	3. Secondary Control Device Code	4. Pollutant Regulatory Code
SO2	NA	NA	EL
NOX	024	NA	EL
CO	NA	NA	NS
VOC	NA	NA	NS
PM	077	NA	EL
PM10	077	NA	NS
H133	NA	NA	NS
H106	NA	NA	NS
H107	NA	NA	NS
SAM	NA	NA	NS
HAP	NA	NA	NS

**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION  
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**

**Information for Facility\_ID: 1 Emission Unit #: 2 Pollutant #: 1**

**Pollutant Detail Information**

1. Pollutant Emitted:	Sulfur Dioxide
2. Total Percent Efficiency of Control:	%
3. Potential Emissions:	8387.5 lbs/hr                      36737.25 tons/yr
4. Synthetically Limited? (Yes/No):	No
5. Range of Estimated Fugitive/Other Emissions: (1, 2, 3):	to tons/yr
6. Emission Factor:	2.75                      Units lb/mmBtu
Reference:	DEP Rule 62-296.405(1)(c)1.j.
7. Emissions Method Code: (0, 1, 2, 3, 4, 5):	0
	<input type="checkbox"/> 0 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input type="checkbox"/> 5
8. Calculation of Emissions (limit to 600 characters):	2.75 lb/mmBtu * 3050mmBtu/hr = 8387.5 lb/hr  (8387.5 lb/hr * 8760 hr/yr) / 2000 lb/ton = 36737.25 tons/yr
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters):	SO2 emissions are limited by Rule 62-296.405(1)(c)1.j. Equivalent allowable emissions are for liquid fuel.

**Information for Facility\_ID: 1 Emission Unit #: 2 Pollutant #: 1  
Basis For Allowable Emission #: 1**

**Allowable Emissions** (Pollutant identified on front page)

1. Basis for Allowable Emissions Code: Required or assumed by permittee for other reasons.
2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 2.75 Units : lb/mmBtu
4. Equivalent Allowable Emissions: 8387.5 lbs/hr 36737.25 tons/yr
5. Method of Compliance: Fuel sampling and analysis
6. Pollutant Allowable Emissions Comment ( <b>Desc. of Related Operating Method/Mode</b> ) (limit to 200 characters): 156 2.75 lb/mmBtu is the current regulatory limit on SO2 emissions [Rule 62-295.405(1)(c)1.j.]. Equivalent allowable emissions are given for liquid fuel firing.

**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION  
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**

**Information for Facility\_ID: 1 Emission Unit #: 2 Pollutant #: 2**

**Pollutant Detail Information**

1. Pollutant Emitted: Nitrogen Oxides									
2. Total Percent Efficiency of Control: %									
3. Potential Emissions: 1891 lbs/hr                      8282.58 tons/yr									
4. Synthetically Limited? (Yes/No): No									
5. Range of Estimated Fugitive/Other Emissions: (1, 2, 3) : to tons/yr									
6. Emission Factor: 0.62                      Units lb/mmBtu Reference: DEP Rule 62-296.570(4)(b)3.									
7. Emissions Method Code: (0, 1, 2, 3, 4, 5): 0 [ ] 0      [ ] 1      [ ] 2      [ ] 3      [ ] 4      [ ] 5									
8. Calculation of Emissions (limit to 600 characters): 0.62 lb/mmBtu * 3050 mmBtu/hr = 1891.0 lb/hr  (1891 lb/hr * 8760 hr/yr) / 2000 lb/ton = 8282.58 tons/yr									
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters): Riviera plant is currently conducting an 18-month program to attempt to achieve the following target limits [30-day rolling average]:									
<table style="width: 100%; border: none;"> <tr> <td style="width: 30%;"></td> <td style="text-align: center;">Natural Gas</td> <td style="text-align: center;">Fuel Oil</td> </tr> <tr> <td style="padding-left: 20px;">lb/mmBtu</td> <td style="text-align: center;">0.43</td> <td style="text-align: center;">0.55</td> </tr> <tr> <td style="padding-left: 20px;">lb/hr</td> <td style="text-align: center;">1,402</td> <td style="text-align: center;">1,678</td> </tr> </table>		Natural Gas	Fuel Oil	lb/mmBtu	0.43	0.55	lb/hr	1,402	1,678
	Natural Gas	Fuel Oil							
lb/mmBtu	0.43	0.55							
lb/hr	1,402	1,678							



**Information for Facility\_ID: 1 Emission Unit #: 2 Pollutant #: 2  
Basis For Allowable Emission #: 1**

**Allowable Emissions** (Pollutant identified on front page)

1. Basis for Allowable Emissions Code: Required or assumed by permittee for other reasons.
2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 0.62 Units : lb/mmBtu
4. Equivalent Allowable Emissions: 1891 lbs/hr 8282.58 tons/yr
5. Method of Compliance: Continuous Emissions Monitor
6. Pollutant Allowable Emissions Comment ( <b>Desc. of Related Operating Method/Mode</b> ) (limit to 200 characters): <b>194</b> 0.62 lb/mmBtu is the current reg. limit [Rule 62-296.570(4)(b)3] on NOx emissions [30-day rolling avg - Rule 62-296.570(4)(a)4.]. Equivalent allowable emissions are given for liquid fuel firing.

**Information for Facility\_ID: 1 Emission Unit #: 2 Pollutant #: 2  
Basis For Allowable Emission #: 2**

**Allowable Emissions** (Pollutant identified on front page)

1. Basis for Allowable Emissions Code: Required or assumed by permittee for other reasons.
2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 0.5 Units : lb/mmBtu
4. Equivalent Allowable Emissions: 1630 lbs/hr 7139.4 tons/yr
5. Method of Compliance: Continuous Emissions Monitor
6. Pollutant Allowable Emissions Comment ( <b>Desc. of Related Operating Method/Mode</b> ) (limit to 200 characters): <b>194</b> 0.50 lb/mmBtu is the current reg. limit [Rule 62-296.570(4)(b)3] on NOx emissions [30-day rolling avg - Rule 62-296.570(4)(a)4.]. Equivalent allowable emissions are given for natural gas firing.

**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION  
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**

**Information for Facility\_ID: 1 Emission Unit #: 2 Pollutant #: 4**

**Pollutant Detail Information**

1. Pollutant Emitted: Particulate Matter - Total	
2. Total Percent Efficiency of Control:	%
3. Potential Emissions: 381.25 lbs/hr	1669.88 tons/yr
4. Synthetically Limited? (Yes/No): No	
5. Range of Estimated Fugitive/Other Emissions: (1, 2, 3): to tons/yr	
6. Emission Factor: 0.125	Units lb/mmBtu
Reference: DEP Rule 62-296.405(1)(b) and Rule 62-210.700(3)	
7. Emissions Method Code: (0,1, 2, 3, 4, 5): 0	
[ ] 1	[ ] 2      [ ] 3      [ ] 4      [ ] 5
8. Calculation of Emissions (limit to 600 characters): 0.125 lb/mmBtu * 3050 mmBtu/hr = 381.25 lb/hr  (381.25 lb/hr * 8760 hr/yr) / 2000 lb/ton = 1669.88 tons/yr	
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters): A particulate matter emissions limit of 3 hours /24 hours at 0.3 lb/mmBtu and 21 hours/24 hours at 0.1 lb/mmBtu is equivalent to an average of 0.125 lb/mmBtu	

**Allowable Emissions** (Pollutant identified on front page)

**A.**

1. Basis for Allowable Emissions Code:
2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units:      Units :

**Information for Facility\_ID: 1 Emission Unit #: 2 Pollutant #: 4  
Basis For Allowable Emission #: 1 1**

**Allowable Emissions** (Pollutant identified on front page)

1. Basis for Allowable Emissions Code: Required or assumed by permittee for other reasons.
2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 0.1 Units : lb/mmBtu
4. Equivalent Allowable Emissions: 305 lbs/hr 1168.9 tons/yr
5. Method of Compliance: DEP Rule 62-296.405(1)(e)2.
6. Pollutant Allowable Emissions Comment ( <b>Desc. of Related Operating Method/Mode</b> ) (limit to 200 characters): 167 Data is for steady-state conditions firing liquid fuel. The equivalent allowable emissions given above are based on steady-state operation 21 hours per 24-hour period.

**Information for Facility\_ID: 1 Emission Unit #: 2 Pollutant #: 4  
Basis For Allowable Emission #: 2 2**

**Allowable Emissions** (Pollutant identified on front page)

1. Basis for Allowable Emissions Code: Required or assumed by permittee for other reasons.
2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 0.3 Units : lb/mmBtu
4. Equivalent Allowable Emissions: 915 lbs/hr 501 tons/yr
5. Method of Compliance: DEP Rule 62-296.405(1)(e)2.
6. Pollutant Allowable Emissions Comment ( <b>Desc. of Related Operating Method/Mode</b> ) (limit to 200 characters): 178 Data is for soot-blowing and load-changing conditions firing fuel oil. Equivalent allowable emissions based on 3 hours of sootblowing per 24-hour period [DEP Rule 62-210.700(3)].

**I. VISIBLE EMISSIONS INFORMATION  
(Regulated Emissions Units Only)**

Information for Facility-ID : 1 Emission Unit #: 2  
Visible Emissions Limitation #: 1

1. Visible Emissions Subtype: VE40
2. Basis for Allowable Opacity Code(R/O):   RULE       [ ] Rule       [ ] Other
3. Allowable Opacity: Normal Conditions: 40                           % Exceptional Conditions:     % Maximum Period of Excess Opacity Allowed:   min/hr
4. Method of Compliance Code:   EPA Method 9
5. Visible Emissions Comment (limit to 200 characters): DEP Rule 62-296.405(1)(a) and (1)(e)1., F.A.C. Visible Emissions limited to 40% opacity, except for allowed excess emissions. Compliance testing is performed annually using EPA Method 9.

**I. VISIBLE EMISSIONS INFORMATION  
(Regulated Emissions Units Only)**

Information for Facility-ID : 1 Emission Unit #: 2  
Visible Emissions Limitation #: 2

1. Visible Emissions Subtype: VE60
2. Basis for Allowable Opacity Code(R/O): RULE <input type="checkbox"/> Rule <input type="checkbox"/> Other
3. Allowable Opacity: Normal Conditions: 60                          % Exceptional Conditions: 100     % Maximum Period of Excess Opacity Allowed: 24   min/hr
4. Method of Compliance Code: EPA Method 9
5. Visible Emissions Comment (limit to 200 characters): Rule 62-210.700(3), F.A.C. limits soot blowing & load changing to 60% opacity for up to 3 hrs/24 hrs, with < 4, 6-minute pds of up to 100% opac. if unit has an operational CEM.

**I. VISIBLE EMISSIONS INFORMATION  
(Regulated Emissions Units Only)**

Information for Facility-ID : 1 Emission Unit #: 2  
Visible Emissions Limitation #: 3

1. Visible Emissions Subtype: VE100			
2. Basis for Allowable Opacity Code(R/O):		RULE	[ ] Rule [ ] Other
3. Allowable Opacity: Normal Conditions: _____ % Exceptional Conditions: 100 % Maximum Period of Excess Opacity Allowed: 60 min/hr			
4. Method of Compliance Code: EPA Method 9			
5. Visible Emissions Comment (limit to 200 characters): Rules 62-210.700(1) and (2), F.A.C. allow up to 100% opacity for an unlimited time during startup and shutdown, and up to 2 hrs/24 hrs for malfunctions.			



**J. CONTINUOUS MONITOR INFORMATION  
(Regulated Emissions Units Only)**

Information for Facility-ID : 1 Emission Unit #: 2  
Continuous Monitor #: 1

**Continuous Monitoring System**

1. Parameter Code:			
2. Pollutant(s):	Sulfur Dioxide		
3. CMS Requirement Code(R/O):	RULE	Rule	/ Other
4. Monitor Information:			
Manufacturer: TECO		Serial Number: 43B-45440-273	
Model Number: 43B			
5. Installation Date (DD-MON-YYYY): 01/31/94			
6. Performance Specification Test Date (DD-MON-YYYY): 07/13/94			
7. Continuous Monitor Comment (limit to 200 characters): Required by 40 CFR 75.10(a)(1)			

**J. CONTINUOUS MONITOR INFORMATION  
(Regulated Emissions Units Only)**

Information for Facility-ID : 1 Emission Unit #: 2  
Continuous Monitor #: 2

**Continuous Monitoring System**

1. Parameter Code:			
2. Pollutant(s):	Nitrogen Oxides		
3. CMS Requirement Code(R/O):	RULE	Rule	/ Other
4. Monitor Information:			
Manufacturer: TECO		Serial Number: 42-44845-272	
Model Number: 42			
5. Installation Date (DD-MON-YYYY): 01/31/94			
6. Performance Specification Test Date (DD-MON-YYYY): 07/13/94			
7. Continuous Monitor Comment (limit to 200 characters): Required by 40 CFR 75.10(a)(2)			

**J. CONTINUOUS MONITOR INFORMATION  
(Regulated Emissions Units Only)**

Information for Facility-ID : 1 Emission Unit #: 2  
Continuous Monitor #: 3

**Continuous Monitoring System**

1. Parameter Code:			
2. Pollutant(s):	Carbon dioxide		
3. CMS Requirement Code(R/O):	RULE	Rule	/ Other
4. Monitor Information:			
Manufacturer: Milton Roy		Serial Number: N3H8186T	
Model Number: 3300			
5. Installation Date (DD-MON-YYYY): 01/31/94			
6. Performance Specification Test Date (DD-MON-YYYY): 07/13/94			
7. Continuous Monitor Comment (limit to 200 characters): Required by 40 CFR 75.10(a)(3)(i)			

**J. CONTINUOUS MONITOR INFORMATION  
(Regulated Emissions Units Only)**

Information for Facility-ID : 1 Emission Unit #: 2  
Continuous Monitor #: 4

**Continuous Monitoring System**

1. Parameter Code:			
2. Pollutant(s):		Volumetric flow rate	
3. CMS Requirement Code(R/O):		RULE	Rule / Other
4. Monitor Information:			
Manufacturer: Air Monitor		Serial Number: 5591D	
Model Number: MASSTRON			
5. Installation Date (DD-MON-YYYY): 01/31/94			
6. Performance Specification Test Date (DD-MON-YYYY): 07/13/94			
7. Continuous Monitor Comment (limit to 200 characters): Required by 40 CFR 75.10(a)(1)			

**J. CONTINUOUS MONITOR INFORMATION  
(Regulated Emissions Units Only)**

Information for Facility-ID : 1 Emission Unit #: 2  
 Continuous Monitor #: 5

**Continuous Monitoring System**

1. Parameter Code:			
2. Pollutant(s):		Visible emissions (opacity)	
3. CMS Requirement Code(R/O):		RULE	Rule / Other
4. Monitor Information:			
Manufacturer: Lear Siegler		Serial Number: 1673	
Model Number: RM41			
5. Installation Date (DD-MON-YYYY): 01/31/94			
6. Performance Specification Test Date (DD-MON-YYYY): 12/08/94			
7. Continuous Monitor Comment (limit to 200 characters): Required by 40 CFR 75.10(a)(4)			

**K. PREVENTION OF SIGNIFICANT DETERIORATION (PSD) INCREMENT  
TRACKING INFORMATION  
(Regulated and Unregulated Emissions Units)**

Information for Facility-ID : 1 Emission Unit # : 2

**PSD Increment Consumption Determination**

1. Increment Consuming for Particulate Matter or Sulfur Dioxide?

If the emissions unit addressed in this section emits particulate matter or sulfur dioxide, answer the following series of questions to make a preliminary determination as to whether or not the emissions unit consumes PSD increment for particulate matter or sulfur dioxide. Check the first statement, if any, that applies and skip remaining statements.

Select (1-5) : 5

- [ 1 ] The emissions unit is undergoing PSD review as part of this application, or has undergone PSD review previously, for particulate matter or sulfur dioxide. Final determination is that emissions unit consumes increment.
- [ 2 ] The facility addressed in this application is classified as an EPA major source pursuant to paragraph (c) of the definition of "major source of air pollution" in Chapter 17-213, F.A.C., and the emissions unit addressed in this section commenced (or will commence) construction after January 6, 1975. Preliminary determination is that baseline emissions are zero, and emissions unit consumes increment.
- [ 3 ] The facility addressed in this application is classified as an EPA major source, and the emissions unit began initial operation after January 6, 1975, but before December 27, 1977. Preliminary determination is that baseline emissions are zero, and emissions unit consumes increment.
- [ 4 ] For any facility, the emissions unit began (or will begin) initial operation after December 27, 1977. Preliminary determination is that baseline emissions are zero, and emissions unit consumes increment.
- [ 5 ] None of the above apply. If so, the baseline emissions of the emissions unit are nonzero. In such case, additional analysis, beyond the scope of this application, is needed to determine whether changes in emissions have occurred (or will occur) after the baseline date that may consume or expand increment.

2. Increment Consuming for Nitrogen Dioxide?

If the emissions unit addressed in this section emits nitrogen oxides, answer the following series of questions to make a preliminary determination as to whether or not the emissions unit consumes PSD increment for nitrogen dioxide. Check first statement, if any, that applies and skip remaining statements.

Select (1-5) : 5

- [ 1 ] The emissions unit addressed in this section is undergoing PSD review as part of this application, or has undergone PSD review previously, for nitrogen dioxide. Final determination is that emissions unit consumes increment.
  
- [ 2 ] The facility addressed in this application is classified as an EPA major source pursuant to paragraph (c) of the definition of "major source of air pollution" in Chapter 17-213, F.A.C., and the emissions unit addressed in this section commenced (or will commence) construction after February 8, 1988. Preliminary determination is that baseline emissions are zero, and emissions unit consumes increment.
  
- [ 3 ] The facility addressed in this application is classified as an EPA major source, and the emissions unit began initial operation after February 8, 1988, but before March 28, 1988. Preliminary determination is that baseline emissions are zero, and emissions unit consumes increment.
  
- [ 4 ] For any facility, the emissions unit began (or will begin) initial operation after March 28, 1988. Preliminary determination is that baseline emissions are zero, and emissions unit consumes increment.
  
- [ 5 ] None of the above apply. If so, the baseline emissions of the emissions unit are nonzero. In such case, additional analysis, beyond the scope of this application, is needed to determine whether changes in emissions have occurred (or will occur) after the baseline date that may consume or expand increment.

3. Increment Consuming/Expanding Code: (C, E, U- unkown):

PM	U
SO2	U
NO2	U

4. Baseline Emissions:

PM	lbs/hr	tons/yr
SO2	lbs/hr	tons/yr
NO2	tons/yr	

5. PSD Comment (limit to 200 characters):

Riviera Unit 4 commenced operation in 1963 which pre-dates the major source PSD baseline date of 1/5/75.



**L. EMISSIONS UNIT SUPPLEMENTAL INFORMATION  
(Regulated Emissions Units Only)**

Information for Facility-ID : 1 Emission Unit # : 2


**Supplemental Requirements for All Applications**

1. Process Flow Diagram : PRVU2_1.bmp Attached Document ID / Not Applicable / Waiver Requested
2. Fuel Analysis or Specification: PRVU1_2.txt Attached Document ID / Not Applicable / Waiver Requested
3. Detailed Description of Control Equipment : PRVU1_3.txt Attached Document ID / Not Applicable / Waiver Requested
4. Description of Stack Sampling Facilities : PRVU2_4.bmp Attached Document ID / Not Applicable / Waiver Requested
5. Compliance Test Report : NA Attached Document ID / Previously submitted, Date / Not Applicable
6. Procedures for Startup and Shutdown : PRVU1_6.txt Attached Document ID / Not Applicable
7. Operation and Maintenance Plan : NA Attached Document ID / Not Applicable
8. Supplemental Information for Construction Permit Application : NA Attached Document ID / Not Applicable
9. Other Information Required by Rule or Statute : NA Attached Document ID / Not Applicable

**Additional Supplemental Requirements for Category I Applications Only**

10. Alternative Methods of Operation : PRVU1_10.txt Attached Document ID / Not Applicable
11. Alternative Modes of Operation (Emissions Trading) : NA Attached Document ID / Not Applicable
12. Identification of Additional Applicable Requirements : PRVU1_12.txt Attached Document ID / Not Applicable
13. Enhanced Monitoring Plan : NA Attached Document ID / Not Applicable
14. Acid Rain Permit Application  Acid Rain Application - Phase II (Form No. 17-210.900(1)(a)) Attached Document ID: Not Applicable  Repowering Extension Plan (Form No. 17-210.900(1)(b)) Attached Document ID: NA  New Unit Exemption (Form No. 17-210.900(1)(c)) Attached Document ID: NA  Retired Unit Exemption (Form No. 17-210.900(1)(c)) Attached Document ID: NA  Not Applicable

WALKDOWN INFORMATION			TECHNICAL ACCEPTANCE		
ORG	BY	DATE	ORG	BY	DATE
AS-BUILT INFORMATION			ENGINEERING ORGANIZATION		
ORG	BY	DATE			



BAR CODE

PERMITTED FUEL OPTIONS

	SYSTEM	DISCIPLINE	PLANT/UNIT
	YY	M	RIVIERA PLANT
	SCALE	CAD FILE NAME	TITLE
N/A	RV002857	EMISSION UNIT PROCESS FLOW DIAGRAM STEAM GENERATOR/BOILER ATTACHMENT NO. EU2	
DRAWING SIZE	FPL ARCHIVE NAME		
A (8.5X11)	RV002857		

0	7/24/95	ISSUED FOR TITLE V PERMIT	PWB	PWB	CSP	CSP	ETS
REV	DATE	REVISION DESCRIPTION	BY	CH	COR	APR	ORG

DRAWING NUMBER	SHEET	REV
PRV3-M0107-YY	1 OF 1	0

FLORIDA POWER & LIGHT CO.  
 STACK SAMPLING FACILITIES  
 RIVIERA

PRVU2\_1.BMP



FOSSIL FUEL STEAM GENERATORS  
 UNITS 3 & 4

STACK SPECIFICATIONS

SAMPLING DIAMETER: 216 1/4 in.  
 SAMPLING AREA: 255.1 sq. ft.  
 SAMPLING PORT DEPTH: 50 1/2 in.  
 No. OF PORTS: 4  
 No. OF POINTS PER TRAVERSE: 8  
 TOTAL No. OF POINTS : 24  
 SAMPLING TIME PER POINT: 2.5 min.  
 TOTAL SAMPLING TIME: 60.0 min.  
 NOTE: DRAWING IS NOT TO SCALE

STACK DIAGRAM

PARTICULATE SAMPLING  
 PROBE DIAGRAM



Access to the sampling ports is provided by a ladder. Channel iron with a trolley system is above each port for probe support. AC power is available on the platform and at the base of the stack.

7/1/83

IN REPLY TO: )  
 )  
Petition for Reduction in Quarterly )  
Particulate Emissions Compliance )  
Testing; )  
FLORIDA POWER AND LIGHT COMPANY, )  
 )  
Petitioner. )

OCC Case Nos.: 83-0570  
83-0577, 83-0576,  
83-0585, 83-0586,  
83-0587, 83-0588  
83-0581, 83-0582

ED

ORDER GRANTING PETITION FOR REDUCED  
FREQUENCY OF PARTICULATE TESTING

On September 16, 1983, the Petitioner, FLORIDA POWER AND LIGHT COMPANY, filed a Petition for Reduction in Quarterly Particulate Emissions Compliance Testing pursuant to Florida Administrative Code Rule 17-2.600(5)(b)1 for the following fossil fuel steam generating units:

- Port Everglades Plant Unit No. 2
- Port Everglades Plant Unit No. 3
- Port Everglades Plant Unit No. 4
- Turkey Point Plant Unit No. 1
- Turkey Point Plant Unit No. 2
- Riveria Plant Unit No. 3
- Riveria Plant Unit No. 4
- Manatee Plant Unit No. 1
- Manatee Plant Unit No. 2

Each of the units has a heat input exceeding 250 million Btu per hour.

The petition and supporting documentation submitted by the Petitioner indicate that between August 1979 and July 21, 1983, these units were afforded relief from the particulate standard contained in Florida Administrative Code Rule 17-2.600(5)(b)2 under the terms of a Department-issued variance. During the same period of time the Company elected to test quarterly as permitted under Rule 17-2.600(5)(b)1. Despite the existence of the variance, the tests results submitted during the last two years reveal that each of the above-listed units met the particulate emissions limitations contained in Rule 17-2.600(5)(b)2 of 0.1 pounds per million Btu heat input.

Florida Administrative Code Rule 17-2.600(5)(b)1 specifically provides that I may reduce the frequency of particulate testing



CERTIFICATE OF SERVICE

I HEREBY CERTIFY that a copy of the foregoing Order Denying  
Petition for Reduced Frequency of Particulate Testing and the  
Order Granting Petition for Reduced Frequency of Particulate  
Testing have been furnished by U.S. Mail to Peter C. Cunningham,  
Esquire, Hop, ing Boyd Green and Sams, Post Office Box 6526,  
Tallahassee, Florida 32314 this 25th day of April, 1984.

Nancy E. Wright  
NANCY E. WRIGHT  
Assistant General Counsel

State of Florida Department  
of Environmental Regulation  
2600 Blair Stone Road  
Tallahassee, Florida 32301  
904/488-9730

In the matter of: )  
 )  
Florida Power and Light ) ASP-86-E01  
Co., Inc. )  
 )  
Petitioner )  
 )  
\_\_\_\_\_ )

REC'D  
SEP 2 1986  
EPA-FLORIDA

ORDER APPROVING REQUEST FOR ALTERNATIVE  
PROCEDURES AND REQUIREMENTS

Pursuant to Section 17-2.700 (3), Florida Administrative Code, Petitioner Florida Power and Light Company ("Petitioner") submitted to the Department a request for approval of alternate source sampling procedures and requirements. Having considered the written request, a copy of which is attached hereto as Exhibit 1, and supporting documentation, the following Findings of Fact, Conclusions of Law and Order are entered:

FINDINGS OF FACT

1. On May 30, 1986, Petitioner submitted a written request for approval of alternative procedures and requirements for Manatee Plant Units 1 and 2.
2. The petition requested that the Department grant Petitioner the authority to use EPA Reference Method 7E as an alternate procedure for measuring nitrogen oxides (NO<sub>x</sub>) emissions from the facility.
3. As grounds for the request, Petitioner has stated that using EPA Reference Method 7E in place of the existing EPA Reference Method 7, would allow the testing to be done quicker and would save Petitioner about \$4000 per test. The Petitioner also stated that Reference Method 7E would soon be certified by the Federal government as an adequate procedure for demonstrating compliance with NO<sub>x</sub> emissions. EPA Reference Method 7E was subsequently promulgated in the Federal Register as an approved method on June 11, 1986.
4. After review of the petition and supporting documentation, the Department finds that the alternate procedures and requirements would be adequate for the affected air pollution sources to demonstrate compliance with applicable emission limiting standards.



CONCLUSIONS OF LAW

5. The relief requested is within the scope of relief which can be granted by the Department pursuant to Section 403.061, Florida Statutes, and Section 17-2.700 (3), Florida Administrative Code. Such relief does not relieve Petitioner of the responsibility to comply with all applicable emission limiting standards, ambient air quality standards, or other permit conditions.

ORDER

6. Having considered the petition and supporting documentation, it is hereby ORDERED that:

The relief requested by Petitioner is granted. Therefore, specific condition No. 1 of permit No. A041-51630 and specific condition 1 of permit No. A041-64792 are hereby amended to reflect that Petitioner, Florida Power and Light Company is authorized to utilize EPA Reference Method 7E to demonstrate compliance at Manatee Plant Units 1 and 2.

This order shall constitute final agency action by the Department pursuant to Section 120.52 (9), Florida Statutes. The Petitioner may file a petition for an administrative hearing on this order within twenty-one (21) days of receipt of the order. The petition shall be filed with the Department of Environmental Regulation, Office of General Counsel, Twin Towers Office Building, 2600 Blair Stone Road, Tallahassee, Florida 32301, and shall be in the form required by Chapters 17-103 and 28-5, Florida Administrative Code. Failure to file a petition within the time specified above shall constitute a waiver by the Petitioner to an administrative hearing under Chapter 120, Florida Statutes.

Done and ordered this 5 day of September, 1985 in Tallahassee, Florida.

  
Victoria J. Tschinkel  
Secretary

STATE OF FLORIDA DEPARTMENT  
OF ENVIRONMENTAL REGULATION  
2600 Blair Stone Road  
Tallahassee, Florida 32301

Telephone: (904) 488-4805

FILING AND ACKNOWLEDGEMENT

FILED, on this date, pursuant to §120.52 (9), Florida Statutes, with the designated Department Clerk, receipt of which is hereby acknowledged.

C. A. Hutchins      9-5-85  
Clerk                              Date

17-2.700(3) EXCEPTIONS AND APPROVAL OF ALTERNATE  
PROCEDURES AND REQUIREMENTS

Florida Power and Light Co., Incorporation

REQUEST FOR EXCEPTION

UNIT: Oil Fired Steam PERMIT NO: A041-51630 (Unit 1)  
Electric and A041-64792 (Unit 2)  
Generating - EMISSION LIMITING STANDARD:  
850 megawatts NO<sub>x</sub> - 0.30 pounds per  
million BTU heat input

PLANT: Manatee

DESCRIPTION: Compliance Testing for NO<sub>x</sub> for Manatee Plants  
Units No. 1 and No. 2.

PROVISION TO BE EXCEPTED: Section 17-2.700(2)(a), F.A.C. and  
Specific Condition 1 of the Air  
Permits A041-51630 and A041-64792

EXCEPTION REQUESTED: Use of EPA Reference Method 7E  
in lieu of EPA Reference Method 7

BASIS OF REQUEST: EPA Reference Method 7E has been promulgated  
in the Federal Register; will allow quicker  
testing; and will save the petitioner  
approximately \$4000 per each test.

III. EMISSIONS UNIT INFORMATION

Information for Facility - ID : 1 Emission Unit # : 3

A separate Emissions Unit Information Section (including subsections A through L as required) must be completed for each emissions unit addressed in this Application for Air Permit. If submitting the application form in hard copy, indicate, in the space provided at the top of each page, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application. Some of the subsections comprising the Emissions Unit Information Section of the form are intended for regulated emissions units only. Others are intended for both regulated and unregulated emissions units. Each subsection is appropriately marked.

A. TYPE OF EMISSIONS UNIT (Regulated and Unregulated Emissions Units)

Type of Emissions Unit Addressed in This Section

1. Regulated or Unregulated Emissions Units? Check one:

- [ ] The emissions unit addressed in this Emissions Unit Information Section is a regulated emissions unit.
[ X ] The emissions unit addressed in this Emissions Unit Information Section is a unregulated emissions unit.

2. Single Process, Group Processes, or Fugitive Only?

Enter The Number (1-3): 2

- [ 1 ] This Emissions Unit Information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).
[ 2 ] This Emissions Unit Information Section addresses, as a single emissions unit, a group of process or production units and activities which has at least one definable emission point(stack or vent) but may also produce fugitive emissions.
[ 3 ] This Emissions Unit Information Section addresses, as a single emissions unit, one or more process or production units and activities which produce fugitive emissions only.

**B. GENERAL EMISSIONS UNIT INFORMATION  
(Regulated and Unregulated Emissions Units)**

**Emissions Unit Description and Status**

1. Description of Emissions Unit Addressed in This Section (limit to 60 characters): Unregulated Emission Units
2. Emissions Unit Identification Number: Unk (No Corresponding ID or Unknown)
3. Emission Unit Status Code: (A or C): A
4. Acid Rain Unit? (Y/N): N
5. Emissions Unit Major Group SIC Code: 49
6. Emissions Unit Comment (limit to 500 characters): This Emission Unit section comprises all unregulated sources at the Riviera facility, including the emergency diesel generator. Attachment PRV-FW presents a list of all sources included in this emission unit section.

**Emissions Unit Control Equipment**

**A. Control Equipment # :**

1. Description (limit to 200 characters): None
2. Control Device or Method Code:

**B. Control Equipment # :**

1. Description (limit to 200 characters):

2. Control Device or Method Code:

**C. Control Equipment # :**

1. Description (limit to 200 characters):

2. Control Device or Method Code:

**C. EMISSIONS UNIT DETAIL INFORMATION  
(Regulated Emissions Units)**

**Emissions Unit Details**

1. Initial Startup Date (DD-MON-YYYY): 01/06/78
2. Long-term Reserve Shutdown Date (DD-MON-YYYY):
3. Package Unit: Manufacturer: Detroit Diesel <span style="float: right;">Model Number: 7124-0300 &amp; 7124-9300</span>
4. Generator Nameplate Rating: 0.5 MW
5. Incinerator Information: Dwell Temperature: °F Dwell Time: seconds Incinerator Afterburner Temperature: °F

**Emissions Unit Operating Capacity**

1. Maximum Heat Input Rate: 7.34 mmBtu/hr
2. Maximum Incineration Rate: lbs/hr tons/day
3. Maximum Process or Throughput Rate: Units:
4. Maximum Production Rate: Units:
5. Operating Capacity Comment (limit to 200 characters): Information provided is for the diesel generator which will be limited to 400 hpy of operation. Other sources in this emission unit section may operate up to 8760 hours per year.

**Emissions Unit Operating Schedule**

Requested Maximum Operating Schedule:	
hours/day	days/week
weeks/yr	8760 hours/yr

**D. EMISSIONS UNIT REGULATIONS  
(Regulated Emissions Units Only)**

**Rule Applicability Analysis** (Required for Category II applications and Category III applications involving non Title-V sources. See Instructions.)

Not Applicable

**List of Applicable Regulations** (Required for Category I applications and Category III applications involving Title-V sources. See Instructions.)

Emissions Unit ID 3

F.A.C. 62-210.700(1) F.A.C. 62-210.700(4)	F.A.C. 62-210.700(6) F.A.C. 62-296.320(4)(b)	F.A.C. 62-296.320(4)(c) F.A.C. 62-297.310(2)(b)	F.A.C. 62-297.310(4)(a)2. F.A.C. 62-297.310(5) F.A.C. 62-297.310(7)(a)9. F.A.C. 62-297.310(8)
--	---	--	--



**E. EMISSION POINT (STACK/VENT) INFORMATION  
(Regulated Emissions Units Only)**

**Emission Point Description and Type**

Information for Facility-ID 1 Emission Unit # :3

1. Identification of Point on Plot Plan or Flow Diagram: Unregulated Emission Units
2. Emission Point Type Code (1,2,3,4) : 3
3. Descriptions of Emissions Points Comprising this Emissions Unit (limit to 100 characters):
4. ID Numbers or Descriptions of Emission Units with this Emission Point in Common: NA
5. Discharge Type Code (D, F, H, P, R, V, W) : H
6. Stack Height: 17 ft
7. Exit Diameter: 0.5 ft
8. Exit Temperature: 870 °F
9. Actual Volumetric Flow Rate: 2800 acfm
10. Percent Water Vapor: %
11. Maximum Dry Standard Flow Rate: dscfm
12. Nonstack Emission Point Height: ft
13. Emission Point UTM Coordinates: Zone: 17 East: 2960792 North: 594147
14. Emission Point Comment (limit to 200 characters): Information provided is for the emergency diesel generator. Note that there are 2 diesel engines and 2 exhaust stacks.

**F. SEGMENT (PROCESS/FUEL) INFORMATION  
(Regulated and Unregulated Emissions Units)**

**Segment Description and Rate:**

Information for Facility\_ID :/ Emission Unit #: 3 Segment #: 4

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Emergency Diesel Generator burning Number 2 fuel oil
2. Source Classification Code (SCC): 2-02-001-02
3. SCC Units: thousand gallons burned
4. Maximum Hourly Rate: 0.054
5. Maximum Annual Rate: 473
6. Estimated Annual Activity Factor:
7. Maximum Percent Sulfur: 0.5
8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 136
10. Segment Comment (limit to 200 characters):

**F. SEGMENT (PROCESS/FUEL) INFORMATION  
(Regulated and Unregulated Emissions Units)**

**Segment Description and Rate:**

Information for Facility\_ID :/ Emission Unit #: 3 Segment #: 2

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Above-ground tank #A - Working and breathing loss
2. Source Classification Code (SCC): 4-03-010-21
3. SCC Units: Thousand gallons transferred or handled
4. Maximum Hourly Rate:
5. Maximum Annual Rate:
6. Estimated Annual Activity Factor: 351577556
7. Maximum Percent Sulfur: 2.5
8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 152
10. Segment Comment (limit to 200 characters): Breathing loss = 14.17 lbs VOC / yr (per EPA Tanks2 program) Working loss = 64.25 lbs VOC / yr (per EPA Tanks2 program) Total estimated losses = 0.04 TPY, using estimated activity factor given above.

**F. SEGMENT (PROCESS/FUEL) INFORMATION  
(Regulated and Unregulated Emissions Units)**

**Segment Description and Rate:**

Information for Facility\_ID :/ Emission Unit #: 3 Segment #: 3

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Above-ground tank #B - Working and breathing loss
2. Source Classification Code (SCC): 4-03-010-21
3. SCC Units: Thousand gallons transferred or handled
4. Maximum Hourly Rate:
5. Maximum Annual Rate:
6. Estimated Annual Activity Factor: 351577556
7. Maximum Percent Sulfur: 2.5
8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 152
10. Segment Comment (limit to 200 characters): Breathing loss = 14.17 lbs VOC / yr (per EPA Tanks2 program) Working loss = 64.25 lbs VOC / yr (per EPA Tanks2 program) Total estimated losses = 0.04 TPY, using estimated activity factor given above.

**F. SEGMENT (PROCESS/FUEL) INFORMATION  
(Regulated and Unregulated Emissions Units)**

**Segment Description and Rate:**

Information for Facility\_ID :7 Emission Unit #: 3 Segment #: 4

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Above-ground tank #C - Working and breathing loss
2. Source Classification Code (SCC): 4-03-010-21
3. SCC Units: Thousand gallons transferred or handled
4. Maximum Hourly Rate:
5. Maximum Annual Rate:
6. Estimated Annual Activity Factor: 351560644
7. Maximum Percent Sulfur: 2.5
8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 152
10. Segment Comment (limit to 200 characters): Breathing loss = 37.22 lbs VOC / yr (per EPA Tanks2 program) Working loss = 123.36 lbs VOC / yr (per EPA Tanks2 program) Total estimated losses = 0.08 TPY, using estimated activity factor given above.

**F. SEGMENT (PROCESS/FUEL) INFORMATION  
(Regulated and Unregulated Emissions Units)**

**Segment Description and Rate:**

Information for Facility\_ID : / Emission Unit #: 3 Segment #: 5

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Above-ground tank #D - Working and breathing loss
2. Source Classification Code (SCC): 4-03-010-21
3. SCC Units: Thousand gallons transferred or handled
4. Maximum Hourly Rate:
5. Maximum Annual Rate:
6. Estimated Annual Activity Factor: 351983736
7. Maximum Percent Sulfur: 2.5
8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 152
10. Segment Comment (limit to 200 characters): Breathing loss = 66.18 lbs VOC / yr (per EPA Tanks2 program) Working loss = 174.40 lbs VOC / yr (per EPA Tanks2 program) Total estimated losses = 0.12 TPY, using estimated activity factor given above.

**G. EMISSIONS UNIT POLLUTANTS  
(Regulated Emissions Units Only)**

**Information for Facility\_ID: 1 Emission Unit #: 3**

1. Pollutant Emitted	2. Primary Control Device Code	3. Secondary Control Device Code	4. Pollutant Regulatory Code
NOX	NA	NA	NS

### I. VISIBLE EMISSIONS INFORMATION (Regulated Emissions Units Only)

Information for Facility-ID : / Emission Unit #: 3  
Visible Emissions Limitation #:

1. Visible Emissions Subtype: VE20
2. Basis for Allowable Opacity Code(R/O): OTHER <input type="checkbox"/> Rule <input type="checkbox"/> Other
3. Allowable Opacity: Normal Conditions: 20                          % Exceptional Conditions: 100    % Maximum Period of Excess Opacity Allowed: 60    min/hr
4. Method of Compliance Code:
5. Visible Emissions Comment (limit to 200 characters): The equipment in this EU may be subject to the general visible emission standard, if they emit PM. Rule 62-210.700(1) allows 2 hrs / 24 hrs of excess emissions for startup, shutdown & malfunction.



**K. PREVENTION OF SIGNIFICANT DETERIORATION (PSD) INCREMENT  
TRACKING INFORMATION  
(Regulated and Unregulated Emissions Units)**

Information for Facility-ID : 1 Emission Unit # : 3

**PSD Increment Consumption Determination**

1. Increment Consuming for Particulate Matter or Sulfur Dioxide?

If the emissions unit addressed in this section emits particulate matter or sulfur dioxide, answer the following series of questions to make a preliminary determination as to whether or not the emissions unit consumes PSD increment for particulate matter or sulfur dioxide. Check the first statement, if any, that applies and skip remaining statements.

Select (1-5) : 5

- [ 1 ] The emissions unit is undergoing PSD review as part of this application, or has undergone PSD review previously, for particulate matter or sulfur dioxide. Final determination is that emissions unit consumes increment.
- [ 2 ] The facility addressed in this application is classified as an EPA major source pursuant to paragraph (c) of the definition of "major source of air pollution" in Chapter 17-213, F.A.C., and the emissions unit addressed in this section commenced (or will commence) construction after January 6, 1975. Preliminary determination is that baseline emissions are zero, and emissions unit consumes increment.
- [ 3 ] The facility addressed in this application is classified as an EPA major source, and the emissions unit began initial operation after January 6, 1975, but before December 27, 1977. Preliminary determination is that baseline emissions are zero, and emissions unit consumes increment.
- [ 4 ] For any facility, the emissions unit began (or will begin) initial operation after December 27, 1977. Preliminary determination is that baseline emissions are zero, and emissions unit consumes increment.
- [ 5 ] None of the above apply. If so, the baseline emissions of the emissions unit are nonzero. In such case, additional analysis, beyond the scope of this application, is needed to determine whether changes in emissions have occurred (or will occur) after the baseline date that may consume or expand increment.

2. Increment Consuming for Nitrogen Dioxide?

If the emissions unit addressed in this section emits nitrogen oxides, answer the following series of questions to make a preliminary determination as to whether or not the emissions unit consumes PSD increment for nitrogen dioxide. Check first statement, if any, that applies and skip remaining statements.

Select (1-5) : 5

- [ 1 ] The emissions unit addressed in this section is undergoing PSD review as part of this application, or has undergone PSD review previously, for nitrogen dioxide. Final determination is that emissions unit consumes increment.
  
- [ 2 ] The facility addressed in this application is classified as an EPA major source pursuant to paragraph (c) of the definition of "major source of air pollution" in Chapter 17-213, F.A.C., and the emissions unit addressed in this section commenced (or will commence) construction after February 8, 1988. Preliminary determination is that baseline emissions are zero, and emissions unit consumes increment.
  
- [ 3 ] The facility addressed in this application is classified as an EPA major source, and the emissions unit began initial operation after February 8, 1988, but before March 28, 1988. Preliminary determination is that baseline emissions are zero, and emissions unit consumes increment.
  
- [ 4 ] For any facility, the emissions unit began (or will begin) initial operation after March 28, 1988. Preliminary determination is that baseline emissions are zero, and emissions unit consumes increment.
  
- [ 5 ] None of the above apply. If so, the baseline emissions of the emissions unit are nonzero. In such case, additional analysis, beyond the scope of this application, is needed to determine whether changes in emissions have occurred (or will occur) after the baseline date that may consume or expand increment.

3. Increment Consuming/Expanding Code: (C, E, U- unkown):

PM	U
SO2	U
NO2	U

4. Baseline Emissions:

PM	lbs/hr	tons/yr
SO2	lbs/hr	tons/yr
NO2	tons/yr	

5. PSD Comment (limit to 200 characters):  
The Emergency Diesel Generator was constructed in June 1978.

**L. EMISSIONS UNIT SUPPLEMENTAL INFORMATION  
(Regulated Emissions Units Only)**

Information for Facility-ID : / Emission Unit # : 3

**Supplemental Requirements for All Applications**

1. Process Flow Diagram : PRVU3_1.bmp Attached Document ID / Not Applicable / Waiver Requested
2. Fuel Analysis or Specification: PRVU3_2.txt Attached Document ID / Not Applicable / Waiver Requested
3. Detailed Description of Control Equipment : NA Attached Document ID / Not Applicable / Waiver Requested
4. Description of Stack Sampling Facilities : NA Attached Document ID / Not Applicable / Waiver Requested
5. Compliance Test Report : NA Attached Document ID / Previously submitted, Date / Not Applicable
6. Procedures for Startup and Shutdown : PRVU3_6.txt Attached Document ID / Not Applicable
7. Operation and Maintenance Plan : NA Attached Document ID / Not Applicable
8. Supplemental Information for Construction Permit Application : NA Attached Document ID / Not Applicable
9. Other Information Required by Rule or Statute : NA Attached Document ID / Not Applicable

**Additional Supplemental Requirements for Category I Applications Only**

10. Alternative Methods of Operation : NA Attached Document ID / Not Applicable
11. Alternative Modes of Operation (Emissions Trading) : NA Attached Document ID / Not Applicable
12. Identification of Additional Applicable Requirements : NA Attached Document ID / Not Applicable
13. Enhanced Monitoring Plan : NA Attached Document ID / Not Applicable
14. Acid Rain Permit Application  Acid Rain Application - Phase II (Form No. 17-210.900(1)(a)) Attached Document ID: NA  Repowering Extension Plan (Form No. 17-210.900(1)(b)) Attached Document ID: NA  New Unit Exemption (Form No. 17-210.900(1)(c)) Attached Document ID: NA  Retired Unit Exemption (Form No. 17-210.900(1)(c)) Attached Document ID: NA  Not Applicable

**ATTACHMENT PRV - FW**

**LIST OF UNREGULATED TRIVIAL & DE MINIMIS EMISSION UNITS**

Following are several pages of unregulated trivial and de minimis emission units and activities at the facility. The trivial activities identified in this application are provided for information only and are identified as examples of, but not limited to, the trivial activities identified by the Division of Air Resources Management's (DARM) guidance. It is understood that such activities do not have to be included in the with Title V Application. The trivial activities identified herein are consistent, in terms of amounts of emissions and types, with those activities listed in DARM's guidance.

Pursuant to Rule 62-210.300(3)(b)1., notice is herein provided that the emissions units listed below are not subject to a permit issued by the Department of Environmental Protection and are exempt from permitting until a final determination is made under the Title V permitting requirements (Rule 62-213 F.A.C.). These units would not have triggered review under Rules 62-212.400 or 62-212.500 or any new source performance standard listed in Rule 62-204.800 F.A.C..

ATTACHMENT PRV - FW

LIST OF UNREGULATED TRIVIAL & DE MINIMIS EMISSION UNITS

UNITS 3 & 4 BOILER/STEAM GENERATOR POWER BLOCK

Steam Systems

Steam Drum Relief Valves w/Silencers

Steam Drum - 1½" Maintenance Valves

Super Heater Inlet Header - 1 ½" Maintenance Valves

Main Steam Relief Valves w/Silencers

Economizer Inlet Header - 1" Maintenance Vents

Desuperheater - 4" Relief Valve w/Silencer & Exhaust Hood

Extraction Heaters Relief Valves

Extraction Heaters Maintenance Vents

Continuous Blowdown Flash Tank Relief Valve

Blowdown Flash Pipe - 14 Vent w/Silencer & Exhaust Hood

Steam Seal Regulator Relief Valves

Hogging Ejector 8" Vent w/Silencer & Exhaust Hood

Priming Ejector 8" Vent w/Silencer & Exhaust Hood

After Condenser Maintenance Vent

Priming Ejector Relief Valve

Main Steam at Stop Valves - 1½" Maintenance Vents

Boiler Feed, Condensate & Heater Drains

Extraction Heater - ¾" Feedwater Maintenance Vents

Extraction Heaters - ¾" Feedwater Relief Valves

Feedwater at Boiler Feed Pumps - ¾" Safety Valves

Condensate Collecting Cooler - ¾" Vent

Flash Tank - 3" Relief Valve

Vent Condenser - ¾" Maintenance Vent

ATTACHMENT PRV - FW

LIST OF UNREGULATED TRIVIAL & DE MINIMIS EMISSION UNITS

Boiler Feed, Condensate & Heater Drains (continued)

Condensate Storage Tank - Continuous Vent

Gland Steam Condenser 8" Continuous Vent

Gland Steam Condenser 1" Relief Valve

After Condenser Maintenance Vent

Intercondenser Maintenance Vent

Hydrazine Pumps Relief Valve

Phosphate Pumps Relief Valves

Cooling Water

Cooling Water Surge Tank - 3 Continuous Vent

Turbine Lube Oil Coolers - Maintenance Vent

Evaporator Relief Valve

Evaporator Continuous Vent

Fuel Oil

268,000 BBL Storage Tank 12" Vent

150,000 BBL Storage Tank Vent

55,000 BBL Storage Tank Vent

55,000 BBL Storage Tank Vent

4,500 BBL Metering Tank Vent

Diesel Generator Fuel Tank (1500 Gal) 2" Vents

Fuel Oil Additive Tanks (3700 Gal & 1700 Gal)

Burner Booster Pumps - Maintenance Vents

Oil Recovery Blow Back Tank - Relief Valve

Oil Recovery Blow Back Tank - 1" Maintenance Vent

Service Air at Blow Back Tank - Maintenance Vent



ATTACHMENT PRV - FW

LIST OF UNREGULATED TRIVIAL & DE MINIMIS EMISSION UNITS

Lube Oil

Generator Loop Seal Tank - 4" Continuous Vent w / Exhaust Head

Oil Mist Eliminator - 4" Vapor Extractor

Lube Oil Coolers Maintenance Vent

Lube Oil Reservoir Filter Vent

Gas burner header vent valve

Lube Oil Filter-Filter Vent

Lube Oil Filter Water Ejector

Gas Supply

Vent Valve

Ignition GasPropane Tank (500 Gal)

C.E.M. Equipment

Monitoring Gases

Lime Slurry, Caustic Wash & Instrument Air

Lime Slurry Mixing Tank (2000 Gal)

Lime Slurry Service tank

Caustic Wash Storage Tank - (3000 Gal.)- 2" Vent

Caustic Wash Mixing Tank (1690 Gal)

Instrument Air Tanks - Relief Valves

Air Compressors Relief Valves

Separator Relief Valves

Water Treatment Equipment (abandoned in place)

Caustic Service Tank - (4900 Gal) -2" Vent

Sodium Bisulfite Storage Tank (5000 Gal )-4" Vent

Carbon Purifier- 1/2" Vent

Sand Filter- 1/2" Vent

Waste Neutralizing T.E.T.F. ( 34,000 Gal Tank)- 8" Vent

ATTACHMENT PRV - FW

LIST OF UNREGULATED TRIVIAL & DE MINIMIS EMISSION UNITS

Water Treatment (continued)

Elevated Water Storage Tank Vent

Waste Neutralizing Cement Basin (10,771 Gal)

City Water Basin (94,764 Gal)

Demineralizer Recovery Basin (8025 Gal)

Soda Ash Service Tank (3165 Gal)

Soda Ash Mixing Tank (1690 Gal)

Waste Water & Basins

Oily Waste Water Sumps & Separator

Solids Settling Basins

Miscellaneous Buildings Kitchen Exhaust

Training & Conference Facility

Service Bldg.

Miscellaneous Buildings H.V.A.C. (Cooling/Heating)

P.G.B.U. Training Bldg.

Conference Facility

Stores Warehouse

Doc. Control Bldg.

Water Treatment Lab

Hightower Storage Bldg.

Maintenance Warehouse Office

Switchyard Control Bldg.

Dry Storage Warehouse

Operations/Overhaul Bldg.

Service Bldg.

ATTACHMENT PRV - FW

LIST OF UNREGULATED TRIVIAL & DE MINIMIS EMISSION UNITS

Miscellaneous Buildings Vent/Exhaust Systems

Conference Facility

Stores Warehouse

Doc. Control Bldg.

Paint/Lube Oil Bldg.

Emergency Spill Bldg.

Miscellaneous Buildings Vent/Exhaust Systems (Continued)

Lab/Water Treat. Bldg.

Chem. Storage Bldg.

Chlorination Bldg.

F.O. Pump Pit Enclosure

Maint. Warehouse Office

Lube Oil Storage Bldg.

Hazardous Waste Drum Storage Bldg.

Switchyard Control Bldg.

Operations/Overhaul Bldg.

Service Bldg.

Control Bldg. - Relay & Battery Rooms

Miscellaneous Buildings Sanitary Vents/Stacks

Conference facility

Stores Warehouse

Doc. Control Bldg.

Recreation Pavilion

Operations/Overhaul Bldg.

Service Building

Control Building

P.G.B.U. Training Annex

ATTACHMENT PRV - FW

LIST OF UNREGULATED TRIVIAL & DE MINIMIS EMISSION UNITS

Miscellaneous Activities

Home heating and comfort heating with a gross maximum heat output of less than one million BTU/hr.

Internal combustion engines in boats, aircraft and vehicles used for transportation of passengers or freight

Vacuum pumps used in laboratory operations Various

Equipment used for steam cleaning

Belt or drum sanders having a total sanding surface of five square feet or less and other equipment used exclusively on wood or plastics or their products having a density of 20 pounds per cubic foot or more.

Equipment used exclusively for space heating, other than boilers

Laboratory equipment used exclusively for chemical or physical analysis

Bulk Gas

Storage Cylinders

Miscellaneous Activities

Plant Grounds Maintenance

Routine Maintenance/Repair Activities

Non-Halogenated Solvent Cleaning Operations

Use of spray cans and solvents for routine maintenance activities

Internal Combustion Engines Which Drive Compressors, Generators, Water Pumps or other Auxiliary Equipment

Transformers, Switches and Switchgear, Processing & Venting

Electrically Heated Equipment Used for Heat Treating, Tracing, Drying, Soaking, Case Hardening or Surface Conditioning

Air Compressors and Centrifuges Used for Compressing Air

Storage of Product in Sealed Containers

Miscellaneous Mobile Vehicle Operation

Cars, Light Trucks, Heavy duty Trucks, Back Hoes, Tractors, Forklifts, Cranes, Etc.

ATTACHMENT PRV - FW

LIST OF UNREGULATED TRIVIAL & DE MINIMIS EMISSION UNITS

Miscellaneous Mobile Equipment Operation

Compressors, Chain Saws, Small Generators, (<100KW) Welding Machines Electric Saws & Drills, Etc.

Laundry dryers, extractors, or tumblers for fabrics cleaned with only water solutions of bleach or detergents


Fire & Safety Equipment

Surface coating facilities in ozone attainment areas (provided that 6.0 gallons of coatings per day are applied)

Degreasing units using heavier-than-air vapors exclusively, except any such unit using or emitting any substance classified as a hazardous air pollutant

Use of solvent and spray cans for maintenance activities

WALKDOWN INFORMATION			TECHNICAL ACCEPTANCE		
ORG	BY	DATE	ORG	BY	DATE
AS-BUILT INFORMATION			ENGINEERING ORGANIZATION		
ORG	BY	DATE			



BAR CODE

	SYSTEM YY	DISCIPLINE M	PLANT/UNIT RIVIERA PLANT
	SCALE N/A	CAD FILE NAME RV002858	TITLE EMISSION UNIT FLOW DIAGRAM EMERGENCY DIESEL GENERATOR ATTACHMENT NO. EU3
	DRAWING SIZE A (8.5X11)	FPL ARCHIVE NAME RV002858	

0	7/24/95	ISSUED FOR TITLE V PERMIT	PWB	PWB	CSP	CSP	ETS
REV	DATE	REVISION DESCRIPTION	BY	CH	COR	APR	ORG

DRAWING NUMBER	SHEET	REV
PRV3-M0108-YY	1 OF 1	0

**Attachment PRVU3\_6.txt**

**Procedures for Startup / Shutdown**

The emergency diesel generator is the main backup power supply component for the fossil steam boiler generating units. The function of the emergency diesel generator is to supply electric power to key power plant equipment during emergency loss-of-power situations. This equipment is typically test-run on a monthly basis to ensure that it will function properly when needed in an emergency.

Startup for the emergency diesel generator begins with actuating a switch which sends an electric signal to a starter motor on the diesel engine which "turns over" the diesel engine until ignition of the diesel fuel commences.

Shutdown is performed when the normal electric power supply to plant equipment is restored. Shutdown is performed by shutting off the diesel fuel supply to the emergency diesel generator.

Best Operating Practices include proper maintenance of the diesel engine on the generating unit, and monitoring the visible emissions from the emergency diesel generator to ensure that the opacity limitation is not exceeded. All efforts to minimize both the level and duration of excess emissions are undertaken.

Attachment PRVU3\_2.txt

Fuel Analysis  
No. 2 Distillate oil (typical)<sup>3</sup>

<u>Parameter</u>	<u>Typical value</u>	<u>Specifications</u>
API gravity (@ 60 F)	35.0 <sup>2</sup>	30 - 40 <sup>1</sup>
Heat content (MBtu/bbl)	5,700 - 5,800 <sup>2</sup>	none
% sulfur	0.3 - 0.5 <sup>1</sup>	0.5 maximum <sup>1</sup>
% nitrogen	no specification	none
% ash	<0.01 <sup>2</sup>	0.01 <sup>1</sup>

Footnotes:

(1) Data taken from FPL fuel specifications.

(2) Data taken from laboratory analysis.

(3) The values are "typical" based upon the following:

- Information gathered by FPL through laboratory analysis, and
- FPL's fuel purchasing specifications. It should be noted that the analytical results obtained from grab samples taken at any given time may vary from those listed.