

Sheplak, Scott

From: Vielhauer, Trina
Sent: Monday, July 06, 2009 12:16 PM
To: Sheplak, Scott; Holtom, Jonathan
Subject: FW: Emergency Generators - FPL West County Energy Center- Hurricane Shelter

From: Kirwan, Janet [mailto:Janet.Kirwan@fpl.com]
Sent: Monday, July 06, 2009 9:35 AM
To: Vielhauer, Trina
Cc: Linkiewicz, Barbara P; Washington, Kevin
Subject: Emergency Generators - FPL West County Energy Center- Hurricane Shelter

Ms Vielhauer,

Good Morning! Below is a copy of an email sent to your office on Thursday July 2, 2009 by Kevin Washington. In his email, Mr. Washington is restating the same information contained in the FPL West County Energy Center Site Certification Application, Amendment Application to include the Hurricane Shelters. FPL received the amendment on July 19, 2009. The purpose of this email is to connect the two documents in your office and to avoid any confusion at a later date. If you have any questions please feel free to contact me at 561-691-2820.

Thank you again for your time and consideration,

Jan Kirwan
Senior Environmental Specialist
Florida Power & Light Company
561-691-2820

From: Washington, Kevin
To: Vielhauer, Trina <Trina.Vielhauer@dep.state.fl.us>; scott.sheplak@dep.state.fl.us
<scott.sheplak@dep.state.fl.us>; James_Stormer@doh.state.fl.us <James_Stormer@doh.state.fl.us>
Sent: Thu Jul 02 10:30:41 2009
Subject: EMERGENCY GENERATORS - FPL WEST COUNTY ENERGY CENTER

Trina, Scott, & Jim,

Emergency Generators have been installed at the location referenced above as part of FPL's Hurricane Hardening program. The generators provide power to two small "safe rooms" constructed for operating employees to use in the event of a significant storm. Each safe room will be powered by two 30k W Liquid Propane (LP) fired emergency generators (one primary and one back up). Generator output voltage will be 120/240V, 1-phase and will not be used to generate electricity for sale to FPL customers.

Location	Make & Model	Ignition	HP	Rated
KW Year Built	RPM	Rule Applicability		

7/6/2009

West County Energy Center A & B
30 2006 3600

Guardian 00522-0
None
by Generac

Spark 40

The generators are categorically exempt from permitting as provided by Rule 62-210.300(3)(a). They are also exempt from 40 CFR Part 60 Subparts JJJJ due to their manufacture date (2006), and from ZZZZ due to their size (<500 Hp).

When the Title V permit is applied for, both generator packages will be added as insignificant or unregulated sources.

If you have any questions or require additional information feel free to contact me via return E:mail, or at (561) 691-2877.

Thank you,

Kevin Washington
Project Manager
FPL Environmental Services
(561) 691-2877
kevin_washington@fpl.com