

# Florida Department of Environmental Regulation

Twin Towers Office Bldg. • 2600 Blair Stone Road • Tallahassee, Florida 32399-2400

Bob Martinez, Governor

Dale Twachtman, Secretary

John Shearer, Assistant Secretary

December 8, 1989

Mr. Joseph N. Conover  
Ogden Martin Systems, Inc.  
40 Lane Road, CN 2615  
Fairfield, New Jersey 07007-2615


Dear Mr. Conover:

Re: Pasco County Solid Waste Resource Recovery Facility,  
PSD-FL-127

The Department has reviewed your letter dated September 20, 1989, concerning the permit changes required to substitute natural gas as auxiliary fuel with propane, at the above referenced facility.

The use of propane as auxiliary fuel is acceptable to the Department. No permit modification is required in this instance for the PSD permit, or the Conditions of Certification.

Sincerely,

  
C. H. Fancy, P.E.  
Chief  
Bureau of Air Regulation

CHF/PR/plm

cc: H. Oven, DARM  
B. Thomas, SW District  
W. Aronson, EPA  
C. Shaver, NPS  
J. Gallagher, Pasco Co.

# OGDEN MARTIN SYSTEMS, INC.

40 LANE ROAD  
CN 2615  
FAIRFIELD, NEW JERSEY 07007-2615  
(201) 882-9000



September 20, 1989

RECEIVED

SEP 28 1989

DER-BAQ

Florida Department of Environmental Regulation  
Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, FL 32399-2400

Attention: Mr. C.H. Fancy, Deputy Bureau Chief

**SUBJECT: PASCO COUNTY SOLID WASTE RESOURCE RECOVERY FACILITY  
PSD - FL - 127**

Dear Mr. Fancy:

Specific condition 1.F. of the above referenced PSD Permit for the Pasco County Solid Waste Resource Recovery Facility states that only natural gas be utilized to fuel the auxiliary burners. Subsequent to the PSD application and the power plant site certification applications, natural gas has been determined to be unavailable to this facility. As a result, Ogden Martin has been directed by the county to substitute natural gas with propane for the auxiliary burners. Ogden Martin understands with discussions to Barry Andrews that these two fuels can be used interchangeably without permit modification according to current FDER Policy.

Please verify in writing that the above change in auxiliary fuel is acceptable and that no permit modification is required.

If you have any questions regarding this matter, please do not hesitate to contact the undersigned or our resident construction manager, Mr. Paul Hauck at (813) 856-7697.

Sincerely,

OGDEN MARTIN SYSTEMS OF PASCO, INC.

Joseph N. Conover  
Project Manager

LB:rj/2-96

cc: J. Gallagher - Pasco County  
D. Bramlett - Pasco County  
D. Strobridge - CDM  
P. Hauck - OMSP

*copied to [unclear]  
[unclear]  
[unclear]  
[unclear]  
[unclear]  
[unclear]  
[unclear]*

**OGDEN MARTIN SYSTEMS  
OF PASCO, INC.**

40 LANE ROAD  
CN 2615  
FAIRFIELD, NEW JERSEY 07007-2615



**Mr. C. H. Fancy - Deputy Bureau Chief  
Florida Department of Environmental Regulation  
Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, FL 32399-2400**

