

#### Farzie Shelton, ChE; REM

Associate GM Technical Support

April 9, 2014

Mr. Jeff Koerner, Environmental Administrator Office of Permitting and Compliance Division of Air Resource Management Florida Department of Environmental Protection 2600 Blair Stone Road, MS#5500 Tallahassee, FL 32399

RE:

Lakeland Electric - C.D. McIntosh, Jr. Power Plant (ID No. 1050004)

Application for Minor Source Air Construction Permit for Deletion of Sulfuric Acid Mist Testing Requirement for Unit 3

Dear Jeff:

We are submitting this minor source air construction permit application for deletion of the sulfuric acid mist (SAM) testing requirement related to increasing the percent sulfur in coal for Unit 3 (Emissions Unit 006) at the C.D. McIntosh, Jr. Power Plant. This testing requirement was established by Air Construction Permit No. 1050004-026-AC (Condition No. 15). In addition, we are requesting that the Title V Air Operation Permit No. 1050004-033-AV be concurrently revised to remove Specific Condition No. D.35, which is established by Condition No. 15 of permit No. 1050004-026-AC.

Based on the previous evaluation of numerous SAM test results, it can be reasonably assured that SAM emissions will still be comfortably below the baseline actual emissions of 136 TPY even with the potential scenario of 3.4% coal sulfur content. As a result, further SAM testing should not be necessary and therefore we request the deletion of this requirement (please see Appendix A in support of this application).

Enclosed please find the application signed by Mr. Ken Kosky of Golder Associates and certified by Mr. Tony Candales, Lakeland Electric's Responsible Official.

As always, we appreciate all the help you can give us in this matter. If you have any questions regarding the enclosed, please do not hesitate to contact me or Nedin Bahtic at (863) 834-8180.

Sincerely.

Farzie Shelton

Enclosure

City of Lakeland • Department of Electric Utilities



April 7, 2014 14-02857

Mr. Jeff Koerner, Environmental Administrator Office of Permitting and Compliance Division of Air Resource Management Florida Department of Environmental Protection 2600 Blair Stone Road Tallahassee, FL 32399

**RE: MCINTOSH POWER PLANT** 

AIR CONSTRUCTION PERMIT APPLICATION
REMOVAL OF SAM TESTING REQUIREMENTS FOR UNIT 3 (EU006)

Dear Jeff:

On behalf of Lakeland Electric (LE), Golder is pleased to submit this Air Construction (AC) permit application for the removal of sulfuric acid mist (SAM) testing requirement from AC permit No. 1050004-026-AC (Specific Condition No. 15), which is the basis for Condition D.35 of Permit No. 1050004-033-AV. This permit condition requires LE to re-test for SAM within 45 days if a fuel blend with a sulfur content that is 0.20% sulfur by weight higher than the maximum sulfur content previously tested is fired. Previous testing was conducted using a maximum of 1.72% sulfur coal and therefore, re-testing will be required for firing higher than 1.92% sulfur coal.

LE is currently planning to use coal with higher than 1.92% sulfur by weight. LE has conducted several SAM tests in the past and based on the evaluation of the test results, it can be reasonably assured that even with 3.4% sulfur coal there will still be an overall decrease in SAM emissions compared to the baseline actual emissions of 136 TPY. As a result, further SAM testing should not be required. Documents supporting the previous SAM testing evaluation are presented as an attachment to the AC permit application package.

If you have any comments or questions, please feel free to contact me at (352) 336-5600 or at ken kosky@golder.com.

Sincerely,

**GOLDER ASSOCIATES INC.** 

Kennard F. Kosky, P.E.

Principal







# APPLICATION FOR AIR CONSTRUCTION PERMIT AND REVISED TITLE V AIR OPERATION PERMIT

Lakeland Electric C.D. McIntosh, Jr. Power Plant Lakeland, Florida

Prepared For: Lakeland Electric

501 East Lemon Street Lakeland, FL 33801-5079

**Submitted By:** Golder Associates Inc.

6026 NW 1st Place

Gainesville, FL 32607 USA

**Distribution:** Florida Department of Environmental Protection – 4 copies

Lakeland Electric – 2 copies Golder Associates Inc. – 2 copies

April 2014 14-02857

A world of capabilities delivered locally







# Department of Environmental Protection

# **Division of Air Resource Management**

#### **APPLICATION FOR AIR PERMIT - LONG FORM**

#### I. APPLICATION INFORMATION

**Air Construction Permit** – Use this form to apply for an air construction permit:

- For any required purpose at a facility operating under a federally enforceable state air operation permit (FESOP) or Title V air operation permit;
- For a proposed project subject to prevention of significant deterioration (PSD) review, nonattainment new source review, or maximum achievable control technology (MACT);
- To assume a restriction on the potential emissions of one or more pollutants to escape a requirement such as PSD review, nonattainment new source review, MACT, or Title V; or
- To establish, revise, or renew a plantwide applicability limit (PAL).

#### **Air Operation Permit** – Use this form to apply for:

- An initial federally enforceable state air operation permit (FESOP); or
- An initial, revised, or renewal Title V air operation permit.

#### To ensure accuracy, please see form instructions.

#### **Identification of Facility**

1.	Facility Owner/Company Name: Lakeland Electric					
2.	Site Name: C. D. McIntosh, Jr. Power Plant					
3.	Facility Identification Number: 1050004					
4.	Facility Location					
	Street Address or Other Locator: 3030 East	Lak	e Parker Drive			
	City: Lakeland County: F	olk		Zip Code: <b>33805</b>		
5.	Relocatable Facility?	6.	<b>Existing Title</b>	V Permitted Facility?		
	☐ Yes ☐ No		⊠ Yes	□ No		
Ap	oplication Contact					
1.	Application Contact Name: Ms. Farzie Shell Support	ton,	Associate Gen	eral Manager of Technical		
2.	Application Contact Mailing Address					
	Organization/Firm: Lakeland Electric					
	Street Address: 501 East Lemon Street					
	City: Lakeland Sta	ite:	FL	Zip Code: <b>33801-5079</b>		
3.	Application Contact Telephone Numbers					
	Telephone: (863) 834 - 6603 ext.		Fax: (863) 834	- 6362		
4.	Application Contact E-mail Address: farzie	.she	lton@lakelande	electric.com		
Ap	Application Processing Information (DEP Use)					
1.	Date of Receipt of Application:	3	B. PSD Numbe	r (if applicable):		

2. Project Number(s):

4. Siting Number (if applicable):

#### **Purpose of Application**

Turpose of rippireusion					
This application for air permit is being submitted to obtain: (Check one)					
Air Construction Permit					
☐ Air construction permit.					
☐ Air construction permit to establish, revise, or renew a plantwide applicability limit (PAL).					
☐ Air construction permit to establish, revise, or renew a plantwide applicability limit (PAL), and separate air construction permit to authorize construction or modification of one or more emissions units covered by the PAL.					
Air Operation Permit					
☐ Initial Title V air operation permit.					
☐ Title V air operation permit revision.					
☐ Title V air operation permit renewal.					
☐ Initial federally enforceable state air operation permit (FESOP) where professional engineer (PE) certification is required.					
☐ Initial federally enforceable state air operation permit (FESOP) where professional engineer (PE) certification is not required.					
Air Construction Permit and Revised/Renewal Title V Air Operation Permit (Concurrent Processing)					
☑ Air construction permit and Title V permit revision, incorporating the proposed project.					
☐ Air construction permit and Title V permit renewal, incorporating the proposed project.					
Note: By checking one of the above two boxes, you, the applicant, are requesting concurrent processing pursuant to Rule 62-213.405, F.A.C. In such case, you must also check the following box:					
☑ I hereby request that the department waive the processing time requirements of the air construction permit to accommodate the processing time frames of the Title V air operation permit.					
Application Comment					
Minor course of construction normit amplication to request removal of Culturis Acid Mint (CAM)					

Minor-source air construction permit application to request removal of Sulfuric Acid Mist (SAM) performance test requirements for Unit 3 (EU006) at the McIntosh Jr. Power Plant, established by Air Construction Permit No. 1050004-26-AC (Condition No. 15) and contained in Specific Condition D.35 of Title V air operating permit No. 1050004-33-AV.

# **Scope of Application**

Emissions Unit ID Number	Description of Emissions Unit	Air Permit Type	Air Permit Processing Fee
006	McIntosh Unit 3- Fossil Fuel Fired Steam Generator	AC1B	N/A
	Processing Fee		
Check one:	Attached - Amount: \$	Not Applicable	

# **Owner/Authorized Representative Statement**

Complete if applying for an air construction permit or an initial FESOP.

1.	Owner/Authorized Representat	ive Name :				
2.	Owner/Authorized Representative Mailing Address Organization/Firm:					
	Street Address:					
	City:	State:		Zip Code:		
3.	Owner/Authorized Representat	ive Telephone N	umbers			
	Telephone: ( )	ext.	Fax:	( )		
4.	Owner/Authorized Representat	ive E-mail Addre	ess:			
5.	Owner/Authorized Representat	ive Statement:				
	I, the undersigned, am the owner or authorized representative of the corporation, partnership, or other legal entity submitting this air permit application. To the best of my knowledge, the statements made in this application are true, accurate and complete, and any estimates of emissions reported in this application are based upon reasonable techniques for calculating emissions. I understand that a permit, if granted by the department, cannot be transferred without authorization from the department.					
	Signature		D	ate		

#### **Application Responsible Official Certification**

Complete if applying for an initial, revised, or renewal Title V air operation permit or concurrent processing of an air construction permit and revised or renewal Title V air operation permit. If there are multiple responsible officials, the "application responsible official" need not be the "primary responsible official."

r						
<ol> <li>Application Responsible Official Name:</li> <li>Mr. Tony Candales, Associate General Manager of Production</li> </ol>						
2. Application Responsible Official Qualification (Check one or more of the following options, as applicable):						
<ul> <li>□ For a corporation, the president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision-making functions for the corporation, or a duly authorized representative of such person if the representative is responsible for the overall operation of one or more manufacturing, production, or operating facilities applying for or subject to a permit under Chapter 62-213, F.A.C.</li> <li>□ For a partnership or sole proprietorship, a general partner or the proprietor, respectively.</li> <li>☑ For a municipality, county, state, federal, or other public agency, either a principal executive</li> </ul>						
officer or ranking elected official.  The designated representative at an Acid Rain source or CAIR source.						
3. Application Responsible Official Mailing Address Organization/Firm: City of Lakeland						
Street Address: 501 East Lemon Street						
City: Lakeland State: FL Zip Code: 33801-5079						
4. Application Responsible Official Telephone Numbers						
Telephone: (863) 834-6559 ext. Fax: (863) 834-6363						
Telephone: (863) 834-6559 ext. Fax: (863) 834-6363  5. Application Responsible Official E-mail Address: Tony.Candales@lakelandelectric.com						
5. Application Responsible Official E-mail Address: Tony.Candales@lakelandelectric.com						

DEP Form No. 62-210.900(1) – Form Effective: 03/11/2010

#### **Professional Engineer Certification**

1.	Professional Engineer Name: Kennard F. Kosky
	Registration Number: 14996
2.	Professional Engineer Mailing Address
_,	Organization/Firm: Golder Associates Inc.**
	Street Address: 6026 NW 1st Place
	City: Gainesville State: FL Zip Code: 32607
3.	Professional Engineer Telephone Numbers
	Telephone: (352) 336-5600 ext. 21156 Fax: (352) 336-6603
4.	Professional Engineer E-mail Address: kkosky@golder.com
5.	Professional Engineer Statement:
	I, the undersigned, hereby certify, except as particularly noted herein*, that:
	(1) To the best of my knowledge, there is reasonable assurance that the air pollutant emissions unit(s) and the air pollution control equipment described in this application for air permit, when properly operated and maintained, will comply with all applicable standards for control of air pollutant emissions found in the Florida Statutes and rules of the Department of Environmental Protection; and
	(2) To the best of my knowledge, any emission estimates reported or relied on in this application are true, accurate, and complete and are either based upon reasonable techniques available for calculating emissions or, for emission estimates of hazardous air pollutants not regulated for an emissions unit addressed in this application, based solely upon the materials, information and calculations submitted with this application.
	(3) If the purpose of this application is to obtain a Title V air operation permit (check here \( \scale \), if so), I further certify that each emissions unit described in this application for air permit, when properly operated and maintained, will comply with the applicable requirements identified in this application to which the unit is subject, except those emissions units for which a compliance plan and schedule is submitted with this application.
	(4) If the purpose of this application is to obtain an air construction permit (check here $\boxtimes$ , if so) or concurrently process and obtain an air construction permit and a Title $V$ air operation permit revision or renewal for one or more proposed new or modified emissions units (check here $\boxtimes$ , if so), I further certify that the engineering features of each such emissions unit described in this application have been designed or examined by me or individuals under my direct supervision and found to be in conformity with sound engineering principles applicable to the control of emissions of the air pollutants characterized in this application.
	(5) If the purpose of this application is to obtain an initial air operation permit or operation permit revision or renewal for one or more newly constructed or modified emissions units (check here , if so), I further certify that, with the exception of any changes detailed as part of this application, each such emissions unit has been constructed or modified in substantial accordance with the information given in the corresponding application for air construction permit and with all provisions contained in such permit.  Signature  (seal)

\* Attach any exception to certification statement.

\*\*Board of Professional Engineers Certificate of Authorization #00001670.

DEP Form No. 62-210.900(1) – Form

Effective: 03/11/2010

#### II. FACILITY INFORMATION

#### A. GENERAL FACILITY INFORMATION

#### **Facility Location and Type**

1.	Facility UTM Coordinates			Facility Latitude/Lo	ongi	tude
	Zone <b>17</b> East (km) <b>409.0</b>			Latitude (DD/MM/	SS)	28/04/50
	North (km) 3,106.2			Longitude (DD/MN	I/SS	S) 81/55/32
3.	Governmental 4. Facility Status		5.	Facility Major	6.	Facility SIC(s):
	Facility Code: Code:			Group SIC Code:		
	0	Α		49		4911
7	E-The Comment					

7. Facility Comment:

The McIntosh Power Plant consists of three fossil fuel-fired steam generators (FFSG), two diesel powered generators, one gas turbine peaking unit, and one combined-cycle combustion turbine (Unit 5). FFSG Unit 1 is fired with No.6 fuel oil, natural gas, and on-specification used oil. FFSG Unit 2 is fired with natural gas, No.6 fuel oil, and No.2 fuel oil. FFSG Unit 3 is primarily fired with coal, residual oil, natural gas, and petroleum coke. Unit 5 consists of a Siemens 501G combustion turbine and is primarily fired with natural gas with distillate oil as backup.

#### **Facility Contact**

1.	Facility Contact Name:					
	Ms. Farzie Shelton, Associate Ger	neral Manager of Ted	chnical Support			
2.	Facility Contact Mailing Address					
	Organization/Firm: Lakeland Electric					
	Street Address: 501 E. Lemon	Street				
	City: Lakeland	State: FL	Zip Code: <b>33801-5079</b>			
3.	Facility Contact Telephone Numb	pers:				
	Telephone: (863) 834 - 6603	ext.	Fax: (863) 834 - 6362			
4.	Facility Contact E-mail Address:	farzie.shelton@lake	elandelectric.com			

## **Facility Primary Responsible Official**

Complete if an "application responsible official" is identified in Section I that is not the facility "primary responsible official."

	J 1 J 1					
1.	Facility Primary Responsible	Official Name:				
2.	Facility Primary Responsible	Official Mailing	Address			
	Organization/Firm:					
	Street Address:					
	City:	State:			Zip Code:	
3.	Facility Primary Responsible	Official Telephor	ne Numbers	•••		
	Telephone: ( )	ext.	Fax:	(	)	
4.	Facility Primary Responsible	Official E-mail A	ddress:			

# **Facility Regulatory Classifications**

Check all that would apply *following* completion of all projects and implementation of all other changes proposed in this application for air permit. Refer to instructions to distinguish between a "major source" and a "synthetic minor source."

1. ☐ Small Business Stationary Source ☐ Unknown					
2.  Synthetic Non-Title V Source					
3. ⊠ Title V Source					
4. Major Source of Air Pollutants, Other than Hazardous Air Pollutants (HAPs)					
5.  Synthetic Minor Source of Air Pollutants, Other than HAPs					
6. Major Source of Hazardous Air Pollutants (HAPs)					
7.  Synthetic Minor Source of HAPs					
8.  One or More Emissions Units Subject to NSPS (40 CFR Part 60)					
9.  One or More Emissions Units Subject to Emission Guidelines (40 CFR Part 60)					
10.  One or More Emissions Units Subject to NESHAP (40 CFR Part 61 or Part 63)					
11. Title V Source Solely by EPA Designation (40 CFR 70.3(a)(5))					
The indicate solution of the second of the s	12. Facility Regulatory Classifications Comment:				
12. Facility Regulatory Classifications Comment:  Unit 1 (EU 001), Unit 2 (EU 005), Unit 3 (EU 006), and Unit 5 (EU 028) are regulated under Acid Rain Phase II.					
12. Facility Regulatory Classifications Comment:  Unit 1 (EU 001), Unit 2 (EU 005), Unit 3 (EU 006), and Unit 5 (EU 028) are regulated under					
12. Facility Regulatory Classifications Comment:  Unit 1 (EU 001), Unit 2 (EU 005), Unit 3 (EU 006), and Unit 5 (EU 028) are regulated under Acid Rain Phase II.  Unit 2 and Unit 3 are subject to NSPS Subpart D, Standards of Performance for Fossi	I				
12. Facility Regulatory Classifications Comment:  Unit 1 (EU 001), Unit 2 (EU 005), Unit 3 (EU 006), and Unit 5 (EU 028) are regulated under Acid Rain Phase II.  Unit 2 and Unit 3 are subject to NSPS Subpart D, Standards of Performance for Fossi Fuel-Fired Steam Generators (Construction after August 17, 1971).  Unit 5 is subject to Subpart GG, Standards of Performance for New Stationary Gas	1				
12. Facility Regulatory Classifications Comment:  Unit 1 (EU 001), Unit 2 (EU 005), Unit 3 (EU 006), and Unit 5 (EU 028) are regulated under Acid Rain Phase II.  Unit 2 and Unit 3 are subject to NSPS Subpart D, Standards of Performance for Fossi Fuel-Fired Steam Generators (Construction after August 17, 1971).  Unit 5 is subject to Subpart GG, Standards of Performance for New Stationary Gas Turbines.  The facility has several Reciprocating Internal Combustion Engines (RICE) subject to	1				
12. Facility Regulatory Classifications Comment:  Unit 1 (EU 001), Unit 2 (EU 005), Unit 3 (EU 006), and Unit 5 (EU 028) are regulated under Acid Rain Phase II.  Unit 2 and Unit 3 are subject to NSPS Subpart D, Standards of Performance for Fossi Fuel-Fired Steam Generators (Construction after August 17, 1971).  Unit 5 is subject to Subpart GG, Standards of Performance for New Stationary Gas Turbines.  The facility has several Reciprocating Internal Combustion Engines (RICE) subject to 40 CFR 63 Subpart ZZZZ.  Lakeland Electric intends to comply with 40 CFR 63 Subpart UUUUU, National Emission Standards for Hazardous Air Pollutants: Coal- and Oil-Fired Electric Utility Steam	1				
12. Facility Regulatory Classifications Comment:  Unit 1 (EU 001), Unit 2 (EU 005), Unit 3 (EU 006), and Unit 5 (EU 028) are regulated under Acid Rain Phase II.  Unit 2 and Unit 3 are subject to NSPS Subpart D, Standards of Performance for Fossi Fuel-Fired Steam Generators (Construction after August 17, 1971).  Unit 5 is subject to Subpart GG, Standards of Performance for New Stationary Gas Turbines.  The facility has several Reciprocating Internal Combustion Engines (RICE) subject to 40 CFR 63 Subpart ZZZZ.  Lakeland Electric intends to comply with 40 CFR 63 Subpart UUUUU, National Emission Standards for Hazardous Air Pollutants: Coal- and Oil-Fired Electric Utility Steam	1				

# **List of Pollutants Emitted by Facility**

1. Pollutant Emitted	2. Pollutant Classification	3. Emissions Cap [Y or N]?
		[Y or N]?
PM	A	N
PM10	A	N
VOC	A	N
SO2	A	N
NOx	A	N
СО	A	N
HAPs	A	N
НСІ	A	N
SAM	A	N

# **B. EMISSIONS CAPS**

# **Facility-Wide or Multi-Unit Emissions Caps**

racinty-voice of rotati-ome Emissions Caps							
1. Pollutant Subject to	2. Facility- Wide Cap	3. Emissions Unit ID's	4. Hourly Cap	5. Annual Cap	6. Basis for Emissions		
Emissions	[Y or N]?	Under Cap	(lb/hr)	(ton/yr)	Cap		
	(all units)	(if not all units)	(10/111)	(ton/yr)	Сар		
Cap	(an units)	(if not all units)					
7. Facility-W	ide or Multi-Unit	Emissions Cap Con	nment:				
		Ī					

# C. FACILITY ADDITIONAL INFORMATION

# Additional Requirements for All Applications, Except as Otherwise Stated

1.	Facility Plot Plan: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought)  ☐ Attached, Document ID: ☐ ☑ Previously Submitted, Date: May 2013
2.	Process Flow Diagram(s): (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought)  ☐ Attached, Document ID: ☐ Previously Submitted, Date: May 2013
3.	Precautions to Prevent Emissions of Unconfined Particulate Matter: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought)  ☐ Attached, Document ID: ☐ Previously Submitted, Date: May 20013
Ac	Iditional Requirements for Air Construction Permit Applications
_	Area Map Showing Facility Location:
1.	☐ Attached, Document ID: Not Applicable (existing permitted facility)
2.	Description of Proposed Construction, Modification, or Plantwide Applicability Limit (PAL):
3.	Rule Applicability Analysis:  Attached, Document ID: See Part II
4.	List of Exempt Emissions Units:  ☐ Attached, Document ID:  ☐ Not Applicable (no exempt units at facility)
5.	Fugitive Emissions Identification:  ☐ Attached, Document ID:  ☐ Not Applicable
6.	Air Quality Analysis (Rule 62-212.400(7), F.A.C.):  ☐ Attached, Document ID: ☐ Not Applicable
7.	Source Impact Analysis (Rule 62-212.400(5), F.A.C.):  ☐ Attached, Document ID: ☐ Not Applicable
8.	Air Quality Impact since 1977 (Rule 62-212.400(4)(e), F.A.C.):  ☐ Attached, Document ID: ☐ Not Applicable
9.	Additional Impact Analyses (Rules 62-212.400(8) and 62-212.500(4)(e), F.A.C.):
10	. Alternative Analysis Requirement (Rule 62-212.500(4)(g), F.A.C.):  ☐ Attached, Document ID: ⊠ Not Applicable

# C. FACILITY ADDITIONAL INFORMATION (CONTINUED)

# **Additional Requirements for FESOP Applications**

1.	List of Exempt Emissions Units:  Attached, Document ID: Not Applicable (no exempt units at facility)
Ac	Iditional Requirements for Title V Air Operation Permit Applications
1.	List of Insignificant Activities: (Required for initial/renewal applications only)  Attached, Document ID: Not Applicable (revision application)
2.	Identification of Applicable Requirements: (Required for initial/renewal applications, and for revision applications if this information would be changed as a result of the revision being sought)  Attached, Document ID:
	☐ Not Applicable (revision application with no change in applicable requirements)
3.	Compliance Report and Plan: (Required for all initial/revision/renewal applications)  Attached, Document ID:
	Note: A compliance plan must be submitted for each emissions unit that is not in compliance with all applicable requirements at the time of application and/or at any time during application processing. The department must be notified of any changes in compliance status during application processing.
4.	List of Equipment/Activities Regulated under Title VI: (If applicable, required for initial/renewal applications only)  Attached, Document ID:
	<ul> <li>□ Equipment/Activities Onsite but Not Required to be Individually Listed</li> <li>□ Not Applicable</li> </ul>
5.	Verification of Risk Management Plan Submission to EPA: (If applicable, required for initial/renewal applications only)  Attached, Document ID:   Not Applicable
6.	Requested Changes to Current Title V Air Operation Permit:  Attached, Document ID:

# C. FACILITY ADDITIONAL INFORMATION (CONTINUED)

# Additional Requirements for Facilities Subject to Acid Rain, CAIR, or Hg Budget Program

1. Acid Rain Program Forms:
Acid Rain Part Application (DEP Form No. 62-210.900(1)(a)):  ☐ Attached, Document ID: ☐ Previously Submitted, Date: May, 2013 ☐ Not Applicable (not an Acid Rain source)
Phase II NO <sub>X</sub> Averaging Plan (DEP Form No. 62-210.900(1)(a)1.):  ☐ Attached, Document ID: ☐ Previously Submitted, Date: ☐ Not Applicable
New Unit Exemption (DEP Form No. 62-210.900(1)(a)2.):  ☐ Attached, Document ID: ☐ Previously Submitted, Date: ☐ Not Applicable
2. CAIR Part (DEP Form No. 62-210.900(1)(b)):  ☐ Attached, Document ID: ☐ Not Applicable (not a CAIR source)  ☐ Not Applicable (not a CAIR source)
Additional Requirements Comment

Section [3]

McIntosh Unit 3 - Fossil Fuel Fired Steam Generator

#### III. EMISSIONS UNIT INFORMATION

**Title V Air Operation Permit Application -** For Title V air operation permitting only, emissions units are classified as regulated, unregulated, or insignificant. If this is an application for an initial, revised or renewal Title V air operation permit, a separate Emissions Unit Information Section (including subsections A through I as required) must be completed for each regulated and unregulated emissions unit addressed in this application. Some of the subsections comprising the Emissions Unit Information Section of the form are optional for unregulated emissions units. Each such subsection is appropriately marked. Insignificant emissions units are required to be listed at Section II, Subsection C.

**Air Construction Permit or FESOP Application -** For air construction permitting or federally enforceable state air operation permitting, emissions units are classified as either subject to air permitting or exempt from air permitting. The concept of an "unregulated emissions unit" does not apply. If this is an application for an air construction permit or FESOP, a separate Emissions Unit Information Section (including subsections A through I as required) must be completed for each emissions unit subject to air permitting addressed in this application for air permit. Emissions units exempt from air permitting are required to be listed at Section II, Subsection C.

Air Construction Permit and Revised/Renewal Title V Air Operation Permit Application – Where this application is used to apply for both an air construction permit and a revised or renewal Title V air operation permit, each emissions unit is classified as either subject to air permitting or exempt from air permitting for air construction permitting purposes, and as regulated, unregulated, or insignificant for Title V air operation permitting purposes. A separate Emissions Unit Information Section (including subsections A through I as required) must be completed for each emissions unit addressed in this application that is subject to air construction permitting and for each such emissions unit that is a regulated or unregulated unit for purposes of Title V permitting. (An emissions unit may be exempt from air construction permitting but still be classified as an unregulated unit for Title V purposes.) Emissions units classified as insignificant for Title V purposes are required to be listed at Section II, Subsection C.

If submitting the application form in hard copy, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application must be indicated in the space provided at the top of each page.

DEP Form No. 62-210.900(1) Effective: 03/11/2010

Section [3]

McIntosh Unit 3 – Fossil Fuel Fired Steam Generator

#### A. GENERAL EMISSIONS UNIT INFORMATION

# **Title V Air Operation Permit Emissions Unit Classification**

1.	Regulated or Unregulated Emissions Unit? (Check one, if applying for an initial, revised or renewal Title V air operation permit. Skip this item if applying for an air construction permit or FESOP only.)				
			missions Unit Informati	on Section is a regulated	
	emissions unit.		missions Unit Informati	on Section is an	
	unregulated em		missions Omt miormati	on section is an	
En	nissions Unit Descr	iption and Status			
1.	Type of Emissions	Unit Addressed in this	Section: (Check one)		
	single process	or production unit, or ac	on addresses, as a single ctivity, which produces of efinable emission point	one or more air	
	of process or pr	roduction units and acti		e emissions unit, a group one definable emission	
			on addresses, as a single activities which produce	e emissions unit, one or fugitive emissions only.	
2.		issions Unit Addressed Fossil Fuel Fired Steam			
3.	Emissions Unit Ide	entification Number: 00	16		
4.	Emissions Unit	5. Commence	6. Initial Startup	7. Emissions Unit	
	Status Code:	Construction	Date: <b>Sept, 1982</b>	Major Group	
	^	Date:	Зері, 1902	SIC Code:	
8.	Federal Program A	pplicability: (Check al	that apply)	1	
	□ Acid Rain Unit	-			
	☐ CAIR Unit				
	☐ Hg Budget Uni	t			
9.	Package Unit:		N. 1.137 1		
10	Manufacturer:	- D. C. COLLEGE	Model Number:		
	-	ate Rating: 364 MW			
11.	generating unit. Permit No. 1050004	is a coal, residual oil, -032-AC curtails petrole	natural gas, or petroleu um coke firing effective fo e Florida Regional Haze	rom the date of EPA's	

DEP Form No. 62-210.900(1) Effective: 03/11/2010

Section [3]

McIntosh Unit 3 - Fossil Fuel Fired Steam Generator

<b>Emissions Unit Control Equipment/Method:</b> Co	ntrol <u>'</u>	<u>1</u> of	<u>4</u>
--	----------------	-------------	----------

 Control Equipment/Method Description: PM – Electrostatic Precipitator (ESP)

2. Control Device or Method Code: 010

#### Emissions Unit Control Equipment/Method: Control 2 of 4

1. Control Equipment/Method Description: SO2 – Flue Gas Desulfurization (FGD) system.

2. Control Device or Method Code: 067

#### Emissions Unit Control Equipment/Method: Control 3 of 4

 Control Equipment/Method Description: NOx - Low NOx burners (LNB), Overfire air (OFA) system

2. Control Device or Method Code: 205, 204

#### Emissions Unit Control Equipment/Method: Control 4 of 4

1. Control Equipment/Method Description: Selective Catalytic Reduction (installed voluntarily for CAIR purposes)

2. Control Device or Method Code: 139

#### **Emissions Unit Control Equipment/Method:** Control of

1. Control Equipment/Method Description:

2. Control Device or Method Code:

Section [3]

McIntosh Unit 3 – Fossil Fuel Fired Steam Generator

#### **B. EMISSIONS UNIT CAPACITY INFORMATION**

(Optional for unregulated emissions units.)

# **Emissions Unit Operating Capacity and Schedule**

1.	Maximum Process or Throughp	ut Rate:	
2.	Maximum Production Rate:		
3.	Maximum Heat Input Rate: 3,6	<b>40</b> million Btu/hr	
4.	Maximum Incineration Rate:	pounds/hr	
		tons/day	
5.	Requested Maximum Operating	Schedule:	
		24 hours/day	7 days/week
		52 weeks/year	8760 hours/year
6.	Operating Capacity/Schedule C Emission unit fires coal, residual based on fuel flow sampling.  Maximum heat input based on P	al oil, natural gas, and o	coal/petroleum coke. Heat input

DEP Form No. 62-210.900(1) Effective: 03/11/2010

Section [3]

McIntosh Unit 3 – Fossil Fuel Fired Steam Generator

## C. EMISSION POINT (STACK/VENT) INFORMATION

(Optional for unregulated emissions units.)

# **Emission Point Description and Type**

1.	. Identification of Point on Plot Plan or Flow Diagram: <b>\$003</b>		<ul><li>2. Emission Point Type Code:</li><li>1</li></ul>				
	Descriptions of Emission Exhausts through a single  ID Numbers or Descriptio	stack.					
	006			7. Exit Diameter:			
٥.	<ul><li>5. Discharge Type Code: 6. Stack Height</li><li>250 feet</li></ul>			18 Feet			
8.	Exit Temperature: <b>125°</b> F	9. Actual Volum 1,260,536 acf	metric Flow Rate:	10. Water Vapor: %			
11.	. Maximum Dry Standard F dscfm	low Rate:	12. Nonstack Emission Point Height: Feet				
13. Emission Point UTM Coordinates  Zone: East (km):  North (km):		14. Emission Point Latitude/Longitude Latitude (DD/MM/SS) Longitude (DD/MM/SS)					
15.	Emission Point Comment: Stack parameters based or		. 1050004-033-AV.				

Section [3]

McIntosh Unit 3 – Fossil Fuel Fired Steam Generator

## D. SEGMENT (PROCESS/FUEL) INFORMATION

**Segment Description and Rate:** Segment **1** of **4** 

1. Segment Description (Process/Fuel Type):
External combustion Boilers; Electric Generation, Coal.

2.	Source Classification Cod 1-01-001-01	e (S	CC):	3. SCC Units	:	
4.	Maximum Hourly Rate: <b>165.5</b>	5.	Maximum . 1,449,780	Annual Rate:	6.	Estimated Annual Activity Factor:
7.	Maximum % Sulfur: 1.6 (as received)	8.	Maximum 6		9.	Million Btu per SCC Unit: 22
10.	10. Segment Comment:  Up to 20 percent petroleum coke is authorized to be co-fired with coal.  Maximum hourly rate = 3,640 MMBtu/hr / 22 MMBtu/ton (HHV) = 165.5 tons/hr.  Maximum annual rate = 165.5 ton/hr x 8,760 hr/yr = 1,449,780 tons/year					165.5 tons/hr.
Se	gment Description and Ra	ate:	Segment 2 o	of <u>4</u>		
1.	External Combustion Boile	ers; I	Electric Gene			
2.	Source Classification Cod 1-01-004-01	e (S	CC):	3. SCC Units 1,000 Gallo		urned
4.	Maximum Hourly Rate: 24.27	5.	Maximum . <b>212,579</b>	Annual Rate:	6.	Estimated Annual Activity Factor:
7.	Maximum % Sulfur: <b>0.73</b>	8.	Maximum	% Ash:	9.	Million Btu per SCC Unit: 150
	Maximum hourly rate = 3,6 Maximum annual rate = 24		•	_	•	,

DEP Form No. 62-210.900(1) Effective: 03/11/2010

Section [3]

McIntosh Unit 3 – Fossil Fuel Fired Steam Generator

## D. SEGMENT (PROCESS/FUEL) INFORMATION (CONTINUED)

Segment Description and Rate: Segment 3 of 4

1.	Segment Description (Proc External Combustion Boile		ration; Petroleum	n Coke.
2.	Source Classification Code 1-01-008-01	e (SCC):	3. SCC Units: Tons	
4.	Maximum Hourly Rate: <b>33.1</b>	5. Maximum A 289,956	Annual Rate:	6. Estimated Annual Activity Factor:
7.	Maximum % Sulfur:	8. Maximum 9	% Ash:	9. Million Btu per SCC Unit:
10.		5.5 tons/hr (coal) a 1 ton/hr x 8,760 h coke firing would ion No. B.1 in the	x 0.2 = 33.1 ton/h nr/yr = 289,956 ton d be curtailed effe	r

## Segment Description and Rate: Segment 4 of 4

beg	ment Description and Ka	<u></u>	ocginent <u>-</u> or	그		
1.	Segment Description (Pro External combustion Boile		• 1	ration, Natural G	as	
2.	2. Source Classification Code (SCC):  1-01-006-01  3. SCC Units:  Million Cubic Feet			eet		
4.	Maximum Hourly Rate: 3.56	5.	5. Maximum Annual Rate: 31,139		6.	Estimated Annual Activity Factor:
7.	Maximum % Sulfur:	8.	Maximum <sup>6</sup>	% Ash:	9.	Million Btu per SCC Unit: 1,024
10	Segment Comment: Natural gas or propane on Maximum hourly rate = 3,6	ly or 40 N	in combinati IMBtu/hr / (1,	on with any othe 024 MMBtu/MMft	er fue t <sup>3</sup> ) = :	els or fuel combinations. 3.56 MMft <sup>3</sup> /hr

Section [3]

McIntosh Unit 3 – Fossil Fuel Fired Steam Generator

#### E. EMISSIONS UNIT POLLUTANTS

## **List of Pollutants Emitted by Emissions Unit**

1. Pollutant Emitted	2. Primary Control	3. Secondary Control	4. Pollutant
	Device Code	Device Code	Regulatory Code
PM	010		EL
SO2	067		EL
NOx	205, 204		EL
СО			EL
VOC			NS
PM10	067		NS
HCI	067		NS
H107	010		NS
NH3	139		EL*
SAM			WP

<sup>\*</sup> Not Federally Enforceable

Section [3]

POLLUTANT DETAIL INFORMATION
Page [1] of [5]

McIntosh Unit 3 – Fossil Fuel Fired Steam Generator

Particulate Matter - Total

# F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION – POTENTIAL, FUGITIVE, AND ACTUAL EMISSIONS

(Optional for unregulated emissions units.)

Complete a Subsection F1 for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V operation permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.

# Potential, Estimated Fugitive, and Baseline & Projected Actual Emissions

1. Pollutant Emitted: PM	2. Total Perc	cent Efficiency of Control:			
3. Potential Emissions: lb/hour	tons/year	4. Synthetically Limited?  ☐ Yes ☐ No			
5. Range of Estimated Fugitive Emissions (as to tons/year	applicable):				
6. Emission Factor:  Reference:		7. Emissions Method Code: 0			
8.a. Baseline Actual Emissions (if required): tons/year	8.b. Baseline From:	24-month Period: To:			
9.a. Projected Actual Emissions (if required): tons/year	9.b. Projected  5 year	d Monitoring Period: ars			
10. Calculation of Emissions:					
11. Potential, Fugitive, and Actual Emissions Comment:  No change in potential emissions as a result of the project.					

# EMISSIONS UNIT INFORMATION Section [3]

POLLUTANT DETAIL INFORMATION
Page [1] of [5]

McIntosh Unit 3 – Fossil Fuel Fired Steam Generator

**Particulate Matter - Total** 

# F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION - ALLOWABLE EMISSIONS

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions 1 of 1

1.	Basis for Allowable Emissions Code:	2.	Future Effective Date of Allowable Emissions:			
3.	Allowable Emissions and Units:	4.	Equivalent Allowable Emissions: lb/hour tons/year			
5.	Method of Compliance:					
6.	6. Allowable Emissions Comment (Description of Operating Method): No change in allowable emissions as a result of the project.					
Al	lowable Emissions Allowable Emissions	c	of			
1.	Basis for Allowable Emissions Code:	2.	Future Effective Date of Allowable Emissions:			
3.	Allowable Emissions and Units:	4.	Equivalent Allowable Emissions: lb/hour tons/year			
5.	Method of Compliance:					
6.	6. Allowable Emissions Comment (Description of Operating Method):					
Al	lowable Emissions Allowable Emissions	c	of			
1.	Basis for Allowable Emissions Code:	2.	Future Effective Date of Allowable Emissions:			
3.	Allowable Emissions and Units:	4.	Equivalent Allowable Emissions: lb/hour tons/year			
5.	Method of Compliance:					
6.	Allowable Emissions Comment (Description	of (	Operating Method):			

POLLUTANT DETAIL INFORMATION

Section [3]
McIntosh Unit 3 – Fossil Fuel Fired Steam Generator

Page [2] of [5] Sulfur Dioxide - SO2

# F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION – POTENTIAL, FUGITIVE, AND ACTUAL EMISSIONS

(Optional for unregulated emissions units.)

Complete a Subsection F1 for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V operation permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.

#### Potential, Estimated Fugitive, and Baseline & Projected Actual Emissions

1. Pollutant Emitted: <b>SO2</b>	2. Total Percent Efficiency of Control:			
3. Potential Emissions: lb/hour	tons/year	4. Synth	netically Limited? es 🛛 No	
6. Range of Estimated Fugitive Emissions (as applicable): to tons/year				
6. Emission Factor:  Reference:			7. Emissions Method Code: 0	
8.a. Baseline Actual Emissions (if required): tons/year	8.b. Baseline From:	T	o:	
9.a. Projected Actual Emissions (if required): tons/year	9.b. Projected ☐ 5 year		ng Period:  O years	
10. Calculation of Emissions:				
11. Potential, Fugitive, and Actual Emissions Comment:  No change in potential emissions as a result of the project.				

DEP Form No. 62-210.900(1) Effective: 03/11/2010

POLLUTANT DETAIL INFORMATION
Page [2] of [5]

Section [3]
McIntosh Unit 3 – Fossil Fuel Fired Steam Generator

Sulfur Dioxide - SO2

# F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION - ALLOWABLE EMISSIONS

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions 1 of 1

1.	Basis for Allowable Emissions Code:	2.	Future Effective Date of Allowable Emissions:			
3.	Allowable Emissions and Units:	4.	Equivalent Allowable Emissions:			
			lb/hour tons/year			
5.	Method of Compliance:					
6.	Allowable Emissions Comment (Description No change in allowable emissions as a result					
Al	lowable Emissions Allowable Emissions	c	of			
1.	Basis for Allowable Emissions Code:	2.	Future Effective Date of Allowable Emissions:			
3.	Allowable Emissions and Units:	4.	Equivalent Allowable Emissions:			
			lb/hour tons/year			
	<ul><li>5. Method of Compliance:</li><li>6. Allowable Emissions Comment (Description of Operating Method):</li></ul>					
Al	<b>lowable Emissions</b> Allowable Emissions	(	of			
1.	Basis for Allowable Emissions Code:	2.	Future Effective Date of Allowable Emissions:			
3.	Allowable Emissions and Units:	4.	Equivalent Allowable Emissions: lb/hour tons/year			
	Method of Compliance:					
6.	Allowable Emissions Comment (Description	of (	Operating Method):			

POLLUTANT DETAIL INFORMATION
Page [3] of [5]

Section [3]
McIntosh Unit 3 – Fossil Fuel Fired Steam Generator

Nitrogen Oxides - NOx

# F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION – POTENTIAL, FUGITIVE, AND ACTUAL EMISSIONS

(Optional for unregulated emissions units.)

Complete a Subsection F1 for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V operation permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.

# Potential, Estimated Fugitive, and Baseline & Projected Actual Emissions

1. Pollutant Emitted: NOx	2. Total Percent Efficiency of Control:				
3. Potential Emissions:		4. Synth ☐ Ye	etically Limited?		
lb/hour	tons/year				
5. Range of Estimated Fugitive Emissions (as to tons/year	applicable):				
6. Emission Factor:  Reference:			7. Emissions Method Code: 0		
8.a. Baseline Actual Emissions (if required):	8.b. Baseline	24-month	Period:		
tons/year	From:	To			
9.a. Projected Actual Emissions (if required):	9.b. Projected				
·	☐ 5 yea	rs \[ \] 10	) years		
tons/year					
11. Potential, Fugitive, and Actual Emissions Convochange in potential emissions as a result					

POLLUTANT DETAIL INFORMATION
Page [3] of [5]
Nitrogen Oxides - NOx

Section [3]
McIntosh Unit 3 – Fossil Fuel Fired Steam Generator

# F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION - ALLOWABLE EMISSIONS

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions 1 of 1

1.	Basis for Allowable Emissions Code:	2.	2. Future Effective Date of Allowable Emissions:		
3.	Allowable Emissions and Units:	4.	Equivalent Allowable Emissions:		
		''	lb/hour tons/year		
	N. 1. 1. CO 1'		To note to not		
5.	Method of Compliance:  No change in allowable emissions as a result	of t	he project.		
6.	6. Allowable Emissions Comment (Description of Operating Method): From Permit:				
Al	lowable Emissions Allowable Emissions	c	of		
1.	Basis for Allowable Emissions Code:	2.	Future Effective Date of Allowable Emissions:		
2	A111-1- E	1	England Allegaria Engladers		
3.	Allowable Emissions and Units:	4.	Equivalent Allowable Emissions:		
			lb/hour tons/year		
	<ul><li>5. Method of Compliance:</li><li>6. Allowable Emissions Comment (Description of Operating Method):</li></ul>				
Al	lowable Emissions Allowable Emissions	c	of		
1.	Basis for Allowable Emissions Code:	2.	Future Effective Date of Allowable Emissions:		
3.	Allowable Emissions and Units:	4.	Equivalent Allowable Emissions: lb/hour tons/year		
5.	Method of Compliance:				
6.	6. Allowable Emissions Comment (Description of Operating Method):				

Section [3]

POLLUTANT DETAIL INFORMATION
Page [4] of [5]

McIntosh Unit 3 - Fossil Fuel Fired Steam Generator

Carbon Monoxide - CO

# F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION – POTENTIAL, FUGITIVE, AND ACTUAL EMISSIONS

(Optional for unregulated emissions units.)

Complete a Subsection F1 for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V operation permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.

# Potential, Estimated Fugitive, and Baseline & Projected Actual Emissions

1. Pollutant Emitted: CO	2. Total Percent Efficiency of Control:				
3. Potential Emissions: lb/hour	tons/year	4. Synthetically Limited?  ☐ Yes ☒ No			
5. Range of Estimated Fugitive Emissions (as applicable): to tons/year					
6. Emission Factor:  Reference:		7. Emissions Method Code: 0			
8.a. Baseline Actual Emissions (if required): tons/year	8.b. Baseline 24-month Period: From: To:				
9.a. Projected Actual Emissions (if required): tons/year		d Monitoring Period: urs			
tons/year					
11. Potential, Fugitive, and Actual Emissions Comment:  No change in potential emissions as a result of the project.					

POLLUTANT DETAIL INFORMATION
Page [4] of [5]

Section [3]
McIntosh Unit 3 – Fossil Fuel Fired Steam Generator

Carbon Monoxide - CO

# F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION - ALLOWABLE EMISSIONS

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions 1 of 1

1.	Basis for Allowable Emissions Code:	2.	Future Effective Date of Allowable Emissions:			
3.	Allowable Emissions and Units:	4.	Equivalent Allowable Emissions: lb/hour tons/year			
5.	Method of Compliance:					
6.	Allowable Emissions Comment (Description  No change in allowable emissions as a result					
Al	lowable Emissions Allowable Emissions					
1.	Basis for Allowable Emissions Code:	2.	Future Effective Date of Allowable Emissions:			
3.	Allowable Emissions and Units:	4.	Equivalent Allowable Emissions: lb/hour tons/year			
5.	Method of Compliance:					
6.	6. Allowable Emissions Comment (Description of Operating Method):					
Al	lowable Emissions Allowable Emissions		of			
1.	Basis for Allowable Emissions Code:	2.	Future Effective Date of Allowable Emissions:			
3.	Allowable Emissions and Units:	4.	Equivalent Allowable Emissions: lb/hour tons/year			
5.	Method of Compliance:					
6.	6. Allowable Emissions Comment (Description of Operating Method):					

POLLUTANT DETAIL INFORMATION

Section [3]
McIntosh Unit 3 – Fossil Fuel Fired Steam Generator

Page [5] of [5] Ammonia - NH3

# F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION – POTENTIAL, FUGITIVE, AND ACTUAL EMISSIONS

(Optional for unregulated emissions units.)

Complete a Subsection F1 for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V operation permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.

#### Potential, Estimated Fugitive, and Baseline & Projected Actual Emissions

Pollutant Emitted:     NH3	2. Total Perc	ent Efficien	cy of Control:		
3. Potential Emissions: lb/hour	tons/year	4. Synther ☐ Yes	tically Limited?		
5. Range of Estimated Fugitive Emissions (as to tons/year	applicable):				
6. Emission Factor:  Reference:			7. Emissions Method Code: 0		
8.a. Baseline Actual Emissions (if required):	8.b. Baseline	24 month D	oriod:		
tons/year					
•	From:	To:			
9.a. Projected Actual Emissions (if required):	9.b. Projected	_			
tons/year	☐ 5 yea	$rs \square 10$	years		
10. Calculation of Emissions:	ommonti				
11. Potential, Fugitive, and Actual Emissions Comment:  No change in potential emissions as a result of the project.					

DEP Form No. 62-210.900(1) Effective: 03/11/2010

POLLUTANT DETAIL INFORMATION

Section [3]
McIntosh Unit 3 – Fossil Fuel Fired Steam Generator

Page [5] of [5] Ammonia - NH3

# F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION - ALLOWABLE EMISSIONS

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions 1 of 1

1.	Basis for Allowable Emissions Code:	2.	Future Effective Date of Allowable Emissions:			
3.	Allowable Emissions and Units:	4.	Equivalent Allowable Emissions: lb/hour tons/year			
5.	Method of Compliance:					
6.	. Allowable Emissions Comment (Description of Operating Method):					
	No change in allowable emissions as a result of the project.					
All	lowable Emissions Allowable Emissions	0	f			
1.	Basis for Allowable Emissions Code:	2.	Future Effective Date of Allowable Emissions:			
3.	Allowable Emissions and Units:	4.	Equivalent Allowable Emissions: lb/hour tons/year			
5.	Method of Compliance:					
6.	6. Allowable Emissions Comment (Description of Operating Method):					
Al	lowable Emissions Allowable Emissions	0	f			
1.	Basis for Allowable Emissions Code:	2.	Future Effective Date of Allowable Emissions:			
3.	Allowable Emissions and Units:	4.	Equivalent Allowable Emissions: lb/hour tons/year			
5.	Method of Compliance:					
6.	Allowable Emissions Comment (Description	of (	Operating Method):			

Section [3]

McIntosh Unit 3 – Fossil Fuel Fired Steam Generator

#### G. VISIBLE EMISSIONS INFORMATION

Complete Subsection G if this emissions unit is or would be subject to a unit-specific visible emissions limitation.

<u>Visible Emissions Limitation:</u> Visible Emissions Limitation <u>1</u> of <u>2</u>

1.	Visible Emissions Subtype:	2. Basis for Allowable	Opacity:
	VE20	⊠ Rule	☐ Other
3.	Allowable Opacity:		
	± •	ceptional Conditions:	<b>27</b> %
	Maximum Period of Excess Opacity Allowe	ed:	6 min/hour
4.	Method of Compliance: <b>VE test using DEP</b>	Method 9	
	1		
5.	Visible Emissions Comment:		
	40 CFR 60.42(a)(2) and Permit No. 1050004-0	33-AV	
Vi	sible Emissions Limitation: Visible Emissi	ons Limitation <b>2</b> of <b>2</b>	
1.	Visible Emissions Subtype:	2. Basis for Allowable	Opacity:
	VE99	⊠ Rule	☐ Other
3.	Allowable Opacity:		
.	± •	ceptional Conditions:	100 %
	Maximum Period of Excess Opacity Allowe	1	<b>60</b> min/hour
4	Method of Compliance: None		
''	Method of Comphance. None		
5.	Visible Emissions Comment:		
	Excess VE emissions allowed under FDEP		
	60.11(c) for 2 hours per 24-hour period for st	tartup, shutdown, and mal	function.

Section [3]

McIntosh Unit 3 – Fossil Fuel Fired Steam Generator

### H. CONTINUOUS MONITOR INFORMATION

Complete Subsection H if this emissions unit is or would be subject to continuous monitoring.

Continuous Monitoring System: Continuous Monitor 1 of 6

1.	Parameter Code: EM	2.	Pollutant(s): SO <sub>2</sub>
3.	CMS Requirement:	$\boxtimes$	Rule
4.	Monitor Information Manufacturer: Thermo Electron Corp.		
	Model Number: 43I-ANSAB		Serial Number: 0608716018
5.	Installation Date: 23 May 2008	6.	Performance Specification Test Date:
7.	Continuous Monitor Comment: CEM required pursuant to 40 CFR 75, PSD-F	L-00	8(B), and Title V Permit No. 1050004-033-AV.
Co	ntinuous Monitoring System: Continuous	Moı	nitor <b>2</b> of <b>6</b>
1.	Parameter Code: EM	2.	Pollutant(s): NO <sub>x</sub>
3.	CMS Requirement:	$\boxtimes$	Rule
4.	Monitor Information Manufacturer: Thermo Electron Corp.		
	Model Number: 42I-ANMSDAB		Serial Number: 0608716016
5.	Installation Date: 23 May 2008	6.	Performance Specification Test Date:
7.	Continuous Monitor Comment: CEM required pursuant to 40 CFR 75, PSD-F	L-00	B(B), and Title V Permit No. 1050004-033-AV.

Section [3]

McIntosh Unit 3 – Fossil Fuel Fired Steam Generator

# H. CONTINUOUS MONITOR INFORMATION (CONTINUED)

<u>Continuous Monitoring System:</u> Continuous Monitor <u>3</u> of <u>6</u>

1.	Parameter Code: <b>VE</b>	2.	Pollutant(s):
3.	CMS Requirement:	$\boxtimes$	Rule
4.	Monitor Information Manufacturer: Teledyne		
	Model Number: Lighthawk #560		Serial Number: 5602407
5.	Installation Date: 27 May 2013	6.	Performance Specification Test Date:
7.		L-00	08(B), and Title V Permit No. 1050004-033-AV.
<u>Co</u>	ntinuous Monitoring System: Continuous	Moı	nitor <u>4</u> of <u>6</u>
1.	Parameter Code: CO2	2.	Pollutant(s):
3.	CMS Requirement:	$\boxtimes$	Rule
4.	Monitor Information  Manufacturer: Thermo Electron Corp.		
	Model Number: 410I-ANPDAB	Sei	rial Number: <b>0608716015</b>
5.	Installation Date: 23 May 2008	6.	Performance Specification Test Date:
7.	Continuous Monitor Comment: CEM required pursuant to 40 CFR 75.		

Section [3]

McIntosh Unit 3 – Fossil Fuel Fired Steam Generator

## H. CONTINUOUS MONITOR INFORMATION (CONTINUED)

<u>Continuous Monitoring System:</u> Continuous Monitor <u>5</u> of <u>6</u>

1.	Parameter Code: FLOW	2. Pollutant(s):
3.	CMS Requirement:	⊠ Rule ☐ Other
4.	Monitor Information  Manufacturer: United Science, Inc.	
	Model Number: ULTRAFLOW 100	Serial Number: 1001060
5.	Installation Date:  19 Mar 2000	6. Performance Specification Test Date:
7.	Continuous Monitor Comment: FLOW monitor required pursuant to 40 CFR	75.
<u>Co</u>	ontinuous Monitoring System: Continuous	Monitor 6 of 6
	continuous violitoring bystem.	Monitor <b>6</b> or <b>6</b>
1.	Parameter Code: EM	2. Pollutant(s): <b>CO</b>
	Parameter Code:	2. Pollutant(s):
3.	Parameter Code: EM	2. Pollutant(s): CO
3.	Parameter Code:  EM  CMS Requirement:  Monitor Information	2. Pollutant(s): CO
3.	Parameter Code:  EM  CMS Requirement:  Monitor Information  Manufacturer: Thermo Electron Corp.	2. Pollutant(s):  CO  Nule  Other

Section [3]

McIntosh Unit 3 – Fossil Fuel Fired Steam Generator

# I. EMISSIONS UNIT ADDITIONAL INFORMATION

# Additional Requirements for All Applications, Except as Otherwise Stated

1.	Process Flow Diagram: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought)  Attached, Document ID: Previously Submitted, Date May, 2013
2.	Fuel Analysis or Specification: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought)  Attached, Document ID: Previously Submitted, Date May, 2013
3.	air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought)  Attached, Document ID:   Previously Submitted, Date May, 2013
4.	Procedures for Startup and Shutdown: (Required for all operation permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought)  Attached, Document ID: Previously Submitted, Date  Not Applicable (construction application)
5.	Operation and Maintenance Plan: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought)  Attached, Document ID: Previously Submitted, Date
6.	Compliance Demonstration Reports/Records:  Attached, Document ID:  Test Date(s)/Pollutant(s) Tested:
	□ Previously Submitted, Date:  Test Date(s)/Pollutant(s) Tested:  □ To be Submitted, Date (if known):  Test Date(s)/Pollutant(s) Tested:  □ Not Applicable  Note: For FESOP applications, all required compliance demonstration records/reports must be submitted at the time of application. For Title V air operation permit applications, all required compliance demonstration reports/records must be submitted at the time of application, or a
7.	compliance plan must be submitted at the time of application.  Other Information Required by Rule or Statute:  ☐ Attached, Document ID: ☐ ☒ Not Applicable

Section [3]

McIntosh Unit 3 – Fossil Fuel Fired Steam Generator

# I. EMISSIONS UNIT ADDITIONAL INFORMATION (CONTINUED)

# **Additional Requirements for Air Construction Permit Applications**

1.	Control Technology Review and Analysis	(Rules 62-212.400(10) and 62-212.500(7),
	F.A.C.; 40 CFR 63.43(d) and (e)):	
	☐ Attached, Document ID:	
2.	Good Engineering Practice Stack Height A	nalysis (Rules 62-212.400(4)(d) and 62-
	212.500(4)(f), F.A.C.):	
	Attached, Document ID:	Not Applicable
3.	Description of Stack Sampling Facilities: (only)	Required for proposed new stack sampling facilities
	Attached, Document ID:	
A	dditional Requirements for Title V Air Op	eration Permit Applications
1.	Identification of Applicable Requirements:  ☐ Attached, Document ID:	
2.	Compliance Assurance Monitoring:  Attached, Document ID:	☐ Not Applicable
3.	Alternative Methods of Operation:  Attached, Document ID:	☐ Not Applicable
4.	Alternative Modes of Operation (Emissions	s Trading):
	☐ Attached, Document ID:	☐ Not Applicable
A	dditional Requirements Comment	



#### **PART II**

# APPLICATION FOR MINOR SOURCE AIR CONSTRUCTION PERMIT FOR DELETION OF SULFURIC ACID MIST TESTING REQUIREMENT FOR MCINTOSH UNIT 3 (EU006)

#### **PROJECT SUMMARY**

In this air construction permit application Lakeland Electric (LE) is requesting the Florida Department of Environmental Protection (FDEP) remove the sulfuric acid mist (SAM) testing requirement related to increasing the percent sulfur in coal for the fossil fuel steam generator Unit 3 (EU ID 006) at the McIntosh Jr. Power Plant.

Specific Condition D.35 of Title V Air Operating Permit No. 1050004-033-AV (condition established by Permit No. 1050004-026-AC) requires Unit 3 to conduct stack tests to determine the uncontrolled SAM emission rate, the controlled SAM emission rate, and actual control efficiency of the installed sorbent injection system. LE conducted these tests and submitted test reports to Florida Department of Environmental Protection (FDEP) in January, March, and April, 2010. The tests demonstrated that the sorbent system was not required to reduce SAM emissions at the stack.

Specific Condition D.35 also includes a condition that requires LE to re-test within 45 days if a fuel blend with a sulfur content that is 0.20% sulfur by weight higher than the maximum sulfur content previously tested is fired. Therefore, if previous testing was conducted using a maximum of 1.72% sulfur coal, retesting will be required for firing higher than 1.92% sulfur coal. The data analysis and conclusions drawn from of the previous test results indicate that additional testing is not necessary and therefore, LE is requesting removal of the additional SAM testing requirements from the air permit. Since the proposed change is modification of a permit condition that was issued under an air construction permit, an air construction permit is required from the FDEP.

LE provided a summary of the SAM stack testing results to Mr. Jeff Koerner of FDEP in letter dated April 26, 2010, which included an evaluation completed by Golder Associates Inc. (Golder). The Golder evaluation is also attached in Appendix A of this document.

Table 1 of Appendix A presented a summary of the test results and provides SO<sub>3</sub> emissions in lb/MMBtu at four locations – before and after the SCR, at the ESP inlet, and at the stack. Table 2 presented the SAM emissions increases and decreases between the locations presented in Table 1. The tests conducted at the SCR inlet and SCR outlet clearly demonstrates an increase in SAM emissions resulting from the SCR catalyst as predicted in the original permitting for the installation of the SCR system. A sorbent injection was installed to account for the increase in predicted SAM emissions from the SCR system. However, at the time there was no specific information on the removal capabilities of the downstream equipment (air preheater, ESP and FGD system). The SAM testing demonstrated that there



were no noticeable differences in the stack exit SAM emissions based on the operation of the sorbent injection system. It was also observed that when sorbent is injected, the amount of SAM reduction in the air heater is higher. Additional SAM reduction was also achieved in the ESP and FGD system as shown in Table 2. The overall conclusion from the testing was that the sorbent injection system did not have a measurable influence in reducing SAM emission at the stack and there was no difference in the stack SAM emissions using 1.55 percent and 1.72 percent sulfur coals. As a result, the requirement to utilize the sorbent system was removed.

Table 3 of Appendix A compared projected actual SAM emissions based on the test results and conservative operating hours to the baseline actual SAM emissions of 136 tons per year (TPY). As shown, there was an overall decrease in SAM emissions compared to the baseline actual SAM emissions of 136 TPY. In Table 4 of Appendix A, the projected actual emissions were estimated due to 3.4% sulfur coal based on linear interpolation. For example, in Scenario A the SAM emissions were 63.4 lb/hr with 1.55 percent sulfur coal and were projected to be 139.1 lb/hr using 3.4 percent sulfur coal (i.e., 63.4 lb/hr at 3.4/1.55). Using the removal efficiencies from testing of 62.1 percent for the air preheater and 63.6 percent for the ESP/FGD systems, the projected SAM emissions without sorbent injection would be 84.1 TPY. The results of all scenarios demonstrated that Unit 3's SAM emissions without sorbent injection would still be approximately 44-52% less than the baseline actual emissions of 136 TPY. With sorbent injection the reduction would be approximately 55%.

LE is currently planning to use coal with a maximum sulfur content higher than 1.92%. Based on the evaluation of numerous SAM test results presented in Appendix A, it can be reasonably assured that there will still be an overall decrease in SAM emissions compared to the baseline actual emissions of 136 TPY. As a result, further SAM testing is not required and requests FDEP to remove Specific Condition No. 15 of permit No. 1050004-026-AC (basis for Condition D.35 of Permit No. 1050004-033-AV), which requires SAM performance tests and sorbent injection for SAM emissions control.

McIntosh Unit 3 is currently permitted to fire coal, residual oil, and natural gas. The use of higher sulfur coal is not a physical or operational change since coal is an authorized fuel. Petroleum coke was previously authorized as a fuel. However, the use of petroleum coke was prohibited by Permit No. 1050004-032-AC and is effective upon the date of EPA's approval of the Florida Regional Haze State Implementation Plan.

Since there are no physical changes to the emission unit and no change in emissions, the proposed change in permit condition is not a "modification" as defined in Rule 62-210.200(205), Florida Administrative Code (F.A.C.). As a result, a minor source air construction permit is being submitted for the project.

This air construction permit application package consists of the appropriate application form [DEP Form 62-210.900(1)], a description of the proposed change, and rule applicability.



## **RULE APPLICABILITY**

Under federal and state of Florida Prevention of Significant Deterioration (PSD) review requirements, all major new or modified sources of air pollutants regulated under the Clean Air Act (CAA) must be reviewed and a pre-construction permit issued. The U.S. Environmental Protection Agency (EPA) has approved Florida's State Implementation Plan (SIP), which contains PSD regulations. The applicable PSD rules in Florida are found in Rule 62-212.400, F.A.C.

A "major facility" is defined as any of 28 named source categories that have the potential to emit 100 TPY or more, or any other stationary facility that has the potential to emit 250 TPY or more, of any pollutant regulated under the CAA. "Potential to emit" means the capability, at maximum design capacity, to emit a pollutant after the application of control equipment. Once a new source is determined to be a "major facility" for a particular pollutant, any pollutant emitted in amounts greater than the PSD significant emission rates is subject to PSD review. For an existing source for which a modification is proposed, the modification is subject to PSD review if the net increase in emissions due to the modification is greater than the PSD significant emission rates.

PSD review is used to determine whether significant air quality deterioration will result from the new or modified facility. Federal PSD requirements are contained in Title 40, Part 52.21 of the Code of Federal Regulations (40 CFR 52.21), Prevention of Significant Deterioration of Air Quality. The state of Florida has adopted the federal PSD regulations by reference (Rule 62-212.400, F.A.C.). Major facilities and major modifications are required to undergo the following analyses related to PSD for each pollutant emitted in significant amounts:

- Control technology review
- Source impact analysis
- Air quality analysis (monitoring)
- Source information
- Additional impact analyses

The McIntosh Power Plant is a major facility under FDEP rules. Based on Rule 62-210.200(205), F.A.C., modification is defined as any physical change in, change in the method of operation of, or addition to a facility which would result in an increase in the actual emissions of any pollutant subject to new source review regulation under the CAA. Because there are no physical changes, nor a change in the method of operation, the project is not a modification as defined in the FDEP rules in Rule 62-210.200 and under the PSD rules in Rule 62-212.400, F.A.C. PSD review would be required for the project if there were a significant net increase in emissions. There are no changes in emissions as a result of the project. Therefore, PSD review does not apply and baseline-to-future projected actual emissions test is not required.







April 21, 2010 103-87550

Ms. Farzie Shelton, Associate General Manager Technical Support Lakeland Electric 501 East Lemon Street Lakeland, Florida 33801

RE: C.D. MCINTOSH JR. POWER PLANT UNIT 3 SULFURIC ACID MIST TESTING PROJECT NO. 1050004-027-AC

Dear Ms. Shelton:

Lakeland Electric recently completed installation of the selective catalytic reduction (SCR) system on McIntosh Unit 3 that was authorized under the Florida Department of Environmental Protection (FDEP) Air Construction Permit No. 1050004-019-AC. According to Condition 11 of the permit, Lakeland Electric is required to demonstrate through testing and reporting that the actual annual sulfuric acid mist (SAM) emissions due to the SCR system will be less than 7 tons per year (TPY) over the baseline SAM emissions of 136 TPY. To meet this requirement, Lakeland Electric installed a sorbent injection system to provide additional SAM control for potential increase in SAM due to the SCR system (Condition 9 of the permit). Lakeland Electric is required to conduct initial performance tests of the sorbent injection system (Specific Condition No. 15 of the permit). This permit Condition specifically requires Lakeland Electric to determine the controlled SAM emission rate, uncontrolled SAM emission rate, and the actual control efficiency of the sorbent injection system by conducting tests while firing the highest sulfur fuel. The detailed requirements for the testing were specified in FDEP's letter dated November 25, 2009. Lakeland Electric conducted tests on February 1 through 10, 2010, and submitted test reports on March 26, 2010. This correspondence provides a presentation and evaluation of the test results for compliance with the air construction permit conditions.

The SAM tests were conducted at the following test locations at loads of 100, 88, and 74\* percent with the sorbent injection system operating and not operating:

- Before the SCR Baseline SAM emission rate
- After the SCR Estimation of SAM emissions increase due to the SCR system
- After the Air Heater Estimation of SAM emissions after being absorbed by the sorbent
- At the stack SAM emissions released into the atmosphere

\*Load on the Unit was increased from 69% to 74% load to meet the SCR system's minimum temperature operating setpoint requirements.

A summary of these tests provided to FDEP is presented in attached Tables 1 through 4. A total of 12 scenarios were tested with a total of 16 test runs based on the Test Protocol submitted to FDEP in September 2009 and detailed in FDEP's November 25, 2009, authorization. Table 1 presents a summary of the test results and provides sulfur trioxide (SO<sub>3</sub>) emissions in pounds per million British thermal units (lb/MMBtu) at four locations – before and after the SCR, at the electrostatic precipitator (ESP) inlet, and at the stack. Table 2 presents the SAM emissions increases and decreases between the locations presented in Table 1 as well as the SAM reductions. The tests conducted at the SCR inlet and SCR outlet clearly indicate an increase in SAM emissions resulting from the SCR catalyst. The increases were generally higher at the 100 percent load. Table 2 shows the reduction in SAM emission rates between the two testing locations for each scenario as well as the percent reduction. The results of Scenarios 1A-C, 2A-B, and 3A-B indicate that, as expected, SAM is reduced in the air heater located after the SCR outlet and before the ESP inlet. However, when sorbent is injected, the amount of SAM reduction in the air

L042110\_550\_rev1 kfk.docx





heater is higher. Additional reduction is also achieved in the ESP and flue gas desulfurization (FGD) system as shown in Table 2. Comparing the scenarios with and without sorbent injection suggests that that there is no difference in the stack emission rates. Overall, the increase in SAM emissions observed from the SCR catalyst is being removed effectively in the air pre-heater (APH), ESP, and FGD system.

Table 3 presents the projected actual SAM emissions based on the test data compared to the baseline actual SAM emissions. The calculations were based on the pound per hour (lb/hr) SAM emissions rates calculated using the SAM emission rates in lb/MMBtu and the heat inputs observed during the tests. The annual projected actual SAM emissions were based on the assumption that Unit 3 operated for 8,760 hours per year for each scenario. As a result, the comparison is especially conservative for higher loads. This table shows that there is an overall decrease in SAM emissions compared to the baseline actual SAM emissions of 136 TPY using a conservative calculation.

Table 4 presents an illustration of the projected actual SAM emissions with the potential fuel sulfur content of 3.4 percent compared to the baseline actual emissions. For this comparison, the sulfur content of 3.4 percent was used to increase the SAM emissions based on a linear relationship. For example, the SAM emissions for Scenarios 1A through 1C were increased by the ratio 3.4/1.55. The percentage of SAM emissions removed within the system – at the APH and within the ESP – observed in the testing was used to reduce the increased SAM emissions. Table 4 shows that using coal with a sulfur content of 3.4 percent would have resulted in project actual SAM emissions less than the baseline actual emissions.

Based on the test conditions and results, the SAM emissions from combustion and increased by the SCR catalyst are effectively limited by the air preheater, ESP and FGD system. Within the air preheater the reduction is likely due to a combination of the reduction in temperature and interaction with the ash. The use of the sorbent injection, while incrementally effective in reducing SAM at the air preheater, does not have a measurable influence in reducing SAM emission at the stack. This is evidence in Table 1 where the stack emissions with and without the sorbent injection system are the same.

If you have any questions, please do not hesitate to call us at (352) 336-5600 or via email (kkosky@golder.com or smohammad@golder.com).

Salahuddin Mohammad

Senior Project Engineer

Sincerely,

**GOLDER ASSOCIATES INC.** 

Kennard F. Kosky, P.E.

Principal Engineer

cc: Bret Galbraith, Lakeland Electric

**Enclosures** 

SKM/tz



TABLE 1 SAM TEST RESULTS MCINTOSH UNIT 3

						SO <sub>3</sub> at S	CR Inlet	SO <sub>3</sub> at SO	CR Outlet	SO <sub>3</sub> at E	SP Inlet	SO <sub>3</sub> at Stack	
Scenario	Unit Capacity (%)	Gross Output (MW)	Heat Input (Ib/MMBtu)	Fuel Sulfur (%)	Sorbent Injection Rate [Ib/hr Ca(OH) <sub>2</sub> ]	South Duct (Side 31) (lb/MMBtu)	North Duct (Side 32) (lb/MMBtu)	South Duct (Side 31) (Ib/MMBtu)	North Duct (Side 32) (Ib/MMBtu)	South Duct (Side 31) (lb/MMBtu)	North Duct (Side 32) (lb/MMBtu)	Average (lb/MMBtu)	
1A	100	365	3571	1.55	0	0.004	0.002	0.012	0.019	0.002	0.009	0.0020	
1B	100	365			0	0.001		0.013					
			3893	1.55	0	0.001	0.005	0.013	0.022	0.003	0.011	0.0020	
1C	100	365	3908	1.55	0	0.002	0.005	0.014	0.020	0.006	0.010	0.0020	
2A	88	320	3291	1.31	0	0.001	0.004	0.004	0.009	0.003	0.003	0.0010	
2B	88	320	3240	1.31	0	0.001	0.004	0.008	0.016	0.004	0.003	0.0010	
ЗА	74	270	2911	1.43	0	0.003	0.009	0.010	0.016	0.005	0.005	0.0010	
3B	74	270	2928	1.43	0	0.002	0.005	0.009	0.014	0.002	0.004	0.0010	
4	100	365	3807	1.72	120	0.001	0.005	0.004	0.021	0.000	0.010	0.0020	
5	100	365	3825	1.72	360	0.004	0.007	0.015	0.018	0.001	0.008	0.0020	
6	100	365	3822	1.72	240	0.003	0.004	0.013	0.025	0.001	0.017	0.0020	
7	88	320	3287	1.31	105	0.001	0.004	0.008	0.012	0.000	0.004	0.0010	
8	88	320	3285	1.31	316	0.000	0.003	0.009	0.013	0.000	0.003	0.0010	
9	88	320	3288	1.31	211	0.000	0.002	0.009	0.014	0.000	0.005	0.0010	
10	74	270	2938	1.43	89	0.001	0.003	0.008	0.016	0.002	0.003	0.0010	
11	74	270	2960	1.43	267	0.002	0.002	0.009	0.017	0.002	0.003	0.0010	
12	74	270	2961	1.43	179	0.001	0.004	0.009	0.016	0.002	0.003	0.0010	

Note: Data based on SAM tests conducted on February 1, 2, 3, 8, and 9, 2010.



TABLE 2  ${\rm SO_3}$  EMISSIONS AND PERCENT REDUCTION MCINTOSH UNIT 3

						SCR Out	let - Inlet		ESP Inlet -	SCR Outlet		Stack -	ESP Inlet
						Emission	Increase	Emission Reduction		Emission Reduction %		Emission Reduction	Emission Reduction %
Scenario	Unit Capacity	Gross Output	Heat Input	Fuel Sulfur	Sorbent Injection Rate	South Duct (Side 31)	North Duct (Side 32)	South Duct (Side 31)	North Duct (Side 32)	South Duct (Side 31)	North Duct (Side 32)	Average	Average
	(%)	(MW)	(lb/MMBtu)	(%)	[lb/hr Ca(OH) <sub>2</sub> ]	(lb/MMBtu)	(lb/MMBtu)	(lb/MMBtu)	(lb/MMBtu)			(lb/MMBtu)	
1A	100	365	3571	1.55	0	0.012	0.017	-0.011	-0.010	84.6%	52.6%	-0.0035	63.6%
1B	100	365	3893	1.55	0	0.012	0.017	-0.01	-0.011	76.9%	50.0%	-0.0050	71.4%
1C	100	365	3908	1.55	0	0.012	0.015	-0.008	-0.010	57.1%	50.0%	-0.0060	75.0%
2A	88	320	3291	1.31	0	0.003	0.005	-0.001	-0.006	25.0%	66.7%	-0.0020	66.7%
2B	88	320	3240	1.31	0	0.007	0.012	-0.004	-0.013	50.0%	81.3%	-0.0025	71.4%
3A	74	270	2911	1.43	0	0.007	0.007	-0.005	-0.011	50.0%	68.8%	-0.0040	80.0%
3B	74	270	2928	1.43	0	0.007	0.009	-0.007	-0.010	77.8%	71.4%	-0.0020	66.7%
4	100	365	3807	1.72	120	0.003	0.016	-0.004	-0.011	100.0%	52.4%	-0.0030	60.0%
5	100	365	3825	1.72	360	0.011	0.011	-0.014	-0.010	93.3%	55.6%	-0.0025	55.6%
6	100	365	3822	1.72	240	0.010	0.021	-0.012	-0.008	92.3%	32.0%	-0.0070	77.8%
7	88	320	3287	1.31	105	0.007	0.008	-0.008	-0.008	100.0%	66.7%	-0.0010	50.0%
8	88	320	3285	1.31	316	0.009	0.01	-0.009	-0.010	100.0%	76.9%	-0.0005	33.3%
9	88	320	3288	1.31	211	0.009	0.012	-0.009	-0.009	100.0%	64.3%	-0.0015	60.0%
10	74	270	2938	1.43	89	0.007	0.013	-0.006	-0.013	75.0%	81.3%	-0.0015	60.0%
11	74	270	2960	1.43	267	0.007	0.015	-0.007	-0.014	77.8%	82.4%	-0.0015	60.0%
12	74	270	2961	1.43	179	0.008	0.012	-0.007	-0.013	77.8%	81.3%	-0.0015	60.0%

Note: Data based on SAM tests conducted on February 1, 2, 3, 8, and 9, 2010.



TABLE 3
PROJECTED ACTUAL SAM EMISSIONS BASED ON TEST DATA COMPARED TO BASELINE ACTUAL SAM EMISSIONS MCINTOSH UNIT 3

						SO <sub>3</sub> Generated in SCR <sup>a</sup>					SO <sub>3</sub>	SO <sub>3</sub> at ESP Inlet <sup>a</sup>			SO <sub>3</sub> at Stack <sup>a</sup>			
Scenario	Unit Capacity	Gross Output	Heat Input	Fuel Sulfur	Sorbent Injection Rate	South Duct (Side 31)	North Duct (Side 32)	Average SO <sub>3</sub>	Average SO <sub>3</sub>	Average SAM <sup>c</sup>	Average SO <sub>3</sub>	Average SO <sub>3</sub>	Average SAM <sup>c</sup>	Average SO <sub>3</sub>	Average SO <sub>3</sub>	Average SAM <sup>c</sup>	Project Actual SAM <sup>b</sup>	from Baseline Actual <sup>d</sup>
	(%)	(MW)	(lb/MMBtu)	(%)	[lb/hr Ca(OH) <sub>2</sub> ]	(lb/MMBtu)	(lb/MMBtu)	(lb/MMBtu)	(lb/hr)	(lb/hr)	(lb/MMBtu)	(lb/hr)	(lb/hr)	(lb/MMBtu)	(lb/hr)	(lb/hr)	(TPY)	(TPY)
1A	100	365	3571	1.55	0	0.012	0.017	0.015	51.8	63.4	0.0055	19.6	24.1	0.0020	7.1	8.7	38.3	-97.7
1B	100	365	3893	1.55	0	0.012	0.017	0.015	56.4	69.1	0.0070	27.3	33.4	0.0020	7.8	9.5	41.8	-94.2
1C	100	365	3908	1.55	0	0.012	0.015	0.014	52.8	64.6	0.0080	31.3	38.3	0.0020	7.8	9.6	41.9	-94.1
2A	88	320	3291	1.31	0	0.003	0.005	0.004	13.2	16.1	0.0030	9.9	12.1	0.0010	3.3	4.0	17.7	-118.3
2B	88	320	3240	1.31	0	0.007	0.012	0.010	30.8	37.7	0.0035	11.3	13.9	0.0010	3.2	4.0	17.4	-118.6
3A	74	270	2911	1.43	0	0.007	0.007	0.007	20.4	25.0	0.0050	14.6	17.8	0.0010	2.9	3.6	15.6	-120.4
3B	74	270	2928	1.43	0	0.007	0.009	0.008	23.4	28.7	0.0030	8.8	10.8	0.0010	2.9	3.6	15.7	-120.3
4	100	365	3807	1.72	120	0.003	0.016	0.010	36.2	44.3	0.0050	19.0	23.3	0.0020	7.6	9.3	40.9	-95.1
5	100	365	3825	1.72	360	0.011	0.011	0.011	42.1	51.5	0.0045	17.2	21.1	0.0020	7.7	9.4	41.0	-95.0
6	100	365	3822	1.72	240	0.010	0.021	0.016	59.2	72.6	0.0090	34.4	42.1	0.0020	7.6	9.4	41.0	-95.0
7	88	320	3287	1.31	105	0.007	0.008	0.008	24.7	30.2	0.0020	6.6	8.1	0.0010	3.3	4.0	17.6	-118.4
8	88	320	3285	1.31	316	0.009	0.010	0.010	31.2	38.2	0.0015	4.9	6.0	0.0010	3.3	4.0	17.6	-118.4
9	88	320	3288	1.31	211	0.009	0.012	0.011	34.5	42.3	0.0025	8.2	10.1	0.0010	3.3	4.0	17.6	-118.4
10	74	270	2938	1.43	89	0.007	0.013	0.010	29.4	36.0	0.0025	7.3	9.0	0.0010	2.9	3.6	15.8	-120.2
11	74	270	2960	1.43	267	0.007	0.015	0.011	32.6	39.9	0.0025	7.4	9.1	0.0010	3.0	3.6	15.9	-120.1
12	74	270	2961	1.43	179	0.008	0.012	0.010	29.6	36.3	0.0025	7.4	9.1	0.0010	3.0	3.6	15.9	-120.1

<sup>&</sup>lt;sup>a</sup> Based on SAM test results presented in Table 1.



<sup>&</sup>lt;sup>b</sup> Based on 8,760 hr/yr operation.

<sup>&</sup>lt;sup>c</sup> Based on assuming 100 percent of SO<sub>3</sub> converts to H<sub>2</sub>SO<sub>4</sub> and using a molar ratio of (98/80).

<sup>&</sup>lt;sup>a</sup> Increase over baseline emissions of 136 TPY.

TABLE 4
PROJECTED ACTUAL SAM EMISSIONS WITH POTENTIAL FUEL SULFUR COMPARED TO BASELINE ACTUAL SAM EMISSIONS
MCINTOSH UNIT 3

						SAM Emissions <sup>a</sup>					Poten	ial Scena	ario with	3.4% Fuel 9	Sulfur <sup>d</sup>
Scenario	Unit Capacity	Gross Output	Heat Input	Fuel Sulfur	Sorbent Injection Rate	Generated in SCR	at ESP Inlet	at Stack	% Removal in APH <sup>b</sup>	% Removal in ESP and FGD <sup>c</sup>	Generated in SCR	at ESP Inlet	at Stack	Projected Actual SAM	Difference from Baseline Actual
	(%)	(MW)	(lb/MMBtu)	(%)	[lb/hr Ca(OH) <sub>2</sub> ]	(lb/hr)	(lb/hr)	(lb/hr)	(%)	(%)	(lb/hr)	(lb/hr)	(lb/hr)	(TPY)	(TPY)
1A	100	365	3571	1.55	0	63.4	24.1	8.7	62.1%	63.6%	139.1	52.8	19.2	84.1	-51.9
1B	100	365	3893	1.55	0	69.1	33.4	9.5	51.7%	71.4%	151.7	73.2	20.9	91.6	-44.4
1C	100	365	3908	1.55	0	64.6	38.3	9.6	40.7%	75.0%	141.8	84.0	21.0	92.0	-44.0
2A	88	320	3291	1.31	0	16.1	12.1	4.0	25.0%	66.7%	41.9	31.4	10.5	45.8	-90.2
2B	88	320	3240	1.31	0	37.7	13.9	4.0	63.2%	71.4%	97.9	36.1	10.3	45.1	-90.9
3A	74	270	2911	1.43	0	25.0	17.8	3.6	28.6%	80.0%	59.3	42.4	8.5	37.1	-98.9
3B	74	270	2928	1.43	0	28.7	10.8	3.6	62.5%	66.7%	68.2	25.6	8.5	37.4	-98.6
4	100	365	3807	1.72	120	44.3	23.3	9.3	47.4%	60.0%	87.6	46.1	18.4	80.8	-55.2
5	100	365	3825	1.72	360	51.5	21.1	9.4	59.1%	55.6%	101.9	41.7	18.5	81.1	-54.9
6	100	365	3822	1.72	240	72.6	42.1	9.4	41.9%	77.8%	143.5	83.3	18.5	81.1	-54.9
7	88	320	3287	1.31	105	30.2	8.1	4.0	73.3%	50.0%	78.4	20.9	10.5	45.8	-90.2
8	88	320	3285	1.31	316	38.2	6.0	4.0	84.2%	33.3%	99.2	15.7	10.4	45.7	-90.3
9	88	320	3288	1.31	211	42.3	10.1	4.0	76.2%	60.0%	109.8	26.1	10.5	45.8	-90.2
10	74	270	2938	1.43	89	36.0	9.0	3.6	75.0%	60.0%	85.6	21.4	8.6	37.5	-98.5
11	74	270	2960	1.43	267	39.9	9.1	3.6	77.3%	60.0%	94.8	21.6	8.6	37.8	-98.2
12	74	270	2961	1.43	179	36.3	9.1	3.6	75.0%	60.0%	86.2	21.6	8.6	37.8	-98.2

<sup>&</sup>lt;sup>a</sup> Based on Table 2.



<sup>&</sup>lt;sup>b</sup> Removal percentage in air pre-heater (APH) is calculated based on SAM emissions generated in the SCR and detected at ESP inlet.

<sup>&</sup>lt;sup>c</sup> Calculated based on SAM emissions rate detected at the stack and at the ESP inlet.

<sup>&</sup>lt;sup>u</sup> Calculated based on multiplying the actual SAM generated in SCR from the test results by the ratio of potential 3.4% fuel sulfur content and the actual sulfur content and using the actual SAM removal percentages in the APH and ESP from the test results.