

EMISSIONS TEST REPORT

POLK POWER STATION
FACILITY ID NUMBER: 1050233

IGCC – UNIT 1, EMISSIONS UNIT ID -001

NITROGEN OXIDES, SULFUR DIOXIDE, SULFURIC ACID MIST,
CARBON MONOXIDE, AND VISIBLE EMISSIONS

SULFURIC ACID PLANT, EMISSIONS UNIT ID -004

SULFUR DIOXIDE, SULFURIC ACID MIST AND VISIBLE
EMISSIONS

December 1, 2006

Prepared For:
Tampa Electric Company
Polk Power Station
P.O. Box 111
Tampa, Florida 33601-0111

Prepared By:
Tampa Electric Company
Environmental, Health and Safety
Environmental Services
Air Services Group



Environmental Services
Air Services Group
5010 Causeway Boulevard
Tampa, Florida 33619- 6130

2.0 DISCUSSION OF RESULTS

**Executive Summary
Tampa Electric Company
Polk Power Station
IGCC Combustion Turbine Unit 1 and Sulfuric Acid Plant
Emission Unit -001 and -004
Firing Petroleum Coke/Coal Gasification Syngas Fuel**

IGCC Combustion Turbine		
Compliance Parameter	Test Result	FDEP Permit Limit
NO _x , ppmvd @ 15% O ₂	13	15
NO _x , lbs/hr	113.37	132
SO ₂ , lb/mmBtu	0.12	0.17
SO ₂ , lbs/hr	207	357
H ₂ SO ₄ , lbs/hr	0.000	55
CO, ppmvd	2	25
CO, lbs/hr	12	98
VE, % Opacity	0	10
Calculated Heat Input, mmBtu/hr	1673	--
Permitted Heat Input, mmBtu/hr ¹	1733	--
Unit Capacity Factor, % of Permit ²	97%	90 – 100 %
Sulfuric Acid Plant		
SO ₂ , lbs/ton of acid produced	Three	Four
H ₂ SO ₄ , lbs/ton of acid produced	0.05	0.15
VE, % Opacity	0	10

¹ Permitted Heat Input Corrected to Inlet Vane Temperature.

² Calculated Heat Input divided by Permitted Heat Input, result times 100.

IGCC Combustion Turbine

Nitrogen Oxides (NO_x)

During the Sulfuric Acid Mist test time period (9:00 to 13:25) on the IGCC, the average NO_x concentration was 13 ppmvd @ 15% O₂, and the average emission rate was 113.37 lbs/hr. The permitted concentration and emission rate is 15 ppmvd @ 15% O₂, and 132 lbs/hr.



TAMPA ELECTRIC

January 12, 2007

Mr. J. Koerner
Florida Department of Environmental Protection
111 South Magnolia Drive, Suite 4
Tallahassee, FL 32301

Mr. Robert Soich
Florida Department of Environmental Protection, Southwest District
13051 N. Telecom Parkway
Temple Terrace, FL 33637

**Re: Tampa Electric Company (TEC)
Polk Power Station
Combustion Turbine Unit 1 and Sulfuric Acid Plant (SAP)
Stack Emission Compliance Test Trial #1
Permit No. 1050233-016-AV, 1050233-019-AC
AIRS #1050233, E.U. ID #001, #004**

RECEIVED

JAN 17 2007

BUREAU OF AIR REGULATION

Via FedEx
Airbill No. 7922 7199 5220

Via FedEx
Airbill No. 7912 0911 5024

Dear Mr. J. Koerner and Mr. R. Soich:

According to Condition 10 of Construction Air Permit No. 1050233-019-AC for each trial burn TEC is required to conduct emissions tests on the combustion turbine Unit 1 (E.U. 001) for CO, SAM, and visible emissions with the existing continuous emissions monitoring systems (CEMS) used to determine NO_x and SO₂ emissions. Additionally TEC is required to conduct emissions tests on the sulfuric acid plant (SAP) (E.U. 004) for SAM and SO₂ emissions concurrent to emissions tests on the combustion turbine.

The trial #1 burn testing was conducted while gasifying and firing a coal/petroleum coke blend of approximately (25/75). Per Condition 14, TEC shall file a report to the Compliance and Permitting Authority of the results of each test within 45 days of completing the last emissions test required for each test scenario.

Enclosed please find the emissions tests report for trial test #1 performed on December 1, 2006.

In addition to this letter, enclosed please find a revised page 2 for the baseline Stack Emission Compliance Test Report submitted to your department on December 19, 2006.

If you have any questions, please contact me Joshua Ellwein at (813) 228-4433.

Sincerely,

Joshua D. Ellwein
Air Programs
Environmental, Health & Safety

ENVP\Admin\STAKTEST\2007\ PPS102 Polk U1 & SAP Trial
#1 Stacktest Report

Enclosures

TAMPA ELECTRIC COMPANY
P. O. BOX 111 TAMPA, FL 33601-0111

(813) 228-4111

AN EQUAL OPPORTUNITY COMPANY
HTTP://WWW.TAMPAELECTRIC.COM

CUSTOMER SERVICE:
HILLSBOROUGH COUNTY (813) 223-0800
OUTSIDE HILLSBOROUGH COUNTY 1 (888) 223-0800

EMISSIONS TEST REPORT

POLK POWER STATION
FACILITY ID NUMBER: 1050233

IGCC – UNIT 1, EMISSIONS UNIT ID -001

NITROGEN OXIDES, SULFUR DIOXIDE, SULFURIC ACID MIST,
CARBON MONOXIDE, AND VISIBLE EMISSIONS

SULFURIC ACID PLANT, EMISSIONS UNIT ID -004

SULFUR DIOXIDE, SULFURIC ACID MIST AND VISIBLE
EMISSIONS

December 1, 2006

Prepared For:
Tampa Electric Company
Polk Power Station
P.O. Box 111
Tampa, Florida 33601-0111

Prepared By:
Tampa Electric Company
Environmental, Health and Safety
Environmental Services
Air Services Group



Environmental Services
Air Services Group
5010 Causeway Boulevard
Tampa, Florida 33619- 6130


REPORT CERTIFICATION

The sampling and subsequent data entry/reduction detailed in this report was conducted at my direction, and I hereby certify that this test report is authentic and accurate to the best of my knowledge.

Signature: 

Charles R. Dufeny
Environmental Technician
Test Team Lead
Air Services Group
Environmental Health & Safety
Tampa Electric Company

I have reviewed the test performance, associated quality assurance activities, the resultant calculations, and the contents of this report, and certify that all project quality objectives have been met. This report is approved for submittal.

Signature: 

Raymond A. McDarby, Jr.
Senior Environmental Technician
Quality Assurance/Quality Control Specialist
Air Services Group
Environmental Health & Safety
Tampa Electric Company

I have reviewed the testing details and results submitted in this report, and hereby certify that this test report is authentic and accurate to the best of my knowledge.

Signature: 

David A. Smith
Coordinator – Air Services Group
Environmental Health & Safety
Tampa Electric Company

TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE</u>
1.0 INTRODUCTION	1
2.0 DISCUSSION OF RESULTS	2
3.0 SOURCE DESCRIPTION	5
4.0 FUEL INFORMATION	6
5.0 TESTING PROCEDURES	8
6.0 TABULATED RESULTS	
<u>IGCC COMBUSTION TURBINE</u>	
NITROGEN OXIDES FROM CEMS	10
SULFUR DIOXIDE FROM CEMS	11
SULFURIC ACID MIST DATA SUMMARY	12
CARBON MONOXIDE DATA SUMMARY	13
HEAT INPUT CALCULATION	14
<u>SULFURIC ACID PLANT</u>	
SULFUR DIOXIDE DATA SUMMARY	15
SULFURIC ACID MIST DATA SUMMARY	16
7.0 FIGURES	
FIGURE 1 SULFURIC ACID PLANT SAMPLING LOCATION	18
FIGURE 2 IGCC SAMPLING LOCATION	19

LIST OF TABLES

EXECUTIVE SUMMARY	2
TABLE 1 – FUEL INFORMATION, BLEND COAL	6
TABLE 2 – FUEL INFORMATION, BASELINE BLENDED FUEL	7

APPENDICIES

APPENDIX A – IGCC CEMS DATA – SO ₂ , NO _x , CO ₂ , STACK FLOW	
APPENDIX B – SULFURIC ACID MIST TEST DATA – IGCC	
FIELD DATA SHEETS	
CALCULATED DATA	
LABORATORY ANALYSIS	
CALIBRATION DATA	

APPENDIX C – SULFURIC ACID MIST TEST DATA – SULFURIC ACID PLANT
FIELD DATA SHEETS
CALCULATED DATA
LABORATORY ANALYSIS
CALIBRATION DATA

APPENDIX D – INSTRUMENTAL REFERENCE METHOD TEST DATA – IGCC
OXYGEN, CARBON DIOXIDE, CARBON MONOXIDE DATA
CALIBRATION GAS CERTIFICATIONS

APPENDIX E – INSTRUMENTAL REFERENCE METHOD TEST DATA – SULFURIC
ACID PLANT
SULFUR DIOXIDE, OXYGEN, CARBON DIOXIDE SUMMARY
QUALITY ASSURANCE ACTIVITIES
RUN LOG
CALIBRATION GAS CERTIFICATIONS

APPENDIX F – FUEL ANALYSIS
SYNTHETIC GAS ANALYSIS – DECEMBER 1, 2006

APPENDIX G – PLANT OPERATIONS DATA
IGCC
SULFURIC ACID PLANT

APPENDIX H – VISIBLE EMISSIONS OBSERVATIONS
IGCC
SULFURIC ACID PLANT

APPENDIX I – CHAIN OF CUSTODY

APPENDIX J – PROJECT PARTICIPANTS

1.0 INTRODUCTION

On December 01, 2006, Tampa Electric Company's Air Services Group (ASG), and Trigon Engineering Consultants performed relative concurrent emissions testing on Polk Power Station's Integrated Gasification and Combined Cycle (IGCC) Combustion Turbine (Unit 1, E.U. 001), and it's attendant Sulfuric Acid Plant (SAP, E.U. 004). Testing was conducted as part of the project specified in Florida Department of Environmental Protection (FDEP) Draft Air Permit No. 1050233-019-AC. The permitted emissions limits and test methodologies are consistent with the requirements of Title V Permit No. 1050233-016-AV. This specific test was conducted with a blended fuel content of 75% petroleum coke/25% coal gasification. For the purposes of Permit No. 1050233-019-AC this test establishes emissions for test burn scenario number 1 for Nitrogen Oxides (NO_x, IGCC only), Sulfur Dioxide (SO₂, SAP and IGCC), Sulfuric Acid Mist (H₂SO₄, SAP and IGCC), Carbon Monoxide (CO, IGCC), and Visible Emissions (SAP and IGCC). All testing was performed using approved United States Environmental Protection Agency (USEPA) Reference Methods. SO₂ and NO_x for E.U. 001 were provided by the installed, certified Continuous Emissions Monitoring (CEM) system.

2.0 DISCUSSION OF RESULTS

**Executive Summary
Tampa Electric Company
Polk Power Station
IGCC Combustion Turbine Unit 1 and Sulfuric Acid Plant
Emission Unit -001 and -004
Firing Petroleum Coke/Coal Gasification Syngas Fuel**

IGCC Combustion Turbine		
Compliance Parameter	Test Result	FDEP Permit Limit
NO _x , ppmvd @ 15% O ₂	13	15
NO _x , lbs/hr	113.37	132
SO ₂ , lb/mmBtu	0.12	0.17
SO ₂ , lbs/hr	207	357
H ₂ SO ₄ , lbs/hr	0.000	55
CO, ppmvd	2	25
CO, lbs/hr	12	98
VE, % Opacity	0	10
Calculated Heat Input, mmBtu/hr	1673	--
Permitted Heat Input, mmBtu/hr ¹	1733	--
Unit Capacity Factor, % of Permit ²	97%	90 – 100 %
Sulfuric Acid Plant		
SO ₂ , lbs/ton of acid produced	Three	Four
H ₂ SO ₄ , lbs/ton of acid produced	0.05	0.15
VE, % Opacity	0	10

¹ Permitted Heat Input Corrected to Inlet Vane Temperature.

² Calculated Heat Input divided by Permitted Heat Input, result times 100.

IGCC Combustion Turbine

Nitrogen Oxides (NO_x)

During the Sulfuric Acid Mist test time period (9:00 to 13:25) on the IGCC, the average NO_x concentration was 13 ppmvd @ 15% O₂, and the average emission rate was 113.37 lbs/hr. The permitted concentration and emission rate is 15 ppmvd @ 15% O₂, and 132 lbs/hr.

was 207 lbs/hr. The permitted concentration and emission rate is 0.17 lb/mmBtu and 357 lbs/hr.

Sulfuric Acid Mist (H₂SO₄)

The Sulfuric Acid Mist test was conducted from 9:00 to 13:25. The average H₂SO₄ emission rate for the test period was 34 pounds per hour. The permitted emission rate is 55 lbs/hr.

Carbon Monoxide (CO)

During the Sulfuric Acid Mist test time period (9:00 to 13:25) on the IGCC, the average CO concentration was 2 ppmvd, and the average emission rate was 12 lbs/hr. The permitted concentration and emission rate is 25 ppmvd, and 98 lbs/hr.

Visible Emissions

The Visible Emissions test was conducted from 10:10 through 10:40. The average opacity from the IGCC was 0%. The permitted opacity from this source is 10%.

Heat Input

During the test the IGCC was operated at an average heat input of 1673 mmBtu/hr. The FDEP permitted heat input is 1755 mmBtu/hr, at an ambient temperature of 59° (corrected to 1733 mmBtu/hr based on an average inlet vane temperature of 81°F, and the manufacturer's heat input correction curve for this unit). The calculated capacity factor during the test was 97% of the FDEP permitted heat input.

Sulfuric Acid Plant

Sulfur Dioxide SO₂

During the Sulfuric Acid Mist test time period (9:00 to 13:32) on the SAP, the average SO₂ emission rate was three pounds per ton of 100% acid produced. The permitted emission rate is four pounds per ton of 100 percent acid produced.

Sulfuric Acid Mist (H₂SO₄)

The Sulfuric Acid Mist test was conducted from 9:00 to 13:32. The average H₂SO₄ emission rate for the test period was 0.05 pound per ton of 100 percent

acid produced. The permitted emission rate is 0.15 pound per ton of 100 percent acid produced.

Visible Emissions

The Visible Emissions test was conducted from 10:10 through 10:40. The average opacity from the Sulfuric Acid Plant was 0%. The permitted opacity from this source is 10%.

3.0 SOURCE DESCRIPTION

The Polk Power Station facility is located at 9995 State Road 37 South, Mulberry, Polk County, Florida. The UTM Coordinates are, Zone 17, 402.45 km East and 3067.35 km North. Title V Air Operation Permit No. 1050233-016-AV regulates the emissions from this facility.

The Sulfuric Acid Plant at this facility takes the sulfur gas stream from the solid fuel gasification plant's hot or cold gas cleanup systems and converts it to sulfuric acid using a double contact process. The sulfuric acid plant has a 15 MMBtu/hr, propane fired, H₂S to SO₂ conversion furnace, and a 9 MMBtu/hr, propane fired non-contact SO₂ to SO₃ converter pre-heater, which vents to the atmosphere through a 198-foot exhaust stack. The exhaust stack is designed to maintain ultra low flow velocities to prevent sulfuric acid liquid from becoming entrained in the exhaust stream, eliminating the emissions of acid droplets. A diagram of the exhaust stack is included as Figure 1 in this report.

Unit No. 1 is an Integrated Gasification Combined Cycle Combustion Turbine generating unit, with a net capacity of 192 MW when fired with Syngas fuel. The source sampling location consists of a circular stack 19 feet in diameter with four sample ports located 90 degrees apart on the stack circumference. A diagram of the stack sampling location is included as Figure 2 in this report.

4.0 FUEL INFORMATION

Blending Procedure

Coal and petroleum coke for Polk Power Station are blended at Tampa Electric's Big Bend Power Station and delivered by truck to the Polk site. Blending is accomplished as follows. Polk's blend coal is stored in a dedicated pile at Big Bend Power Station. As each petroleum coke barge is received and unloaded using a conveyor system with a calibrated scale, coal is reclaimed from the coal pile, weighed and blended with the petroleum coke on the unloading conveyor. The blended fuel is stored in a separate dedicated blended fuel bin for Polk. The sulfur content and other parameters of the blended fuel are measured using ASTM methods on each barge of petroleum coke and coal (individually) and calculated based on their ratio in the blended fuel.

Coal

The coal portion of the blended fuel for the November 8 stack tests was assumed to be an equal mixture of the previous two coal shipments (August 9, 2006 and October 4, 2006) for Polk Power Station. The composition of each shipment is shown in Table 1 below.

Fuel Analysis (As Received Basis)	Units	Coal Shipment 8/9/06	Coal Shipment 10/4/06	Coal Mixture
Total Moisture	Wt %	11.10	14.06	12.58
Ash	Wt %	10.96	10.88	10.92
Carbon	Wt %	62.03	59.83	60.93
Hydrogen	Wt %	4.29	4.13	4.21
Nitrogen	Wt %	1.40	1.37	1.39
Sulfur	Wt %	0.64	0.64	0.64
Chlorine	Wt %	0.02	0.02	0.02
Oxygen (By Difference)	Wt %	9.56	9.08	9.32
Volatiles	Wt %	33.10	32.90	33.00
Fixed Carbon	Wt %	44.84	42.16	43.50
HHV	Btu/lb	11,044	10,651	10,848

Table 1 Blend Coal

Blended Fuel

The fuel consumed during this stack test was from the blend the petroleum coke barge received on November 17, 2006, as well as the coal blend detailed in Table 1. The petroleum coke analysis, the calculated composition of the coal blend, and the calculated composition of the final blend are shown in Table 2. The tonnages of both the petroleum coke and coal blend from the Big Bend certified scales used in the blending operation are also included in Table 2.

Fuel Analysis (As Received Basis)	Units	Blend Coal	Petroleum Coke Barge	Blended Fuel
Quantity	Tons	4,154	12,396	16,550
Total Moisture	Wt %	12.58	5.59	7.34
Ash	Wt %	10.92	0.49	3.11
Carbon	Wt %	60.93	82.54	77.12
Hydrogen	Wt %	4.21	3.49	3.67
Nitrogen	Wt %	1.39	1.68	1.61
Sulfur	Wt %	0.64	4.97	3.88
Chlorine	Wt %	0.02	0.01	0.01
Oxygen	Wt %	9.32	1.23	3.26
Volatiles	Wt %	33.00	9.42	15.34
Fixed Carbon	Wt %	43.50	84.50	74.21
HHV	BTU/Lb	10,848	14,272	13,412

Table 2 Blended Fuel

5.0 TESTING PROCEDURES

Nitrogen Oxides (NO_x) and Sulfur Dioxide (SO₂) data for the IGCC for the test period was supplied by the installed, certified CEM system on that unit.

Sulfur Dioxide (SO₂) data for the SAP was derived from 3 United States Environmental Protection Agency (USEPA) Reference Method 6C – “DETERMINATION OF SULFUR DIOXIDE EMISSIONS FROM STATIONARY SOURCES (INSTRUMENTAL ANALYZER PROCEDURE)” test runs.

Sulfuric Acid Mist (H₂SO₄) data for the IGCC, and the SAP were derived from 3 USEPA Reference Method 8 – “DETERMINATION OF SULFURIC ACID MIST AND SULFUR DIOXIDE EMISSIONS FROM STATIONARY SOURCES” test runs.

Carbon Monoxide (CO) data for the IGCC was derived from 3 USEPA Reference Method 10 – “DETERMINATION OF CARBON MONOXIDE EMISSIONS FROM STATIONARY SOURCES (INSTRUMENTAL ANALYZER PROCEDURE)” test runs.

Visible Emissions data for the IGCC and SAP were derived from 30-minute visible emissions observations using USEPA Reference Method 9 – “VISUAL DETERMINATION OF THE OPACITY OF EMISSIONS FROM STATIONARY SOURCES” test runs. These tests were conducted concurrently.

6.0 TABULATED RESULTS



**POLK POWER STATION - INTEGRATED GASIFICATION COMBINED CYCLE
NITROGEN OXIDES FROM CEMS DATA SUMMARY**

**IGCC COMBUSTION TURBINE - UNIT 1
December 01, 2006**

Test Period Start Time: 9:00 Test Period Stop Time: 13:20

CEMS Data

Average NO_x, ppmvw for Test Period: 19.41 ppmvw
Average NO_x, ppmvd @ 15% O₂ for Test Period: 12.97 ppmvd@ 15% O₂
Average Stack Flow for Test Period: 815.39 kscfm

Calculated Data

NO_x, lbs/hr: 113.37 lbs/hr

NO_x in lbs/hr is calculated as:

NO_x, ppmvw x 1.194E-07 x Stack Flow, kscfm x 1,000/k x 60 min/hr



**POLK POWER STATION - INTEGRATED GASIFICATION COMBINED CYCLE
SULFUR DIOXIDE FROM CEMS DATA SUMMARY**

**IGCC COMBUSTION TURBINE - UNIT 1
December 01, 2006**

Test Period Start Time: 9:00 Test Period Stop Time: 13:20

CEMS Data

Average SO₂, ppmvw for Test Period: 38.62 ppmvw
Average CO₂, % volume for Test Period: 8.42 % volume

Calculated Data

Heat Input: 1673 mmBtu/hr
SO₂, lb/mmBtu 0.12 lb/mmBtu
SO₂, lbs/hr: 206.69 lbs/hr

SO₂ in lb/mmBtu is calculated as:

SO₂, ppmvw x 1.660E-07 x Fc x (100/CO₂, %)

Where:

Fc= 2310 scf/mmBtu

SO₂ in lbs/hr is calculated as:

SO₂, lb/mmBtu x Heat Input, mmBtu/hr



**POLK POWER STATION - INTEGRATED GASIFICATION COMBINED CYCLE
SULFURIC ACID MIST DATA SUMMARY**

IGCC COMBUSTION TURBINE - UNIT 1 December 01, 2006

	<u>Run #1</u>	<u>Run #2</u>	<u>Run #3</u>	<u>Average</u>
Gas Flow Rates				
Q _{s,r} , acfm:	1349432.0	1382717.2	1363572.9	1365240.71
Q _{s(std),r} , dscfm:	870502.8	894697.9	891298.5	885499.77
Sampled Volume, V _{m(std),r} , dscf:	43.56	45.34	44.34	44.417
Stack Moisture, B _{ws} × 100, %:	5.83	5.61	5.22	5.554
Isokinetic Sampling Rate, I, %:	99.3	98.6	98.7	98.87
<hr/>				
C _{H2SO4,r} , lb/dscf:	7.922E-07	6.100E-07	4.931E-07	6.318E-07
Q _{s(std),r} , dscfm:	870502.8	894697.9	891298.5	885499.8
E _{H2SO4,r} , lbs/hr:	41.377	32.748	26.369	33.566

Emission Rate Calculated as C_{H2SO4} × Q_{s(std)} × 60 minutes/hr



**POLK POWER STATION - INTEGRATED GASIFICATION COMBINED CYCLE
CARBON MONOXIDE DATA SUMMARY**

IGCC COMBUSTION TURBINE - UNIT 1 December 01, 2006

Run Number	Test Times		CO ppmvd	O2 % volume	CO ppmvd@15% O2	CO lbs/hr
	Start	Stop				
1	9:00	10:00	3.490	11.916	2.292	12.381
2	10:45	11:45	3.236	11.969	2.138	11.480
3	12:20	13:20	3.168	11.998	2.100	11.239
Averages :					2.1765	11.6998

CO, ppmvd @ 15% O2 is calculated as:

$$\text{CO, ppmvd} \times (5.9 / (20.9 - \text{O2, \% volume}))$$

CO, lbs/hr is calculated as:

$$\text{CO, ppmvd} \times \text{Cf} \times \text{Stack Flow} \times 1000/\text{k} \times 60 \text{ minutes/hr}$$

Where:

$$\text{Cf} = 7.272\text{E-}08$$

$$\text{Stack Flow} = 813.0043 \text{ kscfm}$$



**POLK POWER STATION - INTEGRATED GASIFICATION COMBINED CYCLE
HEAT INPUT CALCULATION**

**IGCC COMBUSTION TURBINE - UNIT 1
December 01, 2006**

Average fuel flow: 6653.6337 Kcfh
Mole weight correction to meter cal: 0.9883 mole weight correction factor
Corrected fuel flow:¹ 6575.7862 Kcfh, corrected for density
Average moisture: 0.0380883 % H₂O added to fuel
Corrected fuel flow:² 6400.2082 Kscfh, corrected for moisture
Gross heating value of fuel (HHV): 261.44 Btu/scf
Heat Input: 1673 mmBtu/hr

Average fuel flow from Plant Information Data Base.

Mole weight correction factor to meter calibration is taken from ratio of syngas mole weight to calibration gas mole weight.

¹Average fuel flow times mole weight correction factor.

²Corrected fuel flow times (1 - (Average moisture / 100)).

Gross Heating value of fuel (HHV) is from fuel analysis.

Heat input is (HHV x Corrected fuel flow) / 1000.



Environmental Services
Air Services Group

**POLK POWER STATION
SULFUR DIOXIDE CALCULATIONS**

**SULFURIC ACID PLANT
December 1, 2006**

Data Calculated from Plant Operational Measurements:

	<u>Run 1</u>	<u>Run 2</u>	<u>Run 3</u>	
Gallons of Acid Produced During The Test Period, P _{gal} =	1420.310	1429.168	1445.304	gallons
Density of Water, D =	8.345	8.345	8.345	lbs/gallon
Specific Gravity of Sulfuric Acid, SG =	1.84	1.84	1.84	dimensionless
Average Concentration of Acid Produced, C _{acid} =	93.502	93.505	93.497	%
Tons of Acid Produced During The Test Period, P _{st} =	10.196	10.260	10.375	short tons

Where:

$$\text{Tons of acid produced} = (P_{gal} \times D \times SG \times (C_{acid})) / 2000 \text{ lbs/ton}$$

Data Calculated from Stack Measurements:

Volumetric Flow Rate Through Stack, Q _{std} =	1041010.5	1044157.8	1099216.3	dscf/hr
Sulfur Dioxide Concentration in Stack, C _{SO2} =	186.36	189.31	193.86	ppmvd
Sulfur Dioxide Concentration in Stack, C _{SO2} =	3.094E-05	3.143E-05	3.218E-05	lbs/scf
Sulfur Dioxide Emission Rate, E _{SO2} =	3.16	3.20	3.41	lbs/ton of acid
Average Sulfur Dioxide Emission Rate, E _{SO2} =		3.26		lbs/ton of acid

Where:

$$C_{SO2} \text{ lbs/scf} = C_{SO2, ppm} \times 1.66E-07$$

$$E_{SO2} = (C_{SO2, lbs/scf} \times Q_{std}) / \text{tons of acid produced}$$




40 CFR 60, Appendix A - Test Methods
Reference Method 8
Test Summary

Customer: Polk Power Station
Facility: Acid Plant
Sampling Location: Stack
Operating Conditions: Compliance Load
Test Date: December 1, 2006

	<u>Run #1</u>	<u>Run #2</u>	<u>Run #3</u>	<u>Average</u>
Gas Flow Rates				
Q _s , acfm:	19131.0	19441.3	19290.9	19287.72
Q _{s(std)} , dscfm:	16368.1	16729.3	16459.3	16518.89
Sampled Volume, V _{m(std)} , dscf:	45.70	47.18	46.91	46.6
Stack Moisture, B _{ws} × 100, %:	0.46	-0.05	0.81	0.41
Isokinetic Sampling Rate, I, %:	94.2	95.2	96.2	95.2
<hr/>				
C _{H₂SO₄} , lbs/dscf:	5.76602E-07	5.7521E-07	5.33604E-07	5.62E-07
Tons of Acid Produced:	12.23	11.21	11.17	11.535
E lbs H ₂ SO ₄ /ton of 100% acid:	0.049	0.055	0.050	0.0516
E _{H₂SO₄} lbs/ton of acid is calculated as:				
$(C_{H_2SO_4}, \text{lb/dscf} \times Q_{s(std)}, \text{dscfm} \times 60 \text{ minutes/hr}) / \text{Tons of Acid Produced}$				

7.0 FIGURES

**POLK POWER STATION
UNIT NO.1 ACID PLANT TEST LOCATION
SAMPLING TRAVERSE POINTS**




TRAVERSE POINTS	% OF STACK DIAMETER	IN. FROM STACK WALL
1	3.2 %	2.30
2	10.5 %	7.56
3	19.4 %	13.97
4	32.3 %	23.26
5	67.7 %	48.74
6	80.6 %	58.03
7	89.5 %	64.44
8	96.8 %	69.70

STACK DIAMETERS DOWNSTREAM FROM DISTURBANCE = 4.2

STACK DIAMETERS UPSTREAM FROM DISTURBANCE = 5.8

STACK DIAMETER = 6.0 FT. ID.
STACK AREA = 28.274 SQ. FT


PORT LENGTH = 5.0 IN.



PORT LOCATION PLAN

Source is Monsanto Enviro-Chem Drawing no. 511-150 v. 2

Figure 1



APPENDIX A

IGCC CEMS DATA
SO₂, NO_x, CO₂, STACK FLOW

HRSO CEMS Data

Date Time	SO21	NOX1	PC1NOXC1	FLO1	CO21
12/1/2006 9:00	34.8	18.2	12.103	815.8	8.6
12/1/2006 9:01	33.69	19.1	12.629	808.4	8.6
12/1/2006 9:02	35.26	19.7	13.097	817.1	8.6
12/1/2006 9:03	34.88	19.9	13.308	827.5	8.6
12/1/2006 9:04	35.12	19.6	12.986	800.9	8.6
12/1/2006 9:05	35.79	18.3	12.213	795.3	8.6
12/1/2006 9:06	35.05	18.1	11.905	804.4	8.6
12/1/2006 9:07	36.82	18.7	12.371	819	8.6
12/1/2006 9:08	37.65	19	12.502	812.8	8.6
12/1/2006 9:09	37.65	19.3	12.796	817.5	8.6
12/1/2006 9:10	38.79	17.8	11.795	813.2	8.5
12/1/2006 9:11	36.15	17.9	11.751	808.2	8.5
12/1/2006 9:12	37.01	18.8	12.268	818.2	8.5
12/1/2006 9:13	37.37	19.3	12.769	795.7	8.5
12/1/2006 9:14	37.99	19.7	13.097	809	8.5
12/1/2006 9:15	38.36	19.2	12.881	817.9	8.5
12/1/2006 9:16	38.76	19	12.708	804.2	8.5
12/1/2006 9:17	39.7	19.3	12.828	799.6	8.5
12/1/2006 9:18	39.26	19.6	13.003	811	8.5
12/1/2006 9:19	40.05	19.3	12.918	809.3	8.5
12/1/2006 9:20	37.73	18	11.883	818.2	8.5
12/1/2006 9:21	35.59	19	12.495	822.3	8.5
12/1/2006 9:22	35.44	19.7	13.142	826.7	8.5
12/1/2006 9:23	36.38	19.7	13.075	826.9	8.5
12/1/2006 9:24	37.57	20	13.287	814.6	8.4
12/1/2006 9:25	36.21	18.7	12.532	809.5	8.5
12/1/2006 9:26	35.85	18.3	12.038	813.9	8.5
12/1/2006 9:27	36.37	18.8	12.485	816.5	8.4
12/1/2006 9:28	38.04	19.6	12.952	817.4	8.4
12/1/2006 9:29	38.34	19.8	13.201	800.4	8.5
12/1/2006 9:30	37.06	18.2	12.179	800.2	8.4
12/1/2006 9:31	34.55	18	11.751	804.5	8.5
12/1/2006 9:32	35.43	18.8	12.423	807.6	8.5
12/1/2006 9:33	37.54	18.9	12.56	802.2	8.5
12/1/2006 9:34	37.59	19.3	12.8	811.4	8.4
12/1/2006 9:35	38.17	19.1	12.62	802.6	8.5
12/1/2006 9:36	37.86	18.8	12.479	813.7	8.5
12/1/2006 9:37	39.02	19.1	12.708	826.2	8.5
12/1/2006 9:38	39.14	19.4	12.863	826	8.4
12/1/2006 9:39	38.48	19.4	12.92	822.9	8.4

HRSG CEMS Data

Date Time	SO21	NOX1	PC1NOXC1	FLO1	CO21
12/1/2006 9:40	38.42	18.1	12.093	816.7	8.5
12/1/2006 9:41	36.99	18.8	12.396	806.2	8.5
12/1/2006 9:42	37.08	19.5	12.986	808.2	8.5
12/1/2006 9:43	38.53	20.1	13.342	811	8.5
12/1/2006 9:44	39.21	20.1	13.381	804.9	8.5
12/1/2006 9:45	39.34	18.7	12.511	803.1	8.5
12/1/2006 9:46	36.84	18.4	12.229	806.1	8.5
12/1/2006 9:47	36.51	19.1	12.674	811.2	8.5
12/1/2006 9:48	36.88	19.6	13.088	815.4	8.5
12/1/2006 9:49	38.98	19.9	13.234	803.5	8.5
12/1/2006 9:50	38.1	18.4	12.366	818.9	8.5
12/1/2006 9:51	37.4	18	11.896	830.4	8.5
12/1/2006 9:52	36.99	19.2	12.763	821.4	8.5
12/1/2006 9:53	38.35	19.6	13.03	817.8	8.5
12/1/2006 9:54	38.15	19.4	12.997	811.1	8.5
12/1/2006 9:55	38.39	19.4	12.975	794.1	8.5
12/1/2006 9:56	38.69	19.5	13.008	814.5	8.5
12/1/2006 9:57	38.28	19.6	13.086	815.8	8.5
12/1/2006 9:58	40.38	19.5	13.008	818.5	8.5
12/1/2006 9:59	39.88	19.3	12.807	815	8.5
12/1/2006 10:00	38.52	18.4	12.282	812.7	8.5
12/1/2006 10:01	37.67	19.1	12.685	817.3	8.5
12/1/2006 10:02	38.14	19.9	13.231	817.4	8.5
12/1/2006 10:03	38.39	20.3	13.542	823.2	8.5
12/1/2006 10:04	37.85	19.9	13.308	818.2	8.5
12/1/2006 10:05	36.29	19	12.852	818.6	8.5
12/1/2006 10:06	35.85	18.9	12.529	826.2	8.5
12/1/2006 10:07	36.68	19.4	12.919	814.5	8.5
12/1/2006 10:08	37.61	19.4	12.919	821.5	8.5
12/1/2006 10:09	38.05	19.7	13.05	799.8	8.5
12/1/2006 10:10	37.02	18.7	12.499	807.6	8.5
12/1/2006 10:11	35.88	18.3	12.095	807.8	8.5
12/1/2006 10:12	36.17	19	12.629	815.2	8.5
12/1/2006 10:13	37.55	19.6	13.03	824.5	8.5
12/1/2006 10:14	36.85	20	13.353	794.8	8.5
12/1/2006 10:15	36.52	19.6	13.108	832.3	8.5
12/1/2006 10:16	37.27	19.3	12.897	799.6	8.5
12/1/2006 10:17	38.22	19.7	13.075	813.1	8.5
12/1/2006 10:18	37.81	20	13.308	818.2	8.5
12/1/2006 10:19	37.75	20	13.32	784	8.5

HRSO CEMS Data

Date Time	SO21	NOX1	PC1NOXC1	FLO1	CO21
12/1/2006 10:20	36.72	18.4	12.339	818.3	8.5
12/1/2006 10:21	38.12	19.4	12.808	817.1	8.5
12/1/2006 10:22	36.33	19.8	13.208	808.4	8.5
12/1/2006 10:23	37.84	20.1	13.386	828	8.5
12/1/2006 10:24	38.7	20.1	13.442	818.6	8.5
12/1/2006 10:25	37.6	19.2	12.975	836.5	8.5
12/1/2006 10:26	37.12	19	12.574	825.6	8.5
12/1/2006 10:27	36.27	19.5	12.997	829.3	8.5
12/1/2006 10:28	37.84	19.8	13.231	830.8	8.5
12/1/2006 10:29	38.24	20	13.326	819.7	8.5
12/1/2006 10:30	39.28	18.8	12.645	816.4	8.5
12/1/2006 10:31	37.41	18.2	12.106	807.5	8.5
12/1/2006 10:32	37.22	19.3	12.752	798.2	8.5
12/1/2006 10:33	39.15	19.7	13.175	805.1	8.5
12/1/2006 10:34	38.18	19.6	13.153	792.1	8.5
12/1/2006 10:35	39.78	19.7	13.164	809.6	8.5
12/1/2006 10:36	37.88	19.7	13.186	813.6	8.5
12/1/2006 10:37	38.02	19.7	13.142	805.6	8.5
12/1/2006 10:38	39.94	20.1	13.427	800.8	8.5
12/1/2006 10:39	38.72	19.9	13.32	811.4	8.5
12/1/2006 10:40	38.06	18.5	12.348	805.1	8.5
12/1/2006 10:41	36.68	19.4	12.808	814.5	8.5
12/1/2006 10:42	38.53	19.8	13.247	811	8.5
12/1/2006 10:43	40.43	20.2	13.464	801.9	8.5
12/1/2006 10:44	39.46	20	13.412	801.8	8.5
12/1/2006 10:45	41.16	19.3	12.986	826.1	8.5
12/1/2006 10:46	37.08	19.2	12.741	824.2	8.5
12/1/2006 10:47	38.24	19.8	13.186	820.1	8.5
12/1/2006 10:48	37.76	20	13.308	820.9	8.5
12/1/2006 10:49	39.51	20.2	13.495	816.1	8.5
12/1/2006 10:50	38.31	19	12.73	803.8	8.5
12/1/2006 10:51	38.44	18.4	12.274	827.6	8.5
12/1/2006 10:52	37.13	19.2	12.752	817.1	8.5
12/1/2006 10:53	39.58	19.7	13.141	809.8	8.5
12/1/2006 10:54	40.02	20	13.364	813.7	8.5
12/1/2006 10:55	38.56	19.7	13.197	810.8	8.5
12/1/2006 10:56	37.83	19.4	12.964	810.3	8.5
12/1/2006 10:57	38.63	19.7	13.119	812.6	8.5
12/1/2006 10:58	39.02	19.8	13.255	802.2	8.5
12/1/2006 10:59	40.59	19.9	13.286	803.2	8.5

HRSO CEMS Data

Date Time	SO21	NOX1	PC1NOXC1	FLO1	CO21
12/1/2006 11:00	39.45	18.6	12.496	813.6	8.5
12/1/2006 11:01	37.26	19.2	12.818	818.4	8.5
12/1/2006 11:02	38.14	20	13.461	817	8.5
12/1/2006 11:03	39.73	20.4	13.663	823.1	8.5
12/1/2006 11:04	41.34	20.6	13.851	813	8.5
12/1/2006 11:05	42.09	19.7	13.264	815	8.5
12/1/2006 11:06	38.89	19.3	12.863	822	8.5
12/1/2006 11:07	38.05	19.8	13.164	810.1	8.5
12/1/2006 11:08	39.79	19.9	13.359	823.6	8.5
12/1/2006 11:09	40.48	20.1	13.412	810.4	8.5
12/1/2006 11:10	39.15	19	12.815	816.4	8.5
12/1/2006 11:11	38.2	18.7	12.396	820.2	8.5
12/1/2006 11:12	38.66	19.6	13.019	817.3	8.5
12/1/2006 11:13	39.93	20	13.331	813.7	8.5
12/1/2006 11:14	41.11	20	13.353	820.2	8.5
12/1/2006 11:15	40.19	19.8	13.208	820.7	8.5
12/1/2006 11:16	41.19	20.1	13.356	827	8.5
12/1/2006 11:17	41.04	20.3	13.52	823.5	8.5
12/1/2006 11:18	41.59	20.2	13.497	827.3	8.5
12/1/2006 11:19	41.86	19.8	13.242	825.9	8.5
12/1/2006 11:20	39.7	18.6	12.496	819.8	8.5
12/1/2006 11:21	37.86	19.4	12.808	821	8.5
12/1/2006 11:22	40.31	20	13.458	810.6	8.5
12/1/2006 11:23	40.91	20.2	13.618	795.1	8.5
12/1/2006 11:24	40.92	20.7	13.865	815.8	8.5
12/1/2006 11:25	40.49	19.8	13.475	823.2	8.5
12/1/2006 11:26	40.04	19	12.663	821.7	8.5
12/1/2006 11:27	38.35	19.6	13.117	833.8	8.5
12/1/2006 11:28	40.4	20.1	13.4	803.6	8.5
12/1/2006 11:29	40.59	20.2	13.535	821.4	8.5
12/1/2006 11:30	39.55	19.2	12.98	813.8	8.5
12/1/2006 11:31	38.4	18.7	12.418	817.3	8.5
12/1/2006 11:32	38.38	19.5	12.875	811	8.5
12/1/2006 11:33	38.7	20	13.37	816.2	8.5
12/1/2006 11:34	38.83	20.1	13.426	830.4	8.5
12/1/2006 11:35	39.94	19.8	13.253	818.4	8.5
12/1/2006 11:36	40.8	19.9	13.211	823.4	8.5
12/1/2006 11:37	40.09	20.4	13.753	817.5	8.5
12/1/2006 11:38	39.7	20.1	13.512	817.5	8.5
12/1/2006 11:39	40.99	20	13.431	815	8.5

HRSG CEMS Data

Date Time	SO21	NOX1	PC1NOXC1	FLO1	CO21
12/1/2006 11:40	39.22	18.8	12.607	811	8.5
12/1/2006 11:41	37.29	19.3	12.835	816.8	8.5
12/1/2006 11:42	38.64	20	13.517	812.8	8.5
12/1/2006 11:43	39.19	20.4	13.694	829.2	8.5
12/1/2006 11:44	39.45	20.6	13.791	837.7	8.5
12/1/2006 11:45	41.77	19.4	13.13	813.1	8.5
12/1/2006 11:46	39.85	18.9	12.574	832.3	8.5
12/1/2006 11:47	40.24	19.7	13.053	831.5	8.5
12/1/2006 11:48	40.35	20	13.393	819.8	8.5
12/1/2006 11:49	39.44	20.4	13.627	796.9	8.5
12/1/2006 11:50	38.95	19.3	12.973	803.8	8.5
12/1/2006 11:51	37.53	18.5	12.318	792	8.5
12/1/2006 11:52	37.53	19.4	12.875	797.4	8.5
12/1/2006 11:53	37.93	19.6	13.111	793	8.5
12/1/2006 11:54	38.49	19.8	13.317	818.5	8.5
12/1/2006 11:55	38.35	19.8	13.247	809.6	8.5
12/1/2006 11:56	39.14	19.6	13.147	798.9	8.5
12/1/2006 11:57	39.83	20.1	13.448	832.7	8.5
12/1/2006 11:58	40.15	20.2	13.498	823.1	8.5
12/1/2006 11:59	40.63	20.2	13.433	823.3	8.5
12/1/2006 12:00	39.59	18.5	12.471	824	8.5
12/1/2006 12:01	37.36	19.4	12.819	826.5	8.5
12/1/2006 12:02	37.82	20	13.345	814.6	8.5
12/1/2006 12:03	38.64	20	13.379	824.8	8.5
12/1/2006 12:04	40.52	20.3	13.486	833.9	8.5
12/1/2006 12:05	39.86	19.5	13.141	799.1	8.5
12/1/2006 12:06	38.66	19.1	12.73	788.8	8.5
12/1/2006 12:07	37.46	19.6	13.119	800	8.5
12/1/2006 12:08	40.02	19.9	13.396	813.4	8.5
12/1/2006 12:09	40.41	19.9	13.3	809.7	8.5
12/1/2006 12:10	41.14	18.8	12.73	800.4	8.5
12/1/2006 12:11	39.08	18	11.984	803.2	8.5
12/1/2006 12:12	38.82	18.9	12.496	827.2	8.5
12/1/2006 12:13	39.55	19.5	13.019	813.8	8.5
12/1/2006 12:14	40.69	20.1	13.331	824.3	8.5
12/1/2006 12:15	40.47	19.9	13.364	820	8.5
12/1/2006 12:16	41.2	19.7	13.119	798.9	8.5
12/1/2006 12:17	42.08	19.8	13.36	810.4	8.5
12/1/2006 12:18	42.53	20.2	13.585	819.3	8.5
12/1/2006 12:19	42.9	20.1	13.534	801.8	8.5

HRSG CEMS Data

Date Time	SO21	NOX1	PC1NOXC1	FLO1	CO21
12/1/2006 12:20	42.23	19	12.823	822.4	8.5
12/1/2006 12:21	39.84	19.6	13.135	818.9	8.5
12/1/2006 12:22	39.68	20.3	13.607	820.5	8.5
12/1/2006 12:23	39.46	20.8	14.001	824.4	8.5
12/1/2006 12:24	39.66	20.9	14.098	829	8.5
12/1/2006 12:25	39.16	20	13.609	834.2	8.5
12/1/2006 12:26	31.83	12.3	10.325	810.7	3.4
12/1/2006 12:27	2.83	0.4	0.27	807.6	0
12/1/2006 12:28	16.43	11.4	6.156	815.9	6.8
12/1/2006 12:29	39.2	20.1	13.415	819.6	8.4
12/1/2006 12:30	40.79	19.4	13.047	818.7	8.4
12/1/2006 12:31	37.6	18.7	12.418	818.1	8.4
12/1/2006 12:32	38.08	19.5	12.963	826.3	8.4
12/1/2006 12:33	39.49	19.9	13.326	827.1	8.4
12/1/2006 12:34	39.29	20	13.378	824.3	8.4
12/1/2006 12:35	39.37	19.9	13.308	830.4	8.4
12/1/2006 12:36	39.24	19.7	13.314	827.6	8.4
12/1/2006 12:37	40.67	20.3	13.578	794.2	8.4
12/1/2006 12:38	40.78	20.5	13.832	819	8.4
12/1/2006 12:39	41.27	20.2	13.518	820	8.4
12/1/2006 12:40	40.06	18.8	12.663	818.8	8.4
12/1/2006 12:41	37.33	19.5	13.089	822.1	8.4
12/1/2006 12:42	38.87	20	13.506	828.5	8.4
12/1/2006 12:43	39.51	20.4	13.753	812.7	8.4
12/1/2006 12:44	40.5	20.6	13.813	826	8.4
12/1/2006 12:45	40.66	19.9	13.453	822.4	8.4
12/1/2006 12:46	39.2	19.2	12.811	817.2	8.4
12/1/2006 12:47	39	19.8	13.278	806.1	8.4
12/1/2006 12:48	39.99	20.5	13.787	833.3	8.4
12/1/2006 12:49	40.64	20.5	13.817	814.1	8.4
12/1/2006 12:50	41.79	19.5	13.231	820.5	8.4
12/1/2006 12:51	39.31	18.6	12.374	814.9	8.4
12/1/2006 12:52	38.62	19.5	12.98	805.4	8.4
12/1/2006 12:53	40.35	20	13.41	824	8.4
12/1/2006 12:54	41.28	20.2	13.507	825.6	8.4
12/1/2006 12:55	41.17	19.8	13.331	823.6	8.4
12/1/2006 12:56	41.22	19.9	13.285	819	8.4
12/1/2006 12:57	42.26	20.3	13.615	830.9	8.4
12/1/2006 12:58	41.15	20.1	13.607	832.6	8.4
12/1/2006 12:59	41.4	20	13.408	821.5	8.5

HRSO CEMS Data

Date Time	SO21	NOX1	PC1NOXC1	FLO1	CO21
12/1/2006 13:00	41.28	19	12.73	819.2	8.4
12/1/2006 13:01	38.97	19.5	13.033	821.2	8.4
12/1/2006 13:02	39.31	20.3	13.618	827.1	8.4
12/1/2006 13:03	40.77	20.7	13.967	821	8.4
12/1/2006 13:04	40	20.4	13.765	823.1	8.4
12/1/2006 13:05	39.76	20	13.453	806.1	8.4
12/1/2006 13:06	38.59	19.3	12.948	811.6	8.4
12/1/2006 13:07	36.86	20.1	13.472	819.7	8.4
12/1/2006 13:08	38.67	20.6	13.877	835.7	8.4
12/1/2006 13:09	40.48	20.2	13.669	818.8	8.4
12/1/2006 13:10	40.46	19.3	13.014	812.1	8.3
12/1/2006 13:11	38.47	18.5	12.352	803.3	8.3
12/1/2006 13:12	38.51	19.4	12.929	808.8	8.3
12/1/2006 13:13	39.55	19.7	13.281	812.1	8.3
12/1/2006 13:14	41.51	19.9	13.379	831.7	8.3
12/1/2006 13:15	39.95	20	13.434	833.1	8.3
12/1/2006 13:16	40.09	19.9	13.326	817.4	8.3
12/1/2006 13:17	40.94	20.1	13.518	821.7	8.3
12/1/2006 13:18	42.58	20.2	13.675	796.1	8.3
12/1/2006 13:19	44.21	20.2	13.517	810.3	8.3
12/1/2006 13:20	43.38	18.6	12.563	821.8	8.3

APPENDIX B
SULFURIC ACID MIST TEST DATA – IGCC

FIELD DATA SHEETS

Isokinetic Field Data Sheet - EPA Method 8

Client TECO Run Number 1
 City/State Tampa FL Date 12-30-06 12-1-06
 Sampling Location Unit # 1 Operators JAB

Bar. Press., In. Hg 29.97 NOMOGRAPH SET-UP: K Factor 1.358 LEAK CHECKS
 Static Press., In. H₂O -0.50 ΔH @ 1.88 Y = .79 Avg. ΔP 1.40 Pre-Test 2.004 @ 15 In. Hg.
 Meter Box No. 300.390 Meter Temp. 85 Ref. ΔP — Post-Test 0.003 @ 5 In. Hg.
 Sample Box No. 5 Stack Temp. 314 Desired Nozzle .209 Pre-Test Pitot <0.1 @ 15.213 In. H₂O
 Probe/Pitot No. 200.109 Pitot Coeff. 0.84 Nozzle No. 200.287A Post-Test Pitot <0.1 @ 16.814 In. H₂O
 Probe Temp. Setting 250 % Moisture 6 Nozzle Calibration 1.89.1209 1.89.1209 1.89.1209
 Sample ID No. 6120-01/02 C Factor — Nozzle Diameter 1.89.209 Observer —
 Filter No. N/A Start Time 08:54 End Time 10:00 Agency —

Sample Point	Clock Time	Dry Gas Meter Cubic Feet	Pitot Reading ΔP In. H ₂ O	Orifice Setting ΔH Inches H ₂ O Ideal Actual	Dry Gas Meter Temp °F	Pump Vacuum Inches Hg	Stack Temp °F	Probe Temp °F	Filter Box °F	Imp. Temp °F
A 1	0	79.900	1.3	1.77 1.80	77	1.0	312	248	N/A	59
2	2.5	81.55	1.30	1.77 1.80	77	1.0	312	247		55
3	5	83.37	1.40	1.90 1.90	77	1.0	311	248		53
4	7.5	85.22	1.40	1.90 1.90	78	1.0	312	248		55
5	10	87.07	1.40	1.90 1.90	78	1.0	311	247		56
6	12.5	88.92	1.30	1.77 1.80	79	1.0	311	247		59
B 1	15	90.83	1.40	1.90 1.90	80	1.0	311	246		59
2	17.5	92.53	1.30	1.77 1.80	80	1.0	311	245		59
3	20	94.35	1.40	1.90 1.90	80	1.0	311	247		60
4	22.5	96.23	1.40	1.90 1.90	81	1.0	311	249		59
5	25	98.12	1.30	1.77 1.80	82	1.0	311	246		58
6	27.5	99.95	1.30	1.77 1.80	82	1.0	311	245		57
C 1	30	101.763	1.30	1.77 1.80	82	1.0	308	246		60
2	32.5	103.58	1.40	1.90 1.90	82	1.0	311	243		56
3	35	105.44	1.40	1.90 1.90	83	1.0	311	245		56
4	37.5	107.30	1.40	1.90 1.90	83	1.0	311	248		58
5	40	109.16	1.30	1.77 1.80	83	1.0	311	248		58
6	42.5	111.00	1.30	1.77 1.90	83	1.0	311	249		59
D 1	45	112.845	1.40	1.90 1.90	83	1.0	312	249		58
2	47.5	114.74	1.40	1.90 1.90	83	1.0	312	250		58
3	50	116.65	1.50	2.03 2.05	84	1.0	311	247		58
4	52.5	118.73	1.40	2.17 2.15	84	1.5	311	249		58
5	55	120.77	1.60	2.17 2.15	84	1.5	312	250		58
6	57.5	122.75	1.40	1.90 1.90	84	1.5	311	250		58
	60	124.631	—	—	—	—	—	—		—
		44.731	1.383	1.995	81.2		311.1			

Comments: 57.2

Isokinetic Check: 99.435
 Audited by: ZJK Date: 12/1/06

02 11.6
 002 8.6

67.2 H₂O - COLLECTED



Isokinetic Field Data Sheet - EPA Method

8

Client TECO
 City/State Tampa, FL
 Sampling Location Unit #

Run Number 2
 Date 12/1/2006
 Operators JAB

Bar. Press., In. Hg 29.97

NOMOGRAPH SET-UP: K Factor 1.409

LEAK CHECKS

Static Press., In. H₂O -0.80 $\Delta H @ 1.778 Y = .592$ Avg. ΔP 1.40 Pre-Test 2.002 @ 11 In. Hg.
 Meter Box No. 300.390 Meter Temp. 85 Ref. ΔP --- Post-Test 0.001 @ 5 In. Hg.
 Sample Box No. 5 Stack Temp. 314 Desired Nozzle .209 Pre-Test Pitot <0.1 @ 5.6/4.2 In. H₂O
 Probe/Pitot No. 200.108 Pitot Coeff. 0.84 Nozzle No. 300.217 Post-Test Pitot <0.1 @ 6.2/5.1 In. H₂O
 Probe Temp. Setting 250 % Moisture 6 Nozzle Calibration .211 .211 .211
 Sample ID No. 6120103104 C Factor --- Nozzle Diameter .211 Observer ---
 Filter No. N/A Start Time 10:48 End Time 11:51 Agency ---

Sample Point	Clock Time	Dry Gas Meter Cubic Feet	Pitot Reading ΔP In. H ₂ O	Orifice Setting ΔH Inches H ₂ O		Dry Gas Meter Temp. °F	Pump Vacuum Inches Hg	Stack Temp °F	Probe Temp °F	Filter Box °F	Imp. Temp °F
				Ideal	Actual						
A 1	0	124.900	1.60	2.25	2.25	85	2.0	311	242	N/A	58
2	2.5	126.74	1.56	2.11	2.10	85	2.0	312	253		57
3	5	128.77	1.50	2.11	2.10	85	2.0	312	254		55
4	7.5	130.88	1.60	2.25	2.25	86	2.0	312	255		55
5	10	132.86	1.50	2.11	2.10	86	2.0	311	253		56
6	12.5	134.89	1.40	1.97	2.00	87	2.0	310	251		57
B 1	15	136.854	1.40	1.97	2.00	87	2.0	308	250		58
2	17.5	138.80	1.50	2.11	2.10	87	2.0	310	252		57
3	20	140.88	1.40	1.97	2.00	87	2.0	312	252		56
4	22.5	142.67	1.40	1.97	2.00	87	2.0	312	255		56
5	25	144.68	1.40	1.97	2.00	87	2.0	312	254		57
6	27.5	146.50	1.40	1.97	2.00	88	2.0	311	252		58
C 1	30	148.436	1.40	1.97	2.00	88	2.0	309	246		59
2	32.5	150.37	1.40	1.97	2.00	88	2.0	308	250		57
3	35	152.30	1.40	1.97	2.00	88	2.0	311	251		56
4	37.5	154.24	1.40	1.97	2.00	88	2.0	312	253		56
5	40	156.26	1.40	1.97	2.00	89	2.0	309	254		57
6	42.5	158.10	1.40	1.97	2.00	89	2.0	308	251		58
D 1	45	160.055	1.40	1.97	2.00	89	2.0	305	251		58
2	47.5	161.95	1.50	2.11	2.10	89	2.0	310	252		57
3	50	163.92	1.50	2.11	2.10	89	2.0	312	252		57
4	52.5	165.94	1.50	2.11	2.10	89	2.0	312	254		58
5	55	167.96	1.50	2.11	2.10	90	2.0	312	255		58
6	57.5	169.99	1.50	2.11	2.10	90	2.0	312	253	✓	58
60		171.992	---	---	---	---	---	---	---	---	---
		47.092	1.454		2.058	87.6		310.5			

Comments:

57.2

Isokinetic Check: 99.000

Audited by JAB Date: 12/1/06

02 11.6

02 8.8



Isokinetic Field Data Sheet - EPA Method

8

Client TECO
 City/State TAMPA, FL
 Sampling Location UNIT #1

Run Number 3
 Date 12/01/2006
 Operators JAB

Bar. Press., In. Hg 29.97 ⁽³⁵⁾ 29.91 **NOMOGRAPH SET-UP: K Factor** 1.369 **LEAK CHECKS**
 Static Press., In. H₂O 0.50 ΔH @ 1.878 Y = .992 Avg. ΔP 1.45 Pre-Test 0.004 @ 10 In. Hg.
 Meter Box No. 300.390 Meter Temp. 90 Ref. ΔP — Post-Test 0.003 @ 5 In. Hg.
 Sample Box No. 5 Stack Temp. 314 Desired Nozzle .206 Pre-Test Pitot <0.1 @ 14.5/4.9 In. H₂O
 Probe/Pitot No. 200.109 Pitot Coeff. 0.84 Nozzle No. 200.222 Post-Test Pitot <0.1 @ 15.3/3.2 In. H₂O
 Probe Temp. Setting 250 % Moisture 6 Nozzle Calibration .209, .209, .209
 Sample ID No. 6120/05/02 C Factor — Nozzle Diameter .209 Observer —
 Filter No. nln Start Time 1220 End Time 1323 Agency —

Sample Point	Clock Time	Dry Gas Meter Cubic Feet	Pitot Reading ΔP In. H ₂ O	Orifice Setting ΔH Inches H ₂ O Ideal	Actual	Dry Gas Meter Temp. °F	Pump Vacuum Inches Hg	Stack Temp °F	Probe Temp °F	Filter Box °F	Imp. Temp °F
A 1	0	173.100	1.40	1.91	1.90	87	1.0	313	246	nln	57
2	2.5	174.99	1.40	1.91	1.90	87	1.0	313	246		57
3	5	176.82	1.50	2.05	2.05	87	1.0	313	247		57
4	7.5	178.78	1.50	2.05	2.05	87	1.0	313	248		58
5	10	180.77	1.50	2.05	2.05	87	1.0	313	249		58
6	12.5	182.75	1.40	1.91	1.90	87	1.0	313	248		58
B 1	15	184.666	1.40	1.91	1.90	87	1.0	313	250		57
2	17.5	186.68	1.40	1.91	1.90	87	1.0	312	252		58
3	20	188.47	1.30	1.78	1.80	88	1.0	312	253		58
4	22.5	190.36	1.40	1.91	1.90	88	1.0	312	250		59
5	25	192.29	1.40	1.91	1.90	88	1.0	312	246		59
6	27.5	194.22	1.30	1.78	1.80	88	1.0	312	249		60
C 1	30	196.100	1.40	1.91	1.90	87	1.0	309	250		57
2	32.5	197.99	1.40	1.91	1.90	87	1.0	312	247		58
3	35	199.900	1.40	1.91	1.90	87	1.0	311	244		59
4	37.5	201.800	1.40	1.91	1.90	87	1.0	312	243		59
5	40	203.71	1.40	1.91	1.90	87	1.0	312	250		59
6	42.5	205.61	1.40	1.91	1.90	87	1.0	312	248		59
D 1	45	207.528	1.40	1.91	1.90	87	1.0	312	245		59
2	47.5	209.45	1.40	1.91	1.90	87	1.0	312	250		59
3	50	211.35	1.50	2.05	2.05	88	1.0	312	251		59
4	52.5	213.29	1.60	2.09	2.20	88	1.5	311	253		59
5	55	215.31	1.50	2.05	2.05	88	1.5	311	247		59
6	57.5	217.27	1.50	2.05	2.05	88	1.5	311	249		59
	60	219.284	—	—	—	—	—	—	—	—	—
		46.134	1.425	1.942	1.942	87.3	—	312.8	—	—	—

Comments:

518

Isokinetic Check: 99.877

Checked by: _____ Date: 1/1

O₂ 11.6
CO 8.8

EPA Methods 4 and 8 - Moisture Determination and Sample Recovery - Data Analysis

Client Name TECO Project Number 046-06-120
 City/State Polk Co. FL Sample Date 11/30/06
 Sampling Location Unit 1 Samples Recovered By ISD
 Clean-Up Box Number 2 Recovery Date ~~11/30/06~~ 12/1/06
 Chain of Custody: Date Received 12/1/06 Received By _____ Locked? _____

Equipment Documentation

Run Number	04 ⁵⁰ 1	2	3
Sample ID Number	6120-01/02	6120-03/04	6120-05/06
Sample Box Number	5	5	5
Probe Number	200.109	200.104	200.107

Analysis of Moisture and Sample Recovery - Sulfuric Acid

Reagent Recovery Container #	6120-01	6120-03	6120-05	6120-50
Impinger Absorbing Solution	80% IPA	80% IPA	80% IPA	
Description of Reagent	clear	clear	clear	
Reagent Level Marked?	✓	✓	✓	
Final Volume, ml	60	68	60	
Initial Volume, ml	100	100	100	
Net Condensed Volume, ml	-40	-32	-40	
80% Isopropanol Rinse?	✓	✓	✓	
Dilute to 250 ml in Isopropanol?	✓	✓	✓	

Analysis of Moisture and Sample Recovery - Sulfur Dioxide

Reagent Recovery Container #	6120-02	6120-04	6120-06
Impinger Absorbing Solution	H ₂ O ₂ (3%)	3% H ₂ O ₂	3% H ₂ O ₂
Description of Reagent	clear	clear	clear
Reagent Level Marked?	✓	✓	✓
Final Volume, ml	275	270	270
Initial Volume, ml	200	200	200
Net Condensed Volume, ml	75	70	70
Distilled Water Rinse?	✓	✓	✓
Dilute to 1000 ml in DI Water?	✓	✓	✓

Analysis of Moisture Recovery

Silica Gel Recovery Container #	1	2	3
Percent Silica Gel Spent	15	15	10
Final Weight, g	222.2	219.2	221.8
Initial Weight, g	200	200	200
Net Absorbed Water, g	22.2	19.2	21.8
Total Moisture Collected, ml	57.2	57.2	57.8

Reagent Blanks

Absorbing Reagent Blank	80% IPA	Rinsing Reagent Blank	
Absorbing Blank Identification #	6120-07	Rinsing Blank Identification #	6120-08 ⁵⁰
Absorbing Reagent Blank	H ₂ O ₂	Rinsing Reagent Blank	6120-08
Absorbing Blank Identification #	6120-08	Rinsing Blank Identification #	6120-08



CALCULATED DATA



40 CFR 60, Appendix A - Test Methods
Reference Method 8
Test Calculations

Customer: Polk Power Station
Facility: Acid Plant
Sampling Location: Stack
Operating Conditions: Full Load
Run Number: 1
Date: 12/01/06

Sample Time, θ :	60 minutes	Nozzle Diameter, D_n :	0.209 inches
Barometric Pressure, P_b :	29.97 "Hg	Nozzle Area, A_n :	0.0002382 ft ²
Stack Pressure, P_s :	29.93 "Hg	Average Orifice Meter, ΔH :	1.890 "H ₂ O
Effective Stack Area, A_s :	283.529 ft ²	Sample Volume, V_m :	44.731 ft ³
Pitot Coefficient, C_p :	0.84 dimensionless	Average Meter Temp., T_m :	81.2 °F
Gas Analysis:	8.8 % CO ₂	Average Stack Temp., T_s :	311.1 °F
	11.6 % O ₂	Average $\sqrt{\Delta p}$:	1.176 "H ₂ O
	0.0 % CO	Condensate Volume, V_c :	57.2 ml
	79.6 % N ₂	Meter Box Y:	0.992 dimensionless

Data Calculated from Source Measurements:

$V_{w(std)} = 4.714E-02 \times V_{lc}$	2.696 scf
$V_{m(std)} = 17.647 \times V_m \times Y \times (P_b + (\Delta H / 13.6)) / (T_m + 460)$	43.563 dscf
$B_{ws} = V_{w(std)} / (V_{m(std)} + V_{w(std)})$	0.058 %
$FDA = 1.0 - B_{ws}$	0.942 %
$M_d = (0.44 \times \%CO_2) + (0.32 \times \%O_2) + (0.28 \times (\%N_2 + \%CO))$	29.87 lb./lb. mole
$M_s = (M_d \times FDA) + (18.0 \times B_{ws})$	29.18 lb./lb. mole
$v_s = 85.49 \times C_p \times (\sqrt{\Delta p}) \times (\sqrt{(T_s + 460)} / (M_s \times P_s))$	79.32 ft/second
$Q_s = v_s \times A_s \times 60$	1349432.0 acf/minute
$Q_{s(std)} = Q_s \times FDA \times (528 / (T_s + 460)) \times (P_s / 29.92)$	870502.8 dscf/minute
$I = (T_s + 460) \times ((2.67E-03 \times V_c) + (V_{m(std)} / 17.647)) \times 100 / (\theta \times P_s \times A_n \times v_s \times 60)$	99.3 %

Data from Laboratory Analysis:

	H ₂ SO ₄
Normality of Barium Chloride titrant, N	0.00975
Volume Titrant Blank, V_{lb}	0.1
Volume Titrant Sample, V_t	500
Volume of Sample Aliquot, V_a	100
Total Volume of Solution, V_{soln}	6.55

Calculated Concentration and Emission Rate Data:

$C_{H_2SO_4} = 1.081E-04 \times (N \times (V_t - V_{lb}) \times (V_{soln} / V_a)) / V_{m(std)}$	= 7.922E-07 lb/dscf
$F_c\text{-factor} =$	2310 dscf/mmBtu
$E_{H_2SO_4} = C_{H_2SO_4} \times F_c\text{-factor} \times (100/\%CO_2)$	= 0.02080 lb/mmBtu
$E_{H_2SO_4} = C_{H_2SO_4} \times Q_{s(std)} \times 60$	= 41.3765 lb/hr



40 CFR 60, Appendix A - Test Methods
Reference Method 8
Test Calculations

Customer: Polk Power Station
Facility: Acid Plant
Sampling Location: Stack
Operating Conditions: Full Load
Run Number: 2
Date: 12/01/06

Sample Time, θ :	60 minutes	Nozzle Diameter, D_n :	0.211 inches
Barometric Pressure, P_b :	29.97 "Hg	Nozzle Area, A_n :	0.00024281 ft ²
Stack Pressure, P_s :	29.93 "Hg	Average Orifice Meter, ΔH :	2.058 "H ₂ O
Effective Stack Area, A_s :	283.529 ft ²	Sample Volume, V_m :	47.092 ft ³
Pitot Coefficient, C_p :	0.84 dimensionless	Average Meter Temp., T_m :	87.6 °F
Gas Analysis:	8.8 % CO ₂	Average Stack Temp., T_s :	310.5 °F
	11.6 % O ₂	Average $\sqrt{\Delta p}$:	1.206 "H ₂ O
	0.0 % CO	Condensate Volume, V_{lc} :	57.2 ml
	79.6 % N ₂	Meter Box Y:	0.992 dimensionless

Data Calculated from Source Measurements:

$V_{w(std)} = 4.714E-02 \times V_{lc}$	2.696 scf
$V_{m(std)} = 17.647 \times V_m \times Y \times (P_b + (\Delta H / 13.6)) / (T_m + 460)$	45.344 dscf
$B_{ws} = V_{w(std)} / (V_{m(std)} + V_{w(std)})$	0.056 %
$FDA = 1.0 - B_{ws}$	0.944 %
$M_d = (0.44 \times \%CO_2) + (0.32 \times \%O_2) + (0.28 \times (\%N_2 + \%CO))$	29.87 lb./lb. mole
$M_s = (M_d \times FDA) + (18.0 \times B_{ws})$	29.21 lb./lb. mole
$v_s = 85.49 \times C_p \times (\sqrt{\Delta p}) \times (\sqrt{(T_s + 460)} / (M_s \times P_s))$	81.28 ft/second
$Q_s = v_s \times A_s \times 60$	1382717.2 acf/minute
$Q_{s(std)} = Q_s \times FDA \times (528 / (T_s + 460)) \times (P_s / 29.92)$	894697.9 dscf/minute
$I = (T_s + 460) \times ((2.67E-03 \times V_{lc}) + (V_{m(std)} / 17.647)) \times 100 / (\theta \times P_s \times A_n \times v_s \times 6)$	98.6 %

Data from Laboratory Analysis:

	H ₂ SO ₄
Normality of Barium Chloride titrant, N	0.00975
Volume Titrant Blank, V_{tb}	0.1
Volume Titrant Sample, V_t	500
Volume of Sample Aliquot, V_a	100
Total Volume of Solution, V_{soln}	5.25

Calculated Concentration and Emission Rate Data:

$C_{H_2SO_4} = 1.081E-04 \times (N \times (V_t - V_{tb}) \times (V_{soln} / V_a)) / V_{m(std)}$	6.100E-07 lb/dscf
$F_c\text{-factor} =$	2310 dscf/MMBtu
$E_{H_2SO_4} = C_{H_2SO_4} \times F_c\text{-factor} \times (100/\%CO_2)$	0.01601 lb/MMBtu
$E_{H_2SO_4} = C_{H_2SO_4} \times Q_{s(std)} \times 60 =$	32.7476 lb/hr



40 CFR 60, Appendix A - Test Methods
Reference Method 8
Test Calculations

Customer: Polk Power Station
Facility: Acid Plant
Sampling Location: Stack
Operating Conditions: Full Load
Run Number: 3
Date: 12/01/06

Sample Time, θ :	60 minutes	Nozzle Diameter, D_n :	0.209 inches
Barometric Pressure, P_b :	29.91 "Hg	Nozzle Area, A_n :	0.00023823 ft ²
Stack Pressure, P_s :	29.87 "Hg	Average Orifice Meter, ΔH :	1.942 "H ₂ O
Effective Stack Area, A_s :	283.529 ft ²	Sample Volume, V_m :	46.134 ft ³
Pitot Coefficient, C_p :	0.84 dimensionless	Average Meter Temp., T_m :	87.3 °F
Gas Analysis:	8.8 % CO ₂	Average Stack Temp., T_s :	304.4 °F
	11.6 % O ₂	Average $\sqrt{\Delta p}$:	1.193 "H ₂ O
	0.0 % CO	Condensate Volume, V_{lc} :	51.8 ml
	79.6 % N ₂	Meter Box Y:	0.992 dimensionless

Data Calculated from Source Measurements:

$V_{w(std)} = 4.714E-02 \times V_{lc}$	2.442 scf
$V_{m(std)} = 17.647 \times V_m \times Y \times (P_b + (\Delta H / 13.6)) / (T_m + 460)$	44.344 dscf
$B_{ws} = V_{w(std)} / (V_{m(std)} + V_{w(std)})$	0.052 %
$FDA = 1.0 - B_{ws}$	0.948 %
$M_d = (0.44 \times \%CO_2) + (0.32 \times \%O_2) + (0.28 \times (\%N_2 + \%CO))$	29.87 lb./lb. mole
$M_s = (M_d \times FDA) + (18.0 \times B_{ws})$	29.25 lb./lb. mole
$v_s = 85.49 \times C_p \times (\sqrt{\Delta p}) \times (\sqrt{(T_s + 460)} / (M_s \times P_s))$	80.15 ft/second
$Q_s = v_s \times A_s \times 60$	1363572.9 acf/minute
$Q_{s(std)} = Q_s \times FDA \times (528 / (T_s + 460)) \times (P_s / 29.92)$	891298.5 dscf/minute
$I = (T_s + 460) \times ((2.67E-03 \times V_{lc}) + (V_{m(std)} / 17.647)) \times 100 / (\theta \times P_s \times A_n \times v_s \times 6)$	98.7 %

Data from Laboratory Analysis:

	H ₂ SO ₄
Normality of Barium Chloride titrant, N	0.00975
Volume Titrant Blank, V_{tb}	0.1
Volume Titrant Sample, V_t	500
Volume of Sample Aliquot, V_a	100
Total Volume of Solution, V_{soln}	4.15

Calculated Concentration and Emission Rate Data:

$C_{H_2SO_4} = 1.081E-04 \times (N \times (V_t - V_{tb}) \times (V_{soln} / V_a)) / V_{m(std)}$	4.931E-07 lb/dscf
$F_c\text{-factor} =$	2310 dscf/MMBtu
$E_{H_2SO_4} = C_{H_2SO_4} \times F_c\text{-factor} \times (100/\%CO_2) =$	0.01294 lb/MMBtu
$E_{H_2SO_4} = C_{H_2SO_4} \times Q_{s(std)} \times 60 =$	26.3694 lb/hr

LABORATORY ANALYSIS



Laboratory Services

5012 Causeway Blvd * Tampa Fl. 33619 * Ph (813)630-7378 * Fax (813)630-7360 * DOH #E54272

Report For:

Report Date: 1/3/2007

Laboratory ID: AA85903

Location Code: TE_PPS_1_SAM_SYNGAS

Sample Information

Description: Polk No. 1 Acid Mist Comp on Syngas

Sampled By: TRIGON

Project Account Code:

Date and Time Collected: 12/1/2006 1:30:00 PM

Sample Collection Method:

Date of Sample Receipt: 12/4/2006

Laboratory Results


PARAMETER	Result	Units	MDL	Qualifier Code	Test Method	Analyst	Analysis Date & Time	Lower Limit	Upper Limit	Violation Check
Normality of BaCl2 * 2H2O	0.00975		0.0001			MM	12/4/2006 7:15:00 AM			
SO3 emission rate, lbs/hr	34	lbs/hr			EPA - RM8	RAM	1/3/2007 8:28:00 AM			
SO3, Avg. of Blank Titrations	0.1	milliliters	0.01		EPA - Meth.8	MM	12/4/2006 7:15:00 AM			
SO3, Run #1, Avg. of Titrations	6.55	milliliters	0.01		EPA - Meth.8	MM	12/4/2006 7:15:00 AM			
SO3, Run #2, Avg. of Titrations	5.25	milliliters	0.01		EPA - Meth.8	MM	12/4/2006 7:15:00 AM			
SO3, Run #3, Avg. of Titrations	4.15	milliliters	0.01		EPA - Meth.8	MM	12/4/2006 7:15:00 AM			
SO3, Volume of Contained Sample	500	milliliters	1		EPA - Meth.8	MM	12/4/2006 7:15:00 AM			
SO3, Volume of Sample Aliquot	100	milliliters	0.1		EPA - Meth.8	MM	12/4/2006 7:15:00 AM			

Comments

All results calculated on a wet to wet basis, unless otherwise indicated.

Data Qualifier Codes Explanation:

Subcontracted Laboratories:



Robert Dorey,
Manager, Laboratory Services

CALIBRATION DATA

Meter Console Information

Console Number	300.200
Dry Gas Meter Number	7811505
Calibration Date:	10/25/2006
Expiration Date:	10/25/2007

Calibration Condition

Time:	
Barometric Pressure (P _b):	29.18
Calibration Technician	S. Marquis
Wet Test Meter ID	11088.00
Wet Test Meter Verification Date	8/1/2006

Pass Positive Leak Check?	Yes
Pass Negative Leak Check?	Yes

DGM Orifice Setting	Vacuum Setting	Console Meter					Wet Test Meter					Run		
		Meter Initial Volume	Meter Final Volume	Sample Volume	Outlet Temp. Initial	Outlet Temp. Final	Outlet Temp. Average	Wet Test Initial Volume	Wet Test Final Volume	Wet Test Volume	Wet Test Temp. Initial		Wet Test Temp. Final	Wet Test Temp. Average
(P _m)	(2-4 in Hg)	(V _{di})	(V _{df})	(V _m)	(T _{di})	(T _{df})	(T _d)	(V _{wi})	(V _{wf})	(V _w)	(T _{wi})	(T _{wf})	(T _w)	⊖
in. H ₂ O	in. Hg	cubic feet	cubic feet	cubic feet	°F	°F	°F	cubic feet	cubic feet	cubic feet	°F	°F	°F	minutes
0.5	3.0	0	4.945	4.945	76	76	76.0	0	5	5.000	68	68	68.0	12.32
1.0	3.3	0	7.834	7.834	80	76	78.0	0	8	8.000	68	68	68.0	13.7
1.5	3.0	0	9.63	9.630	68	78	73.0	0	10	10.000	68	68	68.0	14.17
2.0	3.0	0	30.403	30.403	80	88	84.0	0	31	31.000	68	68	68.0	39
3.0	3.0	0	11.316	11.316	85	90	87.5	0	11.51	11.510	68	68	68.0	12
4.0	3.0	0	9.834	9.834	90	91	90.5	0	10	10.000	68	68	68.0	9.1

DGM Orifice Setting	DGM Factor	DGM Factor	Orifice Meter	Orifice Meter
(P _m)	γ	Δγ	ΔH _{or}	ΔΔH _{or}
in. H ₂ O			in. H ₂ O	in. H ₂ O
0.5	1.025	-0.016	1.715	-0.029
1	1.038	-0.004	1.651	-0.093
1.5	1.044	0.003	1.711	-0.033
2	1.045	0.004	1.762	0.018
3	1.047	0.005	1.804	0.059
4	1.050	0.008	1.822	0.078

1.042 γ Average 1.744 ΔH_{or} Average

Meter Box Thermocouple Calibration.

Test Points	30	50	75	90	120
Reading	31	51	75	90	120

$$\gamma = V_w * P_b * (T_d + 460) / V_d * (P_b - \Delta H / 13.6) * (T_w + 460)$$

$$\Delta H_{or} = ((0.0319 * \Delta H) / (P_b * (T_d + 460))) * (((T_w - 460) * 0) / V_w)^2$$

Note: For Calibration Factor γ, the ratio of the calibration meter to dry gas meter, acceptable tolerance of individual values from the average is ±0.02

Note: For ΔH_{or}, orifice pressure differential that equates to 0.75 cfm (0.0212 m³/min) at standard temperature and pressure.

acceptable tolerance of individual values from the average is ±0.2 inches (5.1mm) H₂O

APPENDIX C

SULFURIC ACID MIST TEST DATA – SULFURIC ACID PLANT

FIELD DATA SHEETS

ISOKINETIC FIELD DATA SHEET

Plant	<u>Polk Power Station</u>	Run No	<u>1</u>	Dry Gas Meter Volume	
Location	<u>Acid Plant Stack</u>	Nozzle I.D. No	<u>74</u>	Final	<u>710.521</u> Ft.
Date	<u>12-1-06</u>	Nozzle Diameter	<u>0.490</u>	Initial	<u>663.114</u> Ft.
Method No.	<u>RM-8</u>	Pilot Tube No.	<u>1705</u>	Net	<u>47.410</u> Ft.
Box Operator	<u>DAS</u>	Pilot Tube (C _p)	<u>2.84</u>	Equipment Leak Checks	
Probe Operator	<u>SFB</u>	Probe Length	<u>9</u>	Initial	<u>0.0</u> CFM @ <u>15</u> "Hg
Time - Start	<u>0900</u> End <u>10:16</u>	Probe Liner Material	<u>6/0.5</u>	Final	<u>0.0</u> CFM @ <u>10</u> "H ₂ O
Sampling Time	<u>64 min</u>	Pressure	<u>Pb ("Hg): 32.15 Pg ("H₂O)</u>	Pilot Tube	<u>0</u> "H ₂ O
Min. \ Pl.	<u>4 min.</u>	Assumed Moisture (%)	<u>6.2%</u>	Moisture Determination	
Meter Box No.	<u>MB07</u>	Filter Holder No.		Impinger	<u>-10.0</u> ml
Pyrometer No.	<u>P407</u>	Comments		Silica Gel	<u>14.5</u> gm
Barometer No.		Start	Imp#1 <u>200</u> Imp#2 <u>100</u> Imp#3 <u>100</u>	Total	<u>4.5</u>
Meter Cal. (ΔH)	<u>1.670</u>	Finish	Imp#1 <u>100</u> Imp#2 <u>120</u> Imp#3 <u>110</u>		
Meter Cal. (ΔY)	<u>0.999</u>	O ₂	<u>8.9</u>	CO ₂ <u>17.4</u>	

Traverse Point No	Clock Time	Gas Sample Volume (Ft ³)	Stack Temp Ts (F)	Meter Temp. (F)	Δ P (In. H ₂ O)	Δ H (In. H ₂ O)	Probe Temp (F)	Filter Box Temp. Tm (F)	Last Imp. Temp. (F)	Vacuum (In Hg)
1	9:00	666.0	151	87	0.034	1.60	209	62	62	6
2		668.96	160	92	0.042	1.63	214		62	6
3		671.82	163	93	0.035	1.63	224		63	6
4		674.83	162	92	0.038	1.76	218		63	6.5
6		677.77	161	93	0.038	1.76	221		63	6.5
6		680.59	161	93	0.040	1.86	213		61	7
7		683.92	160	93	0.046	2.14	204		62	8
8	0932	687.03	158	93	0.040	1.87	205		62	8
1	0944	692.017	159	90	0.037	1.75	169		58	7
2		693.05	160	95	0.038	1.77	172		59	7
3		696.06	160	96	0.035	1.64	172		60	7
4		698.91	160	96	0.035	1.64	171		60	6
5		701.89	160	96	0.031	1.45	176		60	6
6		704.62	160	96	0.036	1.68	174		60	6
7		707.52	160	96	0.035	1.64	169		61	6
8	1016	710.521	155	96	0.037	1.74	170		61	6

Quality Assurance / Quality Control Information

Console Operator Signature:	<u>DAS</u>	Date:	<u>1-3-07</u>
Complete: <input checked="" type="checkbox"/>	Legible: <input checked="" type="checkbox"/>	Accurate: <input checked="" type="checkbox"/>	Project Scope: <input checked="" type="checkbox"/>
Reasonableness: <input checked="" type="checkbox"/>			
Reviewer's Signature:	<u>[Signature]</u>	Title:	<u>QA/QC</u>
		Date:	<u>3 JAN-07</u>

ISOKINETIC FIELD DATA SHEET

Plant Pella
 Location Acid Plant
 Date 12-1-06
 Method No. RM-8
 Box Operator DMS
 Probe Operator SEU
 Time - Start: 10:45 End: 11:37
 Sampling Time 64 min.
 Min. Pt. 4 min.
 Meter Box No. MB67
 Pyrometer No. PY05
 Barometer No. _____
 Meter Cal. (ΔH) 599
 Meter Cal. (ΔY) 1.676

Run No. 2
 Nozzle I.D. No. 74
 Nozzle Diameter 0.490
 Pilot Tube No. PT05
 Pilot Tube (C_p) _____
 Probe Length 7'
 Probe Liner Material 6/655
 Pressure Pb ("Hg): 30.15 Pg ("H₂O):
 Assumed Moisture (%) 22
 Filter Holder No. _____
 Comments _____
 Start Imp#1 200 Imp#2 100 Imp#3 100
 Finish Imp#1 140 Imp#2 150 Imp#3 112
 O₂ 8.8 CO₂ 17.8

Dry Gas Meter Volume
 Final 760.072 Ft.³
 Initial 713.801 Ft.³
 Net 46.276 Ft.³

Equipment Leak Checks
 Initial 2.0 CFM @ 10 "Hg
 Final 0.0 CFM @ 12 "H₂O
 Pitot Tube J "H₂O

Moisture Determination
 Impinger -18.0 ml
 Silica Gel 17.0 gm
 Total -0.5

Traverse Point No.	Clock Time	Gas Sample Volume (Ft ³)	Stack Temp. Ts (°F)	Meter Temp. (°F)	ΔP (In. H ₂ O)	ΔH (In. H ₂ O)	Probe Temp. (°F)	Filter Box Temp. Tm (°F)	Last Imp. Temp. (°F)	Vacuum (In Hg)
1	10:45	713.801	158	87	.035	1.62	210		63	8
2		716.83	160	97	.037	1.83	213		61	8
3		719.65	161	98	.036	1.69	213		62	8
4		722.84	164	98	.036	1.75	205		62	8
5		726.01	160	98	.044	2.07	214		63	8
6		728.77	159	98	.037	1.83	213		63	8
7		732.07	159	98	.043	2.05	209		63	10
8	11:17	735.27	159	98	.043	2.05	210		62	10
1	11:25	738.4	160	91	.037	1.71	178		62	9
2		741.35	160	97	.034	1.57	177		62	8.5
3		744.72	160	98	.041	1.92	171		63	9
4		747.52	160	98	.038	1.81	177		62	9
5		750.65	161	100	.040	1.88	178		60	9
6		753.77	159	101	.041	1.94	174		61	9.5
7		757.08	155	101	.040	1.90	178		63	9.5
8	11:57	760.072	154	101	.036	1.74	176		63	9

Quality Assurance / Quality Control Information

Console Operator Signature: [Signature] Date: 1-3-07
 Complete: Legible: Accurate: Project Scope: Reasonableness:
 Reviewer's Signature: [Signature] Title: QA/QC Date: 3 JAN-07

ISOKINETIC FIELD DATA SHEET

Plant: <u>Polk Power</u>	Run No.: <u>3</u>	Dry Gas Meter Volume
Location: <u>Acid Plant</u>	Nozzle I.D. No.: <u>74</u>	Final: <u>809.615</u> Ft. ³
Date: <u>12-1-06</u>	Nozzle Diameter: <u>0.490</u>	Initial: <u>760.338</u> Ft. ³
Method No.: <u>RM-8</u>	Pitot Tube No.: <u>PT05</u>	Net: <u>49.260</u> Ft. ³
Box Operator: <u>DA</u>	Pitot Tube (C _p):	Equipment Leak Checks
Probe Operator: <u>SEB</u>	Probe Length: <u>9'</u>	Initial: <u>0.0</u> CFM @ <u>12</u> "Hg
Time - Start: <u>12:21</u> End: <u>13:52</u>	Probe Liner Material: <u>6/655</u>	Final: <u>0.0</u> CFM @ <u>10</u> "H ₂ O
Sampling Time: <u>64 min.</u>	Pressure: <u>Pb ("Hg): 30.15 Pb ("H₂O): .5</u>	Pitot Tube: <u>Ø</u> "H ₂ O
Min. V Pl.: <u>34 m.w</u>	Assumed Moisture (%): <u>2.8</u>	Moisture Determination
Meter Box No.: <u>M307</u>	Filter Holder No.:	Impinger: <u>-15</u> ml
Pyrometer No.: <u>Py 69</u>	Comments:	Silica Gel: <u>18.4</u> gm
Barometer No.:	Start: Imp#1 <u>200</u> Imp#2 <u>100</u> Imp#3 <u>100</u>	Total: <u>3.4</u>
Meter Cal. (Δ H): <u>.777</u>	Finish: Imp#1 <u>178</u> Imp#2 <u>120</u> Imp#3 <u>111</u>	
Meter Cal. (Δ Y): <u>1.670</u>	O ₂ <u>7.9</u> CO ₂ <u>18.7</u>	

Traverse Point No.	Clock Time	Gas Sample Volume (Ft ³)	Stack Temp. Ts (°F)	Meter Temp. (°F)	Δ P (In. H ₂ O)	Δ H (In. H ₂ O)	Probe Temp. (°F)	Filter Box Temp. Tm (°F)	Last Imp. Temp. (°F)	Vacuum (In. Hg)
1	1221	763.52	159	90	.039	1.81	215		60	8
2		766.67	159	101	.040	1.89	215		59	8
3		769.72	159	101	.038	1.82	227		59	8
4		772.74	163	102	.035	1.65	219		60	7.5
5		775.58	163	102	.031	1.46	213		63	7
6		778.51	160	101	.041	1.93	211		61	7
7		781.48	159	102	.039	1.85	214		62	8
8	1253	784.81	154	102	.041	1.95	207		65	8.5
1	1300	788.07	154	94	.043	2.05	180		61	8.5
2		791.16	161	100	.039	1.84	184		63	8
3		794.28	160	102	.041	1.94	183		64	8.5
4		797.15	160	102	.030	1.44	187		62	6.5
5		800.23	162	102	.041	1.93	190		66	8
6		803.42	160	102	.039	1.87	196		66	8
7		806.47	159	103	.036	1.71	191		65	8
8	1332	809.615	157	103	.036	1.71	180		65	8

Quality Assurance / Quality Control Information

Console Operator Signature: <u>[Signature]</u>	Date: <u>1-3-07</u>
Complete: <input checked="" type="checkbox"/> Legible: <input checked="" type="checkbox"/> Accurate: <input checked="" type="checkbox"/>	Project Scope: <input checked="" type="checkbox"/> Reasonableness: <input checked="" type="checkbox"/>
Reviewer's Signature: <u>[Signature]</u>	Date: <u>3-JAN-07</u>
Title: <u>QA/QC</u>	

CALCULATED DATA



40 CFR 60, Appendix A - Test Methods
Reference Method 8
Test Calculations

Customer: Polk Power Station
Facility: Acid Plant
Sampling Location: Stack
Operating Conditions: Compliance Load
Run Number: 1
Date: 12/01/06

Sample Time, θ :	64 minutes	Nozzle Diameter, D_n :	0.490 inches
Barometric Pressure, P_b :	30.15 "Hg	Nozzle Area, A_n :	0.00130946 ft ²
Stack Pressure, P_s :	30.19 "Hg	Average Orifice Meter, ΔH :	1.743 "H ₂ O
Effective Stack Area, A_s :	28.274 ft ²	Sample Volume, V_m :	47.407 ft ³
Pitot Coefficient, C_p :	0.84 dimensionless	Average Meter Temp., T_m :	93.8 °F
Gas Analysis:	17.4 % CO ₂	Average Stack Temp., T_g :	159.8 °F
	8.9 % O ₂	Average ΔP :	0.193 "H ₂ O
	0.0 % CO	Condensate Volume, V_c :	4.5 ml
	73.7 % N ₂	Meter Box Y :	0.999 dimensionless

Data Calculated from Source Measurements:

$V_{w(std)} = 4.714E-02 \times V_{ic}$	0.212 scf
$V_{m(std)} = 17.647 \times V_m \times Y \times (P_b + (\Delta H / 13.6)) / (T_m + 460)$	45.698 dscf
$B_{ws} = V_{w(std)} / (V_{m(std)} + V_{w(std)})$	0.005 %
$FDA = 1.0 - B_{ws}$	0.995 %
$M_d = (0.44 \times \%CO_2) + (0.32 \times \%O_2) + (0.28 \times (\%N_2 + \%CO))$	31.14 lb./lb. mole
$M_s = (M_d \times FDA) + (18.0 \times B_{ws})$	31.08 lb./lb. mole
$v_s = 85.49 \times C_p \times (\sqrt{\Delta P}) \times (\sqrt{(T_s + 460)}) / (M_s \times P_s)$	11.28 ft/second
$Q_s = v_s \times A_s \times 60$	19131.0 acf/minute
$Q_{s(std)} = Q_s \times FDA \times (528 / (T_s + 460)) \times (P_s / 29.92)$	16368.1 dscf/minute
$I = (T_s + 460) \times \{(2.67E-03 \times V_{ic}) + (V_{m(std)} / 17.647)\} \times 100 / (\theta \times P_s \times A_n \times v_s \times 60)$	94.2 %

Data from Laboratory Analysis:

	H ₂ SO ₄
Normality of Barium Chloride titrant, N	0.00975
Volume Titrant Blank, V_{tb}	0.1
Volume Titrant Sample, V_t	5.1
Volume of Sample Aliquot, V_a	100
Total Volume of Solution, V_{soln}	500

Data Calculated from Plant Operational Measurements:

Gallons of Acid Produced During The Test Period,	P_{gal}	1702.90063	gallons
Density of Water,	D	8.345	lbs/gallon
Specific Gravity of Sulfuric Acid,	SG	1.84	dimensionless
Average Concentration of Acid Produced,	C_{acid}	93.5088026	%
Tons of Acid Produced During The Test Period,	P_{st}	12.2251999	short tons
Volumetric Flow Rate Through Stack ,	Q_{std}	16368.1	dscf/min
Total Sampling Time During Test Period,	θ	64	minutes
$C_{H_2SO_4} = 1.081E-04 \times (N \times (V_t - V_{tb}) \times (V_{soln} / V_a)) / V_{m(std)}$		5.766E-07	lbs/dscf

Calculated H₂SO₄ Emission Rate, **E = 0.04941 lbs H₂SO₄/ton of acid**

Where;

Tons of Acid Produced, $P_{st} = (P_{gal} \times D \times SG \times C_{acid}) / 2000$

Emission Rate, $E = (Q_{std} \times \theta \times C_{sample}) / P_{st}$



40 CFR 60, Appendix A - Test Methods
Reference Method 8
Test Calculations

Customer: Polk Power Station
Facility: Acid Plant
Sampling Location: Stack
Operating Conditions: Compliance Load
Run Number: 2
Date: 12/01/06

Sample Time, θ :	64 minutes	Nozzle Diameter, D_n :	0.490 inches
Barometric Pressure, P_b :	30.15 "Hg	Nozzle Area, A_n :	0.00130946 ft ²
Stack Pressure, P_s :	30.19 "Hg	Average Orifice Meter, ΔH :	1.821 "H ₂ O
Effective Stack Area, A_s :	28.274 ft ²	Sample Volume, V_m :	49.264 ft ³
Pitot Coefficient, C_p :	0.84 dimensionless	Average Meter Temp., T_m :	97.4 °F
Gas Analysis:	17.8 % CO ₂	Average Stack Temp., T_s :	159.4 °F
	8.8 % O ₂	Average $\sqrt{\Delta p}$:	0.197 "H ₂ O
	0.0 % CO	Condensate Volume, V_{lc} :	-0.5 ml
	73.4 % N ₂	Meter Box Y:	0.999 dimensionless

Data Calculated from Source Measurements:

$V_{w(std)} = 4.714E-02 \times V_{lc}$	-0.024 scf
$V_{m(std)} = 17.647 \times V_m \times Y \times (P_b + (\Delta H / 13.6)) / (T_m + 460)$	47.183 dscf
$B_{ws} = V_{w(std)} / (V_{m(std)} + V_{w(std)})$	0.000 %
$FDA = 1.0 - B_{ws}$	1.000 %
$M_d = (0.44 \times \%CO_2) + (0.32 \times \%O_2) + (0.28 \times (\%N_2 + \%CO))$	31.20 lb./lb. mole
$M_s = (M_d \times FDA) + (18.0 \times B_{ws})$	31.21 lb./lb. mole
$v_s = 85.49 \times C_p \times (\sqrt{\Delta p}) \times (\sqrt{(T_s + 460)} / (M_s \times P_s))$	11.46 ft/second
$Q_s = v_s \times A_s \times 60$	19441.3 acf/minute
$Q_{s(std)} = Q_s \times FDA \times (528 / (T_s + 460)) \times (P_s / 29.92)$	16729.3 dscf/minute
$I = (T_s + 460) \times ((2.67E-03 \times V_{lc}) + (V_{m(std)} / 17.647)) \times 100 / (\theta \times P_s \times A_n \times v_s)$	95.2 %

Data from Laboratory Analysis:

	H ₂ SO ₄
Normality of Barium Chloride titrant, N	0.00975
Volume Titrant Blank, V_{tb}	0.1
Volume Titrant Sample, V_t	5.25
Volume of Sample Aliquot, V_a	100
Total Volume of Solution, V_{soln}	500

Data Calculated from Plant Operational Measurements:

Gallons of Acid Produced During The Test Period,	P_{gal}	1560.977516	gallons
Density of Water,	D	8.345	lbs/gallon
Specific Gravity of Sulfuric Acid,	SG	1.84	dimensionless
Average Concentration of Acid Produced,	C_{acid}	93.51097609	%
Tons of Acid Produced During The Test Period,	P_{st}	11.20658801	short tons
Volumetric Flow Rate Through Stack,	Q_{std}	16729.3	dscf/min
Total Sampling Time During Test Period,	θ	64	minutes
$C_{H_2SO_4} = 1.081E-04 \times (N \times (V_t - V_{tb}) \times (V_{soln} / V_a)) / V_{m(std)}$		5.752E-07	lbs/dscf

Calculated H₂SO₄ Emission Rate, E = 0.05496 lbs H₂SO₄/ton of acid

Where;

Tons of Acid Produced, $P_{st} = (P_{gal} \times D \times SG \times C_{acid}) / 2000$

Emission Rate, E = $(Q_{std} \times \theta \times C_{sample}) / P_{st}$



40 CFR 60, Appendix A - Test Methods
Reference Method 8
Test Calculations

Customer: Polk Power Station
Facility: Acid Plant
Sampling Location: Stack
Operating Conditions: Compliance Load
Run Number: 3
Date: 12/01/06

Sample Time, θ :	64 minutes	Nozzle Diameter, D_n :	0.490 inches
Barometric Pressure, P_b :	30.15 "Hg	Nozzle Area, A_n :	0.00130946 ft ²
Stack Pressure, P_s :	30.19 "Hg	Average Orifice Meter, ΔH :	1.804 "H ₂ O
Effective Stack Area, A_s :	28.274 ft ²	Sample Volume, V_m :	49.257 ft ³
Pitot Coefficient, C_p :	0.84 dimensionless	Average Meter Temp., T_m :	100.6 °F
Gas Analysis:	18.7 % CO ₂	Average Stack Temp., T_s :	159.3 °F
	7.9 % O ₂	Average $\sqrt{\Delta p}$:	0.195 "H ₂ O
	0.0 % CO	Condensate Volume, V_c :	8.1 ml
	73.4 % N ₂	Meter Box Y:	0.999 dimensionless

Data Calculated from Source Measurements:

$V_{w(std)} = 4.714E-02 \times V_{lc}$	0.382 scf
$V_{m(std)} = 17.647 \times V_m \times Y \times (P_b + (\Delta H / 13.6)) / (T_m + 460)$	46.911 dscf
$B_{ws} = V_{w(std)} / (V_{m(std)} + V_{w(std)})$	0.008 %
$FDA = 1.0 - B_{ws}$	0.992 %
$M_d = (0.44 \times \%CO_2) + (0.32 \times \%O_2) + (0.28 \times (\%N_2 + \%CO))$	31.31 lb./lb. mole
$M_s = (M_d \times FDA) + (18.0 \times B_{ws})$	31.20 lb./lb. mole
$v_s = 85.49 \times C_p \times (\sqrt{\Delta p}) \times (\sqrt{T_s + 460}) / (M_s \times P_s)$	11.37 ft/second
$Q_s = v_s \times A_s \times 60$	19290.9 acf/minute
$Q_{s(std)} = Q_s \times FDA \times (528 / (T_s + 460)) \times (P_s / 29.92)$	16459.3 dscf/minute
$I = (T_s + 460) \times ((2.67E-03 \times V_{lc}) + (V_{m(std)} / 17.647)) \times 100 / (\theta \times P_s \times A_n \times v_s)$	96.2 %

Data from Laboratory Analysis:

	H ₂ SO ₄
Normality of Barium Chloride titrant, N	0.00975 meq/ml
Volume Titrant Blank, V_{tb}	0.1 ml
Volume Titrant Sample, V_t	4.85 ml
Volume of Sample Aliquot, V_a	100 ml
Total Volume of Solution, V_{soln}	500 ml

Data Calculated from Plant Operational Measurements:

Gallons of Acid Produced During The Test Period,	P_{gal}	1556.541618	gallons
Density of Water,	D	8.345	lbs/gallon
Specific Gravity of Sulfuric Acid,	SG	1.84	dimensionless
Average Concentration of Acid Produced,	C_{acid}	93.50460243	%
Tons of Acid Produced During The Test Period,	P_{st}	11.1739801	short tons
Volumetric Flow Rate Through Stack ,	Q_{std}	16459.3	dscf/min
Total Sampling Time During Test Period,	θ	64	minutes
$C_{H_2SO_4} = 1.081E-04 \times (N \times (V_t - V_{tb}) \times (V_{soln} / V_a)) / V_{m(std)}$		5.336E-07	lbs/dscf

Calculated H₂SO₄ Emission Rate, E= 0.05030 lbs H₂SO₄/ton of acid

Where:

Tons of Acid Produced, $P_{st} = (P_{gal} \times D \times SG \times C_{acid}) / 2000$

Emission Rate, E = $(Q_{std} \times \theta \times C_{sample}) / P_{st}$

LABORATORY ANALYSIS



Laboratory Services

5012 Causeway Blvd * Tampa Fl. 33619 * Ph (813)630-7378 * Fax (813)630-7360 * DOH #E54272

Report For:

Report Date: 1/3/2007

Laboratory ID: AA85904

Location Code: TE_PPS_SAP_COMP_SYNGAS

Sample Information

Description: Polk Sulfuric Acid Plant Compliance

Sampled By: ASG

Project Account Code:

Date and Time Collected: 12/1/2006 1:30:00 PM

Sample Collection Method:

Date of Sample Receipt: 12/4/2006

Laboratory Results


PARAMETER	Result	Units	MDL	Qualifier Code	Test Method	Analyst	Analysis Date & Time	Lower Limit	Upper Limit	Violation Check
Normality of BaCl2 * 2H2O	0.00975		0.0001			MM	12/4/2006 7:15:00 AM			
SO2 emission rate, lbs/ton of acid	3	lbs/ton acid			EPA - RM6C	RAM	1/3/2007 8:30:00 AM			
SO3 emission rate, lbs/ton of acid	0.05	lbs/ton acid			EPA - RM8	RAM	1/3/2007 8:30:00 AM			
SO3, Avg. of Blank Titrations	0.05	milliliters	0.01		EPA - Meth.8	MM	12/4/2006 7:15:00 AM			
SO3, Run #1, Avg. of Titrations	5.1	milliliters	0.01		EPA - Meth.8	MM	12/4/2006 7:15:00 AM			
SO3, Run #2, Avg. of Titrations	5.25	milliliters	0.01		EPA - Meth.8	MM	12/4/2006 7:15:00 AM			
SO3, Run #3, Avg. of Titrations	4.85	milliliters	0.01		EPA - Meth.8	MM	12/4/2006 7:15:00 AM			
SO3, Volume of Contained Sample	500	milliliters	1		EPA - Meth.8	MM	12/4/2006 7:15:00 AM			
SO3, Volume of Sample Aliquot	100	milliliters	0.1		EPA - Meth.8	MM	12/4/2006 7:15:00 AM			

Comments

All results calculated on a wet to wet basis, unless otherwise indicated.

Data Qualifier Codes Explanation:

Subcontracted Laboratories:



Robert Dorey,
Manager, Laboratory Services

CALIBRATION DATA



Environmental Services
Air Services Group

SUMMARY OF EQUIPMENT CALIBRATIONS

<u>EQUIPMENT</u>	<u>CAL DATE</u>	<u>METHOD</u>	<u>RESULTS</u>
<u>CONSOLE (MB 07)</u>		USEPA RM 5	
INITIAL	10/03/2006	(ORIFICE)	0.999
POST TEST	12/04/2006		0.976
<u>NOZZLE (SN74)</u>			
INITIAL	10/02/2006	CALIPER	0.490
POST TEST	12/04/2006	MEASUREMENTS	0.490
PYROMETER (PY 09)	10/02/2006	ASTM THERMOMETER	$\pm 2^{\circ}$ F
PITOT TUBE (PT 05)	10/03/2006	USEPA RM 2	$C_p = 0.84$
BAROMETER (BR 07)	10/02/2006	NWS COMPARISON	± 0.01 " Hg



**USEPA Reference Method 5
Dry Gas Meter Calibration
Critical Orifice Method
Quarterly Calibration**

**Environmental Services
Air Services Group**

Blue Team

Manufacturer: Thermo Anderson
Model Number: MST-C1
Instrument Code Number: ^MB07
LabWorks Sample Number:

Calibration Date: 10/3/2006
Barometric Pressure: 30.15 "Hg
Theoretical Critical Vacuum: 14.22 "Hg
Calibrated By: JAV

IMPORTANT

For valid test results, the Actual Vacuum should be 1 to 2 "Hg greater than the Theoretical Critical Vacuum Shown above.
The Critical Orifice Coefficient, K', should be in English units.

IMPORTANT

Dry Gas Meter Readings

ΔH "H ₂ O	Time Minutes	Initial	Final	Total	Initial Temperatures		Final Temperatures	
		Volume ft ³	Volume ft ³	Volume ft ³	Inlet °F	Outlet °F	Inlet °F	Outlet °F
0.60	15	356.984	363.887	6.903	79	77	79	77
1.10	15	347.782	356.984	9.202	81	78	80	78
1.90	15	335.841	347.782	11.941	81	78	83	78
3.50	15	319.720	335.841	16.121	80	75	88	78

Critical Orifice Readings

Orifice Serial Number	K' Orifice Coefficient	Actual Vacuum "Hg	Ambient Temperatures		
			Initial °F	Final °F	Average °F
48	0.3483	22.0	72	72	72.0
55	0.4660	21.0	72	72	72.0
63	0.5971	19.0	72	72	72.0
73	0.8177	16.5	72	72	72.0

CALCULATED DATA

Dry Gas Meter Volume Corrected Vm _(std) , ft ³	Critical Orifice Volume Corrected Vcr _(std) , ft ³	Critical Orifice Volume Nominal Vcr _(std) , ft ³	Calibration Y Value (ratio)	Calibration ΔHα Value "H ₂ O	Calibration QA/QC ± 0.02	Calibration QA/QC ± 0.2
6.834	6.829	6.831	0.999	1.610	0.000	-0.060
9.100	9.137	9.140	1.004	1.645	0.005	-0.025
11.815	11.708	11.711	0.991	1.729	-0.008	0.058
16.006	16.033	16.038	1.002	1.697	0.003	0.027

Averages: 0.999

1.670

For Calibration Y, the ratio of the reading of the calibration orifice to the dry gas meter, acceptable tolerance from average is ± 0.02.

For Calibration ΔHα, the acceptable tolerance of individual values from the average is + 0.2.

Review/Approval:

5-Oct-06



**USEPA Reference Method 5
Dry Gas Meter Calibration
Critical Orifice Method
POST - TEST CALIBRATION CHECK**

**Environmental Services
Air Services Group**

Manufacturer: Thermo	Calibration Date: 12/4/2006
Model Number: MST	Barometric Pressure: 30.4 "Hg
Instrument Code Number: MB07	Theoretical Critical Vacuum: 14.34 "Hg
LabWorks Sample Number:	Calibrated By: GDB
Associated Test: Polk Acid Plant	Team: BLUE

IMPORTANT

For valid test results, the Actual Vacuum should be 1 to 2 "Hg greater than the Theoretical Critical Vacuum Shown above.
The Critical Orifice Coefficient, K', should be in English units.

IMPORTANT

Dry Gas Meter Readings

ΔH "H ₂ O	Time Minutes	Initial	Final	Total	Initial Temperatures		Final Temperatures	
		Volume ft ³	Volume ft ³	Volume ft ³	Inlet °F	Outlet °F	Inlet °F	Outlet °F
2	10	827.100	834.998	7.898	74	68	75	71
2	10	834.998	842.717	7.719	75	71	75	74
2	10	842.717	850.675	7.958	75	74	78	74

Critical Orifice Readings


Orifice Serial Number	K' Orifice Coefficient	Actual Vacuum "Hg	Ambient Temperatures		
			Initial °F	Final °F	Average °F
63	0.5877	19.0	72	72	72.0
63	0.5877	19.0	72	72	72.0
63	0.5877	19.0	72	72	72.0

CALCULATED DATA

Dry Gas Meter	Critical Orifice		Calibration	Calibration		
Volume Corrected Vm _(std) , ft ³	Volume Corrected Vcr _(std) , ft ³	Volume Nominal Vcr _(std) , ft ³	Y Value (ratio)	QA/QC ± 0.02	ΔHα Value "H ₂ O	QA/QC ± 0.2
8.000	7.746	7.684	0.968	-0.008	1.891	0.006
7.793	7.746	7.684	0.994	0.018	1.885	0.000
8.012	7.746	7.684	0.967	-0.010	1.879	-0.006
Averages:			0.976		1.885	
Prior Y:			0.999			
% Difference:			2.27%			

For Calibration Y, the ratio of the reading of the calibration orifice to the dry gas meter, acceptable tolerance from average is ± 0.02.

For Calibration ΔHα, the acceptable tolerance of individual values from the average is + 0.2.

Review/Approval 

Date: 7-Dec-06



Environmental Services
Air Services Group

QUARTERLY NOZZLE CALIBRATIONS


Shared Resource

STEEL NOZZLE SET

Calibration Date: 10/2/2006 Responsible Party: SEG

Nozzle I.D.	Nozzle Diameter, D _n (cm)			Maximum Difference, "	Average D _{nr} inches
	D ₁	D ₂	D ₃		
^SN01	0.296	0.294	0.290	0.002	0.115
^SN04	0.320	0.320	0.320	0.000	0.126
^SN05	0.380	0.380	0.378	0.001	0.149
^SN06	0.500	0.496	0.500	0.002	0.196
^SN09	0.695	0.689	0.690	0.002	0.272
^SN10	0.755	0.750	0.755	0.002	0.297
^SN12	0.985	0.985	0.983	0.001	0.388
^SN15	0.420	0.420	0.420	0.000	0.165
^SN16	0.504	0.505	0.505	0.000	0.199
^SN19	0.717	0.714	0.715	0.001	0.282
^SN22	0.932	0.930	0.934	0.002	0.367
^SN30	0.795	0.792	0.795	0.001	0.313
^SN36	0.480	0.477	0.477	0.001	0.188
^SN37	0.535	0.534	0.532	0.001	0.210
^SN38	0.635	0.640	0.640	0.002	0.251
^SN46	0.482	0.485	0.483	0.001	0.190
^SN47	0.515	0.516	0.516	0.000	0.203
^SN48	0.645	0.640	0.640	0.002	0.253
^SN50	0.788	0.790	0.791	0.001	0.311
^SN58	0.619	0.611	0.615	0.003	0.242
^SN68	0.630	0.625	0.632	0.003	0.248
^SN69	0.950	0.950	0.950	0.000	0.374
^SN70	1.565	1.565	1.565	0.000	0.616
^SN71	1.558	1.560	1.560	0.001	0.614
^SN72	0.955	0.953	0.950	0.002	0.375
^SN73	1.277	1.280	1.280	0.001	0.504
^SN74	1.245	1.240	1.245	0.002	0.490

Data Notations: All micrometer readings are converted from cm to inches by multiplying by 0.393700787. Maximum Difference must be ≤ 0.004".

QA/QC Review by: 

5-Oct-06



POST TEST NOZZLE CALIBRATION

Shared Resource


Calibration Date: 12/4/2006
Calibration Personnel: SEG
Test Designation: POLK ACID PLANT

Nozzle Identifier	Nozzle Diameter, D _n (cm)			Maximum Difference, "	Average D _n , inches
	D ₁	D ₂	D ₃		
^SN74	1.245	1.245	1.240	0.002	0.490

Data Notations: All micrometer readings are converted from cm to inches by multiplying by 0.393700787. Maximum Difference must be ≤ 0.004".

Quarterly (pre-test) value for nozzle ID ^SN74 was 0.490

Difference (Pre-test/Post-test) is: 0.000

QA/QC Review by: 

7-Dec-06



Environmental Services
Air Services Group

Pyrometer Calibration

Blue Team

Pyrometer Under Test

Pyrometer Number: ^PY09
Labworks Sample # 0
Calibration Date: 10/2/2006

Calibrator Information

Calibrator Type/Manufacturer: Hart Scientific
Calibrator Serial Number: AOA024
Date of Last Calibration: 7/11/2006
Calibration Personnel (Typed and Signature): JAV

Calibration Data

Calibration Point	Reference Temperature	Pyrometer Indication	Difference
1	400	399	1
2	212	213	-1
3	32	33	-1

Reference temperatures must encompass the expected range of measurement. These three points should be ~ 32 degrees, ~212 degrees, and ~ 400 degrees Farenheit.

Difference is calculated as follows:

$$(\text{reference temperature}) - (\text{pyrometer indication})$$

Quality Control Data

Calibration Point	Difference
1	Pass
2	Pass
3	Pass

Reviewer:

5-Oct-06



PITOT TUBE CALIBRATION DATA SHEET

Environmental Services Air Services Group

Pitot Tube ID # PT05

Calibration Date 10/3/2006

Operating Quarter/Year:

Red Team

Openings Damaged? [] Y [x] N

Repaired? [] Y [x] N [] N/A

Labworks #: 0

Alpha and Beta Angle Determinations

alpha_1 2 degrees Pass

alpha_2 0.8 degrees Pass

beta_1 2.1 degrees Pass

beta_2 3.1 degrees Pass

Gamma, Theta, A, Z, and W Determinations

psi 0.3 degrees

A 2.31 cm

Z 0.012 cm Pass

o 0.1 degrees

W 0.004 cm Pass

Acceptable Limits:
Dt 0.48 < Dt < 0.95 cm
alpha < 10 degrees
(alpha_1 measured across top impact openings)
(alpha_2 measured across bottom impact openings)
beta_1 < 5 degrees (alongside top impact openings)
beta_2 < 5 degrees (alongside bottom impact openings)
Z < 0.32 cm (Asinpsi)
W < 0.08 cm (Asino)
A distance between tips
o angle of plane on side of pitots
psi angle between tips

NOTES

All measurements are taken in accordance with the requirements of 40 CFR 60, Appendix A - Test Methods, Method 2, "Determination of stack gas velocity and volumetric flow rate (Type S pitot tube)". Measurement details are found in EPA/600/4-77/027b, "Quality Assurance Handbook for Air Pollution Measurement Systems: Stationary Source Specific Methods", sub-section 3.1.1, Procurement of Apparatus and Supplies.

Comments: REMOVABLE

Calibrated by:

Quality Assurance Review / Approval:

[Signature]

16-Oct-06



Environmental Services
Air Services Group

BAROMETER CALIBRATION

Blue Team


Instrument Number: ^BR04
Calibration Date: 10/2/2006
Calibration Personnel: JAV

Labworks #:

Time	Barometer Reading Inches Mercury	Reference Reading Inches Mercury	Difference "Hg
11:00	30.25	30.18	0.07
13:00	30.2	30.15	0.05
14:50	30.2	30.12	0.08
Average Difference:			0.07

Note: Barometric readings must agree within ± 0.1 "Hg.
Current Reference is National Weather Service, TIA.
Current Conditions at Tampa International Airport

Comments (Note any adjustments):

QA/QC Review by: 

Date: 5-Oct-06

APPENDIX D

INSTRUMENTAL REFERENCE METHOD TEST DATA – IGCC

OXYGEN, CARBON DIOXIDE, CARBON MONOXIDE DATA

Calibration Error Test, Run 1 STRATA Version 2.01

	O2 OT	CO2 OT	CO
	%	%	ppm
12-01-2006 07:34:41	9.135	6.605	-0.101
12-01-2006 07:35:41	21.896	17.456	-1.407
12-01-2006 07:36:40	21.919	17.552	-2.381*
12-01-2006 07:37:41	21.902	17.575	-2.402*
12-01-2006 07:38:40	18.771	14.771	-2.356*
12-01-2006 07:39:41	12.463	9.949	-1.777
12-01-2006 07:40:41	3.870	2.940	-0.796
12-01-2006 07:41:41	0.127	0.049	3.921
12-01-2006 07:42:41	0.015	0.018	6.644
12-01-2006 07:43:41	0.015	0.009	8.672
12-01-2006 07:44:41	0.016	0.009	9.032
12-01-2006 07:45:41	0.017	0.009	9.131
12-01-2006 07:46:41	0.018	0.009	10.894
12-01-2006 07:47:41	0.018	0.013	15.974
12-01-2006 07:48:41	0.018	0.029	16.016
12-01-2006 07:49:41	0.019	0.029	15.959
12-01-2006 07:50:41	0.019	0.029	15.691
12-01-2006 07:51:41	0.173	0.070	17.469
12-01-2006 07:52:41	0.019	0.029	17.377
12-01-2006 07:53:41	0.020	0.019	15.944
12-01-2006 07:54:41	0.020	0.019	15.830
12-01-2006 07:55:41	0.019	0.018	12.653
12-01-2006 07:56:41	0.019	0.017	9.195

Calibration Error Test at Run 1

Operator: Ian T. DeVivi
 Plant Name: TECO Polk Plant
 Location: Unit 1

	Reference Cylinder Numbers			
	Zero	Low-range	Mid-range	High-range
O2 OT	CC-136551		CC-107096	CC-250656
CO2 OT	CC-136551		CC-107096	CC-250656
CO	CC-136551	CC-165111	CC-150548	CC-50737

Date/Time	12-01-2006		07:57:40	PASSED
Analyte	O2 OT	CO2 OT	CO	
Units	%	%	ppm	
Zero Ref Cyl	0.000	0.000	0.000	
Zero Avg	0.004	0.000	0.013	
Zero Error%	0.0%	0.0%	0.1%	
Low Ref Cyl			9.260	
Low Avg			9.286	
Low Error%			0.2%	
Mid Ref Cyl	12.500	9.810	15.900	
Mid Avg	12.460	9.948	15.921	
Mid Error%	0.2%	0.7%	0.1%	
High Ref Cyl	21.900	17.700		
High Avg	21.904	17.580		
High Error%	0.0%	0.6%		

Calibration Error Test End

Initial System Bias Check, Run 1 STRATA Version 2.01

	O2 OT	CO2 OT	CO
	%	%	ppm
12-01-2006 07:59:02	20.711	0.117	5.555
12-01-2006 08:00:02	20.694	0.129	0.443
12-01-2006 08:01:02	20.679	0.130	-0.058
12-01-2006 08:02:01	19.888	0.202	0.005
12-01-2006 08:03:01	0.275	0.102	0.558
12-01-2006 08:04:02	0.002	0.096	0.149
12-01-2006 08:05:02	-0.013	0.075	-0.185
12-01-2006 08:06:02	5.774	4.635	-0.094
12-01-2006 08:07:02	12.284	9.826	-1.114
12-01-2006 08:08:02	7.463	5.968	-1.522
12-01-2006 08:09:01	-0.002	0.152	3.734
12-01-2006 08:10:01	-0.018	0.120	8.256
12-01-2006 08:11:02	-0.023	0.118	8.642
12-01-2006 08:12:01	-0.026	0.109	8.708
12-01-2006 08:13:01	-0.026	0.109	8.609
12-01-2006 08:14:01	-0.026	0.106	8.705

Initial System Bias Check for Run 1
 Operator: Ian T. DeVivi
 Plant Name: TECO Polk Plant
 Location: Unit 1

Reference Cylinder Numbers

	Zero	Span
O2 OT	CC-136551	CC-107096
CO2 OT	CC-136551	CC-107096
CO	CC-136551	CC-165111

Date/Time	12-01-2006	08:14:08	PASSED
Analyte	O2 OT	CO2 OT	CO
Units	%	%	ppm
Zero Ref Cyl	0.000	0.000	0.000
Zero Cal	0.004	0.000	0.013
Zero Avg	-0.010	0.079	-0.185
Zero Bias%	0.1%	0.4%	1.2%
Zero Drift%			
Span Ref Cyl	12.500	9.810	9.260
Span Cal	12.460	9.948	9.286
Span Avg	12.281	9.812	8.769
Span Bias%	0.7%	0.7%	3.3%
Span Drift%			

System Bias Check End

Test Run 1 STRATA Version 2.01

	O2 OT	CO2 OT	CO
	%	%	ppm
12-01-2006 08:59:39	11.711	8.837	3.268
12-01-2006 09:00:39	11.711	8.844	3.256
Begin calculating run averages			
12-01-2006 09:01:46	11.715	8.837	3.094
12-01-2006 09:02:47	11.719	8.832	3.065
12-01-2006 09:03:47	11.707	8.835	2.979
12-01-2006 09:04:47	11.684	8.824	3.289
12-01-2006 09:05:47	11.609	8.829	3.284
12-01-2006 09:06:47	11.669	8.842	3.543
12-01-2006 09:07:47	11.716	8.840	3.358
12-01-2006 09:08:47	11.738	8.845	3.211
12-01-2006 09:09:47	11.713	8.867	3.127
12-01-2006 09:10:46	11.639	8.873	3.081
12-01-2006 09:11:46	11.642	8.884	3.280
12-01-2006 09:12:46	11.663	8.899	3.198
12-01-2006 09:13:46	11.701	8.879	2.988
12-01-2006 09:14:46	11.689	8.880	3.356
12-01-2006 09:15:46	11.617	8.841	3.499
12-01-2006 09:16:47	11.606	8.854	3.710
12-01-2006 09:17:47	11.673	8.844	3.655
12-01-2006 09:18:47	11.699	8.836	3.500
12-01-2006 09:19:47	11.740	8.825	3.205
12-01-2006 09:20:47	11.717	8.829	2.885
12-01-2006 09:21:46	11.705	8.836	3.048
12-01-2006 09:22:46	11.716	8.843	2.986
12-01-2006 09:23:46	11.731	8.847	3.085
12-01-2006 09:24:46	11.708	8.839	3.178
12-01-2006 09:25:46	11.623	8.853	3.201
12-01-2006 09:26:46	11.689	8.839	3.624
12-01-2006 09:27:46	11.738	8.821	3.478
12-01-2006 09:28:46	11.759	8.817	2.945
12-01-2006 09:29:46	11.771	8.804	2.659
12-01-2006 09:30:46	11.676	8.815	2.735
12-01-2006 09:31:46	11.658	8.828	3.158
12-01-2006 09:32:46	11.701	8.830	3.126
12-01-2006 09:33:46	11.733	8.833	2.946
12-01-2006 09:34:46	11.742	8.827	3.189
12-01-2006 09:35:46	11.638	8.825	3.028
12-01-2006 09:36:46	11.617	8.846	3.527
12-01-2006 09:37:46	11.693	8.816	3.430
12-01-2006 09:38:46	11.699	8.812	3.123
12-01-2006 09:39:46	11.724	8.809	3.100
12-01-2006 09:40:46	11.694	8.809	2.836
12-01-2006 09:41:47	11.675	8.811	3.218
12-01-2006 09:42:47	11.695	8.813	3.244
12-01-2006 09:43:47	11.741	8.818	3.229
12-01-2006 09:44:46	11.727	8.820	3.007
12-01-2006 09:45:46	11.633	8.827	3.190
12-01-2006 09:46:46	11.688	8.831	3.576
12-01-2006 09:47:46	11.735	8.823	3.223
12-01-2006 09:48:46	11.750	8.824	2.978
12-01-2006 09:49:46	11.743	8.810	3.152
12-01-2006 09:50:46	11.667	8.796	3.068
12-01-2006 09:51:46	11.663	8.795	3.346
12-01-2006 09:52:46	11.717	8.796	3.203
12-01-2006 09:53:46	11.747	8.796	2.982
12-01-2006 09:54:46	11.769	8.804	2.721
12-01-2006 09:55:46	11.654	8.812	2.778
12-01-2006 09:56:46	11.625	8.827	3.424
12-01-2006 09:57:47	11.705	8.823	3.362
12-01-2006 09:58:47	11.733	8.816	3.086
12-01-2006 09:59:47	11.736	8.799	3.047
12-01-2006 10:00:47	11.726	8.793	2.713
Run Averages			
	O2 OT	CO2 OT	CO
	%	%	ppm
12-01-2006 10:00:47	11.697	8.830	3.171

Operator: Ian T. DeVivi
 Plant Name: TECO Polk Plant
 Location: Unit 1
 Test Run 1 End

Final System Bias Check, Run 1 STRATA Version 2.01

	O2 OT	CO2 OT	CO
	%	%	ppm
12-01-2006 10:02:14	4.656	3.219	3.068
12-01-2006 10:03:14	-0.025	0.192	1.134
12-01-2006 10:04:14	-0.035	0.167	-0.163
12-01-2006 10:05:14	-0.019	0.170	-0.228
12-01-2006 10:06:14	11.704	9.449	-0.778
12-01-2006 10:07:14	12.267	9.927	-1.867
12-01-2006 10:08:14	4.153	3.451	-0.961
12-01-2006 10:09:14	-0.024	0.212	5.731
12-01-2006 10:10:14	-0.034	0.185	8.584
12-01-2006 10:11:14	-0.037	0.158	8.560
12-01-2006 10:12:14	-0.039	0.149	8.666

Final System Bias Check for Run 1
 Operator: Ian T. DeVivi
 Plant Name: TECO Polk Plant
 Location: Unit 1

Reference Cylinder Numbers

	Zero	Span
O2 OT	CC-136551	CC-107096
CO2 OT	CC-136551	CC-107096
CO	CC-136551	CC-165111

Date/Time	12-01-2006		10:12:38	PASSED
Analyte	O2 OT	CO2 OT	CO	
Units	%	%	ppm	
Zero Ref Cyl	0.000	0.000	0.000	
Zero Cal	0.004	0.000	0.013	
Zero Avg	-0.036	0.163	-0.245	
Zero Bias%	0.2%	0.8%	1.6%	
Zero Drift%	-0.1%	0.4%	-0.4%	
Span Ref Cyl	12.500	9.810	9.260	
Span Cal	12.460	9.948	9.286	
Span Avg	12.262	9.911	8.768	
Span Bias%	0.8%	0.2%	3.3%	
Span Drift%	-0.1%	0.5%	0.0%	
Ini Zero Avg	-0.010	0.079	-0.185	
Ini Span Avg	12.281	9.812	8.769	
Run Avg	11.697	8.830	3.171	
Co	-0.023	0.121	-0.215	
Cm	12.271	9.862	8.769	
Correct Avg	11.916	8.771	3.490	

System Bias Check End

Test Run 2 STRATA Version 2.01

	O2 OT	CO2 OT	CO
	%	%	ppm
12-01-2006 10:13:39	0.387	0.430	8.564
12-01-2006 10:14:40	11.489	8.597	6.702
12-01-2006 10:15:39	11.679	8.736	3.535
12-01-2006 10:16:39	11.636	8.783	3.486
12-01-2006 10:17:39	11.693	8.790	3.624
12-01-2006 10:18:39	11.729	8.786	3.468
12-01-2006 10:19:39	11.763	8.783	2.958
12-01-2006 10:20:39	11.737	8.779	2.574
12-01-2006 10:21:40	11.731	8.770	2.727
12-01-2006 10:22:40	11.728	8.769	2.890
12-01-2006 10:23:39	11.746	8.774	2.984
12-01-2006 10:24:39	11.759	8.761	3.060
12-01-2006 10:25:39	11.665	8.771	2.946
12-01-2006 10:26:39	11.705	8.785	2.975
12-01-2006 10:27:39	11.755	8.795	2.962
12-01-2006 10:28:39	11.751	8.824	2.766
12-01-2006 10:29:39	11.764	8.817	2.736
12-01-2006 10:30:39	11.726	8.814	2.877
12-01-2006 10:31:39	11.697	8.822	3.027
12-01-2006 10:32:39	11.732	8.817	3.149
12-01-2006 10:33:39	11.747	8.794	2.925
12-01-2006 10:34:39	11.750	8.792	2.664
12-01-2006 10:35:40	11.691	8.778	2.888
12-01-2006 10:36:39	11.674	8.758	2.859
12-01-2006 10:37:39	11.737	8.763	2.688
12-01-2006 10:38:39	11.749	8.780	2.647
12-01-2006 10:39:39	11.744	8.783	2.899
12-01-2006 10:40:39	11.746	8.788	2.672
12-01-2006 10:41:39	11.768	8.767	2.625
12-01-2006 10:42:39	11.758	8.780	2.419
12-01-2006 10:43:39	11.765	8.783	2.593
12-01-2006 10:44:39	11.768	8.765	2.626
Begin calculating run averages			
12-01-2006 10:46:05	11.668	8.771	2.919
12-01-2006 10:47:05	11.750	8.759	3.003
12-01-2006 10:48:05	11.773	8.758	2.703
12-01-2006 10:49:05	11.774	8.757	2.506
12-01-2006 10:50:05	11.766	8.765	2.549
12-01-2006 10:51:04	11.707	8.780	2.902
12-01-2006 10:52:04	11.723	8.775	3.095
12-01-2006 10:53:04	11.746	8.777	3.064
12-01-2006 10:54:04	11.750	8.778	3.031
12-01-2006 10:55:04	11.745	8.775	2.894
12-01-2006 10:56:04	11.657	8.753	2.885
12-01-2006 10:57:04	11.669	8.761	3.222
12-01-2006 10:58:04	11.718	8.750	3.138
12-01-2006 10:59:04	11.750	8.754	2.945
12-01-2006 11:00:04	11.734	8.757	2.775
12-01-2006 11:01:04	11.719	8.762	2.898
12-01-2006 11:02:05	11.714	8.783	3.131
12-01-2006 11:03:05	11.737	8.772	2.921
12-01-2006 11:04:05	11.750	8.779	2.947
12-01-2006 11:05:05	11.723	8.771	2.854
12-01-2006 11:06:05	11.671	8.776	3.290
12-01-2006 11:07:05	11.734	8.763	3.083
12-01-2006 11:08:05	11.766	8.750	2.816
12-01-2006 11:09:05	11.780	8.757	2.563
12-01-2006 11:10:05	11.782	8.745	2.581
12-01-2006 11:11:05	11.703	8.759	2.570
12-01-2006 11:12:05	11.721	8.764	3.056
12-01-2006 11:13:05	11.735	8.787	2.781
12-01-2006 11:14:05	11.739	8.798	2.433
12-01-2006 11:15:05	11.750	8.776	2.645
12-01-2006 11:16:05	11.664	8.777	2.956
12-01-2006 11:17:05	11.692	8.788	3.150
12-01-2006 11:18:05	11.733	8.777	2.907
12-01-2006 11:19:05	11.738	8.767	2.690
12-01-2006 11:20:05	11.750	8.751	2.738
12-01-2006 11:21:05	11.733	8.754	2.712
12-01-2006 11:22:05	11.762	8.749	2.690
12-01-2006 11:23:05	11.743	8.772	2.743
12-01-2006 11:24:05	11.725	8.789	2.911
12-01-2006 11:25:05	11.701	8.776	3.106
12-01-2006 11:26:05	11.678	8.786	3.106
12-01-2006 11:27:05	11.734	8.795	2.932
12-01-2006 11:28:05	11.769	8.781	2.584
12-01-2006 11:29:05	11.798	8.759	2.609
12-01-2006 11:30:05	11.793	8.760	2.333
12-01-2006 11:31:05	11.713	8.753	2.452
12-01-2006 11:32:05	11.687	8.776	2.787
12-01-2006 11:33:05	11.752	8.757	2.961
12-01-2006 11:34:05	11.753	8.765	2.849
12-01-2006 11:35:04	11.759	8.777	2.864

12-01-2006 11:36:05	11.677	8.768	2.580
12-01-2006 11:37:05	11.688	8.787	2.988
12-01-2006 11:38:04	11.738	8.779	3.134
12-01-2006 11:39:04	11.764	8.775	2.822
12-01-2006 11:40:04	11.762	8.766	2.685
12-01-2006 11:41:04	11.748	8.757	2.599
12-01-2006 11:42:04	11.759	8.762	2.690
12-01-2006 11:43:04	11.771	8.763	2.535
12-01-2006 11:44:04	11.766	8.771	2.570
12-01-2006 11:45:04	11.725	8.781	2.679
Run Averages	O2 O ₂	CO2 O ₂	CO
	%	%	ppm
12-01-2006 11:45:04	11.734	8.769	2.826

Operator: Ian T. DeVivi
 Plant Name: TECO Polk Plant
 Location: Unit 1
 Test Run 2 End

Final System Bias Check, Run 2 STRATA Version 2.01

	O2 OT	CO2 OT	CO
	%	%	ppm
12-01-2006 11:47:04	8.454	6.058	3.028
12-01-2006 11:48:04	-0.016	0.284	1.581
12-01-2006 11:49:04	-0.034	0.247	-0.482
12-01-2006 11:50:04	1.360	1.328	-0.452
12-01-2006 11:51:04	12.208	9.871	-1.100
12-01-2006 11:52:04	12.258	9.942	-1.675
12-01-2006 11:53:04	1.510	1.400	0.062
12-01-2006 11:54:04	-0.027	0.247	6.694
12-01-2006 11:55:04	-0.035	0.224	8.255
12-01-2006 11:56:04	-0.037	0.220	8.358
12-01-2006 11:57:05	-0.039	0.227	8.642

Final System Bias Check for Run 2

Operator: Ian T. DeVivi
 Plant Name: TECO Polk Plant
 Location: Unit 1

Reference Cylinder Numbers

	Zero	Span
O2 OT	CC-136551	CC-107096
CO2 OT	CC-136551	CC-107096
CO	CC-136551	CC-165111

Date/Time	12-01-2006		11:57:30	PASSED
Analyte	O2 OT	CO2 OT	CO	
Units	%	%	ppm	
Zero Ref Cyl	0.000	0.000	0.000	
Zero Cal	0.004	0.000	0.013	
Zero Avg	-0.034	0.245	-0.564	
Zero Bias%	0.2%	1.2%	3.6%	
Zero Drift%	0.0%	0.4%	-2.0%	
Span Ref Cyl	12.500	9.810	9.260	
Span Cal	12.460	9.948	9.286	
Span Avg	12.249	9.925	8.914	
Span Bias%	0.8%	0.1%	2.3%	
Span Drift%	-0.1%	0.1%	0.9%	
Ini Zero Avg	-0.036	0.163	-0.245	
Ini Span Avg	12.262	9.911	8.768	
Run Avg	11.734	8.769	2.826	
Co	-0.035	0.204	-0.405	
Cm	12.255	9.918	8.841	
Correct Avg	11.969	8.650	3.236	
System Bias Check End				

Test Run 3 STRATA Version 2.01

	O2	OT	CO2	OT	CO
	%		%		ppm
12-01-2006 12:17:01	11.640		8.740		3.143
12-01-2006 12:18:00	11.705		8.737		3.038
12-01-2006 12:19:00	11.730		8.740		2.841
12-01-2006 12:20:00	11.748		8.765		2.670
Begin calculating run averages					
12-01-2006 12:21:21	11.737		8.758		2.820
12-01-2006 12:22:21	11.733		8.763		2.877
12-01-2006 12:23:21	11.751		8.764		3.100
12-01-2006 12:24:21	11.761		8.763		2.860
12-01-2006 12:25:21	11.728		8.747		2.710
12-01-2006 12:26:21	11.709		8.750		2.975
12-01-2006 12:27:20	11.763		8.729		2.843
12-01-2006 12:28:20	11.791		8.727		2.655
12-01-2006 12:29:20	11.812		8.713		2.634
12-01-2006 12:30:20	11.775		8.724		2.448
12-01-2006 12:31:21	11.709		8.733		2.645
12-01-2006 12:32:21	11.714		8.739		2.726
12-01-2006 12:33:21	11.753		8.751		2.721
12-01-2006 12:34:21	11.768		8.739		2.780
12-01-2006 12:35:20	11.748		8.736		2.556
12-01-2006 12:36:20	11.653		8.748		2.960
12-01-2006 12:37:20	11.692		8.753		3.243
12-01-2006 12:38:21	11.728		8.733		3.066
12-01-2006 12:39:21	11.733		8.731		2.734
12-01-2006 12:40:21	11.738		8.724		2.822
12-01-2006 12:41:21	11.741		8.713		2.925
12-01-2006 12:42:20	11.777		8.711		2.766
12-01-2006 12:43:20	11.764		8.756		2.652
12-01-2006 12:44:20	11.779		8.740		2.660
12-01-2006 12:45:20	11.718		8.739		2.847
12-01-2006 12:46:20	11.698		8.750		3.080
12-01-2006 12:47:21	11.763		8.739		2.797
12-01-2006 12:48:21	11.779		8.744		2.561
12-01-2006 12:49:21	11.783		8.743		2.620
12-01-2006 12:50:21	11.769		8.728		2.714
12-01-2006 12:51:21	11.721		8.719		2.742
12-01-2006 12:52:20	11.733		8.732		2.842
12-01-2006 12:53:20	11.761		8.735		2.899
12-01-2006 12:54:21	11.789		8.718		2.648
12-01-2006 12:55:21	11.771		8.729		2.370
12-01-2006 12:56:21	11.680		8.731		2.574
12-01-2006 12:57:21	11.705		8.747		2.777
12-01-2006 12:58:21	11.744		8.745		2.894
12-01-2006 12:59:20	11.756		8.737		2.728
12-01-2006 13:00:20	11.752		8.732		2.781
12-01-2006 13:01:21	11.728		8.752		2.742
12-01-2006 13:02:21	11.760		8.738		2.850
12-01-2006 13:03:21	11.772		8.736		2.488
12-01-2006 13:04:21	11.771		8.740		2.412
12-01-2006 13:05:21	11.726		8.741		2.686
12-01-2006 13:06:21	11.716		8.742		2.821
12-01-2006 13:07:21	11.765		8.751		2.895
12-01-2006 13:08:21	11.792		8.740		2.598
12-01-2006 13:09:21	11.793		8.734		2.460
12-01-2006 13:10:20	11.769		8.735		2.640
12-01-2006 13:11:20	11.727		8.724		2.886
12-01-2006 13:12:21	11.748		8.728		2.899
12-01-2006 13:13:20	11.784		8.721		2.768
12-01-2006 13:14:20	11.795		8.703		2.294
12-01-2006 13:15:20	11.762		8.707		2.015
12-01-2006 13:16:20	11.674		8.710		2.799
12-01-2006 13:17:20	11.714		8.712		3.015
12-01-2006 13:18:21	11.752		8.714		2.735
12-01-2006 13:19:21	11.780		8.718		2.425
12-01-2006 13:20:21	11.764		8.737		2.303
Run Averages					
	O2	OT	CO2	OT	CO
	%		%		ppm
12-01-2006 13:20:21	11.748		8.735		2.730

Operator: Ian T. DeVivi
 Plant Name: TECO Polk Plant
 Location: Unit 1
 Test Run 3 End

Final System Bias Check, Run 3 STRATA Version 2.01

	O2 OT	CO2 OT	CO
	%	%	ppm
12-01-2006 13:21:28	4.919	3.523	2.629
12-01-2006 13:22:28	-0.021	0.299	0.899
12-01-2006 13:23:28	-0.033	0.274	-0.315
12-01-2006 13:24:28	4.819	4.069	-0.391
12-01-2006 13:25:28	12.239	9.876	-1.419
12-01-2006 13:26:28	6.082	4.985	-1.571
12-01-2006 13:27:28	-0.018	0.296	4.431
12-01-2006 13:28:28	-0.031	0.262	8.447

Final System Bias Check for Run 3

Operator: Ian T. DeVivi
 Plant Name: TECO Polk Plant
 Location: Unit 1

	Reference Cylinder Numbers	
	Zero	Span
O2 OT	CC-136551	CC-107096
CO2 OT	CC-136551	CC-107096
CO	CC-136551	CC-165111

Date/Time	12-01-2006		13:28:54	PASSED
Analyte	O2 OT	CO2 OT	CO	
Units	%	%	ppm	
Zero Ref Cyl	0.000	0.000	0.000	
Zero Cal	0.004	0.000	0.013	
Zero Avg	-0.032	0.278	-0.341	
Zero Bias%	0.1%	1.4%	2.2%	
Zero Drift%	0.0%	0.2%	1.4%	
Span Ref Cyl	12.500	9.810	9.260	
Span Cal	12.460	9.948	9.286	
Span Avg	12.232	9.861	8.785	
Span Bias%	0.9%	0.4%	3.2%	
Span Drift%	-0.1%	-0.3%	-0.8%	
Ini Zero Avg	-0.034	0.245	-0.564	
Ini Span Avg	12.249	9.925	8.914	
Run Avg	11.748	8.735	2.730	
Co	-0.033	0.261	-0.453	
Cm	12.240	9.893	8.849	
Correct Avg	11.998	8.631	3.168	
System Bias Check End				

CALIBRATION GAS CERTIFICATIONS



Certificate of Analysis

EPA Protocol

Performed according to EPA-600/R-97/121, Procedure G1

Notice: This Cylinder is not to be used when pressure is under 150 psig.

Manufactured and certified at:

Linde Gas LLC
Maumee Specialty Gas Plant
6421 Monclova Road
MAUMEE OH 43537
419-893-7226

Produced for customer:

MFD/HOLOX LTD
4236 STATESVILLE RD
CHARLOTTE NC 28269-4298
USA
704-596-6262

Material:	6132	Blend Tolerance:	5 % Relative
EPA CO/N2 3-9.9 PPM	A31	Store/Use Temp:	35 to 90 F
Production #:	100065596	Blend Type:	EPA Protocol
Lot #:	02499D3040GD	Cyl. Pressure:	2000 psig
Cylinder #:	CC165111	Balance Gas:	Nitrogen
Expiration Date:	11/16/2009	CGA:	350
Shelf Life:	36 months	Analytical Accuracy:	1.00 % Relative

CAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
630-08-0	Carbon Monoxide	9	9.28 +/- 0.1 ppm	11/16/2006
7727-37-9	Nitrogen		Balance	11/16/2006
630-08-0	Carbon Monoxide	9	9.26 +/- 0.18 ppm	04/15/2003
7727-37-9	Nitrogen		Balance	04/15/2003

CAS #	Reference Standard	Cylinder/Standard #	Concentration	Expire Date
630-08-0	Carbon Monoxide	CC180333 , NTRM	10.17 ppm	07/11/2009

Instrument	Serial #	Analytical Principle	Calibration Date
MCTa FTIR	AET0600294	FTIR	11/16, 2006

All analyses are performed under controlled environmental conditions. This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.

Linde Gas LLC

6055 Reel Street, Wrentham, MA 01995
Independence, OH 44131
USA
Phone: (216) 642-6600
Fax: (216) 642-9675
www.us.lindegas.com





P. O. Box 12013
 Research Triangle Park, N.C. 27709
 Phone 919/544-3772

CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS MIXTURE

Customer:	National Welders, Charlotte, NC	Reference #	8B-94904
NSG PO#	4704164	Certification Date:	12/28/04
Customer PO#		Expiration Date:	12/28/07
Cylinder #	CC50737	Pressure, psig*	2000

ANALYTICAL INFORMATION

METHOD: This standard was analyzed according to EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards: Procedure G1 (September 1997)

ANALYZED CYLINDER


<u>Components</u>	<u>Certified Concentration</u>	<u>Analytical Accuracy**</u>
Carbon Monoxide	29.8 ppm	+/-1%
Balance - Nitrogen		

REFERENCE STANDARD

<u>Type/SRM Sample #</u>	<u>Cylinder #</u>	<u>Concentration</u>
GMIS (Traceable to SRM # 1678c)	CC87177	50.2 ppm CO/N2

INSTRUMENTATION

<u>Instrument/Model/Serial #</u>	<u>Last Date Calibrated</u>	<u>Analytical Method</u>
Rosemount 880A CO 00172	12/08/04	Non-dispersive Infrared

Analyst:  Jeremy Kenworthy

This report states accurately the results of the investigation made upon the material submitted to the analytical laboratory. Every effort has been made to determine objectively the information requested. However, in connection with this report, National Specialty Gases shall have no liability in excess of established charge for this service. Assayed at National Specialty Gases, 630 United Drive, Durham, NC 27713 (919) 544-3772

*Do not use this standard when cylinder pressure is below 150 psig.

**Analytical accuracy includes typical known error sources which, at least, include precision of the analytical instrument.



Certificate of Analysis
 EPA Protocol
 Formed according to EPA-600/R-87/121 Procedure G1

Notice: This Cylinder is not to be used when pressure is under 150 psig.

Manufactured and certified at:

Linde Gas LLC
 Charlotte
 4236 Statesville Road
 CHARLOTTE NC 28269

Material:	18225	Blend Tolerance:	5 % Relative
EPA 20-25% O2/16-20% CO2/N2	A31	Blend Type:	EPA Protocol
Production #:	100124043	Cyl. Pressure:	2000 psig
Lot #:	30499H6210DC	Balance Gas:	Nitrogen
Cylinder #:	CC250656	CGA:	590
Expiration Date:	8/25/2009	Analytical Accuracy:	1.00 % Relative
Shelf Life:	36 months	Confidence:	95 %

CAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
124-38-9	Carbon Dioxide	18	17.7 +/- 0.17 %	08/25/2006
7782-44-7	Oxygen	22	21.9 +/- 0.2 %	08/25/2006
7727-37-9	Nitrogen		Balance	

CAS #	Reference Standard	Cylinder/Standard #	Concentration	Expiry Date
7782-44-7	Oxygen	AT9284 , GMIS	21.04 %	03/17/2009
124-38-9	Carbon Dioxide	CC234661 , GMIS	18.11 %	03/29/2009

Instrument	Serial #	Analytical Principle	Calibration Date
Teledyne 3000M	240141	Paramagnetic	05/24/2005
HORIBA MODEL VIA-510 CO2	4285416002	NDIR	11/22/2005

All analyses are performed under controlled environmental conditions. This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.

Analytical report approved by Lance Crayton



Linde Gas



Certificate of Analysis EPA Protocol

Performed according to EPA-600/R-97/121, Procedure G1

Notice: This Cylinder is not to be used when pressure is under -150 psig.

Manufactured and certified at:

Linde Gas LLC
Charlotte
4236 Statesville Road
CHARLOTTE NC 28269

Material:	18224	Blend Tolerance:	5 % Relative
EPA 10-15% O2/8-12% CO2/N2	A31	Blend Type:	EPA Protocol
Production #:	100118070	Cyl. Pressure:	2000 psig
Lot #:	30499E6010CC	Balance Gas:	Nitrogen
Cylinder #:	CC107096	CGA:	590
Expiration Date:	5/8/2009	Analytical Accuracy:	1.00 % Relative
Shelf Life:	36 months	Confidence:	95 %

GAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
7782-44-7	Oxygen	10 to 15	12.5 +/- 0.09 %	05/08/2006
124-38-9	Carbon Dioxide	8 to 12	9.81 +/- 0.09 %	05/08/2006
7727-37-9	Nitrogen		Balance	

GAS #	Reference Standard	Cylinder/Standard #	Concentration	Expiry Date
7782-44-7	Oxygen	112347 , GMIS	10.01 %	05/02/2009
124-38-9	Carbon Dioxide	HO2290685Y , GMIS	14.01 %	05/02/2009

Instrument	Serial #	Analytical Principle	Calibration Date
Teledyne 3000M	240141	Paramagnetic	05/08/2006
HORIBA MODEL VIA-510 CO2	4285416002	NDIR	05/08/2006

All analyses are performed under controlled environmental conditions. This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.

Analytical report approved by Lance Crayton

**HQ Analysis
Certificate**



Certificate of Analysis
 EPA Protocol
 HiQ® Certificate
 Formed according to EPA 600/4-97/121 Procedure G1

Notice: This Cylinder is not to be used when pressure is under 150 psig.

Manufactured and certified at:

Linde Gas LLC
 Charlotte
 4236 Statesville Road
 CHARLOTTE NC 28269

Material:	13968	Blend Tolerance:	5 % Relative
EPA 13 - 18 PPM CO/N2	A31	Blend Type:	GRAVIMETRIC
Production #:	100121715	Cyl. Pressure:	2000 psig
Lot #:	30499G6060DC	Balance Gas:	Nitrogen
Cylinder #:	CC150548	CGA:	350
Expiration Date:	7/19/2009	Analytical Accuracy:	1.00 % Relative
Shelf Life:	36 months	Confidence:	95 %

CAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
630-08-0	Carbon Monoxide	13 to 18	15.9 +/- 0.18 ppm	07/19/2006
7727-37-9	Nitrogen		Balance	07/19/2006

CAS #	Reference Standard	Cylinder/Standard #	Concentration	Expiry Date
630-08-0	Carbon Monoxide	CC180333 , NTRM	10.17 ppm	07/11/2009

Instrument	Serial #	Analytical Principle	Calibration Date
HORIBA MODEL VIA-510 CO	4345887002	NDIR	07/19/2006

All analyses are performed under controlled environmental conditions. This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.

Analytical report approved by Greg Eccleston





Certificate of Analysis
 EPA Protocol
 HiQ® Certificate
 Form prepared according to EPA Method 9071a Procedure G1

Notice: This Cylinder is not to be used when pressure is under 150 psig.

Manufactured and certified at:

Linde Gas LLC
 Charlotte
 4236 Statesville Road
 CHARLOTTE NC 28269

Material:	13970	Blend Tolerance:	5 % Relative
EPA 43 - 47 PPM CO/N2	A31	Blend Type:	GRAVIMETRIC
Production #:	100121717	Cyl. Pressure:	2000 psig
Lot #:	30499G6060DB	Balance Gas:	Nitrogen
Cylinder #:	CC149754	CGA:	350
Expiration Date:	7/19/2009	Analytical Accuracy:	1.00 % Relative
Shelf Life:	36 months	Confidence:	95 %

CAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
630-08-0	Carbon Monoxide	43 to 47	46.3 +/- 0.3 ppm	07/19/2006
7727-37-9	Nitrogen		Balance	07/19/2006

CAS #	Reference Standard	Cylinder Standard #	Concentration	Expire Date
630-08-0	Carbon Monoxide	CC179892 , NTRM	49.33 ppm	07/11/2009

Instrument	Serial #	Analytical Principle	Calibration Date
HORIBA MODEL VIA-510 CO	4345887002	NDIR	07/19/2006

All analyses are performed under controlled environmental conditions. This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.

Analytical report approved by Greg Eccleston





Certificate of Analysis
 HiQ® EPA Protocol
 Formed according to EPA Method 9712, Procedure G1

Notice: This Cylinder is not to be used when pressure is under 150 psig.

Manufactured and certified at:

Linde Gas LLC
 Charlotte
 4236 Statesville Road
 CHARLOTTE NC 28269

Material:	18246	Blend Tolerance:	5 % Relative
EPA 60 PPM CO/N2 (+/-2%)	A31	Blend Type:	EPA Protocol
Production #:	100118386	Cyl. Pressure:	2000 psig
Lot #:	30499E6050DD	Balance Gas:	Nitrogen
Cylinder #:	CC174902	CGA:	350
Expiration Date:	7/12/2009	Analytical Accuracy:	1.00 % Relative
Shelf Life:	36 months	Confidence:	95 %

CAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
630-08-0	Carbon Monoxide	60	61.7 ppm	07/12/2006
7727-37-9	Nitrogen		Balance	

CAS #	Reference Standard	Cylinder/Standard #	Concentration	Expire Date
630-08-0	Carbon Monoxide	CC179892 , NTRM	49.33 ppm	07/11/2009

Instrument	Serial #	Analytical Principle	Calibration Date
HORIBA MODEL VIA-510 CO	4345887002	NDIR	07/12/2006

All analyses are performed under controlled environmental conditions. This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.

Analytical report approved by Lance Crayton



Linde Gas



Certificate of Analysis

EPA Protocol

Performed according to EPA-600/R-97/121, Procedure G1

Notice: This Cylinder is not to be used when pressure is under 150 psig.

Manufactured and certified at:

Linde Gas LLC
Charlotte
4236 Statesville Road
CHARLOTTE NC 28269

Material:	6198	Blend Tolerance:	5 % Relative
EPA CO/N2 100-999 PPM	A31	Blend Type:	EPA Protocol
Production #:	100117213	Cyl. Pressure:	2000 psig
Lot #:	30499D6060DD	Balance Gas:	Nitrogen
Cylinder #:	CC237798	CGA:	350
Expiration Date:	4/18/2009	Analytical Accuracy:	1.00 % Relative
Shelf Life:	36 months	Confidence:	95 %

CAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
630-08-0	Carbon Monoxide	100	101 +/- 0.7 ppm	04/18/2006
7727-37-9	Nitrogen		Balance	

CAS #	Reference Standard	Cylinder/Standard #	Concentration	Expiry Date
630-08-0	Carbon Monoxide	CC179992, NTRM	99.49 ppm	07/11/2009

Instrument	Serial #	Analytical Principle	Calibration Date
HORIBA MODEL VIA-510 CO	4345887002	NDIR	04/18/2006

All analyses are performed under controlled environmental conditions. This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.

Analytical report approved by Lance Crayton



Certificate of Analysis

EPA Protocol

Performed according to EPA-600/R-97/121, Procedure G1

Notice: This Cylinder is not to be used when pressure is under 150 psig.

Manufactured and certified at:

Linde Gas LLC
 Charlotte
 4236 Statesville Road
 CHARLOTTE NC 28269

Material:	2179	Blend Tolerance:	5 % Relative
MISC 3 COMPONENT EPA	A31	Blend Type:	EPA Protocol
Production #:	100115060	Cyl. Pressure:	2000 psig
Lot #:	30499B6100DB	Balance Gas:	Nitrogen
Cylinder #:	CC7551	CGA:	590
Expiration Date:	2/21/2009	Analytical Accuracy:	1.00 % Relative
Shelf Life:	36 months	Confidence:	95 %


CAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
630-08-0	Carbon Monoxide	100	101 +/- 0.7 ppm	02/21/2006
7782-44-7	Oxygen	11	11.0 +/- 0.08 %	02/14/2006
7727-37-9	Nitrogen		Balance	

CAS #	Reference Standard	Cylinder Standard #	Concentration	Expiry Date
7782-44-7	Oxygen	CC73289 , NTRM	9.90 %	06/13/2009
630-08-0	Carbon Monoxide	CC179992 , NTRM	99.49 ppm	07/11/2009

Instrument	Serial #	Analytical Principle	Calibration Date
Teledyne 3000M	240141	Paramagnetic	02/14/2006
HORIBA MODEL VIA-510 CO	4345887002	NDIR	02/21/2006

All analyses are performed under controlled environmental conditions. This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.

Analytical report approved by Lance Crayton






P. O. Box 12013
Research Triangle Park, N.C. 27709
Phone 919/544-3772


CERTIFICATE OF ANALYSIS

CERTIFIED MIXTURE

Customer: National Welders
Charlotte, NC

Reference #: 88-99088
Cylinder #: CC85291
Order #: 5031323
Date Reported: 8/8/2005
Expiration Date: 8/8/2008

Component	Specification	Concentration / *Cert. Accuracy	Analytical Method
Oxygen	12%	12.0% +/- 2%	Paramagnetic
Carbon Dioxide	10%	10.0% +/- 2%	Non-Dispersive Infrared
Balance - Nitrogen			


Analyst Carolyn S. Williams

* CERTIFICATION ACCURACY IS A PERCENTAGE (+/-) OF THE COMPONENT
THIS REPORT STATES ACCURATELY THE RESULTS OF THE INVESTIGATION MADE UPON THE MATERIAL SUBMITTED TO THE ANALYTICAL LABORATORY
EVERY EFFORT HAS BEEN MADE TO DETERMINE OBJECTIVELY THE INFORMATION REQUESTED. HOWEVER, IN CONNECTION WITH ITS RENDERING OF THIS REPORT,
NATIONAL SPECIALTY GASES SHALL HAVE NO LIABILITY IN EXCESS OF THE ESTABLISHED CHARGE FOR THE SERVICE

APPENDIX E

INSTRUMENTAL REFERENCE METHOD TEST DATA – SULFURIC ACID
PLANT

SULFUR DIOXIDE, OXYGEN, CARBON DIOXIDE SUMMARY

Polk Acid Plant - Report			
RUN 1			
	12/1/2006	9:00:01	
Linearity Check - Calibration Error	O2	SO2	CO22
Analyzer Range	25	300	50
Units	%	%	%
Low Level Certified Value (PPM or %)			
Mid Level Certified Value (PPM or %)	10.1	152.2	25.07
High Level Certified Value (PPM or %)	20.9	269	45.1
Zero Level Observed	0.002	-0.003	0.12
Low Level Observed	-	-	-
Mid Level Observed	10.195	152.166	25.024
High Level Observed	21.243	268.599	45.167
Initial Readings			
Zero	0.002	0.583	0.12
Span	10.134	152.166	25.024
Final Readings			
Zero	0.002	0.583	-0.002
Span	10.134	151.873	25.024
Run Results			
Raw Results	8.83	186.01	17.71
Corrected Results (ppmv)	8.8	186.36	17.73
Polk Acid Plant - Report			
RUN 2			
	12/1/2006	10:37:40	
Initial Readings			
Zero	0.002	0.583	-0.002
Span	10.134	151.873	25.024
Final Readings			
Zero	0.002	0.437	-0.002
Span	10.195	152.166	25.024
Run Results			
Raw Results	8.71	188.96	17.87
Corrected Results (ppmv)	8.65	189.31	17.9
Polk Acid Plant - Report			
RUN 3			
	12/1/2006	12:09:56	
Initial Readings			
Zero	0.002	0.437	-0.002
Span	10.195	152.166	25.024
Final Readings			
Zero	0.002	0.437	0.12
Span	10.195	152.605	24.902
Run Results			
Raw Results	8.63	193.98	17.94
Corrected Results (ppmv)	8.55	193.86	18

QUALITY ASSURANCE ACTIVITIES



**POLK POWER STATION
EMISSIONS UNIT ID 004**

INSTRUMENTAL REFERENCE METHOD QUALITY ASSURANCE CALCULATIONS

**SULFURIC ACID PLANT
Analyzer Calibration Error**

ACE = ((C_{Dir} - C_V) / CS) x 100 Eq. 7E-1

		O₂	SO₂	CO₂
Low-level gas	C_{Dir} =	n/a	n/a	n/a
	C_V =	n/a	n/a	n/a
	CS =	n/a	n/a	n/a
	C_{Dir} - C_V =	n/a	n/a	n/a
	(C_{Dir} - C_V) / CS =	n/a	n/a	n/a
	((C_{Dir} - C_V) / CS) x 100 =	n/a	n/a	n/a

		O₂	SO₂	CO₂
Mid-level gas	C_{Dir} =	10.195	152.166	25.024
	C_V =	10.1	152.2	25.07
	CS =	20.9	269	45.1
	C_{Dir} - C_V =	0.095	-0.034	-0.046
	(C_{Dir} - C_V) / CS =	0.00455	-0.00013	-0.00102
	((C_{Dir} - C_V) / CS) x 100 =	0.45	-0.01	-0.10

		O₂	SO₂	CO₂
High-level gas	C_{Dir} =	21.243	268.599	45.167
	C_V =	20.9	269	45.1
	CS =	20.9	269	45.1
	C_{Dir} - C_V =	0.343	-0.401	0.067
	(C_{Dir} - C_V) / CS =	0.01641	-0.00149	0.00149
	((C_{Dir} - C_V) / CS) x 100 =	1.64	-0.15	0.15

Performance Specification is:

ACE ± 2% or |C_{Dir} - C_V| ≤ 0.5 ppm or 0.5 % volume



**POLK POWER STATION
EMISSIONS UNIT ID 004
INSTRUMENTAL REFERENCE METHOD QUALITY ASSURANCE CALCULATIONS**

**COMBINED CYCLE COMBUSTION TURBINE - CT1A
System Bias Calculations**

SB = ((C_S - C_{Dir}) / CS) x 100

Eq. 7E-2

		O₂	SO₂	CO₂
Initial Zero	C_S =	0.002	0.583	0.12
	C_{Dir} =	0.002	-0.003	0.12
	CS =	20.9	269	45.1
	(C_S - C_{Dir}) =	0.000	0.586	0.000
	(C_S - C_{Dir}) / CS =	0.00000	0.00218	0.00000
	((C_S - C_{Dir}) / CS) x 100 =	0.00	0.22	0.00

		O₂	SO₂	CO₂
Initial Span	C_S =	10.134	152.166	25.024
	C_{Dir} =	10.195	152.166	25.024
	CS =	20.9	269	45.1
	(C_S - C_{Dir}) =	-0.061	0.000	0.000
	(C_S - C_{Dir}) / CS =	-0.00292	0.00000	0.00000
	((C_S - C_{Dir}) / CS) x 100 =	-0.29	0.00	0.00

		O₂	SO₂	CO₂
Run 1 Post Run Zero	C_S =	0.002	0.583	-0.002
	C_{Dir} =	0.002	-0.003	0.12
	CS =	20.9	269	45.1
	(C_S - C_{Dir}) =	0.000	0.586	-0.122
	(C_S - C_{Dir}) / CS =	0.00000	0.00218	-0.00271
	((C_S - C_{Dir}) / CS) x 100 =	0.00	0.22	-0.27



**POLK POWER STATION
EMISSIONS UNIT ID 004
INSTRUMENTAL REFERENCE METHOD QUALITY ASSURANCE CALCULATIONS**

**COMBINED CYCLE COMBUSTION TURBINE - CT1A
System Bias Calculations**

		O₂	SO₂	CO₂
Run 1 Post Run Span	C_S =	10.134	151.873	25.024
	C_{Dir} =	10.195	152.166	25.024
	CS =	20.9	269	45.1
	(C_S - C_{Dir}) =	-0.061	-0.293	0.000
	(C_S - C_{Dir}) / CS =	-0.00292	-0.00109	0.00000
	((C_S - C_{Dir}) / CS) x 100 =	-0.29	-0.11	0.00

		O₂	SO₂	CO₂
Run 2 Post Run Zero	C_S =	0.002	0.437	-0.002
	C_{Dir} =	0.002	-0.003	0.12
	CS =	20.9	269	45.1
	(C_S - C_{Dir}) =	0.000	0.440	-0.122
	(C_S - C_{Dir}) / CS =	0.00000	0.00164	-0.00271
	((C_S - C_{Dir}) / CS) x 100 =	0.00	0.16	-0.27

		O₂	SO₂	CO₂
Run 2 Post Run Span	C_S =	10.195	152.166	25.024
	C_{Dir} =	10.195	152.166	25.024
	CS =	20.9	269	45.1
	(C_S - C_{Dir}) =	0.000	0.000	0.000
	(C_S - C_{Dir}) / CS =	0.00000	0.00000	0.00000
	((C_S - C_{Dir}) / CS) x 100 =	0.00	0.00	0.00



**POLK POWER STATION
EMISSIONS UNIT ID 004
INSTRUMENTAL REFERENCE METHOD QUALITY ASSURANCE CALCULATIONS**

**COMBINED CYCLE COMBUSTION TURBINE - CT1A
System Bias Calculations**

		O₂	SO₂	CO₂
Run 3 Post Run Zero	C_S =	0.002	0.437	0.12
	C_{Dir} =	0.002	-0.003	0.12
	CS =	20.9	269	45.1
	(C_S - C_{Dir}) =	0.000	0.440	0.000
	(C_S - C_{Dir}) / CS =	0.00000	0.00164	0.00000
	((C_S - C_{Dir}) / CS) x 100 =	0.00	0.16	0.00

		O₂	SO₂	CO₂
Run 3 Post Run Span	C_S =	10.195	152.605	24.902
	C_{Dir} =	10.195	152.166	25.024
	CS =	20.9	269	45.1
	(C_S - C_{Dir}) =	0.000	0.439	-0.122
	(C_S - C_{Dir}) / CS =	0.00000	0.00163	-0.00271
	((C_S - C_{Dir}) / CS) x 100 =	0.00	0.16	-0.27

Performance Specification is:

SB ± 5% or |C_S - Cdir| ≤ 0.5 ppm or 0.5 % volume



**POLK POWER STATION
EMISSIONS UNIT ID 004
INSTRUMENTAL REFERENCE METHOD QUALITY ASSURANCE CALCULATIONS**

**COMBINED CYCLE COMBUSTION TURBINE - CT1A
Drift Assessment Calculations**

$D = SB_{final} - SB_i $		Eq. 7E-4		
		O_2	SO_2	CO_2
Run 1 Zero	$SB_{final} =$	0.00	0.22	-0.27
	$SB_i =$	0.00	0.22	0.00
	$ SB_{final} - SB_i =$	0.00	0.00	0.27
Run 1 Span	$SB_{final} =$	-0.29	-0.11	0.00
	$SB_i =$	-0.29	0.00	0.00
	$ SB_{final} - SB_i =$	0.00	0.11	0.00
Run 2 Zero	$SB_{final} =$	0.00	0.16	-0.27
	$SB_i =$	0.00	0.22	-0.27
	$ SB_{final} - SB_i =$	0.00	0.05	0.00
Run 2 Span	$SB_{final} =$	0.00	0.00	0.00
	$SB_i =$	-0.29	-0.11	0.00
	$ SB_{final} - SB_i =$	0.29	0.11	0.00
Run 3 Zero	$SB_{final} =$	0.00	0.16	0.00
	$SB_i =$	0.00	0.16	-0.27
	$ SB_{final} - SB_i =$	0.00	0.00	0.27
Run 3 Span	$SB_{final} =$	0.00	0.16	-0.27
	$SB_i =$	0.00	0.00	0.00
	$ SB_{final} - SB_i =$	0.00	0.16	0.27

Performance Specification is:

$$D \pm 3\% \text{ of CS or } |C_{S \text{ post-run}} - C_{S \text{ pre-run}}| \leq 0.5 \text{ ppmv Or } 0.5 \% \text{ volume}$$



**POLK POWER STATION
EMISSIONS UNIT ID 004
INSTRUMENTAL REFERENCE METHOD QUALITY ASSURANCE CALCULATIONS**

**COMBINED CYCLE COMBUSTION TURBINE - CT1A
Effluent Gas Concentration**

$$C_{Gas} = (C_{Avg} - C_0) \times (C_{MA} / (C_M - C_0)) \quad \text{Eq. 7E-5}$$

		O₂	SO₂	CO₂
Run 1	C_{Avg} =	8.83	186.01	17.71
	C₀ =	0.002	0.583	0.059
	C_{MA} =	10.1	152.2	25.07
	C_M =	10.134	152.02	25.024
	(C_{Avg} - C₀) =	8.828	185.427	17.651
	(C_M - C₀) =	10.132	151.437	24.965
	(C_{MA} / (C_M - C₀)) =	0.99684	1.00504	1.00421
	(C_{Avg} - C₀) x (C_{MA} / (C_M - C₀)) =	8.80	186.36	17.73

		O₂	SO₂	CO₂
Run 2	C_{Avg} =	8.71	188.96	17.87
	C₀ =	0.002	0.51	-0.002
	C_{MA} =	10.1	152.2	25.07
	C_M =	10.1645	152.02	25.024
	(C_{Avg} - C₀) =	8.708	188.45	17.872
	(C_M - C₀) =	10.1625	151.51	25.026
	(C_{MA} / (C_M - C₀)) =	0.99385	1.00456	1.00176
	(C_{Avg} - C₀) x (C_{MA} / (C_M - C₀)) =	8.65	189.31	17.90



**POLK POWER STATION
 EMISSIONS UNIT ID 004
 INSTRUMENTAL REFERENCE METHOD QUALITY ASSURANCE CALCULATIONS**

**COMBINED CYCLE COMBUSTION TURBINE - CT1A
 Effluent Gas Concentration**

		O₂	SO₂	CO₂
Run 3	C_{AVg} =	8.63	193.98	17.94
	C_O =	0.002	0.437	0.059
	C_{MA} =	10.1	152.2	25.07
	C_M =	10.195	152.386	24.963
	(C_{AVg} - C_O) =	8.628	193.543	17.881
	(C_M - C_O) =	10.193	151.949	24.904
	(C_{MA} / (C_M - C_O)) =	0.99088	1.00166	1.00667
	(C_{AVg} - C_O) x (C_{MA} / (C_M - C_O)) =	8.55	193.86	18.00

RUN LOG

LabView Run Log
Polk Acid Plant

Date	Time	Status	O2 (%)	SO2 (%)	CO22 (%)
12/1/2006	7:53:00 AM		9.16	181.46	17.45
12/1/2006	7:53:30 AM		9.16	180.73	17.45
12/1/2006	7:54:00 AM		9.04	180.43	17.58
12/1/2006	7:54:30 AM		9.1	181.02	17.7
12/1/2006	7:55:00 AM		9.04	182.19	17.58
12/1/2006	7:55:30 AM		9.04	114.09	17.45
12/1/2006	7:56:00 AM		3.18	3.07	6.47
12/1/2006	7:56:30 AM		0.06	-0.15	0.12
12/1/2006	7:57:00 AM	Linearity Check	0	-0.3	0.12
12/1/2006	7:57:30 AM	Linearity Check	0	0	0.12
12/1/2006	7:58:00 AM	Linearity Check	0.06	0	10.62
12/1/2006	7:58:30 AM	Linearity Check	-0.06	0	35.89
12/1/2006	7:59:00 AM	Linearity Check	-0.12	0	44.56
12/1/2006	7:59:30 AM	Linearity Check	-0.12	-0.15	45.41
12/1/2006	8:00:00 AM	Linearity Check	7.45	-0.44	19.41
12/1/2006	8:00:30 AM	Linearity Check	10.13	-0.3	9.15
12/1/2006	8:01:00 AM	Linearity Check	10.2	-0.44	8.67
12/1/2006	8:01:30 AM	Linearity Check	6.04	-0.15	15.75
12/1/2006	8:02:00 AM	Linearity Check	0.12	-0.15	24.66
12/1/2006	8:02:30 AM	Linearity Check	-0.06	-0.15	25.02
12/1/2006	8:03:00 AM	Linearity Check	1.04	-0.3	24.78
12/1/2006	8:03:30 AM	Linearity Check	18.62	-0.59	11.72
12/1/2006	8:04:00 AM	Linearity Check	20.27	-0.44	14.04
12/1/2006	8:04:30 AM	Linearity Check	21.24	-0.44	17.21
12/1/2006	8:05:00 AM	Linearity Check	21.24	87.14	17.45
12/1/2006	8:05:30 AM	Linearity Check	3.85	128.59	8.67
12/1/2006	8:06:00 AM	Linearity Check	-0.06	151.73	9.52
12/1/2006	8:06:30 AM	Linearity Check	-0.06	151.14	9.89
12/1/2006	8:07:00 AM	Linearity Check	-0.06	154.51	10.01
12/1/2006	8:07:30 AM	Linearity Check	0.06	20.21	11.47
12/1/2006	8:08:00 AM	Linearity Check	-0.06	225.98	12.94
12/1/2006	8:08:30 AM	Linearity Check	-0.06	262.59	17.45
12/1/2006	8:09:00 AM	Linearity Check	-0.06	267.87	17.82
12/1/2006	8:09:30 AM	Linearity Check	-0.06	269.18	17.82
12/1/2006	8:10:00 AM	Linearity Check	1.28	169.45	17.58
12/1/2006	8:10:30 AM	Linearity Check	5.19	8.49	8.05
12/1/2006	8:11:00 AM	Linearity Check	0.06	1.46	0.36
12/1/2006	8:11:30 AM	- ZERO	-0.06	1.17	0
12/1/2006	8:12:00 AM	- ZERO	-0.06	0.73	0
12/1/2006	8:12:30 AM	- ZERO	-0.06	0.44	0
12/1/2006	8:13:00 AM	- ZERO	-0.06	0.44	12.08
12/1/2006	8:13:30 AM	- ZERO	-0.06	0.73	23.56
12/1/2006	8:14:00 AM	- ZERO	-0.06	0.29	24.9
12/1/2006	8:14:30 AM	- Span	-0.12	0.44	24.9
12/1/2006	8:15:00 AM	- Span	-0.06	0.14	25.02
12/1/2006	8:15:30 AM	- Span	8.3	0	12.45
12/1/2006	8:16:00 AM	- Span	10.2	-0.15	8.79
12/1/2006	8:16:30 AM	- Span	10.2	41.74	8.79
12/1/2006	8:17:00 AM	- Span	2.08	148.94	9.52
12/1/2006	8:17:30 AM	- Span	0	150.41	9.89

LabView Run Log
Polk Acid Plant

Date	Time	Status	O2 (%)	SO2 (%)	CO22 (%)
12/1/2006	8:18:00 AM	- Span	-0.06	152.31	9.89
12/1/2006	8:18:30 AM	- Span	-0.06	151.14	10.01
12/1/2006	8:19:00 AM	- Span	0.8	178.53	10.37
12/1/2006	8:19:30 AM	- Span	8.12	182.63	16.72
12/1/2006	8:20:00 AM	- Span	8.73	182.92	17.58
12/1/2006	8:20:30 AM	- Span	8.79	181.02	17.58
12/1/2006	8:21:00 AM	- Span	8.79	182.63	17.58
12/1/2006	8:21:30 AM	- Span	8.91	181.02	17.58
12/1/2006	8:22:00 AM	- Span	8.85	182.92	17.58
12/1/2006	8:22:30 AM	- Span	8.97	182.34	17.58
12/1/2006	8:23:00 AM	- Span	8.97	182.63	17.58
12/1/2006	8:23:30 AM	- Span	8.97	182.92	17.58
12/1/2006	8:24:00 AM	- Span	8.91	183.07	17.7
12/1/2006	8:24:30 AM	- Span	8.91	182.48	17.58
12/1/2006	8:25:00 AM	- Span	8.91	182.63	17.58
12/1/2006	8:25:30 AM	- Span	8.97	183.07	17.7
12/1/2006	8:26:00 AM	- Span	8.91	183.8	17.58
12/1/2006	8:26:30 AM	- Span	8.91	183.65	17.58
12/1/2006	8:27:00 AM	- Span	8.91	182.48	17.58
12/1/2006	8:27:30 AM	- Span	9.04	181.16	17.45
12/1/2006	8:28:00 AM	- Span	8.97	180.58	17.58
12/1/2006	8:28:30 AM	- Span	8.97	181.9	17.7
12/1/2006	8:29:00 AM	- Span	8.97	181.9	17.7
12/1/2006	8:29:30 AM	- Span	8.91	181.75	17.7
12/1/2006	8:30:00 AM	- Span	8.79	182.19	17.82
12/1/2006	8:30:30 AM	- Span	8.73	182.19	17.7
12/1/2006	8:31:00 AM	- Span	8.79	183.07	17.7
12/1/2006	8:31:30 AM	- Span	8.73	184.39	17.7
12/1/2006	8:32:00 AM	- Span	8.73	184.83	17.7
12/1/2006	8:32:30 AM	- Span	8.73	183.36	17.82
12/1/2006	8:33:00 AM	- Span	8.73	182.63	17.7
12/1/2006	8:33:30 AM	- Span	8.79	181.9	17.7
12/1/2006	8:34:00 AM	- Span	8.79	182.92	17.7
12/1/2006	8:34:30 AM	- Span	8.79	184.39	17.7
12/1/2006	8:35:00 AM	- Span	8.85	183.8	17.58
12/1/2006	8:35:30 AM	- Span	8.91	182.78	17.7
12/1/2006	8:36:00 AM	- Span	8.85	183.51	17.7
12/1/2006	8:36:30 AM	- Span	8.85	184.97	17.7
12/1/2006	8:37:00 AM	- Span	8.79	184.68	17.58
12/1/2006	8:37:30 AM	- Span	8.91	183.8	17.58
12/1/2006	8:38:00 AM	- Span	8.79	183.51	17.7
12/1/2006	8:38:30 AM	- Span	8.85	183.95	17.58
12/1/2006	8:39:00 AM	- Span	8.85	184.83	17.58
12/1/2006	8:39:30 AM	- Span	8.85	185.7	17.58
12/1/2006	8:40:00 AM	- Span	8.91	185.41	17.45
12/1/2006	8:40:30 AM	- Span	8.91	184.83	17.58
12/1/2006	8:41:00 AM	- Span	8.97	184.53	17.45
12/1/2006	8:41:30 AM	- Span	9.04	184.53	17.45
12/1/2006	8:42:00 AM	- Span	9.1	184.24	17.33
12/1/2006	8:42:30 AM	- Span	9.04	184.24	17.45

LabView Run Log
Polk Acid Plant

Date	Time	Status	O2 (%)	SO2 (%)	CO22 (%)
12/1/2006	8:43:00 AM	- Span	9.1	184.09	17.45
12/1/2006	8:43:30 AM	- Span	9.1	183.21	17.45
12/1/2006	8:44:00 AM	- Span	9.04	183.65	17.45
12/1/2006	8:44:30 AM	- Span	8.91	184.24	17.45
12/1/2006	8:45:00 AM	- Span	8.97	183.8	17.58
12/1/2006	8:45:30 AM	- Span	8.91	183.36	17.45
12/1/2006	8:46:00 AM	- Span	8.97	183.51	17.45
12/1/2006	8:46:30 AM	- Span	8.91	183.95	17.7
12/1/2006	8:47:00 AM	- Span	8.79	184.09	17.7
12/1/2006	8:47:30 AM	- Span	8.85	184.24	17.7
12/1/2006	8:48:00 AM	- Span	8.79	184.83	17.7
12/1/2006	8:48:30 AM	- Span	8.79	184.09	17.7
12/1/2006	8:49:00 AM	- Span	8.73	184.68	17.7
12/1/2006	8:49:30 AM	- Span	8.73	185.12	17.7
12/1/2006	8:50:00 AM	- Span	8.73	184.53	17.7
12/1/2006	8:50:30 AM	- Span	8.85	183.8	17.45
12/1/2006	8:51:00 AM	- Span	8.85	183.51	17.58
12/1/2006	8:51:30 AM	- Span	9.1	183.36	17.33
12/1/2006	8:52:00 AM	- Span	9.22	183.21	17.33
12/1/2006	8:52:30 AM	- Span	9.16	183.65	17.45
12/1/2006	8:53:00 AM	- Span	9.1	183.8	17.45
12/1/2006	8:53:30 AM	- Span	8.97	183.95	17.58
12/1/2006	8:54:00 AM	- Span	8.97	183.21	17.58
12/1/2006	8:54:30 AM	- Span	8.85	184.24	17.7
12/1/2006	8:55:00 AM	- Span	8.73	184.53	17.82
12/1/2006	8:55:30 AM	- Span	8.67	183.95	17.7
12/1/2006	8:56:00 AM	- Span	8.67	184.68	17.82
12/1/2006	8:56:30 AM	- Span	8.67	184.68	17.7
12/1/2006	8:57:00 AM	- Span	8.61	185.41	17.7
12/1/2006	8:57:30 AM	- Span	8.61	185.27	17.7
12/1/2006	8:58:00 AM	- Span	8.67	185.12	17.7
12/1/2006	8:58:30 AM	- Span	8.73	185.56	17.7
12/1/2006	8:59:00 AM	- Span	8.73	184.97	17.7
12/1/2006	8:59:30 AM	- Span	8.73	185.85	17.58
12/1/2006	9:00:00 AM	- Span	8.85	186.44	17.45
12/1/2006	9:00:30 AM	Run 1 - 1	8.85	186.14	17.45
12/1/2006	9:01:00 AM	Run 1 - 1	8.85	186	17.58
12/1/2006	9:01:30 AM	Run 1 - 1	8.91	185.12	17.58
12/1/2006	9:02:00 AM	Run 1 - 1	8.97	184.83	17.45
12/1/2006	9:02:30 AM	Run 1 - 1	8.97	185.12	17.45
12/1/2006	9:03:00 AM	Run 1 - 1	8.91	185.41	17.58
12/1/2006	9:03:30 AM	Run 1 - 1	8.91	184.97	17.58
12/1/2006	9:04:00 AM	Run 1 - 1	8.85	185.27	17.58
12/1/2006	9:04:30 AM	Run 1 - 1	8.91	185.85	17.58
12/1/2006	9:05:00 AM	Run 1 - 1	8.85	186	17.58
12/1/2006	9:05:30 AM	Run 1 - 1	8.79	186	17.7
12/1/2006	9:06:00 AM	Run 1 - 1	8.73	185.27	17.82
12/1/2006	9:06:30 AM	Run 1 - 1	8.79	185.56	17.58
12/1/2006	9:07:00 AM	Run 1 - 1	8.73	185.85	17.7
12/1/2006	9:07:30 AM	Run 1 - 1	8.73	185.12	17.7

LabView Run Log
Polk Acid Plant

Date	Time	Status	O2 (%)	SO2 (%)	CO22 (%)
12/1/2006	9:08:00 AM	Run 1 - 1	8.67	185.56	17.7
12/1/2006	9:08:30 AM	Run 1 - 1	8.73	185.27	17.7
12/1/2006	9:09:00 AM	Run 1 - 1	8.73	185.12	17.7
12/1/2006	9:09:30 AM	Run 1 - 1	8.73	185.56	17.7
12/1/2006	9:10:00 AM	Run 1 - 1	8.73	185.7	17.7
12/1/2006	9:10:30 AM	Run 1 - 1	8.73	186.73	17.58
12/1/2006	9:11:00 AM	Run 1 - 1	8.73	186.58	17.7
12/1/2006	9:11:30 AM	Run 1 - 1	8.73	186.29	17.58
12/1/2006	9:12:00 AM	Run 1 - 1	8.73	186.44	17.7
12/1/2006	9:12:30 AM	Run 1 - 1	8.85	185.85	17.58
12/1/2006	9:13:00 AM	Run 1 - 1	8.91	186	17.58
12/1/2006	9:13:30 AM	Run 1 - 1	8.85	186	17.58
12/1/2006	9:14:00 AM	Run 1 - 1	8.91	186	17.58
12/1/2006	9:14:30 AM	Run 1 - 1	8.91	186	17.58
12/1/2006	9:15:00 AM	Run 1 - 1	9.04	186	17.58
12/1/2006	9:15:30 AM	Run 1 - 1	9.1	185.56	17.58
12/1/2006	9:16:00 AM	Run 1 - 1	8.97	185.85	17.58
12/1/2006	9:16:30 AM	Run 1 - 1	9.04	185.56	17.58
12/1/2006	9:17:00 AM	Run 1 - 1	9.1	185.41	17.58
12/1/2006	9:17:30 AM	Run 1 - 1	9.04	184.83	17.58
12/1/2006	9:18:00 AM	Run 1 - 1	8.97	184.39	17.7
12/1/2006	9:18:30 AM	Run 1 - 1	8.91	184.83	17.7
12/1/2006	9:19:00 AM	Run 1 - 1	8.85	184.97	17.82
12/1/2006	9:19:30 AM	Run 1 - 1	8.73	185.85	17.7
12/1/2006	9:20:00 AM	Run 1 - 1	8.73	185.12	17.82
12/1/2006	9:20:30 AM	Run 1 - 1	8.73	184.68	17.82
12/1/2006	9:21:00 AM	Run 1 - 1	8.73	183.95	17.7
12/1/2006	9:21:30 AM	Run 1 - 1	8.79	183.95	17.7
12/1/2006	9:22:00 AM	Run 1 - 1	8.85	184.53	17.7
12/1/2006	9:22:30 AM	Run 1 - 1	8.79	185.56	17.7
12/1/2006	9:23:00 AM	Run 1 - 1	8.91	185.12	17.7
12/1/2006	9:23:30 AM	Run 1 - 1	8.91	184.68	17.7
12/1/2006	9:24:00 AM	Run 1 - 1	8.91	184.53	17.7
12/1/2006	9:24:30 AM	Run 1 - 1	8.85	185.41	17.7
12/1/2006	9:25:00 AM	Run 1 - 1	8.85	185.12	17.7
12/1/2006	9:25:30 AM	Run 1 - 1	8.79	184.83	17.7
12/1/2006	9:26:00 AM	Run 1 - 1	8.79	185.56	17.82
12/1/2006	9:26:30 AM	Run 1 - 1	8.73	186.29	17.82
12/1/2006	9:27:00 AM	Run 1 - 1	8.67	186.58	17.82
12/1/2006	9:27:30 AM	Run 1 - 1	8.85	185.85	17.7
12/1/2006	9:28:00 AM	Run 1 - 1	8.85	186.58	17.7
12/1/2006	9:28:30 AM	Run 1 - 1	8.85	186.44	17.82
12/1/2006	9:29:00 AM	Run 1 - 1	8.91	186.14	17.7
12/1/2006	9:29:30 AM	Run 1 - 1	8.85	186	17.7
12/1/2006	9:30:00 AM	Run 1 - 1	8.73	186	17.82
12/1/2006	9:30:30 AM	Run 1 - 1	8.73	186.88	17.7
12/1/2006	9:31:00 AM	Run 1 - 1	8.67	187.75	17.7
12/1/2006	9:31:30 AM	Run 1 - 1	8.67	187.75	17.82
12/1/2006	9:32:00 AM	Run 1 - 1	8.67	188.49	17.7
12/1/2006	9:32:30 AM	Run 1 - 1	8.67	188.49	17.82

LabView Run Log
Polk Acid Plant

Date	Time	Status	O2 (%)	SO2 (%)	CO22 (%)
12/1/2006	9:33:00 AM	Run 1 - 1	8.73	187.32	17.82
12/1/2006	9:33:30 AM	Run 1 - 1	8.67	187.9	17.7
12/1/2006	9:34:00 AM	Run 1 - 1	8.73	189.22	17.7
12/1/2006	9:34:30 AM	Run 1 - 1	8.73	189.51	17.7
12/1/2006	9:35:00 AM	Run 1 - 1	8.73	188.78	17.7
12/1/2006	9:35:30 AM	Run 1 - 1	8.73	188.93	17.7
12/1/2006	9:36:00 AM	Run 1 - 1	8.79	189.22	17.7
12/1/2006	9:36:30 AM	Run 1 - 1	8.79	189.22	17.7
12/1/2006	9:37:00 AM	Run 1 - 1	8.85	189.37	17.7
12/1/2006	9:37:30 AM	Run 1 - 1	8.85	189.37	17.7
12/1/2006	9:38:00 AM	Run 1 - 1	8.85	188.93	17.58
12/1/2006	9:38:30 AM	Run 1 - 1	8.85	188.93	17.7
12/1/2006	9:39:00 AM	Run 1 - 1	8.91	188.34	17.7
12/1/2006	9:39:30 AM	Run 1 - 1	8.97	187.9	17.45
12/1/2006	9:40:00 AM	Run 1 - 1	9.1	187.02	17.45
12/1/2006	9:40:30 AM	Run 1 - 1	9.22	186.58	17.45
12/1/2006	9:41:00 AM	Run 1 - 1	9.22	185.85	17.33
12/1/2006	9:41:30 AM	Run 1 - 1	9.28	184.97	17.45
12/1/2006	9:42:00 AM	Run 1 - 1	9.22	184.83	17.45
12/1/2006	9:42:30 AM	Run 1 - 1	9.1	184.97	17.58
12/1/2006	9:43:00 AM	Run 1 - 1	9.04	185.56	17.7
12/1/2006	9:43:30 AM	Run 1 - 1	8.85	185.41	17.82
12/1/2006	9:44:00 AM	Run 1 - 1	8.85	185.12	17.82
12/1/2006	9:44:30 AM	Run 1 - 1	8.73	185.27	17.94
12/1/2006	9:45:00 AM	Run 1 - 1	8.73	185.12	17.82
12/1/2006	9:45:30 AM	Run 1 - 1	8.61	185.12	17.94
12/1/2006	9:46:00 AM	Run 1 - 1	8.67	185.7	17.82
12/1/2006	9:46:30 AM	Run 1 - 1	8.61	185.41	17.82
12/1/2006	9:47:00 AM	Run 1 - 1	8.61	184.97	17.94
12/1/2006	9:47:30 AM	Run 1 - 1	8.61	184.83	17.94
12/1/2006	9:48:00 AM	Run 1 - 1	8.67	185.7	17.94
12/1/2006	9:48:30 AM	Run 1 - 1	8.67	186.29	17.82
12/1/2006	9:49:00 AM	Run 1 - 1	8.73	186.58	17.82
12/1/2006	9:49:30 AM	Run 1 - 1	8.73	186.58	17.82
12/1/2006	9:50:00 AM	Run 1 - 1	8.79	186.14	17.7
12/1/2006	9:50:30 AM	Run 1 - 1	8.85	185.85	17.7
12/1/2006	9:51:00 AM	Run 1 - 1	8.97	185.85	17.7
12/1/2006	9:51:30 AM	Run 1 - 1	8.97	186.14	17.58
12/1/2006	9:52:00 AM	Run 1 - 1	9.04	185.7	17.58
12/1/2006	9:52:30 AM	Run 1 - 1	9.1	184.53	17.58
12/1/2006	9:53:00 AM	Run 1 - 1	9.1	184.09	17.58
12/1/2006	9:53:30 AM	Run 1 - 1	8.97	185.41	17.7
12/1/2006	9:54:00 AM	Run 1 - 1	8.91	185.56	17.7
12/1/2006	9:54:30 AM	Run 1 - 1	8.91	185.27	17.82
12/1/2006	9:55:00 AM	Run 1 - 1	8.73	184.97	17.82
12/1/2006	9:55:30 AM	Run 1 - 1	8.73	185.41	17.82
12/1/2006	9:56:00 AM	Run 1 - 1	8.73	185.27	17.94
12/1/2006	9:56:30 AM	Run 1 - 1	8.67	185.27	17.82
12/1/2006	9:57:00 AM	Run 1 - 1	8.67	184.97	17.94
12/1/2006	9:57:30 AM	Run 1 - 1	8.61	184.97	17.94

LabView Run Log
Polk Acid Plant

Date	Time	Status	O2 (%)	SO2 (%)	CO22 (%)
12/1/2006	9:58:00 AM	Run 1 - 1	8.61	184.97	17.94
12/1/2006	9:58:30 AM	Run 1 - 1	8.67	186.44	17.94
12/1/2006	9:59:00 AM	Run 1 - 1	8.73	187.02	17.82
12/1/2006	9:59:30 AM	Run 1 - 1	8.79	186.58	17.82
12/1/2006	10:00:00 AM	Run 1 - 1	8.79	185.7	17.7
12/1/2006	10:00:30 AM		8.91	130.93	17.58
12/1/2006	10:01:00 AM		3.3	5.86	7.2
12/1/2006	10:01:30 AM		0.06	1.32	0.24
12/1/2006	10:02:00 AM	- ZERO	0	1.02	0
12/1/2006	10:02:30 AM	- ZERO	0	0.88	0
12/1/2006	10:03:00 AM	- ZERO	0	0.44	0
12/1/2006	10:03:30 AM	- ZERO	0	0.73	0
12/1/2006	10:04:00 AM	- ZERO	-0.06	0.44	13.67
12/1/2006	10:04:30 AM	- ZERO	-0.12	0.58	24.05
12/1/2006	10:05:00 AM	- Span	-0.06	0.29	25.02
12/1/2006	10:05:30 AM	- Span	-0.06	0.14	25.02
12/1/2006	10:06:00 AM	- Span	6.41	0	16.11
12/1/2006	10:06:30 AM	- Span	10.13	0	8.91
12/1/2006	10:07:00 AM	- Span	10.26	0	8.67
12/1/2006	10:07:30 AM	- Span	10.2	14.06	8.67
12/1/2006	10:08:00 AM	- Span	4.27	147.92	9.28
12/1/2006	10:08:30 AM	- Span	-0.06	151.58	10.01
12/1/2006	10:09:00 AM	- Span	-0.06	152.31	9.89
12/1/2006	10:09:30 AM	- Span	2.32	183.65	11.84
12/1/2006	10:10:00 AM	- Span	8.24	184.97	17.58
12/1/2006	10:10:30 AM	- Span	8.49	186.88	17.82
12/1/2006	10:11:00 AM	- Span	8.61	186.44	17.7
12/1/2006	10:11:30 AM	- Span	8.67	187.32	17.7
12/1/2006	10:12:00 AM	- Span	8.61	186.58	17.82
12/1/2006	10:12:30 AM	- Span	8.67	186	17.7
12/1/2006	10:13:00 AM	- Span	8.73	186.88	17.7
12/1/2006	10:13:30 AM	- Span	8.79	187.46	17.7
12/1/2006	10:14:00 AM	- Span	8.73	187.75	17.82
12/1/2006	10:14:30 AM	- Span	8.79	187.75	17.82
12/1/2006	10:15:00 AM	- Span	8.79	187.9	17.7
12/1/2006	10:15:30 AM	- Span	8.79	187.32	17.7
12/1/2006	10:16:00 AM	- Span	8.73	187.46	17.82
12/1/2006	10:16:30 AM	- Span	8.73	188.63	17.82
12/1/2006	10:17:00 AM	- Span	8.85	188.19	17.7
12/1/2006	10:17:30 AM	- Span	8.85	188.05	17.7
12/1/2006	10:18:00 AM	- Span	8.79	187.9	17.82
12/1/2006	10:18:30 AM	- Span	8.79	188.19	17.82
12/1/2006	10:19:00 AM	- Span	8.85	187.75	17.82
12/1/2006	10:19:30 AM	- Span	8.91	186.44	17.7
12/1/2006	10:20:00 AM	- Span	8.85	187.17	17.82
12/1/2006	10:20:30 AM	- Span	8.85	187.32	17.7
12/1/2006	10:21:00 AM	- Span	8.85	187.17	17.7
12/1/2006	10:21:30 AM	- Span	8.91	187.46	17.7
12/1/2006	10:22:00 AM	- Span	8.97	187.32	17.58
12/1/2006	10:22:30 AM	- Span	8.97	186.73	17.7

LabView Run Log
Polk Acid Plant

Date	Time	Status	O2 (%)	SO2 (%)	CO22 (%)
12/1/2006	10:23:00 AM	- Span	8.91	186.29	17.7
12/1/2006	10:23:30 AM	- Span	8.85	186.73	17.7
12/1/2006	10:24:00 AM	- Span	8.85	186.44	17.7
12/1/2006	10:24:30 AM	- Span	8.73	186.58	17.94
12/1/2006	10:25:00 AM	- Span	8.67	187.02	17.82
12/1/2006	10:25:30 AM	- Span	8.55	187.02	17.82
12/1/2006	10:26:00 AM	- Span	8.67	187.32	17.94
12/1/2006	10:26:30 AM	- Span	8.67	187.32	17.82
12/1/2006	10:27:00 AM	- Span	8.67	187.17	17.82
12/1/2006	10:27:30 AM	- Span	8.79	187.17	17.7
12/1/2006	10:28:00 AM	- Span	8.91	186.29	17.58
12/1/2006	10:28:30 AM	- Span	8.97	186.14	17.7
12/1/2006	10:29:00 AM	- Span	9.04	185.56	17.7
12/1/2006	10:29:30 AM	- Span	9.04	186	17.7
12/1/2006	10:30:00 AM	- Span	8.97	186.14	17.7
12/1/2006	10:30:30 AM	- Span	8.91	186.58	17.82
12/1/2006	10:31:00 AM	- Span	8.79	187.75	17.82
12/1/2006	10:31:30 AM	- Span	8.73	187.17	17.94
12/1/2006	10:32:00 AM	- Span	8.73	186.88	17.94
12/1/2006	10:32:30 AM	- Span	8.67	186.58	18.07
12/1/2006	10:33:00 AM	- Span	8.55	187.75	18.07
12/1/2006	10:33:30 AM	- Span	8.49	188.34	17.94
12/1/2006	10:34:00 AM	- Span	8.49	187.75	17.94
12/1/2006	10:34:30 AM	- Span	8.43	187.75	17.94
12/1/2006	10:35:00 AM	- Span	8.43	188.93	17.94
12/1/2006	10:35:30 AM	- Span	8.49	188.93	17.94
12/1/2006	10:36:00 AM	- Span	8.55	188.93	17.82
12/1/2006	10:36:30 AM	- Span	8.67	188.49	17.82
12/1/2006	10:37:00 AM	- Span	8.79	187.75	17.82
12/1/2006	10:37:30 AM	- Span	8.85	187.75	17.7
12/1/2006	10:38:00 AM	Run 2 - 1	9.04	187.61	17.7
12/1/2006	10:38:30 AM	Run 2 - 1	9.04	187.46	17.58
12/1/2006	10:39:00 AM	Run 2 - 1	9.04	187.32	17.7
12/1/2006	10:39:30 AM	Run 2 - 1	8.85	188.49	17.82
12/1/2006	10:40:00 AM	Run 2 - 1	8.79	188.34	17.82
12/1/2006	10:40:30 AM	Run 2 - 1	8.79	188.05	17.82
12/1/2006	10:41:00 AM	Run 2 - 1	8.73	188.19	17.94
12/1/2006	10:41:30 AM	Run 2 - 1	8.73	187.61	17.82
12/1/2006	10:42:00 AM	Run 2 - 1	8.79	187.9	17.82
12/1/2006	10:42:30 AM	Run 2 - 1	8.79	187.61	17.82
12/1/2006	10:43:00 AM	Run 2 - 1	8.73	187.32	17.82
12/1/2006	10:43:30 AM	Run 2 - 1	8.73	187.46	17.82
12/1/2006	10:44:00 AM	Run 2 - 1	8.73	187.02	17.82
12/1/2006	10:44:30 AM	Run 2 - 1	8.73	187.17	17.7
12/1/2006	10:45:00 AM	Run 2 - 1	8.73	187.17	17.82
12/1/2006	10:45:30 AM	Run 2 - 1	8.73	187.17	17.7
12/1/2006	10:46:00 AM	Run 2 - 1	8.73	187.17	17.82
12/1/2006	10:46:30 AM	Run 2 - 1	8.85	186.29	17.7
12/1/2006	10:47:00 AM	Run 2 - 1	8.85	186.73	17.82
12/1/2006	10:47:30 AM	Run 2 - 1	8.79	186.88	17.82

LabView Run Log
Polk Acid Plant

Date	Time	Status	O2 (%)	SO2 (%)	CO22 (%)
12/1/2006	10:48:00 AM	Run 2 - 1	8.73	186.44	17.82
12/1/2006	10:48:30 AM	Run 2 - 1	8.67	186.88	17.82
12/1/2006	10:49:00 AM	Run 2 - 1	8.67	187.32	17.82
12/1/2006	10:49:30 AM	Run 2 - 1	8.73	187.17	17.94
12/1/2006	10:50:00 AM	Run 2 - 1	8.67	187.61	17.82
12/1/2006	10:50:30 AM	Run 2 - 1	8.67	187.32	17.82
12/1/2006	10:51:00 AM	Run 2 - 1	8.73	186.44	17.82
12/1/2006	10:51:30 AM	Run 2 - 1	8.73	187.17	17.82
12/1/2006	10:52:00 AM	Run 2 - 1	8.73	188.78	17.82
12/1/2006	10:52:30 AM	Run 2 - 1	8.79	188.05	17.7
12/1/2006	10:53:00 AM	Run 2 - 1	8.85	187.02	17.7
12/1/2006	10:53:30 AM	Run 2 - 1	8.91	186.29	17.7
12/1/2006	10:54:00 AM	Run 2 - 1	8.79	186.58	17.82
12/1/2006	10:54:30 AM	Run 2 - 1	8.79	187.61	17.82
12/1/2006	10:55:00 AM	Run 2 - 1	8.79	187.9	17.82
12/1/2006	10:55:30 AM	Run 2 - 1	8.55	188.34	18.07
12/1/2006	10:56:00 AM	Run 2 - 1	8.49	187.75	18.07
12/1/2006	10:56:30 AM	Run 2 - 1	8.55	187.61	17.94
12/1/2006	10:57:00 AM	Run 2 - 1	8.49	188.49	18.07
12/1/2006	10:57:30 AM	Run 2 - 1	8.55	189.07	17.94
12/1/2006	10:58:00 AM	Run 2 - 1	8.49	189.07	18.07
12/1/2006	10:58:30 AM	Run 2 - 1	8.55	189.07	18.07
12/1/2006	10:59:00 AM	Run 2 - 1	8.67	188.05	17.82
12/1/2006	10:59:30 AM	Run 2 - 1	8.67	188.34	17.94
12/1/2006	11:00:00 AM	Run 2 - 1	8.73	188.49	17.82
12/1/2006	11:00:30 AM	Run 2 - 1	8.73	189.07	17.7
12/1/2006	11:01:00 AM	Run 2 - 1	8.79	188.34	17.82
12/1/2006	11:01:30 AM	Run 2 - 1	8.79	188.78	17.7
12/1/2006	11:02:00 AM	Run 2 - 1	8.79	188.93	17.82
12/1/2006	11:02:30 AM	Run 2 - 1	8.85	188.34	17.82
12/1/2006	11:03:00 AM	Run 2 - 1	8.85	187.17	17.7
12/1/2006	11:03:30 AM	Run 2 - 1	8.91	187.75	17.7
12/1/2006	11:04:00 AM	Run 2 - 1	8.85	188.34	17.82
12/1/2006	11:04:30 AM	Run 2 - 1	8.79	188.49	17.7
12/1/2006	11:05:00 AM	Run 2 - 1	8.85	188.34	17.7
12/1/2006	11:05:30 AM	Run 2 - 1	8.79	188.19	17.7
12/1/2006	11:06:00 AM	Run 2 - 1	8.73	188.05	17.82
12/1/2006	11:06:30 AM	Run 2 - 1	8.79	188.05	17.82
12/1/2006	11:07:00 AM	Run 2 - 1	8.73	188.34	17.94
12/1/2006	11:07:30 AM	Run 2 - 1	8.79	188.19	17.82
12/1/2006	11:08:00 AM	Run 2 - 1	8.73	187.32	17.82
12/1/2006	11:08:30 AM	Run 2 - 1	8.73	187.02	17.82
12/1/2006	11:09:00 AM	Run 2 - 1	8.73	187.61	17.94
12/1/2006	11:09:30 AM	Run 2 - 1	8.73	187.9	17.82
12/1/2006	11:10:00 AM	Run 2 - 1	8.79	188.19	17.82
12/1/2006	11:10:30 AM	Run 2 - 1	8.67	187.61	17.82
12/1/2006	11:11:00 AM	Run 2 - 1	8.73	187.9	17.82
12/1/2006	11:11:30 AM	Run 2 - 1	8.79	187.75	17.82
12/1/2006	11:12:00 AM	Run 2 - 1	8.79	187.75	17.82
12/1/2006	11:12:30 AM	Run 2 - 1	8.73	188.93	17.82

LabView Run Log
Polk Acid Plant

Date	Time	Status	O2 (%)	SO2 (%)	CO22 (%)
12/1/2006	11:13:00 AM	Run 2 - 1	8.79	188.49	17.82
12/1/2006	11:13:30 AM	Run 2 - 1	8.79	188.93	17.82
12/1/2006	11:14:00 AM	Run 2 - 1	8.79	189.22	17.82
12/1/2006	11:14:30 AM	Run 2 - 1	8.67	189.66	17.94
12/1/2006	11:15:00 AM	Run 2 - 1	8.61	190.39	17.94
12/1/2006	11:15:30 AM	Run 2 - 1	8.61	190.1	17.94
12/1/2006	11:16:00 AM	Run 2 - 1	8.61	189.95	17.94
12/1/2006	11:16:30 AM	Run 2 - 1	8.67	190.24	17.82
12/1/2006	11:17:00 AM	Run 2 - 1	8.73	189.81	17.82
12/1/2006	11:17:30 AM	Run 2 - 1	8.79	189.81	17.7
12/1/2006	11:18:00 AM	Run 2 - 1	8.79	189.51	17.82
12/1/2006	11:18:30 AM	Run 2 - 1	8.73	189.95	17.82
12/1/2006	11:19:00 AM	Run 2 - 1	8.67	190.39	17.94
12/1/2006	11:19:30 AM	Run 2 - 1	8.67	191.27	17.94
12/1/2006	11:20:00 AM	Run 2 - 1	8.67	191.42	17.94
12/1/2006	11:20:30 AM	Run 2 - 1	8.61	190.83	17.94
12/1/2006	11:21:00 AM	Run 2 - 1	8.67	191.12	17.94
12/1/2006	11:21:30 AM	Run 2 - 1	8.61	191.12	17.94
12/1/2006	11:22:00 AM	Run 2 - 1	8.67	190.98	17.94
12/1/2006	11:22:30 AM	Run 2 - 1	8.67	191.71	17.94
12/1/2006	11:23:00 AM	Run 2 - 1	8.67	190.98	17.82
12/1/2006	11:23:30 AM	Run 2 - 1	8.67	190.68	17.94
12/1/2006	11:24:00 AM	Run 2 - 1	8.73	190.98	17.94
12/1/2006	11:24:30 AM	Run 2 - 1	8.73	190.24	17.94
12/1/2006	11:25:00 AM	Run 2 - 1	8.61	191.12	17.82
12/1/2006	11:25:30 AM	Run 2 - 1	8.61	190.98	17.94
12/1/2006	11:26:00 AM	Run 2 - 1	8.67	191.12	17.94
12/1/2006	11:26:30 AM	Run 2 - 1	8.67	190.24	17.94
12/1/2006	11:27:00 AM	Run 2 - 1	8.61	190.68	17.94
12/1/2006	11:27:30 AM	Run 2 - 1	8.55	191.27	17.94
12/1/2006	11:28:00 AM	Run 2 - 1	8.55	190.39	17.94
12/1/2006	11:28:30 AM	Run 2 - 1	8.55	190.24	17.94
12/1/2006	11:29:00 AM	Run 2 - 1	8.55	190.54	18.07
12/1/2006	11:29:30 AM	Run 2 - 1	8.55	190.39	17.94
12/1/2006	11:30:00 AM	Run 2 - 1	8.49	191.12	17.94
12/1/2006	11:30:30 AM	Run 2 - 1	8.55	190.98	18.07
12/1/2006	11:31:00 AM	Run 2 - 1	8.55	191.12	18.07
12/1/2006	11:31:30 AM	Run 2 - 1	8.55	190.83	17.94
12/1/2006	11:32:00 AM	Run 2 - 1	8.55	190.98	18.07
12/1/2006	11:32:30 AM	Run 2 - 1	8.61	190.83	17.94
12/1/2006	11:33:00 AM	Run 2 - 1	8.67	190.68	17.94
12/1/2006	11:33:30 AM	Run 2 - 1	8.67	190.24	17.94
12/1/2006	11:34:00 AM	Run 2 - 1	8.61	190.24	17.94
12/1/2006	11:34:30 AM	Run 2 - 1	8.61	191.42	18.07
12/1/2006	11:35:00 AM	Run 2 - 1	8.67	190.98	17.94
12/1/2006	11:35:30 AM	Run 2 - 1	8.61	190.98	18.07
12/1/2006	11:36:00 AM	Run 2 - 1	8.61	191.42	17.94
12/1/2006	11:36:30 AM	Run 2 - 1	8.61	191.42	17.94
12/1/2006	11:37:00 AM	Run 2 - 1	8.67	191.42	17.94
12/1/2006	11:37:30 AM	Run 2 - 1	8.61	191.71	17.94

LabView Run Log
Polk Acid Plant

Date	Time	Status	O2 (%)	SO2 (%)	CO22 (%)
12/1/2006	11:38:00 AM		8.61	191.56	17.94
12/1/2006	11:38:30 AM		7.51	31.63	16.36
12/1/2006	11:39:00 AM		0.73	2.34	2.2
12/1/2006	11:39:30 AM	- ZERO	0	1.17	0.24
12/1/2006	11:40:00 AM	- ZERO	-0.06	0.88	0.12
12/1/2006	11:40:30 AM	- ZERO	0	0.73	0.12
12/1/2006	11:41:00 AM	- ZERO	-0.06	0.73	3.9
12/1/2006	11:41:30 AM	- ZERO	-0.12	0.58	20.75
12/1/2006	11:42:00 AM	- ZERO	-0.06	0.44	24.9
12/1/2006	11:42:30 AM	- Span	-0.06	0.29	25.02
12/1/2006	11:43:00 AM	- Span	-0.06	0.29	24.9
12/1/2006	11:43:30 AM	- Span	16.67	0.14	18.43
12/1/2006	11:44:00 AM	- Span	21.18	0	17.33
12/1/2006	11:44:30 AM	- Span	21.3	-0.15	17.58
12/1/2006	11:45:00 AM	- Span	14.65	0	12.82
12/1/2006	11:45:30 AM	- Span	10.26	-0.15	8.79
12/1/2006	11:46:00 AM	- Span	10.2	-0.15	8.67
12/1/2006	11:46:30 AM	- Span	10.2	27.09	8.67
12/1/2006	11:47:00 AM	- Span	2.99	148.36	9.28
12/1/2006	11:47:30 AM	- Span	-0.06	150.99	9.89
12/1/2006	11:48:00 AM	- Span	-0.06	150.7	10.01
12/1/2006	11:48:30 AM	- Span	-0.06	157.15	10.01
12/1/2006	11:49:00 AM	- Span	5.19	188.49	14.28
12/1/2006	11:49:30 AM	- Span	8.67	189.37	17.7
12/1/2006	11:50:00 AM	- Span	8.67	190.24	17.82
12/1/2006	11:50:30 AM	- Span	8.67	189.37	17.94
12/1/2006	11:51:00 AM	- Span	8.67	190.54	17.94
12/1/2006	11:51:30 AM	- Span	8.61	190.83	17.94
12/1/2006	11:52:00 AM	- Span	8.55	191.42	17.94
12/1/2006	11:52:30 AM	- Span	8.55	191.12	18.07
12/1/2006	11:53:00 AM	- Span	8.55	192.15	17.94
12/1/2006	11:53:30 AM	- Span	8.55	191.86	18.07
12/1/2006	11:54:00 AM	- Span	8.55	191.71	18.07
12/1/2006	11:54:30 AM	- Span	8.49	191.71	18.07
12/1/2006	11:55:00 AM	- Span	8.55	191.12	18.07
12/1/2006	11:55:30 AM	- Span	8.55	191.12	17.94
12/1/2006	11:56:00 AM	- Span	8.61	191.12	17.94
12/1/2006	11:56:30 AM	- Span	8.61	191.71	17.94
12/1/2006	11:57:00 AM	- Span	8.61	192.3	17.82
12/1/2006	11:57:30 AM	- Span	8.67	191.56	17.82
12/1/2006	11:58:00 AM	- Span	8.67	192.3	17.82
12/1/2006	11:58:30 AM	- Span	8.67	192	17.82
12/1/2006	11:59:00 AM	- Span	8.73	192.59	17.7
12/1/2006	11:59:30 AM	- Span	8.73	192.59	17.7
12/1/2006	12:00:00 PM	- Span	8.73	191.12	17.7
12/1/2006	12:00:30 PM	- Span	8.79	190.68	17.7
12/1/2006	12:01:00 PM	- Span	8.85	190.83	17.7
12/1/2006	12:01:30 PM	- Span	8.91	190.24	17.7
12/1/2006	12:02:00 PM	- Span	8.91	189.95	17.7
12/1/2006	12:02:30 PM	- Span	8.97	189.22	17.7

LabView Run Log
Polk Acid Plant

Date	Time	Status	O2 (%)	SO2 (%)	CO22 (%)
12/1/2006	12:03:00 PM	- Span	8.91	188.93	17.7
12/1/2006	12:03:30 PM	- Span	8.97	189.07	17.7
12/1/2006	12:04:00 PM	- Span	8.91	188.49	17.7
12/1/2006	12:04:30 PM	- Span	8.73	189.22	17.94
12/1/2006	12:05:00 PM	- Span	8.73	188.93	17.82
12/1/2006	12:05:30 PM	- Span	8.73	188.19	17.7
12/1/2006	12:06:00 PM	- Span	8.79	187.75	17.82
12/1/2006	12:06:30 PM	- Span	8.73	187.17	17.82
12/1/2006	12:07:00 PM	- Span	8.73	187.32	17.94
12/1/2006	12:07:30 PM	- Span	8.73	188.19	17.94
12/1/2006	12:08:00 PM	- Span	8.67	188.05	17.94
12/1/2006	12:08:30 PM	- Span	8.49	189.22	18.07
12/1/2006	12:09:00 PM	- Span	8.36	189.81	18.19
12/1/2006	12:09:30 PM	- Span	8.36	190.83	18.07
12/1/2006	12:10:00 PM	Run 3 - 1	8.36	192	18.07
12/1/2006	12:10:30 PM	Run 3 - 1	8.3	191.42	17.94
12/1/2006	12:11:00 PM	Run 3 - 1	8.3	191.71	18.07
12/1/2006	12:11:30 PM	Run 3 - 1	8.36	192.3	17.94
12/1/2006	12:12:00 PM	Run 3 - 1	8.55	192	17.94
12/1/2006	12:12:30 PM	Run 3 - 1	8.61	192	17.94
12/1/2006	12:13:00 PM	Run 3 - 1	8.61	192.88	17.94
12/1/2006	12:13:30 PM	Run 3 - 1	8.67	193.47	17.94
12/1/2006	12:14:00 PM	Run 3 - 1	8.79	193.47	17.7
12/1/2006	12:14:30 PM	Run 3 - 1	8.73	193.61	17.94
12/1/2006	12:15:00 PM	Run 3 - 1	8.79	193.03	17.82
12/1/2006	12:15:30 PM	Run 3 - 1	8.73	193.17	17.82
12/1/2006	12:16:00 PM	Run 3 - 1	8.79	193.03	17.7
12/1/2006	12:16:30 PM	Run 3 - 1	8.79	193.47	17.82
12/1/2006	12:17:00 PM	Run 3 - 1	8.85	193.61	17.82
12/1/2006	12:17:30 PM	Run 3 - 1	8.85	193.17	17.82
12/1/2006	12:18:00 PM	Run 3 - 1	8.85	192.3	17.82
12/1/2006	12:18:30 PM	Run 3 - 1	8.85	191.42	17.82
12/1/2006	12:19:00 PM	Run 3 - 1	8.91	191.12	17.82
12/1/2006	12:19:30 PM	Run 3 - 1	8.85	191.71	17.7
12/1/2006	12:20:00 PM	Run 3 - 1	8.91	191.42	17.7
12/1/2006	12:20:30 PM	Run 3 - 1	9.04	190.54	17.58
12/1/2006	12:21:00 PM	Run 3 - 1	9.04	189.07	17.58
12/1/2006	12:21:30 PM	Run 3 - 1	9.04	188.34	17.58
12/1/2006	12:22:00 PM	Run 3 - 1	8.97	187.61	17.7
12/1/2006	12:22:30 PM	Run 3 - 1	8.97	188.34	17.7
12/1/2006	12:23:00 PM	Run 3 - 1	8.97	187.9	17.82
12/1/2006	12:23:30 PM	Run 3 - 1	8.85	188.34	17.82
12/1/2006	12:24:00 PM	Run 3 - 1	8.73	188.19	17.82
12/1/2006	12:24:30 PM	Run 3 - 1	8.67	188.05	17.82
12/1/2006	12:25:00 PM	Run 3 - 1	8.61	187.61	18.07
12/1/2006	12:25:30 PM	Run 3 - 1	8.61	188.49	17.94
12/1/2006	12:26:00 PM	Run 3 - 1	8.55	188.34	18.07
12/1/2006	12:26:30 PM	Run 3 - 1	8.55	188.78	17.94
12/1/2006	12:27:00 PM	Run 3 - 1	8.55	189.37	17.94
12/1/2006	12:27:30 PM	Run 3 - 1	8.49	189.37	18.07

LabView Run Log
Polk Acid Plant

Date	Time	Status	O2 (%)	SO2 (%)	CO22 (%)
12/1/2006	12:28:00 PM	Run 3 - 1	8.55	188.63	18.07
12/1/2006	12:28:30 PM	Run 3 - 1	8.55	189.22	17.94
12/1/2006	12:29:00 PM	Run 3 - 1	8.67	189.51	17.94
12/1/2006	12:29:30 PM	Run 3 - 1	8.55	189.81	17.94
12/1/2006	12:30:00 PM	Run 3 - 1	8.61	191.12	17.82
12/1/2006	12:30:30 PM	Run 3 - 1	8.73	190.98	17.7
12/1/2006	12:31:00 PM	Run 3 - 1	8.67	191.12	17.94
12/1/2006	12:31:30 PM	Run 3 - 1	8.55	191.56	17.94
12/1/2006	12:32:00 PM	Run 3 - 1	8.43	193.03	18.07
12/1/2006	12:32:30 PM	Run 3 - 1	8.43	193.32	18.07
12/1/2006	12:33:00 PM	Run 3 - 1	8.36	193.47	18.19
12/1/2006	12:33:30 PM	Run 3 - 1	8.3	194.35	18.31
12/1/2006	12:34:00 PM	Run 3 - 1	8.24	194.35	18.31
12/1/2006	12:34:30 PM	Run 3 - 1	8.3	195.08	18.19
12/1/2006	12:35:00 PM	Run 3 - 1	8.36	195.22	18.19
12/1/2006	12:35:30 PM	Run 3 - 1	8.36	195.22	18.07
12/1/2006	12:36:00 PM	Run 3 - 1	8.43	195.52	18.07
12/1/2006	12:36:30 PM	Run 3 - 1	8.55	195.96	17.94
12/1/2006	12:37:00 PM	Run 3 - 1	8.61	196.54	17.82
12/1/2006	12:37:30 PM	Run 3 - 1	8.61	196.54	17.94
12/1/2006	12:38:00 PM	Run 3 - 1	8.67	196.25	17.94
12/1/2006	12:38:30 PM	Run 3 - 1	8.73	196.69	17.94
12/1/2006	12:39:00 PM	Run 3 - 1	8.85	196.25	17.7
12/1/2006	12:39:30 PM	Run 3 - 1	8.85	195.96	17.82
12/1/2006	12:40:00 PM	Run 3 - 1	8.79	195.37	17.82
12/1/2006	12:40:30 PM	Run 3 - 1	8.85	195.37	17.7
12/1/2006	12:41:00 PM	Run 3 - 1	8.91	194.35	17.7
12/1/2006	12:41:30 PM	Run 3 - 1	8.91	194.49	17.7
12/1/2006	12:42:00 PM	Run 3 - 1	8.85	194.2	17.82
12/1/2006	12:42:30 PM	Run 3 - 1	8.91	193.03	17.82
12/1/2006	12:43:00 PM	Run 3 - 1	8.91	192.59	17.82
12/1/2006	12:43:30 PM	Run 3 - 1	8.85	192.44	17.82
12/1/2006	12:44:00 PM	Run 3 - 1	8.79	191.86	17.82
12/1/2006	12:44:30 PM	Run 3 - 1	8.73	192.3	17.82
12/1/2006	12:45:00 PM	Run 3 - 1	8.73	192.73	17.82
12/1/2006	12:45:30 PM	Run 3 - 1	8.67	193.17	17.94
12/1/2006	12:46:00 PM	Run 3 - 1	8.55	192.44	17.94
12/1/2006	12:46:30 PM	Run 3 - 1	8.55	192.44	17.94
12/1/2006	12:47:00 PM	Run 3 - 1	8.61	191.42	17.94
12/1/2006	12:47:30 PM	Run 3 - 1	8.61	191.71	17.94
12/1/2006	12:48:00 PM	Run 3 - 1	8.55	192.59	17.94
12/1/2006	12:48:30 PM	Run 3 - 1	8.55	193.47	17.94
12/1/2006	12:49:00 PM	Run 3 - 1	8.55	193.47	17.94
12/1/2006	12:49:30 PM	Run 3 - 1	8.55	193.03	18.07
12/1/2006	12:50:00 PM	Run 3 - 1	8.49	193.32	18.07
12/1/2006	12:50:30 PM	Run 3 - 1	8.43	195.08	18.07
12/1/2006	12:51:00 PM	Run 3 - 1	8.49	195.52	17.94
12/1/2006	12:51:30 PM	Run 3 - 1	8.55	195.52	17.94
12/1/2006	12:52:00 PM	Run 3 - 1	8.55	195.08	18.07
12/1/2006	12:52:30 PM	Run 3 - 1	8.49	195.66	18.07

LabView Run Log
Polk Acid Plant

Date	Time	Status	O2 (%)	SO2 (%)	CO22 (%)
12/1/2006	12:53:00 PM	Run 3 - 1	8.55	196.4	18.07
12/1/2006	12:53:30 PM	Run 3 - 1	8.61	196.98	18.07
12/1/2006	12:54:00 PM	Run 3 - 1	8.61	197.57	17.94
12/1/2006	12:54:30 PM	Run 3 - 1	8.61	196.98	18.07
12/1/2006	12:55:00 PM	Run 3 - 1	8.61	196.69	18.07
12/1/2006	12:55:30 PM	Run 3 - 1	8.61	196.84	17.94
12/1/2006	12:56:00 PM	Run 3 - 1	8.67	197.27	18.07
12/1/2006	12:56:30 PM	Run 3 - 1	8.49	197.71	18.19
12/1/2006	12:57:00 PM	Run 3 - 1	8.43	199.18	18.19
12/1/2006	12:57:30 PM	Run 3 - 1	8.43	199.62	18.19
12/1/2006	12:58:00 PM	Run 3 - 1	8.43	199.91	18.07
12/1/2006	12:58:30 PM	Run 3 - 1	8.43	199.76	18.07
12/1/2006	12:59:00 PM	Run 3 - 1	8.55	199.33	18.07
12/1/2006	12:59:30 PM	Run 3 - 1	8.73	198.74	17.94
12/1/2006	1:00:00 PM	Run 3 - 1	8.73	198.59	17.94
12/1/2006	1:00:30 PM	Run 3 - 1	8.67	198.89	17.94
12/1/2006	1:01:00 PM	Run 3 - 1	8.67	198.59	17.94
12/1/2006	1:01:30 PM	Run 3 - 1	8.73	198.74	17.94
12/1/2006	1:02:00 PM	Run 3 - 1	8.73	198.59	17.94
12/1/2006	1:02:30 PM	Run 3 - 1	8.67	197.57	17.82
12/1/2006	1:03:00 PM	Run 3 - 1	8.67	198.15	17.94
12/1/2006	1:03:30 PM	Run 3 - 1	8.67	197.57	17.94
12/1/2006	1:04:00 PM	Run 3 - 1	8.73	197.71	17.94
12/1/2006	1:04:30 PM	Run 3 - 1	8.67	197.57	17.94
12/1/2006	1:05:00 PM	Run 3 - 1	8.61	197.42	18.07
12/1/2006	1:05:30 PM	Run 3 - 1	8.67	196.98	17.94
12/1/2006	1:06:00 PM	Run 3 - 1	8.61	196.54	17.94
12/1/2006	1:06:30 PM	Run 3 - 1	8.61	196.54	17.94
12/1/2006	1:07:00 PM	Run 3 - 1	8.49	197.71	17.94
12/1/2006	1:07:30 PM	Run 3 - 1	8.49	198.15	18.07
12/1/2006	1:08:00 PM	Run 3 - 1	8.49	197.57	18.07
12/1/2006	1:08:30 PM	Run 3 - 1	8.49	197.27	18.19
12/1/2006	1:09:00 PM	Run 3 - 1	8.43	196.69	18.07
12/1/2006	1:09:30 PM	Run 3 - 1	8.49	197.57	18.07
12/1/2006	1:10:00 PM		8.49	198.15	18.07
12/1/2006	1:10:30 PM		7.69	23.28	14.28
12/1/2006	1:11:00 PM		0.67	1.9	1.46
12/1/2006	1:11:30 PM	- ZERO	0	1.02	0.12
12/1/2006	1:12:00 PM	- ZERO	0	0.58	0.12
12/1/2006	1:12:30 PM	- ZERO	0	0.44	0.12
12/1/2006	1:13:00 PM	- ZERO	0	0.88	0
12/1/2006	1:13:30 PM	- ZERO	-0.06	0.44	16.84
12/1/2006	1:14:00 PM	- ZERO	-0.06	0.44	24.54
12/1/2006	1:14:30 PM	- Span	-0.06	0.14	24.78
12/1/2006	1:15:00 PM	- Span	-0.06	0	24.9
12/1/2006	1:15:30 PM	- Span	4.27	0	18.68
12/1/2006	1:16:00 PM	- Span	10.07	0	8.91
12/1/2006	1:16:30 PM	- Span	10.2	-0.15	8.79
12/1/2006	1:17:00 PM	- Span	10.13	77.91	8.67
12/1/2006	1:17:30 PM	- Span	1.59	150.55	9.4

LabView Run Log
Polk Acid Plant

Date	Time	Status	O2 (%)	SO2 (%)	CO22 (%)
12/1/2006	1:18:00 PM	- Span	-0.06	152.31	9.89
12/1/2006	1:18:30 PM	- Span	-0.06	161.83	10.01
12/1/2006	1:19:00 PM	- Span	5.62	196.84	14.77
12/1/2006	1:19:30 PM	- Span	8.61	196.98	17.82
12/1/2006	1:20:00 PM	- Span	8.67	197.57	17.94
12/1/2006	1:20:30 PM	- Span	8.73	196.25	17.94
12/1/2006	1:21:00 PM	- Span	8.67	198.59	18.07
12/1/2006	1:21:30 PM	- Span	8.61	196.84	18.07
12/1/2006	1:22:00 PM	- Span	8.55	198.15	18.07
12/1/2006	1:22:30 PM	- Span	8.49	197.86	18.07
12/1/2006	1:23:00 PM	- Span	8.43	197.42	18.07
12/1/2006	1:23:30 PM	- Span	8.36	198.74	17.94
12/1/2006	1:24:00 PM	- Span	8.36	198.74	17.94
12/1/2006	1:24:30 PM	- Span	8.43	198.45	17.94
12/1/2006	1:25:00 PM	- Span	8.43	199.03	17.82
12/1/2006	1:25:30 PM	- Span	8.43	199.03	17.94
12/1/2006	1:26:00 PM	- Span	8.49	198.01	17.94
12/1/2006	1:26:30 PM	- Span	8.61	198.01	17.82
12/1/2006	1:27:00 PM	- Span	8.61	197.71	17.82
12/1/2006	1:27:30 PM	- Span	8.67	197.86	17.82
12/1/2006	1:28:00 PM	- Span	8.61	198.45	17.94
12/1/2006	1:28:30 PM	- Span	8.61	199.33	17.82
12/1/2006	1:29:00 PM	- Span	8.61	200.06	17.94
12/1/2006	1:29:30 PM	- Span	8.55	199.76	17.94
12/1/2006	1:30:00 PM	- Span	8.43	199.33	17.94
12/1/2006	1:30:30 PM	- Span	8.36	199.91	17.94
12/1/2006	1:31:00 PM	- Span	8.36	199.62	18.07
12/1/2006	1:31:30 PM	- Span	8.36	199.76	18.07
12/1/2006	1:32:00 PM	- Span	8.36	200.35	18.19
12/1/2006	1:32:30 PM	- Span	8.36	200.64	18.07
12/1/2006	1:33:00 PM	- Span	8.36	200.2	18.07
12/1/2006	1:33:30 PM	- Span	8.49	199.47	18.07
12/1/2006	1:34:00 PM	- Span	8.43	200.35	18.07
12/1/2006	1:34:30 PM	- Span	8.49	201.23	18.07
12/1/2006	1:35:00 PM	- Span	8.49	201.81	18.07
12/1/2006	1:35:30 PM	- Span	8.43	202.11	18.07
12/1/2006	1:36:00 PM	- Span	8.36	202.84	18.19
12/1/2006	1:36:30 PM	- Span	8.36	203.87	18.07
12/1/2006	1:37:00 PM	- Span	8.36	204.01	18.19
12/1/2006	1:37:30 PM	- Span	8.24	204.45	18.31
12/1/2006	1:38:00 PM	- Span	8.3	206.79	18.31
12/1/2006	1:38:30 PM	- Span	8.3	206.5	18.19
12/1/2006	1:39:00 PM	- Span	8.36	206.06	18.07
12/1/2006	1:39:30 PM	- Span	8.49	205.92	17.94
12/1/2006	1:40:00 PM	- Span	8.55	205.48	17.94
12/1/2006	1:40:30 PM	- Span	8.61	205.92	17.82
12/1/2006	1:41:00 PM	- Span	8.73	205.92	17.7
12/1/2006	1:41:30 PM	- Span	8.85	205.18	17.7
12/1/2006	1:42:00 PM	- Span	8.97	204.45	17.7
12/1/2006	1:42:30 PM	- Span	8.97	204.3	17.7

LabView Run Log
Polk Acid Plant

Date	Time	Status	O2 (%)	SO2 (%)	CO22 (%)
12/1/2006	1:43:00 PM	- Span	9.04	203.43	17.58
12/1/2006	1:43:30 PM	- Span	9.1	202.25	17.7
12/1/2006	1:44:00 PM	- Span	9.1	202.25	17.7
12/1/2006	1:44:30 PM	- Span	8.97	201.67	17.82
12/1/2006	1:45:00 PM	- Span	8.85	201.52	17.94
12/1/2006	1:45:30 PM	- Span	8.73	201.96	17.82
12/1/2006	1:46:00 PM	- Span	8.61	202.11	17.94
12/1/2006	1:46:30 PM	- Span	8.67	199.91	17.82
12/1/2006	1:47:00 PM	- Span	8.49	99.29	17.94
12/1/2006	1:47:30 PM	- Span	4.21	6.15	6.59
12/1/2006	1:48:00 PM	- Span	0.06	1.17	0.24
12/1/2006	1:48:30 PM	- Span	0	1.02	0
12/1/2006	1:49:00 PM	- Span	0	0.73	0
12/1/2006	1:49:30 PM	- Span	0	0.73	0
12/1/2006	1:50:00 PM	- Span	0	0.58	0
12/1/2006	1:50:30 PM	- Span	0	0.44	0
12/1/2006	1:51:00 PM	- Span	0	0.29	0
12/1/2006	1:51:30 PM	- Span	0	0.14	0
12/1/2006	1:52:00 PM	- Span	-0.06	0.14	0
12/1/2006	1:52:30 PM	- Span	0	0.14	0.12

CALIBRATION GAS CERTIFICATIONS

RATA CLASS



Scott Specialty Gases

Dual-Analyzed Calibration Standard

6141 EASTON ROAD, BLDG 1, PLUMSTEADVILLE, PA 18949-0310

Phone: 800-331-4953

Fax: 215-766-7226

CERTIFICATE OF ACCURACY: EPA Protocol Gas

Assay Laboratory

SCOTT SPECIALTY GASES
6141 EASTON ROAD, BLDG 1
PLUMSTEADVILLE, PA 18949-0310

P.O. No.: E-N06925

Project No.: 01-58671-002

Customer

TAMPA ELECTRIC COMPANY
CHARLES DUFENY
5010 CAUSEWAY BLVD
TAMPA FL 33619

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure G-1; September, 1997.

Cylinder Number: ALM022018 Certification Date: 12Oct2006 Exp. Date: 11Oct2009
Cylinder Pressure***: 2000 PSIG

COMPONENT	CERTIFIED CONCENTRATION (Moles)	ANALYTICAL ACCURACY**	TRACEABILITY
CARBON DIOXIDE	18.0 %	+/- 1%	Direct NIST and NMI
OXYGEN	20.9 %	+/- 1%	Direct NIST and NMI
NITROGEN	BALANCE		

*** Do not use when cylinder pressure is below 150 psig

** Analytical accuracy is based on the requirements of EPA Protocol Procedure G1, September 1997.

REFERENCE STANDARD

TYPE/SRM NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
NTRM 1675	04Jul2008	K001509	13.93 %	CARBON DIOXIDE
NTRM 2659	04Jul2008	K004610	20.85 %	OXYGEN

INSTRUMENTATION

INSTRUMENT/MODEL/SERIAL#	DATE LAST CALIBRATED	ANALYTICAL PRINCIPLE
MTI:M200/170927	20Sep2006	GC-TCD
MTI:M200/170927	20Sep2006	GC-TCD

ANALYZER READINGS

(Z = Zero Gas R = Reference Gas T = Test Gas r = Correlation Coefficient)

First Triad Analysis

Second Triad Analysis

Calibration Curve

CARBON DIOXIDE

Date: 12Oct2006	Response Unit: AREA
Z1 = 0.00000	R1 = 643255.0 T1 = 826324.0
R2 = 643437.0	Z2 = 0.00000 T2 = 826277.0
Z3 = 0.00000	T3 = 826351.0 R3 = 643355.0
Avg. Concentration	18.00 %



Concentration = A + Bx + Cx ² + Dx ³ + Ex ⁴
r = .999988 1675
Constants: A = -2.56089E-02
B = 2.1778E-05 C =
D = E =

OXYGEN

Date: 12Oct2006	Response Unit: AREA
Z1 = 0.00000	R1 = 536285.0 T1 = 549300.0
R2 = 636629.0	Z2 = 0.00000 T2 = 549027.0
Z3 = 0.00000	T3 = 548522.0 R3 = 537922.0
Avg. Concentration:	20.90 %



Concentration = A + Bx + Cx ² + Dx ³ + Ex ⁴
r = .999998 2659
Constants: A = 1.9132E-02
B = 3.8059E-05 C =
D = E =

APPROVED BY:

JOHN C. FITZ

RATA CLASS



Scott Specialty Gases

Dual-Analyzed Calibration Standard

6141 EASTON ROAD, BLDG 1, PLUMSTEADVILLE, PA 18949-0310

Phone: 800-331-4953

Fax: 215-766-7226

CERTIFICATE OF ACCURACY: EPA Protocol Gas

Assay Laboratory

SCOTT SPECIALTY GASES
6141 EASTON ROAD, BLDG 1
PLUMSTEADVILLE, PA 18949-0310

P.O. No.: E-N06925

Project No.: 01-58671-001

Customer

TAMPA ELECTRIC COMPANY
CHARLES DUFENY
5010 CAUSEWAY BLVD
TAMPA FL 33619

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure G-1; September, 1997.

Cylinder Number: AAL20064 Certification Date: 12Oct2006 Exp. Date: 11Oct2009
Cylinder Pressure***: 2000 PSIG

COMPONENT	CERTIFIED CONCENTRATION (Moles)		ANALYTICAL ACCURACY**	TRACEABILITY
CARBON DIOXIDE	8.96	%	+/- 1%	Direct NIST and NMI
OXYGEN	10.1	%	+/- 1%	Direct NIST and NMI
NITROGEN	BALANCE			

*** Do not use when cylinder pressure is below 150 psig.

** Analytical accuracy is based on the requirements of EPA Protocol Procedure G1, September 1997.

REFERENCE STANDARD

TYPE/SRM NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
NTRM 1675	04Jul2008	K001509	13.93 %	CARBON DIOXIDE
NTRM 2658	02Oct2010	ALM065248	9.930 %	OXYGEN

INSTRUMENTATION

INSTRUMENT/MODEL/SERIAL#	DATE LAST CALIBRATED	ANALYTICAL PRINCIPLE
MTI/M200/170927	20Sep2006	GC-TCD
MTI/M200/170927	20Sep2006	GC-TCD

ANALYZER READINGS

(Z = Zero Gas R = Reference Gas T = Test Gas r = Correlation Coefficient)

First Triad Analysis

Second Triad Analysis

Calibration Curve

CARBON DIOXIDE

Date: 12Oct2006 Response Unit: AREA
Z1 = 0.00000 R1 = 643432.0 T1 = 412451.0
R2 = 843593.0 Z2 = 0.00000 T2 = 412322.0
Z3 = 0.00000 T3 = 412407.0 R3 = 643560.0
Avg. Concentration: 8.960 %

Concentration = A + Bx + Cx² + Dx³ + Ex⁴
r = .999988 1675
Constants: A = -2.56089E-02
B = 2.1778E-05 C =
D = E =

OXYGEN

Date: 12Oct2006 Response Unit: AREA
Z1 = 0.00000 R1 = 255181.0 T1 = 263879.0
R2 = 255371.0 Z2 = 0.00000 T2 = 263727.0
Z3 = 0.00000 T3 = 263736.0 R3 = 254821.0
Avg. Concentration: 10.10 %

Concentration = A + Bx + Cx² + Dx³ + Ex⁴
r = .999998 2658
Constants: A = 1.9132E-02
B = 3.8059E-05 C =
D = E =

APPROVED BY:

JOHN C. FITZ

BL501

RATA CLASS



Scott Specialty Gases

Dual-Analyzed Calibration Standard

1290 COMBERMERE STREET, TROY, MI 48063

Phone: 248-589-2950

Fax: 248-540-2134

CERTIFICATE OF ACCURACY: EPA Protocol Gas

Assay Laboratory

SCOTT SPECIALTY GASES
1290 COMBERMERE STREET
TROY, MI 48063

P.O. No.: E-N06925
Project No.: 05-27508-004

Customer

TAMPA ELECTRIC COMPANY
CHARLES DUFENY
5010 CAUSEWAY BLVD
TAMPA FL 33619

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards: Procedure G-1; September, 1997.

Cylinder Number: ALM042687 Certification Date: 07Feb2005 Exp. Date: 07Feb2008
Cylinder Pressure***: 1850 PSIG

COMPONENT	CERTIFIED CONCENTRATION (Moles)	ANALYTICAL ACCURACY**	TRACEABILITY
CARBON DIOXIDE	25.07 %	± 1%	Direct NIST and NMI
NITROGEN	BALANCE		

*** Do not use when cylinder pressure is below 150 psig
 ** Analytical accuracy is based on the requirements of EPA Protocol Procedure G1, September 1997
 Product certified to ± 1% analytical accuracy is directly traceable to NIST or NMI standards

REFERENCE STANDARD

TYPE/SRM NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
HIRM 2309	01Jan2008	ALM049147	23.34 %	CARBON DIOXIDE

INSTRUMENTATION

INSTRUMENT/MODEL/SERIAL#	DATE LAST CALIBRATED	ANALYTICAL PRINCIPLE
VALTRAC/3600/10883	28Jan2005	THERMAL CONDUCTIVITY


ANALYZER READINGS

(Z = Zero Gas R = Reference Gas T = Test Gas r = Correlation Coefficient)

First Triad Analysis Second Triad Analysis Calibration Curve

CARBON DIOXIDE

Date: 07Feb2005	Response Unit: AREA		
Z1 = 0.00000	R1 = 1214000	T1 = 1303800	
R2 = 1213747	Z2 = 0.00000	T2 = 1304200	
T3 = 0.00000	R3 = 1304300	R3 = 1214512	
Avg. Concentration:	25.07	%	



Concentration = A + Bx - Cx2 + Dx3 + Ex4	
r =	0.99999
Constants:	A = -0.26088732
	B = 1.54E-05
	C = 0
	D = 0
	E = 0

APPROVED BY:
DAVID BABCOCK

BL502

RATA CLASS



Scott Specialty Gases

Dual-Analyzed Calibration Standard

1290 COMBERMERE STREET, TROY, MI 48063

Phone: 248-593-2950

Fax: 248-593-2131

CERTIFICATE OF ACCURACY: EPA Protocol Gas

Assay Laboratory

SCOTT SPECIALTY GASES
1290 COMBERMERE STREET
TROY, MI 48063

P.O. No.: E-R06925
Project No. 05-27508-005

Customer

TAMPA ELECTRIC COMPANY
CHARLES DUFENY
5010 CAUSEWAY BLVD
TAMPA FL 33619

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards:
Procedure G-1: September, 1997

Cylinder Number: ALMD16344 Certification Date: 07Feb2005 Exp. Date: 07Feb2008
Cylinder Pressure***: 1850 PSIG

Table with 4 columns: COMPONENT, CERTIFIED CONCENTRATION (Moles), ANALYTICAL ACCURACY**, TRACEABILITY. Rows include CARBON DIOXIDE and NITROGEN.

*** Do not use when cylinder pressure is below 150 psig

** Analytical accuracy is based on the requirements of EPA Protocol Procedure G1, September 1997

Product certified at 1% analytical accuracy is directly traceable to NIST or BAM standards

REFERENCE STANDARD

Table with 5 columns: TYPE/SRM NO., EXPIRATION DATE, CYLINDER NUMBER, CONCENTRATION, COMPONENT. Row includes N1 RM 2300.

INSTRUMENTATION

Table with 3 columns: INSTRUMENT/MODEL/SERIAL#, DATE LAST CALIBRATED, ANALYTICAL PRINCIPLE. Row includes VARIAN 3500/093.

ANALYZER READINGS

I = Zero Gas R = Reference Gas T = Test Gas r = Correlation Coefficient

First Triad Analysis

Second Triad Analysis

Calibration Curve

CARBON DIOXIDE

Table with 3 columns: Data: 07Feb2005, Response Unit: MW. Rows include T1, T2, T3 and Avg. Concentration.



Table with 2 columns: Concentration = A + Bx - Cx2 - Dx3 + Ex4, Coefficients: r = .999959, A = -.025093732, B = 1.94E-05, C = 0, D = 0, E = 0.

APPROVED BY: _____

RATA CLASS



Scott Specialty Gases

Dual-Analyzed Calibration Standard

6141 EASTON ROAD, BLDG 1, PLUMSTEADVILLE, PA 18949-0310

Phone: 800-331-4953

Fax: 215-766-7226

CERTIFICATE OF ACCURACY: Interference Free TM Multi-Component EPA Protocol Gas

Assay Laboratory

SCOTT SPECIALTY GASES
6141 EASTON ROAD, BLDG 1
PLUMSTEADVILLE, PA 18949-0310

P.O. No.: E-N06925

Project No.: 01-52729-001

Customer

TAMPA ELECTRIC COMPANY
5010 CAUSEWAY BLVD
TAMPA FL 33619

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure G-1; September, 1997.

Cylinder Number: ALM009682 Certification Date: 27Jun2006 Exp. Date: 26Jun2008
Cylinder Pressure***: 1999 PSIG

COMPONENT	CERTIFIED CONCENTRATION (Moles)	ANALYTICAL ACCURACY**	TRACEABILITY
CARBON DIOXIDE	10.21 %	+/- 1%	Direct NIST and NMI
SULFUR DIOXIDE *	152.2 PPM	+/- 1%	Direct NIST and NMI
NITROGEN	BALANCE		

*** Do not use when cylinder pressure is below 150 psig.

** Analytical accuracy is based on the requirements of EPA Protocol Procedure G1, September 1997.

* This Protocol has been certified using corrected NIST SO2 standard values, per EPA guidance dated 7/24/96 and will not correlate with uncorrected Prot

REFERENCE STANDARD

TYPE/SRM NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
NTRM 1675	04Jul2008	K012148	13.93 %	CARBON DIOXIDE
NTRM 0260	02Oct2006	ALM057284	266.6 PPM	SULFUR DIOXIDE

INSTRUMENTATION

INSTRUMENT/MODEL/SERIAL#	DATE LAST CALIBRATED	ANALYTICAL PRINCIPLE
FTIR/000928781	08Jun2006	FTIR
FTIR/000928781	08Jun2006	FTIR

ANALYZER READINGS

(Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

First Triad Analysis

Second Triad Analysis

Calibration Curve

CARBON DIOXIDE

Date: 20Jun2006	Response Unit: %
Z1 = -0.00878	R1 = 13.97749 T1 = 10.24188
R2 = 13.98411	Z2 = -0.00769 T2 = 10.24781
Z3 = -0.00535	T3 = 10.25074 R3 = 13.99919
Avg. Concentration:	10.21 %

Z1 = 0.00000	R1 = 0.00000 T1 = 0.00000
R2 = 0.00000	Z2 = 0.00000 T2 = 0.00000
Z3 = 0.00000	T3 = 0.00000 R3 = 0.00000
Avg. Concentration:	0.000

Concentration = A + Bx + Cx ² + Dx ³ + Ex ⁴
r = 9.99997E-1
Constants: A = 0.00000E+0
B = 9.73447E-1 C = 3.63400E-3
D = 1.70000E-5 E = 0.00000E+0

SULFUR DIOXIDE *

Date: 20Jun2006	Response Unit: PPM
Z1 = -0.03225	R1 = 266.0084 T1 = 151.8536
R2 = 266.1603	Z2 = -0.01621 T2 = 151.9421
Z3 = 0.01808	T3 = 152.0154 R3 = 266.2468
Avg. Concentration:	152.2 PPM

Date: 27Jun2006	Response Unit: PPM
Z1 = -0.05180	R1 = 265.8178 T1 = 151.7932
R2 = 265.9785	Z2 = -0.04659 T2 = 151.8102
Z3 = 0.06517	T3 = 151.8972 R3 = 266.0725
Avg. Concentration:	152.2 PPM

Concentration = A + Bx + Cx ² + Dx ³ + Ex ⁴
r = 9.99998E-1
Constants: A = 0.00000E+0
B = 9.98458E-1 C = 1.00000E-5
D = 0.00000E+0 E = 0.00000E+0

APPROVED BY: 
Michael A. Kuhns

RDD018

RATA CLASS



Scott Specialty Gases

Dual-Analyzed Calibration Standard

6141 EASTON ROAD, BLDG 1, PLUMSTEADVILLE, PA 18949-0310

Phone: 800-331-4953

Fax: 215-766-7226

CERTIFICATE OF ACCURACY: Interference Free Multi-Component EPA Protocol Gas

Assay Laboratory

SCOTT SPECIALTY GASES
6141 EASTON ROAD, BLDG 1
PLUMSTEADVILLE, PA 18949-0310

P.O. No.: E-W06925
Project No.: 01-22406-002

Customer

TAMPA ELECTRIC COMPANY
CHARLES DUFENY
5010 CAUSEWAY BLVD
TAMPA FL 33619

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure G-1; September, 1997.

Cylinder Number: ALM029767 Certification Date: 27Dec2004 Exp. Date: 27Dec2006
Cylinder Pressure***: 1939 PSIG

Table with 4 columns: COMPONENT, CERTIFIED CONCENTRATION (Moles), ANALYTICAL ACCURACY**, TRACEABILITY. Rows include CARBON DIOXIDE, SULFUR DIOXIDE, and NITROGEN.

*** Do not use when cylinder pressure is below 150 psig

** Analytical accuracy is based on the requirements of EPA Protocol Procedure G-1, September 1997.

Product certified at +/- 1% analytical accuracy is directly traceable to NIST or IRM standards

* This Protocol has been certified using certified NIST SO2 standard values, per EPA guidance dated 7/24/98 and will not correlate with uncorrected protocols.

REFERENCE STANDARD

Table with 5 columns: TYPE/SIM NO., EXPIRATION DATE, CYLINDER NUMBER, CONCENTRATION, COMPONENT. Rows include ITRM 1100 and ITRM 0200.

INSTRUMENTATION

Table with 3 columns: INSTRUMENT/MODEL/SERIAL#, DATE LAST CALIBRATED, ANALYTICAL PRINCIPLE. Rows include MRS Online:2020/MS-99-110.

ANALYZER READINGS

(Z = Zero Gas R = Reference Gas T = Test Gas r = Correlation Coefficient)

First Triad Analysis

Second Triad Analysis

Calibration Curve

CARBON DIOXIDE

Table with 3 columns: Response Unit: PPM. Rows include Z1, R1, T1, Z2, R2, T2, Z3, R3, T3, Avg. Concentration.

Empty table box for Carbon Dioxide Second Triad Analysis.

Table with 2 columns: Concentration = A + Bx + Cx2 + Dx3 + Ex4, Constants. Rows include A, B, C, D, E values.

SULFUR DIOXIDE*

Table with 3 columns: Response Unit: PPM. Rows include Z1, R1, T1, Z2, R2, T2, Z3, R3, T3, Avg. Concentration.

Table with 3 columns: Response Unit: PPM. Rows include Z1, R1, T1, Z2, R2, T2, Z3, R3, T3, Avg. Concentration.

Table with 2 columns: Concentration = A + Bx + Cx2 + Dx3 + Ex4, Constants. Rows include A, B, C, D, E values.

APPROVED BY:

Handwritten signature

APPENDIX F
FUEL ANALYSIS

SYNTHETIC GAS ANALYSIS – DECEMBER 1, 2006

UNIT 1 STACK TEST 12/01/06 CT & ACID PLANT

Calibration Standard Check

	% CO2	% O2	% N2	% CH4	% CO	Calc. % H2	% H2S/COS
True Value	14.70	1.010	2.99	0.1040	45.20	36.00	N.A.
Std. 1	14.94	1.022	3.00	0.1011	45.28	35.66	N.A.
Std. 2	14.77	0.991	2.95	0.1049	45.28	35.90	N.A.
Std. 3	14.69	0.999	2.95	0.1048	45.31	35.95	N.A.
Avg.	14.80	1.004	2.97	0.1036	45.29	35.84	N.A.

Clean Syngas Sampled @ 0915 12/01/06

	% CO2	% O2	% N2	% CH4	% CO	Calc. % H2	% H2S/COS
1st Bomb	14.32	0.880	3.79	0.0293	47.24	33.74	N.A.
2nd Bomb	14.34	0.850	3.83	0.0287	46.90	34.05	N.A.
Avg.	14.33	0.87	3.81	0.0290	47.07	33.90	N.A.

Clean Syngas Sampled @ 1020 12/01/06

	% CO2	% O2	% N2	% CH4	% CO	Calc. % H2	% H2S/COS
1st Bomb	14.50	0.850	3.87	0.0275	47.12	33.63	N.A.
2nd Bomb	14.47	0.860	3.96	0.0323	46.89	33.79	N.A.
Avg.	14.49	0.86	3.92	0.0299	47.01	33.71	N.A.

Clean Syngas Sampled @ 1140 12/01/06

	% CO2	% O2	% N2	% CH4	% CO	Calc. % H2	% H2S/COS
1st Bomb	14.44	0.850	3.97	0.0304	46.78	33.96	N.A.
2nd Bomb	14.48	0.860	3.94	< 0.0050	47.03	33.69	N.A.
Avg.	14.46	0.86	3.96	0.0304	46.91	33.83	N.A.

Clean Syngas Sampled @ 1255 12/01/06

	% CO2	% O2	% N2	% CH4	% CO	Calc. % H2	% H2S/COS
1st Bomb	14.56	0.870	3.67	0.0272	47.16	33.74	N.A.
2nd Bomb	14.53	0.860	4.02	0.0299	47.13	33.43	N.A.
Avg.	14.55	0.87	3.85	0.0286	47.15	33.59	N.A.

Average for All Syngas Samples Using all Results

	% CO2	% O2	% N2	% CH4	% CO	Calc. % H2	% H2S/COS
Avg.	14.46	0.86	3.88	0.0293	47.03	33.75	0

Mole Wt.	21.65
----------	-------

HHV	BTU/SCF	260.5
-----	---------	-------

HHV	BTU/Lb	4565
-----	--------	------



Coal Derived Gas and Heating Value Calculations

Customer: Tampa Electric Company

Sample ID: Polk GC

Facility: Polk Power Station

Analysis Date:

12/1/2006

Source: Unit 1

CALCULATION OF DENSITY AND HEATING VALUE @ 60°F and 30 in Hg

Component	% Volume	Molecular Wt.	Density* (lb/ft ³)	% volume		Component		Gross* Heating Value (Btu/SCF)	Volume Fract. Btu
				x Density	weight %	Gross Btu/lb	Weight Fract. Btu		
Hydrogen	33.7540	2.016	0.0053	0.00179	3.1313	61100	1913.21	325.0	109.7006
Oxygen	0.8600	32.000	0.0846	0.00073	1.2735	0	0.00	0.0	0
Argon	0.0000	39.948	0.1065	0.00000	0.0000	0	0.00	0.0	0
Nitrogen	3.8813	28.016	0.0744	0.00289	5.0543	0	0.00	0.0	0
CO2	14.4550	44.010	0.1170	0.01691	29.6022	0	0.00	0.0	0
CO	47.0313	28.010	0.0740	0.03480	60.9170	4347	2648.06	322.0	151.4406
COS	0.0000	60.070	0.1602	0.00000	0.0000	0	0.00	0.0	0
Methane	0.0293	16.041	0.0424	0.00001	0.0218	23879	5.20	1013.0	0.297098
Ethane	0.000	30.067	0.0803	0.00000	0.0000	22320	0.00	1792.0	0
Ethylene	0.000	28.051	0.0746	0.00000	0.0000	21644	0.00	1614.0	0
Propane	0.000	44.092	0.1196	0.00000	0.0000	21661	0.00	2590.0	0
propylene	0.000	42.077	0.1110	0.00000	0.0000	21041	0.00	2336.0	0
Isobutane	0.000	58.118	0.1582	0.00000	0.0000	21257	0.00	3363.0	0
n-butane	0.000	58.118	0.1582	0.00000	0.0000	21308	0.00	3370.0	0
Isobutene	0.000	56.102	0.1480	0.00000	0.0000	20730	0.00	3068.0	0
Isopentane	0.000	72.144	0.1904	0.00000	0.0000	21052	0.00	4008.0	0
n-pentane		72.144	0.1904	0.00000	0.0000	21091	0.00	4016.0	0
n-hexane		86.169	0.2274	0.00000	0.0000	20940	0.00	4762.0	0
H2S		34.076	0.0911	0.00000	0.0000	7100	0.00	647.0	0

Total: 100.01

Average Density	0.05713	100.0000
Specific Gravity	0.74682	

Gross Heating Value			
Btu/lb	4566	Btu/SCF	261.44
Net Heating Values			
Btu/lb	4276	Btu/SCF	244

* Density (lb/ft³) and Gross Heating Value (Btu/scf) data from Perry's Chemical Engineering Handbook.

Net Heating Value (Lower Heating Value), Btu/lb, calculated as Gross Heating Value (Higher Heating Value) - 10.30 (%H₂ x 8.94)



Coal Derived Gas and Heating Value Calculations

Customer: Tampa Electric Company

Facility: Polk Power Station

Source: Unit 1

Sample ID: Polk GC

Analysis Date:

12/1/2006

CALCULATION OF F FACTORS

Component	Mol. Wt.	C Factor	H Factor	% volume	Fract. Wt.	Weight Percents			
						Carbon	Hydrogen	Nitrogen	Oxygen
Hydrogen	2.016	0	1	33.754	68.0481	3.1528793			
Oxygen	32.000	0	0	0.860	27.5200				1.2750861
Argon	39.948	0	0	0.000	0.0000				
Nitrogen	28.016	0	0	3.881	108.7371			5.038123867	
CO2	44.010	0.272273	0	14.455	636.1646	8.02537132			21.428658
CO	28.010	0.42587	0	47.031	1317.3453	25.9936803			35.077766
COS	60.070	0.1998	0	0.000	0.0000	0			0
Methane	16.041	0.75	0.25	0.029	0.4705	0.01634838	0.0054495		
Ethane	30.067	0.8	0.2	0.000	0.0000	0	0		
Ethylene	28.051	0.85714	0.14286	0.000	0.0000	0	0		
Propane	44.092	0.81818	0.181818	0.000	0.0000	0	0		
Propene	42.077	0.85714	0.14286	0.000	0.0000	0	0		
Isobutane	58.118	0.82759	0.17247	0.000	0.0000	0	0		
n-butane	58.118	0.82759	0.17247	0.000	0.0000	0	0		
Isobutene	56.102	0.85714	0.14286	0.000	0.0000	0	0		
Isopentane	72.144	0.83333	0.16667	0.000	0.0000	0	0		
n-pentane	72.144	0.83333	0.16667	0.000	0.0000	0	0		
n-hexane	86.169	0.83721	0.16279	0.000	0.0000	0	0		
H2S	34.076	0	0.0586923	0.000	0.0000	0	0		
Totals				100.01087	2158.2856	34.0354	3.16	5.038123867	57.78151

CALCULATED VALUES		
O2 F Factor (dry), Fd	8255	DSCF of Exhaust/MM Btu of Fuel Burned @ 0% excess air
O2 F Factor (wet), Fw	9590	SCF of Exhaust/MM Btu of Fuel Burned @ 0% excess air
Moisture F Factor	1335	SCF of Water/MM Btu of Fuel Burned @ 0% excess air
Combust. Moisture	13.92	volume % water in flue gas @ 0% excess air
CO2 F Factor, Fc	2393	DSCF of CO2/MM Btu of Fuel Burned @ 0% excess air
Carbon Dioxide	28.98	volume % CO2 in flue gas @ 0% O2
Predicted Fo Factor	0.72	EPA Method 3a Fo value

APPENDIX G
PLANT OPERATIONS DATA

IGCC

IGCC Operations Data

Plant Information Source: polk-1pisrv

Start Time: 12/1/2006 9:00

End Time: 12/1/2006 13:20

Time Interval: 1 Min

Tag Name:	1pwrij900	1TSYFI100	1tmsti922m	1tsyai202
Tag Explanation:	Unit Load	Fuel Flow	Inlet Temp	Satuator
Tag Units:	Mwe	KCFH	°F	% H2O
Run Average:	174.995426	6653.63375	80.8493319	3.80882985
01-Dec-06 09:00:00	174.470459	6633.5249	74.2104568	3.79977226
01-Dec-06 09:01:00	174.686264	6632.97461	74.2362137	3.79914117
01-Dec-06 09:02:00	174.623215	6654.13818	74.377121	3.79851031
01-Dec-06 09:03:00	174.195465	6687.87305	74.377121	3.79787922
01-Dec-06 09:04:00	174.495041	6696.52637	74.377121	3.79724813
01-Dec-06 09:05:00	175.543274	6675.56445	74.377121	3.79661703
01-Dec-06 09:06:00	175.009918	6658.86816	74.377121	3.79598594
01-Dec-06 09:07:00	175.660873	6649.70117	74.377121	3.79535484
01-Dec-06 09:08:00	173.732758	6727.37646	74.5942841	3.79472399
01-Dec-06 09:09:00	173.983841	6726.27637	74.4352951	3.79409289
01-Dec-06 09:10:00	175.104111	6637.52148	74.6406174	3.7934618
01-Dec-06 09:11:00	174.183777	6620.97559	74.8459396	3.79283071
01-Dec-06 09:12:00	174.256973	6650.60742	74.8572388	3.79219961
01-Dec-06 09:13:00	175.714584	6667.93799	74.690239	3.79156852
01-Dec-06 09:14:00	175.500656	6645.60693	74.690239	3.79093766
01-Dec-06 09:15:00	174.813995	6636.17773	74.9863434	3.79030657
01-Dec-06 09:16:00	175.45488	6630.8916	74.8842392	3.78967547
01-Dec-06 09:17:00	175.473633	6678.96191	74.782135	3.78904438
01-Dec-06 09:18:00	174.117706	6699.03223	74.7004471	3.78841329
01-Dec-06 09:19:00	173.548721	6613.25195	74.8025513	3.78778219
01-Dec-06 09:20:00	175.353867	6619.07129	74.9046555	3.78715134
01-Dec-06 09:21:00	174.683823	6608.38867	74.9930878	3.78652024
01-Dec-06 09:22:00	174.967224	6634.0957	74.6928253	3.78588915
01-Dec-06 09:23:00	174.950867	6681.8335	74.8480911	3.78525805
01-Dec-06 09:24:00	175.874084	6675.61035	75.0033569	3.78462696
01-Dec-06 09:25:00	175.08316	6668.45996	75.4140854	3.78399587
01-Dec-06 09:26:00	175.33316	6611.37109	75.5133591	3.78336501
01-Dec-06 09:27:00	175.970901	6652.23145	75.6126251	3.78273392
01-Dec-06 09:28:00	176.21405	6729.38086	75.3464203	3.78210282
01-Dec-06 09:29:00	175.446335	6698.58545	75.5904541	3.78147173
01-Dec-06 09:30:00	175.013901	6665.95117	75.400589	3.78084064
01-Dec-06 09:31:00	174.331848	6656.75342	75.4958115	3.78020954
01-Dec-06 09:32:00	174.416641	6623.43457	75.5910339	3.77957845
01-Dec-06 09:33:00	175.672333	6702.88965	75.6862564	3.77894759

IGCC Operations Data

Tag Name:	1pwrj900	1TSYFI100	1tmsti922m	1tsyai202
Tag Explanation:	Unit Load	Fuel Flow	Inlet Temp	Satuator
Tag Units:	Mwe	KCFH	°F	% H2O
01-Dec-06 09:34:00	176.294952	6673.76855	75.7814789	3.7783165
01-Dec-06 09:35:00	175.424057	6668.73779	75.8767014	3.7776854
01-Dec-06 09:36:00	174.500305	6591.61279	75.9719315	3.77705431
01-Dec-06 09:37:00	174.139038	6647.99023	76.0671539	3.77642322
01-Dec-06 09:38:00	174.692871	6784.71143	76.1623764	3.77579212
01-Dec-06 09:39:00	174.04837	6625.97803	76.2575989	3.77516127
01-Dec-06 09:40:00	174.132462	6627.45313	76.3528214	3.77453017
01-Dec-06 09:41:00	175.186462	6628.92773	76.4480438	3.77389908
01-Dec-06 09:42:00	175.559494	6638.46875	76.5432663	3.77326798
01-Dec-06 09:43:00	175.404602	6694.0332	76.6384888	3.77263689
01-Dec-06 09:44:00	175.073883	6695.1084	76.7337112	3.7720058
01-Dec-06 09:45:00	174.729004	6622.76758	76.8289337	3.77137494
01-Dec-06 09:46:00	174.97998	6616.48193	76.7063751	3.77074385
01-Dec-06 09:47:00	174.819992	6626.12109	76.6423874	3.77011275
01-Dec-06 09:48:00	175.444366	6745.46582	76.7963791	3.76948166
01-Dec-06 09:49:00	175.045135	6705.61182	76.9503784	3.76885056
01-Dec-06 09:50:00	175.351212	6665.16309	77.1043701	3.76821947
01-Dec-06 09:51:00	175.378784	6633.62842	76.9001541	3.76758862
01-Dec-06 09:52:00	176.151001	6691.69824	76.9619598	3.76695752
01-Dec-06 09:53:00	175.837341	6669.56299	77.0237579	3.76632643
01-Dec-06 09:54:00	175.158234	6682.53125	77.085556	3.76569533
01-Dec-06 09:55:00	175.908722	6673.51709	77.1473618	3.76506424
01-Dec-06 09:56:00	175.522827	6631.53223	77.5302048	3.76443315
01-Dec-06 09:57:00	174.798233	6662.13281	77.6175842	3.76380229
01-Dec-06 09:58:00	174.989777	6680.95459	77.7049713	3.7631712
01-Dec-06 09:59:00	174.569443	6610.58887	77.7923508	3.7625401
01-Dec-06 10:00:00	173.824265	6602.146	77.8797302	3.76190901
01-Dec-06 10:01:00	175.880081	6628.8252	77.9671173	3.76127791
01-Dec-06 10:02:00	174.617599	6606.71387	78.0544968	3.76064682
01-Dec-06 10:03:00	173.902237	6674.54639	78.0973969	3.76001596
01-Dec-06 10:04:00	175.076828	6697.57764	77.942131	3.75938487
01-Dec-06 10:05:00	176.251419	6692.61523	77.8273697	3.75875378
01-Dec-06 10:06:00	175.900208	6643.79834	77.9151611	3.75812268
01-Dec-06 10:07:00	174.423355	6612.64209	78.0029526	3.75799751
01-Dec-06 10:08:00	174.984787	6699.10547	78.090744	3.75863123
01-Dec-06 10:09:00	174.549683	6717.06738	78.1785355	3.75926495
01-Dec-06 10:10:00	174.158325	6631.79883	78.2663269	3.75989866
01-Dec-06 10:11:00	173.802612	6614.40771	78.3541183	3.76053238
01-Dec-06 10:12:00	175.396835	6693.94336	78.4595108	3.7611661
01-Dec-06 10:13:00	175.774124	6678.521	78.7520981	3.76179981

IGCC Operations Data

Tag Name:	1pwri900	1TSYFI100	1tmsti922m	1tsyai202
Tag Explanation:	Unit Load	Fuel Flow	Inlet Temp	Satuator
Tag Units:	Mwe	KCFH	°F	% H2O
01-Dec-06 10:14:00	175.164658	6669.9834	79.0551147	3.76243353
01-Dec-06 10:15:00	174.409866	6634.89111	78.7625351	3.76306725
01-Dec-06 10:16:00	174.380371	6615.72266	78.8510666	3.76370096
01-Dec-06 10:17:00	175.964539	6650.37354	78.9534531	3.76433468
01-Dec-06 10:18:00	175.233047	6690.43359	79.0558319	3.7649684
01-Dec-06 10:19:00	175.34024	6683.375	79.1582184	3.76560211
01-Dec-06 10:20:00	175.758209	6653.13281	79.2606049	3.76623583
01-Dec-06 10:21:00	176.176178	6642.6792	79.3629837	3.76686931
01-Dec-06 10:22:00	175.823196	6649.47266	79.438942	3.76750302
01-Dec-06 10:23:00	174.768204	6646.74902	79.8723755	3.76813674
01-Dec-06 10:24:00	174.280014	6677.98633	79.9958801	3.76877046
01-Dec-06 10:25:00	174.66124	6668.36523	79.9958801	3.76940417
01-Dec-06 10:26:00	175.042465	6631.39795	79.9958801	3.77003789
01-Dec-06 10:27:00	175.039276	6641.55469	79.9958801	3.77067161
01-Dec-06 10:28:00	175.185181	6711.24219	80.4167938	3.77130532
01-Dec-06 10:29:00	174.4254	6689.63379	80.5707855	3.77193904
01-Dec-06 10:30:00	174.717865	6629.04492	80.3089981	3.77257276
01-Dec-06 10:31:00	176.086319	6678.13135	80.6421051	3.77320647
01-Dec-06 10:32:00	175.233276	6642.08643	80.6728516	3.77384019
01-Dec-06 10:33:00	175.464035	6652.52441	80.703598	3.77447391
01-Dec-06 10:34:00	175.554123	6683.47266	80.7343521	3.77510762
01-Dec-06 10:35:00	174.419556	6653.24609	80.7650986	3.77574134
01-Dec-06 10:36:00	174.823593	6610.0083	80.795845	3.77637506
01-Dec-06 10:37:00	174.97818	6659.17383	80.8265991	3.77700877
01-Dec-06 10:38:00	175.497498	6704.27539	80.8573456	3.77764249
01-Dec-06 10:39:00	174.966171	6679.7998	80.888092	3.77827621
01-Dec-06 10:40:00	174.744202	6634.69824	80.9188461	3.77890992
01-Dec-06 10:41:00	175.244003	6634.08691	80.7578049	3.7795434
01-Dec-06 10:42:00	175.211884	6613.70557	80.6862793	3.78017712
01-Dec-06 10:43:00	174.360413	6658.31836	80.8402786	3.78081083
01-Dec-06 10:44:00	174.834122	6684.75146	80.8171768	3.78144455
01-Dec-06 10:45:00	175.459229	6656.16699	80.8995056	3.78207827
01-Dec-06 10:46:00	174.82164	6620.96582	80.7974014	3.78271198
01-Dec-06 10:47:00	176.260101	6612.45898	80.6952896	3.7833457
01-Dec-06 10:48:00	175.39415	6703.854	80.6513672	3.78397942
01-Dec-06 10:49:00	175.075943	6726.73486	80.7545929	3.78461313
01-Dec-06 10:50:00	174.757751	6616.78955	80.8578186	3.78524685
01-Dec-06 10:51:00	174.009521	6597.09082	81.22612	3.78588057
01-Dec-06 10:52:00	174.522217	6620.0957	81.1234512	3.78651428
01-Dec-06 10:53:00	175.098267	6643.10059	81.0207901	3.787148

IGCC Operations Data

Tag Name:	1pwri900	1TSYFI100	1tmsti922m	1tsyai202
Tag Explanation:	Unit Load	Fuel Flow	Inlet Temp	Satuator
Tag Units:	Mwe	KCFH	°F	% H2O
01-Dec-06 10:54:00	175.125275	6666.10547	80.960907	3.78778172
01-Dec-06 10:55:00	175.647583	6647.56445	81.1148987	3.78841543
01-Dec-06 10:56:00	174.793747	6634.06494	81.2688904	3.78904915
01-Dec-06 10:57:00	174.767303	6672.82813	81.4228821	3.78968287
01-Dec-06 10:58:00	175.684357	6755.67676	81.5512695	3.79031658
01-Dec-06 10:59:00	174.207428	6689.42773	81.4491653	3.7909503
01-Dec-06 11:00:00	175.216537	6643.66846	81.3470612	3.79158378
01-Dec-06 11:01:00	174.65535	6607.96094	81.255127	3.79221749
01-Dec-06 11:02:00	175.027557	6623.54492	81.4582367	3.79285121
01-Dec-06 11:03:00	175.015701	6656.08496	81.6613388	3.79348493
01-Dec-06 11:04:00	175.694763	6682.85547	81.8644409	3.79411864
01-Dec-06 11:05:00	176.081589	6673.21387	81.8745956	3.79475236
01-Dec-06 11:06:00	175.471848	6649.7583	81.2988663	3.79538608
01-Dec-06 11:07:00	175.446167	6633.98486	81.5306778	3.79601979
01-Dec-06 11:08:00	174.823456	6694.38916	81.4695816	3.79665351
01-Dec-06 11:09:00	174.735641	6696.58691	81.3674774	3.79728723
01-Dec-06 11:10:00	175.189362	6666.3584	81.2653732	3.79792094
01-Dec-06 11:11:00	175.573318	6652.6875	81.3506851	3.79855466
01-Dec-06 11:12:00	174.888168	6643.39844	81.4734802	3.79918838
01-Dec-06 11:13:00	174.831711	6634.10938	81.5962677	3.79982209
01-Dec-06 11:14:00	174.698639	6649.78467	81.7190628	3.80045581
01-Dec-06 11:15:00	175.809662	6640.01953	81.8418503	3.80108953
01-Dec-06 11:16:00	175.347748	6650.58154	81.6449738	3.80172324
01-Dec-06 11:17:00	175.021118	6652.77539	81.8745956	3.80235696
01-Dec-06 11:18:00	175.22464	6719.68799	81.8745956	3.80299067
01-Dec-06 11:19:00	174.535721	6653.41162	82.2903824	3.80362439
01-Dec-06 11:20:00	174.003342	6614.42676	82.4443741	3.80425787
01-Dec-06 11:21:00	173.831985	6600.29102	82.263443	3.80489159
01-Dec-06 11:22:00	174.297012	6615.95459	82.3862305	3.8055253
01-Dec-06 11:23:00	175.898697	6690.06689	82.5090256	3.80615902
01-Dec-06 11:24:00	175.419968	6715.75098	82.631813	3.80679274
01-Dec-06 11:25:00	174.933762	6684.13281	82.7546082	3.80742645
01-Dec-06 11:26:00	174.551926	6595.64063	82.6548309	3.80806017
01-Dec-06 11:27:00	174.430969	6613.21631	82.6548309	3.80869389
01-Dec-06 11:28:00	176.102219	6719.97852	82.6473007	3.8093276
01-Dec-06 11:29:00	175.910095	6742.00684	82.6730576	3.80996132
01-Dec-06 11:30:00	175.717987	6649.75635	82.1877213	3.81059504
01-Dec-06 11:31:00	175.317245	6604.49072	82.1877213	3.81122875
01-Dec-06 11:32:00	174.530167	6617.63818	82.4418106	3.81186247
01-Dec-06 11:33:00	174.126724	6639.08887	82.2878189	3.81249619

IGCC Operations Data

Tag Name:	1pwrij900	1TSYFI100	1tmsti922m	1tsyai202
Tag Explanation:	Unit Load	Fuel Flow	Inlet Temp	Satuator
Tag Units:	Mwe	KCFH	°F	% H2O
01-Dec-06 11:34:00	174.78157	6624.23975	82.2946396	3.8131299
01-Dec-06 11:35:00	175.719498	6688.48682	82.6001205	3.81376362
01-Dec-06 11:36:00	175.20488	6642.10156	82.7677612	3.81439734
01-Dec-06 11:37:00	175.106369	6628.63525	82.6137695	3.81503105
01-Dec-06 11:38:00	173.977173	6676.42578	82.5280685	3.81566477
01-Dec-06 11:39:00	173.856934	6634.60645	82.6301727	3.81629848
01-Dec-06 11:40:00	174.095276	6616.63916	82.7322769	3.81693196
01-Dec-06 11:41:00	175.01796	6619.0835	82.7893982	3.81756568
01-Dec-06 11:42:00	175.883087	6621.52783	82.6666107	3.8181994
01-Dec-06 11:43:00	174.65834	6647.84326	82.5438156	3.81883311
01-Dec-06 11:44:00	175.009552	6688.1416	82.4210281	3.81946683
01-Dec-06 11:45:00	174.306992	6631.27539	82.298233	3.82010055
01-Dec-06 11:46:00	174.654129	6599.19092	82.1877213	3.82073426
01-Dec-06 11:47:00	174.855621	6609.69678	82.4923782	3.82136798
01-Dec-06 11:48:00	175.015121	6687.83154	82.3908234	3.8220017
01-Dec-06 11:49:00	175.583664	6721.72949	82.2892761	3.82263541
01-Dec-06 11:50:00	175.163727	6693.23193	82.1877213	3.82326913
01-Dec-06 11:51:00	174.072845	6630.17578	82.2184677	3.82390285
01-Dec-06 11:52:00	174.967377	6612.60547	82.2492142	3.82453656
01-Dec-06 11:53:00	174.340302	6629.65625	82.2799683	3.82517028
01-Dec-06 11:54:00	174.277267	6610.4668	82.3107147	3.825804
01-Dec-06 11:55:00	174.566483	6621.00879	82.3414612	3.82643771
01-Dec-06 11:56:00	174.530273	6649.70117	82.3722076	3.82707143
01-Dec-06 11:57:00	174.494049	6611.21094	82.4029541	3.82770514
01-Dec-06 11:58:00	174.346756	6691.64355	82.4337082	3.82833886
01-Dec-06 11:59:00	174.452866	6644.86133	82.4644547	3.82897258
01-Dec-06 12:00:00	174.822098	6620.51953	82.4952011	3.82960606
01-Dec-06 12:01:00	174.934052	6622.53662	82.5008392	3.83023977
01-Dec-06 12:02:00	175.418106	6630.6001	82.9755707	3.83087349
01-Dec-06 12:03:00	174.90921	6639.87305	82.8882599	3.83150721
01-Dec-06 12:04:00	174.92691	6698.12109	83.2400131	3.83214092
01-Dec-06 12:05:00	175.101166	6643.30273	83.3940048	3.83277464
01-Dec-06 12:06:00	174.488739	6607.31299	83.2210159	3.83340836
01-Dec-06 12:07:00	175.3004	6627.24805	83.4102097	3.83404207
01-Dec-06 12:08:00	176.263153	6706.2959	83.3663101	3.83467579
01-Dec-06 12:09:00	175.413681	6717.01904	83.3224182	3.83530951
01-Dec-06 12:10:00	174.971405	6642.05273	83.2785187	3.83594322
01-Dec-06 12:11:00	174.779617	6622.65283	83.2346268	3.83657694
01-Dec-06 12:12:00	174.990997	6666.1167	83.1907272	3.83721066
01-Dec-06 12:13:00	175.643555	6669.88086	83.1468353	3.83784437

IGCC Operations Data

Tag Name:	1pwrij900	1TSYFI100	1tmsti922m	1tsyai202
Tag Explanation:	Unit Load	Fuel Flow	Inlet Temp	Satuator
Tag Units:	Mwe	KCFH	°F	% H2O
01-Dec-06 12:14:00	175.363327	6643.99365	83.2759399	3.83847809
01-Dec-06 12:15:00	174.789627	6631.12256	83.2066422	3.83911118
01-Dec-06 12:16:00	174.116028	6646.93896	83.3606415	3.83974552
01-Dec-06 12:17:00	174.503296	6646.25	83.2913437	3.84037924
01-Dec-06 12:18:00	174.765152	6721.78467	83.2223816	3.84101295
01-Dec-06 12:19:00	174.289841	6664.04053	83.42659	3.84164643
01-Dec-06 12:20:00	174.007843	6595.29834	83.6307907	3.84228015
01-Dec-06 12:21:00	174.753738	6608.86523	83.6917191	3.84291387
01-Dec-06 12:22:00	175.057129	6642.96631	83.5377274	3.84354758
01-Dec-06 12:23:00	174.988098	6657.26709	83.1270828	3.8441813
01-Dec-06 12:24:00	176.064255	6704.80713	82.8139572	3.84481502
01-Dec-06 12:25:00	174.494003	6623.25146	82.8139572	3.84544873
01-Dec-06 12:26:00	174.997711	6624.74951	82.991394	3.84608245
01-Dec-06 12:27:00	176.119949	6628.95947	83.1882553	3.84671617
01-Dec-06 12:28:00	175.307114	6683.43018	83.43293	3.84734988
01-Dec-06 12:29:00	174.619278	6702.95508	83.6776047	3.8479836
01-Dec-06 12:30:00	174.896545	6642.28223	83.9222794	3.84861732
01-Dec-06 12:31:00	174.702057	6628.4707	84.1669617	3.84925103
01-Dec-06 12:32:00	176.013367	6659.91943	84.3877792	3.84988475
01-Dec-06 12:33:00	176.049393	6683.41162	84.4893341	3.85051847
01-Dec-06 12:34:00	175.065475	6635.76758	84.590889	3.85115218
01-Dec-06 12:35:00	175.198059	6629.21631	84.6578903	3.8517859
01-Dec-06 12:36:00	174.601578	6598.59082	84.694252	3.85241961
01-Dec-06 12:37:00	173.834351	6595.35352	84.8482437	3.85305333
01-Dec-06 12:38:00	175.593872	6761.47754	84.981842	3.85368705
01-Dec-06 12:39:00	175.578094	6680.38623	84.5241394	3.85432053
01-Dec-06 12:40:00	175.220947	6668.94629	84.0664368	3.85495424
01-Dec-06 12:41:00	174.948273	6603.1084	83.7636108	3.85558796
01-Dec-06 12:42:00	174.358307	6590.67822	84.0664368	3.85622168
01-Dec-06 12:43:00	173.931458	6616.45557	84.5012589	3.85685539
01-Dec-06 12:44:00	173.441116	6671.01758	84.9589615	3.85748911
01-Dec-06 12:45:00	174.217834	6631.92969	85.2475967	3.85812283
01-Dec-06 12:46:00	175.613678	6629.14307	85.1331253	3.85875654
01-Dec-06 12:47:00	175.456223	6622.24951	85.287117	3.85939026
01-Dec-06 12:48:00	175.410156	6672.80225	85.4411087	3.86002398
01-Dec-06 12:49:00	175.491211	6737.35889	85.595108	3.86065769
01-Dec-06 12:50:00	175.302536	6673.64258	85.2491226	3.86129141
01-Dec-06 12:51:00	175.00853	6659.93164	84.7909012	3.86192513
01-Dec-06 12:52:00	174.967667	6645.22803	84.6839828	3.86255884
01-Dec-06 12:53:00	174.131165	6634.11768	84.6839828	3.86319256

IGCC Operations Data

Tag Name:	1pwri900	1TSYF100	1tmsti922m	1tsyai202
Tag Explanation:	Unit Load	Fuel Flow	Inlet Temp	Satuator
Tag Units:	Mwe	KCFH	°F	% H2O
01-Dec-06 12:54:00	174.578201	6625.5249	84.5952606	3.86382627
01-Dec-06 12:55:00	175.372025	6660.30371	84.7815094	3.86445999
01-Dec-06 12:56:00	176.013367	6648.59424	84.7892075	3.86509371
01-Dec-06 12:57:00	174.448975	6621.36279	84.9432068	3.86572742
01-Dec-06 12:58:00	174.090698	6699.06836	85.5052795	3.86636114
01-Dec-06 12:59:00	174.610733	6657.95117	85.4334106	3.86699462
01-Dec-06 13:00:00	174.717117	6610.52539	85.4950104	3.86762834
01-Dec-06 13:01:00	175.748611	6620.06885	85.5042191	3.86826205
01-Dec-06 13:02:00	175.213684	6601.28711	85.3000107	3.86889577
01-Dec-06 13:03:00	174.136185	6616.83936	85.0958023	3.86952949
01-Dec-06 13:04:00	174.006882	6674.3457	84.9971008	3.8701632
01-Dec-06 13:05:00	174.290543	6649.06299	84.9971008	3.87079692
01-Dec-06 13:06:00	174.758163	6623.78027	85.2948227	3.87143064
01-Dec-06 13:07:00	175.047455	6617.2915	85.3447266	3.87206435
01-Dec-06 13:08:00	174.830963	6680.33301	85.4214096	3.87269807
01-Dec-06 13:09:00	175.122986	6715.47754	85.4980927	3.87333179
01-Dec-06 13:10:00	174.658798	6638.01465	85.5747681	3.8739655
01-Dec-06 13:11:00	174.669601	6629.50977	85.5085297	3.87459922
01-Dec-06 13:12:00	174.370392	6603.40186	85.5155411	3.87523293
01-Dec-06 13:13:00	175.394821	6657.3042	85.4124603	3.87586665
01-Dec-06 13:14:00	175.693634	6671.67871	85.7191925	3.87650037
01-Dec-06 13:15:00	175.992447	6684.94141	86.0259247	3.87713408
01-Dec-06 13:16:00	176.158966	6624.24902	86.3326492	3.8777678
01-Dec-06 13:17:00	176.187775	6660.03564	86.448143	3.87840152
01-Dec-06 13:18:00	175.853073	6694.70313	85.9899139	3.879035
01-Dec-06 13:19:00	174.915909	6668.76514	85.7164993	3.87966871
01-Dec-06 13:20:00	175.416946	6595.62793	86.1822968	3.88030243

SULFURIC ACID PLANT

Ops Run 1

Start Time: 12/1/2006 9:00
 Stop Time: 12/1/2006 10:16
 Interval: 1m

PI Tag	1SRGFI487	1SRGAI446b
PI Descriptor	Acid Flow	Acid Concentration
Tag Units	Gallons	%
01-Dec-06 09:00:00	27.78502464	93.46537018
01-Dec-06 09:01:00	28.21019173	93.46440125
01-Dec-06 09:02:00	27.30363846	93.46343231
01-Dec-06 09:03:00	27.74376678	93.48878479
01-Dec-06 09:04:00	26.32045364	93.53107452
01-Dec-06 09:05:00	25.4934082	93.51403046
01-Dec-06 09:06:00	25.05070877	93.49699402
01-Dec-06 09:07:00	23.44331169	93.47994995
01-Dec-06 09:08:00	23.06603813	93.47263336
01-Dec-06 09:09:00	21.71669769	93.48336792
01-Dec-06 09:10:00	21.56954765	93.49411011
01-Dec-06 09:11:00	20.98880005	93.50484467
01-Dec-06 09:12:00	20.64504814	93.51558685
01-Dec-06 09:13:00	19.20642853	93.52632904
01-Dec-06 09:14:00	18.51779556	93.5370636
01-Dec-06 09:15:00	16.84566498	93.54780579
01-Dec-06 09:16:00	16.32238579	93.55854034
01-Dec-06 09:17:00	16.25473404	93.56928253
01-Dec-06 09:18:00	15.3859396	93.56995392
01-Dec-06 09:19:00	15.08987713	93.55193329
01-Dec-06 09:20:00	15.58015728	93.53390503
01-Dec-06 09:21:00	16.24164581	93.5158844
01-Dec-06 09:22:00	16.61151695	93.49786377
01-Dec-06 09:23:00	16.17938805	93.4932251
01-Dec-06 09:24:00	16.89535141	93.51346588
01-Dec-06 09:25:00	17.78787613	93.53369904
01-Dec-06 09:26:00	18.1586647	93.54548645
01-Dec-06 09:27:00	19.26957703	93.54159546
01-Dec-06 09:28:00	19.75726318	93.53770447
01-Dec-06 09:29:00	19.57340813	93.53381348
01-Dec-06 09:30:00	21.62596893	93.52992249
01-Dec-06 09:31:00	21.8271389	93.52603149
01-Dec-06 09:32:00	22.465168	93.51528168
01-Dec-06 09:33:00	23.99054718	93.49177551
01-Dec-06 09:34:00	24.92076683	93.46826935
01-Dec-06 09:35:00	25.34622765	93.46255493

Ops Run 1

PI Tag PI Descriptor Tag Units	1SRGFI487 Acid Flow Gallons	1SRGAI446b Acid Concentration %
01-Dec-06 09:36:00	26.06377983	93.48987579
01-Dec-06 09:37:00	27.87441063	93.47788239
01-Dec-06 09:38:00	28.12085152	93.42681885
01-Dec-06 09:39:00	28.41798973	93.43437958
01-Dec-06 09:40:00	28.63371849	93.44194031
01-Dec-06 09:41:00	28.64352798	93.44950104
01-Dec-06 09:42:00	28.61082458	93.45706177
01-Dec-06 09:43:00	28.77627182	93.4646225
01-Dec-06 09:44:00	28.40077972	93.47218323
01-Dec-06 09:45:00	28.09085274	93.47974396
01-Dec-06 09:46:00	28.31199455	93.48730469
01-Dec-06 09:47:00	28.50691032	93.49289703
01-Dec-06 09:48:00	28.59101486	93.49484253
01-Dec-06 09:49:00	28.65052223	93.4967804
01-Dec-06 09:50:00	27.66983414	93.49871826
01-Dec-06 09:51:00	27.88570786	93.50066376
01-Dec-06 09:52:00	26.84090042	93.50260162
01-Dec-06 09:53:00	26.51586342	93.50454712
01-Dec-06 09:54:00	26.07448006	93.50648499
01-Dec-06 09:55:00	25.29698753	93.50843048
01-Dec-06 09:56:00	23.51574326	93.51036835
01-Dec-06 09:57:00	22.8305912	93.51231384
01-Dec-06 09:58:00	21.59775925	93.51425171
01-Dec-06 09:59:00	23.51412964	93.5161972
01-Dec-06 10:00:00	19.68430328	93.51813507
01-Dec-06 10:01:00	18.87592697	93.52008057
01-Dec-06 10:02:00	17.57759285	93.52201843
01-Dec-06 10:03:00	12.52952671	93.52396393
01-Dec-06 10:04:00	25.03555489	93.52590179
01-Dec-06 10:05:00	18.85072708	93.52784729
01-Dec-06 10:06:00	17.41357803	93.5300293
01-Dec-06 10:07:00	17.33560181	93.5326767
01-Dec-06 10:08:00	17.02531433	93.5353241
01-Dec-06 10:09:00	16.19791603	93.5379715
01-Dec-06 10:10:00	17.89147568	93.54061127
01-Dec-06 10:11:00	16.56319237	93.54325867
01-Dec-06 10:12:00	16.99263	93.54590607
01-Dec-06 10:13:00	17.93761253	93.54855347
01-Dec-06 10:14:00	16.9590435	93.55120087
01-Dec-06 10:15:00	17.81960487	93.5430603

Ops Run 1

PI Tag	1SRGFI487	1SRGAI446b
PI Descriptor	Acid Flow	Acid Concentration
Tag Units	Gallons	%
01-Dec-06 10:16:00	17.58545113	93.51488495

Ops Run 2

Start Time: 12/1/2006 10:45
 Stop Time: 12/1/2006 11:57
 Interval: 1m

PI Tag	1SRGFI487	1SRGAI446b
PI Descriptor	Acid Flow	Acid Concentration
Tag Units	Gallons	%
01-Dec-06 10:45:00	24.81376076	93.49940491
01-Dec-06 10:46:00	22.89592934	93.50131226
01-Dec-06 10:47:00	22.39478683	93.51085663
01-Dec-06 10:48:00	19.93430901	93.52039337
01-Dec-06 10:49:00	20.27495766	93.52993011
01-Dec-06 10:50:00	19.91744614	93.53947449
01-Dec-06 10:51:00	17.54257393	93.54901123
01-Dec-06 10:52:00	15.76693058	93.55854797
01-Dec-06 10:53:00	17.40314102	93.56251526
01-Dec-06 10:54:00	17.51663208	93.55686951
01-Dec-06 10:55:00	15.8992281	93.55121613
01-Dec-06 10:56:00	16.36616135	93.54556274
01-Dec-06 10:57:00	14.41671467	93.53990936
01-Dec-06 10:58:00	15.16575336	93.53425598
01-Dec-06 10:59:00	15.83239174	93.5286026
01-Dec-06 11:00:00	17.52677345	93.52294922
01-Dec-06 11:01:00	16.08989334	93.51730347
01-Dec-06 11:02:00	16.55682564	93.51165009
01-Dec-06 11:03:00	17.40995026	93.5059967
01-Dec-06 11:04:00	18.0328064	93.50034332
01-Dec-06 11:05:00	19.1630497	93.49468994
01-Dec-06 11:06:00	19.24752808	93.48903656
01-Dec-06 11:07:00	19.30465698	93.48339081
01-Dec-06 11:08:00	21.30342293	93.47773743
01-Dec-06 11:09:00	22.13223076	93.47208405
01-Dec-06 11:10:00	23.21401215	93.46643066
01-Dec-06 11:11:00	23.57389832	93.46077728
01-Dec-06 11:12:00	24.00601196	93.45965576
01-Dec-06 11:13:00	25.48270798	93.46634674
01-Dec-06 11:14:00	26.53207397	93.47303772
01-Dec-06 11:15:00	26.79130936	93.4797287
01-Dec-06 11:16:00	27.18885994	93.48642731
01-Dec-06 11:17:00	27.77987671	93.49311829
01-Dec-06 11:18:00	28.35927582	93.49980927
01-Dec-06 11:19:00	28.644104	93.50650024
01-Dec-06 11:20:00	28.51919937	93.51319122

Ops Run 2

PI Tag PI Descriptor Tag Units	1SRGFI487 Acid Flow Gallons	1SRGAI446b Acid Concentration %
01-Dec-06 11:21:00	28.37153244	93.51651001
01-Dec-06 11:22:00	28.29162216	93.51397705
01-Dec-06 11:23:00	28.53301239	93.51145172
01-Dec-06 11:24:00	28.68195534	93.50892639
01-Dec-06 11:25:00	28.33005905	93.50640106
01-Dec-06 11:26:00	28.58103561	93.5038681
01-Dec-06 11:27:00	27.98178291	93.50134277
01-Dec-06 11:28:00	28.30842972	93.49881744
01-Dec-06 11:29:00	27.58072853	93.49629211
01-Dec-06 11:30:00	27.33546066	93.49375916
01-Dec-06 11:31:00	27.68540001	93.49123383
01-Dec-06 11:32:00	26.34355164	93.4887085
01-Dec-06 11:33:00	26.12300491	93.48618317
01-Dec-06 11:34:00	25.06778526	93.48365021
01-Dec-06 11:35:00	24.06972504	93.48112488
01-Dec-06 11:36:00	23.51172638	93.47859955
01-Dec-06 11:37:00	22.74806786	93.47607422
01-Dec-06 11:38:00	24.20674706	93.47722626
01-Dec-06 11:39:00	21.73978424	93.48474884
01-Dec-06 11:40:00	23.1600399	93.49227142
01-Dec-06 11:41:00	15.42840385	93.49978638
01-Dec-06 11:42:00	18.66775322	93.50730896
01-Dec-06 11:43:00	17.12492752	93.51483154
01-Dec-06 11:44:00	15.49215794	93.5223465
01-Dec-06 11:45:00	15.16769886	93.52954102
01-Dec-06 11:46:00	15.07560921	93.53612518
01-Dec-06 11:47:00	14.57235909	93.54271698
01-Dec-06 11:48:00	16.19573021	93.54930115
01-Dec-06 11:49:00	16.36071396	93.55588531
01-Dec-06 11:50:00	16.49975586	93.54155731
01-Dec-06 11:51:00	15.58853817	93.52974701
01-Dec-06 11:52:00	15.35196209	93.5707016
01-Dec-06 11:53:00	16.36379242	93.56061554
01-Dec-06 11:54:00	18.06073952	93.55052185
01-Dec-06 11:55:00	16.72803497	93.54043579
01-Dec-06 11:56:00	18.81069946	93.5303421
01-Dec-06 11:57:00	19.83800507	93.52025604

Ops Run 3

Start Time: 12/1/2006 12:21
 Stop Time: 12/1/2006 13:32
 Interval: 1m

PI Tag	1SRGFI487	1SRGAI446b
PI Descriptor	Acid Flow	Acid Concentration
Tag Units	Gallons	%
01-Dec-06 12:21:00	26.54945564	93.49086761
01-Dec-06 12:22:00	25.19431114	93.49350739
01-Dec-06 12:23:00	24.24565887	93.49614716
01-Dec-06 12:24:00	22.80313301	93.49803162
01-Dec-06 12:25:00	22.75828362	93.49861145
01-Dec-06 12:26:00	22.10820198	93.49919128
01-Dec-06 12:27:00	20.77284241	93.49977112
01-Dec-06 12:28:00	18.99655151	93.5063324
01-Dec-06 12:29:00	19.28838539	93.52399445
01-Dec-06 12:30:00	15.91479206	93.537323
01-Dec-06 12:31:00	16.9459362	93.54315186
01-Dec-06 12:32:00	16.83309555	93.54828644
01-Dec-06 12:33:00	16.1206665	93.55219269
01-Dec-06 12:34:00	15.37219906	93.55609894
01-Dec-06 12:35:00	15.17158985	93.56001282
01-Dec-06 12:36:00	15.81984901	93.56391907
01-Dec-06 12:37:00	15.24163055	93.55861664
01-Dec-06 12:38:00	16.76564789	93.53620148
01-Dec-06 12:39:00	17.13660049	93.51995087
01-Dec-06 12:40:00	15.7085638	93.51512909
01-Dec-06 12:41:00	15.51271057	93.51031494
01-Dec-06 12:42:00	17.26226044	93.50549316
01-Dec-06 12:43:00	17.39624405	93.50067902
01-Dec-06 12:44:00	17.804142	93.49585724
01-Dec-06 12:45:00	18.58090973	93.49103546
01-Dec-06 12:46:00	18.83090019	93.48622131
01-Dec-06 12:47:00	20.51719666	93.48139954
01-Dec-06 12:48:00	22.39820099	93.47658539
01-Dec-06 12:49:00	23.038517	93.47176361
01-Dec-06 12:50:00	24.13442993	93.44772339
01-Dec-06 12:51:00	25.30501366	93.43882751
01-Dec-06 12:52:00	26.69705772	93.48272705
01-Dec-06 12:53:00	26.84956932	93.48361969
01-Dec-06 12:54:00	28.03206253	93.48451233
01-Dec-06 12:55:00	27.90480804	93.48540497
01-Dec-06 12:56:00	28.63759232	93.48629761

Ops Run 3

PI Tag PI Descriptor Tag Units	1SRGFI487 Acid Flow Gallons	1SRGAI446b Acid Concentration %
01-Dec-06 12:57:00	28.75903893	93.48719025
01-Dec-06 12:58:00	28.92666435	93.48808289
01-Dec-06 12:59:00	28.66518211	93.48897552
01-Dec-06 13:00:00	28.90792084	93.48986816
01-Dec-06 13:01:00	28.16115189	93.4907608
01-Dec-06 13:02:00	28.71001625	93.49165344
01-Dec-06 13:03:00	28.66949844	93.51124573
01-Dec-06 13:04:00	28.29980469	93.53730011
01-Dec-06 13:05:00	28.68383217	93.51535797
01-Dec-06 13:06:00	27.99263954	93.4934082
01-Dec-06 13:07:00	27.95467758	93.47146606
01-Dec-06 13:08:00	27.81062317	93.46382904
01-Dec-06 13:09:00	26.01124954	93.4827652
01-Dec-06 13:10:00	25.93829155	93.50170135
01-Dec-06 13:11:00	25.59587479	93.48405457
01-Dec-06 13:12:00	25.18997192	93.43802643
01-Dec-06 13:13:00	24.30197716	93.45662689
01-Dec-06 13:14:00	23.38766861	93.47522736
01-Dec-06 13:15:00	22.1136837	93.49382782
01-Dec-06 13:16:00	22.16335869	93.51242828
01-Dec-06 13:17:00	29.52200317	93.53102112
01-Dec-06 13:18:00	18.22222137	93.54092407
01-Dec-06 13:19:00	17.28057098	93.53466797
01-Dec-06 13:20:00	18.38953781	93.52841187
01-Dec-06 13:21:00	17.45567131	93.52214813
01-Dec-06 13:22:00	15.32042503	93.51589203
01-Dec-06 13:23:00	16.06765747	93.51211548
01-Dec-06 13:24:00	16.5723896	93.51295471
01-Dec-06 13:25:00	15.15758228	93.51378632
01-Dec-06 13:26:00	15.86031723	93.51461792
01-Dec-06 13:27:00	15.58404827	93.51545715
01-Dec-06 13:28:00	14.35834789	93.51628876
01-Dec-06 13:29:00	16.65799332	93.51712036
01-Dec-06 13:30:00	14.79674625	93.51795959
01-Dec-06 13:31:00	20.45280075	93.5187912
01-Dec-06 13:32:00	19.95116997	93.5196228

APPENDIX H

VISIBLE EMISSIONS OBSERVATIONS

IGCC

VISIBLE EMISSION OBSERVATION

E-496 R 10/85

SOURCE NAME		SOURCE LOCATION		OBSERVATION DATE				START TIME				STOP TIME									
Polk Power Station		Blk Co FL		12/1/2006				10:10				10:40									
TYPE OF FACILITY		DISTANCE FROM OBSERVER		SKY CONDITIONS/PLUME BACKGROUND		SUN LOCATION SKETCH		AVERAGE OPACITY		WIND SPEED (EST.)		WIND DIRECTION (EST.)		OBSERVER'S NAME (PRINT)		OBSERVER'S SIGNATURE		DATE		COMMENTS	
HRSg - firing synthetic gas		~1200'		Overcast / white gray				∅		moderate ~20 mph		~ENE		R.A. McDarby		[Signature]		1-DEC-2006		sa ~7°	
SEC.	MIN	0	15	30	45	MIN	0	15	30	45	MIN	0	15	30	45	MIN	0	15	30	45	
1	∅	∅	∅	∅	∅	31															
2	∅	∅	∅	∅	∅	32															
3	∅	∅	∅	∅	∅	33															
4	∅	∅	∅	∅	∅	34															
5	∅	∅	∅	∅	∅	35															
6	∅	∅	∅	∅	∅	36															
7	∅	∅	∅	∅	∅	37															
8	∅	∅	∅	∅	∅	38															
9	∅	∅	∅	∅	∅	39															
10	∅	∅	∅	∅	∅	40															
11	∅	∅	∅	∅	∅	41															
12	∅	∅	∅	∅	∅	42															
13	∅	∅	∅	∅	∅	43															
14	∅	∅	∅	∅	∅	44															
15	∅	∅	∅	∅	∅	45															
16	∅	∅	∅	∅	∅	46															
17	∅	∅	∅	∅	∅	47															
18	∅	∅	∅	∅	∅	48															
19	∅	∅	∅	∅	∅	49															
20	∅	∅	∅	∅	∅	50															
21	∅	∅	∅	∅	∅	51															
22	∅	∅	∅	∅	∅	52															
23	∅	∅	∅	∅	∅	53															
24	∅	∅	∅	∅	∅	54															
25	∅	∅	∅	∅	∅	55															
26	∅	∅	∅	∅	∅	56															
27	∅	∅	∅	∅	∅	57															
28	∅	∅	∅	∅	∅	58															
29	∅	∅	∅	∅	∅	59															
30	∅	∅	∅	∅	∅	60															

COPY OF VISIBLE EMISSIONS CERTIFICATION CARD

re-certified 8/15/2006 ETA-Tampa

EASTERN TECHNICAL ASSOCIATES

RAY MCDARBY

met the specifications of Federal Reference Method 9 and qualifies as a visible emissions evaluator. Maximum deviation on white and black smoke did not exceed 7.5% opacity and no single error exceeding 1.5% opacity was incurred during the certification test conducted by Eastern Technical Associates of Raleigh, NC. This certificate is valid for six months from date of issue and expires on the date below

2/14/06 8/15/06 ETMPEC4

DATE OF SCHOOL EXPIRATION DATE LAST LECTURE

337141 Michael W. Sanford [Signature]

CERT NUMBER TRAINING MANAGER BEARER

SULFURIC ACID PLANT

VISIBLE EMISSION OBSERVATION

E-496 R 10/85

SOURCE NAME		SOURCE LOCATION		OBSERVATION DATE				START TIME		STOP TIME			
Polk Power Station		Polk Co. FL		12/1/2006				10:10		10:40			
TYPE OF FACILITY				SEC.				SEC.					
Sulfuric Acid Plant				MIN	0	15	30	45	MIN	0	15	30	45
DISTANCE FROM OBSERVER				1				31					
~150'				2				32					
SKY CONDITIONS/PLUME BACKGROUND				3				33					
Overcast / white & gray				4				34					
SOURCE LAYOUT SKETCH				5				35					
DRAW NORTH ARROW				6				36					
<p>X EMISSION POINT O OBSERVER'S POSITION 140° SUN LOCATION LINE SUN → WIND →</p>				7				37					
AVERAGE OPACITY				8				38					
∅				9				39					
WIND SPEED (EST.)		WIND DIRECTION (EST.)		10				40					
moderate ~20 mph		ENE		11				41					
OBSERVER'S NAME (PRINT)				12				42					
R. A. McDarby				13				43					
OBSERVER'S SIGNATURE				14				44					
<i>R.A. McDarby</i>				15				45					
DATE				16				46					
1-DEC-2006				17				47					
COMMENTS				18				48					
sa #99				19				49					
				20				50					
				21				51					
				22				52					
				23				53					
				24				54					
				25				55					
				26				56					
				27				57					
				28				58					
				29				59					
				30				60					

COPY OF VISIBLE EMISSIONS CERTIFICATION CARD

re-certified 8/15/2006 ETA-Tampa

EASTERN TECHNICAL ASSOCIATES
RAY MCDARBY

met the specifications of Federal Reference Method and qualifies as a visible emissions evaluator. Maximum deviation on white and black smoke did not exceed 7.5% opacity and no single error exceeding 1.5% opacity was incurred during the certification test conducted by Eastern Technical Associates of Raleigh, NC. This certificate is valid for six months from date of issue and expires on the date below.

2/14/06 8/15/06 JTM/PC4
DATE OF SCHOOL EXPIRATION DATE LAST LECTURE

33714 Michael W. Sanford R.A. McDarby
CERT. NUMBER TRAINING MANAGER BEARER

APPENDIX I
CHAIN OF CUSTODY

Trigon Engineering Consultants, Inc. Chain of Custody Sampler's Signature *[Signature]*

Company: TECO Laboratory: TECO No. of Containers: 8 Sampling Methods: 8
 City, State: Polk Co. Florida Project No. 0-16-06-130
 Contact: David Smith Purchase Order No. _____

Sample Description	Sample ID	Date	Time	Sample Disposition and Remarks
Unit 1 Run 1	6120-01	12/01/06		80% IPA → SO ₂ catch
Run 1	6120-02	12/01/06		3% H ₂ O ₂ → SO ₂ catch
Run 2	6120-03	12/01/06		80% IPA → SO ₂ catch
Run 2	6120-04	12/01/06		3% H ₂ O ₂ → SO ₂ catch
Run 3	6120-05	12/01/06		80% IPA → SO ₂ catch
Run 3	6120-06	12/01/06		3% H ₂ O ₂ → SO ₂ catch
Reagent Blank	6120-07	12/01/06		80% IPA blank
Reagent Blank	6120-08	12/01/06		3% H ₂ O ₂ blank

Relinquished By: <i>[Signature]</i>	Date/Time: <u>12/01/06, 1425</u>	Received By: <i>[Signature]</i>	Date/Time: <u>12-01-06, 1425</u>
Relinquished By: _____	Date/Time: <u>/</u>	Received By: _____	Date/Time: <u>/</u>
Received for Laboratory By: _____	Date/Time: <u>/</u>	Analyze for the Following Compounds: _____	
_____	Date/Time: <u>/</u>	_____	



ANALYSIS REQUEST & CHAIN OF CUSTODY

ENVIRONMENTAL SERVICES

5012 CAUSEWAY BLVD., TAMPA, FL, 33619 PHONE (813)228-4111

PROJECT REFERENCE <i>Polk Acid SAP</i>		PROJECT NO.		PROJECT LOCATION (SITE) <i>Polk</i>		REQUIRED ANALYSIS				DUE DATE <div style="border: 1px solid black; width: 100px; height: 20px;"></div>	
SAMPLER'S PRINTED NAME <i>Scott Green</i>		SAMPLER'S SIGNATURE <i>Scott Green</i>				RMB <i>H2SO4</i>				<input type="checkbox"/> EMAIL RESULTS <input type="checkbox"/> FAX RESULTS <input type="checkbox"/> MAIL RESULTS	
PO NUMBER		CONTRACT NO.		SITE							
CLIENT NAME		CLIENT PHONE		CLIENT FAX		PRESERVATIVE				NUMBER OF COOLERS SUBMITTED PER SHIPMENT	
CLIENT EMAIL		CLIENT ADDRESS									
SAMPLE ID	SAMPLE DESCRIPTION	SAMPLING		* MATRIX	NUMBER OF CONTAINERS SUBMITTED				REMARKS		
		DATE	TIME								
<i>Run I</i>	<i>SAP Acid Mist</i>	<i>12/1/06</i>	<i>10:40</i>		<i>1</i>						
<i>Run II</i>	<i>" " "</i>	<i>12/1/06</i>	<i>12:30</i>		<i>1</i>						
<i>Run III</i>	<i>" " "</i>	<i>12/1/06</i>	<i>1:30</i>		<i>1</i>						
<i>80% Blank</i>	<i>80% IPA</i>				<i>1</i>						

* GW - GROUND WATER SW - SURFACE WATER DW - DRINKING WATER WW - WASTE WATER C - COAL O - OIL SO - SOLID/SOIL SL - SLUDGE W - WASTE SAMPLE A - AIR

CONTAINERS/SEALS INTACT <input type="checkbox"/> Yes <input type="checkbox"/> No	ON ICE/ 4°C <input type="checkbox"/> Yes <input type="checkbox"/> No
---	---

SAMPLE TRANSFERS

RELINQUISHED BY:	RECEIVED BY:	DATE	TIME
PERSON'S NAME: <i>Scott Green / Scott Green</i>	PERSON'S NAME: <i>Sam Soto</i>	<i>12-1-06</i>	<i>1610</i>
FACILITY NAME:	FACILITY NAME: <i>CSWY/LAB</i>		
PERSON'S NAME:	PERSON'S NAME:		
FACILITY NAME:	FACILITY NAME:		
PERSON'S NAME:	PERSON'S NAME:		
FACILITY NAME:	FACILITY NAME:		
PERSON'S NAME:	PERSON'S NAME:		
FACILITY NAME:	FACILITY NAME:		

APPENDIX J
PROJECT PARTICIPANTS

TEST PARTICIPANTS

ENVIRONMENTAL SERVICES, AIR SERVICES GROUP

Test Team

Charles Dufeny	Environmental Technician, Test Team Lead
Scott Given	Associate Technician
Gary Barber	Associate Technician
Raymond A. McDarby	Senior Environmental Technician
David A. Smith	Coordinator, Air Services Group

TRIGON ENGINEERING CONSULTANTS, INC

Test Team

Quentin Best	Team Lead
Jamie Bell	Technician
Larry Reynolds	Technician
Ian DeVivi	Technician

Process Data

Raymond A. McDarby	Senior Environmental Technician
--------------------	---------------------------------

Fuel Analysis

Raymond A. McDarby	Senior Environmental Technician
Bret Nicholas	Senior Environmental Technician

Report Preparation

Raymond A. McDarby	Senior Environmental Technician
--------------------	---------------------------------

Quality Assurance/Quality Control Review

Raymond A. McDarby	Senior Environmental Technician
--------------------	---------------------------------

Test Coordination

David A. Smith	Coordinator, Air Services Group
Michael Perkins	Environmental Coordinator – PPS
Paul Jenkins	Program Manager – Trigon Engineering Consultants, Inc.