

*ENVIRONMENTAL AFFAIRS
AIR PROGRAMS REPORT*

PETCOKE FUEL EMISSIONS TEST

*POLK POWER STATION
UNIT NO. 1*


AIRS # 1050233

FEBRUARY 7, 2000 THRU APRIL 26, 2000

**Petcoke Fuel Emissions Test
Polk Power Station
Unit No. 1
February 7, 2000 through April 26, 2000
Sulfuric Acid Mist, Sulfur Dioxide, Opacity
Oxides of Nitrogen and Fuel Analysis**


Tampa Electric Company

May 26, 2000




REPORT CERTIFICATION

I have reviewed the test performance, the resulting calculations, and contents of this report, and verified that all project quality objectives have been met.

Date 6/7/2000 Signature 


Senior Environmental Technician
Air Services
Environmental Affairs
Tampa Electric Company

I have calculated and compiled all data in this report, and hereby certify that the test report is authentic and accurate to the best of my knowledge.

Date 6/7/00 Signature 


Test Report Author
Coordinator-Air Services
Environmental Affairs
Tampa Electric Company

The sampling and analysis performed for this report were carried out under my direction and, and I hereby certify that this test is authentic and accurate.

Date 6/7/00 Signature 

Test Team Leader
Environmental Technician
Air Services
Environmental Affairs
Tampa Electric Company

I have reviewed the testing details and results in this report, and hereby certify that the test report is authentic and accurate to the best of my knowledge.

Date 6/8/00 Signature 

Administrator-Air Programs
Environmental Affairs
Tampa Electric Company

TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE NO.</u>
1.0 INTRODUCTION	1
2.0 SOURCE DESCRIPTION	4
SAMPLING LOCATION, FIGURE 1	5
3.0 TEST PROCEDURES / SAMPLING TRAIN DIAGRAMS	6
SULFURIC ACID MIST SAMPLING TRAIN, FIGURE 2	7
INTEGRATED SAMPLING TRAIN, FIGURE 3	8
ORSAT ANALYZER, FIGURE 4	9
4.0 SUMMARY OF RESULTS	10
CEMS TEST DATA	11
STACK TEST DATA	12
FUEL ANALYSIS DATA	13
UNIT OPERATIONS SUMMARY	14
NOMENCLATURE	15

TABLE OF CONTENTS (CONT.)

APPENDICES

A. SOURCE TEST CALCULATIONS

- A-1 BASELINE SULFURIC ACID MIST CALCULATIONS
- A-2 FUEL BLEND SULFURIC ACID MIST CALCULATIONS

B. LABORATORY ANALYTICAL DATA

- B-1 BASELINE SULFURIC ACID MIST
- B-2 FUEL BLEND SULFURIC ACID MIST

C. COMBUSTION TURBINE OPERATION DATA

- C-1 BASELINE OPERATIONAL DATA
- C-2 FUEL BLEND OPERATIONAL DATA

D. CONTINUOUS EMISSION MONITORING SYSTEM DATA

- D-1 BASELINE CEMS STACK TEST LOGS
- D-2 FUEL BLEND CEMS STACK TEST LOGS
- D-3 CONTINUOUS EMISSION MONITOR RELATIVE ACCURACY
TEST AUDIT RESULTS , 1999
- D-4 CONTINUOUS EMISSION MONITOR QUALITY ASSURANCE
LINEARITY CHECKS QUARTER 1, 2000

E. FUEL ANALYSIS

- E-1 BASELINE COMPOSITE
- E-2 FUEL BLEND COMPOSITES

TABLE OF CONTENTS (CONT.)

F. FIELD DATA SHEETS

- F-1 BASELINE SULFURIC ACID DATA SHEETS
- F-2 BASELINE ORSAT DATA SHEETS
- F-3 FUEL BLEND SULFURIC ACID MIST DATA SHEETS
- F-4 FUEL BLEND ORSAT DATA SHEETS

G. SAMPLE EQUIPMENT CALIBRATIONS

- G-1 BASELINE EQUIPMENT CALIBRATIONS
- G-2 FUEL BLEND EQUIPMENT CALIBRATIONS

H. CHAIN OF CUSTODY

- H-1 BASELINE CHAIN OF CUSTODY
- H-2 FUEL BLEND CHAIN OF CUSTODY

I. PROJECT PARTICIPANTS

1.0 INTRODUCTION

The Environmental Affairs, Air Services group of Tampa Electric Company performed a series of emission tests during the Petcoke test burn on Unit No. 1 at the Polk Power Station. The emission tests were conducted to measure pollutant emissions while firing syngas that was gasified from a blend of Petcoke and coal.

The Florida Department of Environmental Protection issued a letter of authorization to Tampa Electric Company for these emission tests to be conducted at Polk Power Station Unit No. 1, (operating permit No. 1050233-001-AV, Airs # 1050233). The test burn authorization included a Baseline Test firing syngas that was gasified with 100% coal and a series of Fuel Blend Petcoke Tests (Blend Tests) firing syngas that was gasified from a fuel blend of up to 70% Petcoke.

The Baseline stack test was performed on February 7, 2000 and February 8, 2000. The Fuel Blend test of 60% Petcoke and 40% coal was performed on April 24th, 25th and 26th, 2000. Operational data during the baseline and fuel blend testing can be found in Appendix C.

Unit No. 1 is an integrated coal gasification combined cycle (IGCC) generating unit. The combustion turbine is normally fired with syngas. Nitrogen Oxides, Sulfur Dioxide and Opacity data were measured and recorded using Continuous Emission Monitoring System (CEMS) during the Baseline and Fuel Blend Tests. All emission tests were performed following the procedures and quality control guidelines given in 40 CFR 60 Appendix A -Test Methods.

The Sulfuric Acid Mist (H_2SO_4) emissions rate for the baseline test was derived from 8 test runs. The calculated average was 0.018 lbs/MMBtu. The ninth run was not completed due to turbine failure, which resulted in the unit coming off

line. The H₂SO₄ emissions rate for the blend test was derived from 9 test runs. The calculated average during the blend was 0.011 lbs/MMBtu.

The sulfur dioxide (SO₂) emissions rate for the baseline test was derived from a 2-day daily CEMS average. The calculated average during the baseline test was 0.176 lbs/MMBtu. The sulfur dioxide (SO₂) emissions rate for the blend test was derived from a 3-day daily CEMS average during the blend test period. The calculated average during the blend was 0.133 lbs/MMBtu.

The nitrogen oxides (NO_x) emissions rate for the baseline test was derived from a 2-day daily CEMS average. The calculated average during the baseline test was 0.093 lbs/MMBtu. The nitrogen oxides (NO_x) emissions rate for the blend test was derived from a 3-day daily CEMS average during the blend test period. The calculated average during the blend was 0.097 lbs/MMBtu.

The SO₂ and NO_x averages were calculated on a daily CEMS average for each test period. Due to the short run time period on the Petcoke blend, a 30-day rolling average comparison in lbs/hr was not possible.

The average opacity for the baseline test was 1.3% and the blend test was 4.4%. The FDEP allowable rate for opacity is 20%. Increases in opacity from the baseline test period to the fuel blend test period are primarily caused by lense fouling on the opacity monitor as well as misalignment of the monitor itself. Differences in ambient temperatures cause the stack metal to expand and contract which, ultimately, results in an inelastic structural distortion in the brackets that fix the monitor to the stack. This distortion causes monitor misalignment which, in turn, results in opacity measurements that trend upward with time and can only be corrected through monitor realignment. In correspondence dated September 15, 1999, to Dr. Richard D. Garrity of FDEP, Tampa Electric Company explained this phenomenon to FDEP. To address this issue, The Company realigns the monitor whenever Polk Unit 1 is offline for a

maintenance outage greater than 24 hours in duration.

Section 2.0 presents a brief source description and diagram of the sample point locations.

Section 3.0 outlines the procedures and test methods used along with diagrams of sampling trains used.

Section 4.0 presents the test results and comparison tables.

All supporting documentation, field data sheets, laboratory data, sample calculations, calibration data, and quality assurance/quality control measures are included in the appendices to this report.

2.0 SOURCE DESCRIPTION

Polk Power Station is located at County Road 630 approximately 13 miles southwest of Bartow in Polk County, Florida. Unit No. 1 is an integrated coal gasification combined cycle (IGCC) generating unit. It's net capacity is 192 MW when fired with Syngas fuel. The source sampling location consists of a circular stack 19 ft. in diameter with four sample ports located 90° apart on the stack circumference. A diagram of the stack sampling location is included in Figure 1 along with other pertinent information on the test site.




FIGURE 1

3.0 TEST PROCEDURES/SAMPLING TRAIN DIAGRAMS

Sulfuric Acid Mist sampling was performed according to U.S. EPA Method 8 "Determination of Sulfuric Acid Mist and Sulfur Dioxide Emissions from Stationary Sources". Sampling was performed using the equipment depicted on Figure 2.

Sulfur Dioxide (SO₂), Nitrogen Oxides (NO_x) and Opacity emissions were taken from the Continuous Emissions Monitoring System (CEMS) readings.

Gas sampling and analysis was performed according to U.S. EPA Method 3-B "Gas Analysis for Determination of Emission Rate Correction Factor, or Excess Air ". Sampling was performed using the equipment depicted in Figure 3 and 4.




FIGURE 2
 SULFURIC ACID MIST SAMPLING TRAIN
 USEPA METHOD 8




FIGURE 3
 INTEGRATED GAS SAMPLING TRAIN
 USEPA METHOD 3-B






FIGURE 4
 ORSAT ANALYZER
 USEPA METHOD 3-B



4.0 SUMMARY OF RESULTS

Table 1 presents the Continuous Emission Monitoring System (CEMS) data from the Baseline Test and the Fuel Blend Test. Data is presented comparing SO₂, NO_x and Opacity during Baseline and Fuel Blend Tests.

TABLE 1 POLK POWER STATION UNIT NO. 1 CONTINUOUS EMISSION MONITORING SYSTEM DATA			
PARAMETER	BASELINE	FUEL BLEND	EMISSION RATE
SO ₂	0.176	0.133	lbs/MMBtu
NO _x	0.093	0.097	lbs/MMBtu
Opacity	1.3	4.4	%

Table 2 presents stack test data from the Baseline Test and the Fuel Blend Test comparing Sulfuric Acid Mist test levels.

TABLE 2 POLK POWER STATION UNIT NO. 1 STACK TEST DATA			
PARAMETER	BASELINE	FUEL BLEND	EMISSION RATE
H ₂ SO ₄	0.018	0.011	lbs/MMBtu

Table 3 represents Fuel Analysis data from Appendix E for Baseline vs. Blend tests.

TABLE 3 POLK POWER STATION UNIT NO. 1 FUEL ANALYSIS DATA			
PARAMETER	Coal Baseline	40% Coal 60% Petcoke Blend	Units
Total Moisture	12.9	6.98	%
Ash, as Received	8.97	3.90	%
BTU, as Received	11313	13535	Btu/Lbs
Sulfur, as Received	2.88	2.88	%
BTU, Moisture-Ash Free, Calc	14479	15187	Btu/Lb
Pounds SO2/Million BTU, Coal	4.84	4.05	Lb/MMBtu
Ash, Dry Basis	10.3	4.19	%
BTU, Dry Basis	12988	14551	Btu/Lb
Sulfur, Dry Basis	3.31	3.10	%
Carbon, as Received	63.16	77.51	%
Hydrogen, as Received	4.33	4.14	%
Nitrogen, as Received	1.39	1.82	%
Oxygen, as Received (Calculated)	6.27	2.69	%
Carbon, Dry Basis	72.51	83.33	%
Hydrogen, Dry Basis	4.97	4.45	%
Nitrogen, Dry Basis	1.60	1.96	%
Oxygen, Dry Basis (Calculated)	7.19	2.88	%
Chlorine by Bomb/IC, as Received	0.10	0.08	%
Chlorine by Bomb/IC, Dry Basis	0.12	0.09	%
Volatiles, Dry Basis	39.05	23.60	%
Volatiles, as Received	34.01	21.95	%

UNIT OPERATIONS SUMMARY

Fuel sample composites were taken for coal and Petcoke/coal blends during barge loading prior to leaving the port. A certified laboratory performed all analysis and details are included in Appendix E.

Operational data during the baseline and fuel blend testing can be found in Appendix C.

SOURCE SAMPLING NOMENCLATURE

A	=	Absorbance of sample.
A_n	=	Cross-sectional area of nozzle, m ² (ft ²).
A_s	=	Cross-sectional area of stack, m ² (ft ²).
B_{ws}	=	Water vapor in the gas stream, proportion by volume.
C	=	Concentration of particulate matter, (lbs/dscf), Method 5,17.
C	=	Concentration of NO _x , as NO ₂ , basis, corrected to standard conditions, mg/dscm (lbs/dscf), Method 7.
C_a	=	Concentration of acetone blank residue, mg/g.
CH ₂ SO ₄	=	Sulfuric acid (including SO ₃) concentration, g/dscm (lbs/dscf).
C_p	=	Pitot tube coefficient, dimensionless.
c_s	=	Concentration of stack gas particulates, dry basis corrected to standard conditions, g/dscm (lbs/dscf).
CSO ₂	=	Sulfur dioxide concentration, mg/dscm (lbs/dscf).
E	=	Pollutant emissions, lbs/10 ⁶ Btu.
EM	=	Particulate emission rate, lbs/hr.
F	=	Factor ratio of generated flue gases to calorific value of fuel, Method 5,17.
F	=	Dilution factor (i.e., 25/5, 25/10, etc.) required only if sample dilution was needed to reduce the absorbance to the range of calibration, Method 7.
FDA	=	Fraction of dry air.
I	=	Percent of isokinetic sampling, %.
K_c	=	Spectrophotometer calibration factor.
K_p	=	Pitot tube constant,

$$34.97m / sec \left[\frac{(g / g - mole)(mmHg)}{(^{\circ}K)(mmH20)} \right]^{1/2}$$

Metric

$$85.49 \text{ ft} / \text{sec} \left[\frac{(\text{lb} / \text{lb} - \text{mole})(\text{in} \text{ Hg})}{(\text{° K})(\text{mmH}_2\text{O})} \right]^{1/2}$$

English

- L_a = Maximum acceptable leakage rate for either a pretest leak check or a leak check following a component change; equal to 0.00057 m^3/min (0.02 ft^3/min) or 4% of the average sampling rate, whichever is less.
- L_i = Individual leakage rate observed during the leak check conducted prior to the "ith" component change ($i = 1, 2, 3, \dots, n$), m^3/min (ft^3/min).
- L_p = Leakage rate observed during the post test leak check, m^3/min (ft^3/min).
- m = Mass of NO_x as NO_2 in gas sample, :g.
- m_a = Mass of acetone residue after evaporation, mg.
- M_d = Molecular weight of stack gas, dry basis, g/g-mole (lb/lb-mole).
- m_f = Filter weight gain, mg.
- m_n = Total amount of particulate collected, mg.
- M_s = Molecular weight of stack gas, wet basis, g/g-mole (lb/lb-mole), or $M_d(1 - B_{ws}) = 18.0 B_{ws}$.
- M_w = Molecular weight of water, 18.0 g/g-mole (18.0 lb/lb-mole).
- N = Normality of $\text{Ba}(\text{ClO}_4)_2 \cdot 3\text{H}_2\text{O}$ titrant, g-eq/l.
- N = Normality of barium perchlorate titrant, meq/ml.
- P_a = Density of acetone, mg/ml (see bottle label).
- P_{bar} = Barometric pressure at sampling site, mm Hg (in. Hg).
- P_f = Final absolute pressure of flask, mm Hg (in. Hg).
- P_g = Stack static pressure, mm Hg (in. Hg).
- P_i = Initial absolute pressure of flask, mm Hg (in. Hg).
- P_s = Absolute stack pressure, 760 mm Hg (29.92 in. Hg).
- P_w = Density of water, 0.9982 g/ml (0.0022 lb/ml).
- Q_s = Volumetric flow rate, actual cubic feet per min, acf/min.
- Q_{std} = Dry volumetric stack gas flow rate corrected to standard conditions dsm^3/hr (dscf/hr).
- R = Ideal gas constant, 0.06236 (mm Hg - m^3)/(EK - g - mole) for metric units and 21.85 (in. Hg - ft^3)(ER - lb - mole) for English units.

S.V.P.	=	Saturated vapor pressure of water at average stack temperature mm Hg (in. Hg).
T_f	=	Final absolute temperature of flask, K (ER).
T_i	=	Initial absolute temperature of flask, K (ER).
T_m	=	Absolute average dry gas meter temperature, K (ER).
t_s	=	Stack temperature, EC (EF).
T_s	=	Absolute stack temperature, K (ER), or $273 + t_s$ for metric system or $460 + t_s$ for English system.
T_{std}	=	Standard absolute temperature, 293K (528ER).
V_a	=	Volume of acetone blank, ml, (Method 5,17).
V_a	=	Volume of sample aliquot titrated, ml, (Method 6).
V_a	=	Volume of absorbing solution, 25 ml, (Method 7).
V_a	=	Volume of sample aliquot titrated, 100 ml for H_2SO_4 and 10ml for SO_2 (Method 8).
V_{aw}	=	Volume of acetone used in wash, ml.
V_f	=	Final volume of condenser water, ml.
V_f	=	Volume of flask and valve, ml.
V_i	=	Initial volume of condenser water, ml.
V_{ic}	=	Total volumes of liquid and silica gel collected in impingers, ml.
V_m	=	Dry gas volume measured by dry gas meter, scm (dcf).
$V_{m(std)}$	=	Volume of gas sample measured by the dry gas meter and corrected to standard condition, dscm (dscf).
v_s	=	Average stack gas velocity calculated by Method 2, m/sec (ft/sec).
V_{sc}	=	Sample volume at standard conditions (dry basis), ml.
V_{soln}	=	Total volume of solution in which the sulfur dioxide sample is contained, 100 ml, (method 6).
V_{soln}	=	Total volume of solution in which the H_2SO_4 or SO_2 sample is contained, 250 ml or 1000 ml, respectively, (Method 8).
V_t	=	Volume of $Ba(ClO_4)_2 \cdot 3H_2O$ titrant used for the sample, ml, (Method 8).
V_t	=	Volume of barium perchlorate titrant used for the sample (average of replicate titrations), ml, (Method 6).
V_{tb}	=	Volume of barium perchlorate titrant used for the blank, ml.
$V_{w(std)}$	=	Volume of water vapor in the gas sample, corrected to standard conditions, scm (scf).

$V_{wc(std)}$	=	Volume of condensed water vapor, corrected to standard conditions, $sm^3(scf)$.
$V_{wsg(std)}$	=	Volume of water vapor collected in silica gel, corrected to standard conditions, $sm^3(scf)$.
W_a	=	Weight of acetone wash residue, mg.
W_f	=	Final weight of silica gel or silica gel plus impinger, g.
W_i	=	Initial weight of silica gel or silica gel plus impinger, g.
Y	=	Dry gas meter calibration factor.
$)H$	=	Average pressure differential across the orifice meter, mm (in) H_2O .
$)H@$	=	Measurement of pressure differential across the orifice meter, mm (in.) H_2O .
$)p$	=	Average velocity head of stack gas, mm (in.) H_2O .
$)V_m$	=	Incremental volume measured by dry gas meter at each traverse point, $dm^3(dcf)$.
%CO	=	Percent CO by volume (dry basis), average of three CO values.
%CO ₂	=	Percent CO ₂ by volume (dry basis), average of three analyses.
%EA	=	Percent excess air, %.
%N ₂	=	Percent N ₂ by volume (dry basis), average of three N ₂ values.
%O ₂	=	Percent O ₂ by volume (dry basis), average of three O ₂ values.
0.262	=	Ratio of O ₂ to N ₂ in air, v/v.
2	=	50/25, the aliquot factor, (Method 7).
13.6	=	Specific gravity of mercury (Hg).
18.0	=	Molecular weight of water, g/g-mole (lb/lb-mole).
32.03	=	Equivalent weight of sulfur dioxide.
60	=	Seconds per minute (sec/min).
100	=	Conversion to percent, %.
3600	=	Conversion factor, (sec/hr).
2	=	Total sampling time, min.
2_1	=	Interval of sampling time from beginning of a run until first component change, min.
2_i	=	Interval of sampling time between two successive component changes, beginning with first and second changes, min.
2_p	=	Interval of sampling time from final (nth) component change until the end of the sampling run, min.

APPENDIX A

SOURCE TEST CALCULATIONS

A-1 BASELINE SULFURIC ACID MIST CALCULATIONS

A-2 FUEL BLEND SULFURIC ACID MIST CALCULATIONS

A-1 BASELINE SULFURIC ACID MIST CALCULATIONS



40 CFR 60, Appendix A - Test Methods
Method 8 Test Calculations
Test Summary

Plant: Polk Power Station
Date: 02/07/00 -02/08/00
Sampling Location: Stack
Operating Conditions: Baseload

	Run #1	Run #2	Run #3	Run #4	Run #5	Run #6	Run #7	Run #8	Average
Gas Flow Rate									
acfm	1366047.5	1374893.7	1370300.5	1370300.5	1355840.5	1360433.6	1351247.3	1364006.1	1364133.7
dscfm	866391.5	864442.5	865226.9	861984.7	850867.9	853857.7	850877.5	855426.6	858634.4
Average Stack Temperature, °F	335.8	334.7	333.0	331.3	335.7	335.6	336.0	336.0	334.8
% Isokinetic	98.1	100.1	99.9	101.5	103.5	102.2	101.4	100.2	100.9
Moisture, %H2O	4.6	5.4	5.2	5.6	5.3	5.3	5.1	5.2	5.2
Sampled Volume, dscf	39.622	40.351	40.317	40.788	41.038	40.720	40.251	39.976	40.383
Condensate Volume, ml	40.6	49.1	46.8	51.4	49.2	48.3	46.0	46.4	47.2
Meter Temperature, °F	83.6	83.5	82.9	73.5	61.4	66.6	75.0	81.0	75.9
$C_{H_2SO_4}$, lb/dscf	5.172E-07	6.034E-07	5.707E-07	7.124E-07	4.759E-07	5.913E-07	6.315E-07	7.295E-07	6.0399E-07
$E_{H_2SO_4} = C_{H_2SO_4} \times F\text{-factor}$, lbs/MMBtu	0.015	0.018	0.017	0.021	0.014	0.017	0.018	0.021	0.018

F-factor is calculated from flow data during testing and DCS data Heat Input on a run/run basis.

40 CFR 60, Appendix A - Test Methods
Method 8 Test Calculations

Run Number 1

Plant: Polk Power Station
Date: 02/07/2000
Sampling Location: Stack
Operating Conditions: Baseload

Sample Time, θ :	60 minutes	Nozzle Diameter, D_n :	0.201 inches
Barometric Pressure, P_b :	30.05 " Hg	Nozzle Area, A_n :	0.0002204 ft. ²
Stack Pressure, P_s :	29.98 " Hg	Average Orifice Meter, ΔH :	1.436 " H ₂ O
Effective Stack Area, A_s :	283.53 ft. ²	Sample Volume, V_m :	40.924 ft. ³
Pitot Coefficient, C_p :	0.84 dimensionless	Average Meter Temp., T_m :	83.6 °F
Gas Analysis:	8.0 % CO ₂	Average Stack Temp., T_s :	335.8 °F
	11.8 % O ₂	Average $\sqrt{\Delta p}$:	1.173 " H ₂ O
	0.0 % CO	Condensate Volume, V_{lc} :	40.6 ml
	80.2 % N ₂	Meter Box Y:	0.989 dimensionless

Data Calculated from Source Measurements:

$V_{w(std)} = 4.714E-02 \times V_{lc}$	1.914 scf
$V_{m(std)} = 17.647 \times V_m \times Y \times (P_b + (\Delta H / 13.6)) / (T_m + 460)$	39.622 dscf
$B_{ws} = V_{w(std)} / (V_{m(std)} + V_{w(std)})$	0.046 %
$FDA = 1.0 - B_{ws}$	0.954 %
$M_d = (0.44 \times \%CO_2) + (0.32 \times \%O_2) + (0.28 \times (\%N_2 + \%CO))$	29.75 lb/lb mole
$M_s = (M_d \times FDA) + (18.0 \times B_{ws})$	29.21 lb/lb mole
$v_s = 85.49 \times C_p \times (\sqrt{\Delta p}) \times (\sqrt{T_s + 460}) / (M_s \times P_s)$	80.3 ft/second
$Q_s = v_s \times A_s \times 60$	1366047.5 acf/minute
$Q_{s(std)} = Q_s \times FDA \times (528 / (T_s + 460)) \times (P_s / 29.92)$	866391.5 dscf/minute
$I = (T_s + 460) \times ((2.67E-03 \times V_{lc}) + (V_{m(std)} / 17.647)) \times 100 / (\theta \times P_s \times A_n \times v_s \times 60)$	98.1 %
Calculated F-factor = $Q_{s(std)} / \text{Heat Input}$	29452.40 dscf/MMBtu

Data from Laboratory Analysis:

Normality of Barium Perchlorate titrant, N	0.0099 meq/ml
Volume Titrant Blank, V_{tb}	0.05 ml
Volume Titrant Sample, V_t	3.88 ml
Volume of Sample Aliquot, V_a	100 ml
Total Volume of Solution, V_{soln}	500 ml

Calculated Data from Laboratory Analysis:

$C_{H_2SO_4} = 1.081E-04 \times (N \times (V_t - V_{tb}) \times (V_{soln} / V_a)) / V_{m(std)}$	5.172E-07 lb/dscf
$E_{H_2SO_4} = C_{H_2SO_4} \times \text{F-factor}$	0.015 lb/MMBtu

40 CFR 60, Appendix A - Test Methods

Method 8 Test Calculations

Run Number 2

Plant: Polk Power Station
Date: 02/07/2000
Sampling Location: Stack
Operating Conditions: Baseload

Sample Time, θ :	60 minutes	Nozzle Diameter, D_n :	0.201 inches
Barometric Pressure, P_b :	30.00 " Hg	Nozzle Area, A_n :	0.0002204 ft. ²
Stack Pressure, P_s :	29.93 " Hg	Average Orifice Meter, ΔH :	1.468 " H ₂ O
Effective Stack Area, A_s :	283.53 ft. ²	Sample Volume, V_m :	41.736 ft. ³
Pitot Coefficient, C_p :	0.84 dimensionless	Average Meter Temp., T_m :	83.5 °F
Gas Analysis:	8.2 % CO ₂	Average Stack Temp., T_s :	334.7 °F
	11.8 % O ₂	Average $\sqrt{\Delta p}$:	1.179 " H ₂ O
	0.0 % CO	Condensate Volume, V_{lc} :	49.1 ml
	80.0 % N ₂	Meter Box Y:	0.989 dimensionless

Data Calculated from Source Measurements:

$V_{w(std)} = 4.714E-02 \times V_{lc}$	2.315 scf
$V_{m(std)} = 17.647 \times V_m \times Y \times (P_b + (\Delta H / 13.6)) / (T_m + 460)$	40.351 dscf
$B_{ws} = V_{w(std)} / (V_{m(std)} + V_{w(std)})$	0.054 %
$FDA = 1.0 - B_{ws}$	0.946 %
$M_d = (0.44 \times \%CO_2) + (0.32 \times \%O_2) + (0.28 \times (\%N_2 + \%CO))$	29.78 lb/lb mole
$M_s = (M_d \times FDA) + (18.0 \times B_{ws})$	29.14 lb/lb mole
$v_s = 85.49 \times C_p \times (\sqrt{\Delta p}) \times (\sqrt{T_s + 460}) / (M_s \times P_s)$	80.82 ft/second
$Q_s = v_s \times A_s \times 60$	1374893.7 acf/minute
$Q_{s(std)} = Q_s \times FDA \times (528 / (T_s + 460)) \times (P_s / 29.92)$	864442.5 dscf/minute
$I = (T_s + 460) \times ((2.67E-03 \times V_{lc}) + (V_{m(std)} / 17.647)) \times 100 / (\theta \times P_s \times A_n \times v_s \times 60)$	100.1 %
Calculated F-factor = $Q_{s(std)} / \text{Heat Input}$	29386.15 dscf/MMBtu

Data from Laboratory Analysis:

Normality of Barium Perchlorate titrant, N	0.0099 meq/ml
Volume Titrant Blank, V_{tb}	0.05 ml
Volume Titrant Sample, V_t	4.6 ml
Volume of Sample Aliquot, V_a	100 ml
Total Volume of Solution, V_{soln}	500 ml

Calculated Data from Laboratory Analysis:

$C_{H_2SO_4} = 1.081E-04 \times (N \times (V_t - V_{tb}) \times (V_{soln} / V_a)) / V_{m(std)}$	6.034E-07 lb/dscf
$E_{H_2SO_4} = C_{H_2SO_4} \times \text{F-factor}$	0.018 lb/MMBtu

40 CFR 60, Appendix A - Test Methods

Method 8 Test Calculations

Run Number 3

Plant: Polk Power Station
Date: 02/07/2000
Sampling Location: Stack
Operating Conditions: Baseload

Sample Time, θ :	60 minutes	Nozzle Diameter, D_n :	0.201 inches
Barometric Pressure, P_b :	30.00 " Hg	Nozzle Area, A_n :	0.0002204 ft. ²
Stack Pressure, P_s :	29.93 " Hg	Average Orifice Meter, ΔH :	1.46 " H ₂ O
Effective Stack Area, A_s :	283.53 ft. ²	Sample Volume, V_m :	41.655 ft. ³
Pitot Coefficient, C_p :	0.84 dimensionless	Average Meter Temp., T_m :	82.9 °F
Gas Analysis:	8.2 % CO ₂	Average Stack Temp., T_s :	333 °F
	11.8 % O ₂	Average $\sqrt{\Delta p}$:	1.177 " H ₂ O
	0.0 % CO	Condensate Volume, V_{lc} :	46.8 ml
	80.0 % N ₂	Meter Box Y:	0.989 dimensionless

Data Calculated from Source Measurements:

$V_{w(std)} = 4.714E-02 \times V_{lc}$	2.206 scf
$V_{m(std)} = 17.647 \times V_m \times Y \times (P_b + (\Delta H / 13.6)) / (T_m + 460)$	40.317 dscf
$B_{ws} = V_{w(std)} / (V_{m(std)} + V_{w(std)})$	0.052 %
$FDA = 1.0 - B_{ws}$	0.948 %
$M_d = (0.44 \times \%CO_2) + (0.32 \times \%O_2) + (0.28 \times (\%N_2 + \%CO))$	29.78 lb/lb mole
$M_s = (M_d \times FDA) + (18.0 \times B_{ws})$	29.17 lb/lb mole
$v_s = 85.49 \times C_p \times (\sqrt{\Delta p}) \times (\sqrt{T_s + 460}) / (M_s \times P_s)$	80.55 ft/second
$Q_s = v_s \times A_s \times 60$	1370300.5 acf/minute
$Q_{s(std)} = Q_s \times FDA \times (528 / (T_s + 460)) \times (P_s / 29.92)$	865226.9 dscf/minute
$l = (T_s + 460) \times ((2.67E-03 \times V_{lc}) + (V_{m(std)} / 17.647)) \times 100 / (\theta \times P_s \times A_n \times v_s \times 60)$	99.9 %
Calculated F-factor = $Q_{s(std)} / \text{Heat Input}$	29412.81 dscf/MMBtu

Data from Laboratory Analysis:

Normality of Barium Perchlorate titrant, N	0.0099 meq/ml
Volume Titrant Blank, V_{tb}	0.05 ml
Volume Titrant Sample, V_t	4.35 ml
Volume of Sample Aliquot, V_a	100 ml
Total Volume of Solution, V_{soln}	500 ml

Calculated Data from Laboratory Analysis:

$C_{H_2SO_4} = 1.081E-04 \times (N \times (V_t - V_{tb}) \times (V_{soln} / V_a)) / V_{m(std)}$	5.707E-07 lb/dscf
$E_{H_2SO_4} = C_{H_2SO_4} \times \text{F-factor}$	0.017 lb/MMBtu

40 CFR 60, Appendix A - Test Methods
Method 8 Test Calculations

Run Number 4

Plant: Polk Power Station
Date: 02/07/2000
Sampling Location: Stack
Operating Conditions: Baseload

Sample Time, θ :	60 minutes	Nozzle Diameter, D_n :	0.201 inches
Barometric Pressure, P_b :	29.95 " Hg	Nozzle Area, A_n :	0.0002204 ft. ²
Stack Pressure, P_s :	29.88 " Hg	Average Orifice Meter, ΔH :	1.445 " H ₂ O
Effective Stack Area, A_s :	283.53 ft. ²	Sample Volume, V_m :	41.483 ft. ³
Pitot Coefficient, C_p :	0.84 dimensionless	Average Meter Temp., T_m :	73.5 °F
Gas Analysis:	8.4 % CO ₂	Average Stack Temp., T_s :	331.3 °F
	11.8 % O ₂	Average $\sqrt{\Delta p}$:	1.177 " H ₂ O
	0.0 % CO	Condensate Volume, V_{lc} :	51.4 ml
	79.8 % N ₂	Meter Box Y:	0.989 dimensionless

Data Calculated from Source Measurements:

$V_{w(std)} = 4.714E-02 \times V_{lc}$	2.423 scf
$V_{m(std)} = 17.647 \times V_m \times Y \times (P_b + (\Delta H / 13.6)) / (T_m + 460)$	40.788 dscf
$B_{ws} = V_{w(std)} / (V_{m(std)} + V_{w(std)})$	0.056 %
$FDA = 1.0 - B_{ws}$	0.944 %
$M_d = (0.44 \times \%CO_2) + (0.32 \times \%O_2) + (0.28 \times (\%N_2 + \%CO))$	29.82 lb/lb mole
$M_s = (M_d \times FDA) + (18.0 \times B_{ws})$	29.16 lb/lb mole
$v_s = 85.49 \times C_p \times (\sqrt{\Delta p}) \times (\sqrt{T_s + 460}) / (M_s \times P_s)$	80.55 ft/second
$Q_s = v_s \times A_s \times 60$	1370300.5 acf/minute
$Q_{s(std)} = Q_s \times FDA \times (528 / (T_s + 460)) \times (P_s / 29.92)$	861984.7 dscf/minute
$I = (T_s + 460) \times ((2.67E-03 \times V_{lc}) + (V_{m(std)} / 17.647)) \times 100 / (\theta \times P_s \times A_n \times v_s \times 60)$	101.5 %
Calculated F-factor = $Q_{s(std)} / \text{Heat Input}$	29302.60 dscf/MMBtu

Data from Laboratory Analysis:

Normality of Barium Perchlorate titrant, N	0.0099 meq/ml
Volume Titrant Blank, V_{tb}	0.05 ml
Volume Titrant Sample, V_t	5.48 ml
Volume of Sample Aliquot, V_a	100 ml
Total Volume of Solution, V_{soln}	500 ml

Calculated Data from Laboratory Analysis:

$C_{H_2SO_4} = 1.081E-04 \times (N \times (V_t - V_{tb}) \times (V_{soln} / V_a)) / V_{m(std)}$	7.124E-07 lb/dscf
$E_{H_2SO_4} = C_{H_2SO_4} \times \text{F-factor}$	0.021 lb/MMBtu

40 CFR 60, Appendix A - Test Methods

Method 8 Test Calculations

Run Number 5

Plant: Polk Power Station
Date: 02/08/2000
Sampling Location: Stack
Operating Conditions: Baseload

Sample Time, θ :	60 minutes	Nozzle Diameter, D_n :	0.201 inches
Barometric Pressure, P_b :	29.95 " Hg	Nozzle Area, A_n :	0.0002204 ft. ²
Stack Pressure, P_s :	29.88 " Hg	Average Orifice Meter, ΔH :	1.38 " H ₂ O
Effective Stack Area, A_s :	283.53 ft. ²	Sample Volume, V_m :	40.797 ft. ³
Pitot Coefficient, C_p :	0.84 dimensionless	Average Meter Temp., T_m :	61.4 °F
Gas Analysis:	8.0 % CO ₂	Average Stack Temp., T_s :	335.7 °F
	12.0 % O ₂	Average $\sqrt{\Delta p}$:	1.161 " H ₂ O
	0.0 % CO	Condensate Volume, V_{lc} :	49.2 ml
	80.0 % N ₂	Meter Box Y:	0.989 dimensionless

Data Calculated from Source Measurements:

$V_{w(std)} = 4.714E-02 \times V_{lc}$	2.319 scf
$V_{m(std)} = 17.647 \times V_m \times Y \times (P_b + (\Delta H / 13.6)) / (T_m + 460)$	41.038 dscf
$B_{ws} = V_{w(std)} / (V_{m(std)} + V_{w(std)})$	0.053 %
$FDA = 1.0 - B_{ws}$	0.947 %
$M_d = (0.44 \times \%CO_2) + (0.32 \times \%O_2) + (0.28 \times (\%N_2 + \%CO))$	29.76 lb/lb mole
$M_s = (M_d \times FDA) + (18.0 \times B_{ws})$	29.14 lb/lb mole
$v_s = 85.49 \times C_p \times (\sqrt{\Delta p}) \times (\sqrt{T_s + 460}) / (M_s \times P_s)$	79.7 ft/second
$Q_s = v_s \times A_s \times 60$	1355840.5 acf/minute
$Q_{s(std)} = Q_s \times FDA \times (528 / (T_s + 460)) \times (P_s / 29.92)$	850867.9 dscf/minute
$I = (T_s + 460) \times ((2.67E-03 \times V_{lc}) + (V_{m(std)} / 17.647)) \times 100 / (\theta \times P_s \times A_n \times v_s \times 60)$	103.5 %
Calculated F-factor = $Q_{s(std)} / \text{Heat Input}$	28924.69 dscf/MMBtu

Data from Laboratory Analysis:

Normality of Barium Perchlorate titrant, N	0.0099 meq/ml
Volume Titrant Blank, V_{tb}	0.05 ml
Volume Titrant Sample, V_t	3.7 ml
Volume of Sample Aliquot, V_a	100 ml
Total Volume of Solution, V_{soln}	500 ml

Calculated Data from Laboratory Analysis:

$C_{H_2SO_4} = 1.081E-04 \times (N \times (V_t - V_{tb}) \times (V_{soln} / V_a)) / V_{m(std)}$	4.759E-07 lb/dscf
$E_{H_2SO_4} = C_{H_2SO_4} \times \text{F-factor}$	0.014 lb/MMBtu

40 CFR 60, Appendix A - Test Methods
Method 8 Test Calculations

Run Number 6

Plant: Polk Power Station
Date: 02/08/2000
Sampling Location: Stack
Operating Conditions: Baseload

Sample Time, θ :	60 minutes	Nozzle Diameter, D_n :	0.201 inches
Barometric Pressure, P_b :	29.95 " Hg	Nozzle Area, A_n :	0.0002204 ft. ²
Stack Pressure, P_s :	29.88 " Hg	Average Orifice Meter, ΔH :	1.388 " H ₂ O
Effective Stack Area, A_s :	283.53 ft. ²	Sample Volume, V_m :	40.883 ft. ³
Pitot Coefficient, C_p :	0.84 dimensionless	Average Meter Temp., T_m :	66.6 °F
Gas Analysis:	8.0 % CO ₂	Average Stack Temp., T_s :	335.6 °F
	12.0 % O ₂	Average $\sqrt{\Delta p}$:	1.165 " H ₂ O
	0.0 % CO	Condensate Volume, V_{lc} :	48.3 ml
	80.0 % N ₂	Meter Box Y:	0.989 dimensionless

Data Calculated from Source Measurements:

$V_{w(std)} = 4.714E-02 \times V_{lc}$	2.277 scf
$V_{m(std)} = 17.647 \times V_m \times Y \times (P_b + (\Delta H / 13.6)) / (T_m + 460)$	40.72 dscf
$B_{ws} = V_{w(std)} / (V_{m(std)} + V_{w(std)})$	0.053 %
$FDA = 1.0 - B_{ws}$	0.947 %
$M_d = (0.44 \times \%CO_2) + (0.32 \times \%O_2) + (0.28 \times (\%N_2 + \%CO))$	29.76 lb/lb mole
$M_s = (M_d \times FDA) + (18.0 \times B_{ws})$	29.14 lb/lb mole
$v_s = 85.49 \times C_p \times (\sqrt{\Delta p}) \times (\sqrt{(T_s + 460)}) / (M_s \times P_s)$	79.97 ft/second
$Q_s = v_s \times A_s \times 60$	1360433.6 acf/minute
$Q_{s(std)} = Q_s \times FDA \times (528 / (T_s + 460)) \times (P_s / 29.92)$	853857.7 dscf/minute
$I = (T_s + 460) \times ((2.67E-03 \times V_{lc}) + (V_{m(std)} / 17.647)) \times 100 / (\theta \times P_s \times A_n \times v_s \times 60)$	102.2 %
Calculated F-factor = $Q_{s(std)} / \text{Heat Input}$	29026.32 dscf/MMBtu

Data from Laboratory Analysis:

Normality of Barium Perchlorate titrant, N	0.0099 meq/ml
Volume Titrant Blank, V_{tb}	0.05 ml
Volume Titrant Sample, V_t	4.55 ml
Volume of Sample Aliquot, V_a	100 ml
Total Volume of Solution, V_{soln}	500 ml

Calculated Data from Laboratory Analysis:

$C_{H_2SO_4} = 1.081E-04 \times (N \times (V_t - V_{tb}) \times (V_{soln} / V_a)) / V_{m(std)}$	5.913E-07 lb/dscf
---	-------------------

$E_{H_2SO_4} = C_{H_2SO_4} \times \text{F-factor}$	0.017 lb/MMBtu
--	----------------

40 CFR 60, Appendix A - Test Methods

Method 8 Test Calculations

Run Number 7

Plant: Polk Power Station
Date: 02/08/2000
Sampling Location: Stack
Operating Conditions: Baseload

Sample Time, θ :	60 minutes	Nozzle Diameter, D_n :	0.201 inches
Barometric Pressure, P_b :	30.00 " Hg	Nozzle Area, A_n :	0.0002204 ft. ²
Stack Pressure, P_s :	29.93 " Hg	Average Orifice Meter, ΔH :	1.398 " H ₂ O
Effective Stack Area, A_s :	283.53 ft. ²	Sample Volume, V_m :	40.988 ft. ³
Pitot Coefficient, C_p :	0.84 dimensionless	Average Meter Temp., T_m :	75.0 °F
Gas Analysis:	8.0 % CO ₂	Average Stack Temp., T_s :	336.0 °F
	11.8 % O ₂	Average $\sqrt{\Delta p}$:	1.158 " H ₂ O
	0.0 % CO	Condensate Volume, V_{lc} :	46.0 ml
	80.2 % N ₂	Meter Box Y:	0.989 dimensionless

Data Calculated from Source Measurements:

$V_{w(std)} = 4.714E-02 \times V_{lc}$	2.168 scf
$V_{m(std)} = 17.647 \times V_m \times Y \times (P_b + (\Delta H / 13.6)) / (T_m + 460)$	40.251 dscf
$B_{ws} = V_{w(std)} / (V_{m(std)} + V_{w(std)})$	0.051 %
$FDA = 1.0 - B_{ws}$	0.949 %
$M_d = (0.44 \times \%CO_2) + (0.32 \times \%O_2) + (0.28 \times (\%N_2 + \%CO))$	29.75 lb/lb mole
$M_s = (M_d \times FDA) + (18.0 \times B_{ws})$	29.15 lb/lb mole
$v_s = 85.49 \times C_p \times (\sqrt{\Delta p}) \times (\sqrt{T_s + 460}) / (M_s \times P_s)$	79.43 ft/second
$Q_s = v_s \times A_s \times 60$	1351247.3 acf/minute
$Q_{s(std)} = Q_s \times FDA \times (528 / (T_s + 460)) \times (P_s / 29.92)$	850877.5 dscf/minute
$l = (T_s + 460) \times ((2.67E-03 \times V_{lc}) + (V_{m(std)} / 17.647)) \times 100 / (\theta \times P_s \times A_n \times v_s \times 60)$	101.4 %
Calculated F-factor = $Q_{s(std)} / \text{Heat Input}$	28925.01 dscf/MMBtu

Data from Laboratory Analysis:

Normality of Barium Perchlorate titrant, N	0.0099 meq/ml
Volume Titrant Blank, V_{tb}	0.05 ml
Volume Titrant Sample, V_t	4.8 ml
Volume of Sample Aliquot, V_a	100 ml
Total Volume of Solution, V_{soln}	500 ml

Calculated Data from Laboratory Analysis:

$C_{H_2SO_4} = 1.081E-04 \times (N \times (V_t - V_{tb}) \times (V_{soln} / V_a)) / V_{m(std)}$	6.315E-07 lb/dscf
---	-------------------

$E_{H_2SO_4} = C_{H_2SO_4} \times \text{F-factor}$	0.018 lb/MMBtu
--	----------------

40 CFR 60, Appendix A - Test Methods
Method 8 Test Calculations

Run Number 8

Plant: Polk Power Station
Date: 02/08/2000
Sampling Location: Stack
Operating Conditions: Baseload

Sample Time, θ :	60 minutes	Nozzle Diameter, D_n :	0.201 inches
Barometric Pressure, P_b :	29.91 " Hg	Nozzle Area, A_n :	0.0002204 ft. ²
Stack Pressure, P_s :	29.84 " Hg	Average Orifice Meter, ΔH :	1.418 " H ₂ O
Effective Stack Area, A_s :	283.53 ft. ²	Sample Volume, V_m :	41.286 ft. ³
Pitot Coefficient, C_p :	0.84 dimensionless	Average Meter Temp., T_m :	81.0 °F
Gas Analysis:	8.0 % CO ₂	Average Stack Temp., T_s :	336.0 °F
	11.8 % O ₂	Average $\sqrt{\Delta p}$:	1.167 " H ₂ O
	0.0 % CO	Condensate Volume, V_{lc} :	46.4 ml
	80.2 % N ₂	Meter Box Y:	0.989 dimensionless

Data Calculated from Source Measurements:

$V_{w(std)} = 4.714E-02 \times V_{lc}$	2.187 scf
$V_{m(std)} = 17.647 \times V_m \times Y \times (P_b + (\Delta H / 13.6)) / (T_m + 460)$	39.976 dscf
$B_{ws} = V_{w(std)} / (V_{m(std)} + V_{w(std)})$	0.052 %
$FDA = 1.0 - B_{ws}$	0.948 %
$M_d = (0.44 \times \%CO_2) + (0.32 \times \%O_2) + (0.28 \times (\%N_2 + \%CO))$	29.75 lb/lb mole
$M_s = (M_d \times FDA) + (18.0 \times B_{ws})$	29.14 lb/lb mole
$v_s = 85.49 \times C_p \times (\sqrt{\Delta p}) \times (\sqrt{(T_s + 460)}) / (M_s \times P_s)$	80.18 ft/second
$Q_s = v_s \times A_s \times 60$	1364006.1 acf/minute
$Q_{s(std)} = Q_s \times FDA \times (528 / (T_s + 460)) \times (P_s / 29.92)$	855426.6 dscf/minute
$I = (T_s + 460) \times ((2.67E-03 \times V_{lc}) + (V_{m(std)} / 17.647)) \times 100 / (\theta \times P_s \times A_n \times v_s \times 60)$	100.2 %
Calculated F-factor = $Q_{s(std)} / \text{Heat Input}$	29079.66 dscf/MMBtu

Data from Laboratory Analysis:

Normality of Barium Perchlorate titrant, N	0.0099 meq/ml
Volume Titrant Blank, V_{tb}	0.05 ml
Volume Titrant Sample, V_t	5.5 ml
Volume of Sample Aliquot, V_a	100 ml
Total Volume of Solution, V_{soln}	500 ml

Calculated Data from Laboratory Analysis:

$C_{H_2SO_4} = 1.081E-04 \times (N \times (V_t - V_{tb}) \times (V_{soln} / V_a)) / V_{m(std)}$	7.295E-07 lb/dscf
$E_{H_2SO_4} = C_{H_2SO_4} \times \text{F-factor}$	0.021 lb/MMBtu

A-2 FUEL BLEND SULFURIC ACID MIST CALCULATIONS



40 CFR 60, Appendix A - Test Methods
Method 8 Test Calculations
Test Summary

Plant: Polk Power Station
Date: 4-24-00 To 4-26-00
Sampling Location: Stack
Operating Conditions: Baseload, Blend 2

	Run #1	Run #2	Run #3	Run #6	Run #7	Run #8	Run #9	Run #10	Run #11	Average
Gas Flow Rate										
acfm	1408917.3	1405174.7	1425418.7	1363665.9	1360773.9	1357031.3	1357031.3	1385270.9	1390884.8	1383797
dscfm	872528.9	866398.3	881799.7	856027.9	853858	860571.4	860571.4	873817.2	873322.5	866544
Average Stack Temperature, °F	320.7	320	321.3	322	321.0	321.8	321.8	324.5	324.8	322.0
% Isokinetic	104.0	105.8	99	103	102.4	102	102	102.3	101.9	102.5
Moisture, %H2O	5.2	5.7	4.9	5.8	5.8	4.7	4.7	5.2	5.6	5.3
Sampled Volume, dscf	42.321	42.76	40.705	41.144	40.782	40.927	40.927	41.698	41.51	41.419
Condensate Volume, ml	49.4	54.9	44.5	53.3	53.2	43.1	43.1	48.6	52.4	49.2
Meter Temperature, °F	80.4	86.7	84.6	88.1	89.0	86.5	86.5	72.8	80.4	83.9
$C_{H_2SO_4}$, lb/dscf	3.457E-07	2.17E-07	8.72E-08	5.666E-07	4.712E-07	4.243E-07	5.189E-07	4.085E-07	4.392E-07	3.86511E-07
$E_{H_2SO_4} = C_{H_2SO_4} \times F$ -factor, lbs/MMBtu	0.010	0.006	0.003	0.017	0.014	0.013	0.015	0.012	0.013	0.011

F-factor is calculated from flow data during testing and DCS data Heat Input on a run/run basis.

40 CFR 60, Appendix A - Test Methods
Method 8 Test Calculations

Run Number 1

Plant: Polk Power Station
Date: 04/24/2000
Sampling Location: Stack
Operating Conditions: Baseload, Blend 2

Sample Time, θ :	60 minutes	Nozzle Diameter, D_n :	0.201 inches
Barometric Pressure, P_b :	29.50 " Hg	Nozzle Area, A_n :	0.0002204 ft. ²
Stack Pressure, P_s :	28.9 " Hg	Average Orifice Meter, ΔH :	1.544 " H ₂ O
Effective Stack Area, A_s :	283.53 ft. ²	Sample Volume, V_m :	43.72 ft. ³
Pitot Coefficient, C_p :	0.84 dimensionless	Average Meter Temp., T_m :	80.4 °F
Gas Analysis:	7.0 % CO ₂	Average Stack Temp., T_s :	320.7 °F
	12.0 % O ₂	Average $\sqrt{\Delta p}$:	1.195 " H ₂ O
	0.0 % CO	Condensate Volume, V_{lc} :	49.4 ml
	81.0 % N ₂	Meter Box Y:	1.001 dimensionless

Data Calculated from Source Measurements:

$V_{w(std)} = 4.714E-02 \times V_{lc}$	2.329 scf
$V_{m(std)} = 17.647 \times V_m \times Y \times (P_b + (\Delta H / 13.6)) / (T_m + 460)$	42.321 dscf
$B_{ws} = V_{w(std)} / (V_{m(std)} + V_{w(std)})$	0.052 %
$FDA = 1.0 - B_{ws}$	0.948 %
$M_d = (0.44 \times \%CO_2) + (0.32 \times \%O_2) + (0.28 \times (\%N_2 + \%CO))$	29.6 lb/lb mole
$M_s = (M_d \times FDA) + (18.0 \times B_{ws})$	29 lb/lb mole
$v_s = 85.49 \times C_p \times (\sqrt{\Delta p}) \times (\sqrt{(T_s + 460)}) / (M_s \times P_s)$	82.82 ft/second
$Q_s = v_s \times A_s \times 60$	1408917.3 acf/minute
$Q_{s(std)} = Q_s \times FDA \times (528 / (T_s + 460)) \times (P_s / 29.92)$	872528.9 dscf/minute
$I = (T_s + 460) \times ((2.67E-03 \times V_{lc}) + (V_{m(std)} / 17.647)) \times 100 / (\theta \times P_s \times A_n \times v_s \times 60)$	104.0 %
Calculated F-factor = $Q_{s(std)} / \text{Heat Input}$	30087.20 dscf/MMBtu

Data from Laboratory Analysis:

Normality of Barium Perchlorate titrant, N	0.0101 meq/ml
Volume Titrant Blank, V_{tb}	0 ml
Volume Titrant Sample, V_t	2.68 ml
Volume of Sample Aliquot, V_a	100 ml
Total Volume of Solution, V_{soln}	500 ml

Calculated Data from Laboratory Analysis:

$C_{H_2SO_4} = 1.081E-04 \times (N \times (V_t - V_{tb}) \times (V_{soln} / V_a)) / V_{m(std)}$	3.457E-07 lb/dscf
$E_{H_2SO_4} = C_{H_2SO_4} \times \text{F-factor}$	0.010 lb/MMBtu

40 CFR 60, Appendix A - Test Methods

Method 8 Test Calculations

Run Number 2

Plant: Polk Power Station
Date: 04/24/2000
Sampling Location: Stack
Operating Conditions: Baseload, Blend 2

Sample Time, θ :	60 minutes	Nozzle Diameter, D_n :	0.201 inches
Barometric Pressure, P_b :	29.50 " Hg	Nozzle Area, A_n :	0.0002204 ft. ²
Stack Pressure, P_s :	28.9 " Hg	Average Orifice Meter, ΔH :	1.553 " H ₂ O
Effective Stack Area, A_s :	283.53 ft. ²	Sample Volume, V_m :	44.687 ft. ³
Pitot Coefficient, C_p :	0.84 dimensionless	Average Meter Temp., T_m :	86.7 °F
Gas Analysis:	7.0 % CO ₂	Average Stack Temp., T_s :	320 °F
	12.0 % O ₂	Average $\sqrt{\Delta p}$:	1.191 " H ₂ O
	0.0 % CO	Condensate Volume, V_{lc} :	54.9 ml
	81.0 % N ₂	Meter Box Y:	1.001 dimensionless

Data Calculated from Source Measurements:

$V_{w(std)} = 4.714E-02 \times V_{lc}$	2.588 scf
$V_{m(std)} = 17.647 \times V_m \times Y \times (P_b + (\Delta H / 13.6)) / (T_m + 460)$	42.76 dscf
$B_{ws} = V_{w(std)} / (V_{m(std)} + V_{w(std)})$	0.057 %
$FDA = 1.0 - B_{ws}$	0.943 %
$M_d = (0.44 \times \%CO_2) + (0.32 \times \%O_2) + (0.28 \times (\%N_2 + \%CO))$	29.6 lb/lb mole
$M_s = (M_d \times FDA) + (18.0 \times B_{ws})$	28.94 lb/lb mole
$v_s = 85.49 \times C_p \times (\sqrt{\Delta p}) \times (\sqrt{(T_s + 460)}) / (M_s \times P_s)$	82.6 ft/second
$Q_s = v_s \times A_s \times 60$	1405174.7 acf/minute
$Q_{s(std)} = Q_s \times FDA \times (528 / (T_s + 460)) \times (P_s / 29.92)$	866398.3 dscf/minute
$I = (T_s + 460) \times ((2.67E-03 \times V_{lc}) + (V_{m(std)} / 17.647)) \times 100 / (\theta \times P_s \times A_n \times v_s \times 60)$	105.8 %
Calculated F-factor = $Q_{s(std)} / \text{Heat Input}$	29875.80 dscf/MMBtu

Data from Laboratory Analysis:

Normality of Barium Perchlorate titrant, N	0.0101 meq/ml
Volume Titrant Blank, V_{tb}	0 ml
Volume Titrant Sample, V_t	1.7 ml
Volume of Sample Aliquot, V_a	100 ml
Total Volume of Solution, V_{soln}	500 ml

Calculated Data from Laboratory Analysis:

$C_{H_2SO_4} = 1.081E-04 \times (N \times (V_t - V_{tb}) \times (V_{soln} / V_a)) / V_{m(std)}$	2.170E-07 lb/dscf
$E_{H_2SO_4} = C_{H_2SO_4} \times \text{F-factor}$	0.006 lb/MMBtu

40 CFR 60, Appendix A - Test Methods
Method 8 Test Calculations

Run Number 3

Plant: Polk Power Station
Date: 04/24/2000
Sampling Location: Stack
Operating Conditions: Baseload, Blend 2

Sample Time, θ :	60 minutes	Nozzle Diameter, D_n :	0.201 inches
Barometric Pressure, P_b :	29.40 " Hg	Nozzle Area, A_n :	0.0002204 ft. ²
Stack Pressure, P_s :	28.8 " Hg	Average Orifice Meter, ΔH :	1.569 " H ₂ O
Effective Stack Area, A_s :	283.53 ft. ²	Sample Volume, V_m :	42.518 ft. ³
Pitot Coefficient, C_p :	0.84 dimensionless	Average Meter Temp., T_m :	84.6 °F
Gas Analysis:	7.0 % CO ₂	Average Stack Temp., T_s :	321.3 °F
	12.0 % O ₂	Average $\sqrt{\Delta p}$:	1.207 " H ₂ O
	0.0 % CO	Condensate Volume, V_{lc} :	44.5 ml
	81.0 % N ₂	Meter Box Y:	1.001 dimensionless

Data Calculated from Source Measurements:

$V_{w(std)} = 4.714E-02 \times V_{lc}$	2.098 scf
$V_{m(std)} = 17.647 \times V_m \times Y \times (P_b + (\Delta H / 13.6)) / (T_m + 460)$	40.705 dscf
$B_{ws} = V_{w(std)} / (V_{m(std)} + V_{w(std)})$	0.049 %
$FDA = 1.0 - B_{ws}$	0.951 %
$M_d = (0.44 \times \%CO_2) + (0.32 \times \%O_2) + (0.28 \times (\%N_2 + \%CO))$	29.6 lb/lb mole
$M_s = (M_d \times FDA) + (18.0 \times B_{ws})$	29.03 lb/lb mole
$v_s = 85.49 \times C_p \times (\sqrt{\Delta p}) \times (\sqrt{(T_s + 460)} / (M_s \times P_s))$	83.79 ft/second
$Q_s = v_s \times A_s \times 60$	1425418.7 acf/minute
$Q_{s(std)} = Q_s \times FDA \times (528 / (T_s + 460)) \times (P_s / 29.92)$	881799.7 dscf/minute
$I = (T_s + 460) \times ((2.67E-03 \times V_{lc}) + (V_{m(std)} / 17.647)) \times 100 / (\theta \times P_s \times A_n \times v_s \times 60)$	99 %
Calculated F-factor = $Q_{s(std)} / \text{Heat Input}$	30406.89 dscf/MMBtu

Data from Laboratory Analysis:

Normality of Barium Perchlorate titrant, N	0.0101 meq/ml
Volume Titrant Blank, V_{tb}	0 ml
Volume Titrant Sample, V_t	0.65 ml
Volume of Sample Aliquot, V_a	100 ml
Total Volume of Solution, V_{soln}	500 ml

Calculated Data from Laboratory Analysis:

$C_{H_2SO_4} = 1.081E-04 \times (N \times (V_t - V_{tb}) \times (V_{soln} / V_a)) / V_{m(std)}$	8.720E-08 lb/dscf
$E_{H_2SO_4} = C_{H_2SO_4} \times \text{F-factor}$	0.003 lb/MMBtu

40 CFR 60, Appendix A - Test Methods

Method 8 Test Calculations

Run Number 6

Plant: Polk Power Station
Date: 04/25/2000
Sampling Location: Stack
Operating Conditions: Baseload, Blend 2

Sample Time, θ :	60 minutes	Nozzle Diameter, D_n :	0.201 inches
Barometric Pressure, P_b :	29.60 " Hg	Nozzle Area, A_n :	0.0002204 ft. ²
Stack Pressure, P_s :	29.53 " Hg	Average Orifice Meter, ΔH :	1.47 " H ₂ O
Effective Stack Area, A_s :	283.53 ft. ²	Sample Volume, V_m :	42.972 ft. ³
Pitot Coefficient, C_p :	0.84 dimensionless	Average Meter Temp., T_m :	88.1 °F
Gas Analysis:	8.1 % CO ₂	Average Stack Temp., T_s :	322 °F
	13.3 % O ₂	Average $\sqrt{\Delta p}$:	1.171 " H ₂ O
	0.0 % CO	Condensate Volume, V_{lc} :	53.3 ml
	78.6 % N ₂	Meter Box Y:	1.001 dimensionless

Data Calculated from Source Measurements:

$V_{w(std)} = 4.714E-02 \times V_{lc}$	2.513 scf
$V_{m(std)} = 17.647 \times V_m \times Y \times (P_b + (\Delta H / 13.6)) / (T_m + 460)$	41.144 dscf
$B_{ws} = V_{w(std)} / (V_{m(std)} + V_{w(std)})$	0.058 %
$FDA = 1.0 - B_{ws}$	0.942 %
$M_d = (0.44 \times \%CO_2) + (0.32 \times \%O_2) + (0.28 \times (\%N_2 + \%CO))$	29.83 lb/lb mole
$M_s = (M_d \times FDA) + (18.0 \times B_{ws})$	29.14 lb/lb mole
$v_s = 85.49 \times C_p \times (\sqrt{\Delta p}) \times (\sqrt{T_s + 460}) / (M_s \times P_s)$	80.16 ft/second
$Q_s = v_s \times A_s \times 60$	1363665.9 acf/minute
$Q_{s(std)} = Q_s \times FDA \times (528 / (T_s + 460)) \times (P_s / 29.92)$	856027.9 dscf/minute
$I = (T_s + 460) \times ((2.67E-03 \times V_{lc}) + (V_{m(std)} / 17.647)) \times 100 / (\theta \times P_s \times A_n \times v_s \times 60)$	103 %
Calculated F-factor = $Q_{s(std)} / \text{Heat Input}$	29518.20 dscf/MMBtu

Data from Laboratory Analysis:

Normality of Barium Perchlorate titrant, N	0.0101 meq/ml
Volume Titrant Blank, V_{tb}	0.01 ml
Volume Titrant Sample, V_t	4.28 ml
Volume of Sample Aliquot, V_a	100 ml
Total Volume of Solution, V_{soln}	500 ml

Calculated Data from Laboratory Analysis:

$C_{H_2SO_4} = 1.081E-04 \times (N \times (V_t - V_{tb}) \times (V_{soln} / V_a)) / V_{m(std)}$	5.666E-07 lb/dscf
$E_{H_2SO_4} = C_{H_2SO_4} \times \text{F-factor}$	0.017 lb/MMBtu

40 CFR 60, Appendix A - Test Methods

Method 8 Test Calculations

Run Number 7

Plant: Polk Power Station

Date: 04/25/2000

Sampling Location: Stack

Operating Conditions: Baseload, Blend 2

Sample Time, θ :	60 minutes	Nozzle Diameter, D_n :	0.201 inches
Barometric Pressure, P_b :	29.55 " Hg	Nozzle Area, A_n :	0.0002204 ft. ²
Stack Pressure, P_s :	29.48 " Hg	Average Orifice Meter, ΔH :	1.456 " H ₂ O
Effective Stack Area, A_s :	283.53 ft. ²	Sample Volume, V_m :	42.737 ft. ³
Pitot Coefficient, C_p :	0.84 dimensionless	Average Meter Temp., T_m :	89.0 °F
Gas Analysis:	7.7 % CO ₂	Average Stack Temp., T_s :	321.0 °F
	13.1 % O ₂	Average $\sqrt{\Delta p}$:	1.167 " H ₂ O
	0.0 % CO	Condensate Volume, V_{lc} :	53.2 ml
	79.2 % N ₂	Meter Box Y:	1.001 dimensionless

Data Calculated from Source Measurements:

$V_{w(std)} = 4.714E-02 \times V_{lc}$	2.508 scf
$V_{m(std)} = 17.647 \times V_m \times Y \times (P_b + (\Delta H / 13.6)) / (T_m + 460)$	40.782 dscf
$B_{ws} = V_{w(std)} / (V_{m(std)} + V_{w(std)})$	0.058 %
$FDA = 1.0 - B_{ws}$	0.942 %
$M_d = (0.44 \times \%CO_2) + (0.32 \times \%O_2) + (0.28 \times (\%N_2 + \%CO))$	29.76 lb/lb mole
$M_s = (M_d \times FDA) + (18.0 \times B_{ws})$	29.08 lb/lb mole
$v_s = 85.49 \times C_p \times (\sqrt{\Delta p}) \times (\sqrt{(T_s + 460)}) / (M_s \times P_s)$	79.99 ft/second
$Q_s = v_s \times A_s \times 60$	1360773.9 acf/minute
$Q_{s(std)} = Q_s \times FDA \times (528 / (T_s + 460)) \times (P_s / 29.92)$	853858 dscf/minute
$I = (T_s + 460) \times ((2.67E-03 \times V_{lc}) + (V_{m(std)} / 17.647)) \times 100 / (\theta \times P_s \times A_n \times v_s \times 60)$	102.4 %
Calculated F-factor = $Q_{s(std)} / \text{Heat Input}$	29443.38 dscf/MMBtu

Data from Laboratory Analysis:

Normality of Barium Perchlorate titrant, N	0.0101 meq/ml
Volume Titrant Blank, V_{tb}	0.01 ml
Volume Titrant Sample, V_t	3.53 ml
Volume of Sample Aliquot, V_a	100 ml
Total Volume of Solution, V_{soln}	500 ml

Calculated Data from Laboratory Analysis:

$C_{H_2SO_4} = 1.081E-04 \times (N \times (V_t - V_{tb}) \times (V_{soln} / V_a)) / V_{m(std)}$	4.712E-07 lb/dscf
$E_{H_2SO_4} = C_{H_2SO_4} \times \text{F-factor}$	0.014 lb/MMBtu

40 CFR 60, Appendix A - Test Methods
Method 8 Test Calculations

Run Number 8

Plant: Polk Power Station
Date: 04/25/2000
Sampling Location: Stack
Operating Conditions: Baseload, Blend 2

Sample Time, θ :	60 minutes	Nozzle Diameter, D_n :	0.201 inches
Barometric Pressure, P_b :	29.55 " Hg	Nozzle Area, A_n :	0.0002204 ft. ²
Stack Pressure, P_s :	29.48 " Hg	Average Orifice Meter, ΔH :	1.461 " H ₂ O
Effective Stack Area, A_s :	283.53 ft. ²	Sample Volume, V_m :	42.799 ft. ³
Pitot Coefficient, C_p :	0.84 dimensionless	Average Meter Temp., T_m :	89.8 °F
Gas Analysis:	7.8 % CO ₂	Average Stack Temp., T_s :	321.3 °F
	13.0 % O ₂	Average $\sqrt{\Delta p}$:	1.167 " H ₂ O
	0.0 % CO	Condensate Volume, V_{lc} :	47.8 ml
	79.2 % N ₂	Meter Box Y:	1.001 dimensionless

Data Calculated from Source Measurements:

$V_{w(std)} = 4.714E-02 \times V_{lc}$	2.253 scf
$V_{m(std)} = 17.647 \times V_m \times Y \times (P_b + (\Delta H / 13.6)) / (T_m + 460)$	40.782 dscf
$B_{ws} = V_{w(std)} / (V_{m(std)} + V_{w(std)})$	0.052 %
$FDA = 1.0 - B_{ws}$	0.948 %
$M_d = (0.44 \times \%CO_2) + (0.32 \times \%O_2) + (0.28 \times (\%N_2 + \%CO))$	29.77 lb/lb mole
$M_s = (M_d \times FDA) + (18.0 \times B_{ws})$	29.16 lb/lb mole
$v_s = 85.49 \times C_p \times \sqrt{\Delta p} \times \sqrt{(T_s + 460)} / (M_s \times P_s)$	79.89 ft/second
$Q_s = v_s \times A_s \times 60$	1359072.7 acf/minute
$Q_{s(std)} = Q_s \times FDA \times (528 / (T_s + 460)) \times (P_s / 29.92)$	857892.8 dscf/minute
$I = (T_s + 460) \times ((2.67E-03 \times V_{lc}) + (V_{m(std)} / 17.647)) \times 100 / (\theta \times P_s \times A_n \times v_s \times 60)$	102 %
Calculated F-factor = $Q_{s(std)} / \text{Heat Input}$	29582.51 dscf/MMBtu

Data from Laboratory Analysis:

Normality of Barium Perchlorate titrant, N	0.0101 meq/ml
Volume Titrant Blank, V_{tb}	0.01 ml
Volume Titrant Sample, V_t	3.18 ml
Volume of Sample Aliquot, V_a	100 ml
Total Volume of Solution, V_{soln}	500 ml

Calculated Data from Laboratory Analysis:

$C_{H_2SO_4} = 1.081E-04 \times (N \times (V_t - V_{tb}) \times (V_{soln} / V_a)) / V_{m(std)}$	4.243E-07 lb/dscf
$E_{H_2SO_4} = C_{H_2SO_4} \times \text{F-factor}$	0.013 lb/MMBtu

40 CFR 60, Appendix A - Test Methods
Method 8 Test Calculations

Run Number 9

Plant: Polk Power Station
Date: 04/25/2000
Sampling Location: Stack
Operating Conditions: Baseload, Blend 2

Sample Time, θ :	60 minutes	Nozzle Diameter, D_n :	0.201 inches
Barometric Pressure, P_b :	29.5 " Hg	Nozzle Area, A_n :	0.0002204 ft. ²
Stack Pressure, P_s :	29.48 " Hg	Average Orifice Meter, ΔH :	1.46 " H ₂ O
Effective Stack Area, A_s :	283.53 ft. ²	Sample Volume, V_m :	42.766 ft. ³
Pitot Coefficient, C_p :	0.84 dimensionless	Average Meter Temp., T_m :	86.5 °F
Gas Analysis:	7.8 % CO ₂	Average Stack Temp., T_s :	321.8 °F
	13.0 % O ₂	Average $\sqrt{\Delta p}$:	1.166 " H ₂ O
	0.0 % CO	Condensate Volume, V_{lc} :	43.1 ml
	79.2 % N ₂	Meter Box Y:	1.001 dimensionless

Data Calculated from Source Measurements:

$V_{w(std)} = 4.714E-02 \times V_{lc}$	2.032 scf
$V_{m(std)} = 17.647 \times V_m \times Y \times (P_b + (\Delta H / 13.6)) / (T_m + 460)$	40.927 dscf
$B_{ws} = V_{w(std)} / (V_{m(std)} + V_{w(std)})$	0.047 %
$FDA = 1.0 - B_{ws}$	0.953 %
$M_d = (0.44 \times \%CO_2) + (0.32 \times \%O_2) + (0.28 \times (\%N_2 + \%CO))$	29.77 lb/lb mole
$M_s = (M_d \times FDA) + (18.0 \times B_{ws})$	29.22 lb/lb mole
$v_s = 85.49 \times C_p \times \sqrt{\Delta p} \times \sqrt{(T_s + 460) / (M_s \times P_s)}$	79.77 ft/second
$Q_s = v_s \times A_s \times 60$	1357031.3 acf/minute
$Q_{s(std)} = Q_s \times FDA \times (528 / (T_s + 460)) \times (P_s / 29.92)$	860571.4 dscf/minute
$I = (T_s + 460) \times ((2.67E-03 \times V_{lc}) + (V_{m(std)} / 17.647)) \times 100 / (\theta \times P_s \times A_n \times v_s \times 60)$	102 %
Calculated F-factor = $Q_{s(std)} / \text{Heat Input}$	29674.88 dscf/MMBtu

Data from Laboratory Analysis:

Normality of Barium Perchlorate titrant, N	0.0101 meq/ml
Volume Titrant Blank, V_{tb}	0.01 ml
Volume Titrant Sample, V_t	3.9 ml
Volume of Sample Aliquot, V_a	100 ml
Total Volume of Solution, V_{soln}	500 ml

Calculated Data from Laboratory Analysis:

$C_{H_2SO_4} = 1.081E-04 \times (N \times (V_t - V_{tb}) \times (V_{soln} / V_a)) / V_{m(std)}$	5.189E-07 lb/dscf
$E_{H_2SO_4} = C_{H_2SO_4} \times \text{F-factor}$	0.015 lb/MMBtu

40 CFR 60, Appendix A - Test Methods
Method 8 Test Calculations

Run Number 10

Plant: Polk Power Station
Date: 04/26/2000
Sampling Location: Stack
Operating Conditions: Baseload, Blend 2

Sample Time, θ :	60 minutes	Nozzle Diameter, D_n :	0.201 inches
Barometric Pressure, P_b :	29.65 " Hg	Nozzle Area, A_n :	0.0002204 ft. ²
Stack Pressure, P_s :	29.58 " Hg	Average Orifice Meter, ΔH :	1.476 " H ₂ O
Effective Stack Area, A_s :	283.53 ft. ²	Sample Volume, V_m :	42.263 ft. ³
Pitot Coefficient, C_p :	0.84 dimensionless	Average Meter Temp., T_m :	72.8 °F
Gas Analysis:	7.8 % CO ₂	Average Stack Temp., T_s :	324.5 °F
	13.0 % O ₂	Average $\sqrt{\Delta p}$:	1.189 " H ₂ O
	0.0 % CO	Condensate Volume, V_{lc} :	48.6 ml
	79.2 % N ₂	Meter Box Y:	1.001 dimensionless

Data Calculated from Source Measurements:

$V_{w(std)} = 4.714E-02 \times V_{lc}$	2.291 scf
$V_{m(std)} = 17.647 \times V_m \times Y \times (P_b + (\Delta H / 13.6)) / (T_m + 460)$	41.698 dscf
$B_{ws} = V_{w(std)} / (V_{m(std)} + V_{w(std)})$	0.052 %
$FDA = 1.0 - B_{ws}$	0.948 %
$M_d = (0.44 \times \%CO_2) + (0.32 \times \%O_2) + (0.28 \times (\%N_2 + \%CO))$	29.77 lb/lb mole
$M_s = (M_d \times FDA) + (18.0 \times B_{ws})$	29.16 lb/lb mole
$v_s = 85.49 \times C_p \times (\sqrt{\Delta p}) \times (\sqrt{(T_s + 460)} / (M_s \times P_s))$	81.43 ft/second
$Q_s = v_s \times A_s \times 60$	1385270.9 acf/minute
$Q_{s(std)} = Q_s \times FDA \times (528 / (T_s + 460)) \times (P_s / 29.92)$	873817.2 dscf/minute
$I = (T_s + 460) \times ((2.67E-03 \times V_{lc}) + (V_{m(std)} / 17.647)) \times 100 / (\theta \times P_s \times A_n \times v_s \times 60)$	102.3 %
Calculated F-factor = $Q_{s(std)} / \text{Heat Input}$	30131.63 dscf/MMBtu

Data from Laboratory Analysis:

Normality of Barium Perchlorate titrant, N	0.0101 meq/ml
Volume Titrant Blank, V_{tb}	0.01 ml
Volume Titrant Sample, V_t	3.13 ml
Volume of Sample Aliquot, V_a	100 ml
Total Volume of Solution, V_{soln}	500 ml

Calculated Data from Laboratory Analysis:

$C_{H_2SO_4} = 1.081E-04 \times (N \times (V_t - V_{tb}) \times (V_{soln} / V_a)) / V_{m(std)}$	4.085E-07 lb/dscf
$E_{H_2SO_4} = C_{H_2SO_4} \times \text{F-factor}$	0.012 lb/MMBtu

40 CFR 60, Appendix A - Test Methods
Method 8 Test Calculations

Run Number 11

Plant: Polk Power Station
Date: 04/26/2000
Sampling Location: Stack
Operating Conditions: Baseload, Blend 2

Sample Time, θ :	60 minutes	Nozzle Diameter, D_n :	0.201 inches
Barometric Pressure, P_b :	29.65 " Hg	Nozzle Area, A_n :	0.0002204 ft. ²
Stack Pressure, P_s :	29.58 " Hg	Average Orifice Meter, ΔH :	1.49 " H ₂ O
Effective Stack Area, A_s :	283.53 ft. ²	Sample Volume, V_m :	42.671 ft. ³
Pitot Coefficient, C_p :	0.84 dimensionless	Average Meter Temp., T_m :	80.4 °F
Gas Analysis:	8.0 % CO ₂	Average Stack Temp., T_s :	324.8 °F
	11.6 % O ₂	Average $\sqrt{\Delta p}$:	1.192 " H ₂ O
	0.0 % CO	Condensate Volume, V_{lc} :	52.4 ml
	80.4 % N ₂	Meter Box Y:	1.001 dimensionless

Data Calculated from Source Measurements:

$V_{w(std)} = 4.714E-02 \times V_{lc}$	2.47 scf
$V_{m(std)} = 17.647 \times V_m \times Y \times (P_b + (\Delta H / 13.6)) / (T_m + 460)$	41.51 dscf
$B_{ws} = V_{w(std)} / (V_{m(std)} + V_{w(std)})$	0.056 %
$FDA = 1.0 - B_{ws}$	0.944 %
$M_d = (0.44 \times \%CO_2) + (0.32 \times \%O_2) + (0.28 \times (\%N_2 + \%CO))$	29.74 lb/lb mole
$M_s = (M_d \times FDA) + (18.0 \times B_{ws})$	29.08 lb/lb mole
$v_s = 85.49 \times C_p \times (\sqrt{\Delta p}) \times (\sqrt{(T_s + 460)} / (M_s \times P_s))$	81.76 ft/second
$Q_s = v_s \times A_s \times 60$	1390884.8 acf/minute
$Q_{s(std)} = Q_s \times FDA \times (528 / (T_s + 460)) \times (P_s / 29.92)$	873322.5 dscf/minute
$I = (T_s + 460) \times ((2.67E-03 \times V_{lc}) + (V_{m(std)} / 17.647)) \times 100 / (\theta \times P_s \times A_n \times v_s \times 60)$	101.9 %
Calculated F-factor = $Q_{s(std)} / \text{Heat Input}$	30114.57 dscf/MMBtu

Data from Laboratory Analysis:

Normality of Barium Perchlorate titrant, N	0.0101 meq/ml
Volume Titrant Blank, V_{tb}	0.01 ml
Volume Titrant Sample, V_t	3.35 ml
Volume of Sample Aliquot, V_a	100 ml
Total Volume of Solution, V_{soln}	500 ml

Calculated Data from Laboratory Analysis:

$C_{H_2SO_4} = 1.081E-04 \times (N \times (V_t - V_{tb}) \times (V_{soln} / V_a)) / V_{m(std)}$	4.392E-07 lb/dscf
$E_{H_2SO_4} = C_{H_2SO_4} \times \text{F-factor}$	0.013 lb/MMBtu

APPENDIX B

LABORATORY ANALYTICAL DATA

B-1 BASELINE SULFURIC ACID MIST LABORATORY DATA

B-2 FUEL BLEND SULFURIC ACID MIST LABORATORY DATA

B-1 BASELINE SULFURIC ACID MIST LABORATORY DATA



5012 Causeway Blvd * Tampa Fl. 33619 * Ph (813)630-7378 * Fax (813)630-7360 * CompQAP #910140G * DOH #E54272

Report For: David Smith, Air Programs

Report Date: 02/08/00

Laboratory ID: AA53532

Sample Information

Location Code: SPECL-PK

Location Description: Polk Power Plant

Sampled By: R. BARTHELETTE

Date Sampled: 02/07/00

Time Sampled: 11:56:00 AM

POLK STACK TEST

BASELINE FOR PETCOKE TEST BURN

Laboratory Results

Parameter	Result	Units	MDL	Method
Normality of BaCl ₂ * 2H ₂ O	0.0099		0.0001	
SO ₃ , Avg. of Blank Titrations	0.05	milliliters	0.01	EPA - Meth.8
SO ₃ , Run #1, Avg. of Titrations	3.88	milliliters	0.01	EPA - Meth.8
SO ₃ , Run #2, Avg. of Titrations	4.60	milliliters	0.01	EPA - Meth.8
SO ₃ , Run #3, Avg. of Titrations	4.35	milliliters	0.01	EPA - Meth.8
SO ₃ , Run #4, Avg. of Titrations	5.48	milliliters	0.01	EPA - Meth.8
SO ₃ , Volume of Contained Sample	500	milliliters	1	EPA - Meth.8
SO ₃ , Volume of Sample Aliquot	100	milliliters	0.1	EPA - Meth.8

Comments:

Samples received at the lab were isopropanol solutions recovered from stack test for SO₃ analysis.

Robert Dorey,
Supervisor of Laboratory Services



5012 Causeway Blvd * Tampa Fl. 33619 * Ph (813)630-7378 * Fax (813)630-7360 * CompQAP #910140G * DOH #E54272

Report For: David Smith, Air Programs

Report Date: 03/15/00

Laboratory ID: AA53545

Sample Information

Location Code: SPECL-PK
Location Description: Polk Power Plant
Project Account Code: L3
SAMPLE DESCRIPTION: ISOPROPANOL
SOLUTION
RECOVERD FROM STACKTEST FOR SO3
ANALYSIS

Sampled By: R. BARTHELETTE
Date Sampled: 02/08/00
Time Sampled: 10:01:00 AM

Laboratory Results

Parameter	Result	Units	MDL	Lower Limit	Upper Limit	Violation Check
Normality of BaCl2 * 2H2O	0.0099		0.0001			
SO3, Avg. of Blank Titrations	0.05	milliliters	0.01			
SO3, Run #5, Avg. of Titrations	3.70	milliliters	0.01			
SO3, Run #6, Avg. of Titrations	4.55	milliliters	0.01			
SO3, Run #7, Avg. of Titrations	4.80	milliliters	0.01			
SO3, Run #8, Avg. of Titrations	5.50	milliliters	0.01			
SO3, Volume of Contained Sample	500	milliliters	1			
SO3, Volume of Sample Aliquot	100	milliliters	0.1			

Comments:

Robert Dorey,
Supervisor of Laboratory Services

B-2 FUEL BLEND SULFURIC ACID MIST LABORATORY DATA



**Corporate Environmental
Laboratory Services**

5012 Causeway Blvd * Tampa Fl. 33619 * Ph (813)630-7378 * Fax (813)630-7360 * CompQAP #910140G * DOH #E54272

Report For: David Smith, Air Programs

Report Date: 04/28/00

Laboratory ID: AA54563

Sample Information

Location Code: SPECL-PK

Sampled By: AIR PROGRAMS

Location Description: Polk Power Plant

Date Sampled: 04/24/00

Project Account Code: L16

Time Sampled: 12:00:00 AM

SAMPLE DESCRIPTION:
60/40 PETCOKE BLEND

Laboratory Results

Parameter	Result	Units	MDL	Lower Limit	Upper Limit	Violation Check
Normality of BaCl2 * 2H2O	0.0101		0.0001			
SO3, Avg. of Blank Titrations	0.0	milliliters	0.01			
SO3, Run #1, Avg. of Titrations	2.68	milliliters	0.01			
SO3, Run #2, Avg. of Titrations	1.70	milliliters	0.01			
SO3, Run #3, Avg. of Titrations	0.65	milliliters	0.01			
SO3, Volume of Contained Sample	500	milliliters	1			
SO3, Volume of Sample Aliquot	100	milliliters	0.1			

Comments:

Robert Dorey,
Supervisor of Laboratory Services



**Corporate Environmental
Laboratory Services**

5012 Causeway Blvd * Tampa Fl. 33619 * Ph (813)630-7378 * Fax (813)630-7360 * CompQAP #910140G * DOH #E54272

Report For: David Smith, Air Programs

Report Date: 04/28/00

Laboratory ID: AA54564

Sample Information

Location Code: SPECL-PK

Sampled By: AIR PROGRAMS

Location Description: Polk Power Plant

Date Sampled: 04/25/00

Project Account Code: L16

Time Sampled: 12:00:00 AM

SAMPLE DESCRIPTION:

60/40 PETCOKE BLEND

Laboratory Results

Parameter	Result	Units	MDL	Lower Limit	Upper Limit	Violation Check
Normality of BaCl ₂ * 2H ₂ O	0.0101		0.0001			
SO ₃ , Avg. of Blank Titrations	0.01	milliliters	0.01			
SO ₃ , Run #6, Avg. of Titrations	4.28	milliliters	0.01			
SO ₃ , Run #7, Avg. of Titrations	3.53	milliliters	0.01			
SO ₃ , Run #8, Avg. of Titrations	3.18	milliliters	0.01			
SO ₃ , Run #9, Avg. of Titrations	3.90	milliliters	0.01			
SO ₃ , Volume of Contained Sample	500	milliliters	1			
SO ₃ , Volume of Sample Aliquot	100	milliliters	0.1			

Comments:

Robert Dorey,
Supervisor of Laboratory Services



**Corporate Environmental
Laboratory Services**

5012 Causeway Blvd * Tampa Fl. 33619 * Ph (813)630-7378 * Fax (813)630-7360 * CompQAP #910140G * DOH #E54272

Report For: David Smith, Air Programs

Report Date: 04/28/00

Laboratory ID: AA54565

Sample Information

Location Code: SPECL-PK

Sampled By: AIR PROGRAMS

Location Description: Polk Power Plant

Date Sampled: 04/26/00

Project Account Code: L16

Time Sampled: 12:00:00 AM

SAMPLE DESCRIPTION:

60/40 PETCOKE BLEND

Laboratory Results

Parameter	Result	Units	MDL	Lower Limit	Upper Limit	Violation Check
Normality of BaCl ₂ * 2H ₂ O	0.0101		0.0001			
SO ₃ , Avg. of Blank Titrations	0.01	milliliters	0.01			
SO ₃ , Run #10, Avg. of Titrations	3.13	milliliters	0.01			
SO ₃ , Run #11, Avg. of Titrations	3.35	milliliters	0.01			
SO ₃ , Volume of Contained Sample	500	milliliters	1			
SO ₃ , Volume of Sample Aliquot	100	milliliters	0.1			

Comments:

Robert Dorey,
Supervisor of Laboratory Services

APPENDIX C

COMBUSTION TURBINE OPERATION DATA

C-1 BASELINE OPERATIONAL DATA

C-2 FUEL BLEND OPERATIONAL DATA

C-1 BASELINE OPERATIONAL DATA

Baseline

POLK POWER STATION DCS DATA

Date	Time	Fuel To Slurry Preparation	Combustion Turbine Output (MW)	Net Output Generation (MW)	Diluent N2 To Turbine (KSCFH)	Fuel Flow To Turbine (KSCFH)	Fuel LHV To Turbine (BTU/SCF)	Fuel HHV To Turbine (BTU/SCF)	Fuel HHV To Turbine (MMBTU/Hr)	NOx Emissions (Lb/Hr)	NOx Emissions (lb/MMBTU)	SO2 Emissions (Lb/Hr)	SO2 Emissions (lb/MMBTU)	Opacity %
02/07/00	10:00	Kentucky 9	191.8	248.7	5793	6607	247.2	267.7	1768	173.264	0.098	247.52	0.140	0.6
02/07/00	11:00	Kentucky 9	191.8	249.1	5816.0	6622	247.5	268	1774	175.626	0.099	266.1	0.150	1.3
02/07/00	12:00	Kentucky 9	191.8	251.0	5838.0	6623	247.4	267.8	1774	177.4	0.100	301.58	0.170	1.9
02/07/00	13:00	Kentucky 9	191.8	250.2	5852.0	6626	246.8	267.1	1770	178.77	0.101	300.9	0.170	1.6
02/07/00	14:00	Kentucky 9	191.8	249.9	5865.0	6642	245.7	265.8	1765	180.03	0.102	335.35	0.190	2.1
02/07/00	15:00	Kentucky 9	191.8	251.8	5859.0	6655	245.2	265.1	1764	179.928	0.102	335.16	0.190	2.3
02/07/00	16:00	Kentucky 9	191.8	251.6	5852.0	6662	244.8	264.6	1762	181.486	0.103	334.78	0.190	2.9
02/07/00	17:00	Kentucky 9	191.8	252.4	5843.0	6650	245	264.8	1761	177.861	0.101	352.2	0.200	1.5
02/07/00	18:00	Kentucky 9	191.8	251.1	5836.0	6642	245.5	265.3	1762	174.438	0.099	352.4	0.200	1.6
02/07/00	19:00	Kentucky 9	191.8	250.8	5832.0	6633	245.4	265.1	1759	172.382	0.098	316.62	0.180	1.1
02/08/00	8:00	Kentucky 9	191.3	251.1	5816.0	6718	243.5	263.4	1770	141.6	0.080	460.2	0.260	0.9
02/08/00	9:00	Kentucky 9	190.0	250.7	5832.0	6682	243.8	263.8	1763	142.803	0.081	282.08	0.160	0.8
02/08/00	10:00	Kentucky 9	190.0	249.1	5872.0	6677	244.1	264.2	1764	142.884	0.081	299.88	0.170	1.2
02/08/00	11:00	Kentucky 9	190.0	249.2	5896.0	6679	244.2	264.4	1766	144.812	0.082	282.56	0.160	1
02/08/00	12:00	Kentucky 9	190.0	249.6	5917.0	6681	244	264.3	1766	150.11	0.085	264.9	0.150	0.8
02/08/00	13:00	Kentucky 9	190.1	249.5	5937.0	6685	243.3	263.5	1761	149.685	0.085	281.76	0.160	0.5
02/08/00	14:00	Kentucky 9	190.0	249.9	5938.0	6672	243.4	263.6	1759	151.274	0.086	281.44	0.160	0.9
02/08/00	15:00	Kentucky 9	189.9	249.4	5927.0	6658	241.7	264.1	1758	154.704	0.088	298.86	0.170	0.9
		Average	191.1	250.3	5862.3	6656	244.9	265.1	1765	164	0.093	311	0.176	1.3

C-2 FUEL BLEND OPERATIONAL DATA

Blend 60%

POLK POWER STATION DCS DATA

Date	Time	Fuel To Slurry Preparation	Combustion Turbine Output (MW)	Net Output Generation (MW)	Diluent N2 To Turbine (KSCFH)	Fuel Flow To Turbine (KSCFH)	Fuel LHV To Turbine (BTU/SCF)	Fuel HHV To Turbine (BTU/SCF)	Fuel HHV To Turbine (MMBTU/Hr)	NOx Emissions (Lb/Hr)	NOx Emissions (lb/MMBTU)	SO2 Emissions (Lb/Hr)	SO2 Emissions (lb/MMBTU)	Opacity %
04/24/00	9:00	60% Pet Coke	191.8	251.2	5887	6481	251.1	269.5	1747	191.7	0.110	197.5	0.113	3.4
04/24/00	10:00	60% Pet Coke	191.8	251.7	5865	6493	250.9	269.3	1749	195.1	0.112	208.4	0.119	3.1
04/24/00	11:00	60% Pet Coke	191.8	252.0	5863	6510	250.7	269.0	1751	198.9	0.114	235.5	0.134	3.7
04/24/00	12:00	60% Pet Coke	191.8	251.5	5991	6498	250.7	269.0	1748	185.7	0.106	241.0	0.138	3.7
04/24/00	13:00	60% Pet Coke	191.7	251.1	6143	6484	251.0	269.4	1747	184.6	0.106	243.8	0.140	3.9
04/24/00	14:00	60% Pet Coke	191.8	251.0	6272	6476	250.9	269.3	1744	174.9	0.100	236.5	0.136	4.0
04/24/00	15:00	60% Pet Coke	191.8	250.4	6287	6467	251.2	269.6	1743	166.0	0.095	241.3	0.138	4.1
04/24/00	16:00	60% Pet Coke	191.8	250.0	6284	6455	251.4	269.8	1742	160.6	0.092	236.6	0.136	4.2
04/24/00	17:00	60% Pet Coke	191.8	250.0	6281	6449	251.4	269.9	1741	158.9	0.091	231.3	0.133	4.3
04/24/00	18:00	60% Pet Coke	191.8	249.9	6278	6448	251.5	269.9	1740	160.0	0.092	237.4	0.136	4.3
04/25/00	12:00	60% Pet Coke	190.3	247.7	6301	6410	250.8	269.1	1725	155.3	0.090	245.2	0.142	5.4
04/25/00	13:00	60% Pet Coke	191.7	249.7	6332	6438	251.3	269.7	1736	156.5	0.090	240.4	0.138	5.3
04/25/00	14:00	60% Pet Coke	191.7	249.2	6362	6426	251.8	270.3	1737	161.5	0.093	244.4	0.141	5.3
04/25/00	15:00	60% Pet Coke	191.7	248.9	6392	6423	251.8	270.3	1736	161.8	0.093	250.2	0.144	5.4
04/25/00	16:00	60% Pet Coke	191.8	249.3	6423	6416	252.2	270.7	1737	164.0	0.094	254.8	0.147	5.6
04/25/00	17:00	60% Pet Coke	191.8	249.0	6450	6411	252.6	271.1	1738	162.6	0.094	253.4	0.146	5.9
04/25/00	18:00	60% Pet Coke	191.8	248.6	6444	6402	253.1	271.6	1739	160.8	0.092	249.1	0.143	5.4
04/25/00	19:00	60% Pet Coke	191.7	248.4	6428	6396	253.2	271.8	1738	157.7	0.091	239.4	0.138	5.3
04/26/00	10:00	60% Pet Coke	191.8	246.1	6584	6406	251.9	270.4	1732	158.7	0.092	185.5	0.107	2.9
04/26/00	11:00	60% Pet Coke	191.8	246.6	6603	6420	251.7	270.3	1735	158.4	0.091	191.7	0.110	3.0
04/26/00	12:00	60% Pet Coke	191.8	247.2	6622	6419	251.8	270.4	1736	156.6	0.090	194.2	0.112	3.4
		Average	191.7	249.5	6290.2	6444.2	251.6	270.0	1740.1	168.1	0.097	231.3	0.133	4.4

APPENDIX D

CONTINUOUS EMISSION MONITORING SYSTEM DATA

- D-1 BASELINE CEMS STACK TEST LOGS**
- D-2 FUEL BLEND CEMS STACK TEST LOGS**
- D-3 CONTINUOUS EMISSIONS RELATIVE
ACCURACY TEST AUDIT RESULTS 1999**
- D-4 CONTINUOUS EMISSIONS QUALITY
ASSURANCE LINEARITY CHECKS - QUARTER 1,
2000**

D-1 BASELINE CEMS STACK TESTS LOGS

Polk Station
HRSG
Tampa

Today's Date: 05/11/2000
Time: 05:10:44

Reporting Period
Day: 02/07/2000

DAILY EPA CEM SUMMARY

Time	CO2 %	SO2 ppm	SO2 lb/mmBtu	SO2 lb/hr	NOX ppm	NOX lb/mmBtu	FLOW kscfh	Ht Inp mmBtu
100	8	30.1	0.14	265.7	28.2	0.097	53172	1841
200	8	28.2	0.14	245.4	28.3	0.098M	52416M	1815
300	8	27.1	0.13	239.1	28.1	0.097	53160	1841
400	8	27.6	0.13	239.3	28.2	0.097	52230	1808
500	8	26.9	0.13	235.3	29	0.1	52692	1824
600	8	27.2	0.13	231.4	28.8	0.099	51252	1774
700	8	27.4	0.13	238	28.8	0.099	52326	1812
800	8.1	28.2	0.13	243.9	28.7	0.098	52104	1827
900	8.1	28.7	0.14	245	28.8	0.098	51432	1803
1000	8.1	30.9	0.15	272.8	29.2	0.099	53184	1864
1100	8.1	35	0.17	315.6	29.3	0.1	54312	1904
1200	8.1	36	0.17	342.3	29.6	0.101	57282	2008
1300	8	38.8	0.19	356.2	29.6	0.102	55296	1915
1400	8.1	40	0.19	363.9	30.1	0.102	54804	1921
1500	8.1	39.9	0.19	358.3	30.3	0.103	54090	1896
1600	8.1	41.8	0.2	377.9	29.7	0.101	54468	1909
1700	8.1	42.8	0.2	386.6	29	0.099M	54408M	1907
1800	8.2	38.9	0.18	339	29.1	0.098	52494	1863
1900	8.1	34.8	0.16	307.5	28.6	0.097	53238	1866
2000	8.2	35.8	0.17	315.5	28.4	0.096	53094	1884
2100	8.2	32.8	0.15	288.4	27.8	0.094	52962	1880
2200	8.2	30.9	0.14	272.7	27.2	0.091	53166	1887
2300	8.2	29.3	0.14	227.5	27.1	0.091M	46770M	1660
2400	8.1	31.6	0.15	257.2	27	0.092	49026	1719
AVRGE	8.1	32.9	0.156	290.2	28.7	0.098	52891	1852

Daily SO2 3.5 Tons
Daily CO2 5851.6 Tons

Legend
C - Out of Control
F - Fans Off
D - Out of Service
I - Insufficient Data
M - Maintenance Fault
A - Calibration Error

Polk Station
 HRSG
 Tampa

Today's Date: 05/11/2000
 Time: 05:11:10

Reporting Period
 Day: 02/08/2000

DAILY EPA CEM SUMMARY

Time	CO2 %	SO2 ppm	SO2 lb/mmBtu	SO2 lb/hr	NOX ppm	NOX lb/mmBtu	FLOW kscfh	Ht Inp mmBtu
100	8.1	32.2	0.15	283.4	26.5	0.090M	53028M	1859
200	8.1	31.6	0.15	266	26.6	0.091	50712	1778
300	8.2	31.7	0.15	277.3	26.4	0.089M	52698M	1870
400	8.2	37.9	0.18	345.1	25.8	0.087	54858	1947
500	8.2	48.8	0.23	475.4	24.8	0.083	58686	2083
600	8.2	64.1	0.3	617.5	24.2	0.081	58032	2060
700	8.2	55.5	0.26	443.2	23.9	0.080M	48108M	1707
800	8.2	34.6	0.16	303.2	24.2	0.081	52794	1874
900	8.2	36.1	0.17	327.3	24.2	0.081	54624	1939
1000	8.2	33.7	0.16	304.9	24.4	0.082	54498	1934
1100	8.2	32.5	0.15	292.3	25.2	0.085	54174	1923
1200	8.2	33.6	0.16	301.7	25.4	0.085	54096	1920
1300	8.1	33.8	0.16	357.4	25.3	0.086M	63690M	2233
1400	8.2	36.2	0.17	323.5	26.3	0.088	53826	1910
1500	8.2	36.4	0.17	324.3	27	0.091	53670	1905
1600	8.2	32.7	0.15	292.5	27.6	0.093M	53892M	1913
1700	7.6	31.6	0.16	256.7	25.6	0.093M	48936M	1610
1800	0	0	0	0	0	0.000M	0M	0
1900	0	0	0	0	0	0	0	0
2000	0	0	0	0	0	0	0	0
2100	0	0	0	0	0	0	0	0
2200	0	0	0	0	0	0	0	0
2300	0	0	0	0	0	0	0	0
2400	0	0	0	0	0	0	0	0
AVRGE	5.8	26.8	0.126	241.3	18.1	0.061	38347	1353

Daily SO2 2.9 Tons
 Daily CO2 4275.3 Tons

- Legend
 C - Out of Control
 F - Fans Off
 D - Out of Service
 I - Insufficient Data
 M - Maintenance Fault
 A - Calibration Error

D-2 FUEL BLEND CEMS STACK TEST LOGS

=====

Polk Station
HRSG
Tampa

=====

Today's Date: 05/11/2000
Time: 05:11:32

Reporting Period
Day: 04/24/2000

DAILY EPA CEM SUMMARY

Time	CO2 %	SO2 ppm	SO2 lb/mmBtu	SO2 lb/hr	NOX ppm	NOX lb/mmBtu	FLOW kscfh	Ht Inp mmBtu
100	7.8	32.3	0.16	0	31.3	0.111C	0C	0
200	7.9	37.6	0.18	0	31.1	0.109C	0C	0
300	7.9	38.7	0.19	0	31.6	0.110C	0C	0
400	7.9	38.8	0.19	0	31.3	0.109C	0C	0
500	7.9	39.8	0.19	0	31	0.108C	0C	0
600	7.9	39	0.19	0	31.1	0.109C	0C	0
700	7.9	24.9	0.12	0	30.6	0.107C	0C	0
800	7.9	22.6	0.11	0	30.8	0.108C	0C	0
900	8	22.9	0.11	0	31.1	0.107C	0C	0
1000	7.9	24	0.12	0	31.5	0.110C	0C	0
1100	7.9	26.5	0.13	0	31.5	0.110C	0C	0
1200	7.9	27.5	0.13	0	29.9	0.104C	0C	0
1300	7.8	28	0.14	0	29.2	0.103C	0C	0
1400	7.9	27.7	0.13	0	28.5	0.100C	0C	0
1500	7.9	28	0.14	0	27.1	0.095C	0C	0
1600	7.9	27.9	0.14	0	26.2	0.091C	0C	0
1700	7.9	27.3	0.13	0	25.9	0.090C	0C	0
1800	7.9	27.8	0.13	0	25.7	0.090C	0C	0
1900	7.9	27.4	0.13	0	25.5	0.089C	0C	0
2000	7.9	28	0.14	0	25.6	0.089C	0C	0
2100	7.9	29.9	0.15	0	25.1	0.088C	0C	0
2200	7.9	30.9	0.15	0	24.8	0.087C	0C	0
2300	7.9	29.4	0.14	0	25.3	0.088C	0C	0
2400	7.9	29.8	0.14	0	25.5	0.089C	0C	0
AVRGE	7.9	29.9	0.145	0	28.6	0.1	0	0

Daily SO2 0.0 Tons
Daily CO2 0.0 Tons

- Legend
- C - Out of Control
 - F - Fans Off
 - D - Out of Service
 - I - Insufficient Data
 - M - Maintenance Fault
 - A - Calibration Error

=====

Polk Station
HRSG
Tampa

=====

Today's Date: 05/11/2000
Time: 05:11:48

Reporting Period
Day: 04/25/2000

DAILY EPA CEM SUMMARY

Time	CO2 %	SO2 ppm	SO2 lb/mmBtu	SO2 lb/hr	NOX ppm	NOX lb/mmBtu	FLOW kscfh	Ht Inp mmBtu
100	7.9	30.6	0.15	0	25	0.087C	0C	0
200	7.9	32.6	0.16	0	24.8	0.087C	0C	0
300	7.9	34.2	0.17	0	24.4	0.085C	0C	0
400	8	37.3	0.18	0	23.9	0.082C	0C	0
500	8	43.7	0.21	0	23	0.079C	0C	0
600	8	49.7	0.24	0	22.7	0.078C	0C	0
700	7.9A	40.0A	0.19	0	21.6A	0.075C	0C	0
800	7.9	32.8	0.16	0	23.1	0.081C	0C	0
900	7.9	29.9	0.15	0	24.3	0.085C	0C	0
1000	7.9	30	0.15	0	24.2	0.084C	0C	0
1100	7.9	29.8	0.14	0	24.7	0.086C	0C	0
1200	7.9	29	0.14	0	25.3	0.088C	0C	0
1300	7.9	28.5	0.14	0	25.5	0.089C	0C	0
1400	7.9	28.7	0.14	0	26.1	0.091C	0C	0
1500	7.9	29.1	0.14	0	26.2	0.091C	0C	0
1600	7.9	29.4	0.14	0	26.3	0.092C	0C	0
1700	7.8	29.6	0.15	0	26.2	0.093C	0C	0
1800	7.8	29.5	0.15	0	26.1	0.092C	0C	0
1900	7.8	29	0.14	0	26	0.092C	0C	0
2000	7.7	26.8	0.13	0	25.6	0.092C	0C	0
2100	7.7	26.4	0.13	0	25.3	0.091C	0C	0
2200	7.7	26.9	0.13	0	25	0.090C	0C	0
2300	7.7	28.6	0.14	0	24.9	0.089C	0C	0
2400	7.7	29	0.14	0	25	0.090C	0C	0
AVRGE	7.9	31.7	0.155	0	24.8	0.087	0	0

Daily SO2 0.0 Tons
Daily CO2 0.0 Tons

- Legend
- C - Out of Control
 - F - Fans Off
 - D - Out of Service
 - I - Insufficient Data
 - M - Maintenance Fault
 - A - Calibration Error

Polk Station
HRSG
Tampa

Today's Date: 05/11/2000
Time: 05:12:13

Reporting Period
Day: 04/26/2000

DAILY EPA CEM SUMMARY

Time	CO2 %	SO2 ppm	SO2 lb/mmBtu	SO2 lb/hr	NOX ppm	NOX lb/mmBtu	FLOW kscfh	Ht Inp mmBtu
100	7.7	29.6	0.15	0	24.7	0.088C	0C	0
200	7.7	29.9	0.15	0	25.2	0.090C	0C	0
300	7.7	30.4	0.15	0	25.4	0.091C	0C	0
400	7.7	30.4	0.15	0	25.2	0.090C	0C	0
500	7.7	30.2	0.15	0	25.3	0.091C	0C	0
600	7.7	29.7	0.15	0	25.1	0.090C	0C	0
700	7.6	27.6	0.14	0	24.5	0.089C	0C	0
800	7.7	25.1	0.12	0	24.5	0.088C	0C	0
900	7.7	23	0.11	0	24.6	0.088C	0C	0
1000	7.7	21	0.1	0	24.7	0.088C	0C	0
1100	7.7	21.3	0.11	0	24.4	0.087C	0C	0
1200	7.7	22	0.11	0	24.8	0.089C	0C	0
1300	7.7	22.9	0.11	0	24.8	0.089C	0C	0
1400	7.7	24.1	0.12	0	24.8	0.089C	0C	0
1500	7.8	24.3	0.12	0	25.2	0.089C	0C	0
1600	7.8	24.2	0.12	0	25.3	0.089C	0C	0
1700	7.8	24.2	0.12	0	25.2	0.089C	0C	0
1800	7.8	23.8	0.12	0	24.9	0.088C	0C	0
1900	7.7	23.5	0.12	0	24.8	0.089C	0C	0
2000	7.7	22.7	0.11	0	24.5	0.088C	0C	0
2100	7.7	20.7	0.1	0	23.9	0.086C	0C	0
2200	7.7	22.3	0.11	0	24.1	0.086C	0C	0
2300	7.7	24.7	0.12	0	24.1	0.086C	0C	0
2400	7.7	26.6	0.13	0	24	0.086C	0C	0
AVRGE	7.7	25.2	0.125	0	24.8	0.088	0	0

Daily SO2 0.0 Tons
Daily CO2 0.0 Tons

- Legend
 C - Out of Control
 F - Fans Off
 D - Out of Service
 I - Insufficient Data
 M - Maintenance Fault
 A - Calibration Error

**D-3 CONTINUOUS EMISSIONS RELATIVE
ACCURACY TEST AUDIT RESULTS - 1999**

SUBJECT: Continuous Emissions Monitoring (CEM) Systems
Relative Accuracy Test Audit Results

TO: David Knapp

FROM: Robert Barthelette Jr.

DATE: 27, October, 1999

Corporate Environmental Services, Air Services Group, performed a Relative Accuracy Test Audit (RATA) on combustion turbine HRSG CEMS (001) September 7 through September 9, 1999. This audit was conducted in accordance with the system supplier's directions, and meet the requirements of 40 CFR 75, Appendix B.

All results were deemed acceptable, meeting the performance specifications of 40 CFR 75, Appendix A, Performance Specification 3.31, 3.32, 3.33, & 3.34.

Attached to this memorandum, you will find data summary sheets for each system tested. All testing was performed under my direction, and the results are certified as true and accurate.

These records should be maintained at your facility for a period of three (3) years to comply with 40 CFR 75, Appendix F, Record Keeping Requirements. Corporate Environmental Services will maintain all supporting information for this test for the same time period.

Should you have any questions regarding this information, feel free to contact me at extension 38227.

Robert A. Barthelette Jr.
Technician
Corporate Environmental Services
Air Services

cc: J. Nail
J. Woodlee
D. Coleman
D. Smith



RELATIVE ACCURACY TEST AUDIT DATA SUMMARY

Plant: **POLK POWER STATION**

Unit: **HRSO PRIMARY**

Plant ORIS Code: **7242**

Boiler or Stack ID: **#1**

Test Date: **09/7&9/99**

Run Number	Start Time	End Time	RM - 6C SO2 ppm	CEM SO2 ppm	Difference ppm	RM - 7E/3A NOx lbs/Mmbtu	CEM NOx lbs/Mmbtu	Difference lbs/MMBtu	RM- 3A CO2 %	CEM CO2 %	Difference %	Run Flag
1	1847	1908	12.600	12.481	0.119	0.078	0.074	0.004	7.640	8.262	-0.622	1
2	1937	1958	13.200	13.096	0.104	0.075	0.073	0.002	7.740	8.354	-0.614	1
3	2014	2035	13.700	12.838	0.862	0.077	0.073	0.004	7.900	8.366	-0.466	0
4	2104	2125	13.800	12.714	1.086	0.076	0.073	0.003	7.890	8.399	-0.509	0
5	0719	0740	9.300	8.877	0.423	0.08	0.078	0.002	7.890	8.201	-0.311	1
6	0819	0840	9.600	8.654	0.946	0.08	0.079	0.001	7.900	8.207	-0.307	0
7	0915	0936	9.500	8.698	0.802	0.083	0.082	0.001	7.860	8.135	-0.275	1
8	1001	1022	8.700	9.117	-0.417	0.081	0.083	-0.002	7.770	8.136	-0.366	1
9	1048	1109	8.500	8.935	-0.435	0.083	0.086	-0.003	7.790	8.064	-0.274	1
10	1130	1151	8.700	9.008	-0.308	0.085	0.086	-0.001	7.630	8.072	-0.442	1
11	1209	1230	8.2	8.724	-0.524	0.084	0.087	-0.003	7.760	8.074	-0.314	1
12	1255	1316	8.1	8.492	-0.392	0.083	0.087	-0.004	7.810	8.021	-0.211	1
Means of Accepted:			9.644	9.714	-0.070	0.081	0.082	0.000	7.766	8.147	-0.381	
Standard Deviations (n-1) of Differences:					0.460			0.003			0.149	

SO2 Confidence Coefficient:	0.353	Number of Valid Runs:	9
SO2 Relative Accuracy:	4.35	T-value:	2.306

SO2 Bias Test:	Passed
SO2 Bias Adjustment Factor:	1.000
NOx Confidence Coefficient:	0.002
NOx Relative Accuracy:	3.16
NOx Bias Test:	Passed
NOx Bias Adjustment Factor:	1.000
CO2 Confidence Coefficient:	0.114
CO2 Relative Accuracy:	6.08

CEM RACK
 SO2 Analyzer S/N: 43B-48910-282
 NOx Analyzer S/N: 42D-53124-294
 CO2 Analyzer S/N: EN-029

SUBJECT: Continuous Emissions Monitoring (CEM) Systems
Relative Accuracy Test Audit Results

TO: David Knapp

FROM: Robert Barthelette Jr.

DATE: 16, December 1999

Corporate Environmental Services, Air Services Group, performed a Relative Accuracy Test Audit (RATA) on combustion turbine HRSG CEMS (001) on November 8 through November 16, 1999. These audits were conducted in accordance with the system supplier's directions, and meet the requirements of 40 CFR 75, Appendix B.

All results were deemed acceptable, meeting the performance specifications of 40 CFR 75, Appendix A, Performance Specification 3.34.

Attached to this memorandum, you will find data summary sheets for each system tested. All testing was performed under my direction, and the results are certified as true and accurate.

These records should be maintained at your facility for a period of three (3) years to comply with 40 CFR 75, Appendix F, Record Keeping Requirements. Corporate Environmental Services will maintain all supporting information for this test for the same time period.

Should you have any questions regarding this information, feel free to contact me at extension 38227.

Robert A. Barthelette Jr.
Technician
Corporate Environmental Services
Air Services

cc: J. Nail
J. Woodlee
D. Coleman
D. Smith

CEMS Flow Rate Relative Accuracy

Plant Name: POLK POWER STATION

Unit #: 1

Date: 11/16/99

Load: HIGH,192MW

Run #	Start Time	End Time	Reference Method Data	Source Data		Difference
			Flow Rate (scfh)	Unit Load	CEMS Flow Rate (scfh)	CEMS Flow Rate (scfh)
1	12:07	12:21	49548678.000	191.104	53104560.000	-3555882.000
2	12:22	12:33	49451007.000	191.306	49797120.000	-346113.000
3	12:34	12:44	49640552.000	191.084	51307380.000	-1666828.000
4	12:45	12:56	50082886.000	191.173	52852980.000	-2770094.000
5	12:57	13:10	49720685.000	191.222	51809940.000	-2089255.000
6	13:12	13:24	49747758.000	191.189	51581820.000	-1834062.000
7	13:24	13:34	49679427.000	191.218	51745140.000	-2065713.000
8	13:36	13:47	49949132.000	191.314	52079700.000	-2130568.000
9	13:48	13:58	49822211.000	191.176	53990940.000	-4168729.000
* 10	0:00	0:00				
* 11	0:00	0:00				
* 12	0:00	0:00				
Arithmetic Mean:			49738037.333	191.198	52029953.333	-2291916.000
			$R_{rel} =$	2.601	Standard Deviation:	1109812.954
					Confidence Coefficient:	853076.224
					Relative Accuracy (%):	6.32
					Bias Adjustment Factor:	1.000
					T-Value:	2.306

* Runs not included in Relative Accuracy Calculator

CEMS Flow Rate Relative Accuracy

Plant Name: POLK POWER STATION
 Unit #: 1
 Date: 11/11/99
 Load: MID,180

Run #	Start Time	End Time	Reference Method Data	Source Data	Difference
			Flow Rate (scfh)	CEMS Flow Rate (scfh)	CEMS Flow Rate (scfh)
1	14:55	15:12	47000135.000	49091460.000	-2091325.000
2	15:17	15:29	46830213.000	49268160.000	-2437947.000
3	15:30	15:42	47483042.000	48638220.000	-1155178.000
4	15:44	15:56	47688787.000	49946340.000	-2257553.000
5	15:58	16:10	47403358.000	49539660.000	-2136302.000
6	16:14	16:24	47520527.000	49007520.000	-1486993.000
7	16:26	16:35	47786355.000	50421060.000	-2634705.000
8	16:36	16:45	48080908.000	50286960.000	-2206052.000
9	16:47	16:56	47565053.000	48331080.000	-766027.000
* 10	0:00	0:00	#DIV/0!	0.000	#DIV/0!
* 11	0:00	0:00	#DIV/0!	0.000	#DIV/0!
* 12	0:00	0:00	#DIV/0!	0.000	#DIV/0!
Arithmetic Mean:			47484264.222	49392273.333	-1908009.111
				Standard Deviation:	627872.033
				Confidence Coefficient:	482624.303
				Relative Accuracy (%):	5.03
				Bias Adjustment Factor:	1.000
				T-Value:	2.306
* Runs not included in Relative Accuracy Calculaton					

CEMS Flow Rate Relative Accuracy

Plant Name: POLK POWER STATION
 Unit #: 1
 Date: 11/16/99
 Load: LOW,165 MW

Run #	Start Time	End Time	Reference Method Data	Source Data	Difference
			Flow Rate (scfh)	CEMS Flow Rate (scfh)	CEMS Flow Rate (scfh)
1	8:27	8:39	46397799.000	48139560.000	-1741761.000
2	8:40	8:50	46610216.000	47565840.000	-955624.000
3	8:52	9:03	46598399.000	45584400.000	1013999.000
4	9:17	9:29	46147705.000	47698500.000	-1550795.000
5	9:30	9:41	46117811.000	47575020.000	-1457209.000
6	9:42	9:52	46076884.000	47006340.000	-929456.000
7	10:00	10:10	46027076.000	46789980.000	-762904.000
8	10:11	10:23	46604078.000	46296480.000	307598.000
9	10:24	10:35	46240982.000	48306300.000	-2065318.000
* 10	0:00	0:00	#DIV/0!	0.000	#DIV/0!
* 11	0:00	0:00	#DIV/0!	0.000	#DIV/0!
* 12	0:00	0:00	#DIV/0!	0.000	#DIV/0!
Arithmetic Mean:			46313438.889	47218046.667	-904607.778
				Standard Deviation:	996543.692
				Confidence Coefficient:	766009.918
				Relative Accuracy (%):	3.61
				Bias Adjustment Factor:	1.000
				T-Value:	2.306

* Runs not included in Relative Accuracy Calculator

**D-4 CONTINUOUS EMISSIONS QUALITY ASSURANCE LINEARITY
CHECKS - QUARTER 1, 2000**

Polk Station

HRSG Start Time: _____ Date: _____ End Time: _____ Date: _____

Analyzer SO2	LOW	MID	HIGH
-----	---	---	----
REF GAS VALUE	22.87	55.97	91.36
DATE	03/29/2000	03/29/2000	03/29/2000
TIME	16:33	16:40	16:52
RUN 1	21.60	52.05	88.53
DATE	03/29/2000	03/29/2000	03/29/2000
TIME	17:16	17:24	17:32
RUN 2	24.20	58.03	90.83
DATE	03/29/2000	03/29/2000	03/29/2000
TIME	17:41	17:49	17:57
RUN 3	24.01	57.13	90.80
AVERAGE=SUM/3	23.27	55.74	90.05
% ACCURACY	0.40	0.23	1.31
OUT OF CONTROL	NO	NO	NO
SERIAL NUMBER	ALM 010535	ALM 045236	ALM 049904
EXPIRATION DATE	09/02/2000	03/03/2002	03/03/2002

Analyzer NOX	LOW	MID	HIGH
-----	---	---	----
REF GAS VALUE	24.88	54.03	89.31
DATE	03/29/2000	03/29/2000	03/29/2000
TIME	16:33	16:40	16:52
RUN 1	26.44	58.28	92.38
DATE	03/29/2000	03/29/2000	03/29/2000
TIME	17:16	17:24	17:32
RUN 2	26.07	56.31	89.83
DATE	03/29/2000	03/29/2000	03/29/2000
TIME	17:41	17:49	17:57
RUN 3	25.71	55.80	89.23
AVERAGE=SUM/3	26.07	56.80	90.48
% ACCURACY	1.19	2.77	1.17
OUT OF CONTROL	NO	NO	NO
SERIAL NUMBER	ALM 010535	ALM 045236	ALM 049904
EXPIRATION DATE	09/02/2000	03/03/2002	03/03/2002

Analyzer CO2	LOW	MID	HIGH
-----	---	---	----
REF GAS VALUE	3.46	7.72	12.54
DATE	03/29/2000	03/29/2000	03/29/2000
TIME	16:33	16:40	16:52
RUN 1	3.52	7.67	12.40
DATE	03/29/2000	03/29/2000	03/29/2000
TIME	17:16	17:24	17:32
RUN 2	3.56	7.71	12.41
DATE	03/29/2000	03/29/2000	03/29/2000
TIME	17:41	17:49	17:57
RUN 3	3.59	7.71	12.44
AVERAGE=SUM/3	3.56	7.70	12.42
% ACCURACY	0.10	0.02	0.96
OUT OF CONTROL	NO	NO	NO
SERIAL NUMBER	ALM 010535	ALM 045236	ALM 049904
EXPIRATION DATE	09/02/2000	03/03/2002	03/03/2002

APPENDIX E

FUEL ANALYSIS

- E-1 BASELINE COMPOSITE**
- E-2 FUEL BLEND COMPOSITES**

E-1 BASELINE COMPOSITE



**Corporate Environmental
Laboratory Services**

5012 Causeway Blvd * Tampa, Fl. 33619 * Ph (813)630-7378 * Fax (813)630-7360 * CompQAP #910140G * DOH #E54272

Parameter	Results	Units
Aluminum Oxide, Al ₂ O ₃	18.07	%
Hydrogen, Dry Basis	4.97	%
Iron Oxide, Fe ₂ O ₃	19.28	%
Magnesium Oxide, MgO	1.00	%
Nitrogen, as Received	1.39	%
Nitrogen, Dry Basis	1.60	%
Oxygen, as Received	6.27	%
Oxygen, Dry Basis	7.19	%
Phosphorus, P ₂ O ₅	0.09	%
Potassium Oxide, K ₂ O	2.40	%
Pounds SO ₂ / Million BTU	4.84	Lbs. SO ₂ /MMBTU
Silica Value	66.3	%
Silicon Dioxide, SiO ₂	50.79	%
Sodium Oxide, Na ₂ O	0.81	%
Sulfur in Ash	1.56	%
Sulfur Trioxide, SO ₃	3.90	%
Sulfur, as Received	2.88	%
Sulfur, Dry Basis	3.31	%
Titanium Dioxide, TiO ₂	1.00	%
Total Moisture	12.9	%
Volatiles, as Received	34.01	%
Volatiles, Dry Basis	39.05	%

Comments:



Robert E. Dorey
Supervisor of Laboratory Services

Analyses reported by this laboratory are based upon material supplied by the client. Laboratory Services does not imply that the contents of the sample received by this laboratory are the same as all such material in the environment from which the sample was taken. Our results relate only to the sample or samples as tested. Tampa Electric assumes no responsibility and makes no warranty or representation, express or implied, as to the suitability of the sample material for any specific use.

E-2 FUEL BLEND COMPOSITES



John McDaniel, Polk
Martin Duff, Fuels

Report Date: 5/11/00

Laboratory ID: AA54434

Location Polk Power Plant

Sampled By: CTE, ST. ROSE

Description:

Location Code: SPECL-PK

Date Sampled: 04/13/00

Sample Description: PET COKE TEST BURN AT
POLK

Time Sampled: 00:00

Date Received: 04/14/00

ANALYTICAL RESULTS

Parameter	Results	Units
Ash Fusion, FT, Reducing	2390	Degrees F
Ash Fusion, HT, Reducing	2340	Degrees F
Ash Fusion, IT, Reducing	2270	Degrees F
Ash Fusion, ST, Reducing	2290	Degrees F
Ash, as Received	3.90	%
Ash, Dry Basis	4.19	%
BTU, as Received	13535	BTU/Lb
BTU, Dry Basis	14551	BTU/Lb.
BTU, Moisture-Ash Free	15187	BTU/Lb.
Calcium Oxide, CaO	6.10	%
Carbon, as Received	77.51	%
Carbon, Dry Basis	83.33	%
Chlorine , as Received	0.08	%
Chlorine , Dry Basis	0.09	%
Fixed Carbon, as Received	67.17	%
Fixed Carbon, Dry Basis	72.21	%
Hardgrove Grindability Index	55	HGI

Analyses reported by this laboratory are based upon material supplied by the client. Laboratory Services does not imply that the contents of the sample received by this laboratory are the same as all such material in the environment from which the sample was taken. Our results relate only to the sample or samples as tested. Tampa Electric assumes no responsibility and makes no warranty or representation, express or implied, as to the suitability of the sample material for any specific use.



Corporate Environmental
Laboratory Services

5012 Causeway Blvd * Tampa, FL 33619 * Ph (813)630-7378 * Fax (813)630-7360 * CompQAP #910140G * DOH #E54272

Parameter	Results	Units
Aluminum Oxide, Al ₂ O ₃	21.87	%
Hydrogen, as Received	4.14	%
Hydrogen, Dry Basis	4.45	%
Iron Oxide, Fe ₂ O ₃	12.73	%
Magnesium Oxide, MgO	0.97	%
Nitrogen, as Received	1.82	%
Nitrogen, Dry Basis	1.96	%
Oxygen, as Received	2.69	%
Oxygen, Dry Basis	2.88	%
Phosphorus, P ₂ O ₅	0.37	%
Potassium Oxide, K ₂ O	1.41	%
Pounds of Ash / Million BTU	2.877	Lbs./MMBTU
Pounds SO ₂ / Million BTU	4.05	Lbs. SO ₂ /MMBTU
Silica Value	70.9	%
Silicon Dioxide, SiO ₂	48.24	%
Sodium Oxide, Na ₂ O	0.93	%
Sulfur in Ash	0.40	%
Sulfur Trioxide, SO ₃	1.00	%
Sulfur, as Received	2.88	%
Sulfur, Dry Basis	3.10	%
Titanium Dioxide, TiO ₂	1.10	%
Total Moisture	6.98	%
Volatiles, as Received	21.95	%
Volatiles, Dry Basis	23.6	%

Comments:

CTE, St. Rose Lab #'s 89-1634-15, 16, 17

A weighted composite was made from the three supplied samples.

89-1634-15 = 8308 short tons (hold 1)

89-1634-16 = 8094 short tons (hold 2)

Robert L. Dorey
Supervisor of Laboratory Services

Analyses reported by this laboratory are based upon material supplied by the client. Laboratory Services does not imply that the contents of the sample received by this laboratory are the same as all such material in the environment from which the sample was taken. Our results relate only to the sample or samples as tested. Tampa Electric assumes no responsibility and makes no warranty or representation, express or implied, as to the suitability of the sample material for any specific use.

APPENDIX F

FIELD DATA SHEETS

- F-1 BASELINE SULFURIC ACID DATA SHEETS**
- F-2 BASELINE ORSAT DATA SHEETS**
- F-3 FUEL BLEND SULFURIC ACID MIST DATA SHEETS**
- F-4 FUEL BLEND ORSAT DATA SHEETS**

F-1 BASELINE SULFURIC ACID DATA SHEETS

Sulfuric Acid Mist Field Data Form

Plant Pink Power Station
 Location Unit #1
 Date 2-7-00
 Method No. 8
 Run No. BASE-1
 Box Operator RAB/CVC
 Probe Operator RAB/RAN
 Time - Start 10:17 End: 11:25
 Sampling Time 60
 Min. \ Pt 2.5
 Meter Box No. 6
 Stack Area Ft² 283.529
 Meter Cal. (ΔH) 1.780
 Meter Cal. (ΔY) 0.989

Nozzle I.D. No. #47 0.201
 Nozzle Diameter 0.201"
 Pitot Tube No. _____
 Pitot Tube (C_p) 0.84
 Probe Length 14"
 Probe Liner Material PYREX
 Probe Heater Setting 250
 Pressure Pb ("Hg): 30.65 Pp ("H₂O): 2.52 Ps ("Hg): 29.98
 Ambient Temperature 70 °F
 Assumed Moisture (%) 7.0
 Filter Holder No. _____
 Comments BASELINE TEST

Dry Gas Meter Volume
 Final 148,326 Ft³
 Initial 107,402 Ft³
 Net 40,924 Ft³
 Equipment Leak Checks
 Initial 0.000 CFM @ 15 "Hg
 Final 0.000 CFM @ 5 "H₂O
 Pitot Tube OK @ 6.7 "H₂O
 Moisture Determination
 Impinger 16 ml
 Silica Gel 24.6 gm
 Total 40.6

Traverse Point No.	Clock Time	Gas Sample Volume (Ft ³)	Δ P (In. H ₂ O)	Δ H (In. H ₂ O)	Probe Temp. (°F)	Stack Temp. Ts (°F)	Meter Temp. (°F)	Umbilical Temp. Tm (°F)	Last Imp. Temp. (°F)	Vacuum (In. Hg)
1	10:17	109.2	1.45	1.51	235	336	74	270	63	5
2		111.0	1.45	1.51	235	335	77	267	62	5
3		112.8	1.45	1.51	230	336	78	270	62	5
4		114.4	1.45	1.51	240	335	79	270	62	5
5		116.2	1.45	1.51	239	335	79	270	63	5
6	10:32	117.8	1.25	1.30	237	334	80	267	64	5
1	10:35	119.6	1.45	1.51	235	334	78	267	62	5
2		121.3	1.45	1.51	228	336	80	265	63	5
3		123.1	1.45	1.51	229	336	82	265	64	5
4		124.8	1.45	1.51	228	336	83	266	65	5
5		126.5	1.45	1.51	226	336	84	274	64	5
6	11:00	128.1	1.25	1.30	228	335	85	276	64	5

Sulfuric Acid Mist Field Data Form (Continued)

Traverse Point No.	Clock Time	Gas Sample Volume (Ft ³)	ΔP (In. H ₂ O)	ΔH (In. H ₂ O)	Probe Temp. (°F)	Stack Temp. Ts (°F)	Meter Temp. (°F)	Umbilical Temp. Tm (°F)	Last Imp. Temp. (°F)	Vacuum (In. Hg)
1	10:52	129.8	1.30	1.36	236	335	84	277	63	5
2		131.5	1.35	1.41	238	336	85	276	63	5
3		133.1	1.35	1.41	238	336	86	276	64	5
4		134.9	1.35	1.41	242	337	87	278	65	5
5		136.5	1.35	1.41	244	336	88	278	65	5
6	11:07	138.1	1.20	1.25	238	334	88	277	65	5
1	11:10	139.8	1.30	1.36	226	335	86	273	64	5
2		141.5	1.35	1.41	227	336	88	275	64	5
3		143.3	1.40	1.46	224	337	89	274	64	5
4		145.0	1.40	1.46	220	338	89	274	64	5
5		146.7	1.40	1.46	219	337	89	271	65	5
6	11:25	148.326	1.30	1.36	217	337	89	276	65	5

Sulfuric Acid Mist Field Data Form

Plant Peak Power Station
 Location Unit #1
 Date 2-7-00
 Method No. 8
 Run No. BASE-2
 Box Operator RB
 Probe Operator AK/RM
 Time - Start 13:36 End: 14:42
 Sampling Time 60
 Min. \ Pt 2.5
 Meter Box No. 6
 Stack Area Ft² 243.529
 Meter Cal. (ΔH) 0.4 1.780
 Meter Cal. (ΔY) 0.989

Nozzle I.D. No. #47
 Nozzle Diameter 0.201
 Pitot Tube No. _____
 Pitot Tube (C_p) 0.84
 Probe Length 14 FT
 Probe Liner Material Pyrex
 Probe Heater Setting 250
 Pressure Pb ("Hg): 30.00 Pg ("H₂O): -0.92 Ps ("Hg): 24.93
 Ambient Temperature 75 windy
 Assumed Moisture (%) 7.0
 Filter Holder No. _____
 Comments BASELINE

Dry Gas Meter Volume
 Final 199.456 FL³
 Initial 157.824 FL³
 Net 41.136 FL³
 Equipment Leak Checks 15.0 PM
 Initial 0.000 CFM @ 4.5 "Hg
 Final 0.000 CFM @ 8.0 "H₂O
 Pitot Tube OK @ 4.6 "H₂O
 Moisture Determination
 Impinger 34 ml
 Silica Gel 15.1 gm
 Total 99.1

Traverse Point No.	Clock Time	Gas Sample Volume (FP)	ΔP (In. H ₂ O)	ΔH (In. H ₂ O)	Probe Temp. (°F)	Stack Temp. Ts (°F)	Meter Temp. (°F)	Umbilical Temp. Tm (°F)	Last Imp. Temp. (°F)	Vacuum (In. Hg)
1	13:36	159.6	1.35	1.42	180	335	75	263	62	8
2		161.3	1.35	1.42	180	335	78	267	62	7
3		163.0	1.35	1.42	178	335	79	270	57	7
4		164.7	1.40	1.48	182	336	80	268	56	7
5		166.5	1.45	1.53	196	336	81	270	55	8
6	13:51	168.2	1.30	1.37	190	334	81	268	55	7
1	13:53	169.9	1.35	1.42	206	331	80	270	57	7
2		171.6	1.35	1.42	211	336	81	269	55	7
3		173.3	1.35	1.42	216	336	81	270	54	7
4		175.0	1.40	1.48	213	337	82	271	55	7
5		176.8	1.45	1.53	223	336	83	268	56	7
6	14:08	178.6	1.30	1.37	232	335	84	270	56	7

Sulfuric Acid Mist Field Data Form (Continued)

Traverse Point No.	Clock Time	Gas Sample Volume (F ³)	ΔP (In. H ₂ O)	ΔH (In. H ₂ O)	Probe Temp. (°F)	Stack Temp. Ts (°F)	Meter Temp. (°F)	Umbilical Temp. Tm (°F)	Last Imp. Temp. (°F)	Vacuum (In. Hg)
1	14:10	180.3	1.40	1.48	240	334	84	270	58	7
2		182.0	1.45	1.53	245	336	87	271	57	7
3		183.8	1.45	1.53	241	335	88	274	57	7
4		185.6	1.45	1.53	246	335	89	274	57	7
5		187.3	1.45	1.53	217	334	89	273	58	7
6	14:25	189.0	1.30	1.37	201	333	87	273	59	7
1	14:27	190.8	1.40	1.48	205	333	85	270	59	7
2		192.5	1.45	1.53	210	334	84	268	58	7
3		194.2	1.45	1.53	223	334	85	269	57	7
4		196.0	1.45	1.53	226	335	86	271	58	7
5		197.8	1.45	1.53	234	335	87	271	58	7
6	14:42	199.456	1.30	1.37	232	333	88	269	59	7

Sulfuric Acid Mist Field Data Form

Plant PALK POWER STATION
 Location UNIT #1
 Date 2-7-00
 Method No. 8
 Run No. BASE-3
 Box Operator RAB
 Probe Operator CVC/RM
 Time - Start 15:36 End: 16:45
 Sampling Time 60
 Min. \ Pt 2.5
 Meter Box No. 6
 Stack Area Ft² 283.529
 Meter Cal. (ΔH) 1.760
 Meter Cal. (ΔY) 0.989

Nozzle I.D. No. #47
 Nozzle Diameter 0.201
 Pitot Tube No. _____
 Pitot Tube (Cp) 0.84
 Probe Length 14.0 FT
 Probe Liner Material PYREX
 Probe Heater Setting 250°F
 Pressure Pb ("Hg): 30.00 Pg ("H2O): -.92 Ps ("Hg): 29.93
 Ambient Temperature 82
 Assumed Moisture (%) 7.0
 Filter Holder No. _____
 Comments BASELINE

Dry Gas Meter Volume
 Final 251.380 Ft.³
 Initial 209.725 Ft.³
 Net 41.655 Ft.³

Equipment Leak Checks
 Initial 0.002 CFM @ 15 "Hg
 Final 0.000 CFM @ 10 "H2O
 Pitot Tube OK @ 4.6 "H2O

Moisture Determination
 Impinger 30 ml
 Silica Gel 16.8 gm
 Total 46.8

Traverse Point No.	Clock Time	Gas Sample Volume (Ft ³)	Δ P (In. H ₂ O)	Δ H (In. H ₂ O)	Probe Temp. (°F)	Stack Temp. Ts (°F)	Meter Temp. (°F)	Umbilical Temp. Tm (°F)	Last Imp. Temp. (°F)	Vacuum (In. Hg)
1	15:36	211.5	1.40	1.48	221	333	81	271	63	10
2		213.3	1.45	1.53	196	334	84	267	54	9
3		215.1	1.45	1.53	193	334	85	268	59	9
4		216.9	1.45	1.53	191	334	86	268	59	9
5		218.6	1.45	1.53	201	334	85	270	59	9
6	15:51	220.2	1.30	1.37	198	332	86	270	60	9
1	15:53	222.0	1.45	1.48 ^{PP} 53	206	331	84	269	61	9
2		223.8	1.45	1.53	205	332	85	272	59	9
3		225.5	1.45	1.53	200	331	86	272	60	9
4		227.3	1.45	1.53	188	332	86	272	61	9
5		229.0	1.45	1.53	181	332	86	269	61	9
6	16:08	230.7	1.30	1.37	197	331	86	270	62	9

Sulfuric Acid Mist Field Data Form (Continued)

Traverse Point No.	Clock Time	Gas Sample Volume (Ft ³)	ΔP (In. H ₂ O)	ΔH (In. H ₂ O)	Probe Temp. (°F)	Stack Temp. Ts (°F)	Meter Temp. (°F)	Umbilical Temp. Tm (°F)	Last Imp. Temp. (°F)	Vacuum (In. Hg)
1	16:12	232.5	1.35	1.42	192	334	81	270	62	9
2		234.2	1.35	1.42	191	334	82	271	60	9
3		235.9	1.35	1.42	189	333	82	271	59	9
4		237.6	1.35	1.42	186	334	82	272	61	9
5		239.3	1.35	1.42	182	334	82	268	61	9
6	16:27	241.1	1.30	1.37	177	333	82	271	62	9
1	16:30	242.7	1.35	1.42	163	332	79	268	62	9
2		244.5	1.35	1.42	160	334	80	266	60	9
3		246.2	1.35	1.42	165	334	80	265	61	9
4		247.9	1.40	1.48	164	334	80	268	61	9
5		249.7	1.40	1.48	161	334	80	267	61	9
6	16:45	251.380	1.30	1.37	161	333	80	269	61	9

Sulfuric Acid Mist Field Data Form

Plant Polk Power Station
 Location Unit #1
 Date 2-7-00
 Method No. 8
 Run No. Basic-4
 Box Operator RAS
 Probe Operator RAM/DAS
 Time - Start: 17:37 End: 18:45
 Sampling Time 60
 Min. \ Pt. 2.5
 Meter Box No. 6
 Stack Area Ft² 283.529
 Meter Cal. (ΔH) 1.780
 Meter Cal. (ΔY) 0.989

Nozzle I.D. No. #47
 Nozzle Diameter 0.201"
 Pitot Tube No. _____
 Pitot Tube (C_p) 0.84
 Probe Length 14 FT
 Probe Liner Material Pyrex
 Probe Heater Setting 250
 Pressure Pb ("Hg): 29.95 Pg ("H₂O): -.92 Ps ("Hg): 29.88
 Ambient Temperature 71
 Assumed Moisture (%) 7.0
 Filter Holder No. _____
 Comments BASELINE

Dry Gas Meter Volume
 Final 303.408 Ft³
 Initial 261.925 Ft³
 Net 41.483 Ft³

Equipment Leak Checks
 Initial 0.000 CFM @ 15 "Hg
 Final 0.000 CFM @ 8 "H₂O
 Pitot Tube OK @ 4.6 "H₂O

Moisture Determination
 Impinger 31 ml
 Silica Gel 20.4 gm
 Total 51.4

Traverse Point No.	Clock Time	Gas Sample Volume (Ft ³)	Δ P (In. H ₂ O)	Δ H (In. H ₂ O)	Probe Temp. (°F)	Stack Temp. Ts (°F)	Meter Temp. (°F)	Umbilical Temp. Tm (°F)	Last Imp. Temp. (°F)	Vacuum (In. Hg)
1	17:37	263.8	1.35	1.41	160	333	72	260	61	108
2		265.4	1.35	1.41	164	333	74	264	55	108
3		267.1	1.35	1.41	165	333	75	268	56	8
4		268.9	1.40	1.46	166	332	76	267	57	8
5		270.6	1.40	1.46	167	331	76	267	58	8
6	17:52	272.2	1.30	1.36	171	330	76	266	58	8
1	17:55	273.9	1.35	1.41	187	330	74	270	58	8
2		275.6	1.35	1.41	194	331	75	271	57	8
3		277.3	1.35	1.41	194	331	75	267	57	8
4		279.0	1.40	1.46	196	331	75	270	58	8
5		280.7	1.35	1.41	197	332	75	267	58	8
6	18:10	282.4	1.30	1.36	195	331	75	268	59	8

Sulfuric Acid Mist Field Data Form (Continued)

Traverse Point No.	Clock Time	Gas Sample Volume (Ft ³)	ΔP (In. H ₂ O)	ΔH (In. H ₂ O)	Probe Temp. (°F)	Stack Temp. Ts (°F)	Meter Temp. (°F)	Umbilical Temp. Tm (°F)	Last Imp. Temp. (°F)	Vacuum (In. Hg)
1	18:13	284.2	1.40	1.46	180	331	73	268	58	8
2		286.0	1.45	1.51	175	333	73	270	58	8
3		287.7	1.45	1.51	170	333	74	266	59	8
4		289.5	1.45	1.51	169	332	73	267	60	8
5		291.2	1.45	1.51	164	332	73	265	60	8
6	18:28	292.9	1.30	1.36	162	329	73	266	61	7
1	18:30	294.6	1.40	1.46	165	330	71	272	60	8
2		296.2	1.45	1.51	164	332	71	271	59	8
3		298.2	1.45	1.51	164	331	71	268	60	8
4		299.9	1.45	1.51	166	331	71	271	61	8
5		301.7	1.45	1.51	167	330	71	270	61	8
6	18:45	303.408	1.30	1.36	166	329	71	267	62	7

Sulfuric Acid Mist Field Data Form

Plant POLK POWER STATION
 Location UNIT #1
 Date 2-8-00
 Method No. 8
 Run No. BASE-S
 Box Operator RAH/CVC
 Probe Operator CVC/RM
 Time - Start 8:17 End: 9:37
 Sampling Time 60
 Min. \ Pt 2.5
 Meter Box No. 6
 Stack Area Ft² 283.524
 Meter Cal. (ΔH) 1.780
 Meter Cal. (ΔY) 0.989

Nozzle I.D. No. #47
 Nozzle Diameter 0.201"
 Pitot Tube No. _____
 Pitot Tube (C_p) 0.84
 Probe Length 14.0 FT
 Probe Liner Material PYREX
 Probe Heater Setting 250 °F
 Pressure Pb ("Hg): 29.95 Pg ("H2O): -.40 Ps ("Hg): 29.83
 Ambient Temperature 58 °F
 Assumed Moisture (%) 7.0
 Filter Holder No. _____
 Comments BASELINE

Dry Gas Meter Volume
 Final 353.510 Ft³
 Initial 312.713 Ft³
 Net 40.797 Ft³

Equipment Leak Checks
 Initial 0.000 CFM @ 15 "Hg
 Final 0.000 CFM @ 12 "H₂O
 Pitot Tube OK @ 7.7 "H₂O

Moisture Determination
 Impinger 29 ml
 Silica Gel 20.2 gm
 Total 49.2

Traverse Point No.	Clock Time	Gas Sample Volume (Ft ³)	ΔP (In. H ₂ O)	ΔH (In. H ₂ O)	Probe Temp. (°F)	Stack Temp. Ts (°F)	Meter Temp. (°F)	Umbilical Temp. Tm (°F)	Last Imp. Temp. (°F)	Vacuum (In. Hg)
1	8:17	314.4	1.45	1.48	170	336	55	268	50	10
2		316.1	1.45	1.48	169	336	56	268	49	10
3		317.8	1.45	1.48	168	336	57	269	49	10
4		319.5	1.45	1.48	173	336	58	271	50	10
5		321.2	1.45	1.48	174	335	59	269	52	10
6	8:32	322.8	1.30	1.33	174	334	60	273	53	9
1	8:35	326.2 324.1	1.45	1.48	188	336	60	268	52	10
2		326.2	1.45	1.48	194	336	60	263	53	10
3		327.8	1.45	1.48	194	336	60	253	54	10
4		329.6	1.45	1.48	202	336	60	256	51	10
5		331.3	1.45	1.48	211	336	62	261	52	10
6	8:58	332.9	1.20	1.22	214	334	63	269	54	8

Sulfuric Acid Mist Field Data Form (Continued)

Traverse Point No.	Clock Time	Gas Sample Volume (F ³)	ΔP R (In. H ₂ O)	ΔH G (In. H ₂ O)	Probe Temp. (°F)	Stack Temp. Ts (°F)	Meter Temp. (°F)	Umbilical Temp. Tm (°F)	Last Imp. Temp. (°F)	Vacuum (In. Hg)
1	9:03	334.6	1.30	1.33	192	337	62	269	55	10
2		336.3	1.30	1.33	187	337	63	266	54	10
3		337.9	1.30	1.33	183	337	64	266	54	10
4		339.6	1.30	1.33	182	336	64	266	56	10
5		341.4	1.30	1.33	177	336	65	269	57	10
6	9:18	343.0	1.20	1.22	175	334	65	269	58	10
						334 ^{cvc}	62 ^{cvc}	269 ^{cvc}		
1	9:22	343.0	1.30	1.33	190	334	62	269	56	10
2		344.7	1.30	1.33	196	336	63	271	56	10
3		346.3	1.34	1.37	199	336	64	273	57	12 ¹⁰ ^{cvc}
4		348.1	1.34	1.37	199	336	64	273	58	12 ¹⁰ ^{cvc}
5		350.0	1.34	1.37	195	336	64	273	59	12
6	9:37	351.9	1.10	1.12	197	334	64	273	59	10
		353.510								

Sulfuric Acid Mist Field Data Form

Plant Polk Power Station
 Location Unit #1
 Date 2-8-00
 Method No. 8
 Run No. B44-6
 Box Operator CVC/RAB
 Probe Operator RAB/RAM/CVC
 Time - Start 10:18 End: 11:27
 Sampling Time 60
 Min. \ Pt 2.5
 Meter Box No. 6
 Stack Area Ft² 283.529
 Meter Cal. (ΔH) 1.786
 Meter Cal. (ΔY) 0.989

Nozzle I.D. No. #47
 Nozzle Diameter 0.201"
 Pitot Tube No. _____
 Pitot Tube (C_p) 0.84
 Probe Length 14.0 ft
 Probe Liner Material Pyrex
 Probe Heater Setting 250°F
 Pressure Pb (Hg): 29.95 Pg (H₂O): -90 Ps (Hg): 29.88
 Ambient Temperature 58°F
 Assumed Moisture (%) 7.0
 Filter Holder No. _____
 Comments Baseline - 6

Dry Gas Meter Volume
 Final 404.392 Ft³
 Initial 363.509 Ft³
 Net 40.883 Ft³

Equipment Leak Checks
 Initial 0.000 CFM @ 15 "Hg
 Final 0.000 CFM @ 11 "H₂O
 Pitot Tube 0.00 7.7 "H₂O

Moisture Determination
 Impinger 26 ml
 Silica Gel 22.3 gm
 Total 48.3

Traverse Point No.	Clock Time	Gas Sample Volume (Ft ³)	Δ P (In. H ₂ O)	Δ H (In. H ₂ O)	Probe Temp. (°F)	Stack Temp. Ts (°F)	Meter Temp. (°F)	Umbilical Temp. Tm (°F)	Last Imp. Temp. (°F)	Vacuum (In. Hg)
1	10:18	365.3	1.40	1.43	187	336	61	260	55	11
2		367.0	1.30	1.33	190	336	62	259	53	11
3		368.7	1.30	1.33	195	336	63	263	54	10
4		370.4	1.40	1.43	194	336	64	266	55	10
5		372.1	1.40	1.43	199	336	64	270	56	10
6	10:33	373.8	1.30	1.33	198	335	65	273	56	10
1	10:35	375.5	1.30	1.33	179	334	64	274	56	11
2		377.1	1.30	1.33	173	337	65	273	56	11
3		378.7	1.30	1.33	179	337	65	270	57	11
4		380.4	1.30	1.33	180	336	66	273	58	11
5		382.1	1.30	1.33	181	336	66	272	59	10
6	10:50	383.7	1.20	1.22	173	334	67	271	61	9

Sulfuric Acid Mist Field Data Form (Continued)

Traverse Point No.	Clock Time	Gas Sample Volume (Ft ³)	ΔP (In. H ₂ O)	ΔH (In. H ₂ O)	Probe Temp. (°F)	Stack Temp. Ts (°F)	Meter Temp. (°F)	Umbilical Temp. Tm (°F)	Last Imp. Temp. (°F)	Vacuum (In. Hg)
1	1054	385.4	1.40	1.43	193	335	66	273	60	10
2		387.2	1.40	1.43	198	335	67	273	59	10
3		388.9	1.40	1.43	202	336	68	270	60	10
4		390.6	1.40	1.43	193	335	69	273	61	10
5		392.3	1.40	1.43	193	335	69	269	63	10
6	1109	393.9	1.20	1.22	198	335	69	273	63	9
1	1112	395.7	1.40	1.43	203	336	67	270	62	10
2		397.4	1.40	1.43	199	336	69	269	59	10
3		399.1	1.50	1.53	207	336	70	272	61	11
4		400.9	1.50	1.53	205	336	70	272	61	11
5		402.7	1.50	1.53	209	336	71	271	62	11
6	1127	404.392	1.30	1.33	204	335	72	269	63	10

Sulfuric Acid Mist Field Data Form

Plant Polk Power Station
 Location Unit #1
 Date 2-8-00
 Method No. 8
 Run No. Baseline-7
 Box Operator CVC/RAB
 Probe Operator RAM/RAB/CVC
 Time - Start 1216 End: 1324
 Sampling Time 60
 Min. \ Pt 2.5
 Meter Box No. 6
 Stack Area Ft.² 283.529
 Meter Cal. (ΔH) 1.780
 Meter Cal. (ΔY) 0.989

Nozzle I.D. No. 447
 Nozzle Diameter 0.201"
 Pitot Tube No. _____
 Pitot Tube (C_p) 0.84
 Probe Length 14.0 Ft
 Probe Liner Material Pyrex
 Probe Heater Setting 250°F
 Pressure Pb ("Hg): 30.00 Pg ("H₂O): -.40 Ps ("Hg): 29.88
 Ambient Temperature 60°F
 Assumed Moisture (%) 7.0
 Filter Holder No. _____
 Comments Baseline-7

Dry Gas Meter Volume
 Final 456.063 Ft.³
 Initial 415.075 Ft.³
 Net 40.988 Ft.³

Equipment Leak Checks
 Initial 0.000 CFM @ 15 "Hg
 Final 0.000 CFM @ 12 "H₂O
 Pitot Tube 0.27.7 "H₂O

Moisture Determination
 Impinger 26 ml
 Silica Gel 20 gm
 Total 46

Traverse Point No.	Clock Time	Gas Sample Volume (Ft ³)	ΔP (In. H ₂ O)	ΔH (In. H ₂ O)	Probe Temp. (°F)	Stack Temp. Ts (°F)	Meter Temp. (°F)	Umbilical Temp. Tm (°F)	Last Imp. Temp. (°F)	Vacuum (In. Hg)
1	1216	416.8	1.40	1.46	233	337	73	269	59	11
2		418.5	1.40	1.46	208	337	76	268	57	11
3		420.2	1.40	1.46	209	336	76	269	56	11
4		422.0	1.40	1.46	191	336	76	269	57	11
5		423.7	1.40	1.46	192	336	76	269	57	11
6	1231	425.4	1.30	1.35	201	335	76	270	57	11
1	1233	427.1	1.40	1.46	202	336	75	275	60	12
2		428.9	1.40	1.46	196	336	75	271	59	12
3		430.6	1.40	1.46	203	336	74	270	60	12
4		432.3	1.40	1.46	207	337	74	271	61	12
5		434.1	1.40	1.46	219	336	74	271	61	12
6	1248	435.7	1.20	1.25	226	334	74	273	62	10

Sulfuric Acid Mist Field Data Form (Continued)

Traverse Point No.	Clock Time	Gas Sample Volume (Ft ³)	Δ P (In. H ₂ O)	Δ H (In. H ₂ O)	Probe Temp. (°F)	Stack Temp. Ts (°F)	Meter Temp. (°F)	Umbilical Temp. Tm (°F)	Last Imp. Temp. (°F)	Vacuum (In. Hg)
1	1251	437.4	1.30	1.35	198	336	73	270	64	11
2		439.0	1.20	1.25	203	336	74	271	61	10
3		440.7	1.30	1.35	204	336	74	271	61	11
4		442.4	1.40	1.46	209	336	75	270	63	12
5		444.2	1.40	1.46	210	336	75	269	64	12
6	1306	445.8	1.20	1.25	215	335	75	270	64	10
1	1309	447.5	1.30	1.35	219	336	74	273	66	11
2		449.2	1.30	1.35	220	337	75	269	61	11
3		450.9	1.30	1.35	233	337	75	272	62	11
4		452.6	1.40	1.46	230	337	76	272	62	12
5		454.4	1.40	1.46	238	336	77	269	63	12
6	1324	456.063	1.20	1.25	237	335	77	268	63	10

Sulfuric Acid Mist Field Data Form

Plant	<u>Polk Power Station</u>	Nozzle I.D. No.	<u>#47</u>	Dry Gas Meter Volume	
Location	<u>Unit 41</u>	Nozzle Diameter	<u>0.201"</u>	Final	<u>507.654</u> Ft. ³
Date	<u>2-8-00</u>	Pitot Tube No.		Initial	<u>466.368</u> Ft. ³
Method No.	<u>8</u>	Pitot Tube (C _p)	<u>0.84</u>	Net	<u>41.286</u> Ft. ³
Run No.	<u>Bx-8</u>	Probe Length	<u>14.0 ft</u>	Equipment Leak Checks	
Box Operator	<u>CULRAB</u>	Probe Liner Material	<u>Pyrex</u>	Initial	<u>0.000 CFM @ 15</u> "Hg
Probe Operator	<u>RAMIRABICVL</u>	Probe Heater Setting	<u>250°F</u>	Final	<u>0.000 CFM @ 12</u> "H ₂ O
Time - Start	<u>1404</u> End: <u>1512</u>	Pressure	<u>Pb ("Hg): 29.91 Pg ("H₂O): -0.40 Ps ("Hg): 29.84</u>	Pitot Tube	<u>0.0077</u> "H ₂ O
Sampling Time	<u>60</u>	Ambient Temperature	<u>60°F</u>	Moisture Determination	
Min. \ Pt.	<u>2.5</u>	Assumed Moisture (%)	<u>7.0</u>	Impinger	<u>26</u> ml
Meter Box No.	<u>6</u>	Filter Holder No.		Silica Gel	<u>20.4</u> gm
Stack Area Ft. ²	<u>283.529</u>	Comments	<u>Baseline</u>	Total	<u>46.4</u>
Meter Cal. (ΔH)	<u>1.750</u>				
Meter Cal. (ΔY)	<u>0.989</u>				

Traverse Point No.	Clock Time	Gas Sample Volume (Ft ³)	ΔP (In. H ₂ O)	ΔH (In. H ₂ O)	Probe Temp. (°F)	Stack Temp. Ts (°F)	Meter Temp. (°F)	Umbilical Temp. Tm (°F)	Last Imp. Temp. (°F)	Vacuum (In. Hg)
1	1404	468.0	1.30	1.35	188	336	74	266	61	10
2		469.7	1.30	1.35	191	337	76	270	58	10
3		471.4	1.40	1.46	201	337	77	271	57	10
4		473.1	1.40	1.46	214	337	78	272	58	11
5		474.9	1.40	1.46	223	336	79	272	60	11
6	1419	476.6	1.30	1.35	224	335	80	270	60	10
1	14:21	478.3	1.30	1.35	218	336	78	269	62	10
2		480.0	1.30	1.35	225	336	79	269	60	10
3		481.6	1.30	1.35	232	336	80	273	60	10
4		483.3	1.35	1.40	225	336	81	271	61	10
5		485.0	1.40	1.46	220	336	81	269	62	11
6	14:36	486.6	1.25	1.30	230	335	82	272	62	9

Sulfuric Acid Mist Field Data Form (Continued)

Traverse Point No.	Clock Time	Gas Sample Volume (F ³)	ΔP (In. H ₂ O)	ΔH (In. H ₂ O)	Probe Temp. (°F)	Stack Temp. Ts (°F)	Meter Temp. (°F)	Umbilical Temp. Tm (°F)	Last Imp. Temp. (°F)	Vacuum (In. Hg)
1	1439	488.3	1.30	1.35	221	335	81	273	65	10
2		490.1	1.40	1.46	222	336	82	274	64	11
3		491.8	1.40	1.46	211	336	82	272	67	11
4		493.5	1.40	1.46	209	336	83	275	67	11
5		495.3	1.40	1.46	213	336	84	271	67	11
6	1454	496.9	1.20	1.25	223	334	84	272	66	10
1	1457	498.8	1.40	1.46	215	337	82	271	65	11
2		500.5	1.40	1.46	213	337	84	274	62	11
3		502.3	1.50	1.56	211	336	84	270	62	12
4		504.2	1.50	1.56	212	336	84	272	63	12
5		505.9	1.50	1.56	223	336	84	270	62	12
6	1512	507.654	1.30	1.35	228	335	85	269	62	10

F-2 BASELINE ORSAT DATA SHEETS

ORSAT DATA AND CALCULATION SHEET

Source Unit #1 Location POCK POWER STATION

Run No.	Date	Gas	Orsat Analysis, Dry Basis (% Volume)				Remarks
			1	2	3	Avg.	
BASE-1	2-7-00 PAT	CO ₂	8.0	8.0	8.0	8.0	
		O ₂	11.8	11.8	11.8	11.8	
		CO	0	0	0	0	
		N ₂	80.2	80.2	80.2	80.2	
BASE-2	2-7-00 PAT	CO ₂	8.2	8.2	8.2	8.2	
		O ₂	11.8	11.8	11.8	11.8	
		CO	0	0	0	0	
		N ₂	80.0	80.0	80.0	80.0	
BASE-3	2-7-00 PAT	CO ₂	8.2	8.2	8.2	8.2	
		O ₂	11.8	11.8	11.8	11.8	
		CO	0	0	0	0	
		N ₂	80.0	80.0	80.0	80.0	

ORSAT DATA AND CALCULATION SHEET

Source Unit #1

Location POLK POWER STATION

Run No.	Date	Gas	Orsat Analysis, Dry Basis (% Volume)				Remarks
			1	2	3	Avg.	
BASE 4	2-7-00 RSP	CO ₂	8.4	8.4	8.4	8.4	
		O ₂	11.8	11.8	11.8	11.8	
		CO	0	0	0	0	
		N ₂	79.8	79.8	79.8	79.8	
		CO ₂					
		O ₂					
		CO					
		N ₂					
		CO ₂					
		O ₂					
		CO					
		N ₂					

ORSAT DATA AND CALCULATION SHEET

Source UWIT #1

Location POLK POWER STATION

Run No.	Date	Gas	Orsat Analysis, Dry Basis (% Volume)				Remarks
			1	2	3	Avg.	
BASE-5	2-8-00 PAB	CO ₂	8.0	8.0	8.0	8.0	
		O ₂	12.0	12.0	12.0	12.0	
		CO	0	0	0	0	
		N ₂	80.0	80.0	80.0	80.0	
BASE-6	2-8-00 PAB	CO ₂	8.0	8.0	8.0	8.0	
		O ₂	12.0	12.0	12.0	12.0	
		CO	0	0	0	0	
		N ₂	80.0	80.0	80.0	80.0	
BASE-7	2-8-00 PAB	CO ₂	8.0	8.0	8.0	8.0	
		O ₂	11.8	11.8	11.8	11.8	
		CO	0	0	0	0	
		N ₂	80.2	80.2	80.2	80.2	

ORSAT DATA AND CALCULATION SHEET

Source Unit #1 Location POCK POWER STATION

Run No.	Date	Gas	Orsat Analysis, Dry Basis (% Volume)				Remarks
			1	2	3	Avg.	
BASE-8	2-8-00 AD	CO2	8.0	8.0	8.0	8.0	
		O2	11.8	11.8	11.8	11.8	
		CO	0	0	0	0	
		N2	80.2	80.2	80.2	80.2	
BASE-9		CO2					
		O2					
		CO					
		N2					
		CO2					
		O2					
		CO					
		N2					

F-3 FUEL BLEND SULFURIC ACID MIST DATA SHEETS

Sulfuric Acid Mist Field Data Form

Plant Polk Power Station
 Location HR5G
 Date 04-24-2000
 Method No. 8
 Run No. 1
 Box Operator C. Coronado
 Probe Operator J. Werner, D. Smith
 Time - Start 1037 End: 1200
 Sampling Time 60 minutes
 Min. \ Pt. 2.5
 Meter Box No. 6
 Stack Area Ft² 283.53 ft²
 Meter Cal. (ΔH) 1.756
 Meter Cal. (ΔY) 1.001

Nozzle I.D. No. 47
 Nozzle Diameter 0.201 inches
 Pitot Tube No. 00122
 Pitot Tube (Cp) .84
 Probe Length 14
 Probe Liner Material Quartz
 Probe Heater Setting 280
 Pressure Pb ("Hg): 29.5 Pg ("H2O): -.83 Ps ("Hg): 28.9
 Ambient Temperature 74
 Assumed Moisture (%) 6.0
 Filter Holder No. 1
 Comments _____

Dry Gas Meter Volume
 Final 394.899 Ft³
 Initial 351.179 Ft³
 Net 43.720 Ft³

Equipment Leak Checks
 Initial 0.0 CFM @ 15 "Hg
 Final 0.0 CFM @ 6 "H₂O
 Pitot Tube 0.0 @ 7.0 "H₂O

Moisture Determination
 Impinger 29 ml
 Silica Gel 20.4 gm
 Total 49.4 ✓

reviewed - JRM 5/1/2000

Traverse Point No.	Clock Time	Gas Sample Volume (Ft ³)	Δ P (In. H ₂ O)	Δ H (In. H ₂ O)	Probe Temp. (°F)	Stack Temp. Ts (°F)	Meter Temp. (°F)	Umbilical Temp. Tm (°F)	Last Imp. Temp. (°F)	Vacuum (In. Hg)
1 2.5	1037	353.0	1.40	1.50 1.51	188	319	74	245	59	5.5
2 5.0		354.8	1.40	1.50 1.51	188	320	75	245	56	5.5
3 7.5		356.6	1.50	1.62	190	320	87	246	57	5.5
4 10.0		358.4	1.60	1.73	187	320	78	246	59	6.0
5 12.5		360.3	1.60	1.73	188	321	78	247	61	6.0
6 15.0	1052	362.1	1.40	1.50 1.51	187	320	79	247	63	6.0
1 2.5	1055	364.0	1.50	1.62	197	321	78	250	66	5.5
2 5.0		365.8	1.40	1.50 1.51	201	321	79	251	65	5.5
3 7.5		367.7	1.50	1.62	199	320	80	250	66	5.5
4 10.0		369.5	1.50	1.62	202	321	80	252	67	5.5
5 12.5		371.4	1.40	1.50 1.51	198	321	81	252	66	5.5
6 15.0	1110	373.1	1.30	1.41	197	319	82	253	66	5.0

Sulfuric Acid Mist Field Data Form (Continued)

Traverse Point No.	Clock Time	Gas Sample Volume (Ft ³)	ΔP (In. H ₂ O)	ΔH (In. H ₂ O)	Probe Temp. (°F)	Stack Temp. Ts (°F)	Meter Temp. (°F)	Umbilical Temp. Tm (°F)	Last Imp. Temp. (°F)	Vacuum (In. Hg)
1 ^{2.5}	1113	374.9	1.40	1.51	193	321	80	255	65	5.0
2 ^{5.0}		376.7	1.30	1.41	188	321	81	256	65	5.0
3 ^{7.5}		378.4	1.30	1.41	186	322	82	255	66	5.0
4 ^{10.0}		380.3	1.50	1.62	180	322	82	257	66	5.5
5 ^{12.5}		382.1	1.40	1.51	180	322	82	255	66	5.0
6 ^{15.0}	1128	383.8	1.20	1.30	186	320	82	255	65	5.0
1	1145	385.6	1.40	1.51	185	320	80	257	66	5.0
2		387.5	1.40	1.51	185	321	82	256	63	5.0
3		389.3	1.50	1.62	189	321	82	255	66	5.5
4		391.2	1.50	1.62	188	321	82	255	66	5.5
5		393.1	1.50	1.62	183	322	82	255	67	5.5
6	1200	394.899	1.40	1.51	184	321	82	255	67	5.5

Sulfuric Acid Mist Field Data Form

Plant Polk Power Station
 Location HRS6
 Date 4-24-2000
 Method No. 8
 Run No. 2
 Box Operator C. Conrad
 Probe Operator J. Werner, D. Smith
 Time - Start 1313 End: 1423
 Sampling Time 60 min
 Min. \ Pt. 15 min / pt.
 Meter Box No. 6
 Stack Area Ft² 283.53 ft²
 Meter Cal. (ΔH) 1.756
 Meter Cal. (ΔY) 1.001

Nozzle I.D. No. 47
 Nozzle Diameter 0.201 inches
 Pitot Tube No. 00122
 Pitot Tube (Cp) 0.84
 Probe Length 14 ft
 Probe Liner Material Quartz
 Probe Heater Setting 600°/450°
 Pressure Pb ("Hg): 29.5 Pg ("H2O): -, 83 Ps ("Hg): 28.9
 Ambient Temperature 76
 Assumed Moisture (%) 6.0
 Filter Holder No. 2
 Comments _____

Dry Gas Meter Volume
 Final 449.498 Ft³
 Initial 404.811 Ft³
 Net 44.687 ✓ Ft³

Equipment Leak Checks
 Initial 0.0 CFM @ 15 "Hg
 Final 0.0 CFM @ 10 "H2O
 Pitot Tube 0.0 @ 7.0 "H2O

Moisture Determination
 Impinger 35 ml
 Silica Gel 19.9 gm
 Total 54.9 ✓

reviewed - BTM 5/1/2000

Traverse Point No.	Clock Time	Gas Sample Volume (Ft ³)	Δ P (In. H ₂ O)	Δ H (In. H ₂ O)	Probe Temp. (°F)	Stack Temp. Ts (°F)	Meter Temp. (°F)	Umbilical Temp. Tm (°F)	Last Imp. Temp. (°F)	Vacuum (In. Hg)
1 ^{2.5}	1313	406.6	1.40	^{CVL} 1.53	182	320	85	235	65	^{CVL} 5.6
2 ^{5.0}		408.4	1.40	1.53	177	321	86	236	65	6
3 ^{7.5}		410.3	1.60	1.75	180	321	86	241	66	6.5
4 ^{10.0}		412.3	1.60	1.75	182	321	86	243	66	6.5
5 ^{12.5}		414.2	1.60	1.75	179	322	86	246	66	6.5
6 ^{15.0}	1328	416.2	1.30	1.42	177	320	87	247	67	5.5
1	1330	417.9	1.30	1.42	191	322	86	249	68	5.5
2		419.6	1.30	1.42	180	322	87	251	68	5.5
3		421.5	1.40	1.53	172	321	87	254	67	6
4		423.4	1.50	1.64	171	321	87	255	67	6
5		425.2	1.40	1.53	164	321	87	256	67	6
6	1345	427.1	1.30	1.42	164	320	87	257	67	5.5

Sulfuric Acid Mist Field Data Form (Continued)

Traverse Point No.	Clock Time	Gas Sample Volume (Ft ³)	Δ P (In. H ₂ O)	Δ H (In. H ₂ O)	Probe Temp. (°F)	Stack Temp. Ts (°F)	Meter Temp. (°F)	Umbilical Temp. Tm (°F)	Last Imp. Temp. (°F)	Vacuum (In. Hg)
1 ^{2.5}	1350	428.9	1.40	1.53	182	320	86	260	67	6.0
2 ^{5.0}		430.8	1.40	1.53	180	320	87	260	66	6.0
3 ^{7.5}		432.7	1.50	1.64	179	319	87	260	67	6.0
4 ^{10.0}		434.6	1.40	1.53	176	320	87	261	67	6.0
5 ^{12.5}		436.5	1.40	1.53	180	320	87	260	68	6.0
6 ^{15.0}	1405	438.2	1.20	1.31	179	318	87	259	68	5.0
1	1408	440.1	1.40	1.53	170	320	86	260	67	6.0
2		442.0	1.50	1.64	171	320	87	259	67	6.0
3		443.9	1.50	1.64	172	318	87	258	68	6.0
4		445.8	1.50	1.64	172	318	87	257	68	6.0
5		447.7	1.50	1.64	177	318	87	257	67	6.0
6	1423	449.498	1.30	1.42	185	316	88	257	68	5.5

Sulfuric Acid Mist Field Data Form

Plant Pdk Power Station
 Location HRSG
 Date 04-24-00
 Method No. 8
 Run No. 3
 Box Operator J. Werner
 Probe Operator C. Coronado/D. Smith
 Time - Start 1630 End: 1855
 Sampling Time 60 min.
 Min. \ Pt 5 min/pt.
 Meter Box No. 6
 Stack Area Ft² 283.53 ft²
 Meter Cal. (ΔH) 1.756
 Meter Cal. (ΔY) 1.001

Nozzle I.D. No. 47
 Nozzle Diameter 0.201 inches
 Pitot Tube No. 00122
 Pitot Tube (C_p) .84
 Probe Length 14'
 Probe Liner Material Q Jontz
 Probe Heater Setting 230
 Pressure Pb ("Hg): 29.40 Pg ("H₂O): -.83 Ps ("Hg): 28.9
 Ambient Temperature 84° F
 Assumed Moisture (%) 6.0
 Filter Holder No. 3
 Comments STOPPED @ 1705 DUE TO BROKEN LINER
RESUME TESTING @ 1820
(Leak check = 0.015 @ 10")

Dry Gas Meter Volume
 Final 505.00 Ft³
 Initial 462.490 Ft³
 Net 42.51 Ft³

Equipment Leak Checks
 Initial 0.15 CFM @ 10 "Hg
 Final 0.12 CFM @ 10 "H₂O
 Pitot Tube 0.0 @ 7.5 "H₂O

Moisture Determination
 Impinger 24 ml
 Silica Gel 20.5 gm
 Total 44.5

reviewed - RAM 5/1/2000

Traverse Point No.	Clock Time	Gas Sample Volume (Ft ³)	Δ P (In. H ₂ O)	Δ H (In. H ₂ O)	Probe Temp. (°F)	Stack Temp. Ts (°F)	Meter Temp. (°F)	Umbilical Temp. Tm (°F)	Last Imp. Temp. (°F)	Vacuum (In. Hg)
1	1630		1.5	1.61	172	320	84	222	64	5
2			1.5	1.61	170	322	86	229	82	4
3		467.9	1.6	1.82	169	322	86	237	64	5
4		469.7	1.7	1.83	171	323	85	240	66	5
5		471.6	1.6	1.72	171	322	85	243	67	5
6	1645	473.	1.4	1.51	174	322	86	246	66	4
1	1700	475.1	1.4	1.51	161	321	85	251	65	4
2		476.7	1.5	1.61	162	320	85	252	65	4
3		478.3	1.4	1.51	160	320	86	254	65	4
4		480.1	1.5	1.61	162	320	86	254	66	4
5	<u>RAM</u>	481.8	1.4	1.51	169	320	86	255	65	4
6	1715	483.5	1.2	1.29	164	318	85	256	68	4

Sulfuric Acid Mist Field Data Form (Continued)

Traverse Point No.	Clock Time	Gas Sample Volume (Ft ³)	ΔP (In. H ₂ O)	ΔH (In. H ₂ O)	Probe Temp. (°F)	Stack Temp. Ts (°F)	Meter Temp. (°F)	Umbilical Temp. Tm (°F)	Last Imp. Temp. (°F)	Vacuum (In. Hg)
1	1820	485.9	1.4	1.51	191	323	83	260	64	4
2		487.7	1.4	1.51	186	323	83	259	62	4
3		489.4	1.4	1.51	190	323	84	258	62	4
4		491.0	1.4	1.51	188	323	85	258	65	4
5		492.7	1.4	1.51	189	321	84	257	64	4
6	1835	494.4	1.2	1.29	184	321	84	257	64	4
1	1840	496.1	1.6	1.61	175	318	83	257	65	4.5
2		497.9	1.5	1.61	172	321	84	256	65	4.5
3		499.65	1.6	1.72	174	321	84	255	65	5.0
4		501.56	1.6	1.72	167	322	84	255	64	5.0
5		503.10	1.6	1.72	162	322	84	255	64	5.0
6	1855	505.008	Jan 1.3	Jan 1.40	162	322	84	255	64	5.0

Sulfuric Acid Mist Field Data Form

Plant POLK POWER STATION
 Location Unit 1 HRSG
 Date 4-25-00
 Method No. 8
 Run No. 6
 Box Operator RAD
 Probe Operator JAW / CUC
 Time - Start 12:21 End: 14:28
 Sampling Time 60 MIN
 Min. \ Pt 2.5
 Meter Box No. 6
 Stack Area Ft³ 283.530
 Meter Cal. (ΔH) 1.756
 Meter Cal. (ΔY) 1.001

Nozzle I.D. No. #47
 Nozzle Diameter 0.201
 Pitot Tube No. AND 6-8400122
 Pitot Tube (C_p) 0.84
 Probe Length 14.0
 Probe Liner Material PYREX
 Probe Heater Setting 300 °F
 Pressure Pb ("Hg): 29.60 Pg ("H₂O): -1.97 Ps ("Hg): 29.53
 Ambient Temperature 85 °F
 Assumed Moisture (%) 6.0%
 Filter Holder No. _____
 Comments _____

Dry Gas Meter Volume
 Final 665.156 Ft³
 Initial 622.184 Ft³
 Net 42.972 Ft³

Equipment Leak Checks
 Initial 0.002 CFM @ 15 "Hg
 Final 0.000 CFM @ 7 "H₂O
 Pitot Tube OK @ 4.2 "H₂O

Moisture Determination
 Impinger 34 ml
 Silica Gel 19.3 gm
 Total 53.3 ✓

reviewed - RSM 6/1/00

Traverse Point No.	Clock Time	Gas Sample Volume (Ft ³)	Δ P (In. H ₂ O)	Δ H (In. H ₂ O)	Probe Temp. (°F)	Stack Temp. Ts (°F)	Meter Temp. (°F)	Umbilical Temp. Tm (°F)	Last Imp. Temp. (°F)	Vacuum (In. Hg)
1	13:21	624.0	1.40	1.50	191	321	85	256	64	7
2		625.9	1.40	1.50	180	324	86	256	63	7
3		627.7	1.40	1.50	182	323	87	256	62	7
4		629.5	1.40	1.50	188	324	87	256	62	7
5		631.3	1.40	1.50	195	323	88	256	62	7
6	13:36	633.0	1.25	1.34	190	323	88	257	62	6
1	13:38	634.8	1.35	1.45	206	321	87	258	63	7
2		636.6	1.40	1.50	213	322	88	259	63	7
3		638.3	1.40	1.50	213	322	89	258	63	7
4		640.1	1.40	1.50	212	322	89	258	63	7
5		641.9	1.35	1.45	210	321	88	258	63	7
6	13:53	643.6	1.25	1.34	216	322	88	258	63	7

Sulfuric Acid Mist Field Data Form (Continued)

Traverse Point No.	Clock Time	Gas Sample Volume (F ³)	ΔP (In. H ₂ O)	ΔH (In. H ₂ O)	Probe Temp. (°F)	Stack Temp. Ts (°F)	Meter Temp. (°F)	Umbilical Temp. Tm (°F)	Last Imp. Temp. (°F)	Vacuum (In. Hg)
1	13:55	645.4	1.35	1.45	202	320	87	259	64	7
2		647.3	1.40	1.50	199	324	88	260	64	7
3		649.0	1.40	1.50	195	324	89	260	63	7
4		650.8	1.40	1.50	194	322	89	259	63	7
5		652.7	1.40	1.50	192	322	89	260	63	7
6	14:10	654.4	1.35	1.45	198	321	90	261	63	7
1	14:13	656.2	1.35	1.45	192	321	88	260	64	7
2		658.0	1.40	1.50	195	322	89	260	64	7
3		659.8	1.40	1.50	204	321	89	259	64	7
4		661.6	1.40	1.50	211	321	89	259	64	7
5		663.4	1.40	1.50	209	321	89	259	64	7
6	14:28	665.156	1.25	1.34	205	320	89	259	65	7

Sulfuric Acid Mist Field Data Form

Plant Rock Power Station
 Location Unit #1 HXSG
 Date 4-25-00
 Method No. 8
 Run No. 7
 Box Operator MAP
 Probe Operator NVC / Jaw
 Time - Start 15:04 End: 16:10
 Sampling Time 60 min
 Min. \ Pt 2.5
 Meter Box No. 6
 Stack Area Ft² 253.530
 Meter Cal. (ΔH) 1.756
 Meter Cal. (ΔY) 1.001

Nozzle I.D. No. #47
 Nozzle Diameter 0.201
 Pitot Tube No. 00122
 Pitot Tube (C_p) 0.84
 Probe Length 14 ft
 Probe Liner Material PURX
 Probe Heater Setting 300 °F
 Pressure Pb ("Hg): 29.55 Pg ("H₂O): -.97 Ps ("Hg): 29.48
 Ambient Temperature 85 °F
 Assumed Moisture (%) 6.0 %
 Filter Holder No. _____
 Comments _____

Dry Gas Meter Volume
 Final 717.050 Ft³
 Initial 674.313 Ft³
 Net 42.737 Ft³

Equipment Leak Checks
 Initial 0.000 CFM @ 15 "Hg
 Final 0.000 CFM @ 8 "H₂O
 Pitot Tube OK @ 4.6 "H₂O

Moisture Determination
 Impinger 32 ml
 Silica Gel 21.2 gm
 Total 53.2

reviewed - *RTM* 5/1/2000

Traverse Point No.	Clock Time	Gas Sample Volume (Ft ³)	Δ P (In. H ₂ O)	Δ H (In. H ₂ O)	Probe Temp. (°F)	Stack Temp. Ts (°F)	Meter Temp. (°F)	Umbilical Temp. Tm (°F)	Last Imp. Temp. (°F)	Vacuum (In. Hg)
1	15:04	676.1	1.35	1.45	207	322	85	265	63	8
2		678.0	1.40	1.50	209	321	86	263	63	8
3		679.8	1.40	1.50	206	321	86	263	62	8
4		681.6	1.40	1.50	206	321	87	262	62	8
5		683.3	1.40	1.50	199	320	88	261	62	8
6	15:19	685.1	1.25	1.34	203	319	88	259	63	7
1	15:21	686.9	1.35	1.45	195	320	88	260	63	8
2		688.7	1.40	1.50	194	321	89	259	63	8
3		690.4	1.40	1.50	190	322	89	258	64	8
4		692.2	1.40	1.50	186	321	89	258	64	8
5		694.0	1.40	1.50	188	321	89	258	64	8
6	15:36	695.7	1.20	1.29	191	320	89	259	64	7

Sulfuric Acid Mist Field Data Form (Continued)

Traverse Point No.	Clock Time	Gas Sample Volume (Ft ³)	ΔP (In. H ₂ O)	ΔH (In. H ₂ O)	Probe Temp. (°F)	Stack Temp. Ts (°F)	Meter Temp. (°F)	Umbilical Temp. Tm (°F)	Last Imp. Temp. (°F)	Vacuum (In. Hg)
1	15:38	699.2	1.35	1.45	203	322	89	256	64	8
2		701.1	1.40	1.50	202	323	89	252	64	8
3		702.9	1.40	1.50	206	321	90	252	65	8
4		704.7 ^{703.45}	1.40	1.50	210	322	90	251	65	8
5		704.7	1.40	1.50	216	320	91	251	64	8
6	15:53	706.5	1.25	1.34	217	321	91	251	63	¹⁰⁰ 8.7
1	15:55	708.1	1.35	1.45	214	321	90	251	63	8
2		710.1	1.40	1.50	199	321	90	251	63	8
3		711.8	1.40	1.50	198	322	91	252	63	8
4		713.6	1.40	1.50	195	322	91	252	64	8
5		715.4	1.40	1.50	194	321	91	254	64	8
6	16:10	717.050	1.20	1.29	196	321	91	253	64	7

Sulfuric Acid Mist Field Data Form

Plant Polk Power Station
 Location Unit #1 HHS6
 Date 4-25-00
 Method No. 8
 Run No. 8
 Box Operator AD
 Probe Operator CVC/JAW
 Time - Start 17:12 End: 18:17
 Sampling Time 6.0 min
 Min. 1 Pt. 2.5
 Meter Box No. 6
 Stack Area Ft² 283.530
 Meter Cal. (ΔH) 1.756
 Meter Cal. (ΔY) 1.001

Nozzle I.D. No. #47
 Nozzle Diameter 0.201
 Pitot Tube No. 00122
 Pitot Tube (Cp) AD 140 - 0.84
 Probe Length 14.0
 Probe Liner Material Pyrex
 Probe Heater Setting 300 °F
 Pressure Pb ("Hg): 29.5 SPg ("H2O): -.97Ps ("Hg): 29.48
 Ambient Temperature 84 °F
 Assumed Moisture (%) 6.0
 Filter Holder No. _____
 Comments _____

Dry Gas Meter Volume
 Final 268.895 Ft³
 Initial 726.096 Ft³
 Net 42.799 Ft³

Equipment Leak Checks
 Initial 0.000 CFM @ 15" "Hg
 Final 0.000 CFM @ 8" "H2O
 Pitot Tube OK @ 4.6" "H2O

Moisture Determination
 Impinger 28 ml
 Silica Gel 19.8 gm
 Total 47.8 ✓

reviewed - RSM 5/1/2000

Traverse Point No.	Clock Time	Gas Sample Volume (Ft ³)	Δ P (In. H ₂ O)	Δ H (In. H ₂ O)	Probe Temp. (°F)	Stack Temp. Ts (°F)	Meter Temp. (°F)	Umbilical Temp. Tm (°F)	Last Imp. Temp. (°F)	Vacuum (In. Hg)
1	17:12	727.9	1.35	1.45	190	323	87	255	64	8
2		729.7	1.40	1.50	197	323	89	254	63	8
3		731.5	1.40	1.50	197	322	90	254	62	8
4		733.3	1.40	1.50	198	322	91	253	62	8
5		735.2	1.40	1.50	195	321	91	254	62	8
6	17:27	736.9	1.20	1.29	191	320	91	254	62	7
1	17:29	738.7	1.35	1.45	200	321	90	255	62	8
2		740.5	1.40	1.50	203	321	90	255	62	8
3		742.2	1.40	1.50	207	322	90	255	63	8
4		743.9	1.40	1.50	207	321	90	254	63	8
5		745.7	1.40	1.50	203	322	90	255	63	8
6	17:44	747.4	1.25	1.34	204	321	90	254	63	7

Sulfuric Acid Mist Field Data Form (Continued)

Traverse Point No.	Clock Time	Gas Sample Volume (Ft ³)	ΔP (In. H ₂ O)	ΔH (In. H ₂ O)	Probe Temp. (°F)	Stack Temp. Ts (°F)	Meter Temp. (°F)	Umbilical Temp. Tm (°F)	Last Imp. Temp. (°F)	Vacuum (In. Hg)
1	17:45	749.2	1.35	1.45	197	320	89	254	64	7
2		751.0	1.40	1.50	200	322	89	254	64	8
3		752.8	1.40	1.50	195	321	90	255	64	8
4		754.6	1.40	1.50	204	321	90	255	64	8
5		756.4	1.40	1.50	204	320	90	256	64	8
6	18:00	758.1	1.20	1.29	196	320	90	256	64	7
1	18:02	759.9	1.35	1.45	198	319	89	255	64	7
2		761.7	1.40	1.50	201	322	90	256	64	8
3		763.5	1.40	1.50	196	321	89	256	64	8
4		765.3	1.40	1.50	197	322	89	256	65	8
5		767.1	1.40	1.50	199	322	90	256	65	8
6	18:17	768.895	1.25	1.35	196	321	90	256	65	7

Sulfuric Acid Mist Field Data Form

Plant Polk Power Station
 Location Unit #1 Hesp
 Date 4-25-00
 Method No. 8
 Run No. 9
 Box Operator AB
 Probe Operator CUC/jaw
 Time - Start 18:49 End: 20:00
 Sampling Time 60 min
 Min. 1 Pt 2.5
 Meter Box No. 6
 Stack Area Ft² 283.530
 Meter Cal. (ΔH) 1.756
 Meter Cal. (ΔY) 1.001

Nozzle I.D. No. #47
 Nozzle Diameter 0.201
 Pitot Tube No. 00122
 Pitot Tube (C_p) 0.87
 Probe Length 14.0
 Probe Liner Material Pyrex
 Probe Heater Setting 300 °F
 Pressure Pb ("Hg): 24.50 Pg ("H₂O): .97 Ps ("Hg): 24.48
 Ambient Temperature 51 °F
 Assumed Moisture (%) 6.0
 Filter Holder No. _____
 Comments _____

Dry Gas Meter Volume
 Final 820.390 Ft³
 Initial 777.624 Ft³
 Net 42.766 Ft³

Equipment Leak Checks
 Initial 0.000 CFM @ 15 "Hg
 Final 0.000 CFM @ 6 "H₂O
 Pitot Tube OK @ 4.6 "H₂O

Moisture Determination
 Impinger 24 ml
 Silica Gel 19.1 gm
 Total 43.1 gm

reviewed - RTM 5/1/2000

Traverse Point No.	Clock Time	Gas Sample Volume (Ft ³)	Δ P (In. H ₂ O)	Δ H (In. H ₂ O)	Probe Temp. (°F)	Stack Temp. Ts (°F)	Meter Temp. (°F)	Umbilical Temp. Tm (°F)	Last Imp. Temp. (°F)	Vacuum (In. Hg)
1	18:49	779.5	1.35	1.45	217	323	86	260	63	6
2		781.3	1.40	1.50	217	322	86	259	62	6
3		783.3	1.40	1.50	214	322	87	259	63	6
4		784.9	1.40	1.50	206	322	87	258	63	6
5		786.7	1.40	1.50	202	321	88	257	64	6
6	19:04	788.4	1.25	1.35	198	320	88	257	64	5
1	19:06	790.2	1.35	1.45	192	315	87	257	64	5
2		792.0	1.40	1.50	195	323	87	257	64	5
3		793.8	1.40	1.50	194	321	87	256	64	5
4		795.6	1.40	1.50	197	322	87	255	64	5
5		797.4	1.40	1.50	201	322	88	255	64	5
6	19:21	799.2	1.25	1.35	201	320	88	255	64	5

Sulfuric Acid Mist Field Data Form (Continued)

Traverse Point No.	Clock Time	Gas Sample Volume (Ft ³)	Δ P (In. H ₂ O)	Δ H (In. H ₂ O)	Probe Temp. (°F)	Stack Temp. Ts (°F)	Meter Temp. (°F)	Umbilical Temp. Tm (°F)	Last Imp. Temp. (°F)	Vacuum (In. Hg)
1	19:23	800.9	1.30	1.40	208	320	87	250	64	5
2		802.7	1.40	1.50	214	323	88	251	64	5
3		804.5	1.40	1.50	223	323	88	252	64	5
4		806.3	1.40	1.50	221	322	88	253	64	5
5		808.2	1.40	1.50	221	324	88	253	64	5
6	19:38	809.8	1.20	1.29	221	320	87	254	63	5
1	19:40	811.6	1.35	1.45	205	321	85	240	63	5
2		813.4	1.40	1.50	213	322	85	235	63	5
3		815.2	1.40	1.50	215	322	85	231	64	5
4		817.9	1.40	1.50	190	324	84	250	65	5
5		818.8	1.40	1.50	187	326	83	253	64	5
6	19:55	820.390	1.20	1.29	190	323	83	253	63	5
	20:00									

Sulfuric Acid Mist Field Data Form

Plant Polk Power Station
 Location Unit #1 HRSG
 Date 4-26-00
 Method No. 8
 Run No. 10
 Box Operator RAS
 Probe Operator CVC/JAW
 Time - Start 10:18 End: 11:25
 Sampling Time 60 min
 Min. \ Pt 2.5
 Meter Box No. 6
 Stack Area Ft² 283.529
 Meter Cal. (ΔH) 1.756
 Meter Cal. (ΔY) 1.601

Nozzle I.D. No. #47
 Nozzle Diameter 0.201
 Pitot Tube No. 00122
 Pitot Tube (C_p) 0.84
 Probe Length 14.0
 Probe Liner Material Pyrex
 Probe Heater Setting 300 °F
 Pressure Pb ("Hg): 29.45 Pg ("H2O): -1.00 Ps ("Hg): 29.58
 Ambient Temperature 60 °F
 Assumed Moisture (%) 6.0 %
 Filter Holder No. _____
 Comments _____

Dry Gas Meter Volume
 Final 870.380 Ft³
 Initial 828.117 Ft³
 Net 42.263 Ft³

Equipment Leak Checks
 Initial 0.000 CFM @ 15 "Hg
 Final 0.000 CFM @ 7 "H2O
 Pitot Tube OK @ 4.7 "H2O

Moisture Determination
 Impinger 28 ml
 Silica Gel 20.6 gm
 Total 48.6

revised - RSM 5/1/2000

Traverse Point No.	Clock Time	Gas Sample Volume (Ft ³)	Δ P (In. H ₂ O)	Δ H (In. H ₂ O)	Probe Temp. (°F)	Stack Temp. Ts (°F)	Meter Temp. (°F)	Umbilical Temp. Tm (°F)	Last Imp. Temp. (°F)	Vacuum (In. Hg)
1	10:18	829.9	1.35	1.41	207	325	67	267	62	7
2		831.7	1.40	1.46	209	325	69	268	56	5
3		833.5	1.45	1.51	213	324	70	266	56	5
4		835.3	1.50	1.56	219	325	70	268	57	5
5		837.0	1.50	1.56	219	325	71	267	58	5
6	10:33	838.8	1.35	1.41	217	325	71	266	59	5
1	10:36	840.6	1.40	1.46	208	323	71	266	60	5
2		842.3	1.40	1.46	196	324	71	267	60	5
3		844.1	1.40	1.46	193	324	72	264	60	5
4		845.8	1.40	1.46	194	324	72	266	61	5
5		847.5	1.40	1.46	190	325	73	267	61	5
6	10:51	849.2	1.25	1.31	186	323	74	265	62	5

Sulfuric Acid Mist Field Data Form (Continued)

Traverse Point No.	Clock Time	Gas Sample Volume (F ³)	ΔP (In. H ₂ O)	ΔH (In. H ₂ O)	Probe Temp. (°F)	Stack Temp. Ts (°F)	Meter Temp. (°F)	Umbilical Temp. Tm (°F)	Last Imp. Temp. (°F)	Vacuum (In. Hg)
1	10:53	851.0	1.45	1.51	202	323	73	268	63	5
2		852.7	1.50 ⁴⁵ _m	1.51	200	325	73	267	63	5
3		854.5	1.45	1.51	203	325	73	266	63	5
4		856.3	1.45	1.51	203	324	74	264	63	5
5		858.0	1.45	1.51	208	324	75	266	63	5
6	11:08	859.7	1.25	1.31	198	323	75	267	63	5
1	11:10	861.5	1.45	1.51	196	323	74	267	63	5
2		863.3	1.45	1.51	190	326	75	267	64	5
3		865.1	1.50	1.57	194	327	76	267	64	6
4		866.9	1.50	1.57	192	326	76	264	63	6
5		868.7	1.50	1.57	193	326	76	264	63	6
6	11:25	870.380	1.25	1.31	190	325	76	266	63	5

Sulfuric Acid Mist Field Data Form

Plant Polk Power Station
 Location Unit #1 H2SO4
 Date 4-26-00
 Method No. 8
 Run No. 11
 Box Operator RAD
 Probe Operator CVC/JAW
 Time - Start 12:02 End: 13:08
 Sampling Time 60 MIN
 Min. \ Pt 2.5
 Meter Box No. #6
 Stack Area Ft² 283.529
 Meter Cal. (ΔH) 1.756
 Meter Cal. (ΔY) 1.001

Nozzle I.D. No. #47
 Nozzle Diameter 0.201
 Pitot Tube No. 00122
 Pitot Tube (C_p) 0.84
 Probe Length 14.0
 Probe Liner Material Pyrex
 Probe Heater Setting 300 °F
 Pressure Pb ("Hg): 25.65 Pg ("H2O): -1.00 Ps ("Hg): 29.58
 Ambient Temperature 63 °F
 Assumed Moisture (%) 6.0 %
 Filter Holder No. _____
 Comments _____

Dry Gas Meter Volume
 Final 922.498 Ft³
 Initial 879.827 Ft³
 Net 42.671 Ft³

Equipment Leak Checks
 Initial 0.000 CFM @ 15 "Hg
 Final 0.000 CFM @ 5 "H₂O
 Pitot Tube OK @ 4.7 "H₂O

Moisture Determination
 Impinger 32 ml
 Silica Gel 20.4 gm
 Total 52.4 ✓

reviewed - BEM 4/1/2000

Traverse Point No.	Clock Time	Gas Sample Volume (Ft ³)	ΔP (In. H ₂ O)	ΔH (In. H ₂ O)	Probe Temp. (°F)	Stack Temp. Ts (°F)	Meter Temp. (°F)	Umbilical Temp. Tm (°F)	Last Imp. Temp. (°F)	Vacuum (In. Hg)
1	12:02	881.7	1.45	1.51	205	325	74	266	57	5
2		883.4	1.45	1.51	207	325	76	267	57	5
3		885.2	1.45	1.51	204	325	77	265	57	5
4		887.0	1.50	1.57	205	326	78	268	58	5
5		888.9	1.50	1.57	201	326	79	265	59	5
6	12:17	890.1	1.25	1.31	194	326	79	264	59	5
1	12:19	892.3	1.45	1.51	203	324	77	266	60	5
2		894.1	1.45	1.51	217	325	78	267	60	5
3		895.9	1.45	1.51	211	324	79	265	61	5
4		897.7	1.45	1.51	210	324	80	266	62	5
5		899.4	1.45	1.51	215	325	80	265	62	5
6	12:34	901.1	1.25	1.31	222	323	81	265	63	5

Sulfuric Acid Mist Field Data Form (Continued)

Traverse Point No.	Clock Time	Gas Sample Volume (Ft ³)	ΔP (In. H ₂ O)	ΔH (In. H ₂ O)	Probe Temp. (°F)	Stack Temp. Ts (°F)	Meter Temp. (°F)	Umbilical Temp. Tm (°F)	Last Imp. Temp. (°F)	Vacuum (In. Hg)
1	12:36	902.9	1.40	1.46	216	324	80	267	63	5
2		904.7	1.45	1.51	220	326	81	268	64	5
3		906.5	1.45	1.51	215	326	82	268	64	5
4		908.3	1.45	1.51	208	325	82	269	64	5
5		910.0	1.45	1.51	207	325	82	266	64	5
6	12:51	911.7	1.25	1.31	213	325	83	265	64	5
1	12:53	913.6	1.45	1.51	212	326	82	266	64	5
2		915.3	1.45	1.51	211	325	83	266	64	5
3		917.1	1.45	1.51	215	325	83	264	65	5
4		919.0	1.50	1.57	217	324	84	266	65	5
5		920.8	1.45	1.51	227	324	84	266	65	5
6	13:08	922.498	1.25	1.31	229	323	85	267	65	5

F-4 FUEL BLEND ORSAT DATA SHEETS

ORSAT DATA AND CALCULATION SHEET

Source UNIT 1 HRSF Location POCK POWER

Run No.	Date	Gas	Orsat Analysis, Dry Basis (% Volume)				Remarks
			1	2	3	Avg.	
1 <i>Jan</i>	4/24/00	CO ₂	7.0	6.8	7.0	6.9	Replaced bladder on Orsat 001 using bladder from Orsat 002 $F_o = 1.043$
		O ₂	13.6	13.8	13.6	13.7	
		CO	0	0	0	0	
		N ₂	79.4	79.4	79.4	79.4	
2 <i>Jan</i>	4/24/00	CO ₂	7.6	7.6 ^{<i>Jan</i>} 12.5	7.6	7.6	$F_o = 1.039$
		O ₂	13.2	13.0	13.0	13.0	
		CO	0	0	0	0	
		N ₂	79.2	79.4	79.4	79.4	
3 <i>Jan</i>	4/24/00	CO ₂	7.6	7.6	7.6	7.6	$F_o = 1.013$
		O ₂	13.4	13.0	13.2	13.2	
		CO	0	0	0	0	
		N ₂	79.0	79.4	79.2	79.2	

PMM
5/1/2000

ORSAT DATA AND CALCULATION SHEET

Source HRSC UNIT 1 Location DOLK POWER STATION

Run No.	Date	Gas	Orsat Analysis, Dry Basis (% Volume)				Remarks
			1	2	3	Avg.	
6	4/25/00	CO ₂	8.0	8.1	8.2	8.1	F _o = 0.938
		O ₂	13.4	13.2	13.2	13.3	
		CO	0	0	0	0	
		N ₂	78.6	78.6	78.6	78.6	
7	4/25/00	CO ₂	7.8	7.8	7.6	7.7	F _o = 1.013
		O ₂	13.0	13.0	13.2	13.1	
		CO	0	0	0	0	
		N ₂	79.2	79.2	79.2	79.2	
8	4/25/00	CO ₂	7.8	7.8	7.8	7.8	F _o = 1.013
		O ₂	13.0	13.0	13.0	13.0	
		CO	0	0	0	0	
		N ₂	79.2	79.2	79.2	79.2	

AM
5/1/2000

ORSAT DATA AND CALCULATION SHEET

Source HRSG UNIT 1 Location POLK POWER STATION

Run No.	Date	Gas	Orsat Analysis, Dry Basis (% Volume)				Remarks
			1	2	3	Avg.	
9	4/25/00	CO ₂	7.8	7.8	7.6	7.7	$F_o = 1.026$
		O ₂	13.0	13.0	13.0	13.0	
		CO	0	0	0	ϕ	
		N ₂	79.2	79.2	79.4	79.3	
		CO ₂					
		O ₂					
		CO					
		N ₂					
		CO ₂					
		O ₂					
		CO					
		N ₂					

AM
5/1/2000

ORSAT DATA AND CALCULATION SHEET

Source HRSG UNIT 1 Location PDLK POWER STATION

Run No.	Date	Gas	Orsat Analysis, Dry Basis (% Volume)				Remarks
			1	2	3	Avg.	
10	4/26/00	CO ₂	7.8	7.8 7.8	7.8	7.9	$F_D = 1.179$
		O ₂	11.8	11.6	11.6	11.7	
		CO	0	0	0	ϕ	
		N ₂	80.4	80.6	80.6	80.5	
11	4/26/00	CO ₂	8.0 8.0	8.0	8.0	8.0	$F_D = 1.163$
		O ₂	11.6	11.6	11.6	11.6	
		CO	0	0	0	ϕ	
		N ₂	80.4	80.4	80.4	80.4	
		CO ₂					
		O ₂					
		CO					
		N ₂					

BAW
5/1/2000

APPENDIX G

SAMPLE EQUIPMENT CALIBRATIONS

G-1 BASELINE EQUIPMENT CALIBRATIONS

G-2 FUEL BLEND EQUIPMENT CALIBRATIONS

G-1 BASELINE EQUIPMENT CALIBRATIONS

SUMMARY OF EQUIPMENT CALIBRATIONS

EQUIPMENT	CALIBRATION DATE	LOCATION	METHOD	RESULTS
Method 8 Console 6 Initial Test Post Test	10-06-99 03-02-00	CES CES	Wet Test Meter Wet Test Meter	Y = 0.989 Y = 0.965
Nozzle #47 Initial Measurement Post Test	10-04-00 03-03-00	CES CES	3 Measurements w/calipers	DN= 0.201 DN= 0.201
Pyrometer No. 12	1-11-00	CES	Comparison to ASTM Thermometer	Correct to ∇ 2EF
Pitot Tube 00122	1-07-00	CES	EPA Method 2	CP = 0.84
Wet Test Meter Serial No. 12-AH-4	7-01-99	CES	Liquid Displacement	CF= 1.003
Barometer SN 00227	1-04-00	CES	Comparison to National Weather Services	Correct to ∇ 0.01" Hg

INITIAL DRY GAS METER AND ORIFICE CALIBRATION

CONTROL BOX NO. 6 BAROMETRIC PRESS. 30.00 IN. HG.

DATE 06-Oct-99 PERFORMED BY Sunk

SYSTEM LEAK CK. 0.000 @ 27" Hg ORIFICE LEAK CK. OK @ 6.3" H₂O

RUN 1 RUN 2 RUN 3 RUN 4

VACUUM ("Hg)	3.0	3.0	3.0	3.0
dHw ("H ₂ O)	0.5	1.1	1.6	2.0
dHd ("H ₂ O)	0.5	1.0	1.5	2.0
INITIAL WTM	0.000	0.000	0.000	0.000
FINAL WTM	5.9595	8.9333	6.7078	7.6529
INITIAL DGM	674.148	680.514	690.009	697.452
FINAL DGM	680.241	689.775	697.048	705.582
TEMP. WTM (F)	71.0	71.0	71.0	71.0
TEMP. DGM (F)	87.0	89.0	90.0	91.0
TEST TIME (MIN.)	15.0	16.0	10.0	10.0

NET VOLUME WTM	5.9595	8.9333	6.7078	7.6529
NET VOLUME DGM	6.093	9.261	7.039	8.130
Y	1.006	0.995	0.983	0.972
dH@	1.725	1.741	1.806	1.847

AVERAGE Y = 0.989

ACCEPTABLE Y RANGE = 0.969 TO 1.009

AVERAGE dH@ = 1.780

ACCEPTABLE dH@ RANGE = 1.630 TO 1.930

$$Y = (V_w (P_b) \times (T_d + 460)) / (V_d (P_b + (dH_d / 13.6)) \times (T_w + 460))$$

$$dH@ = 0.0317 \times dH_d / (P_b (T_d + 460)) \times ((T_w + 460) \times \text{time}) / V_w^2$$

Reviewed By: RAM

Date: 11/15/99

RECHECK OF ORIFICE AND DGM CALIBRATION

CONTROL BOX NO. 6 BAROMETRIC PRESS. 30.10 IN. HG.

DATE 3-2-00 PERFORMED BY BDR JZK

PRIOR Y = 0.989

SYSTEM LEAK CK. 0.000 @ 7" Hg

RUN 1	RUN 2	RUN 3
-------	-------	-------

VACUUM ("Hg)	7.0	7.0	7.0
dHw ("H2O)	1.05	1.05	1.05
dHd ("H2O)	1.00	1.00	1.00
INITIAL WTM	0.0000	8.3365	16.5600
FINAL WTM	8.3365	16.5600	24.7382
INITIAL DGM	302.780	311.688	320.485
FINAL DGM	311.688	320.485	329.246
TEMP. WTM (F)	70.5	70.5	70.0
TEMP. DGM (F)	88.0	89.0	90.0
TEST TIME (MIN.)	15.0	15.0	15.0

NET VOLUME WTM	8.3365	8.2235	8.1782
NET VOLUME DGM	8.908	8.797	8.761
Y	0.964	0.965	0.966
dH@	1.751	1.796	1.809

PRIOR Y = 0.989
 RECHECK Y = 0.965
 % DIFFERENCE = -2.427

AVERAGE dH@ = 1.786

$$Y = (V_w (P_b) \times (T_d + 460)) / (V_d (P_b + (dH_d / 13.6)) \times (T_w + 460))$$

$$dH@ = 0.0317 \times dH_d / (P_b (T_d + 460)) \times ((T_w + 460) \times \text{time} / V_w)^2$$

Reviewed By: *RBW*

Date: 3/13/2000

NOZZLE CALIBRATION DATA FORM

NOZZLE SET NO. 1

DATE: 10/04/99

CALIBRATOR: Bruce D. Rodriguez BDR

NOZZLE I. D.	NOZZLE DIAMETER (IN.)			D diff.	D avg.
	D1	D2	D3		
#1	0.110	0.114	0.114	0.004	0.113
#4	0.122	0.122	0.122	0.000	0.112
#5	0.146	0.146	0.150	0.004	0.147
#6	0.197	0.197	0.193	0.004	0.196
#9	0.276	0.276	0.276	0.000	0.276
#10	0.293	0.293	0.293	0.000	0.293
#12	0.386	0.386	0.388	0.002	0.387
#15	0.159	0.159	0.159	0.000	0.159
#16	0.197	0.197	0.197	0.000	0.197
#19	0.278	0.278	0.280	0.002	0.279
#22	0.364	0.366	0.366	0.002	0.365
#30	0.309	0.311	0.311	0.002	0.310
#36	0.185	0.185	0.185	0.000	0.185
#37	0.211	0.211	0.211	0.000	0.211
#38	0.248	0.248	0.248	0.000	0.248
#46	0.189	0.189	0.189	0.000	0.189
#47	0.201	0.201	0.201	0.000	0.201
#48	0.250	0.252	0.250	0.002	0.251
#50	0.311	0.311	0.311	0.000	0.311
#58	0.240	0.240	0.240	0.000	0.240
#68	0.240	0.240	0.242	0.002	0.241

where:

D 1,2,3 = three different nozzle diameters, (in); each diameter must be measured to the nearest 0.001 in.

D diff. = maximum difference between any two diameters, (in.) must be .004 in. or less.

D avg. = average of D1, D2, and D3.

REVIEWED BY: RAM
DATE: 11/15/99

Page 1
OF 1

FINAL NOZZLE CALIBRATION DATA FORM

NOZZLE NO. 47

DATE: 3-3-00

CALIBRATED BY: BDR BDR

NOZZLE IDENTIFICATION	NOZZLE DIAMETER			1/2 D (IN.)	D AVG
	D1 (IN.)	D2 (IN.)	D3 (IN.)		
47	0.201	0.201	0.201	0.000	0.201
				ERR	ERR
				ERR	ERR
				ERR	ERR
				ERR	ERR

where:

D1,2,3= three different nozzle diameters,(in); each diameter must be measured to the nearest 0.001 in.

1/2 D= maximum difference between any two diameters,(in.)
 1/2 D ≤ 0.004 in.

D AVG= average of D1,D2 and D3.

Reviewed By: BDR
 Date: 3/13/2000

PYROMETER CALIBRATION

PYROMETER NO.: 12

REFERENCE THERMOMETER: ASTM 2-F

CTL SERIAL NO.: 12


SERIAL NO.: L98-213

DATE: 1-11-00

CALIBRATOR: B. P. Kelly

REFERENCE TEMP. (F)	PYROMETER INDICATION
32	33
212	212
400	399

PYROMETER TEMPERATURE CALIBRATION




REVIEWED BY: Btm

DATE: 2/21/00


SERIAL NO. 00122

CALIBRATED BY: SON

DATE 1-7-00




$D_t = 0.95$ cm.



PITOT TUBE OPENINGS DAMAGED? NO

COMMENTS: _____

DEGREE INDICATING LEVEL




PITOT TUBE CALIBRATION SET-UP POSITION

Reviewed By: BAM
Date: 2/21/00

SERIAL NO. 00122

CALIBRATED BY BOA



DATE 1-7-00



DEGREE INDICATING LEVEL POSITION
FOR DETERMINING β_1 and β_2 .

$$\beta_1 = \underline{0.15}^\circ (<5^\circ)$$


$$\beta_2 = \underline{0.2}^\circ (<5^\circ)$$



DEGREE INDICATING LEVEL POSITION
FOR DETERMINING
 α_1 and α_2 .

$$\alpha_1 = \underline{0.4}^\circ (<10^\circ)$$

$$\alpha_2 = \underline{0.4}^\circ (<10^\circ)$$




PITOT TUBE CALIBRATION; α and β DETERMINATION

Reviewed By: BTM
Date: 2/21/00

SERIAL NO. 00122

CALIBRATED BY BOH

DATE 1-7-00




DEGREE INDICATING LEVEL POSITION
FOR DETERMINING γ , THEN CALCULATING Z.

$$\gamma = \underline{0.9}^{\circ}$$

A = DISTANCE BETWEEN TIPS, ($P_a + P_b$), cm. = 2.360
~~0.9~~ cm.

Z = A sin γ = 0.1037 cm; (<0.32 cm).

DEGREE INDICATING LEVEL
POSITION FOR DETERMINING
 θ , THEN CALCULATING W.



$$\theta = \underline{0.2}^{\circ}$$

W = A sin θ = 0.008 cm; (<0.08 cm).

PITOT TUBE CALIBRATION: A, W, γ , θ and Z DETERMINATION

Reviewed By: BAM
Date: 2/21/00

WET TEST METER CALIBRATION DATA FORM

DATE: 07/01/99

BAROMETRIC PRESS: 30.09

WET TEST METER
SERIAL NUMBER

NAME: *Sub*

AMBIENT TEMP: 70.5

12-AH-4

RUN NUMBER	VOLUME OF WATER DISPLACED (LITERS) V_a	INITIAL METER READING (FT3)	FINAL METER READING (FT3)	NET METER VOLUME (FT3)	NET METER VOLUME (LITERS) V_w	ERROR
1	3.3600	0.0000	0.1184	0.1184	3.3531	-0.002053571
2	3.3600	0.1184	0.2372	0.1188	3.3644	0.001309524
3	3.3600	0.2372	0.3555	0.1183	3.3503	-0.002886905
4	3.3600	0.3555	0.4731	0.1176	3.3304	-0.008809524
AVG. ERROR =						-0.003110119

CALCULATIONS:

$$\text{ERROR} = (V_w - V_a) / V_a$$

$$\text{CORRECTION FACTOR (C.F.)} = 1 / (1 + \text{AVERAGE ERROR})$$

* CONVERSION FACTOR, FT3 TO LITERS = FT3 x 28.32

CORRECTION FACTOR: 1.003119822
(1.000 +/- 0.010)

WHEN USING THE WET TEST METER, THE ACTUAL VOLUME OF AIR CAN BE DETERMINED BY THE EQUATION:

$$V_a = V_w \times \text{C.F.}$$

WHERE:

V_a = ACTUAL VOLUME OF AIR PASSED THROUGH THE WET TEST METER.

V_w = MEASURED VOLUME OF AIR PASSED THROUGH THE WET TEST METER.

C.F. = CORRECTION FACTOR FOR THE WET TEST METER.

REVISED 5-9-96

REVIEWED BY:

DATE:

BAM Spady
07/01/99

BAROMETER CALIBRATION DATA FORM

DATE: 1-4-00

CALIBRATOR: BDR

INST. NO: 227

COMMENTS: _____

TIME OF READING	BAROMETER READING (HG")	REFERENCE STANDARD READING (HG")	DIFFERENCE (HG")
1020	30.22	30.16	0.06
1215	30.15	30.14	0.01
1400	30.13	30.13	0.00
			0.00
			0.00
			0.00

*NOTE: BAROMETRIC READINGS MUST AGREE WITHIN 0.1 INCHES HG OF READINGS OBTAINED FROM THE REFERENCE STANDARD, THE NATIONAL WEATHER SERVICE, RUSKIN FL. TO BE DEEMED ACCEPTABLE.

REVIEWED BY: *BDR*
DATE: 2/21/00

G-2 FUEL BLEND EQUIPMENT CALIBRATIONS

SUMMARY OF EQUIPMENT CALIBRATIONS

EQUIPMENT	CALIBRATION DATE	LOCATION	METHOD	RESULTS
Method 8 Console 6 Initial Test Post Test	4-03-00 05-01-00	CES CES	Wet Test Meter Wet Test Meter	Y = 0.986 Y = 0.987
Nozzle #47 Initial Measurement Post Test	10-04-00 05-01-00	CES CES	3 Measurements w/calipers	DN= 0.201 DN= 0.202
Pyrometer No. 12	4-13-00	CES	Comparison to ASTM Thermometer	Correct to ∇ 2EF
Pitot Tube 00122	4-07-00	CES	EPA Method 2	CP = 0.84
Wet Test Meter Serial No. 12-AH-4	1-04-00	CES	Liquid Displacement	CF= 1.003
Barometer SN 00227	4-13-00	CES	Comparison to National Weather Services	Correct to ∇ 0.01" Hg

INITIAL DRY GAS METER AND ORIFICE CALIBRATION

CONTROL BOX NO. 6 BAROMETRIC PRESS. 30.08 IN. HG.
 DATE 4-3-00 PERFORMED BY bdr BOR
 SYSTEM LEAK CK. 0.000 15" Hg ORIFICE LEAK CK. ok @ 5.8" H2O

	RUN 1	RUN 2	RUN 3	RUN 4
VACUUM ("Hg)	3.0	3.0	3.0	3.0
dHw ("H2O)	0.6	1.1	1.6	2.0
dHd ("H2O)	0.5	1.0	1.5	2.0
INITIAL WTM	0.000	6.118	16.769	23.495
FINAL WTM	6.118	14.500	23.495	31.130
INITIAL DGM	877.242	883.515	894.710	901.885
FINAL DGM	883.515	892.302	901.885	910.136
TEMP. WTM (F)	69.5	69.5	69.5	69.5
TEMP. DGM (F)	86.0	92.0	95.0	97.0
TEST TIME (MIN.)	15.0	15.0	10.0	10.0

NET VOLUME WTM	6.1180	8.3820	6.7260	7.6350
NET VOLUME DGM	6.273	8.787	7.175	8.251
Y	1.004	0.992	0.979	0.969
dH@	1.627	1.714	1.765	1.820

AVERAGE Y = 0.986
 ACCEPTABLE Y RANGE = 0.966 TO 1.006
 AVERAGE dH@ = 1.731
 ACCEPTABLE dH@ RANGE = 1.581 TO 1.881

$Y = (V_w (P_b) \times (T_d + 460)) / (V_d (P_b + (dH_d / 13.6)) \times (T_w + 460))$
 $dH@ = 0.0317 \times dH_d / (P_b (T_d + 460)) \times ((T_w + 460) \times \text{time}) / V_w^2$

Reviewed By: *LTW*
 Date: 5/1/2000

RECHECK OF ORIFICE AND DGM CALIBRATION

CONTROL BOX NO. 6 BAROMETRIC PRESS. 30.08 IN. HG.

DATE 5-1-00 PERFORMED BY RAB/JAW

PRIOR Y = 1.001

SYSTEM LEAK CK. 0.000 @ 10 In Hg

RUN 1	RUN 2	RUN 3
-------	-------	-------

VACUUM ("Hg)	10.0	10.0	10.0
dHw ("H2O)	1.05	1.05	1.05
dHd ("H2O)	1.00	1.00	0.99
INITIAL WTM	0.0000	8.3992	16.7632
FINAL WTM	8.3992	16.7632	25.1080
INITIAL DGM	217.472	226.187	234.879
FINAL DGM	226.187	234.899	243.567
TEMP. WTM (F)	71.0	70.5	69.5
TEMP. DGM (F)	85.0	86.0	86.0
TEST TIME (MIN.)	15.0	15.0	15.0

NET VOLUME WTM	8.3992	8.3640	8.3448
NET VOLUME DGM	8.715	8.712	8.688
Y	0.987	0.986	0.988
dH@	1.739	1.747	1.731

PRIOR Y = 1.001

RECHECK Y = 0.987

% DIFFERENCE = -1.399

AVERAGE dH@ = 1.739

$$Y = (V_w (P_b) \times (T_d + 460)) / (V_d (P_b + (dH_d / 13.6)) \times (T_w + 460))$$

$$dH@ = 0.0317 \times dH_d / (P_b (T_d + 460)) \times ((T_w + 460) \times \text{time} / V_w)^2$$

Reviewed By: LTm

Date: 5/2/2000

NOZZLE CALIBRATION DATA FORM

NOZZLE SET NO. 1

DATE: 4-3-00

CALIBRATOR: BDR BDN

NOZZLE I. D.	NOZZLE DIAMETER (IN.)			D diff.	D avg
	D1	D2	D3		
#1	0.114	0.114	0.112	0.002	0.113
#4	0.124	0.124	0.124	0.000	0.124
#5	0.15	0.15	0.15	0.000	0.150
#6	0.193	0.193	0.193	0.000	0.193
#9	0.278	0.278	0.278	0.000	0.278
#10	0.295	0.295	0.295	0.000	0.295
#12	0.395	0.395	0.394	0.001	0.395
#15	0.161	0.161	0.159	0.002	0.160
#16	0.197	0.197	0.197	0.000	0.197
#19	0.280	0.280	0.278	0.002	0.279
#22	0.366	0.366	0.366	0.000	0.366
#30	0.311	0.311	0.311	0.000	0.311
#36	0.187	0.187	0.185	0.002	0.186
#37	0.213	0.213	0.211	0.002	0.212
#38	0.252	0.252	0.252	0.000	0.252
#46	0.193	0.191	0.191	0.002	0.192
#47	0.201	0.201	0.201	0.000	0.201
#48	0.252	0.250	0.252	0.002	0.251
#50	0.311	0.313	0.313	0.002	0.312
#58	0.242	0.240	0.242	0.002	0.241
#68	0.242	0.242	0.242	0.000	0.242

where:

D 1,2,3 = three different nozzle diameters, (in); each diameter must be measured to the nearest 0.001 in.

D diff. = maximum difference between any two diameters, (in.) must be .004 in. or less.

D avg. = average of D1, D2, and D3.

REVIEWED BY: ASms
DATE: 5/1/2000

Page 1
OF 1

FINAL NOZZLE CALIBRATION DATA FORM

NOZZLE NO. 1

DATE: May 01, 2000

CALIBRATED BY: Jim Werner _____

NOZZLE IDENTIFICATION	NOZZLE DIAMETER			1/4D (IN.)	D AVG
	D1 (IN.)	D2 (IN.)	D3 (IN.)		
47	0.201	0.201	0.203	0.002	0.202

where:

D1,2,3= three different nozzle diameters,(in); each diameter must be measured to the nearest 0.001 in.

1/4D= maximum difference between any two diameters,(in).
1/4D≧ 0.004 in.

D AVG= average of D1,D2 and D3


Reviewed By: *JTW*
Date: 5/2/2000

PYROMETER CALIBRATION

PYROMETER NO.: 12 REFERENCE THERMOMETER: ASTM 2-F
CTL SERIAL NO.: 12 SERIAL NO.: L98-218
DATE: 4-13-00 CALIBRATOR: BDR *BDR*

REFERENCE TEMP (F)	PYROMETER INDICATION
32	32
212	213
400	401


PYROMETER TEMPERATURE CALIBRATION




REVIEWED BY: *ASTM*

DATE: 5/1/2000


SERIAL NO. 00122
 CALIBRATED BY: BUL
 DATE 4-7-00



$D_t = 0.95 \text{ cm.}$



PITOT TUBE OPENINGS DAMAGED? no
 COMMENTS: _____



DEGREE INDICATING LEVEL


PITOT TUBE CALIBRATION SET-UP POSITION

Reviewed By: AM
 Date: 5/1/2000

SERIAL NO. 00122

CALIBRATED BY BUN



DATE 4-7-00



DEGREE INDICATING LEVEL POSITION
FOR DETERMINING β_1 and β_2 .

$$\beta_1 = \underline{0.6}^\circ (<5^\circ)$$


$$\beta_2 = \underline{0.5}^\circ (<5^\circ)$$



DEGREE INDICATING LEVEL
POSITION FOR DETERMINING
 α_1 and α_2 .

$$\alpha_1 = \underline{1.8}^\circ (<10^\circ)$$

$$\alpha_2 = \underline{1.4}^\circ (<10^\circ)$$




PITOT TUBE CALIBRATION; α and β DETERMINATION

Reviewed By: RAM
Date: 5/1/2000

SERIAL NO. 00122

CALIBRATED BY BUN

DATE 4-7-00



DEGREE INDICATING LEVEL POSITION
FOR DETERMINING γ , THEN CALCULATING Z.

$$\gamma = \underline{1.2}^{\circ}$$


A = DISTANCE BETWEEN TIPS, ($P_a + P_b$), cm. = 2.35.

Z = A sin γ = 0.049 cm; (<0.32 cm).

DEGREE INDICATING LEVEL
POSITION FOR DETERMINING
 θ , THEN CALCULATING W.

$$\theta = \underline{0.5}^{\circ}$$

W = A sin θ = 0.021 cm; (<0.08 cm).



PITOT TUBE CALIBRATION: A, W, γ , θ and Z DETERMINATION

Reviewed By: BAM
Date: 5/1/2000

WET TEST METER CALIBRATION DATA FORM

DATE: 1-4-00

BAROMETRIC PRESS: 30.2

WET TEST METER
SERIAL NUMBER

NAME: BDR 601

AMBIENT TEMP: 73

12-AH-4

RUN NUMBER	VOLUME OF WATER DISPLACED (LITERS) V_a	INITIAL METER READING (FT3)	FINAL METER READING (FT3)	NET METER VOLUME (FT3)	NET METER VOLUME (LITERS) V_w	ERROR
1	3.3600	0.0000	0.1180	0.1180	3.3418	-0.005416667
2	3.3600	0.1180	0.2362	0.1182	3.3474	-0.003750000
3	3.3600	0.2362	0.3548	0.1186	3.3588	-0.000357143
4	3.3600	0.3548	0.4730	0.1182	3.3474	-0.003750000
					AVG. ERROR =	-0.003318453

CALCULATIONS:

$$ERROR = (V_w - V_a) / V_a$$

$$CORRECTION FACTOR (C.F.) = 1 / (1 + AVERAGE ERROR)$$

* CONVERSION FACTOR, FT3 TO LITERS = FT3 x 28.32

CORRECTION FACTOR: 1.003329501
(1.000 +/- 0.010)

WHEN USING THE WET TEST METER, THE ACTUAL VOLUME OF AIR CAN BE DETERMINED BY THE EQUATION:

$$V_a = V_w \times C.F.$$

WHERE:

V_a = ACTUAL VOLUME OF AIR PASSED THROUGH THE WET TEST METER.

V_w = MEASURED VOLUME OF AIR PASSED THROUGH THE WET TEST METER.

C.F. = CORRECTION FACTOR FOR THE WET TEST METER.

REVISED 5-9-96

REVIEWED BY: RAM

DATE: 2/21/00

BAROMETER CALIBRATION DATA FORM

DATE: 4-13-00

CALIBRATOR: bdr son

INST. NO: 227

COMMENTS: Adjusted after 1015 reading.

TIME OF READING	BAROMETER READING (HG")	REFERENCE STANDARD READING (HG")	DIFFERENCE (HG")
815	30.12	30.11	0.01
1015	30.25	30.13	0.12
1230	30.14	30.15	-0.01
1430	30.08	30.10	-0.02
			0.00
			0.00

***NOTE: BAROMETRIC READINGS MUST AGREE WITHIN 0.1 INCHES HG OF READINGS OBTAINED FROM THE REFERENCE STANDARD, THE NATIONAL WEATHER SERVICE, RUSKIN FL. TO BE DEEMED ACCEPTABLE.**

REVIEWED BY: Stm
 DATE: 5/1/2000

APPENDIX H

CHAIN OF CUSTODY

H-1 BASELINE CHAIN OF CUSTODY

H-2 FUEL BLEND CHAIN OF CUSTODY

H-1 BASELINE CHAIN OF CUSTODY

SAMPLE RECOVERY AND INTEGRITY DATA

Plant POLK POWER STATION Sample location Unit #1

Field Data Checks

Sample recovery personnel R.A. BARTHELETTE

Person with direct responsibility for recovered samples SAME AS ABOVE

Sample Number	Sample Identification Number	Date and Time of Recovery	Liquid Level Marked	Stored in refrigerated Container
1	BASE-1 ISOPHASE	1-7-00 ²⁻⁷⁻⁰⁰ @ 11:56	✓	✓
2	BASE-2 "	1-7-00 ²⁻⁷⁻⁰⁰ @ 15:17	✓	✓
3	BASE-3 "	1-7-00 ²⁻⁷⁻⁰⁰ @ 17:13	✓	✓
4	BASE-4 "	1-7-00 ²⁻⁷⁻⁰⁰ @ 19:10	✓	✓
5		1-7-00		
6				
Blank				

Remarks _____

Signature of field sample trustee *R.A. Barthelette*

Laboratory Data Checks

Lab person with direct responsibility for recovered samples Alvin Alonzo

Date recovered samples received 2-8-00 @ 0700

Analyst Alvin Alonzo

Sample Number	Sample Identification Number	Date and Time of Recovery	Liquid Level Marked	Stored in refrigerated Container
1	BASE-1 ISOPHASE	2-8-00 @ 0700	✓	✓
2	BASE-2 "	2-8-00 @ 0700	✓	✓
3	BASE-3 "	2-8-00 @ 0700	✓	✓
4	BASE-4 "	2-8-00 @ 0700	✓	✓
5				
6				
Blank				

H-2 FUEL BLEND CHAIN OF CUSTODY

TAMPA ELECTRIC COMPANY
SAMPLE CHAIN OF CUSTODY

GENERATING STATION Polk
SOURCE IDENTIFICATION Unit 4 60% Petcoke
DATE OF TEST 4/24/00
POLLUTANT SAMPLED H₂SO₄

SAMPLE RECOVERY

LOCATION Corporate Environmental Services
DATE/TIME 4/24/00 23:00
SIGNATURE (Signature) C. Corona Jr
TITLE Tech.

SAMPLE ANALYSIS

LOCATION CORPORATE ENVIRONMENTAL SERVICES
DATES 4-25-00 @ 8:00
SIGNATURE (Signature)
TITLE _____

CONTAINER CODE	SAMPLE IDENTIFICATION	ANALYTICAL METHOD
<u>H₂O₂ Run 1 @ 12:29</u>	<u>Hydrogen Peroxide</u>	<u>USEPA 8</u>
<u>H₂O₂ Run 2 @ 14:53</u>	}	}
<u>H₂O₂ Run 3 @ 19:31</u>		

SAMPLE RECOVERY AND INTEGRITY DATA

Plant F.J. GANNON STATION Sample location UNIT 03

Field Data Checks

Sample recovery personnel CRAIG V. CORONADO

Person with direct responsibility for recovered samples CRAIG V. CORONADO

Sample Number	Sample Identification Number	Date and Time of Recovery	Liquid Level Marked	Stored in refrigerated Container
1	RUN 1 H ₂ O ₂	4/28/00 @ 335	✓	✓
2	RUN 2 H ₂ O ₂	4/28/00 @ 507	✓	✓
3	RUN 3 H ₂ O ₂	4/28/00 @ 645	✓	✓
4				
5				
6				
Blank				

Remarks WDF BASELINE

Signature of field sample trustee Craig V. Coronado

Laboratory Data Checks

Lab person with direct responsibility for recovered samples _____

Date recovered samples received Monday July 4-28-00

Analyst _____

Sample Number	Sample Identification Number	Date and Time of Recovery	Liquid Level Marked	Stored in refrigerated Container
1				
2				
3				
4				
5				
6				
Blank				

Remarks _____

Signature of lab sample trustee _____

SAMPLE RECOVERY AND INTEGRITY DATA

Plant Polk Power Station Sample location HRS 6 Unit No. 1

Field Data Checks

Sample recovery personnel Craig V. Corrado
 Person with direct responsibility for recovered samples Craig V. Corrado

Sample Number	Sample Identification Number	Date and Time of Recovery	Liquid Level Marked	Stored in refrigerated Container
1	Run 6 Iso	4-25-2000 ^{cvc 14:33} 14:23	✓	✓
2	Run 7 Iso	" 16:28	✓	✓
3	Run 8 Iso	" 18:22	✓	✓
4	Run 9 Iso	" 20:07	✓	✓
5				
6				
Blank				

Remarks _____

Signature of field sample trustee Craig V. Corrado

Laboratory Data Checks

Lab person with direct responsibility for recovered samples Adrian Alroy

Date recovered samples received 4-26-00 @ 6:15

Analyst Adrian Alroy / Manda Jurgens

AA-54564

Sample Number	Sample Identification Number	Date and Time of Recovery	Liquid Level Marked	Stored in refrigerated Container
1	RUN 6 Iso	✓		✓
2	RUN 7 Iso	✓		✓
3	RUN 8 Iso	✓		✓
4	RUN 9 Iso	✓		✓
5				
6				
Blank				

Remarks _____

Signature of lab sample trustee _____

SAMPLE RECOVERY AND INTEGRITY DATA

Plant Polk Power Station Sample location HRS6 unit No. 1

Field Data Checks

Sample recovery personnel Craig V. Conrad

Person with direct responsibility for recovered samples Craig V. Conrad

Sample Number	Sample Identification Number	Date and Time of Recovery	Liquid Level Marked	Stored in refrigerated Container
1	Run 6 H ₂ O ₂	4-25-2000 14:52	✓	✓
2	Run 7 H ₂ O ₂	" 16:31	✓	✓
3	Run 8 H ₂ O ₂	" 18:27	✓	✓
4	Run 9 H ₂ O ₂	" 20:09	✓	✓
5				
6				
Blank				

Remarks _____

Signature of field sample trustee Craig V. Conrad

Laboratory Data Checks

Lab person with direct responsibility for recovered samples Michael Hays

Date recovered samples received 4-26-00 @ 6:15

Analyst Michael Hays

Sample Number	Sample Identification Number	Date and Time of Recovery	Liquid Level Marked	Stored in refrigerated Container
1	Run 6 H ₂ O ₂	4-26-00 @ 6:15	✓	✓
2	Run 7 H ₂ O ₂	4-26-00 @ 6:15	✓	✓
3	Run 8 H ₂ O ₂	4-26-00 @ 6:15	✓	✓
4	Run 9 H ₂ O ₂	4-26-00 @ 6:15	✓	✓
5				
6				
Blank				

Remarks _____

Signature of lab sample trustee _____

SAMPLE RECOVERY AND INTEGRITY DATA

Plant Polk Power Station Sample location HRSU Unit No. 1

Field Data Checks

Sample recovery personnel Craig V. Coronado

Person with direct responsibility for recovered samples Craig V. Coronado

Sample Number	Sample Identification Number	Date and Time of Recovery	Liquid Level Marked	Stored in refrigerated Container
1	Run 10 ISO	4-26-00 @ 11:29	✓	✓
2	Run 11 ISO	4-26-00 @ 13:15	✓	✓
3				
4				
5				
6				
Blank				

Remarks _____

Signature of field sample trustee Craig V. Coronado

Laboratory Data Checks

Lab person with direct responsibility for recovered samples _____

Date recovered samples received _____

Analyst Monica J. Jorgensen

AA54565

Sample Number	Sample Identification Number	Date and Time of Recovery	Liquid Level Marked	Stored in refrigerated Container
1				
2				
3				
4				
5				
6				
Blank				

Remarks _____

Signature of lab sample trustee _____

SAMPLE RECOVERY AND INTEGRITY DATA

Plant POLK POWER STATION Sample location HRSG UNIT 1

Field Data Checks

Sample recovery personnel CRAIG V. CORONADO

Person with direct responsibility for recovered samples CRAIG CORONADO

Sample Number	Sample Identification Number	Date and Time of Recovery	Liquid Level Marked	Stored in refrigerated Container
1	RUN 10 H ₂ O ₂	4/26/00 @ 1137	✓	✓
2	RUN 11 H ₂ O ₂	4/26/00 @ 1319	✓	✓
3				
4				
5				
6				
Blank				

Remarks _____

Signature of field sample trustee Craig V. Coronado

Laboratory Data Checks

Lab person with direct responsibility for recovered samples [Signature]

Date recovered samples received 4-27-00

Analyst A Gonzalez

Sample Number	Sample Identification Number	Date and Time of Recovery	Liquid Level Marked	Stored in refrigerated Container
1				
2				
3				
4				
5				
6				
Blank				

Remarks _____

Signature of lab sample trustee [Signature]

APPENDIX I

PROJECT PARTICIPANTS

PROJECT PARTICIPANTS

Environmental Affairs

Gregory M. Nelson, P.E.	Director
Patrick Shell	Administrator- Air Programs
David Smith	Coordinator- Air Services
Robert Barthelette Jr.	Environmental Technician
Craig Coronado	Technician
Linda Kong	Engineer Associate
Raymond McDarby	Senior Environmental Technician
Glenn Naslund	Environmental Technician
Bruce Rodriguez	Technician
James Werner	Technician

Polk Power Station

David Knapp	Environmental And Safety Engineer
John McDaniel, P.E.	Senior Engineer
Preston Moore	IGCC Specialist