



TAMPA ELECTRIC

RECEIVED

JAN 22 2014

DIVISION OF AIR
RESOURCE MANAGEMENT

January 21, 2014

Mr. Jeff Koerner
Florida Department of Environmental Protection
Division of Air Resource Management
2600 Blairstone Road
Tallahassee, FL 32399 – 2400

Via FedEx
Airbill No. 7976-8228-3570

Re: Tampa Electric Company
Polk Power Station
Permit No. 1050233 – 036 – AV
PSD Applicability Monitoring Report

Dear Mr. Koerner:

Enclosed please find the PSD applicability monitoring emissions compliance report for Polk Power Station, pursuant to condition 14 in permit 1050233 – 021 – AC. This is the fourth full calendar year (CY 2012) following resumption of regular operations in which construction activities occurred, resulting in an increased capability of utilizing a petcoke blend ratio up to 85%.

As identified in the increase petcoke permit application the baseline or preconstruction annual emissions were:

Baseline Actual Emissions (Unit 001 & Unit 004)

SO ₂ (tpy)	H ₂ SO ₄ Mist (tpy)
1,087.6	104.8

The calendar year 2014 actual emissions were:

2014 Actual Emissions (Unit 001 & Unit 004)

SO ₂ (tpy)	H ₂ SO ₄ Mist (tpy)
1,025.3	106.0

TAMPA ELECTRIC COMPANY
P. O. BOX 111 TAMPA, FL 33601-0111

(813) 228-4111

AN EQUAL OPPORTUNITY COMPANY
HTTP://WWW.TAMPAELECTRIC.COM

CUSTOMER SERVICE:
HILLSBOROUGH COUNTY (813) 223-0800
OUTSIDE HILLSBOROUGH COUNTY 1 (888) 223-0800


1910

Mr. Jeff Koerner
January 21, 2014
Page 2 of 2

There was no increase in emissions as seen by the actual emissions compared to baseline emissions.

Please contact me with any questions at 813-228-2182 or Lyndsey Figler at 813-228-4740.

Sincerely,

A handwritten signature in black ink, appearing to read 'Byron T. Burrows', with a long horizontal flourish extending to the right.

Byron T. Burrows, P.E. BCEE
Manager, Air Programs
Environmental, Health & Safety

EHS/iy/LMB165 Petcoke Annual Monitoring 2013

cc: Mr. Erin DiBacco – FDEP (Email)

Erin.DiBacco@dep.state.fl.us

cc: Ms. Catherine DeFoe – FDEP (Email)

Catherine.defoe@dep.state.fl.us

