

Department of Environmental Protection

Jeb Bush
Governor

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Colleen M. Castille
Secretary

August 3, 2005

CERTIFIED MAIL – Return Receipt Requested

Mr. Theodore D. Kennedy
V.P. – Palatka Mill Operations
Georgia-Pacific Corporation
P.O. Box 919
Palatka, Florida 32178-0919

RE: Request for Additional Information (RAI)
Recovery Boiler #4
1070005-027-AC/PSD-FL-226(A)

Dear Mr. Kennedy:

On April 19, 2004, the Department received a request to modify the Recovery Boiler No. 4's sulfur dioxide (SO₂) emission limits. On May 18, 2004, a request for additional information was sent to you by certified mail. Due to the length of time that has passed since that letter was sent to you with no response received, the Department is asking that the request be withdrawn.

If you have any questions regarding this matter, please call Bruce Mitchell at (850)413-9198.

Sincerely,

Trina L. Vielhauer
Chief
Bureau of Air Regulation

TLV/bm

cc: Chris Kirts, DEP - NED
Myra Carpenter, G-PC

"More Protection, Less Process"

Printed on recycled paper.

| SENDER: COMPLETE THIS SECTION | | COMPLETE THIS SECTION ON DELIVERY | |
|---|--|---|--|
| <ul style="list-style-type: none"> Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired. Print your name and address on the reverse so that we can return the card to you. Attach this card to the back of the mailpiece, or on the front if space permits. | | A. Signature <i>John D. Kennedy</i> | |
| | | <input type="checkbox"/> Agent <input type="checkbox"/> Addressee | |
| | | B. Received by / Printed Name <i>John D. Kennedy</i> | |
| | | C. Date of Delivery <i>8/5/05</i> | |
| 1. Article Addressed to: <div style="border: 1px solid black; padding: 5px;"> Mr. Theodore D. Kennedy Vice President - Palatka Operations Georgia Pacific Palatka Mill Post Office Box 919 Palatka, Florida 32178-0919 </div> | | D. Is delivery address different from item 1? <input type="checkbox"/> Yes If YES, enter delivery address below: <input type="checkbox"/> No | |
| | | 3. Service Type <input checked="" type="checkbox"/> Certified Mail <input type="checkbox"/> Express Mail <input type="checkbox"/> Registered <input type="checkbox"/> Return Receipt for Merchandise <input type="checkbox"/> Insured Mail <input type="checkbox"/> C.O.D. | |
| | | 4. Restricted Delivery? (Extra Fee) <input type="checkbox"/> Yes | |
| 2. Article Number (Transfer from service label) | | <i>7001 0320 0001 3692 2435</i> | |
| PS Form 3811, August 2001 | | Domestic Return Receipt | |
| | | 102595-02-M-1540 | |

| U.S. Postal Service | |
|---|------------------------------|
| CERTIFIED MAIL RECEIPT | |
| (Domestic Mail Only; No Insurance Coverage Provided) | |
| OFFICIAL USE | |
| Postage | \$ |
| Certified Fee | |
| Return Receipt Fee (Endorsement Required) | |
| Restricted Delivery Fee (Endorsement Required) | |
| Postmark Here | |
| Mr. Theodore D. Kennedy Vice President - Palatka Operations Georgia Pacific Palatka Mill Post Office Box 919 Palatka, Florida 32178-0919 | |
| PS Form 3800, January 2001 | See Reverse for Instructions |

7001 0320 0001 3692 2435



File 157

Department of Environmental Protection

Jeb Bush
Governor

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Colleen M. Castille
Secretary

July 1, 2005

CERTIFIED MAIL – Return Receipt Requested

Mr. Theodore D. Kennedy
Vice President – Palatka Operations
Georgia-Pacific
Palatka Mill
P.O. Box 919
Palatka, Florida 32178-0919

RE: Modification to the No. 4 Combination Boiler
Project No.: 1070005-033-AC/PSD-FL-357


Dear Mr. Kennedy:

On June 3, 2005, the Department received a request to modify the No. 4 Combination Boiler. Based on our review of the proposed project, we have determined that the following additional information is needed in order to continue processing this application package. Please provide all assumptions, calculations, and reference material(s), that are used or reflected in any of your responses to the following issues:

1. Please expand Table 3-3, and other tables if necessary, to include the upcoming modification of the No. 4 Recovery Boiler. If this expansion of the table results in projected emission impacts greater than PSD significance for other pollutants in addition to CO, please evaluate appropriately per Rule 62-212.400(5), F.A.C., PSD Preconstruction Review Requirements. This includes evaluating these impacts on the appropriate ambient air quality standards and increments.
2. In addition to issue No. 1, above, please identify any other emissions units/activities that will be affected upstream and down stream by the increase in production and steam output due to the proposed modification of the No. 4 Combination Boiler. Also, please include in the analysis any increases in production and associated pollutant emissions, including any collateral emission changes and increases (NCG's TRS to SO₂, etc.) for these emissions units/activities.
3. If any response to the above issues affect the application submittal, please correct and/or change the application to reflect the additional analyses and submit.

The Department will resume processing this application after receipt of the requested information. If you have any questions regarding this matter, please call Bruce Mitchell at (850)413-9198 or Cleve Holladay at (850)921-8986.

Sincerely,


Jeffrey F. Koerner, P.E.
Permitting North Administrator
Bureau of Air Regulation

JFK/bm

cc: Gregg Worley, U.S. EPA, Region 4
John Bunyak, NPS
David Buff, P.E., GAI
Chris Kirts, NED
Myra J. Carpenter, G-PC

Cleve
Bruce } 7/1/05
Tina

"More Protection, Less Process"

| SENDER: COMPLETE THIS SECTION | COMPLETE THIS SECTION ON DELIVERY |
|---|---|
| <ul style="list-style-type: none"> Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired. Print your name and address on the reverse so that we can return the card to you. Attach this card to the back of the mailpiece, or on the front if space permits. <p>1. Article Addressed to:</p> <p>Mr. Theodore D. Kennedy V.P. - Palatka Operations Georgia-Pacific Corp. P.O. Box 919 Palatka, FL 32178-0919</p> | <p>A. Signature <input type="checkbox"/> Agent <i>John Alexander</i> <input type="checkbox"/> Addressee</p> <p>B. Received by (Printed Name) C. Date of Delivery <i>John Alexander 7/6/05</i></p> <p>D. Is delivery address different from item 1? <input checked="" type="checkbox"/> Yes If YES, enter delivery address below: <input type="checkbox"/> No</p> <p>3. Service Type <input checked="" type="checkbox"/> Certified Mail <input type="checkbox"/> Express Mail <input type="checkbox"/> Registered <input type="checkbox"/> Return Receipt for Merchandise <input type="checkbox"/> Insured Mail <input type="checkbox"/> C.O.D.</p> <p>4. Restricted Delivery? (Extra Fee) <input type="checkbox"/> Yes</p> |
| <p>2. Article Number (Transfer from service label)</p> <p>7000 3870 0000 7038 1853</p> | |

PS Form 3811, February 2004 Domestic Return Receipt 102595-02-M-1540

U.S. Postal Service
CERTIFIED MAIL RECEIPT
 (Domestic Mail Only; No Insurance Coverage Provided)

OFFICIAL USE

7000 3870 0000 7038 1853

| | |
|---|----|
| Postage | \$ |
| Certified Fee | |
| Return Receipt Fee (Endorsement Required) | |
| Restricted Delivery Fee (Endorsement Required) | |

Postmark
Here

Mr. Theodore D. Kennedy
 Vice President - Palatka Operations
 Georgia Pacific
 Palatka Mill
 Post Office Box 919
 Palatka, Florida 32178-0919

a Operations

PS Form 3800, May 2000 See Reverse for Instructions