NOTICE OF FINAL TITLE V PERMIT REVISION

In the Matter of an Application for Permit:

Ms. Roxane Kennedy Plant General Manager FPL Sanford Power Plant 950 South Highway 17-92 Debary, Florida 32713 DEP File No. 1270009-007-AV Sanford Power Plant Volusia County

Enclosed is the FINAL Title V Permit Revision, Number 1270009-007-AV, for the incorporation of the Repowered Unit 5 operation (combined cycle combustion turbines 5A thru 5D, plus associated foggers and unfired heat recovery steam generators) at the existing Sanford Plant located at 950 Highway 17-92, on the St. John's River, approximately 7 miles northwest of Sanford, Volusia County. This permit is issued pursuant to Chapter 403, Florida Statutes (F.S.). No comments were received from the Region 4, U.S. EPA.

Any party to this order (permit) has the right to seek judicial review of the permit pursuant to Section 120.68, F.S., by the filing of a Notice of Appeal pursuant to Rule 9.110, Florida Rules of Appellate Procedure, with the Clerk of the Department in the Legal Office; and, by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The Notice of Appeal must be filed within 30 (thirty) days from the date this Notice is filed with the Clerk of the Department.

Executed in Tallahassee, Florida.

Trina L. Vielhauer

Chief

Bureau of Air Regulation

Mund Vielhauer

CERTIFICATE OF SERVICE

The undersigned duly designated deputy agency clerk hereby certifies that this NOTICE OF FINAL TITLE V PERMIT REVISION (including the FINAL permit) was sent by certified mail (*) and copies were mailed by U.S. Mail before the close of business on the person(s) listed or as otherwise noted:

Ms. Roxane Kennedy, FPL*

Mr. Kennard F. Kosky, P.E., GAI

Ms. Mary Archer, FPL Environmental Services Department (JES/JB)

Peading Jule

Mr. Leonard T. Kozlov, P.E., Central District Office

USEPA, Region 4 (INTERNET E-mail Memorandum)

Clerk Stamp

FILING AND ACKNOWLEDGMENT FILED, on this date, pursuant to \$120.52(7), Florida Statutes, with the designated Department Clerk,

eccipt of which is hereby acknowledged.

Clerk

Date

U.S. Postal Service CERTIFIED MAIL RECEIPT (Domestic Mail Only; No Insurance Coverage Provided)

	(Bomestie man			COVER	196 77				
. 									
, ברנו הנו	Ms. Roxane	Kenn	edy 🗛	g-im M		5	C.		,
40	Postage	\$							
507	Certified Fee								
Г- П л	Return Receipt Fee				Postm Hen				
	Endorsement Required) Restricted Delivery Fee								
. — :	Endorsement Required) Total Postage & Fees	\$		-					
₹_	Sent To			<u> </u>				,	
ū	Ms. Roxane	Kenn	edy						
S	treet, Apt. No.; or PO I 950 South H	Box No. ighwa	y 17-92	2					,
	ity, State, ZIP+ 4 Debary, Flor	rida	32713						
PS	S Form 3800, May 20	300		See Rever	se for l	nstruc	tions	3	
ENDER: COMPLETE TH	IIS SEČTION		COMPLET	É THIS SE	CTION	ON D	ELIVEF	?Y	
Complete items 1, 2, and item 4 if Restricted Deliving Print your name and add so that we can return the Attach this card to the barron the front if space p	ery is desired. Iress on the reverse card to you. ack of the mailpied	e .	A. Signatur X A B. Receive	le J d by Prin	ted Nan	23>	U	Agent Address Date of Delv	see
. Article Addressed to:			D. Is deliver	ry address enter delive				V □ Ye ≴ □ No	
Ms. Roxane Kenn Plant General Ma FPL Sanford Power P.	anager lant								
950 South Highw		-	3. Service			-			
Debary, Florida	32713		XXX Certif	stered	☐ Exp ☐ Ret ☐ C.C	turn Re		or Merchandi	ise
			4. Restricte	ed Delivery	? (Extra	Fee)		☐ Yes	
Article Number	11 17000 3574	പ്രവ്വ	0 16061	ا، ا اداء	i III	1 1	11		
1 11 11 *1	11 17000 2870	000	0 /0/28!	11/4	1 111	'	<u>-</u>		

10/30/03

Dear Yi,

I have the ARMS data entry dated 8/19/03 for the incorporation of the Repowered Unit 5 action. However, I cannot find the e-mail message to you for the data check, nor do I have your message to me that the data is OK!? If I did not send a message to you for the data check, please accept this e-mail to you for it. Many thanks.

Bruce

INTEROFFICE MEMORANDUM

Sensitivity: COMPANY CONFIDENTIAL Date: 14-Sep-1999 02:03pm

From: Yi Zhu TAL

ZHU_Y

Dept: Air Resources Management

Tel No: 850/921-9558

To: Bruce Mitchell TAL (MITCHELL B)

Subject: Re: SANFORD PLANT

This is done too. Thanks.

*The inventory data update in ARMS is complete. However, no EUs are linked to *the TV permit. Please link the appropriate EUs and have Bruce updating the *ARMS Data Entry event. Thank you.

*Yi

*

**Yi:

**I've "cleaned up" Sanford (1270009)(all but the 'regulation type' messages).

**Please upload to ARMS when you fix these. Many thanks.

**

* * Tom

FPL's Sandord Power Plant 1270009-007-AU 1270009-008-AC

8/19/03

Dear Yi,

Please check the data for ARMS entry for the above referenced utility and projects. Many thanks.

Bruce

Mitchell, Bruce

From: Friday, Barbara

Sent: Monday, June 16, 2003 2:55 PM

To: Walker, Elizabeth (AIR); Gracy Danois; Joel Huey; Kathleen Forney

Cc: Mitchell, Bruce

Subject: New Posting #1270009

There is a new posting on Florida's website.

1270009007AV

FP&L - SANFORD POWER PLANT

Final Permit Revision

If you have any questions, feel free to contact me.

Thanks, Barbara Dear Barbara,

Please post the above referenced project located at: o:Bar/Title V/Bruce/Permits/1270009.007.AV.FPL.Sanford.Revision:

1270009f.007AV 1270009.007.AV.FD 1270009.007AV.AppH 1270009.007AV.Appl 1270009.007AV.AppU

1270009.007AV.SOB

Many thanks!

Bruce

INTEROFFICE MEMORANDUM

TO: Howard Rhodes

THRU: Scott M. Sheplak

Trina L. Vielhauer

FROM: Bruce Mitchell

DATE: June 5, 2003

SUBJECT: FPL

Sanford Power Plant

FINAL Title V Air Operation Permit Revision

Permit Project No.: 1270009-007-AV

Attached is the FINAL Title V Air Operation Permit Revision, Project No. 1270009-007-AV, for the Sanford Power Plant located at 950 Highway 17-92, on the St. John's River, approximately 7 miles northwest of Sanford, Volusia County. The subject of the Permit Revision is to incorporate the terms and conditions of air construction permits, Nos. 1270009-004-AC/PSD-FL-270 and 1270009-008-AC/PSD-FL-270(A), for four (4) newly constructed combined cycle combustion turbines with unfired heat recovery steam generators (Repowered Unit 5). The emissions units have been built and the initial performance tests have been conducted and compliance demonstrated on natural gas only. A Compliance Plan has been created to address the firing of fuel oil.

There were no comments received from the Region 4, U.S. EPA, during the 45-Day comment period. Day 55 was June 4, 2003, upon which the permit went final. Therefore, it is recommended to issue the FINAL Title V Air Operation Permit Revision.

Attachments

HLR/tlv/bm

Interoffice Memorandum

TO: File No. 1270009-007-AV

FROM: Bruce Mitchell

THRU: Scott Sheplak

DATE: March 27, 2003

SUBJ: Rule 62-297.310(8), F.A.C. Omission from Section III. Subsection B.

I spoke with Mary Archer with FPL and told her of the omission of the above referenced rule from the DRAFT permit. She acknowledged the point.

FINAL Determination

FPL Sanford Power Plant

Facility ID No.: 1270009 Volusia County

Title V Air Operation Permit Revision FINAL Permit No.: 1270009-007-AV

I. Comment(s).

No comments were received from the USEPA during their 45 day review period of the PROPOSED Permit.

II. Conclusion.

In conclusion, the permitting authority hereby issues the FINAL Permit.

STATEMENT OF BASIS

Title V Air Operation Permit Revision
FINAL Permit Project No.: 1270009-007-AV
FPL
Sanford Power Plant
Volusia County

The initial Title V Air Operation Permit was effective on January 1, 2000. This Title V Air Operation Permit Revision is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, 62-213, and 62-214. The above named permittee is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans, and other documents, attached hereto or on file with the permitting authority, in accordance with the terms and conditions of this permit.

The subject of this permit revision is to incorporate the terms and conditions of air construction permits, Nos. 1270009-004-AC/PSD-FL-270 and 1270009-008-AC/PSD-FL-270(A), for four (4) newly constructed combined cycle combustion turbines with unfired heat recovery steam generators (Repowered Unit 5). The emissions units have been built and the initial performance tests have been conducted and compliance demonstrated on natural gas only. A Compliance Plan has been created to address the firing of fuel oil. In addition, references to previously designated Units 4 and 5, which were residual fuel oil-fired and natural gas-fired steam boiler generating units, have been deleted from Section III. Subsection A.'s text.

Repowered Unit 5, which is made up of 4 (four: PSNCT5A thru PSNCT5D) combined cycle only combustion turbines, replaces the existing residual oil-fired and gas-fired steam generating boiler Unit 5, while the existing steam-driven electrical turbine-generator will remain. Each combined cycle turbine unit is a nominal 170 MW (@59°F - compressor inlet) General Electric Frame MS7241FA Advanced natural gas-fired and distillate oil-fired combustion turbinegenerator, with associated inlet foggers and an unfired Heat Recovery Steam Generator (HRSG) that will capture sufficient waste heat to produce another 80 MW via the existing steam-driven electrical turbine-generator (therefore, 250 MW in combined cycle operation). Each combustion turbine is permitted to fire natural gas (which has already been tested for) and distillate fuel oil (which has not been tested for: see Appendix CP-1, Compliance Plan for Repowered Unit 5). Water injection is installed in each turbine for Repowered Unit 5 to control NO_x, when firing distillate oil. Dry Low-NO_x combustors are installed in each turbine for Repowered Unit 5 to control NO_X, when firing natural gas. An evaporative equipment cooler was built instead of the proposed mechanical draft-cooling tower. Unit PSNCT5A commenced operation on February 21, 2002; Unit PSNCT5B commenced operation on February 25, 2002; PSNCT5C commenced operation on March 4, 2002; and, PSNCT5D commenced operation on March 11, 2002.

For Repowered Unit 5, the existing tall boiler (Unit 5) stack will be dismantled and replaced with relatively short stacks per emissions unit for the combined cycle operation. Electrical fuel heaters will be used instead of the natural gas heaters to heat the natural gas prior to use during cold startups.

These emissions units are regulated under: Acid Rain, Phase II; NSPS - 40 CFR 60, Subpart GG, Standards of Performance for Stationary Gas Turbines, adopted and incorporated by reference in Rule 62-204.800(7)(b), F.A.C.; Rule 62-212.400(5), F.A.C., Prevention of Significant

Statement of Basis (cont.)
FPL's Sanford Power Plant
Title V Air Operation Permit Revision
FINAL Permit No.: 1270009-007-AV
Page 2 of 2

Deterioration (PSD); and, Rule 62-212.400(6), F.A.C., Best Available Control Technology (BACT) Determination, dated September 14, 1999.

Also included in this permit are miscellaneous unregulated/insignificant emissions units and/or activities.

For the Repowered Unit 5, Compliance Assurance Monitoring (CAM) does not apply. The NO_X CEMS is used to determine compliance with the emission limiting standards. Natural gas is the primary fuel and, when there is a natural gas curtailment, fuel oil having a maximum sulfur content of 0.05%, by weight, may be burned for a limited time based on fuel oil consumption (28,600,000 gallons per year of distillate fuel oil).

Based on the initial Title V permit application received June 12, 1996, this facility is a major source of hazardous air pollutants (HAPs).

FPL Sanford Power Plant Facility ID No.: 1270009 Volusia County

Title V Air Operation Permit Revision FINAL Permit No.: 1270009-007-AV

Permitting Authority:
State of Florida
Department of Environmental Protection
Division of Air Resources Management
Bureau of Air Regulation
Title V Section
Mail Station #5505
2600 Blair Stone Road
Tallahassee, Florida 32399-2400
Telephone: 850/488-0114

Fax: 850/922-6979

Compliance Authority:
State of Florida
Department of Environmental Protection
Central District Office
3319 Maguire Boulevard, Suite 232
Orlando, Florida 32803-3767
Telephone: 407/894-7555

Fax: 407/897-2966

Title V Air Operation Permit Revision FINAL Permit No.: 1270009-007-AV

Table of Contents

Section P	<u>age Number(s)</u>
Placard Page	1
Facility Information A. Facility Description. B. Summary of Emissions Unit ID No(s). and Brief Description(s) C. Relevant Documents.	
II. Facility-wide Conditions	4 - 7
III. Emissions Unit(s) and Conditions	
A. Emissions Unit 001: Fossil Fuel Steam Generator Unit 3	8 - 19
B. Emissions Units 009 thru 012: Repowered Unit 5	20 - 36
IV. Acid Rain Part	27 20
A. Acid Rain, Phase II	37 - 38



Department of Environmental Protection

Jeb Bush Governor Twin Towers Office Building 2600 Blair Stone Road Tallahassee, Florida 32399-2400

David B. Struhs Secretary

Permittee:

FPL Sanford Power Plant 950 South Highway 17-92 Debary, Florida 32713 FINAL Permit No.: 1270009-007-AV

Facility ID No.: 1270009

SIC No.: 4911

Project: Title V Air Operation Permit Revision

for the Repowered Unit 5

This permit revision is for the incorporation of the Repowered Unit 5 operation (combined cycle combustion turbines 5A thru 5D, plus associated foggers and unfired heat recovery steam generators) at the existing Sanford Plant. This facility is located at 950 Highway 17-92, which is on the St. Johns River, approximately 7 miles northwest of Sanford, Volusia County. The UTM Coordinates are: Zone 17, 468.3 km East and 3190.3 km North; Latitude: 28° 50' 31" North and Longitude: 81° 19' 32" West.

This Title V Air Operation Permit Revision is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-204, 62-210, 62-213, 62-214, 62-296 and 62-297. The above named permittee is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans, and other documents, attached hereto or on file with the permitting authority, in accordance with the terms and conditions of this permit.

Referenced attachments made a part of this permit:

HP Drum Temperature and Pressure During Cold Startup Curves

Appendix U-1, List of Unregulated Emissions Units and/or Activities
Appendix I-1, List of Insignificant Emissions Units and/or Activities
Appendix TV-4, Title V Conditions (version dated 02/12/02)
Appendix SS-1, Stack Sampling Facilities (version dated 10/07/96)
Table 297.310-1, Calibration Schedule (version dated 10/07/96)
Phase II Acid Rain Application/Compliance Plan signed 01/30/02 and received 08/21/02
Alternate Sampling Procedure: ASP Number 97-B-01
Orders for Alternate Opacity Standards: OGC Case Nos: 92-0890 (Unit 3)
Appendix CP-1, Compliance Plan for Repowered Unit 5

Effective Date: January 1, 2000 Revision Effective Date: June 4, 2003

Renewal Application Due Date: July 5, 2004

Expiration Date: December 31, 2004

Howard L(Rhodes, Director

Division of Air Resource Management

HLR/rbm

"More Protection, Less Process"

Sanford Power Plant

Section I. Facility Information.

Subsection A. Facility Description.

This facility contains: Unit 3, which is an existing Babcock & Wilcox wall-fired steam boiler generating unit that is permitted to fire natural gas, No. 6 fuel oil, No. 2 fuel oil, and used oil from FPL operations, and has a generator nameplate rating of 156 megawatts (MW); and, Repowered Unit 5, which is made up of 4 (four: PSNCT5A thru PSNCT5D) combined cycle only combustion turbines, replaces the existing residual oil-fired and gas-fired steam generating boiler Unit 5, while the existing steam turbine will remain. Each combined cycle unit is a 170 MW (@59°F - compressor inlet) General Electric Frame MS7241FA Advanced natural gas-fired and distillate oil-fired combustion turbine-generator, with associated inlet foggers and an unfired Heat Recovery Steam Generator (HRSG) that will capture sufficient waste heat to produce another 80 MW via the steam-driven electrical generators. Each combustion turbine is permitted to fire natural gas (has already been tested for) and distillate fuel oil (has not been tested for: see Appendix CP-1, Compliance Plan for Repowered Unit 5). Water injection is installed in each turbine for Repowered Unit 5 to control NO_x, when firing distillate oil. Dry Low-NO_x combustors are installed in each turbine for Repowered Unit 5 to control NO_x, when firing natural gas. An evaporative equipment cooler was built instead of the proposed mechanical draft-cooling tower. Unit PSNCT5A commenced operation on February 21, 2002; Unit PSNCT5B commenced operation on February 25, 2002; PSNCT5C commenced operation on March 4, 2002; and, PSNCT5D commenced operation on March 11, 2002.

Air pollutants are discharged through a 302 foot stack on Unit 3. For Repowered Unit 5, the existing tall boiler (Unit 5) stack will be dismantled and replaced with relatively short stacks per emissions unit for combined cycle operation.

There is an emergency diesel generator and 4 pre-NSPS fuel oil storage tanks ranging in size from 275 gallons to 268,000 barrels. Also, there are two propane tanks on site.

Also included in this permit are miscellaneous unregulated/insignificant emissions units and/or activities.

Compliance Assurance Monitoring Requirements do not apply.

Based on the initial Title V permit application received June 12, 1996, this facility is a major source of hazardous air pollutants (HAPs).

Subsection B. Summary of Emissions Unit ID No(s). and Brief Description(s).

E.U. ID No.	Brief Description .					
001	Fossil Fuel Steam Generator: Unit 3					
Repowered U	Repowered Unit 5					
009	Combined Cycle Combustion Turbine (CCCT) Generator 5A with an unfired					
	Heat Recovery Steam Generator (HRSG)					
010	CCCT 5B with an unfired HRSG					
011	CCCT 5C with an unfired HRSG					
012	CCCT_5D with an unfired HRSG					

Unregulated Emissions Units and/or Activities							
004	Emergency diesel generators, fuel oil storage tanks, and miscellaneous activities						

Requests to the Department should reference the Permit No., Facility ID No., and appropriate Emissions Unit(s) ID No(s). on all correspondence, test report submittals, applications, etc.

Subsection C. Relevant Documents.

The documents listed below are not a part of this permit; however, they are specifically related to this permitting action.

These documents are provided to the permittee for information purposes only:
Appendix A-1, Abbreviations, Acronyms, Citations, and Identification Numbers
Appendix H-1, Permit History
Table 1-1, Summary of Air Pollutant Standards and Terms
Table 2-1, Summary of Compliance Requirements
Statement of Basis

These documents are on file with the permitting authority:
Initial Title V Permit Application received June 12, 1996.
Application for Revision received August 21, 2002.
Incompleteness Letter sent October 20, 2002.
Response to Incompleteness Letter received October 31, 2002.
Supplemental Information received January 15, 2003.
INTEROFFICE MEMORANDUM dated March 27, 2003, from Bruce Mitchell.

Sanford Power Plant

Section II. Facility-wide Conditions.

The following conditions apply facility-wide:

- 1. APPENDIX TV-4, TITLE V CONDITIONS is a part of this permit. {Permitting Note: APPENDIX TV-4, TITLE V CONDITIONS, is distributed to the permittee only. Other persons requesting copies of these conditions shall be provided a copy when requested or otherwise appropriate.}
- 2. Not Federally Enforceable. General Pollutant Emission Limiting Standards. Objectionable Odor Prohibited. The permittee shall not cause, suffer, allow, or permit the discharge of air pollutants which cause or contribute to an objectionable odor. [Rule 62-296.320(2), F.A.C.]
- 3. General Particulate Emission Limiting Standards. General Visible Emissions Standard. Except for emissions units that are subject to a particulate matter or opacity limit set forth or established by rule and reflected by conditions in this permit, no person shall cause, let, permit, suffer or allow to be discharged into the atmosphere the emissions of air pollutants from any activity, the density of which is equal to or greater than that designated as Number 1 on the Ringelmann Chart (20 percent opacity). EPA Method 9 is the method of compliance pursuant to Chapter 62-297, F.A.C. [Rules 62-296.320(4)(b)1. & 4, F.A.C.]
- 4. Prevention of Accidental Releases (Section 112(r) of CAA).
- a. The permittee shall submit its Risk Management Plan (RMP) to the Chemical Emergency Preparedness and Prevention Office (CEPPO) RMP Reporting Center when, and if, such requirement becomes applicable. Any Risk Management Plans, original submittals, revisions or updates to submittals, should be sent to:

RMP Reporting Center Post Office Box 3346 Merrifield, VA 22116-3346 Telephone: 703/816-4434

and.

- **b.** The permittee shall submit to the permitting authority Title V certification forms or a compliance schedule in accordance with Rule 62-213.440(2), F.A.C. [40 CFR 68]
- 5. <u>Unregulated Emissions Units and/or Activities.</u> Appendix U-1, List of Unregulated Emissions Units and/or Activities, is a part of this permit. [Rule 62-213.440(1), F.A.C.]
- 6. <u>Insignificant Emissions Units and/or Activities.</u> Appendix I-1, List of Insignificant Emissions Units and/or Activities, is a part of this permit. [Rules 62-4.040(1)(b), 62-213.430(6) and 62-213.440(1), F.A.C.]

FPL Sanford Power Plant

7. General Pollutant Emission Limiting Standards. Volatile Organic Compounds (VOC) Emissions or Organic Solvents (OS) Emissions. The permittee shall allow no person to store, pump, handle, process, load, unload or use in any process or installation, volatile organic compounds (VOC) or organic solvents (OS) without applying known and existing vapor emission control devices or systems deemed necessary and ordered by the Department. The owner or operator shall:

- a. Tightly cover or close all VOC or OS containers when they are not in use.
- b. Tightly cover all open tanks which contain VOC or OS when they are not in use.
- c. Maintain all pipes, valves, fittings, etc., which handle VOC or OS in good operating condition.
- d. Immediately confine and clean up VOC or OS spills and make sure wastes are placed in closed containers for reuse, recycling or proper disposal. [Rule 62-296.320(1)(a), F.A.C.]
- 8. No person shall cause, let, permit, suffer or allow the emissions of unconfined particulate matter from any activity without taking reasonable precautions to prevent such emissions. Reasonable precautions to prevent emissions of unconfined particulate matter at this facility shall include:
 - a. Paving of roads, parking areas and equipment yards;
 - b. Landscaping and planting of vegetation;
 - c. Using dust suppressing techniques such as covering and/or application of water or chemicals to the affected areas, as necessary;

The following requirements are "not federally enforceable":

- d. Use of hoods, and/or fans and filters and/or poly flaps to contain and capture sand in the sandblast facility. The facility shall construct temporary sandblasting enclosures when necessary, in order to perform sandblasting on fixed plant equipment;
- e. Limiting access to plant property by unnecessary vehicles;
- f. Bagged chemical products are stored in weather tight buildings until they are used;
- g. Spills of powdered chemical products shall be cleaned up as soon as practicable; and,
- h. Vehicles are restricted to slow speeds on the plant site.

[Rule 62-296.320(4)(c)2., F.A.C.; 1270009-001-AV; and, 1270009-004-AC/PSD-FL-270]

{Permitting Note: The condition implements the requirements of Rules 62-296.320(4)(c)1., 3. & 4., F.A.C. (see Condition 57. of APPENDIX TV-4, TITLE V CONDITIONS.)}

- 9. When appropriate, any recording, monitoring, or reporting requirements that are time-specific shall be in accordance with the effective date of the permit, which defines day one. [Rule 62-213.440, F.A.C.]
- 10. Statement of Compliance. The annual statement of compliance pursuant to Rule 62-213.440(3)(a)2., F.A.C., shall be submitted to the Department and EPA within 60 (sixty) days after the end of the calendar year using DEP Form No. 62-213.900(7), F.A.C. [Rules 62-213.440(3) and 62-213.900, F.A.C.]

{Permitting Note: This condition implements the requirements of Rules 62-213.440(3)(a)2. & 3., F.A.C. (see Condition 51. of APPENDIX TV-4, TITLE V CONDITIONS.)}

Sanford Power Plant

11. The permittee shall submit all compliance related notifications and reports required in this permit to the Department's Central District office:

Department of Environmental Protection Central District Office 3319 Maguire Boulevard, Suite 232 Orlando, Florida 32803-3767 Telephone: 407/894-7555

Fax: 407/897-2966

12. Any reports, data, notifications, certifications, and requests required to be sent to the United States Environmental Protection Agency, Region 4, should be sent to:

United States Environmental Protection Agency

Region 4

Air, Pesticides & Toxics Management Division
Air & EPCRA Enforcement Branch, Air Enforcement Section
61 Forsyth Street

Atlanta, Georgia 30303-8960 Telephone: 404/562-9155 Fax: 404/562-9163 or 404/562-9164

13. Certification by Responsible Official (RO). In addition to the professional engineering certification required for applications by Rule 62-4.050(3), F.A.C., any application form, report, compliance statement, compliance plan and compliance schedule submitted pursuant to Chapter 62-213, F.A.C., shall contain a certification signed by a responsible official that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete. Any responsible official who fails to submit any required information or who has submitted incorrect information shall, upon becoming aware of such failure or incorrect submittal, promptly submit such supplementary information or correct information.

[Rule 62-213.420(4), F.A.C.]

- 14. Facility-wide Emission Caps. The entire facility including Repowered Units 4 and 5 and existing Unit 3, shall be limited to emission caps of 500 TPY of particulate matter (PM/PM₁₀), 4,500 TPY of nitrogen oxides (NO_X), and 4,000 TPY of sulfur dioxide (SO₂). This limitation shall not become effective until 2003, following the initial startup testing and placing into commercial operation of Repowered Units 4 and 5.
- a. For the purpose of complying with the facility-wide emission cap, particulate matter emissions shall be calculated as follows:

Facility-wide Particulate Matter Emissions (PM_{Total}) = Unit 3 PM emissions (PM_3) + Unit 4 PM emissions (PM_4) + Unit 5 PM emissions (PM_5) where:

 PM_4 = annual heat input (MMBtu) x 0.006 lb/MMBtu

 $PM_5 = PM_{5gas} + PM_{5oil}$

PM_{5gas} = annual gas operation heat input (MMBtu) x 0.006 lb/MMBtu

PM_{5oil} = annual oil operation heat input (MMBtu) x 0.01 lb/MMBtu

 $PM_3 = PM_{3oil} + PM_{3gas}$

 PM_{3oil} = Annual oil heat input (MMBtu) x normalized annual stack test results (Fp), where $Fp = [(\text{steady state PM test result x 16 hours}) + (\text{soot blowing PM test result x 8 hours})]/24 hrs <math>PM_{3gas}$ = Annual gas operation heat input x 0.0076 lb/MMBtu

b. For the purpose of complying with the facility-wide emission cap, nitrogen oxide emissions shall be calculated by annually summing the data collected in the continuous emissions monitoring system required by Title IV of the Clean Air Act.

c. For the purpose of complying with the facility-wide emission cap, sulfur dioxide emissions shall be calculated by annually summing the data collected in the continuous emissions monitoring system required by Title IV of the Clean Air Act.

[1270009-008-AC/PSD-FL-270(A)]

FPL Sanford Power Plant

Section III. Emissions Unit(s) and Conditions.

Subsection A. This section addresses the following emissions unit.

	E.U. ID No.	Brief Description	
ſ	001	Fossil Fuel Steam Generator, Unit 3	

Unit 3 is an existing fossil fuel steam generator, which produces electricity. The emissions unit is permitted to fire natural gas, No. 6 fuel oil [low sulfur fuel oil (LSFO) containing no more than 2.5% sulfur content, by weight, and high sulfur fuel oil (HSFO) containing more than 2.5% sulfur content, by weight, which may only be fired in conjunction with natural gas], No. 2 fuel oil, and on-specification used oil from FPL operations. Propane is utilized primarily for ignition of the main fuel at startup. Heat input capacity for Unit 3 is 1762 MMBtu/hr, when firing natural gas, and 1650 MMBtu/hr, when firing fuel oil.

Air pollutants are discharged through a 302 foot stack. Unit 3 has flue gas recirculation to improve unit performance and efficiency. The boiler operates a Westinghouse tandem compound, reheat type extraction turbine. The boiler has an automated fuel additive system to aid in the removal of boiler tube deposits, in which small quantities of additives are injected periodically, such as magnesium oxide, magnesium hydroxide and related compounds, into each boiler to prevent soot from sticking to the boiler tubes. Fossil fuel fired steam generator Unit 3 began commercial operation in 1959.

{Permitting Note(s): This emissions unit is regulated under Acid Rain, Phase II; and Rule 62-296.405, F.A.C., Fossil Fuel Steam Generators with More than 250 million Btu per Hour Heat Input. Fossil fuel fired steam generator Unit 3 began commercial operation in 1959. This emissions unit uses a system to inject small quantities of additives periodically such as magnesium oxide, magnesium hydroxide and related compounds to prevent soot from sticking to the boiler tubes.}

The following specific conditions apply to the emissions unit listed above:

Essential Potential to Emit (PTE) Parameters

A.1. Permitted Capacity. The maximum operation heat input rates are as follows:

E.U. ID No. MMBtu/hr Heat Input		Fuel Types		
. 001	1762/1650	Natural Gas/Fuel Oils		

[Rules 62-4.160(2), 62-210.200(PTE) and 62-296.405, F.A.C.; 40 CFR 75; and, AO64-217877]

{Permitting Note: The heat input limitations have been placed in each permit to identify the capacity of each unit for the purposes of confirming that emissions testing is conducted within 90 to 100 percent of the unit's rated capacity (or to limit future operation to 110 percent of the test load), to establish appropriate emission limits and to aid in determining future rule applicability. Regular recordkeeping is not required for heat input. Instead the owner or operator is expected to determine heat input whenever emission testing is required, to demonstrate at what percentage of the rated capacity that the unit was tested. Rule 62-297.310(5), F.A.C., included in the permit, requires measurement of the process variables for emission tests. Such heat input determination may be based on measurements of fuel consumption by various methods including but not limited to fuel flow metering or tank drop measurements, using the heat value of the fuel

Sanford Power Plant

determined by the fuel vendor or the owner or operator, to calculate average hourly heat input during the test.}

A.2. Emissions Unit Operating Rate Limitation After Testing. See Specific Condition **A.26**. [Rule 62-297.310(2), F.A.C.]

A.3. Methods of Operation. Fuels.

- a. <u>Startup</u>: The only fuels allowed to be burned in the startup process are propane, natural gas, or No. 2 fuel oil for the ignition cycle, followed by any combination of natural gas, No. 2 fuel oil, or No. 6 fuel oil. During the startup process, best operating practices are utilized to minimize emissions.
- b. <u>Normal</u>: The only fuels allowed to be burned are natural gas, No. 2 fuel oil, No. 6 residual fuel oil, or on-specification used oil from FPL's operations. [Rules 62-213.410(1) and 62-297.310, F.A.C.; and, AO64-217877]
- **A.4.** Hours of Operation. The emissions unit may operate continuously, i.e., 8,760 hours/year. [Rule 62-210.200(PTE), F.A.C.]

Emission Limitations and Standards

{Permitting Note: The attached Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

{Permitting Note: Unless otherwise specified, the averaging time for Specific Conditions A.5. through A.9. are based on the specified averaging time of the applicable test method.}

- **A.5.** <u>Visible Emissions (VE)</u>. Visible emissions shall not exceed 40 percent opacity. Emissions units governed by this visible emissions standard shall conduct compliance tests for particulate matter emissions at least annually, in accordance with Specific Condition **A.27**. [Rule 62-296.405(1)(a), F.A.C.; and, OGC Case No. 92-0890]
- **A.6.** Visible Emissions Soot Blowing and Load Change. Visible emissions shall not exceed 60 percent opacity during the 3-hours in any 24 hour period of excess emissions allowed for boiler cleaning (soot blowing) and load change providing (1) best operational practices to minimize emissions are adhered to and (2) the duration of excess emissions shall be minimized.
- (a) A load change occurs when the operational capacity of a unit is in the 10 percent to 100 percent capacity range, other than startup or shutdown, which exceeds 10 percent of the unit's rated capacity and which occurs at a rate of 0.5 percent per minute or more.
- (b) Visible emissions above 60 percent opacity shall be allowed for not more than 4, six (6)-minute periods, during the 3-hour period of excess emissions allowed by this condition provided that continuous opacity monitors are used to report excess emissions.
- (c) The permittee shall record the date, the start time and the end times of all soot blowing and load change periods which correspond to periods of emissions which are above the steady state opacity limit. This data shall be kept on file for 5 years at the Sanford plant and made available to DEP personnel upon request.

[Rules 62-4.070(3), 210.700(3) and 62-213.440, F.A.C.]

A.7. Particulate Matter. Steady state particulate matter emissions shall not exceed 0.1 pound per million Btu heat input, as measured by applicable compliance methods. [Rule 62-296.405(1)(b), F.A.C.]

A.8. Particulate Matter - Soot Blowing and Load Change. Particulate matter emissions shall not exceed an average of 0.3 pound per million Btu heat input during the 3-hours in any 24-hour period of excess emissions allowed for boiler cleaning (soot blowing) and load change as measured by applicable compliance methods.

[Rule 62-210.700(3), F.A.C.]

A.9. <u>Sulfur Dioxide</u>. Sulfur dioxide emissions shall not exceed 2.75 pounds per million Btu heat input, as measured by applicable compliance methods. [Rule 62-296.405(1)(c)1.j, F.A.C.]

Excess Emissions

- **A.10.** Excess emissions resulting from startup, shutdown or malfunction of any emissions unit shall be permitted provided (1) best operational practices to minimize emissions are adhered to and (2) the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration. [Rule 62-210.700(1), F.A.C.]
- **A.11.** Excess emissions from existing fossil fuel steam generators resulting from startup or shutdown shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized. [Rule 62-210.700(2), F.A.C.]
- **A.12.** Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown, or malfunction shall be prohibited. [Rule 62-210.700(4), F.A.C.]

Monitoring of Operations

A.13. CEMS/COMS Required. The owner or operator shall install, certify, and operate a continuous emission monitoring system (CEMS) for SO₂ and NO_X, and a continuous opacity monitoring system (COMS) for opacity in accordance with 40 CFR 75. Data shall be calculated and recorded in units of the applicable standard.

The CEMS and COMS shall be installed, calibrated, operated and maintained in accordance with the quality assurance requirements of 40 CFR 75, Appendix A, adopted and incorporated by reference in Rule 62-204.800, F.A.C.; however, Relative Accuracy Test Audits (RATA) shall be conducted no less frequently than annually. Compliance shall be based on a 3-hour rolling average.

[Rules 62-204.800 and 62-210.700, F.A.C.; and, 40 CFR 75]

A.14. Annual Tests Required. Except as provided in Specific Conditions **A.17.** through **A.19.**, emissions testing for particulate emissions and visible emissions shall be performed annually during the fiscal year (October 1 - September 30).

[Rules 62-4.070(3), 62-213.440(1), 62-296.405(1)(a) and 62-297.310(7), F.A.C.]

FPL Sanford Power Plant

A.15. Sulfur Dioxide. The owner or operator shall demonstrate compliance with the sulfur dioxide limit of Specific Condition **A.9.** by the following:

- a. Through the use of a continuous emission monitoring system (CEMS) installed, calibrated, operated and maintained in accordance with the quality assurance requirements of 40 CFR 75, Appendix A, adopted and incorporated by reference in Rule 62-204.800, F.A.C.; however, Relative Accuracy Test Audits (RATA) shall be conducted no less frequently than annually. Compliance shall be based on a 3-hour rolling average.
- b. In the event the CEMS becomes temporarily inoperable or interrupted, the fuel oil sulfur concentration and the maximum fuel oil to natural gas firing ratio that shall be used is limited to that which was last used to demonstrate compliance prior to the loss of the CEMS, or the emissions units shall fuel switch and be fired with a fuel containing a maximum sulfur content of 2.5%, by weight, or less. See Specific Condition **A.24**.

[Rules 62-213.440(1), 62-204.800 and 62-296.405(1)(c)3., F.A.C.]

A.16. Determination of Process Variables.

- (a) Required Equipment. The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.
- (b) Accuracy of Equipment. Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value.

[Rule 62-297.310(5), F.A.C.]

- **A.17.** Frequency of Compliance Tests. The following provisions apply only to those emissions units that are subject to an emissions limiting standard for which compliance testing is required.
- (a) General Compliance Testing.
 - 1. For excess emission limitations for particulate matter specified in Rule 62-210.700, F.A.C., a compliance test shall be conducted annually while the emissions unit is operating under soot blowing conditions in each federal fiscal year during which soot blowing is part of normal emissions unit operation, except that such test shall not be required in any federal fiscal year in which a fossil fuel steam generator does not burn liquid fuel for more than 400 hours other than during startup.
 - 2. The owner or operator of an emissions unit that is subject to any emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining a renewed operation permit. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy the requirements of this provision. In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of emission compliance test results for any emissions unit that, during the year prior to renewal:
 - a. Did not operate; or,
 - b. In the case of a fuel burning emissions unit, burned liquid fuel for a total of no more than 400 hours.
 - 3. During each federal fiscal year (October 1 September 30), unless otherwise specified by rule, order, or permit, the owner or operator of each emissions unit shall have a formal compliance test conducted for:
 - a. Visible emissions, if there is an applicable standard;

- b. Each of the following pollutants, if there is an applicable standard, and if the emissions unit emits or has the potential to emit: 5 tons per year or more of lead or lead compounds measured as elemental lead; or 100 tons per year or more of any other regulated air pollutant; and
- c. Each NESHAP pollutant, if there is an applicable emission standard.
- 4. An annual compliance test for particulate matter emissions shall not be required for any fuel burning emissions unit that, in a federal fiscal year, does not burn liquid fuel for a total of more than 400 hours.
- 5. The owner or operator shall notify the Department, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator.
- (b) <u>Special Compliance Tests</u>. When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it may require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department.
- (c) Waiver of Compliance Test Requirements. If the owner or operator of an emissions unit that is subject to a compliance test requirement demonstrates to the Department, pursuant to the procedure established in Rule 62-297.620, F.A.C., that the compliance of the emissions unit with an applicable weight emission limiting standard can be adequately determined by means other than the designated test procedure, such as specifying a surrogate standard of no visible emissions for particulate matter sources equipped with a bag house or specifying a fuel analysis for sulfur dioxide emissions, the Department shall waive the compliance test requirements for such emissions units and order that the alternate means of determining compliance be used, provided, however, the provisions of Rule 62-297.310(7)(b), F.A.C, for special compliance tests requested by DEP shall apply.

[Rule 62-297.310(7), F.A.C.; and, SIP approved for item (b) above]

- **A.18.** When Visible Emissions Tests Not Required. By this permit, annual emissions compliance testing for visible emissions is not required for these emissions units while burning:
 - a. only gaseous fuel(s); or,
 - b. gaseous fuel(s) in combination with any amount of liquid fuel(s) for less than 400 hours per year; or,
- c. only liquid fuel(s) for less than 400 hours per year. [Rule 62-297.310(7)(a)4., F.A.C.]
- **A.19.** When PM Tests Not Required. Annual and permit renewal compliance testing for particulate matter emissions is not required for these emissions units while burning:
 - a. only gaseous fuel(s); or,
 - b. gaseous fuel(s) in combination with any amount of liquid fuel(s) for less than 400 hours per year; or,
 - c. only liquid fuel(s) for less than 400 hours per year.

[Rules 62-297.310(7)(a)3. & 5., F.A.C.; and, ASP Number 97-B-01]

Test Methods and Procedures

{Permitting Note: The attached Table 2-1, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

- **A.20.** <u>Visible Emissions (VE)</u>. The test method for visible emissions shall be DEP Method 9, incorporated in Chapter 62-297, F.A.C. (see Specific Condition **A.21.**). A transmissometer shall be used, certified and calibrated according to Rule 62-297.520, F.A.C. VE testing shall be conducted in accordance with the requirements of Specific Condition **A.27**. [Rule 62-296.405(1)(e)1., F.A.C.; and, AO64-217877]
- **A.21.** <u>DEP Method 9</u>. The provisions of EPA Method 9 (40 CFR 60, Appendix A) are adopted by reference with the following exceptions:
- 1. EPA Method 9, Section 2.4, Recording Observations. Opacity observations shall be made and recorded by a Florida DEP certified observer at sequential fifteen second intervals during the required period of observation.
- 2. EPA Method 9, Section 2.5, Data Reduction. For a set of observations to be acceptable, the observer shall have made and recorded, or verified the recording of, at least 90 percent of the possible individual observations during the required observation period. For single-valued opacity standards (e.g., 20 percent opacity), the test result shall be the highest valid six-minute average for the set of observations taken. For multiple-valued opacity standards (e.g., 20 percent opacity, except that an opacity of 40 percent is permissible for not more than two minutes per hour) opacity shall be computed as follows:
 - a. For the basic part of the standard (i.e., 20 percent opacity) the opacity shall be determined as specified above for a single-valued opacity standard.
- b. For the short-term average part of the standard, opacity shall be the highest valid short-term average (i.e., two-minute, three-minute average) for the set of observations taken. In order to be valid, any required average (i.e., a six-minute or two-minute average) shall be based on all of the valid observations in the sequential subset of observations selected, and the selected subset shall contain at least 90 percent of the observations possible for the required averaging time. Each required average shall be calculated by summing the opacity value of each of the valid observations in the appropriate subset, dividing this sum by the number of valid observations in the subset, and rounding the result to the nearest whole number. The number of missing observations in the subset shall be indicated in parenthesis after the subset average value. [Rule 62-297.401, F.A.C.]
- A.22. Particulate Matter. The test methods for particulate emissions shall be EPA Methods 17 or Method 5, incorporated by reference in Chapter 62-297, F.A.C. The minimum sample volume shall be 30 dry standard cubic feet. EPA Method 5 may be used with filter temperature no more than 320 degrees Fahrenheit. For EPA Method 17, stack temperature shall be less than 375 degrees Fahrenheit. EPA Method 3 or 3A with Orsat analysis shall be used when the oxygen based F-factor, computed according to EPA Method 19, is used in lieu of heat input. Acetone wash shall be used with EPA Method 5 or 17. Particulate testing shall be conducted in accordance with the requirements of Specific Conditions A.26 and A.27. [Rules 62-213.440, 62-296.405(1)(e)2. and 62-297.401, F.A.C.]

FPL Sanford Power Plant

A.23. Sulfur Dioxide. The test methods for sulfur dioxide emissions shall be EPA Methods 6, 6A, 6B, or 6C, incorporated by reference in Chapter 62-297, F.A.C. If the emissions unit obtains an alternate procedure under the provisions of Rule 62-297.620, F.A.C., the procedure shall become a condition of the emissions unit's permit. The Department will retain the authority to require EPA Method 6 or 6C if it has reason to believe that exceedences of the sulfur dioxide emissions limiting standard are occurring. The permittee may use the EPA test methods, referenced above, to demonstrate compliance; however, as an alternate sampling procedure authorized by permit, the permittee elected to demonstrate compliance using CEMS for sulfur dioxide. See Specific Condition A.15.

[Rules 62-213.440 and 62-296.405(1)(c)3. & (1)(e)3., F.A.C.; and, 1270009-001-AV]

- **A.24.** For each emissions unit, the following fuel sampling and analysis protocol may be used as an alternate sampling procedure authorized by permit to demonstrate compliance with the sulfur dioxide standard:
 - a. Determine and record the fuel sulfur content, percent by weight, for liquid fuels delivered to the facility using either ASTM D2622-92, ASTM D4294-90, or both ASTM D4057-88 and ASTM D129-91 (or latest editions) to analyze a representative sample of the fuel from each fuel delivery.
 - b. The owner or operator shall identify and dedicate each storage tank containing fuels with sulfur content of no more than 2.5% by weight.

See Specific Condition A.15.b.

[Rules 62-4.070(3), 62-213.440(1), 62-296.405(1)(e)3., 62-296.405(1)(f)1.b. and 62-297.440, F.A.C.]

A.25. Required Number of Test Runs. For mass emission limitations, a compliance test shall consist of three complete and separate determinations of the total air pollutant emission rate through the test section of the stack or duct and three complete and separate determinations of any applicable process variables corresponding to the three distinct time periods during which the stack emission rate was measured provided, however, that three complete and separate determinations shall not be required if the process variables are not subject to variation during a compliance test, or if three determinations are not necessary in order to calculate the unit's emission rate. The three required test runs shall be completed within one consecutive five day period. In the event that a sample is lost or one of the three runs must be discontinued because of circumstances beyond the control of the owner or operator, and a valid third run cannot be obtained within the five day period allowed for the test, the Secretary or his or her designee may accept the results of the two complete runs as proof of compliance, provided that the arithmetic mean of the results of the two complete runs is at least 20 percent below the allowable emission limiting standards.

[Rule 62-297.310(1), F.A.C.]

A.26. Operating Rate During Testing. Testing of emissions shall be conducted with each emissions unit operation at permitted capacity, which is defined as 90 to 100 percent of the maximum operation rate allowed by the permit. If it is impracticable to test at permitted capacity, an emissions unit may be tested at less than the minimum permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test load until a new test is conducted. Once the emissions unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity.

[Rules 62-297.310(2) & (2)(b), F.A.C.]

FPL Sanford Power Plant

- A.27. Operating Conditions During Testing Particulate Matter and Visible Emissions. Compliance testing during soot blowing and steady-state operation for particulate matter and visible emissions shall be conducted at least once annually, if liquid fuel is fired for more than 400 hours. A visible emissions test shall be conducted during one run of each particulate matter test. Testing shall be conducted as follows:
- a. When Burning Fuel Oil Up To 2.5% Sulfur Content, By Weight. When only fuel oil containing less than or equal to 2.5% sulfur content, by weight, is fired (or co-fired with natural gas) in an emissions unit, particulate matter and visible emissions tests during soot blowing and steady-state operation shall be performed on such emissions unit while firing solely fuel oil containing at least 90% of the average sulfur content of the fuel oils fired in the previous 12 month period, except that such test shall not be required to be performed during any year that testing is performed in accordance with Specific Condition A.27.b.
- b. When Burning Fuel Oil Greater Than 2.5% Sulfur Content, By Weight. If fuel oil containing greater than 2.5% sulfur content, by weight, is co-fired with natural gas in an emissions unit, particulate matter and visible emissions tests during soot blowing and steady-state operation shall be performed as soon as practicable, but in no event more than 60 days after firing such fuel oil, while co-firing such oil with the appropriate proportion of natural gas required to maintain SO₂ emissions between 90 to 100% of the SO₂ emission limit (corresponding to 2.475 and 2.75 lb/MMBtu, respectively). Following successful completion of such particulate matter and visible emissions testing, further particulate matter and visible emissions testing shall not be required during the remaining federal fiscal year unless fuel oil is fired that contains greater than 0.20% sulfur content, by weight, above the percentage sulfur concentration fired during the most recent co-firing test. If fuel oil is co-fired containing greater than 0.20% sulfur content, by weight, above the percentage sulfur concentration fired during the most recent co-firing test, additional particulate matter and visible emissions tests shall be performed as described above as soon as practicable, but in no event more than 60 days after firing such higher sulfur fuel oil. If any additional particulate matter and visible emissions tests are imposed after completion of any required annual compliance tests, then the frequency testing base date shall be reset to 12-months after the date of completion of the last tests.

[Rules 62-4.070(3), 62-213.440, 62-296.405(1)(c)3. and 62-297.310(7)(a)9., F.A.C.]

A.28. Fuel Records. The owner or operator shall create and maintain for each emissions unit hourly records of the amount of each liquid fuel fired, the ratio of fuel oil to natural gas if co-fired, and the heating value and fuel oil sulfur content. These records must be of sufficient detail to identify the testing requirements of Specific Condition A.27.(a) or (b) and, when applicable, demonstrate compliance with the requirements of Specific Condition A.15(b). Fuel oil heating value and sulfur content shall be determined using as received or as fired fuel analysis. An asfired fuel oil sample for sulfur content from the blend tank shall be required if the sulfur content of any delivery of fuel oil exceeds 2.5%, by weight; and, that analysis shall be used to evaluate the testing requirements in Specific Condition A.27. No as-fired sampling for sulfur content shall be required if any delivery of fuel oil is 2.5% or less, by weight, pursuant to the vendor's bill of lading. Analysis of a representative sample shall be performed using one of ASTM D2622-94, ASTM D4294-90(95), ASTM D1552-95, ASTM D1266-91, or both ASTM D4057-88 and ASTM D129-95 or the latest edition(s).

[Rules 62-4.070(3) and 62-213.440, F.A.C.]

FPL Sanford Power Plant

A.29. Not Federally Enforceable. In the event FPL exceeds the tested additive injection rate by 10 percent or more, FPL shall notify the Department's Central District, Air Section, in writing within 10 days of the date that the higher rate was initiated. The notification shall include the date the higher injection rate began, the magnitude of the higher rate, and, if applicable, the approximate date by which the higher rate would cease.

[AO64-217877]

A.30. Calculation of Emission Rate. The indicated emission rate or concentration shall be the arithmetic average of the emission rate or concentration determined by each of the separate test runs unless otherwise specified in a particular test method or applicable rule. [Rule 62-297.310(3), F.A.C.]

A.31. Applicable Test Procedures.

- (a) Required Sampling Time.
 - 1. Unless otherwise specified in the applicable rule, the required sampling time for each test run shall be no less than one hour and no greater than four hours, and the sampling time at each sampling point shall be of equal intervals of at least two minutes.
 - 2. Opacity Compliance Tests. When using DEP Method 9 for compliance testing the required minimum period of observation for a compliance test shall be sixty (60) minutes for each of the emissions units. The opacity test observation period shall include the period during which the highest opacity emissions can reasonably be expected to occur. Exceptions to these requirements are as follows:
 - c. The minimum observation period for opacity tests conducted by employees or agents of the Department to verify the day-to-day continuing compliance of a unit or activity with an applicable opacity standard shall be twelve minutes.
- (b) <u>Required Flow Rate Range</u>. For EPA Method 5 or Method 17 particulate sampling which uses Greenburg Smith type impingers, the sampling nozzle and sampling time shall be selected such that the average sampling rate will be between 0.5 and 1.0 actual cubic feet per minute, and the required minimum sampling volume will be obtained.
- (c) <u>Calibration of Sampling Equipment</u>. Calibration of the sampling train equipment shall be conducted in accordance with the schedule shown in Table 297.310-1 (attached to this permit).
- (d) <u>Allowed Modification to EPA Method 5</u>. When EPA Method 5 is required, the following modification is allowed: the heated filter may be separated from the impingers by a flexible tube. [Rule 62-297.310(4), F.A.C.]
- **A.32.** Required Stack Sampling Facilities. When a mass emissions stack test is required, the permittee shall comply with the requirements contained in Appendix SS-1, Stack Sampling Facilities, attached to this permit. [Rule 62-297.310(6), F.A.C.]

Recordkeeping and Reporting Requirements

A.33. Excess Emissions - Malfunctions. If the permittee is temporarily unable to comply with any of the conditions of the permit due to breakdown of equipment or destruction by hazard of fire, wind or by other cause, the permittee shall immediately notify the Department. Notification shall include pertinent information as to the cause of the problem, and what steps are being taken to correct the problem and to prevent its recurrence, and where applicable, the owner's intent toward reconstruction of destroyed facilities. Such notification does not release the permittee from any liability for failure to comply with Department rules. In the case of excess emissions resulting from malfunctions, each owner or operator shall notify the Department's

Sanford Power Plant

Central District, Air Section. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department. [Rules 62-4.130 and 62-210.700(6), F.A.C.]

A.34. Excess Emissions - Reports. Submit to the Department's Central District, Air Section, a written report of emissions in excess of emission limiting standards as set forth in Rule 62-296.405(1), F.A.C., for each calendar quarter. The nature and cause of the excess emissions shall be explained. This report does not relieve the owner or operator of the legal liability for violations. All recorded data shall be maintained on file by the Source for a period of five years. [Rules 62-213.440(1) and 62-296.405(1)(g), F.A.C.]

A.35. Test Reports.

- (a) The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Department's Central District, Air Section, on the results of each such test.
- (b) The required test report shall be filed with the Department's Central District, Air Section, as soon as practical but no later than 45 days after the last sampling run of each test is completed.
- (c) The test report shall provide sufficient detail on the emissions unit tested and the test procedures used to allow the Department's Central District, Air Section, to determine if the test was properly conducted and the test results properly computed. As a minimum, the test report, other than for an EPA or DEP Method 9 test, shall provide the following information:
 - 1. The type, location, and designation of the emissions unit tested.
 - 2. The facility at which the emissions unit is located.
 - 3. The owner or operator of the emissions unit.
 - 4. The normal type and amount of fuels used and materials processed, and the types and amounts of fuels used and material processed during each test run.
 - 5. The means, raw data and computations used to determine the amount of fuels used and materials processed, if necessary to determine compliance with an applicable emission limiting standard.
 - 6. The type of air pollution control devices installed on the emissions unit, their general condition, their normal operating parameters (pressure drops, total operating current and GPM scrubber water), and their operating parameters during each test run.
 - 7. A sketch of the duct within 8 stack diameters upstream and 2 stack diameters downstream of the sampling ports, including the distance to any upstream and downstream bends or other flow disturbances.
 - 8. The date, starting time and duration of each sampling run.
 - 9. The test procedures used, including any alternative procedures authorized pursuant to Rule 62-297.620, F.A.C. Where optional procedures are authorized in this chapter, indicate which option was used.
 - 10. The number of points sampled and configuration and location of the sampling plane.
 - 11. For each sampling point for each run, the dry gas meter reading, velocity head, pressure drop across the stack, temperatures, average meter temperatures and sample time per point.
 - 12. The type, manufacturer and configuration of the sampling equipment used.
 - 13. Data related to the required calibration of the test equipment.
 - 14. Data on the identification, processing and weights of all filters used.
 - 15. Data on the types and amounts of any chemical solutions used.
 - 16. Data on the amount of pollutant collected from each sampling probe, the filters, and the impingers, are reported separately for the compliance test.
 - 17. The names of individuals who furnished the process variable data, conducted the test, analyzed the samples and prepared the report.
 - 18. All measured and calculated data required to be determined by each applicable test procedure for each run.

FPL Sanford Power Plant

19. The detailed calculations for one run that relate the collected data to the calculated emission rate.

- 20. The applicable emission standard, and the resulting maximum allowable emission rate for the emissions unit, plus the test result in the same form and unit of measure.
- 21. A certification that, to the knowledge of the owner or his authorized agent, all data submitted are true and correct. When a compliance test is conducted for the Department or its agent, the person who conducts the test shall provide the certification with respect to the test procedures used. The owner or his authorized agent shall certify that all data required and provided to the person conducting the test are true and correct to his knowledge.
- 22. The identification and measured concentrations of any audit samples. [Rules 62-4.070(3), 62-213.440(1) and 62-297.310(8), F.A.C.]
- **A.36.** Sulfur Dioxide Emission Report. During any quarter that fuels with more than 2.5% sulfur are received at the Sanford plant or fired in the emissions units, the owner or operator shall, by the thirtieth day following each calendar quarter, submit to the Department's Central District, Air Section, a report of each period in which the 3-hour rolling average of sulfur dioxide emissions exceed 2.75 lb/MMBtu. The report shall identify the steps taken to minimize the magnitude and duration of sulfur dioxide emissions during these episodes and any preventative measures implemented to avoid recurrence of these episodes.

In the event that no 3-hour rolling average of sulfur dioxide emissions exceeds the limit of 2.75 lbs/MMBtu, no report is required to be submitted to the Department's Central District Office, Air Section.

[Rules 62-4.070(3), 62-213.440(1) and 62-213.440(1)b., F.A.C.]

A.37. Continuous opacity monitoring (COM) data shall be used to track excess emissions during normal operation of the facility for periodic monitoring purposes. See Specific Conditions **A.5.** and **A.13**.

[Rules 62-204.800 and 62-210.700, F.A.C.; and, 40 CFR 75]

A.38. The Continuous Emissions Monitoring Electronic Data Report will be submitted quarterly for all applicable parameters pursuant to 40 CFR 75.50, Subpart F. [Rules 62-4.160(2), 62-210.200(PTE) and 62-296.405, F.A.C.; and, 40 CFR 75]

Miscellaneous Conditions

- **A.39.** <u>Used Oil</u>. Burning of on-specification used oil is authorized at this facility in accordance with all other conditions of this permit and the following additional conditions:
- a. On-specification Used Oil Allowed as Fuel: This permit allows the burning of used oil fuel consisting only of used lubricating oils resulting from Sanford Plant's maintenance activities, and mineral oil from the FPL's system-wide maintenance operations on transformers. FPL shall control the collection of these waste oils by the use of placards at used oil collection sites, and by informing plant personnel of the restrictions above, to insure that other liquids (waste solvents, paints, and hazardous wastes) are not mixed with the used oils fired in the boilers. This used oil shall meet EPA "on-specification" criteria, and have a PCB concentration of less than 50 ppm. Used oil that does not meet the specifications for on-specification used oil shall not be burned at this facility.

On-specification used oil shall meet the following specifications:

Arsenic shall not exceed 5.0 ppm; Cadmium shall not exceed 2.0 ppm; Chromium shall not exceed 10.0 ppm; Lead shall not exceed 100.0 ppm; FPL Sanford Power Plant

Total halogens shall not exceed 1000 ppm; Flash point shall not be less than 100 degrees F. [40 CFR 279, Subpart B.]

- b. <u>Quantity Limited</u>: The annual quantity of used lubricating oil that may be burned in the boilers shall not exceed the quantity of new lubricating oils consumed at the Sanford plant in any consecutive 12-month period. The annual quantity of used mineral oil burned in the boilers shall not exceed the quantity generated from FPL system wide maintenance activities.
- c. <u>Used Oil Containing PCBs Not Allowed:</u> Used oil containing a PCB concentration of 50 or more ppm shall not be burned at this facility. Used oil shall not be blended to meet this requirement.
- d. <u>PCB Concentration of 2 to less than 50 ppm</u>: On-specification used oil with a PCB concentration of 2 to less than 50 ppm shall be burned only at normal source operating temperatures.
- e. <u>Testing Required</u>: The owner or operator shall sample and analyze each batch of used oil to be burned for the following parameters:
 - (1) Arsenic, cadmium, chromium, lead, total halogens, flash point, PCBs.
 - (2) Testing (sampling, extraction and analysis) shall be performed using approved methods specified in EPA Publication SW-846 (Test Methods for Evaluating Solid Waste, Physical/Chemical Methods), latest edition.
 - (3) Split samples of the used oil shall be labeled with the batch analysis date, when the batch was fired and in which boiler the batch was fired. Split samples shall be retained for three months after analysis and made available to Department upon request for further testing if necessary.
- f. <u>Recordkeeping Required</u>: The owner or operator shall obtain and keep the following records related to the use of used oil in a form suitable for inspection at the facility by the Department:
 - (1) The gallons of on-specification used oil burned each month. (This record shall be completed no later than the fifteenth day of each succeeding month that used oil is fired.)
 - (2) The analysis results, date, batch quantity, date of firing and identification of which boiler fired each batch shall be recorded.

[40 CFR 279.61 and 761.20(e)]

g. <u>Reporting Required</u>: The owner or operator shall submit, with the Annual Operation Report form, a separate listing of the analytical results and the total amount of on-specification used oil burned during the previous calendar year.

[Rules 62-4.070(3) and 62-213.440(1), F.A.C.; 40 CFR 279; and, 40 CFR 761, unless otherwise noted]

FPL

Section III. Emissions Unit(s) and Conditions.

Subsection B. This section addresses the following emissions units.

E.U. ID No.	Brief Description				
	Repowered Unit 5: 4 (four) combined cycle only combustion turbines				
009	Combined Cycle Combustion Turbine (CCCT) Generator PSNCT5A with				
	an unfired Heat Recovery Steam Generator (HRSG)				
. 010	CCCT PSNCT5B with an unfired HRSG				
011	CCCT PSNCT5C with an unfired HRSG				
012	CCCT PSNCT5D with an unfired HRSG				

Repowered Unit 5, which is made up of 4 (four: PSNCT5A thru PSNCT5D) combined cycle only combustion turbines, replaces the existing residual oil-fired and gas-fired steam generating boiler Unit 5, while the existing steam-driven electrical turbine-generator will remain. Each combined cycle turbine unit is a nominal 170 MW (@59°F - compressor inlet) General Electric Frame MS7241FA Advanced natural gas-fired and distillate oil-fired combustion turbinegenerator, with associated inlet foggers and an unfired Heat Recovery Steam Generator (HRSG) that will capture sufficient waste heat to produce another 80 MW via the existing steam-driven electrical turbine-generator (therefore, 250 MW in combined cycle operation). Each combustion turbine is permitted to fire natural gas (which has already been tested for) and distillate fuel oil (which has not been tested for: see Appendix CP-1, Compliance Plan for Repowered Unit 5). Water injection is installed in each turbine for Repowered Unit 5 to control NO_x, when firing distillate oil. Dry Low-NO_X combustors are installed in each turbine for Repowered Unit 5 to control NO_x, when firing natural gas. An evaporative equipment cooler was built instead of the proposed mechanical draft-cooling tower. Unit PSNCT5A commenced operation on February 21, 2002; Unit PSNCT5B commenced operation on February 25, 2002; PSNCT5C commenced operation on March 4, 2002; and, PSNCT5D commenced operation on March 11, 2002.

For Repowered Unit 5, the existing tall boiler (Unit 5) stack will be dismantled and replaced with relatively short stacks per emissions unit for the combined cycle operation.

Electrical fuel heaters will be used instead of the natural gas heaters to heat the natural gas prior to use during cold startups.

{Permitting Note(s): These emissions units are regulated under: Acid Rain, Phase II; NSPS - 40 CFR 60, Subpart GG, Standards of Performance for Stationary Gas Turbines, adopted and incorporated by reference in Rule 62-204.800(7)(b), F.A.C.; Rule 62-212.400(5), F.A.C., Prevention of Significant Deterioration (PSD); and, Rule 62-212.400(6), F.A.C., Best Available Control Technology (BACT) Determination, dated September 14, 1999.}

The following specific conditions apply to the emissions units listed above:

Essential Potential to Emit (PTE) Parameters

B.1. Turbine Capacity. The design heat input rates for natural gas firing, based on the high heating value (HHV) of the fuel to <u>each</u> combustion turbine (CT) at compressor inlet conditions of 59°F, 60% relative humidity, 100% load and 14.7 psia, is 1,776 million Btu per hour (MMBtu/hr). The design heat input for fuel oil firing is 1,930 MMBtu/hr (HHV, 60% relative humidity, 100% load, 59°F compressor inlet and 14.7 psia). This design heat input rate will vary depending upon the CT's inlet conditions and characteristics. Manufacturer's curves corrected

FPL

for site conditions or equations for correction to other compressor inlet conditions shall be provided to the Department within 45 days of completing the initial compliance testing.

{Permitting Note: The heat input limitations have been placed in each permit to identify the capacity of each unit for the purposes of confirming that emissions testing is conducted within 90 to 100 percent of the unit's rated capacity (or to limit future operation to 110 percent of the test load), to establish appropriate emission limits and to aid in determining future rule applicability. Regular recordkeeping is not required for heat input. Instead the owner or operator is expected to determine heat input whenever emission testing is required, to demonstrate at what percentage of the rated capacity that the unit was tested. Rule 62-297.310(5), F.A.C., included in the permit, requires measurement of the process variables for emission tests. Such heat input determination may be based on measurements of fuel consumption by various methods including but not limited to fuel flow metering or tank drop measurements, using the heat value of the fuel determined by the fuel vendor or the owner or operator, to calculate average hourly heat input during the test.}

[Rule 62-210.200(PTE), F.A.C.; and, 1270009-004-AC/PSD-FL-270]

B.2. Emissions Unit Operating Rate Limitation After Testing. See Specific Condition **B.30**. [Rule 62-297.310(2), F.A.C.]

B.3. Methods of Operation. Fuels.

- a. <u>Primary</u>: Pipeline natural gas shall be the primary fuel fired in these emissions units. See Specific Condition **B.45**. and the "Permitting Note", below.
- b. <u>Secondary</u>: When natural gas is <u>not</u> available, up to 28,600,000 gallons per year of distillate fuel oil, having a maximum sulfur content of 0.05%, by weight, is authorized for Repowered Unit 5 operations (ARMS emissions units 009 012: PSNCT5A PSNCT5D, respectively). See Specific Conditions **B.46** and **B.62**.

{Permitting Note: For the purposes of this subsection of this permit, "pipeline natural gas" means natural gas with a sulfur content of less than 20 gr/100 scf that is provided by the natural gas pipeline transmission company. In addition, commercial operation on distillate fuel oil shall not be allowed until the Compliance Plan has been satisfied. (See Specific Conditions **B.24.a. & c.**, **B.45.b. & c.** and **B.62.**)}

[Rule 62-210.200(PTE), F.A.C.; 40 CFR 60.333; and, 1270009-004-AC/PSD-FL-270]

B.4. Hours of Operation. The emissions units may operate continuously, i.e., 8,760 hours/year. [Rule 62-210.200(PTE), F.A.C.; and, 1270009-004-AC/PSD-FL-270]

Control Technology

B.5. DLN systems shall be maintained to minimize NO_X emissions and CO emissions, consistent with normal operation and maintenance practices.

[Rules 62-4.070(3) and 62-210.650, F.A.C.; and, 1270009-004-AC/PSD-FL-270]

B.6. Circumvention. No owner or operator shall build, erect, install, or use any article, machine, equipment or process, the use of which conceals an emission which would otherwise constitute a violation of an applicable standard. Such concealment includes, but is not limited to, the use of gaseous diluents to achieve compliance with an opacity standard or with a standard which is based on the concentration of a pollutant in the gases discharged into the atmosphere.

[40 CFR 60.12]

Emission Limitations and Standards

{Permitting Note: The attached Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

{Permitting Note: Unless otherwise specified, the averaging times for Specific Conditions **B.7.** through **B.11.** are based on the specified averaging time of the applicable test method.}

B.7. The following are the emission limits, assuming full load. Values for NO_X are corrected to 15% O_2 on a dry basis. These limits or their equivalents in terms of pounds per hour, as well as the applicable averaging times, are followed by the applicable specific conditions.

Emissions Unit	NO _x	СО	voc	PM/PM ₁₀ /VE (% Opacity)	Technology and Comments
CTs (each)	9 ppm (30 day) - gas 42 ppm - oil 75/110 ppm (NSPS)	12 ppmvd - gas 20 ppmvd - oil	1.4 ppmvd 7 ppmvw	10 - gas 20 - oil	Dry Low NO _x Combustors; Natural Gas or 0.05% S, by wt., Fuel Oil; Good Combustion; Water Injection on Fuel Oil

<u>NOTE</u>: The 40 CFR 60, Subpart GG requirement to correct test data to ISO conditions applies. However, such correction is not required to demonstrate compliance with non-NSPS permit standard(s). [40 CFR 60.333; and, 1270009-004-AC/PSD-FL-270]

B.8. Nitrogen Oxides (NOx).

- a. Natural Gas Firing: The NOx concentrations in the exhaust gas of each CT shall not exceed 9 ppmvd at 15% O₂, on a 30-day rolling average basis, when firing natural gas, as measured by the CEMS (maintained in accordance with 40 CFR 75). Based on CEMS data at the end of each operating day, a new 30-day average rate is calculated from the arithmetic average of all valid hourly emission rates during the previous 30 operating days. Valid hourly emission rates shall not include periods of startup, shutdown or malfunction. In addition, NOx emissions calculated as NO₂ shall exceed neither 9 ppmvd at 15% O₂ nor 65 lbs/hr (at ISO conditions) to be demonstrated by initial performance tests.
- b. <u>Distillate Oil Firing</u>: The NO_x concentrations in the exhaust gas of <u>each</u> CT shall not exceed 42 ppmvd at 15% O₂, on a 24-hour block average basis, when firing distillate fuel oil, as measured by the CEMS (maintained in accordance with 40 CFR 75). Based on CEMS data at the end of each operating day, a new 24-hour average rate is calculated from the arithmetic average of all valid hourly emission rates during the previous day. Valid hourly emission rates shall not include periods of startup, shutdown or malfunction. In addition, NO_x emissions calculated as NO₂ shall exceed neither 42 ppm at 15% O₂ nor 355 lbs/hr (at ISO conditions) to be demonstrated by initial distillate oil-firing performance tests.

Sanford Power Plant

c. When NO_x monitoring data is not available, substitution for missing data shall be handled as required by Title IV (40 CFR 75) to calculate the 30-day rolling average or 24-hour block average emission rates.

[Rules 62-204.800(7)(b) (Subpart GG) and 62-210.200(PTE), F.A.C.; 40 CFR 75; and, 1270009-004-AC/PSD-FL-270]

- **B.9.** <u>Visible Emissions (VE)</u>. VE emissions from the combustion turbines shall not exceed 10 percent opacity, during gas firing, and 20 percent opacity, during oil firing. [1270009-004-AC/PSD-FL-270]
- **B.10.** Carbon Monoxide (CO). The concentration of CO (@15% O₂) in the exhaust gas shall not exceed 12 ppmvd when firing natural gas and 20 ppmvd when firing distillate oil as measured by EPA Method 10 at full-load conditions. CO emissions (at ISO conditions) shall not exceed 43 lbs/hr/CT, when firing natural gas, and 71.6 lbs/hr/CT, when firing distillate oil, and to be demonstrated by stack tests.

 [1270009-004-AC/PSD-FL-270]
- **B.11.** Volatile Organic Compounds (VOC). The concentration of VOC in the exhaust gas shall not exceed 1.4 ppmvd, when firing natural gas, and 7 ppmvw, when firing distillate oil, as determined by EPA Method 18 or 25A. VOC emissions (at ISO conditions) shall not exceed 2.9 lbs/hr/CT, when firing natural gas, and 16.1 lbs/hr/CT, when firing distillate oil, and to be demonstrated by initial stack tests.

 [1270009-004-AC/PSD-FL-270]
- **B.12.** Sulfur Dioxide (SO₂). As per Specific Condition **B.3**. [1270009-004-AC/PSD-FL-270]

Excess Emissions

{Permitting Note: The Excess Emissions Rule at Rule 62-210.700, F.A.C., cannot vary any requirement of a NSPS or NESHAP provision.}

B.13. Excess emissions resulting from startup, shutdown, or malfunction of the *combustion turbines (CTs) and associated heat recovery steam generators (HRSGs)* shall be permitted provided that best operational practices are adhered to and the duration of excess emissions shall be minimized. Excess emissions occurrences shall in no case exceed two (2) hours in any 24-hour period except during both "cold startup" to or "shutdowns" from combined cycle operation [CT and associated HRSG]. During cold startup to combined cycle operation, up to four (4) hours of excess emissions are allowed. During shutdowns from combined cycle operation, up to three (3) hours of excess emissions are allowed. Cold startup is defined as a startup to combined cycle operation when the heat recovery steam generator high-pressure drum is below 450 psig for at least one (1) hour.

Excess emissions from the CTs resulting from startup of the *steam turbine system* shall be permitted provided that best operational practices are adhered to and the duration of excess emissions shall be minimized. Excess emissions occurrences shall in no case exceed 12 hours per CT per cold startup of the <u>steam turbine system</u> [CT(s) and associated HRSG(s), Steam Turbine and Generator]. Cold startup of the steam turbine system shall be completed within twelve (12) hours.

[Rules 62-210.700(1) and 62-4.130, F.A.C.; G.E. Combined Cycle Startup Curves Data; 1270009-004-AC/PSD-FL-270; and, 1270009-008-AC/PSD-FL-270(A)]

B.14. Excess emissions entirely or in part by poor maintenance, poor operation, or any other equipment or process failure that may reasonably be prevented during startup, shutdown or malfunction, shall be prohibited.

[Rule 62-210.700(4), F.A.C.; and, 1270009-004-AC/PSD-FL-270]

B.15. A malfunction means any sudden, infrequent, and not reasonably preventable failure of air pollution control equipment, process equipment, or a process to operate in a normal or usual manner. Failures that are caused in part by poor maintenance or careless operation are not malfunctions.

[40 CFR 60.2, Definitions - Malfunction]

B.16. A malfunction means any unavoidable mechanical and/or electrical failure of air pollution control equipment or process equipment or of a process resulting in operation in an abnormal or unusual manner.

[Rule 62-210.200, Definitions - Malfunction, F.A.C.]

Monitoring of Operations

- **B.17.** At all times, including periods of startup, shutdown and malfunction, owners and operators shall, to the extent practicable, maintain and operate any affected facility including associated pollution control equipment in a manner consistent with good air pollution control practice for minimizing emissions. Determination of whether acceptable operating and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, opacity observations, review of operating and maintenance procedures, and inspection of the source.

 [40 CFR 60.11(d)]
- **B.18.** Operating Procedures. Operating procedures shall include good operating practices and proper training of all operators and supervisors. The good operating practices shall meet the guidelines and procedures as established by the equipment manufacturers. All operators (including supervisors) of air pollution control devices shall be properly trained in plant specific equipment.

[Rule 62-4.070(3), F.A.C.; and, 1270009-004-AC/PSD-FL-270]

B.19. Determination of Process Variables.

- (a) Required Equipment. The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.
- (b) Accuracy of Equipment. Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value.

[Rule 62-297.310(5), F.A.C.]

B.20. The owner or operator of any stationary gas turbine subject to the provisions of 40 CFR 60, Subpart GG, and using water injection to control NO_X emissions shall operate a continuous monitoring system to monitor and record the fuel consumption and the ratio of water to fuel

Sanford Power Plant

being fired in the turbine. This system shall be accurate to within ±5.0 percent and shall be approved by the Administrator. A nitrogen oxide continuous emissions monitoring system (CEMS) shall be used to determine compliance with this requirement for each CT. See Specific Condition B.47.

[40 CFR 60.334(a)]

- **B.21.** The owner or operator of any stationary gas turbine subject to the provisions of 40 CFR 60, Subpart GG, shall monitor sulfur content and nitrogen content of the fuel being fired in the turbine. The frequency of determinations of these values shall be as follows:
- (1) If the turbine is supplied its fuel from a bulk storage tank, the values shall be determined on each occasion that fuel is transferred to the storage tank from any other source. See Specific Condition **B.46**.
- (2) If the turbine is supplied its fuel without intermediate bulk storage the values shall be determined and recorded daily. Owners, operators or fuel vendors may develop custom schedules for determination of the values based on the design and operation of the affected facility and the characteristics of the fuel supply. These custom schedules shall be substantiated with data and must be approved by the Administrator before they can be used to comply with 40 CFR 60.334(b).

[40 CFR 60.334(b)(1) & (2)]

Compliance Determination

B.22. Continuous compliance with the NO_X emission limits while firing Natural Gas. Continuous compliance with the NO_X emission limits when firing natural gas shall be demonstrated with the CEMS based on a 30-day rolling average. Based on CEMS data, a separate compliance determination is conducted at the end of each operating day and a new 30-day average emission rate is calculated from the arithmetic average of all valid hourly emission rates during the previous 30 operating days. Valid hourly emission rates shall not include periods of startup, shutdown, or malfunction.

[Rules 62-4.070 and 62-210.700, F.A.C.; 40 CFR 75; and, 1270009-004-AC/PSD-FL-270]

B.23. Continuous compliance with the NO_X emission limits while firing Fuel Oil. Compliance with the NO_X emission limits when firing oil shall be demonstrated with the CEMS based on a 24-hour block average. Based on CEMS data, a separate compliance determination is conducted at the end of each operating day and is calculated from the arithmetic average of all valid hourly emission rates during the previous day. Valid hourly emission rates shall not include periods of startup, shutdown, or malfunction. A valid hourly emission rate shall be calculated for each hour in which at least two NO_X concentrations are obtained at least 15 minutes apart. [Rules 62-4.070 and 62-210.700, F.A.C.; 40 CFR 75; and, 1270009-004-AC/PSD-FL-270]

B.24. Compliance with the SO₂ and PM/PM₁₀ emission limits:

- a. Natural Gas. The use of pipeline natural gas is the method for determining compliance for SO_2 and PM/PM_{10} , when firing natural gas. See Specific Conditions **B.3.** and **B.45**.
- b. <u>Fuel Oil</u>. The use of very low sulfur fuel oil (0.05% content, by weight, or less) is the method of compliance for SO_2 and PM/PM_{10} , when firing distillate oil. See Specific Condition **B.46**.
- c. <u>Natural Gas</u>. For the purposes of demonstrating compliance with 40 CFR 60.333(b), when firing natural gas, data from the pipeline natural gas supplier may be submitted or the natural gas sulfur content referenced in 40 CFR 75, Appendix D, may be utilized. Gas analysis, if conducted, may be performed by the owner or operator, a service contractor retained by the owner or operator, the fuel vendor, or any other qualified agency pursuant to 40 CFR 60.335(e) (1998 version). However, the applicant is responsible for ensuring that the procedures in 40 CFR

Sanford Power Plant

FPL

60.335 or 40 CFR 75 are used for determination of fuel sulfur content, if gas analysis is done. See Specific Conditions **B.3.** and **B.45**.

- d. <u>Fuel Oil</u>. For the purposes of demonstrating compliance with 40 CFR 60.333(b), when firing distillate oil, compliance shall follow the requirements of 40 CFR 60.334(b)(1) using methods specified in ASTM 2880-96 (or latest version). See Specific Condition **B.46**. [1270009-004-AC/PSD-FL-270; and, 40 CFR 75]
- **B.25.** Compliance with CO emission limit. An initial test for CO shall be conducted concurrently with the initial NO_x test while operating at permitted capacity. These initial NO_x and CO test results shall be the average of three runs. Annual compliance testing for CO may be conducted at less than capacity when compliance testing is conducted concurrent with the annual NO_x RATA testing, which is performed pursuant to 40 CFR 75.

 [1270009-004-AC/PSD-FL-270; 40 CFR 75]
- **B.26.** Compliance with the VOC emission limit. An initial test is required to demonstrate compliance with the VOC emission limit. Thereafter, the CO emission limit will be employed as a surrogate for VOC and no annual testing is required. The initial compliance test requirement for the affected pollutant(s) has been satisfied and no further tests are required.

[1270009-004-AC/PSD-FL-270]

Test Methods and Procedures

{Permitting note: Table 2-1, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

B.27. To compute the nitrogen oxides emissions, the owner or operator shall use analytical methods and procedures that are accurate to within 5 percent and are approved by the Department to determine the nitrogen content of the fuel being fired. See Specific Condition **B.46**.

[40 CFR 60.335(a)]

B.28. The owner or operator shall determine compliance with the liquid fuel sulfur content standard of 0.05 percent, by weight, and the sulfur content of the gaseous fuels as follows: ASTM D 2880-96, or the latest edition, shall be used to determine the sulfur content of liquid fuels and ASTM D 1072-90(94)E-1, D 3031-81(86), D 4084-94, or D 3246-92, or the latest edition, shall be used for the sulfur content of gaseous fuels (incorporated by reference - see 40 CFR 60.17). The applicable ranges of some ASTM methods mentioned above are not adequate to measure the levels of sulfur in some fuel gases. Dilution of samples before analysis (with verification of the dilution ratio) may be used, subject to the approval of the Administrator. See Specific Conditions **B.45.** and **B.46**.

[40 CFR 60.335(d); and, 1270009-004-AC/PSD-FL-270]

B.29. Required Number of Test Runs. For mass emission limitations, a compliance test shall consist of three complete and separate determinations of the total air pollutant emission rate through the test section of the stack or duct and three complete and separate determinations of any applicable process variables corresponding to the three distinct time periods during which the stack emission rate was measured provided, however, that three complete and separate determinations shall not be required if the process variables are not subject to variation during a compliance test, or if three determinations are not necessary in order to calculate the unit's

FPL Sanford Power Plant

emission rate. The three required test runs shall be completed within one consecutive five day period. In the event that a sample is lost or one of the three runs must be discontinued because of circumstances beyond the control of the owner or operator, and a valid third run cannot be obtained within the five day period allowed for the test, the Secretary or his or her designee may accept the results of the two complete runs as proof of compliance, provided that the arithmetic mean of the results of the two complete runs is at least 20 percent below the allowable emission limiting standards.

[Rule 62-297.310(1), F.A.C.]

B.30. Operating Rate During Testing. Testing of emissions shall be conducted with the CT operating at permitted capacity. Permitted capacity is defined as 90-100 percent of the maximum heat input rate allowed by the permit, corrected for the average compressor inlet temperature during the test (with 100 percent represented by a curve depicting heat input vs. compressor inlet temperature). If it is impracticable to test at permitted capacity, the source may be tested at less than permitted capacity. In this case, subsequent operation is limited by adjusting the entire heat input vs. compressor inlet temperature curve downward by an increment equal to the difference between the maximum permitted heat input (corrected for compressor inlet temperature) and 110 percent of the value reached during the test until a new test is conducted. Once the unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purposes of additional compliance testing to regain the permitted capacity. Test procedures shall meet all applicable requirements (i.e., testing time frequency, minimum compliance duration, etc.) of Chapters 62-204 and 62-297, F.A.C.

[Rule 62-297.310(2), F.A.C.; and, 1270009-008-AC/PSD-FL-270(A)]

- **B.31.** Performance tests shall be conducted under such conditions as the Administrator shall specify to the plant operator based on representative performance of the affected facility. The owner or operator shall make available to the Administrator such records as may be necessary to determine the conditions of the performance tests. Operations during periods of startup, shutdown, and malfunction shall not constitute representative conditions for the purpose of a performance test nor shall emissions in excess of the level of the applicable emission limit during periods of startup, shutdown, and malfunction be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard.

 [40 CFR 60.8(c)]
- **B.32.** Initial (I) performance tests shall be performed pursuant to 40 CFR 60, Subparts A and GG. Annual (A) compliance tests shall be performed during every federal fiscal year (October 1 September 30) pursuant to Rule 62-297.310(7), F.A.C., on <u>each</u> CT as indicated. The following reference methods shall be used in accordance with 40 CFR 60, Appendix A. No other test methods may be used for compliance testing unless prior Department approval is received in writing.
- a. EPA Reference Method 9, "Visual Determination of the Opacity of Emissions from Stationary Sources."
- b. EPA Reference Method 10, "Determination of Carbon Monoxide Emissions from Stationary Sources."
- c. EPA Reference Method 20, "Determination of Oxides of Nitrogen Oxide, Sulfur Dioxide and Diluent Emissions from Stationary Gas Turbines." (Initial test only for compliance with 40 CFR 60, Subpart GG). See the "Permitting Note", below.
- d. EPA Reference Method 18, and/or 25A, "Determination of Volatile Organic Concentrations." Initial test only. The initial compliance test requirement for the affected pollutant(s) has been satisfied and no further tests are required.

FPL

e. EPA Reference Method 19. "Determination of Sulfur Dioxide Removal Efficiency and Particulate Matter, Sulfur Dioxide, and Nitrogen Oxides Emission Rates". Method 19 shall be used only for the calculation of lbs/MMBtu and 40 CFR 75 shall be used to calculate MMBtu/hr and lbs/hr emissions rates from stack tests. Initial test only. The initial compliance test requirement for the affected pollutant(s) has been satisfied and no further tests are required.

{Permitting Note: For Specific Condition B.32.c., above, the annual calibration Relative Accuracy Test Audit (RATA) associated with the NO_X CEMS may be used in lieu of the required annual compliance test using EPA Reference Method 20, as long as all of the requirements of Rule 62-297.310, F.A.C., are met (i.e., prior test notification, proper test result submittal, etc.).}

[40 CFR 60.11(b); and, 1270009-004-AC/PSD-FL-270]

- **B.33.** The opacity standards shall apply at all times except during startup, shutdown, malfunction, and as otherwise provided in the applicable standard. [40 CFR 60.11(c)]
- **B.34.** Calculation of Emission Rate. The indicated emission rate or concentration shall be the arithmetic average of the emission rate or concentration determined by each of the three separate test runs unless otherwise specified in a particular test method or applicable rule. [Rule 62-297.310(3), F.A.C.]

B.35. Applicable Test Procedures.

- (a) Required Sampling Time.
 - 1. Unless otherwise specified in the applicable rule, the required sampling time for each test run shall be no less than one hour and no greater than four hours, and the sampling time at each sampling point shall be of equal intervals of at least two minutes.
 - 2. Opacity Compliance Tests. When either EPA Method 9 or DEP Method 9 is specified as the applicable opacity test method, the required minimum period of observation for a compliance test shall be sixty (60) minutes for emissions units which emit or have the potential to emit 100 tons per year or more of particulate matter, and thirty (30) minutes for emissions units which have potential emissions less than 100 tons per year of particulate matter and are not subject to a multiple-valued opacity standard. The opacity test observation period shall include the period during which the highest opacity emissions can reasonably be expected to occur. Exceptions to these requirements are as follows:
 - c. The minimum observation period for opacity tests conducted by employees or agents of the Department to verify the day-to-day continuing compliance of a unit or activity with an applicable opacity standard shall be twelve minutes.
- (b) Minimum Sample Volume. Unless otherwise specified in the applicable rule, the minimum sample volume per run shall be 25 dry standard cubic feet.
- (c) <u>Required Flow Rate Range</u>. For EPA Method 5 particulate sampling, acid mist/sulfur dioxide, and fluoride sampling which uses Greenburg Smith type impingers, the sampling nozzle and sampling time shall be selected such that the average sampling rate will be between 0.5 and 1.0 actual cubic feet per minute, and the required minimum sampling volume will be obtained.
- (d) <u>Calibration of Sampling Equipment</u>. Calibration of the sampling train equipment shall be conducted in accordance with the schedule shown in Table 297.310-1, attached to this permit.
- (e) Allowed Modification to EPA Method 5. When EPA Method 5 is required, the following modification is allowed: the heated filter may be separated from the impingers by a flexible tube. [Rule 62-297.310(4), F.A.C.]

B.36. The permittee shall comply with the requirements contained in APPENDIX SS-1, Stack Sampling Facilities, attached to this permit. [Rule 62-297.310(6), F.A.C.; and, 40 CFR 60.8(e)]

- **B.37.** Frequency of Compliance Tests. The following provisions apply only to those emissions units that are subject to an emissions limiting standard for which compliance testing is required.
- (a) General Compliance Testing.
 - 3. The owner or operator of an emissions unit that is subject to any emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining a renewed operation permit. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy the requirements of this provision. In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of emission compliance test results for any emissions unit that, during the year prior to renewal:
 - a. Did not operate; or,
 - b. In the case of a fuel burning emissions unit, burned liquid and/or solid fuel for a total of no more than 400 hours.
 - 4. During each federal fiscal year (October 1 September 30), unless otherwise specified by rule, order, or permit, the owner or operator of each emissions unit shall have a formal compliance test conducted for:
 - a. Visible emissions, if there is an applicable standard;
 - b. Each of the following pollutants, if there is an applicable standard, and if the emissions unit emits or has the potential to emit: 5 tons per year or more of lead or lead compounds measured as elemental lead; 30 tons per year or more of acrylonitrile; or 100 tons per year or more of any other regulated air pollutant; and,
 - c. Each NESHAP pollutant, if there is an applicable emission standard.
 - 5. An annual compliance test for particulate matter emissions shall not be required for any fuel burning emissions unit that, in a federal fiscal year, does not burn liquid and/or solid fuel, other than during startup, for a total of more than 400 hours.
 - 8. Any combustion turbine that does not operate for more than 400 hours per year shall conduct a visible emissions test once per each five-year period, coinciding with the term of its air operation permit.
 - 9. The owner or operator shall notify the Department's Central District, Air Section, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator.
- (b) <u>Special Compliance Tests</u>. When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it may require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department.

Sanford Power Plant

(c) Waiver of Compliance Test Requirements. If the owner or operator of an emissions unit that is subject to a compliance test requirement demonstrates to the Department, pursuant to the procedure established in Rule 62-297.620, F.A.C., that the compliance of the emissions unit with an applicable weight emission limiting standard can be adequately determined by means other than the designated test procedure, such as specifying a surrogate standard of no visible emissions for particulate matter sources equipped with a bag house or specifying a fuel analysis for sulfur dioxide emissions, the Department shall waive the compliance test requirements for such emissions units and order that the alternate means of determining compliance be used, provided, however, the provisions of paragraph 62-297.310(7)(b), F.A.C., shall apply. [Rule 62-297.310(7), F.A.C.; and, SIP approved]

Continuous Monitoring Requirements

B.38. <u>CEMS</u>. The permittee shall install, calibrate, maintain, and operate a CEMS in the stack to measure and record the nitrogen oxides emissions from <u>each</u> CT in accordance with the requirements of 40 CFR 75.

[1270009-004-AC/PSD-FL-270]

[40 CFR 60.13(c)]

B.39. For each CT, a CEMS shall be installed, operated, and maintained in accordance with 40 CFR 60, Appendix F, and shall meet the performance specifications of 40 CFR 60, Appendix B, to monitor nitrogen oxides and a diluent gas (carbon dioxide or oxygen). The applicable continuous emissions monitoring procedures of 40 CFR Part 75 may also be used to satisfy the requirements, above.

[40 CFR 60.13(a)]

B.40. A performance evaluation of the CEMS shall be conducted during any required performance test or within 30 days thereafter in accordance with the applicable performance specifications of 40 CFR 60, Appendix B, and at other times as required by the Administrator.

B.41. The zero (or low-level value between 0 and 20 percent of span value) and span (50 to 100 percent of span value) calibration drifts shall be checked at least once daily in accordance with a written procedure. The zero and span shall, at a minimum, be adjusted whenever the 24-hour zero drift or 24-hour span drift exceeds two times the limits of the applicable performance specifications of 40 CFR 60, Appendix B. The system must allow the amount of excess zero and span drift measured at the 24-hour interval checks to be recorded and quantified. [40 CFR 60.13(d)(1)]

- **B.42.** Except for system breakdowns, repairs, calibration checks, and zero and span adjustments required under 40 CFR 60.13(d), all continuous monitoring systems (CMS) shall be in continuous operation and shall meet minimum frequency of operation requirements as follows: (2) All continuous monitoring systems referenced by 40 CFR 60.13(c) for measuring emissions, except opacity, shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period. [40 CFR 60.13(e)(2)]
- **B.43.** All CMS or monitoring devices shall be installed such that representative measurements of emissions or process parameters from the affected facility are obtained. Additional procedures for location of CMS contained in the applicable Performance Specifications of Appendix B, 40 CFR 60, shall be used.

 [40 CFR 60.13(f)]

B.44. For CMS other than opacity, 1-hour averages shall be computed from four or more data points equally spaced over each 1-hour period. Data recorded during periods of continuous monitoring system breakdown, repairs, calibration checks, and zero and span adjustments shall not be included in the data averages computed under this paragraph. An arithmetic or integrated average of all data may be used. The data may be recorded in reduced or non-reduced form (e.g. ppm pollutant and percent O₂ or ng/J of pollutant). All excess emissions shall be converted into units of the standard using the applicable conversion procedures specified in the subparts. After conversion into units of the standard, the data may be rounded to the same number of significant digits as used in the applicable subparts to specify the emission limit. (e.g. rounded to the nearest 1 percent opacity). A continuous opacity monitoring system (COMS) is not required. [40 CFR 60.13(h)]

- **B.45.** Natural Gas Monitoring Schedule. The following custom monitoring schedule for natural gas is approved in lieu of the daily sampling requirements of 40 CFR 60.334(b)(2):
- a. The permittee shall apply for an Acid Rain permit within the deadlines specified in 40 CFR 72.30.
- b. The permittee shall submit a monitoring plan, certified by signature of the Designated Representative, that commits to using a primary fuel of pipeline supplied natural gas (sulfur content less than 20 gr/100 scf pursuant to 40 CFR 75.11(d)(2)).
- c. Each unit shall be monitored for SO₂ emissions using methods consistent with the requirements of 40 CFR 75 and certified by the USEPA.

This custom fuel monitoring schedule will only be valid when pipeline natural gas is used as a primary fuel. If the primary fuel for these units is changed to a higher sulfur fuel, SO₂ emissions must be accounted for as required pursuant to 40 CFR 75.11(d). See Specific Condition **B.3**.

[40 CFR 75; and, 1270009-004-AC/PSD-FL-270]

B.46. Fuel Oil Monitoring Schedule. The following monitoring schedule for No. 2 or superior grade fuel oil shall be followed: For all bulk shipments of No. 2 or superior grade fuel oil received at the Sanford Power Plant, an analysis, which reports the sulfur content and nitrogen content of the fuel, shall be provided by the fuel vendor. The analysis shall also specify the methods by which the analyses were conducted and shall comply with the requirements of 40 CFR 60.335(d).

[1270009-004-AC/PSD-FL-270]

B.47. CEMS in lieu of Water to Fuel Ratio. The NOx CEMS shall be used in lieu of the water/fuel monitoring system for reporting excess emissions in accordance with 40 CFR 60.334(c)(1), Subpart GG (1998 version). The calibration of the water/fuel monitoring device required in 40 CFR 60.335(c) (2) (1998 version) will be replaced by the 40 CFR 75 certification tests of the NOx CEMS. Upon request from Department, the CEMS emission rates for NOx on this Unit shall be corrected to ISO conditions to demonstrate compliance with the NOx standard established in 40 CFR 60.332. See Specific Condition **B.20**. [1270009-004-AC/PSD-FL-270]

Recordkeeping and Reporting Requirements

B.48. Excess Emissions Report. If excess emissions occur for more than two hours due to malfunction, the owner or operator shall notify the Department's Central District office in accordance with Rule 62-4.130, F.A.C., within one (1) working day of: the nature, extent, and duration of the excess emissions; the cause of the excess emissions; and, the actions taken to correct the problem. In addition, the Department may request a written summary report of the incident. Pursuant to the Standards of Performance for New Stationary Sources, all excess emissions shall also be reported in accordance with 40 CFR 60.7, Subpart A. Following this format, 40 CFR 60.7, periods of startup, shutdown, malfunction, and fuel switching shall be monitored, recorded, and reported as excess emissions when emission levels exceed the permitted standards listed in Specific Conditions **B.7.** and **B.8**.

[Rules 62-4.130, 62-204.800 and 62-210.700(6), F.A.C.; 40 CFR 60.7 (1998 version); and, 1270009-004-AC/PSD-FL-270]

- **B.49.** The owner or operator subject to the provisions of 40 CFR 60 shall furnish the Administrator written notification as follows:
- (4) A notification of any physical or operational change to an existing facility which may increase the emission rate of any air pollutant to which a standard applies, unless that change is specifically exempted under an applicable subpart or in 40 CFR 60.14(e). This notice shall be postmarked 60 days or as soon as practicable before the change is commenced and shall include information describing the precise nature of the change, present and proposed emission control systems, productive capacity of the facility before and after the change, and the expected completion date of the change. The Administrator may request additional relevant information subsequent to this notice.

 [40 CFR 60.7(a)(4)]

B.50. The owner or operator subject to the provisions of 40 CFR 60 shall maintain records of the occurrence and duration of any startup, shutdown, or malfunction in the operation of an affected facility; any malfunction of the air pollution control equipment; or, any periods during which a continuous monitoring system or monitoring device is inoperative. The requirements include initiating a recordkeeping system to record the occurrence and duration of any start up, shutdown, load change, fuel switch, high fuel bound nitrogen, and malfunction of a CT, malfunction of the air pollution control equipment, and the periods when the CEMS is inoperable.

[40 CFR 60.7(b)]

- **B.51.** For the purpose of reports required under 40 CFR 60.7(c), periods of excess emissions that shall be reported are defined as follows:
- (1) Nitrogen oxides. Any one-hour period during which the average water-to-fuel ratio, as measured by the continuous monitoring system, falls below the water-to-fuel ratio determined to demonstrate compliance with the permitted nitrogen oxide standard by the initial performance test required in 40 CFR 60.8 or any period during which the fuel-bound nitrogen of the fuel is greater than the maximum nitrogen content allowed by the fuel-bound nitrogen allowance used during the initial performance test. Each report shall include the average water-to-fuel ratio, average fuel consumption, ambient conditions, gas turbine load, and nitrogen content of the fuel during the period of excess emissions, and the graphs or figures developed under 40 CFR 60.335(a). See Specific Conditions **B.48.** and **B.52**.

[Rule 62-296.800, F.A.C.; and, 40 CFR 60.334(c)(1)]

FPL Sanford Power Plant

B.52. NO_X CEMS for Reporting Excess Emissions. The NO_X CEMS may be used in lieu of the requirement for reporting excess emissions in 40 CFR 60.334(c)(1), Subpart GG (1998 version). Thirty day rolling average periods when NO_X emissions (ppmvd at 15% oxygen) are above the standards, listed in Specific Conditions **B.7.** and **B.8.**, shall be provided to the DEP Central District Office within one working day (verbally) followed up by a written explanation not later than three (3) working days (alternately by facsimile). Excess Emissions and Monitoring System Performance Reports shall be submitted as specified in 40 CFR 60.7(c). CEMS downtime shall be calculated and reported according to the requirements of 40 CFR 60.7(c)(3) and 40 CFR 60.7(d)(2). Upon request from Department, the CEMS emission rates for NO_X on each CT shall be corrected to ISO conditions to demonstrate compliance with the NO_X standard established in 40 CFR 60.332.

[Rule 62-204.800 F.A.C.; 1270009-004-AC/PSD-FL-270; 40 CFR 75; and, 40 CFR 60.7]

- **B.53.** CMS Reports. The monitoring devices shall comply with the certification and quality assurance, and any other applicable requirements of Rule 62-297.520, F.A.C., 40 CFR 60.13, including certification of each device in accordance with 40 CFR 60, Appendix B, Performance Specifications, and 40 CFR 60.7(a)(5), or 40 CFR Part 75. Quality assurance procedures must conform to all applicable sections of 40 CFR 60, Appendix F, or 40 CFR 75. The monitoring plan, consisting of data on CEMS equipment specifications, manufacturer, type, calibration and maintenance needs, and its proposed location shall be provided to the Department's Emissions Monitoring Section Administrator and EPA for review no later than 45 days prior to the first scheduled certification test pursuant to 40 CFR 75.62.
- **B.54.** The owner or operator required to install a CMS or monitoring device shall submit an excess emissions and monitoring systems performance report (excess emissions are defined in applicable subparts) and/or a summary report form [see 40 CFR 60.7(d)] to the Administrator semiannually, except when: more frequent reporting is specifically required by an applicable subpart; or, the CMS data are to be used directly for compliance determination, in which case quarterly reports shall be submitted; or, the Administrator, on a case-by-case basis, determines that more frequent reporting is necessary to accurately assess the compliance status of the source. All reports shall be postmarked by the 30th day following the end of each calendar half (or quarter, as appropriate). Written reports of excess emissions shall include the following information:
- (1) The magnitude of excess emissions computed in accordance with 40 CFR 60.13(h), any conversion factor(s) used, and the date and time of commencement and completion of each time period of excess emissions. The process operating time during the reporting period.
- (2) Specific identification of each period of excess emissions that occurs during startups, shutdowns, and malfunctions of the affected facility. The nature and cause of any malfunction (if known), the corrective action taken or preventative measures adopted.
- (3) The date and time identifying each period during which the continuous monitoring system was inoperative except for zero and span checks and the nature of the system repairs or adjustments.
- (4) When no excess emissions have occurred or the continuous monitoring system(s) have not been inoperative, repaired, or adjusted, such information shall be stated in the report. [40 CFR 60.7(c)(1), (2), (3) & (4)]

FPL Sanford Power Plant

B.55. The summary report form shall contain the information and be in the format shown in Figure 1 (attached) unless otherwise specified by the Administrator. One summary report form shall be submitted for each pollutant monitored at each affected facility.

- (1) If the total duration of excess emissions for the reporting period is less than 1 percent of the total operating time for the reporting period and CMS downtime for the reporting period is less than 5 percent of the total operating time for the reporting period, only the summary report form shall be submitted and the excess emission report described in 40 CFR 60.7(c) need not be submitted unless requested by the Administrator.
- (2) If the total duration of excess emissions for the reporting period is 1 percent or greater of the total operating time for the reporting period or the total CMS downtime for the reporting period is 5 percent or greater of the total operating time for the reporting period, the summary report form and the excess emission report described in 40 CFR 60.7(c) shall both be submitted. [40 CFR 60.7(d)(1) & (2)]
- **B.56.** (1) Notwithstanding the frequency of reporting requirements specified in 40 CFR 60.7(c), an owner or operator who is required by an applicable subpart to submit excess emissions and monitoring systems performance reports (and summary reports) on a quarterly (or more frequent) basis may reduce the frequency of reporting for that standard to semiannual if the following conditions are met:
 - (i) For 1 full year (e.g., 4 quarterly or 12 monthly reporting periods) the affected facility's excess emissions and monitoring systems reports submitted to comply with a standard under this part continually demonstrate that the facility is in compliance with the applicable standard;
 - (ii) The owner or operator continues to comply with all recordkeeping and monitoring requirements specified in 40 CFR 60, Subpart A, and the applicable standard; and
 - (iii) The Administrator does not object to a reduced frequency of reporting for the affected facility, as provided in 40 CFR 60.7(e)(2).
- (2) The frequency of reporting of excess emissions and monitoring systems performance (and summary) reports may be reduced only after the owner or operator notifies the Administrator in writing of his or her intention to make such a change and the Administrator does not object to the intended change. In deciding whether to approve a reduced frequency of reporting, the Administrator may review information concerning the source's entire previous performance history during the required recordkeeping period prior to the intended change, including performance test results, monitoring data, and evaluations of an owner or operator's conformance with operation and maintenance requirements. Such information may be used by the Administrator to make a judgment about the source's potential for noncompliance in the future. If the Administrator disapproves the owner or operator's request to reduce the frequency of reporting, the Administrator will notify the owner or operator in writing within 45 days after receiving notice of the owner or operator's intention. The notification from the Administrator to the owner or operator will specify the grounds on which the disapproval is based. In the absence of a notice of disapproval within 45 days, approval is automatically granted.
- (3) As soon as monitoring data indicate that the affected facility is not in compliance with any emission limitation or operating parameter specified in the applicable standard, the frequency of reporting shall revert to the frequency specified in the applicable standard, and the owner or operator shall submit an excess emissions and monitoring systems performance report (and summary report, if required) at the next appropriate reporting period following the noncomplying event. After demonstrating compliance with the applicable standard for another full year, the owner or operator may again request approval from the Administrator to reduce the frequency of reporting for that standard as provided for in 40 CFR 60.7(e)(1) and (e)(2).

[40 CFR 60.7(e)(1), (2) & (3)]

FPL Sanford Power Plant

B.57. Quarterly Reports. Quarterly excess emission reports, in accordance with 40 CFR 60.7(a)(7) and (c) (1998 version), shall be submitted to the Department's Central District office. [1270009-004-AC/PSD-FL-270]

B.58. All recorded data shall be maintained on file by the Source for a period of five years. [Rule 62-213.440, F.A.C.]

B.59. Test Reports.

- (a) The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Department on the results of each such test.
- (b) The required test report shall be filed with the Department as soon as practical but no later than 45 days after the last sampling run of each test is completed.
- (c) The test report shall provide sufficient detail on the emissions unit tested and the test procedures used to allow the Department to determine if the test was properly conducted and the test results properly computed. As a minimum, the test report, other than for an EPA or DEP Method 9 test, shall provide the following information:
 - 1. The type, location, and designation of the emissions unit tested.
 - 2. The facility at which the emissions unit is located.
 - 3. The owner or operator of the emissions unit.
 - 4. The normal type and amount of fuels used and materials processed, and the types and amounts of fuels used and material processed during each test run.
 - 5. The means, raw data and computations used to determine the amount of fuels used and materials processed, if necessary to determine compliance with an applicable emission limiting standard.
 - 6. The type of air pollution control devices installed on the emissions unit, their general condition, their normal operating parameters (pressure drops, total operating current and GPM scrubber water), and their operating parameters during each test run.
 - 7. A sketch of the duct within 8 stack diameters upstream and 2 stack diameters downstream of the sampling ports, including the distance to any upstream and downstream bends or other flow disturbances.
 - 8. The date, starting time and duration of each sampling run.
 - 9. The test procedures used, including any alternative procedures authorized pursuant to Rule 62 297.620, F.A.C. Where optional procedures are authorized in this chapter, indicate which option was used.
 - 10. The number of points sampled and configuration and location of the sampling plane.
 - 11. For each sampling point for each run, the dry gas meter reading, velocity head, pressure drop across the stack, temperatures, average meter temperatures and sample time per point.
 - 12. The type, manufacturer and configuration of the sampling equipment used.
 - 13. Data related to the required calibration of the test equipment.
 - 14. Data on the identification, processing and weights of all filters used.
 - 15. Data on the types and amounts of any chemical solutions used.
 - 16. Data on the amount of pollutant collected from each sampling probe, the filters, and the impingers, are reported separately for the compliance test.
 - 17. The names of individuals who furnished the process variable data, conducted the test, analyzed the samples and prepared the report.
 - 18. All measured and calculated data required to be determined by each applicable test procedure for each run.
 - 19. The detailed calculations for one run that relate the collected data to the calculated emission rate.
 - 20. The applicable emission standard, and the resulting maximum allowable emission rate for the emissions unit, plus the test result in the same form and unit of measure.
 - 21. A certification that, to the knowledge of the owner or his authorized agent, all data submitted are true and correct. When a compliance test is conducted for the Department or its agent, the person

Sanford Power Plant

FPL.

who conducts the test shall provide the certification with respect to the test procedures used. The owner or his authorized agent shall certify that all data required and provided to the person conducting the test are true and correct to his knowledge.

[Rules 62-213.440 and 62-297.310(8), F.A.C.]

Miscellaneous

B.60. For the purpose of submitting compliance certifications or establishing whether or not a person has violated or is in violation of any standard in 40 CFR 60, nothing in 40 CFR 60 shall preclude the use, including the exclusive use, of any credible evidence or information, relevant to whether a source would have been in compliance with applicable requirements if the appropriate performance or compliance test or procedure had been performed. [40 CFR 60.11(g)]

- **B.61.** Modifications: The permittee shall give written notification to the Department when there is any modification to this facility. This notice shall be submitted sufficiently in advance of any critical date involved to allow sufficient time for review, discussion, and revision of plans, if necessary. Such notice shall include, but not be limited to, information describing the precise nature of the change; modifications to any emission control system; production capacity of the facility before and after the change; and the anticipated completion date of the change. [Chapters 62-210 and 62-212, F.A.C.; and, 1270009-004-AC/PSD-FL-270]
- **B.62.** Compliance Plan. Based on the application, the CTs for Repowered Unit 5 have not yet been tested on fuel oil. Therefore, Appendix CP-1, Compliance Plan for Repowered Unit 5, has been established and is a part of this permit. [Rule 62-213.440(2), F.A.C.]

Sanford Power Plant

Section IV. This section is the Acid Rain Part.

Operated by:

FPL

ORIS code:

0620 (Sanford Power Plant)

Subsection A. This subsection addresses requirements of the Acid Rain Program, Phase II.

The emissions units listed below are regulated under the Acid Rain Program, Phase II.

E.U. ID No.	Brief Description				
001	Fossil Fuel Steam Generator, Unit 3 (Acid Rain Boiler ID: PSN3)				
Repowered Unit 5					
009	Combined Cycle Combustion Turbine (CCCT) Generator PSNCT5A with an				
	unfired Heat Recovery Steam Generator (HRSG)				
010	CCCT PSNCT5B with an unfired HRSG				
011	CCCT PSNCT5C with an unfired HRSG				
012	CCCT PSNCT5D with an unfired HRSG				

A.1. The Phase II permit application(s) submitted for this facility, as approved by the Department, is a part of this permit. The owners and operators of these Phase II acid rain unit(s) must comply with the standard requirements and special provisions set forth in the application(s) listed below:

a. DEP Form No. 62-210.900(1)(a), signed April 30, 2002, and received August 21, 2002. [Chapter 62-213 and Rule 62-214.320, F.A.C.]

A.2. Sulfur dioxide (SO₂) allowance allocations for each Acid Rain unit are as follows:

E.U. ID No.	EPA ID	Year	2000	2001	2002	2003	2004
001	PSN3	SO2 allowances,					
		under Table 2 of 40	1073*	1073*	1073*	1073*	1073*
		CFR Part 73					
009	PSNCT5A	SO2 allowances,			0	0	0
		under Table 2 of 40					
		CFR Part 73					
010	PSNCT5B	SO2 allowances,			0	0	0
		under Table 2 of 40					
		CFR Part 73					
011	PSNCT5C	SO2 allowances,			0 .	0	0
		under Table 2 of 40					
		CFR Part 73					
012	PSNCT5D	SO2 allowances,			0	0	0
		under Table 2 of 40					
		CFR Part 73					

^{*} The number of allowances held by an Acid Rain source in a unit account may differ from the number allocated by the USEPA under Table 2 of 40 CFR 73.

A.3. Emission Allowances. Emissions from sources subject to the Federal Acid Rain Program (Title IV) shall not exceed any allowances that the source lawfully holds under the Federal Acid Rain Program. Allowances shall not be used to demonstrate compliance with a non-Title IV applicable requirement of the Act.

Sanford Power Plant

1. No permit revision shall be required for increases in emissions that are authorized by allowances acquired pursuant to the Federal Acid Rain Program, provided that such increases do not require a permit revision pursuant to Rule 62-213.400(3), F.A.C.

- 2. No limit shall be placed on the number of allowances held by the source under the Federal Acid Rain Program.
- 3. Allowances shall be accounted for under the Federal Acid Rain Program. [Rules 62-213.440(1)(c)1., 2. & 3., F.A.C.]
- **A.4.** Fast-Track Revisions of Acid Rain Parts. Those Acid Rain sources making a change described at Rule 62-214.370(4), F.A.C., may request such change as provided in Rule 62-213.413, Fast-Track Revisions of Acid Rain Parts. [Rule 62-213.413, F.A.C.]
- **A.5.** Comments, notes, and justifications: None.

Appendix U-1, List of Unregulated Emissions Units and/or Activities

FPL Sanford Power Plant FINAL Permit No.: 1270009-007-AV Facility ID No.: 1270009

<u>Unregulated Emissions Units and/or Activities</u>. An emissions unit which emits no "emissions-limited pollutant" and which is subject to no unit-specific work practice standard, though it may be subject to regulations applied on a facility-wide basis (e.g., unconfined emissions, odor, general opacity) or to regulations that require only that it be able to prove exemption from unit-specific emissions or work practice standards.

The below listed emissions units and/or activities are neither 'regulated emissions units' nor 'insignificant emissions units'.

Brief Description of Emissions Units and/or Activity

- 1. Small diesel emergency generator operated less than 400 hours per year:
 - a. Stationary Detroit Diesel Model No. 7124-7200N: 500 KW emergency generator
- 2. Tank A: 268,000 barrels No. 6 fuel oil; pre-NSPS
- 3. Tank 3AD: 6,000 barrels No. 6 fuel oil; pre-NSPS; day tank for Unit 3
- 4. Tank 3BD: 6,000 barrels No. 6 fuel oil; pre-NSPS; day tank for Unit 3
- 5. Tank LO: 1,000 barrels No. 2 fuel oil; pre-NSPS; for unit 3 and repowered units 4 and 5
- 6. Day tank for No. 2 fuel oil: 275 gallons
- 7. Sandblasting operations
- 8. Parts washing
- 9. General painting
- 10. Evaporative equipment cooler for Repowered Unit 5

Appendix I-1, List of Insignificant Emissions Units and/or Activities

FINAL Permit No.: 1270009-007-AV

Facility ID No.: 1270009

FPL Sanford Power Plant

The facilities, emissions units, or pollutant-emitting activities listed in Rule 62-210.300(3)(a), F.A.C., Categorical Exemptions, are exempt from the permitting requirements of Chapters 62-210 and 62-4, F.A.C.; provided, however, that exempt emissions units shall be subject to any applicable emission limiting standards and the emissions from exempt emissions units or activities shall be considered in determining the potential emissions of the facility containing such emissions units. Emissions units and pollutant-emitting activities exempt from permitting under Rule 62-210.300(3)(a), F.A.C., shall not be exempt from the permitting requirements of Chapter 62-213, F.A.C., if they are contained within a Title V source; however, such emissions units and activities shall be considered insignificant for Title V purposes provided they also meet the criteria of Rule 62-213.430(6)(b), F.A.C. No emissions unit shall be entitled to an exemption from permitting under Rule 62.210.300(3)(a), F.A.C., if its emissions, in combination with the emissions of other units and activities at the facility, would cause the facility to emit or have the potential to emit any pollutant in such amount as to make the facility a Title V source.

The below listed emissions units and/or activities are considered insignificant pursuant to Rule 62-213.430(6), F.A.C.

Brief Description of Emissions Units and/or Activities

- 1. Vacuum pumps used in laboratory operations
- 2. Propane relief valves
- 3. Hydrazine mixing tank and relief valves
- 4. Fire and safety equipment
- 5. Lube oil tank vents and extraction vents
- 6. Oil/water separators and related equipment
- 7. Miscellaneous mobile vehicle operation (cars, light trucks, heavy-duty trucks, backhoes, tractors, forklifts, cranes, etc.)
- 8. Brazing, soldering, and welding equipment
- 9. Degreasing units using heavier than air vapors except those which use solvents that are listed as HAPs
- 10. Space heating equipment other than boilers
- 11. Equipment used for steam cleaning
- 12. Laboratory equipment used exclusively for chemical and physical analysis, including CEMS
- 13. Evaporation of on-site generated boiler non-hazardous used cleaning chemicals (includes, but not limited to citrosolv and ammonia) by injection into an operating boiler furnace provided that the boiler tube scale and other sediment has been substantially removed from the spent cleaning solution. This activity occurs once every three to five years or longer.
- 14. Cylinder gas storage and vent (Nitrogen, Hydrogen, CO₂, Cryogenic H₂)
- 15. Tanker unloading dock area fugitive emissions for light fuel oil
- 16. CT5A thru CT5D: primarily steam and water vents/drains
- 17. CT5A's thru CT5D's associated HRSGs: primarily steam and water vents/drains
- 18. CT5A thru CT5D common piping area: primarily steam and water vents/drains
- 19. CT5A thru CT5D common feedwater: primarily steam and water vents/drains

Appendix H-1, Permit History

FPL Sanford Power Plant FINAL Permit No.: 1270009-007-AV

Facility ID No.: 1270009

Permit History (for tracking purposes):

EU ID No(s).	Description	Permit No.	Effective Date	Expiration Date	Project Type 1
001	Fossil Fuel Steam Generator: Unit 3	1270009-001-AV	01/01/2000	12/31/2004	Initial
Repowered Un	it 5		•	_	
009	Combined Cycle Combustion Turbine	1270009-007-AV	06/04/2003	12/31/2004	Revision
	(CCCT) Generator 5A with an unfired				
	Heat Recovery Steam Generator (HRSG)	·		•	
		1270009-008-AC	03/18/2003	12/31/2004	Construction (mod.)
010	CCCT 5B with an unfired HRSG	1270009-007-AV	06/04/2003	12/31/2004	Revision
		1270009-008-AC	03/18/2003	12/31/2004	Construction (mod.)
011	CCCT 5C with an unfired HRSG	1270009-007-AV	06/04/2003	12/31/2004	Revision
		1270009-008-AC	03/18/2003	12/31/2004	Construction (mod.)
012	CCCT 5D with an unfired HRSG	1270009-007-AV	06/04/2003	12/31/2004	Revision
		1270009-008-AC	03/18/2003	12/31/2004	Construction (mod.)

Notes:

Project Type (select one): Title V: Initial, Revision, Renewal, or Admin. Correction; Construction (new or mod.); or, Extension (AC only).

² Change to an actual date, which is day 55 from the date of posting the PROPOSED Permit for EPA review (see confirmation e-mail from Tallahassee) or the date that EPA confirms resolvement of any objections.

[Note: This attachment includes "canned conditions" developed from the "Title V Core List."]

{Permitting note: APPENDIX TV-4, TITLE V CONDITIONS, is distributed to the permittee only. Other persons requesting copies of these conditions shall be provided one copy when requested or otherwise appropriate.}

Chapter 62-4, F.A.C.

1. **Not federally enforceable.** General Prohibition. Any stationary installation which will reasonably be expected to be a source of pollution shall not be operated, maintained, constructed, expanded, or modified without the appropriate and valid permits issued by the Department, unless the source is exempted by Department rule. The Department may issue a permit only after it receives reasonable assurance that the installation will not cause pollution in violation of any of the provisions of Chapter 403, F.S., or the rules promulgated thereunder. A permitted installation may only be operated, maintained, constructed, expanded or modified in a manner that is consistent with the terms of the permit.

[Rule 62-4.030, Florida Administrative Code (F.A.C.); Section 403.087, Florida Statute (F.S.)]

- 2. Not federally enforceable. Procedures to Obtain Permits and Other Authorizations; Applications.
- (1) Any person desiring to obtain a permit from the Department shall apply on forms prescribed by the Department and shall submit such additional information as the Department by law may require.
- (2) All applications and supporting documents shall be filed in quadruplicate with the Department.
- (3) To ensure protection of public health, safety, and welfare, any construction, modification, or operation of an installation which may be a source of pollution, shall be in accordance with sound professional engineering practices pursuant to Chapter 471, F.S. All applications for a Department permit shall be certified by a professional engineer registered in the State of Florida except, when the application is for renewal of an air pollution operation permit at a non-Title V source as defined in Rule 62-210.200, F.A.C., or where professional engineering is not required by Chapter 471, F.S. Where required by Chapter 471 or 492, F.S., applicable portions of permit applications and supporting documents which are submitted to the Department for public record shall be signed and sealed by the professional(s) who prepared or approved them.
- (4) Processing fees for air construction permits shall be in accordance with Rule 62-4.050(4), F.A.C.
- (5)(a) To be considered by the Department, each application must be accompanied by the proper processing fee. The fee shall be paid by check, payable to the Department of Environmental Protection. The fee is non-refundable except as provided in Section 120.60, F.S., and in this section.
 - (c) Upon receipt of the proper application fee, the permit processing time requirements of Sections 120.60(2) and 403.0876, F.S., shall begin.
 - (d) If the applicant does not submit the required fee within ten days of receipt of written notification, the Department shall either return the unprocessed application or arrange with the applicant for the pick up of the application.
 - (e) If an applicant submits an application fee in excess of the required fee, the permit processing time requirements of Sections 120.60(2) and 403.0876, F.S., shall begin upon receipt, and the Department shall refund to the applicant the amount received in excess of the required fee.
- (6) Any substantial modification to a complete application shall require an additional processing fee determined pursuant to the schedule set forth in Rule 62-4.050, F.A.C., and shall restart the time requirements of Sections 120.60 and 403.0876, F.S. For purposes of this Subsection, the term "substantial modification" shall mean a modification which is reasonably expected to lead to substantially different environmental impacts which require a detailed review.
- (7) Modifications to existing permits proposed by the permittee which require substantial changes in the existing permit or require substantial evaluation by the Department of potential impacts of the proposed modifications shall require the same fee as a new application for the same time duration except for modification under Chapter 62-45, F.A.C. [Rule 62-4.050, F.A.C.]
- 3. <u>Standards for Issuing or Denying Permits</u>. Except as provided at Rule 62-213.460, F.A.C., the issuance of a permit does not relieve any person from complying with the requirements of Chapter 403, F.S., or Department rules. [Rule 62-4.070(7), F.A.C.]

4. Modification of Permit Conditions.

- (1) For good cause and after notice and an administrative hearing, if requested, the Department may require the permittee to conform to new or additional conditions. The Department shall allow the permittee a reasonable time to conform to the new or additional conditions and on application of the permittee the Department may grant additional time. For the purpose of this section, good cause shall include, but not be limited to, any of the following: (also, see Condition No. 38.).
 - (a) A showing that an improvement in effluent or emission quality or quantity can be accomplished because of technological advances without unreasonable hardship.
 - (b) A showing that a higher degree of treatment is necessary to effect the intent and purpose of Chapter 403, F.S.
 - (c) A showing of any change in the environment or surrounding conditions that requires a modification to conform to applicable air or water quality standards.
 - (e) Adoption or revision of Florida Statutes, rules, or standards which require the modification of a permit condition for compliance.
- (2) A permittee may request a modification of a permit by applying to the Department.
- (3) A permittee may request that a permit be extended as a modification of the permit. Such a request must be submitted to the Department in writing before the expiration of the permit. Upon timely submittal of a request for extension, unless the permit automatically expires by statute or rule, the permit will remain in effect until final agency action is taken on the request. For construction permits, an extension shall be granted if the applicant can demonstrate reasonable assurances that, upon completion, the extended permit will comply with the standards and conditions required by applicable regulation. For all other permits, an extension shall be granted if the applicant can demonstrate reasonable assurances that the extended permit will comply with the standards and conditions applicable to the original permit. A permit for which the permit application fee was prorated in accordance with Rule 62-4.050(4)(1), F.A.C., shall not be extended. In no event shall a permit be extended or remain in effect longer than the time limits established by statute or rule.

[Rule 62-4.080, F.A.C.]

5. Renewals. Prior to 180 days before the expiration of a permit issued pursuant to Chapter 62-213, F.A.C., the permittee shall apply for a renewal of a permit using forms incorporated by reference in the specific rule chapter for that kind of permit. A renewal application shall be timely and sufficient. If the application is submitted prior to 180 days before expiration of the permit, it will be considered timely and sufficient. If the renewal application is submitted at a later date, it will not be considered timely and sufficient unless it is submitted and made complete prior to the expiration of the operation permit. When the application for renewal is timely and sufficient, the existing permit shall remain in effect until the renewal application has been finally acted upon by the Department or, if there is court review of the Department's final agency action, until a later date is required by Section 120.60, F.S., provided that, for renewal of a permit issued pursuant to Chapter 62-213, F.A.C., the applicant complies with the requirements of Rules 62-213.420(1)(b)3. and 4., F.A.C.

[Rule 62-4.090, F.A.C.]

Suspension and Revocation.

- (1) Permits shall be effective until suspended, revoked, surrendered, or expired and shall be subject to the provisions of Chapter 403, F.S., and rules of the Department.
- (2) Failure to comply with pollution control laws and rules shall be grounds for suspension or revocation.
- (3) A permit issued pursuant to Chapter 62-4, F.A.C., shall not become a vested property right in the permittee. The Department may revoke any permit issued by it if it finds that the permit holder or the his agent:
 - (a) Submitted false or inaccurate information in his application or operational reports.
 - (b) Has violated law, Department orders, rules or permit conditions.
 - (c) Has failed to submit operational reports or other information required by Department rules.
 - (d) Has refused lawful inspection under Section 403.091, F.S.
- (4) No revocation shall become effective except after notice is served by personal services, certified mail, or newspaper notice pursuant to Section 120.60(7), F.S., upon the person or persons named therein and a hearing held if requested within the time specified in the notice. The notice shall specify the provision of the law, or rule alleged to be violated, or the permit condition or Department order alleged to be violated, and the facts alleged to constitute a violation thereof. [Rule 62-4.100, F.A.C.]

7. **Not federally enforceable.** Financial Responsibility. The Department may require an applicant to submit proof of financial responsibility and may require the applicant to post an appropriate bond to guarantee compliance with the law and Department rules. [Rule 62-4.110, F.A.C.]

Transfer of Permits.

- (1) Within 30 days after the sale or legal transfer of a permitted facility, an "Application for Transfer of Permit" (DEP Form 62-1.201(1)) must be submitted to the Department. This form must be completed with the notarized signatures of both the permittee and the proposed new permittee. For air permits, an "Application for Transfer of Air Permit" (DEP Form 62-210.900(7)) shall be submitted.
- (2) The Department shall approve the transfer of a permit unless it determines that the proposed new permittee cannot provide reasonable assurances that conditions of the permit will be met. The determination shall be limited solely to the ability of the new permittee to comply with the conditions of the existing permit, and it shall not concern the adequacy of these permit conditions. If the Department proposes to deny the transfer, it shall provide both the permittee and the proposed new permittee a written objection to such transfer together with notice of a right to request a Chapter 120, F.S., proceeding on such determination.
- (3) Within 30 days of receiving a properly completed Application for Transfer of Permit form, the Department shall issue a final determination. The Department may toll the time for making a determination on the transfer by notifying both the permittee and the proposed new permittee that additional information is required to adequately review the transfer request. Such notification shall be served within 30 days of receipt of an Application for Transfer of Permit form, completed pursuant to Rule 62-4.120(1), F.A.C. If the Department fails to take action to approve or deny the transfer within 30 days of receipt of the completed Application for Transfer of Permit form, or within 30 days of receipt of the last item of timely requested additional information, the transfer shall be deemed approved.
- (4) The permittee is encouraged to apply for a permit transfer prior to the sale or legal transfer of a permitted facility. However, the transfer shall not be effective prior to the sale or legal transfer.
- (5) Until this transfer is approved by the Department, the permittee and any other person constructing, operating, or maintaining the permitted facility shall be liable for compliance with the terms of the permit. The permittee transferring the permit shall remain liable for corrective actions that may be required as a result of any violations occurring prior to the sale or legal transfer of the facility. [Rule 62-4.120, F.A.C.]
- 9. <u>Plant Operation-Problems</u>. If the permittee is temporarily unable to comply with any of the conditions of the permit due to breakdown of equipment or destruction by hazard of fire, wind or by other cause, the permittee shall immediately notify the Department. Notification shall include pertinent information as to the cause of the problem, and what steps are being taken to correct the problem and to prevent its recurrence, and where applicable, the owner's intent toward reconstruction of destroyed facilities. Such notification does not release the permittee from any liability for failure to comply with Department rules. (also, see Condition No. 10.).

[Rule 62-4.130, F.A.C.]

- 10. For purposes of notification to the Department pursuant to Condition No. 9., Condition No. 12.(8), and Rule 62-4.130, F.A.C., Plant Operation-Problems, "immediately" shall mean the same day, if during a workday (i.e., 8:00 a.m. 5:00 p.m.), or the first business day after the incident, excluding weekends and holidays; and, for purposes of 40 CFR 70.6(a)(3)(iii)(B), "prompt" shall have the same meaning as "immediately". [also, see Conditions Nos. 9. and 12.(8).]
 [40 CFR 70.6(a)(3)(iii)(B)]
- 11. **Not federally enforceable.** Review. Failure to request a hearing within 14 days of receipt of notice of proposed or final agency action on a permit application or as otherwise required in Chapter 62-103, F.A.C., shall be deemed a waiver of the right to an administrative hearing.

[Rule 62-4.150, F.A.C.]

- 12. Permit Conditions. All permits issued by the Department shall include the following general conditions:
- (1) The terms, conditions, requirements, limitations and restrictions set forth in this permit, are "permit conditions" and are binding and enforceable pursuant to Sections 403.141, 403.727, or 403.859 through 403.861, F.S. The permittee is placed on notice that the Department will review this permit periodically and may initiate enforcement action for any violation of these conditions.
- (2) This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviation from the approved drawings, exhibits, specifications, or conditions of this permit may constitute grounds for revocation and enforcement action by the Department.
- (3) As provided in Subsections 403.087(7) and 403.722(5), F.S., the issuance of this permit does not convey any vested rights or any exclusive privileges. Neither does it authorize any injury to public or private property or any invasion of personal rights, nor any infringement of federal, state, or local laws or regulations. This permit is not a waiver of or approval of any other Department permit that may be required for other aspects of the total project which are not addressed in this permit.
- (4) This permit conveys no title to land or water, does not constitute State recognition or acknowledgment of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the State. Only the Trustees of the Internal Improvement Trust Fund may express State opinion as to title.
- (5) This permit does not relieve the permittee from liability for harm or injury to human health or welfare, animal, or plant life, or property caused by the construction or operation of this permitted source, or from penalties therefore; nor does it allow the permittee to cause pollution in contravention of F.S. and Department rules, unless specifically authorized by an order from the Department.
- (6) The permittee shall properly operate and maintain the facility and systems of treatment and control (and related appurtenances) that are installed and used by the permittee to achieve compliance with the conditions of this permit, as required by Department rules. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to achieve compliance with the conditions of the permit and when required by Department rules.
- (7) The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, upon presentation of credentials or other documents as may be required by law and at reasonable times, access to the premises where the permitted activity is located or conducted to:
 - (a) Have access to and copy any records that must be kept under conditions of the permit;
 - (b) Inspect the facility, equipment, practices, or operations regulated or required under this permit; and,
 - (c) Sample or monitor any substances or parameters at any location reasonably necessary to assure compliance with this permit or Department rules. Reasonable time may depend on the nature of the concern being investigated.
- (8) If, for any reason, the permittee does not comply with or will be unable to comply with any condition or limitation specified in this permit, the permittee shall immediately provide the Department with the following information: (also, see Condition No. 10.)
 - (a) A description of and cause of noncompliance; and,
 - (b) The period of noncompliance, including dates and times; or, if not corrected, the anticipated time the noncompliance is expected to continue, and steps being taken to reduce, eliminate, and prevent recurrence of the noncompliance. The permittee shall be responsible for any and all damages which may result and may be subject to enforcement action by the Department for penalties or for revocation of this permit.
- (9) In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the F.S. or Department rules, except where such use is prescribed by Sections 403.111 and 403.73, F.S. Such evidence shall only be used to the extent it is consistent with the Florida Rules of Civil Procedure and appropriate evidentiary rules.
- (10) The permittee agrees to comply with changes in Department rules and F.S. after a reasonable time for compliance; provided, however, the permittee does not waive any other rights granted by F.S. or Department rules.
- (11) This permit is transferable only upon Department approval in accordance with Rule 62-4.120, F.A.C., as applicable. The permittee shall be liable for any non-compliance of the permitted activity until the transfer is approved by the Department.
- (12) This permit or a copy thereof shall be kept at the work site of the permitted activity.
- (14) The permittee shall comply with the following:
 - (a) Upon request, the permittee shall furnish all records and plans required under Department rules. During enforcement actions, the retention period for all records will be extended automatically unless otherwise stipulated by the Department.
 - (b) The permittee shall hold at the facility or other location designated by this permit records of all monitoring information (including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation) required by the permit, copies of all reports required by this permit, and records of all data used to complete the application for this permit. These materials shall be retained at least five (5) years from the date of the sample, measurement, report, or application unless otherwise specified by Department rule.

- (c) Records of monitoring information shall include:
 - 1. the date, exact place, and time of sampling or measurements;
 - 2. the person responsible for performing the sampling or measurements;
 - 3. the dates analyses were performed;
 - 4. the person responsible for performing the analyses;
 - 5. the analytical techniques or methods used;
 - 6. the results of such analyses.
- (15) When requested by the Department, the permittee shall within a reasonable time furnish any information required by law which is needed to determine compliance with the permit. If the permittee becomes aware the relevant facts were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be corrected promptly. [Rules 62-4.160 and 62-213.440(1)(b), F.A.C.]

13. Construction Permits.

- (1) No person shall construct any installation or facility which will reasonably be expected to be a source of air or water pollution without first applying for and receiving a construction permit from the Department unless exempted by statute or Department rule. In addition to the requirements of Chapter 62-4, F.A.C., applicants for a Department Construction Permit shall submit the following as applicable:
 - (a) A completed application on forms furnished by the Department.
 - (b) An engineering report covering:
 - 1. plant description and operations,
 - 2. types and quantities of all waste material to be generated whether liquid, gaseous or solid,
 - 3. proposed waste control facilities,
 - 4. the treatment objectives,
 - 5. the design criteria on which the control facilities are based, and,
 - 6. other information deemed relevant.

Design criteria submitted pursuant to Rule 62-4.210(1)(b)5., F.A.C., shall be based on the results of laboratory and pilot-plant scale studies whenever such studies are warranted. The design efficiencies of the proposed waste treatment facilities and the quantities and types of pollutants in the treated effluents or emissions shall be indicated. Work of this nature shall be subject to the requirements of Chapter 471, F.S. Where confidential records are involved, certain information may be kept confidential pursuant to Section 403.111, F.S.

- (c) The owners' written guarantee to meet the design criteria as accepted by the Department and to abide by Chapter 403, F.S. and the rules of the Department as to the quantities and types of materials to be discharged from the installation. The owner may be required to post an appropriate bond or other equivalent evidence of financial responsibility to guarantee compliance with such conditions in instances where the owner's financial resources are inadequate or proposed control facilities are experimental in nature.
- (2) The construction permit may contain conditions and an expiration date as determined by the Secretary or the Secretary's designee.
- (3) When the Department issues a permit to construct, the permittee shall be allowed a period of time, specified in the permit, to construct, and to operate and test to determine compliance with Chapter 403, F.S., and the rules of the Department and, where applicable, to apply for and receive an operation permit. The Department may require tests and evaluations of the treatment facilities by the permittee at his/her expense.

[Rule 62-4.210, F.A.C.]

14. Not federally enforceable. Operation Permit for New Sources. To properly apply for an operation permit for new sources, the applicant shall submit the appropriate fee and certification that construction was completed noting any deviations from the conditions in the construction permit and test results where appropriate.

[Rule 62-4.220, F.A.C.]

Chapters 28-106 and 62-110, F.A.C.

15. <u>Public Notice, Public Participation, and Proposed Agency Action</u>. The permittee shall comply with all of the requirements for public notice, public participation, and proposed agency action pursuant to Rules 62-110.106 and 62-210.350, F.A.C. [Rules 62-110.106, 62-210.350 and 62-213.430(1)(b), F.A.C.]

16. <u>Administrative Hearing</u>. The permittee shall comply with all of the requirements for a petition for administrative hearing or waiver of right to administrative proceeding pursuant to Rules 28-106.201, 28-106.301 and 62-110.106, F.A.C. [Rules 28-106.201, 28-106.301 and 62-110.106, F.A.C.]

Chapter 62-204, F.A.C.

17. <u>Asbestos.</u> This permit does not authorize any demolition or renovation of the facility or its parts or components which involves asbestos removal. This permit does not constitute a waiver of any of the requirements of Chapter 62-257, F.A.C., and 40 CFR 61, Subpart M, National Emission Standard for Asbestos, adopted and incorporated by reference in Rule 62-204.800, F.A.C. Compliance with Chapter 62-257, F.A.C., and 40 CFR 61, Subpart M, Section 61.145, is required for any asbestos demolition or renovation at the source.

[40 CFR 61; Rule 62-204.800, F.A.C.; and, Chapter 62-257, F.A.C.]

Chapter 62-210, F.A.C.

- 18. Permits Required. The owner or operator of any emissions unit which emits or can reasonably be expected to emit any air pollutant shall obtain an appropriate permit from the Department prior to beginning construction, modification, or initial or continued operation of the emissions unit unless exempted pursuant to Department rule or statute. All emissions limitations, controls, and other requirements imposed by such permits shall be at least as stringent as any applicable limitations and requirements contained in or enforceable under the State Implementation Plan (SIP) or that are otherwise federally enforceable. Except as provided at Rule 62-213.460, F.A.C., issuance of a permit does not relieve the owner or operator of an emissions unit from complying with any applicable requirements, any emission limiting standards or other requirements of the air pollution rules of the Department or any other such requirements under federal, state, or local law.
- (1) Air Construction Permits.
 - (a) Unless exempt from permitting pursuant to Rule 62-210.300(3)(a) or (b), F.A.C., or Rule 62-4.040, F.A.C., an air construction permit shall be obtained by the owner or operator of any proposed new or modified facility or emissions unit prior to the beginning of construction or modification, in accordance with all applicable provisions of Chapter 62-210, F.A.C., Chapter 62-212, F.A.C., and Chapter 62-4, F.A.C. Except as provided under Rule 62-213.415, F.A.C., the owner or operator of any facility seeking to create or change an air emissions bubble shall obtain an air construction permit in accordance with all the applicable provisions of Chapter 62-210, F.A.C., Chapter 62-212, F.A.C., and Chapter 62-4, F.A.C. The construction permit shall be issued for a period of time sufficient to allow construction or modification of the facility or emissions unit and operation while the new or modified facility or emissions unit is conducting tests or otherwise demonstrating initial compliance with the conditions of the construction permit.
 - (b) Notwithstanding the expiration of an air construction permit, all limitations and requirements of such permit that are applicable to the design and operation of the permitted facility or emissions unit shall remain in effect until the facility or emissions unit is permanently shut down, except for any such limitation or requirement that is obsolete by its nature (such as a requirement for initial compliance testing) or any such limitation or requirement that is changed in accordance with the provisions of Rule 62-210.300(1)(b)I., F.A.C. Either the applicant or the Department can propose that certain conditions be considered obsolete. Any conditions or language in an air construction permit that are included for informational purposes only, if they are transferred to the air operation permit, shall be transferred for informational purposes only and shall not become enforceable conditions unless voluntarily agreed to by the permittee or otherwise required under Department rules.
 - 1. Except for those limitations or requirements that are obsolete, all limitations and requirements of an air construction permit shall be included and identified in any air operation permit for the facility or emissions unit. The limitations and requirements included in the air operation permit can be changed, and thereby superseded, through the issuance of an air construction permit, federally enforceable state air operation permit, federally enforceable air general permit, or Title V air operation permit; provided, however, that:
 - a. Any change that would constitute an administrative correction may be made pursuant to Rule 62-210.360, F.A.C.;
 - b. Any change that would constitute a modification, as defined at Rule 62-210.200, F.A.C., shall be accomplished only through the issuance of an air construction permit; and
 - c. Any change in a permit limitation or requirement that originates from a permit issued pursuant to 40 CFR 52.21, Rule 62-204.800(10)(d)2., F.A.C., Rule 62-212.400, F.A.C., Rule 62-212.500, F.A.C., or any former codification of Rule 62-212.400 or Rule 62-212.500, F.A.C., shall be accomplished only through the issuance of a new or revised air construction permit under Rule 62-204.800(10)(d)2., Rule 62-212.400, or Rule 62-212.500, F.A.C., as appropriate.
 - 2. The force and effect of any change in a permit limitation or requirement made in accordance with the provisions of Rule 62-210.300(1)(b)1., F.A.C., shall be the same as if such change were made to the original air construction permit.
 - 3. Nothing in Rule 62-210.300(1)(b), F.A.C., shall be construed as to allow operation of a facility or emissions unit without a valid air operation permit.

- (2) Air Operation Permits. Upon expiration of the air operation permit for any existing facility or emissions unit, subsequent to construction or modification, or subsequent to the creation of or change to a bubble, and demonstration of compliance with the conditions of the construction permit for any new or modified facility or emissions unit, any air emissions bubble, or as otherwise provided in Chapter 62-210, F.A.C., or Chapter 62-213, F.A.C., the owner or operator of such facility or emissions unit shall obtain a renewal air operation permit, an initial air operation permit or general permit, or an administrative correction or revision of an existing air operation permit, whichever is appropriate, in accordance with all applicable provisions of Chapter 62-210, F.A.C., Chapter 62-213, F.A.C., and Chapter 62-4, F.A.C.
 - (a) Minimum Requirements for All Air Operation Permits. At a minimum, a permit issued pursuant to this subsection shall:
 - 1. Specify the manner, nature, volume and frequency of the emissions permitted, and the applicable emission limiting standards or performance standards, if any;
 - 2. Require proper operation and maintenance of any pollution control equipment by qualified personnel, where applicable in accordance with the provisions of any operation and maintenance plan required by the air pollution rules of the Department.
 - 3. Contain an effective date stated in the permit which shall not be earlier than the date final action is taken on the application and be issued for a period, beginning on the effective date, as provided below.
 - a. The operation permit for an emissions unit which is in compliance with all applicable rules and in operational condition, and which the owner or operator intends to continue operating, shall be issued or renewed for a five-year period, except that, for Title V sources subject to Rule 62-213.420(1)(a)1., F.A.C., operation permits shall be extended until 60 days after the due date for submittal of the facility's Title V permit application as specified in Rule 62-213.420(1)(a)1., F.A.C.
 - b. Except as provided in Rule 62-210.300(2)(a)3.d., F.A.C., the operation permit for an emissions unit which has been shut down for six months or more prior to the expiration date of the current operation permit, shall be renewed for a period not to exceed five years from the date of shutdown, even if the emissions unit is not maintained in operational condition, provided:
 - (i) the owner or operator of the emissions unit demonstrates to the Department that the emissions unit may need to be reactivated and used, or that it is the owner's or operator's intent to apply to the Department for a permit to construct a new emissions unit at the facility before the end of the extension period; and,
 - (ii) the owner or operator of the emissions unit agrees to and is legally prohibited from providing the allowable emission permitted by the renewed permit as an emissions offset to any other person under Rule 62-212.500, F.A.C.; and,
 - (iii) the emissions unit was operating in compliance with all applicable rules as of the time the source was shut down.
 - c. Except as provided in Rule 62-210.300(2)(a)3.d., F.A.C., the operation permit for an emissions unit which has been shut down for five years or more prior to the expiration date of the current operation permit shall be renewed for a maximum period not to exceed ten years from the date of shutdown, even if the emissions unit is not maintained in operational condition, provided the conditions given in Rule 62-210.300(2)(a)3.b., F.A.C., are met and the owner or operator demonstrates to the Department that failure to renew the permit would constitute a hardship, which may include economic hardship.
 - d. The operation permit for an electric utility generating unit on cold standby or long-term reserve shutdown shall be renewed for a five-year period, and additional five-year periods, even if the unit is not maintained in operational condition, provided the conditions given in Rules 62-210.300(2)(a)3.b.(i) through (iii), F.A.C., are met.
 - 4. In the case of an emissions unit permitted pursuant to Rules 62-210.300(2)(a)3.b., c., and d., F.A.C., include reasonable notification and compliance testing requirements for reactivation of such emissions unit and provide that the owner or operator demonstrate to the Department prior to reactivation that such reactivation would not constitute reconstruction pursuant to Rule 62-204.800(7), F.A.C.

[Rules 62-210.300(1) & (2), F.A.C.]

- 19. **Not federally enforceable.** Notification of Startup. The owner or operator of any emissions unit or facility which has a valid air operation permit which has been shut down more than one year, shall notify the Department in writing of the intent to start up such emissions unit or facility, a minimum of 60 days prior to the intended startup date.
 - (a) The notification shall include information as to the startup date, anticipated emission rates or pollutants released, changes to processes or control devices which will result in changes to emission rates, and any other conditions which may differ from the valid outstanding operation permit.

(b) If, due to an emergency, a startup date is not known 60 days prior thereto, the owner shall notify the Department as soon as possible after the date of such startup is ascertained.

[Rule 62-210.300(5), F.A.C.]

20. Emissions Unit Reclassification.

- (a) Any emissions unit whose operation permit has been revoked as provided for in Chapter 62-4, F.A.C., shall be deemed permanently shut down for purposes of Rule 62-212.500, F.A.C. Any emissions unit whose permit to operate has expired without timely renewal or transfer may be deemed permanently shut down, provided, however, that no such emissions unit shall be deemed permanently shut down if, within 20 days after receipt of written notice from the Department, the emissions unit owner or operator demonstrates that the permit expiration resulted from inadvertent failure to comply with the requirements of Rule 62-4.090, F.A.C., and that the owner or operator intends to continue the emissions unit in operation, and either submits an application for an air operation permit or complies with permit transfer requirements, if applicable.
- (b) If the owner or operator of an emissions unit which is so permanently shut down, applies to the Department for a permit to reactivate or operate such emissions unit, the emissions unit will be reviewed and permitted as a new emissions unit. [Rule 62-210.300(6), F.A.C.]

21. Transfer of Air Permits.

- (a) An air permit is transferable only after submission of an Application for Transfer of Air Permit (DEP Form 62-210.900(7)) and Department approval in accordance with Rule 62-4.120, F.A.C. For Title V permit transfers only, a complete application for transfer of air permit shall include the requirements of 40 CFR 70.7(d)(1)(iv), adopted and incorporated by reference at Rule 62-204.800, F.A.C. Within 30 days after approval of the transfer of permit, the Department shall update the permit by an administrative permit correction pursuant to Rule 62-210.360, F.A.C.
- (b) For an air general permit, the provision of Rules 62-210.300(7)(a) and 62-4.120, F.A.C., do not apply. Thirty (30) days before using an air general permit, the new owner must submit an air general permit notification to the Department in accordance with Rule 62-210.300(4), F.A.C., or Rule 62-213.300(2)(b), F.A.C.

[Rule 62-210.300(7), F.A.C.]

22. Public Notice and Comment.

- (1) Public Notice of Proposed Agency Action.
 - (a) A notice of proposed agency action on permit application, where the proposed agency action is to issue the permit, shall be published by any applicant for:
 - 1. An air construction permit;
 - 2. An air operation permit, permit renewal or permit revision subject to Rule 62-210.300(2)(b), F.A.C., (i.e., a FESOP), except as provided in Rule 62-210.300(2)(b)1.b., F.A.C.; or
 - 3. An air operation permit, permit renewal, or permit revision subject to Chapter 62-213, F.A.C., except Title V air general permits or those permit revisions meeting the requirements of Rule 62-213.412(1), F.A.C.
 - (b) The notice required by Rule 62-210.350(1)(a), F.A.C., shall be published in accordance with all otherwise applicable provisions of Rule 62-110.106, F.A.C. A public notice under Rule 62-210.350(1)(a)1., F.A.C., for an air construction permit may be combined with any required public notice under Rule 62-210.350(1)(a)2. or 3., F.A.C., for air operation permits. If such notices are combined, the public notice must comply with the requirements for both notices.
 - (c) Except as otherwise provided at Rules 62-210.350(2) and (5), F.A.C., each notice of intent to issue an air construction permit shall provide a 14-day period for submittal of public comments.
- (2) Additional Public Notice Requirements for Emissions Units Subject to Prevention of Significant Deterioration or Nonattainment Area Preconstruction Review.
 - (a) Before taking final agency action on a construction permit application for any proposed new or modified facility or emissions unit subject to the preconstruction review requirements of Rule 62-212.400 or 62-212.500, F.A.C., the Department shall comply with all applicable provisions of Rule 62-110.106, F.A.C., and provide an opportunity for public comment which shall include as a minimum the following:
 - 1. A complete file available for public inspection in at least one location in the district affected which includes the information submitted by the owner or operator, exclusive of confidential records under Section 403.111, F.S., and the Department's analysis of the effect of the proposed construction or modification on ambient air quality, including the Department's preliminary determination of whether the permit should be approved or disapproved;
 - 2. A 30-day period for submittal of public comments; and,

- 3. A notice, by advertisement in a newspaper of general circulation in the county affected, specifying the nature and location of the proposed facility or emissions unit, whether BACT or LAER has been determined, the degree of PSD increment consumption expected, if applicable, and the location of the information specified in paragraph 1. above; and, notifying the public of the opportunity for submitting comments and requesting a public hearing.
- (b) The notice provided for in Rule 62-210.350(2)(a)3., F.A.C., shall be prepared by the Department and published by the applicant in accordance with all applicable provisions of Rule 62-110.106, F.A.C., except that the applicant shall cause the notice to be published no later than thirty (30) days prior to final agency action.
- (c) A copy of the notice provided for in Rule 62-210.350(2)(a)3., F.A.C., shall also be sent by the Department to the Regional Office of the U. S. Environmental Protection Agency and to all other state and local officials or agencies having cognizance over the location of such new or modified facility or emissions unit, including local air pollution control agencies, chief executives of city or county government, regional land use planning agencies, and any other state, Federal Land Manager, or Indian Governing Body whose lands may be affected by emissions from the new or modified facility or emissions unit.
- (d) A copy of the notice provided for in Rule 62-210.350(2)(a)3., F.A.C., shall be displayed in the appropriate district, branch and local program offices.
- (e) An opportunity for public hearing shall be provided in accordance with Chapter 120, F.S., and Rule 62-110.106, F.A.C.
- (f) Any public comments received shall be made available for public inspection in the location where the information specified in Rule 62-210.350(2)(a)1., F.A.C., is available and shall be considered by the Department in making a final determination to approve or deny the permit.
- (g) The final determination shall be made available for public inspection at the same location where the information specified in Rule 62-210.350(2)(a)1., F.A.C., was made available.
- (h) For a proposed new or modified emissions unit which would be located within 100 kilometers of any Federal Class I area or whose emissions may affect any Federal Class I area, and which would be subject to the preconstruction review requirements of Rule 62-212.400, F.A.C., or Rule 62-212.500, F.A.C.:
 - 1. The Department shall mail or transmit to the Administrator a copy of the initial application for an air construction permit and notice of every action related to the consideration of the permit application.
 - 2. The Department shall mail or transmit to the Federal Land Manager of each affected Class I area a copy of any written notice of intent to apply for an air construction permit; the initial application for an air construction permit, including all required analyses and demonstrations; any subsequently submitted information related to the application; the preliminary determination and notice of proposed agency action on the permit application; and any petition for an administrative hearing regarding the application or the Department's proposed action. Each such document shall be mailed or transmitted to the Federal Land Manager within fourteen (14) days after its receipt by the Department.
- (3) Additional Public Notice Requirements for Facilities Subject to Operation Permits for Title V Sources.
 - (a) Before taking final agency action to issue a new, renewed, or revised air operation permit subject to Chapter 62-213, F.A.C., the Department shall comply with all applicable provisions of Rule 62-110.106, F.A.C., and provide an opportunity for public comment which shall include as a minimum the following:
 - 1. A complete file available for public inspection in at least one location in the district affected which includes the information submitted by the owner or operator, exclusive of confidential records under Section 403.111, F.S.; and,
 - 2. A 30-day period for submittal of public comments.
 - (b) The notice provided for in Rule 62-210.350(3)(a), F.A.C., shall be prepared by the Department and published by the applicant in accordance with all applicable provisions of Rule 62-110.106, F.A.C., except that the applicant shall cause the notice to be published no later than thirty (30) days prior to final agency action. If written comments received during the 30-day comment period on a draft permit result in the Department's issuance of a revised draft permit in accordance with Rule 62-213.430(1), F.A.C., the Department shall require the applicant to publish another public notice in accordance with Rule 62-210.350(1)(a), F.A.C.
 - (c) The notice shall identify:
 - 1. The facility;
 - 2. The name and address of the office at which processing of the permit occurs;
 - 3. The activity or activities involved in the permit action;
 - 4. The emissions change involved in any permit revision;
 - 5. The name, address, and telephone number of a Department representative from whom interested persons may obtain additional information, including copies of the permit draft, the application, and all relevant supporting materials, including any permit application, compliance plan, permit, monitoring report, and compliance statement required pursuant to Chapter 62-213, F.A.C. (except for information entitled to confidential treatment pursuant to Section 403.111, F.S.), and all other materials available to the Department that are relevant to the permit decision;

- 6. A brief description of the comment procedures required by Rule 62-210.350(3), F.A.C.;
- 7. The time and place of any hearing that may be held, including a statement of procedure to request a hearing (unless a hearing has already been scheduled); and,
- 8. The procedures by which persons may petition the Administrator to object to the issuance of the proposed permit after expiration of the Administrator's 45-day review period.

[Rule 62-210.350, F.A.C.]

23. Administrative Permit Corrections.

- (1) A facility owner shall notify the Department by letter of minor corrections to information contained in a permit. Such notifications shall include:
 - (a) Typographical errors noted in the permit;
 - (b) Name, address or phone number change from that in the permit;
 - (c) A change requiring more frequent monitoring or reporting by the permittee;
 - (d) A change in ownership or operational control of a facility, subject to the following provisions:
 - 1. The Department determines that no other change in the permit is necessary;
 - 2. The permittee and proposed new permittee have submitted an Application for Transfer of Air Permit, and the Department has approved the transfer pursuant to Rule 62-210.300(7), F.A.C.; and
 - 3. The new permittee has notified the Department of the effective date of sale or legal transfer.
 - (e) Changes listed at 40 CFR 72.83(a)(1), (2), (6), (9) and (10), adopted and incorporated by reference at Rule 62-204.800, F.A.C., and changes made pursuant to Rules 62-214.340(1) and (2), F.A.C., to Title V sources subject to emissions limitations or reductions pursuant to 42 USC ss. 7651-76510;
 - (f) Changes listed at 40 CFR 72.83(a)(11) and (12), adopted and incorporated by reference at Rule 62-204.800, F.A.C., to Title V sources subject to emissions limitations or reductions pursuant to 42 USC ss. 7651-76510, provided the notification is accompanied by a copy of any EPA determination concerning the similarity of the change to those listed at Rule 62-210.360(1)(e), F.A.C.; and,
 - (g) Any other similar minor administrative change at the source.
- (2) Upon receipt of any such notification the Department shall within 60 days correct the permit and provide a corrected copy to the owner.
- (3) After first notifying the owner, the Department shall correct any permit in which it discovers errors of the types listed at Rules 62-210.360(1)(a) and (b), F.A.C., and provide a corrected copy to the owner.
- (4) For Title V source permits, other than general permits, a copy of the corrected permit shall be provided to EPA and any approved local air program in the county where the facility or any part of the facility is located.
- (5) The Department shall incorporate requirements resulting from issuance of a new or revised construction permit into an existing Title V source permit, if the construction permit revision incorporates requirements of federally enforceable preconstruction review, and if the applicant requests at the time of application that all of the requirements of Rule 62-213.430(1), F.A.C., be complied with in conjunction with the processing of the construction permit application.

[Rule 62-210.360, F.A.C.]

24. Reports

- (3) Annual Operating Report for Air Pollutant Emitting Facility.
 - (a) The Annual Operating Report for Air Pollutant Emitting Facility (DEP Form No. 62-210.900(5)) shall be completed each year.
 - (c) The annual operating report shall be submitted to the appropriate Department District or Department approved local air pollution control program office by March 1 of the following year unless otherwise indicated by permit condition or Department request.

[Rule 62-210.370(3), F.A.C.]

25. <u>Circumvention</u>. No person shall circumvent any air pollution control device, or allow the emission of air pollutants without the applicable air pollution control device operating properly.

[Rule 62-210.650, F.A.C.]

- 26. Forms and Instructions. The forms used by the Department in the stationary source control program are adopted and incorporated by reference in this section. The forms are listed by rule number, which is also the form number, with the subject, title and effective date. Forms 62-210.900(1),(3),(4) and (5), F.A.C., including instructions, are available from the Department as hard-copy documents or executable files on computer diskettes. Copies of forms (hard-copy or diskette) may be obtained by writing to the Department of Environmental Protection, Division of Air Resource Management, 2600 Blair Stone Road, Tallahassee, Florida 32399-2400. Notwithstanding the requirement of Rule 62-4.050(2), F.A.C., to file application forms in quadruplicate, if an air permit application is submitted using the Department's electronic application form, only one copy of the diskette and signature pages is required to be submitted.
- (1) Application for Air Permit Title V Source, Form and Instructions (Effective 02/11/1999).
 - (a) Acid Rain Part (Phase II), Form and Instructions (Effective 04/16/2001).
 - 1. Repowering Extension Plan, Form and Instructions (Effective 07/01/1995).
 - 2. New Unit Exemption, Form and Instructions (Effective 04/16/2001).
 - 3. Retired Unit Exemption, Form and Instructions (Effective 04/16/2001)
 - 4. Phase II NOx Compliance Plan, Form and Instructions (Effective 01/06/1998).
 - 5. Phase II NOx Averaging Plan, Form (Effective 01/06/1998).
 - (b) Reserved.
- (5) Annual Operating Report for Air Pollutant Emitting Facility, Form and Instructions (Effective 02/11/1999).
- (7) Application for Transfer of Air Permit Title V and Non-Title V Source, (Effective 04/16/2001).

[Rule 62-210.900, F.A.C.]

Chapter 62-213, F.A.C.

27. Annual Emissions Fee. Each Title V source permitted to operate in Florida must pay between January 15 and March 1 of each year, upon written notice from the Department, an annual emissions fee in an amount determined as set forth in Rule 62-213.205(1), F.A.C.

[Rules 62-213.205 and 62-213.900(1), F.A.C.]

28. <u>Annual Emissions Fee</u>. Failure to pay timely any required annual emissions fee, penalty, or interest constitutes grounds for permit revocation pursuant to Rule 62-4.100, F.A.C.

[Rule 62-213.205(1)(g), F.A.C.]

29. <u>Annual Emissions Fee</u>. Any documentation of actual hours of operation, actual material or heat input, actual production amount, or actual emissions used to calculate the annual emissions fee shall be retained by the owner for a minimum of five (5) years and shall be made available to the Department upon request.

[Rule 62-213.205(1)(i), F.A.C.]

- 30. <u>Annual Emissions Fee</u>. A completed DEP Form 62-213.900(1), F.A.C., "Major Air Pollution Source Annual Emissions Fee Form", must be submitted by the responsible official with the annual emissions fee. [Rule 62-213.205(1)(j), F.A.C.]
- 31. <u>Air Operation Permit Fees</u>. No permit application processing fee, renewal fee, modification fee or amendment fee is required for an operation permit for a Title V source.

[Rule 62-213.205(4), F.A.C.]

- 32. Permits and Permit Revisions Required. All Title V sources are subject to the permit requirements of Chapter 62-213, F.A.C.
- (1) No Title V source may operate except in compliance with Chapter 62-213, F.A.C.
- (2) Except as provided in Rule 62-213.410, F.A.C., no source with a permit issued under the provisions of this chapter shall make any changes in its operation without first applying for and receiving a permit revision if the change meets any of the following:
 - (a) Constitutes a modification;
 - (b) Violates any applicable requirement;
 - (c) Exceeds the allowable emissions of any air pollutant from any unit within the source;
 - (d) Contravenes any permit term or condition for monitoring, testing, recordkeeping, reporting or of a compliance certification requirement;
 - (e) Requires a case-by-case determination of an emission limitation or other standard or a source specific determination of ambient impacts, or a visibility or increment analysis under the provisions of Chapters 62-212 or 62-296, F.A.C.;
 - (f) Violates a permit term or condition which the source has assumed for which there is no corresponding underlying applicable requirement to which the source would otherwise be subject;
 - (g) Results in the trading of emissions among units within a source except as specifically authorized pursuant to Rule 62-213.415, F.A.C.;

- (h) Results in the change of location of any relocatable facility identified as a Title V source pursuant to paragraph (a)-(e), (g) or (h) of the definition of "major source of air pollution" at Rule 62-210.200, F.A.C.;
- (i) Constitutes a change at an Acid Rain Source under the provisions of 40 CFR 72.81(a)(1),(2),or (3),(b)(1) or (b)(3), hereby incorporated by reference;
- (j) Constitutes a change in a repowering plan, nitrogen oxides averaging plan, or nitrogen oxides compliance deadline extension at an Acid Rain Source;
- (k) Is a request for industrial-utility unit exemption pursuant to Rule 62-214.340, F.A.C. [Rules 62-213.400(1) & (2), F.A.C.]
- 33. <u>Changes Without Permit Revision</u>. Title V sources having a valid permit issued pursuant to Chapter 62-213, F.A.C., may make the following changes without permit revision, provided that sources shall maintain source logs or records to verify periods of operation in each alternative method of operation:
- (1) Permitted sources may change among those alternative methods of operation allowed by the source's permit as provided by the terms of the permit;
- (2) Permitted sources may implement the terms or conditions of a new or revised construction permit if;
 - (a) The application for construction permit complied with the requirements of Rule 62-213.420(3) and (4), F.A.C.;
 - (b) The terms or conditions were subject to federally enforceable preconstruction review pursuant to Chapter 62-212, F.A.C.; and.
 - (c) The new or revised construction permit was issued after the Department and the applicant complied with all the requirements of Rule 62-213.430(1), F.A.C.;
- (3) A permitted source may implement operating changes, as defined in Rule 62-210.200, F.A.C., after the source submits any forms required by any applicable requirement and provides the Department and EPA with at least 7 days written notice prior to implementation. The source and the Department shall attach each notice to the relevant permit;
 - (a) The written notice shall include the date on which the change will occur, and a description of the change within the permitted source, the pollutants emitted and any change in emissions, and any term or condition becoming applicable or no longer applicable as a result of the change;
 - (b) The permit shield described in Rule 62-213.460, F.A.C., shall not apply to such changes;
- (4) Permitted sources may implement changes involving modes of operation only in accordance with Rule 62-213.415, F.A.C. [Rule 62-213.410, F.A.C.]
- 34. Immediate Implementation Pending Revision Process.
- (1) Those permitted Title V sources making any change that constitutes a modification pursuant to the definition of modification at Rule 62-210.200, F.A.C., but which would not constitute a modification pursuant to 42 USC 7412(a) or to 40 CFR 52.01, 60.2, or 61.15, adopted and incorporated by reference at Rule 62-204.800, F.A.C., may implement such change prior to final issuance of a permit revision in accordance with this section, provided the change:
 - (a) Does not violate any applicable requirement;
 - (b) Does not contravene any permit term or condition for monitoring, testing, recordkeeping or reporting, or any compliance certification requirement;
 - (c) Does not require or change a case-by-case determination of an emission limitation or other standard, or a source-specific determination of ambient impacts, or a visibility or increment analysis under the provisions of Chapter 62-212 or 62-296, F.A.C.;
 - (d) Does not seek to establish or change a permit term or condition for which there is no corresponding underlying applicable requirement and which the source has assumed to avoid an applicable requirement to which the source would otherwise be subject including any federally enforceable emissions cap or federally enforceable alternative emissions limit.
- (2) A Title V source may immediately implement such changes after they have been incorporated into the terms and conditions of a new or revised construction permit issued pursuant to Chapter 62-212, F.A.C., and after the source provides to EPA, the Department, each affected state and any approved local air program having geographic jurisdiction over the source, a copy of the source's application for operation permit revision. The Title V source may conform its application for construction permit to include all information required by Rule 62-213.420, F.A.C., in lieu of submitting separate application forms.

- (3) The Department shall process the application for operation permit revision in accordance with the provisions of Chapter 62-213, F.A.C., except that the Department shall issue a draft permit revision or a determination to deny the revision within 60 days of receipt of a complete application for operation permit revision or, if the Title V source has submitted a construction permit application conforming to the requirements of Rule 62-213.420, F.A.C., the Department shall issue a draft permit or a determination to deny the revision at the same time the Department issues its determination on issuance or denial of the construction permit application. The Department shall not take final action until all the requirements of Rules 62-213.430(1)(a), (c), (d), and (e), F.A.C., have been complied with.
- (4) Pending final action on the operation permit revision application, the source shall implement the changes in accordance with the terms and conditions of the source's new or revised construction permit.
- (5) The permit shield described in Rule 62-213.460, F.A.C., shall not apply to such changes until after the Department takes final action to issue the operation permit revision.
- (6) If the Department denies the source's application for operation permit revision, the source shall cease implementation of the proposed changes.

[Rule 62-213.412, F.A.C.]

35. Permit Applications.

- (1) Duty to Apply. For each Title V source, the owner or operator shall submit a timely and complete permit application in compliance with the requirements of Rules 62-213.420, F.A.C., and Rules 62-4.050(1) through (3), F.A.C.
 - (a) Timely Application.
 - 3. For purposes of permit renewal, a timely application is one that is submitted in accordance with Rule 62-4.090, F.A.C.
 - (b) Complete Application.
 - 1. Any applicant for a Title V permit, permit revision or permit renewal must submit an application on DEP Form No. 62-210.900(1), which must include all the information specified by Rule 62-213.420(3), F.A.C., except that an application for permit revision must contain only that information related to the proposed change. The applicant shall include information concerning fugitive emissions and stack emissions in the application. Each application for permit revision or permit renewal shall be certified by a responsible official in accordance with Rule 62-213.420(4), F.A.C.
 - 2. For those applicants submitting initial permit applications pursuant to Rule 62-213.420(1)(a)1., F.A.C., a complete application shall be an application that substantially addresses all the information required by the application form number 62-210.900(1), and such applications shall be deemed complete within sixty days of receipt of a signed and certified application unless the Department notifies the applicant of incompleteness within that time. For all other applicants, the applications shall be deemed complete sixty days after receipt, unless the Department, within sixty days after receipt of a signed application for permit, permit revision or permit renewal, requests additional documentation or information needed to process the application. An applicant making timely and complete application for permit, or timely application for permit renewal as described by Rule 62-4.090(1), F.A.C., shall continue to operate the source under the authority and provisions of any existing valid permit or Florida Electrical Power Plant Siting Certification, and in accordance with applicable requirements of the Acid Rain Program, until the conclusion of proceedings associated with its permit application or until the new permit becomes effective, whichever is later, provided the applicant complies with all the provisions of Rules 62-213.420(1)(b)3. and 4. F.A.C. Failure of the Department to request additional information within sixty days of receipt of a properly signed application shall not impair the Department's ability to request additional information pursuant to Rules 62-213.420(1)(b)3. and 4. F.A.C.
 - 3. For those permit applications submitted pursuant to the provisions of Rule 62-213.420(1)(a)1., F.A.C., the Department shall notify the applicant if the Department becomes aware at any time during processing of the application that the application contains incorrect or incomplete information. The applicant shall submit the corrected or supplementary information to the Department within ninety days unless the applicant has requested and been granted additional time to submit the information. Failure of an applicant to submit corrected or supplementary information requested by the Department within ninety days or such additional time as requested and granted shall render the application incomplete.
 - 4. For all applications other than those addressed at Rule 62-213.420(1)(b)3., F.A.C., should the Department become aware, during processing of any application that the application contains incorrect information, or should the Department become aware, as a result of comment from an affected State, an approved local air program, EPA, or the public that additional information is needed to evaluate the application, the Department shall notify the applicant within 30 days. When an applicant becomes aware that an application contains incorrect or incomplete information, the applicant shall submit the corrected or supplementary information to the Department. If the Department notifies an applicant that corrected or supplementary information is necessary to process the permit, and requests a response, the applicant shall provide the information to the Department within ninety days of the Department request unless the applicant has requested

and been granted additional time to submit the information or, the applicant shall, within ninety days, submit a written request that the Department process the application without the information. Failure of an applicant to submit corrected or supplementary information requested by the Department within ninety days, or such additional time as requested and granted, or to demand in writing within ninety days that the application be processed without the information shall render the application incomplete. Nothing in this section shall limit any other remedies available to the Department.

[Rules 62-213.420(1)(a)3. and 62-213.420(1)(b)1., 2., 3. & 4., F.A.C.]

- 36. <u>Confidential Information</u>. Whenever an applicant submits information under a claim of confidentiality pursuant to Section 403.111, F.S., the applicant shall also submit a copy of all such information and claim directly to EPA. (also, see Condition No. 50.) [Rule 62-213.420(2), F.A.C.]
- 37. Standard Application Form and Required Information. Applications shall be submitted under Chapter 62-213, F.A.C., on forms provided by the Department and adopted by reference in Rule 62-210.900(1), F.A.C. The information as described in Rule 62-210.900(1), F.A.C., shall be included for the Title V source and each emissions unit. An application must include information sufficient to determine all applicable requirements for the Title V source and each emissions unit and to evaluate a fee amount pursuant to Rule 62-213.205, F.A.C.
 [Rule 62-213.420(3), F.A.C.]
- 38. a. <u>Permit Renewal and Expiration</u>. Permits being renewed are subject to the same requirements that apply to permit issuance at the time of application for renewal. Permit renewal applications shall contain that information identified in Rules 62-210.900(1) and 62-213.420(3), F.A.C. Unless a Title V source submits a timely application for permit renewal in accordance with the requirements of Rule 62-4.090(1), F.A.C., the existing permit shall expire and the source's right to operate shall terminate. No Title V permit will be issued for a new term except through the renewal process.
- b. <u>Permit Revision Procedures.</u> Permit revisions shall meet all requirements of Chapter 62-213, F.A.C., including those for content of applications, public participation, review by approved local programs and affected states, and review by EPA, as they apply to permit issuance and permit renewal, except that permit revisions for those activities implemented pursuant to Rule 62-213.412, F.A.C., need not meet the requirements of Rule 62-213.430(1)(b), F.A.C. The Department shall require permit revision in accordance with the provisions of Rule 62-4.080, F.A.C., and 40 CFR 70.7(f), whenever any source becomes subject to any condition listed at 40 CFR 70.7(f)(1), hereby adopted and incorporated by reference. The below requirements from 40 CFR 70.7(f) are adopted and incorporated by reference in Rule 62-213.430(4), F.A.C.:
 - o 40 CFR 70.7(f): Reopening for Cause. (also, see Condition No. 4.)
 - (1) This section contains provisions from 40 CFR 70.7(f) that specify the conditions under which a Title V permit shall be reopened prior to the expiration of the permit. A Title V permit shall be reopened and revised under any of the following circumstances:
 - (i) Additional applicable requirements under the Act become applicable to a major Part 70 source with a remaining permit term of 3 or more years. Such a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which the permit is due to expire, unless the original permit or any of its terms and conditions has been extended pursuant to 40 CFR 70.4(b)(10)(i) or (ii).
 - (ii) Additional requirements (including excess emissions requirements) become applicable to an affected source under the acid rain program. Upon approved by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.
 - (iii) The permitting authority or EPA determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.
 - (iv) The Administrator or the permitting authority determines that the permit must be revised or revoked to assure compliance with the applicable requirements.
 - (2) Proceedings to reopen and issue a permit shall follow the same procedures as apply to initial permit issuance and shall affect only those parts of the permit for which cause to reopen exists. Such reopening shall be made as expeditiously as practicable.
 - (3) Reopenings under 40 CFR 70.7(f)(1) shall not be initiated before a notice of such intent is provided to the Part 70 source by the permitting authority at least 30 days in advance of the date that the permit is to be reopened, except that the permitting authority may provide a shorter time period in the case of an emergency.

[Rules 62-213.430(3) & (4), F.A.C.; and, 40 CFR 70.7(f)]

39. <u>Insignificant Emissions Units or Pollutant-Emitting Activities.</u>

- (a) All requests for determination of insignificant emissions units or activities made pursuant to Rule 62-213.420(3)(m), F.A.C., shall be processed in conjunction with the permit, permit renewal or permit revision application submitted pursuant to Chapter 62-213, F.A.C. Insignificant emissions units or activities shall be approved by the Department consistent with the provisions of Rule 62-4.040(1)(b), F.A.C. Emissions units or activities which are added to a Title V source after issuance of a permit under Chapter 62-213, F.A.C., shall be incorporated into the permit at its next renewal, provided such emissions units or activities have been exempted from the requirement to obtain an air construction permit and also qualify as insignificant pursuant to Rule 62-213.430(6), F.A.C. (b) An emissions unit or activity shall be considered insignificant if all of the following criteria are met:
 - 1. Such unit or activity would be subject to no unit-specific applicable requirement;
 - 2. Such unit or activity, in combination with other units or activities proposed as insignificant, would not cause the facility to exceed any major source threshold(s) as defined in Rule 62-213.420(3)(c)1., F.A.C., unless it is acknowledged in the permit application that such units or activities would cause the facility to exceed such threshold(s);
 - 3. Such unit or activity would not emit or have the potential to emit:
 - a. 500 pounds per year or more of lead and lead compounds expressed as lead;
 - b. 1,000 pounds per year or more of any hazardous air pollutant;
 - c. 2,500 pounds per year or more of total hazardous air pollutants; or
 - d. 5.0 tons per year or more of any other regulated pollutant.

[Rule 62-213.430(6), F.A.C.]

- 40. <u>Permit Duration</u>. Permits for sources subject to the Federal Acid Rain Program shall be issued for terms of five years, provided that the initial Acid Rain Part may be issued for a term less than five years where necessary to coordinate the term of such part with the term of a Title V permit to be issued to the source. Operation permits for Title V sources may not be extended as provided in Rule 62-4.080(3), F.A.C., if such extension will result in a permit term greater than five years. [Rule 62-213.440(1)(a), F.A.C.]
- 41. <u>Monitoring Information</u>. All records of monitoring information shall specify the date, place, and time of sampling or measurement and the operating conditions at the time of sampling or measurement, the date(s) analyses were performed, the company or entity that performed the analyses, the analytical techniques or methods used, and the results of such analyses.

 [Rule 62-213.440(1)(b)2.a., F.A.C.]
- 42. <u>Retention of Records.</u> Retention of records of all monitoring data and support information shall be for a period of at least 5 years from the date of the monitoring sample, measurement, report, or application. Support information includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.

[Rule 62-213.440(1)(b)2.b., F.A.C.]

- 43. <u>Monitoring Reports</u>. The permittee shall submit reports of any required monitoring at least every six (6) months. All instances of deviations from permit requirements must be clearly identified in such reports.

 [Rule 62-213.440(1)(b)3.a., F.A.C.]
- 44. <u>Deviation from Permit Requirements Reports</u>. The permittee shall report in accordance with the requirements of Rules 62-210.700(6) and 62-4.130, F.A.C., deviations from permit requirements, including those attributable to upset conditions as defined in the permit. Reports shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. [Rule 62-213.440(1)(b)3.b., F.A.C.]
- 45. Reports. All reports shall be accompanied by a certification by a responsible official, pursuant to Rule 62-213.420(4), F.A.C. [Rule 62-213.440(1)(b)3.c, F.A.C.]

- 46. If any portion of the final permit is invalidated, the remainder of the permit shall remain in effect. [Rule 62-213.440(1)(d)1., F.A.C.]
- 47. It shall not be a defense for a permittee in an enforcement action that maintaining compliance with any permit condition would necessitate halting of or reduction of the source activity.

[Rule 62-213.440(1)(d)3., F.A.C.]

- 48. Any Title V source shall comply with all the terms and conditions of the existing permit until the Department has taken final action on any permit renewal or any requested permit revision, except as provided at Rule 62-213.412(2), F.A.C. [Rule 62-213.440(1)(d)4., F.A.C.]
- 49. A situation arising from sudden and unforeseeable events beyond the control of the source which causes an exceedance of a technology-based emissions limitation because of unavoidable increases in emissions attributable to the situation and which requires immediate corrective action to restore normal operation, shall be an affirmative defense to an enforcement action in accordance with the provisions and requirements of 40 CFR 70.6(g)(2) and (3), hereby adopted and incorporated by reference.

 [Rule 62-213.440(1)(d)5., F.A.C.]
- 50. <u>Confidentiality Claims.</u> Any permittee may claim confidentiality of any data or other information by complying with Rule 62-213.420(2), F.A.C. (also, see Condition No. 36.). [Rule 62-213.440(1)(d)6., F.A.C.]
- 51. <u>Statement of Compliance</u>. (a)2. The permittee shall submit a Statement of Compliance with all terms and conditions of the permit using DEP Form No. 62-213.900(7). Such statement shall be accompanied by a certification in accordance with Rule 62-213.420(4), F.A.C. Such statements shall be submitted (postmarked) to the Department and EPA:
 - a. Annually, within 60 days after the end of each calendar year during which the Title V permit was effective, or more frequently if specified by Rule 62-213.440(2), F.A.C., or by any other applicable requirement; and b. Within 60 days after submittal of a written agreement for transfer of responsibility as required pursuant to 40 CFR 70.7(d)(1)(iv), adopted and incorporated by reference at Rule 62-204.800, F.A.C., or within 60 days after permanent shutdown of a facility permitted under Chapter 62-213, F.A.C.; provided that, in either such case, the reporting period shall be the portion of the calendar year the permit was effective up to the date of transfer of responsibility or permanent facility shutdown, as
- 3. The statement of compliance status shall include all the provisions of 40 CFR 70.6(c)(5)(iii), incorporated by reference at Rule 62-204.800, F.A.C.
- (b) The responsible official may treat compliance with all other applicable requirements as a surrogate for compliance with Rule 62-296.320(2), Objectionable Odor Prohibited.

[Rules 62-213.440(3)(a)2. & 3. and (b), F.A.C.]

52. <u>Permit Shield</u>. Except as provided in Chapter 62-213, F.A.C., compliance with the terms and conditions of a permit issued pursuant to Chapter 62-213, F.A.C., shall, as of the effective date of the permit, be deemed compliance with any applicable requirements in effect, provided that the source included such applicable requirements in the permit application. Nothing in Rule 62-213.460, F.A.C., or in any permit shall alter or affect the ability of EPA or the Department to deal with an emergency, the liability of an owner or operator of a source for any violation of applicable requirements prior to or at the time of permit issuance, or the requirements of the Federal Acid Rain Program.

[Rule 62-213.460, F.A.C.]

- 53. Forms and Instructions. The forms used by the Department in the Title V source operation program are adopted and incorporated by reference in Rule 62-213.900, F.A.C. The form is listed by rule number, which is also the form number, and with the subject, title, and effective date. Copies of forms may be obtained by writing to the Department of Environmental Protection, Division of Air Resources Management, 2600 Blair Stone Road, Tallahassee, Florida 32399-2400, or by contacting the appropriate permitting authority.
- (1) Major Air Pollution Source Annual Emissions Fee Form. (Effective 01/03/2001)
- (7) Statement of Compliance Form. (Effective 01/03/2001)

[Rule 62-213.900, F.A.C.: Forms (1) and (7)]

Chapter 62-256, F.A.C.

54. Not federally enforceable. Open Burning. This permit does not authorize any open burning nor does it constitute any waiver of the requirements of Chapter 62-256, F.A.C. Source shall comply with Chapter 62-256, F.A.C., for any open burning at the source. [Chapter 62-256, F.A.C.]

Chapter 62-281, F.A.C.

- 55. <u>Refrigerant Requirements</u>. Any facility having refrigeration equipment, including air conditioning equipment, which uses a Class I or II substance (listed at 40 CFR 82, Subpart A, Appendices A and B), and any facility which maintains, services, or repairs motor vehicles using a Class I or Class II substance as refrigerant must comply with all requirements of 40 CFR 82, Subparts B and F, and with Rule 62-281.100, F.A.C. Those requirements include the following restrictions:
- (1) Any facility having any refrigeration equipment normally containing 50 (fifty) pounds of refrigerant, or more, must keep servicing records documenting the date and type of all service and the quantity of any refrigerant added pursuant to 40 CFR 82.166;
- (2) No person repairing or servicing a motor vehicle may perform any service on a motor vehicle air conditioner (MVAC) involving the refrigerant for such air conditioner unless the person has been properly trained and certified as provided at 40 CFR 82.34 and 40 CFR 82.40, and properly uses equipment approved pursuant to 40 CFR 82.36 and 40 CFR 82.38, and complies with 40 CFR 82.42;
- (3) No person may sell or distribute, or offer for sale or distribution, any substance listed as a Class I or Class II substance at 40 CFR 82, Subpart A, Appendices A and B, except in compliance with Rule 62-281.100, F.A.C., and 40 CFR 82.34(b), 40 CFR 82.42, and/or 40 CFR 82.166;
- (4) No person maintaining, servicing, repairing, or disposing of appliances may knowingly vent or otherwise release into the atmosphere any Class I or Class II substance used as a refrigerant in such equipment and no other person may open appliances (except MVACs as defined at 40 CFR 82.152) for service, maintenance or repair unless the person has been properly trained and certified pursuant to 40 CFR 82.161 and unless the person uses equipment certified for that type of appliance pursuant to 40 CFR 82.158 and unless the person observes the practices set forth at 40 CFR 82.156 and 40 CFR 82.166;
- (5) No person may dispose of appliances (except small appliances, as defined at 40 CFR 82.152) without using equipment certified for that type of appliance pursuant to 40 CFR 82.158 and without observing the practices set forth at 40 CFR 82.156 and 40 CFR 82.166;
- (6) No person may recover refrigerant from small appliances, MVACs and MVAC-like appliances (as defined at 40 CFR 82.152), except in compliance with the requirements of 40 CFR 82, Subpart F.

[40 CFR 82; and, Chapter 62-281, F.A.C. (Chapter 62-281, F.A.C., is not federally enforceable)]

Chapter 62-296, F.A.C.

- 56. <u>Industrial, Commercial, and Municipal Open Burning Prohibited</u>. Open burning in connection with industrial, commercial, or municipal operations is prohibited, except when:
 - (a) Open burning is determined by the Department to be the only feasible method of operation and is authorized by an air permit issued pursuant to Chapter 62-210 or 62-213, F.A.C.; or,
 - (b) An emergency exists which requires immediate action to protect human health and safety; or,
 - (c) A county or municipality would use a portable air curtain incinerator to burn yard trash generated by a hurricane, tornado, fire or other disaster and the air curtain incinerator would otherwise be operated in accordance with the permitting exemption criteria of Rule 62-210.300(3), F.A.C.

[Rule 62-296.320(3), F.A.C.]

57. <u>Unconfined Emissions of Particulate Matter</u>.

(4)(c)1. No person shall cause, let, permit, suffer or allow the emissions of unconfined particulate matter from any activity, including vehicular movement; transportation of materials; construction; alteration; demolition or wrecking; or industrially related activities such as loading, unloading, storing or handling; without taking reasonable precautions to prevent such emissions.

- 3. Reasonable precautions include the following:
 - a. Paving and maintenance of roads, parking areas and yards.
 - b. Application of water or chemicals to control emissions from such activities as demolition of buildings, grading roads, construction, and land clearing.
 - c. Application of asphalt, water, oil, chemicals or other dust suppressants to unpaved roads, yards, open stock piles and similar activities.

APPENDIX TV-4, TITLE V CONDITIONS (version dated 02/12/02) (continued)

- d. Removal of particulate matter from roads and other paved areas under the control of the owner or operator of the facility to prevent reentrainment, and from buildings or work areas to prevent particulate from becoming airborne.
- e. Landscaping or planting of vegetation.
- f. Use of hoods, fans, filters, and similar equipment to contain, capture and/or vent particulate matter.
- g. Confining abrasive blasting where possible.
- h. Enclosure or covering of conveyor systems.
- 4. In determining what constitutes reasonable precautions for a particular facility, the Department shall consider the cost of the control technique or work practice, the environmental impacts of the technique or practice, and the degree of reduction of emissions expected from a particular technique or practice.

[Rules 62-296.320(4)(c)1., 3., & 4. F.A.C.]

[electronic file name: tv-4.doc]

APPENDIX SS-1, STACK SAMPLING FACILITIES (version dated 10/07/96)

Stack Sampling Facilities Provided by the Owner of an Emissions Unit. This section describes the minimum requirements for stack sampling facilities that are necessary to sample point emissions units. Sampling facilities include sampling ports, work platforms, access to work platforms, electrical power, and sampling equipment support. Emissions units must provide these facilities at their expense. All stack sampling facilities must meet any Occupational Safety and Health Administration (OSHA) Safety and Health Standards described in 29 CFR Part 1910, Subparts D and E.

(a) Permanent Test Facilities. The owner or operator of an emissions unit for which a compliance test, other than a visible emissions test, is required on at least an annual basis,

shall install and maintain permanent stack sampling facilities.

(b) Temporary Test Facilities. The owner or operator of an emissions unit that is not required to conduct a compliance test on at least an annual basis may use permanent or temporary stack sampling facilities. If the owner chooses to use temporary sampling facilities on an emissions unit, and the Department elects to test the unit, such temporary facilities shall be installed on the emissions unit within 5 days of a request by the Department and remain on the emissions unit until the test is completed.

(c) Sampling Ports.

1. All sampling ports shall have a minimum inside diameter of 3 inches.

2. The ports shall be capable of being sealed when not in use.

3. The sampling ports shall be located in the stack at least 2 stack diameters or equivalent diameters downstream and at least 0.5 stack diameter or equivalent diameter upstream from any fan, bend, constriction or other flow disturbance.

- 4. For emissions units for which a complete application to construct has been filed prior to December 1, 1980, at least two sampling ports, 90 degrees apart, shall be installed at each sampling location on all circular stacks that have an outside diameter of 15 feet or less. For stacks with a larger diameter, four sampling ports, each 90 degrees apart, shall be installed. For emissions units for which a complete application to construct is filed on or after December 1, 1980, at least two sampling ports, 90 degrees apart, shall be installed at each sampling location on all circular stacks that have an outside diameter of 10 feet or less. For stacks with larger diameters, four sampling ports, each 90 degrees apart, shall be installed. On horizontal circular ducts, the ports shall be located so that the probe can enter the stack vertically, horizontally or at a 45 degree angle.
- 5. On rectangular ducts, the cross sectional area shall be divided into the number of equal areas in accordance with EPA Method 1. Sampling ports shall be provided which allow access to each sampling point. The ports shall be located so that the probe can be inserted perpendicular to the gas flow.

(d) Work Platforms.

- 1. Minimum size of the working platform shall be 24 square feet in area. Platforms shall be at least 3 feet wide.
- 2. On circular stacks with 2 sampling ports, the platform shall extend at least 110 degrees around the stack.
- 3. On circular stacks with more than two sampling ports, the work platform shall extend 360 degrees around the stack.
- 4. All platforms shall be equipped with an adequate safety rail (ropes are not acceptable), toeboard, and hinged floor-opening cover if ladder access is used to reach the platform. The safety rail directly in line with the sampling ports shall be removable so that no obstruction exists in an area 14 inches below each sample port and 6 inches on either side of the sampling port.

(e) Access to Work Platform.

APPENDIX SS-1, STACK SAMPLING FACILITIES (version dated 10/07/96) (continued)

- 1. Ladders to the work platform exceeding 15 feet in length shall have safety cages or fall arresters with a minimum of 3 compatible safety belts available for use by sampling personnel.
- 2. Walkways over free-fall areas shall be equipped with safety rails and toeboards. (f) Electrical Power.
- 1. A minimum of two 120-volt AC, 20-amp outlets shall be provided at the sampling platform within 20 feet of each sampling port.
- 2. If extension cords are used to provide the electrical power, they shall be kept on the plant's property and be available immediately upon request by sampling personnel.

 (g) Sampling Equipment Support.
- 1. A three-quarter inch eyebolt and an angle bracket shall be attached directly above each port on vertical stacks and above each row of sampling ports on the sides of horizontal ducts.
- a. The bracket shall be a standard 3 inch x 3 inch x one-quarter inch equal-legs bracket which is 1 and one-half inches wide. A hole that is one-half inch in diameter shall be drilled through the exact center of the horizontal portion of the bracket. The horizontal portion of the bracket shall be located 14 inches above the centerline of the sampling port.
- b. A three-eighth inch bolt which protrudes 2 inches from the stack may be substituted for the required bracket. The bolt shall be located 15 and one-half inches above the centerline of the sampling port.
- c. The three-quarter inch eyebolt shall be capable of supporting a 500 pound working load. For stacks that are less than 12 feet in diameter, the eyebolt shall be located 48 inches above the horizontal portion of the angle bracket. For stacks that are greater than or equal to 12 feet in diameter, the eyebolt shall be located 60 inches above the horizontal portion of the angle bracket. If the eyebolt is more than 120 inches above the platform, a length of chain shall be attached to it to bring the free end of the chain to within safe reach from the platform.
- 2. A complete monorail or dualrail arrangement may be substituted for the eyebolt and bracket.
- 3. When the sample ports are located in the top of a horizontal duct, a frame shall be provided above the port to allow the sample probe to be secured during the test. [Rule 62-297.310(6), F.A.C.]

TABLE 297.310-1 CALIBRATION SCHEDULE (version dated 10/07/96)

Note: This table is referen	ced in Rule 62-297.310, F.A.C.]		
ITEM	MINIMUM CALIBRATION FREQUENCY	REFERENCE INSTRUMENT	TOLERANCE
Liquid in glass thermometer	Annually	ASTM Hg in glass ref. thermometer or equivalent, or thermometric points	+/-2%
Bimetallic thermometer	Quarterly	Calib. liq. in glass thermometer	5 degrees F
Thermocouple ·	Annually	ASTM Hg in glass ref. thermometer, NBS calibrated reference and potentiometer	5 degrees F
Barometer	Monthly	Hg barometer or NOAA station	+/-1% scale
Pitot Tube	When required or when damaged	By construction or measurements in wind tunnel D greater than 16" and standard pitot tube	See EPA Method 2, Fig. 2-2 & 2-3
Probe Nozzles	Before each test or when nicked, dented, or corroded	Micrometer	+/-0.001" mean of at least three readings Max. deviation between
Dry Gas Meter and Orifice Meter	1. Full Scale: When received, When 5% change observed, Annually 2. One Point: Semiannually	Spirometer or calibrated wet test or dry gas test meter	readings .004" 2%
	Check after each test series	Comparison check	5%

[electronic file name: 297310-1.doc]

DRAFT Permit No.: 1270009-007-AV Facility ID No.: 1270009

Appendix CP-1, Compliance Plan for Repowered Unit 5

Compliance Plan for Firing Distillate Oil Firing

Sanford Power Plant's combustion turbines, PSNCT5A thru PSNCT5D, are equipped with dual fuel combustors for firing natural gas and distillate fuel oil. Initial compliance has been demonstrated for natural gas firing, but not on distillate fuel oil firing. When firing fuel oil, the combustion turbine(s) will be operated according to the manufacturer's specifications for NO_X control. Water injection is used to control NO_X with the amount of water based on the manufacturer's requirements to achieve 42 ppmvd, corrected to 15 percent oxygen. The amount of water is automatically regulated by the manufacturer's control system. The following Compliance Plan, for initial compliance for distillate fuel oil firing, follows the requirements of air construction permits, 1270009-004-AC/PSD-FL-270 and 1270009-008-AC/PSD-FL-270(A).

- The Department's Central District, Air Section, will be notified of the actual date of initial operation using distillate fuel oil within 15 days of such date.
- Emission limiting standards for NO_X, CO, VOC, SO₂ and PM/Visibility, as identified in Specific Condition III.18., shall be demonstrated on each emissions unit within 60 days of achieving maximum production rate, when firing distillate fuel oil, but no later than 180 days of initial operation on distillate fuel oil.
- Initial performance tests for NO_X, CO, VOC, SO₂ and PM/Visibility, shall be conducted using the test methods identified in Specific Condition III.28.
- Compliance with SO₂ emission requirements will be demonstrated through fuel oil analyses (i.e., 0.05% sulfur content, by weight, or less), as identified in Specific Condition III.30.
- The Department's Central District, Air Section, shall be notified in writing at least 30 days prior to the initial performance tests.
- Performance test results shall be submitted to the Department's Central District, Air Section, no later than 45 days after the last test run.
- Continuous compliance for NO_X emissions, when firing distillate fuel oil, shall be demonstrated using continuous emission monitoring systems and based on a 24-hour block average, as described in Specific Condition III.29.

STATE OF FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

In the matter of:)	÷.
)	1977 257 24
Florida Electric Power Coordinating Group, Inc.,)	ASP No. 97-B-01
Petitioner.)	

ORDER ON REQUEST FOR ALTERNATE PROCEDURES AND REQUIREMENTS

Pursuant to Rule 62-297.620, Florida Administrative Code (F.A.C.), the Florida Electric Coordinating Group, Incorporated, (FCG) petitioned for approval to: (1) Exempt fossil fuel steam generators which burn liquid and/or solid fuel for less than 400 hours during the federal fiscal year from the requirement to conduct an annual particulate matter compliance test; and, (2) Exempt fossil fuel steam generators which burn liquid and/or solid fuel for less than 400 hours during the federal fiscal year from the requirement to conduct an annual particulate matter compliance test during the year prior to renewal of an operation permit. This Order is intended to clarify particulate testing requirements for those fossil fuel steam generators which primarily burn gaseous fuels including, but not necessarily limited to natural gas.

Having considered the provisions of Rule 62-296.405(1), F.A.C., Rule 62-297.310(7), F.A.C., and all supporting documentation, the following Findings of Fact, Conclusions of Law, and Order are entered:

FINDINGS OF FACT

- 1. The Florida Electric Power Coordinating Group, Incorporated, petitioned the Department to exempt those fossil fuel steam generators which have a heat input of more than 250 million Btu per hour and burn solid and/or liquid fuel less than 400 hours during the year from the requirement to conduct an annual particulate matter compliance test. [Exhibit 1]
- 2. Rule 62-296.405(1)(a), F.A.C., applies to those fossil fuel steam generators that are not subject to the federal standards of performance for new stationary sources (NSPS) in 40 CFR 60 and which have a heat input of more than 250 million Btu per hour.
- 3. Rule 62-296.405(1)(a), F.A.C., limits visible emissions from affected fossil fuel steam generators to, "20 percent opacity except for either one six-minute period per hour during which

Best Available Copy

not exceed 40 percent. The option selected shall be specified in the emissions unit's construction and operation permits. Emissions units governed by this visible emission limit shall test for particulate emission compliance annually and as otherwise required by Rule 62-297, F.A.C."

- 4. Rule 62-296.405(1)(2), F.A.C., further states, "Emissions units electing to test for particulate matter emission compliance quarterly shall be allowed visible emissions of 40 percent opacity. The results of such tests shall be submitted to the Department. Upon demonstration that the particulate standard has been regularly complied with, the Secretary, upon petition by the applicant, shall reduce the frequency of particulate testing to no less than once annually.
- 5. Rule 297.310(7)(a)1., F.A.C., states, "The owner or operator of a new or modified emissions unit that is-subject to an emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining an operation permit for such emissions unit."
- 6. Rule 297.310(7)(a)?., F.A.C., states, "The owner or operator of an emissions unit that is subject to any emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining a renewed operation permit. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy the requirements of this provision.
- 7. Rule 297.310(7)/a)3., F.A.C., further states, "In renewing an air operation permit pursuant to Rule 62-210.360(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of emission compliance test results for any emissions unit that, during the year prior to renewal: a. Did not operate; or, b. In the case of a fuel burning emissions unit, burned liquid and/or solid fuel for a total of no more than 400 hours."
- 8. Rule 297.310(7)(z)4., F.A.C., states, "During each federal fiscal year (October 1 -- September 30), unless otherwise specified by rule, order, or permit, the owner or operator of each emissions unit shall have a formal compliance test conducted for: a. Visible emissions, it there is an applicable standard; c. Each of the following pollutants, if there is an applicable standard; and if the emissions unit emits or has the potential to emit: 5 tons per year or more of lead or lead compounds measured as elemental lead; 30 tons per year or more of any other regulated air pollutant..."
- 9. Rule 297.310(7)(a)5., F.A.C., states. "An annual compliance test for particulate matter emissions shall not be required for any fuel burning emissions unit that, in a federal fiscal year, does not burn liquid and/or solid fuel, other than during startup, for a total of more than 400 hours."
- 10. Rule 297.310(7)(2)6., F.A.C., states, "For fossil fuel steam generators on a semi-annual particulate matter emission compliance testing schedule, a compliance test shall not be

required for any six-month period in which liquid and/or solid fuel is not burned for more than 200 hours other than during startup."

- 11. Rule 297.310(7)(a)7., F.A.C., states, "For emissions units electing to conduct particulate matter emission compliance testing quarterly pursuant to Rule 62-296.405(2)(a), F.A.C., a compliance test shall not be required for any quarter in which liquid and/or solid fuel is not burned for more than 100 hours other than during startup." [Note: The reference should be to Rule 62-296.405(1)(a), F.A.C., rather than Rule 62-296.405(2)(a), F.A.C.]
- 12. The fifth edition of the U. S. Environmental Protection Agency's <u>Compilation of Air Pollutant Emission Factors</u>, AP-42, that emissions of filterable particulate from gas-fired fossil fuel steam generators with a heat input of more than about 10 million Btu per hour may be expected to range from 0.001 to 0.006 pound per million Btu. [Exhibit 2]
- 13. Rule 62-296.405(1)(b), F.A.C. and the federal standards of performance for new stationary sources in 40 CFR 60.42, Subpart D, limit particulate emissions from uncontrolled fossil fuel fired steam generators with a heat input of more than 250 million Btu to 0.1 pound per million Btu.

CONCLUSIONS OF LAW

- 1. The Department has jurisdiction to consider the matter pursuant to Section 403.061, Florida Statutes (F.S.), and Rule 62-297.620, F.A.C.
- 2. Pursuant to Rule 62-297.310(7), F.A.C., the Department may require Petitioner to conduct compliance tests that identify the nature and quantity of pollutant emissions, if, after investigation, it is believed that any applicable emission standard or condition of the applicable permits is being violated.
- 3. There is reason to believe that a fossil fuel steam generator which does not burn liquid and/or solid fuel (other than during startup) for a total of more than 400 hours in a federal fiscal year and complies with all other applicable limits and permit conditions is in compliance with the applicable particulate mass emission limiting standard.

ORDER

Having considered the requirements of Rule 62-296.405, F.A.C., Rule 62-297.310, F.A.C., and supporting documentation, it is hereby ordered that:

1. An annual compliance test for particulate matter emissions shall not be required for any fuel burning emissions unit that, in a federal fiscal year, does not burn liquid and/or solid fue!, other than during startup, for a total of more than 400 hours;

- 2. For fossil fuel steam generators on a semi-annual particulate matter emission compliance testing schedule, a compliance test shall not be required for any six-month period in which liquid and/or solid fuel is not burned for more than 200 hours other than during startup;
- 3. For emissions units electing to conduct particulate matter emission compliance testing quarterly pursuant to Rule 62-296.405(1)(a), F.A.C., a compliance test shall not be required for any quarter in which liquid and/or solid fuel is not burned for more than 100 hours other than during startup;
- 4. In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of particulate matter emission compliance test results for any fossil fuel steam generator emissions unit that burned liquid and/or solid fuel for a total of no more than 400 hours during the year prior to renewal.
- 5. Pursuant to Rule 62-297.310(7), F.A.C., owners of affected fossil fuel steam generators may be required to conduct compliance tests that identify the nature and quantity of pollutant emissions, if, after investigation, it is believed that any applicable emission standard or condition of the applicable permits is being violated.
- 6. Pursuant to Rule 62-297.310(8), F.A.C., owners of affected fossil fuel steam generators shall submit the compliance test report to the District Director of the Department district office having jurisdiction over the emissions unit and, where applicable, the Air Program Administrator of the appropriate Department-approved local air program within 45 days of completion of the test.

PETITION FOR ADMINISTRATIVE REVIEW

The Department will take the action described in this Order unless a timely petition for an administrative hearing is filed pursuant to sections 120.569 and 120.57 of the Fiorida Statutes, or a party requests mediation as an alternative remedy under section 120.573 before the deadline for filing a petition. Choosing mediation will not adversely affect the right to a hearing if mediation does not result in a settlement. The procedures for petitioning for a hearing are set forth below, followed by the procedures for requesting mediation.

A person whose substantial interests are affected by the Department's proposed decision may petition for an administrative hearing in accordance with sections 120.569 and 120.57 of the Florida Statutes. The petition must contain the information set forth below and must be filed (received) in the Office of General Counsel of the Department at 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida 32399-3000. Petitions must be filed within 21 days of receipt of this Order. A petitioner must mail a copy of the petition to the applicant at the address indicated above, at the time of filing. The failure of any person to file a petition (or a request for mediation, as discussed below) within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under sections 120.569 and 120.57 of

the Florida Statutes, or to intervene in this proceeding and participate as a party to it. Any subsequent intervention will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-5.207 of the Florida Administrative Code.

A petition must contain the following information:

- (a) The name, address, and telephone number of each petitioner, the applicant's name and address, the Department File Number, and the county in which the project is proposed;
- (b) A statement of how and when each petitioner received notice of the Department's action or proposed action;
- (c) A statement of how each petitioner's substantial interests are affected by the Department's action or proposed action;
 - (d) A statement of the material facts disputed by each petitioner, if any;
- (e) A statement of facts that the petitioner contends warrant reversal or modification of the Department's action or proposed action;
- (f) A statement identifying the rules or statutes each petitioner contends require reversal or modification of the Department's action or proposed action; and,
- (g) A statement of the relief sought by each petitioner, stating precisely the action each petitioner wants the Department to take with respect to the Department's action or proposed action in the notice of intent.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Department's final action may be different from the position taken by it in this Order. Persons whose substantial interests will be affected by any such final decision of the Department on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

A person whose substantial interests are affected by the Department's proposed decision, may elect to pursue mediation by asking all parties to the proceeding to agree to such mediation and by filing with the Department a request for mediation and the written agreement of all such parties to mediate the dispute. The request and agreement must be filed in (received by) the Office of General Counsel of the Department at 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida 32399-3000, by the same deadline as set forth above for the filing of a petition.

A request for mediation must contain the following information:

BEST AVAILABLE COPY

- (a) The name, address, and telephone number of the person requesting mediation and that person's representative, if any;
 - (b) A statement of the preliminary agency action;
 - (c) A statement of the relief sought; and
- (a) Either an explanation of how the requester's substantial interests will be affected by the action or proposed action addressed in this notice of intent or a statement clearly identifying the petition for hearing that the requester has already filed, and incorporating it by reference.

The agreement to mediate must include the following:

- (2) The names, addresses, and telephone numbers of any persons who may attend the mediation:
- (5) The name, address, and telephone number of the mediator selected by the parties, or a provision for selecting a mediator within a specified time;
 - (c) The agreed allocation of the costs and fees associated with the mediation;
- (d) The agreement of the parties on the confidentiality of discussions and documents introduced during mediation;
- (e) The date, time, and place of the first mediation session, or a deadline for holding the first session, if no mediator has yet been chosen;
- (f) The name of each party's representative who shall have authority to settle or recommend settlement; and
 - (g) The signatures of all parties or their authorized representatives.

As provided in section 120.573 of the Florida Statutes, the timely agreement of all parties to mediate will tell the time limitations imposed by sections 120.569 and 120.57 for requesting and holding an administrative hearing. Unless otherwise agreed by the parties, the mediation must be concluded within sixty days of the execution of the agreement. If mediation results in settlement of the auministrative dispute, the Department must enter a final order incorporating the agreement of the parties. Persons whose substantial interests will be affected by such a modified final decision of the Department have a right to petition for a hearing only in accordance with the requirements for such petitions set forth above. If mediation terminates without settlement of the dispute, the Department shall notify all parties in writing that the administrative hearing processes under sections 120.569 and 120.57 remain available for disposition of the dispute, and the notice will

specify the deadlines that then will apply for challenging the agency action and electing remedies under those two statutes.

In addition to the above, a person subject to regulation has a right to apply for a variance from or waiver of the requirements of particular rules, on certain conditions, under section 120.542 of the Florida Statutes. The relief provided by this state statute applies only to state rules, not statutes, and not to any federal regulatory requirements. Applying for a variance or waiver does not substitute or extend the time for filing a petition for an administrative hearing or exercising any other right that a person may have in relation to the action proposed in this notice of intent.

The application for a variance or waiver is made by filing a petition with the Office of General Counsel of the Department, 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida 32399-3000.

The petition must specify the following information:

- (2) The name, address, and telephone number of the petitioner;
- (b) The name, address, and telephone number of the attorney or qualified representative of the petitioner, if any;
 - (c) Each rule or portion of a rule from which a variance or waiver is requested;
 - (d) The citation to the statute underlying (implemented by) the rule identified in (c) above;
 - (e) The type of action requested;
 - (f) The specific facts that would justify a variance or waiver for the petitioner;
- (g) The reason why the variance or waiver would serve the purposes of the underlying statute (implemented by the rule); and
- (h) A statement whether the variance or waiver is permanent or temporary and, if temporary, a statement of the dates showing the duration of the variance or waiver requested.

The Department will grant a variance or waiver, when the petition demonstrates both that the application of the rule would create a substantial hardship or violate principles of fairness, as each of those terms is defined in section 120.542(2) of the Florida Statutes, and that the purpose of the underlying statute will be or has been achieved by other means by the petitioner. Persons subject to regulation pursuant to any federally delegated or approved air program should be aware that Florida is specifically not authorized to issue variances or waivers from any requirements of any such federally delegated or approved program. The requirements of the program remain fully

each of those terms is defined in section 120.542(2) of the Florida Statutes, and that the purpose of the underlying statute will be or has been achieved by other means by the petitioner. Persons subject to regulation pursuant to any federally delegated or approved air program should be aware that Florida is specifically not authorized to issue variances or waivers from any requirements of any such federally delegated or approved program. The requirements of the program remain fully enforceable by the Administrator of the EPA and by any person under the Clean Air Act unless and until the Administrator separately approves any variance or waiver in accordance with the procedures of the federal program.

This Order constitutes final agency action unless a petition is filed in accordance with the above paragraphs. Upon timely filing of a petition, this Order will not be effective until further Order of the Department.

RIGHT TO APPEAL

Any party to this Order has the right to seek judicial review of the Order pursuant to Section 120.68, F.S., by the filing of a Notice of Appeal pursuant to Rule 9.110, Florida Rules of Appellate Procedure, with the Clerk of the Department in the Office of General Counsel, 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida 32399-3000; and, by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The Notice of Appeal must be filed within 30 days from the date the Notice of Agency Action is filed with the Clerk of the Department.

DONE AND ORDERED this 17 day of March, 1997 in Tallahassee, Florida.

STATE OF FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

HOWARD L. RHODES, Director

Division of Air Resources Management

Twin Towers Office Building

2600 Blair Stone Road

Tallahassee, Florida 32399-2400

(904) 488-0114

CERTIFICATE OF SERVICE

The undersigned duly designated deputy clerk hereby certifies that a copy of the foregoing was mailed to Rich Piper, Chair, Florida Power Coordinating Group, Inc., 405 Reo Street, Suite 100, Tampa, Florida 33609-1004, on this Kord day of March 1997.

Clerk Stamp

FILING AND ACKNOWLEDGMENT FILED, on this date, pursuant to \$120.52(7), Florida Statutes, with the designated Department Clerk, receipt of which is hereby acknowledged.

Cléřk


Date

FLORIDA ELECTRIC POWER COORDINATING GROUP, INC. (FCG) 205 REC STREET, SUITE 100 + (8:3) 289-5644 + FAX (8:3) 289-5645 TAMPA, FLORIDA 33609-1004

January 28, 1997



Clair H. Fancy, P.E. Chief, Bureau of Air Regulation Florida Department of Environmental Protection 2600 Blair Stone Road, MS 5505 Tallahassee, FL 32301



BUREAU OF AIR REGULATION

RE: Comments Regarding Draft Title V Permits

Dear Mr. Fancy:

The Florida Electric Power Coordinating Group, Inc. (FCG), which is made up of 36 utilities owned by investors, municipalities, and cooperatives, has been following the implementation of Title V in Florida and recently submitted comments to you on draft Title V permit conditions by letter dated December 4, 1996. As indicated in that letter, representatives from the FCG would like to meet with you and other members of your air permitting staff to discuss some significant concerns that FCG member companies have regarding conditions that may be included in Title V permits issued by your office. While we will be discussing these issues with you and your staff in greater detail at that meeting, we would like to explain some of our concerns in this letter.

Primarily, the FCG members are concerned that the Title V permits may contain conditions that are much different in important respects than those conditions currently included in existing air permits. During the rulemaking workshops and seminars conducted by the Department to discuss the rules implementing the Title V permitting program, representations were made on several occasions that industry could expect to see permit conditions that were substantively similar to existing permit conditions and that primarily the format was changing. Representations were also made to industry that Title V did not impose additional substantive requirements beyond what was already required under the Department's rules. Based on the first draft Title V permit that we have reviewed, we are concerned that there may be some attempt to change the substantive requirements on existing facilities through the Title V permitting process, and we would like to discuss this with you at the meeting we have scheduled for January 30, 1997.

1. Federal Enforceability--The FCG has long been concerned about the designation of non-federally enforceable permit terms and conditions. We are concerned about this issue because the Department's first draft Title V permits have included language stating that all terms and conditions would become federally enforceable once the permit is issued. This approach is consistent with the Department's guidance memorandum dated September 13, 1996 (DARM-PER/V-18), but we understand that the Department may now intend to remove all references to

BEST AVAILABLE COPY

Clair H. Fancy, P.E. Chief, Bureau of Air Regulation Florida Department of Environmental Protection January 28, 1997 Page 2

the federal enforceability of permit terms and conditions. We are also concerned about this approach because a Title V permit is generally federally enforceable and, without any designation of non-federally enforceable terms and conditions, the entire permit could be interpreted to be federally enforceable. As we stated in the December 4 letter as well as our letter dated October 11, 1996, all terms and conditions in a Title V permit do not become enforceable by the U.S. Environmental Protection Agency and citizens under the Clean Air Act simply by inclusion in a Title V permit. To make it clear which provisions in a Title V permit are not federally enforceable (which are being included because of state or local requirements only), it is very important to specifically designate those conditions as having no federally enforceable basis. Such a designation is actually required under the federal Title V rules, which provide that permitting agencies are to "specifically designate as not being federally enforceable under the Act any terms and conditions included in the permit that are not required under the Act or under any of its applicable requirements." 40 CFR § 70.6(b). We would like to discuss with you our concerns about this issue and to again specifically request that when Title V permits are issued by the Department, conditions having no federally enforceable basis clearly be identified as such.

- 2. PM Testing on Gar-The FCG understands that the Department may attempt to require annual particulate matter compliance testing while firing natural gas to determine compliance with the 0.1 lb/mmBtu emission limit established under Rule 62-296.405(1)(b). F.A.C. The FCG member companies feel strongly that compliance testing for particulate matter should not be required while firing natural gas. The Department has not historically required particulate matter compliance testing while firing natural gas, it is not required under the current permits for these units, and it should not be necessary since natural gas is such a clean fiel. Typically only de minimis amounts of particulate matter would be expected from the firing of natural gas, so compliance testing would not provide meaningful information to the Department. and the expense to conduct such tests is not justified. We understand that Department representatives suggested that industry could pursue an alternative test procedure under Rule 62-297.620, F.A.C., to allow a visible emissions test to be used in lieu of a stack test for determining compliance with the particulate matter limit. While certainly a visible emissions test would be preferable over a stack test, neither of these tests should be needed to demonstrate compliance with the particulate matter limit of 0.1 lb/mmBtu while burning natural gas. The FCG strongly urges that the Department reconsider its position on this issue and clarify that compliance testing for particulate matter while firing natural gas is not required.
- Protection Agency (EPA) submitted a letter dated December 5, 1996, the U.S. Environmental Protection Agency (EPA) submitted a letter commenting on a draft Title V permit that had been issued by the Department and indicated some concern regarding excess emission provisions included in conditions that were quoted from Rule 62-210.700, F.A.C. Because the permit conditions cited simply quote the applicable provisions of the Department's rules regarding

BEST AVAILABLE COPY

Clair H. Fancy, P.E.
Chief, Bureau of Air Regulation
Florida Department of Environmental Protection
January 28, 1997
Page 3

excess emissions and because these rules have been approved as part of Florida's State Implementation Plan, the permit conditions are appropriate to be included in the permit. We understand that the Department intends to include as applicable requirements in Title V permit conditions the provisions of Rule 62-210.700, F.A.C. If the Department receives any further adverse comments regarding the excess emissions rule under 62-210.700, F.A.C., we would appreciate your contacting us. Because this issue is so important to us, we would like to discuss it with you in greater detail at our meeting on January 30.

- Compliance Testing for Combustion Turbines--While the Department's November 22, 1995, guidance regarding the compliance testing requirements for combustion th roines clearly states that the use of heat input curves based on ambient temperatures and humidities is to be included as a permit condition only if requested by a permittee, we understand that the Department may intend to include this requirement in Title V permits for all combustion turbines. As we are sure you recall, the FCG worked over a period of several months with the Department on the development of the guidance memorandum and it was clearly understood by FCG members that the heat input curves would not be mandated but would remain voluntary for any existing combustion turbine. It was also understood by FCG members that the requirement to conduct testing at 95 to 100 percent of capacity would be required only if the permit applicant requested the use of heat input curves. We understand that the Department may be interpreting the requirement to use heat input curves and to test at 95 to 100 percent of permitted capacity to be mandatory for all combustion turbines. We would like to clarify this with you during our meeting. Also, we would like to confirm that, regardless of whether a combustion turbine uses heat input curves or tests at 95 to 100 percent of permitted capacity, it is necessary to test at four load points and correct to ISO only to determine compliance with the nitrogen oxides (NOx) standard under New Source Performance Standard Subpart GG under 40 CFR § 60.332 and not annually thereafter.
- 5. Test Methods--The FCG is concerned about the possibility of the Department requiring a full permit revision to authorize the use of an approved test method not specifically identified in a Title V permit, even though the Department may have separately approved the use of the particular test method for a unit (i.e., through a compliance test protocol). It is the FCG's position that language should be included in all Title V permits indicating that other test methods approved by the Department may be used. Further, a full permit revision (including public notice) should not be necessary when a test method not previously identified in the permit is approved for use by a unit. The Department's subsequent approval of test methods should simply be included in the next permit renewal cycle. The FCG understands that the Department planned to confirm this approach with the U.S. Environmental Protection Agency Region IV, and we would like to discuss this issue with you at the January 30 meeting to learn of the agency's response.

Clair H. Fancy, P.E.
Chief, Bureau of Air Regulation
Florida Department of Environmental Protection
January 28, 1997
Page 4

- 6. Quarterly Reports--The FCG understands that the Department may be interpreting the quarterly reporting requirements under Rule 62-296.405(1)(g), F.A.C., to apply regardless of whether continuous emissions monitors were required under the preceding Rule 62-296.405(1)(f), F.A.C. It is the FCG's position that quarterly reports are required under Rule 62-296.405(1)(g) only when continuous emissions monitors are required under the preceding paragraph (f). While this may not be entirely clear from the language of the rules, paragraphs (f) and (g) were originally included in a separate rule on "continuous emission monitoring requirements" where it was very clear that the requirements of paragraph (g) applied only if continuous emission monitoring was required under paragraph (f). Research indicates that Rule 17-2.710, F.A.C. (copy attached), where these provisions were originally located, was first transferred to Rule 17-297.500, F.A.C. (which later became Rule 62-297.500), later repealed in November of 1994, and ultimately replaced with what is now Rule 62-296.405(1)(f) and (g), F.A.C. To the extent that an emissions unit is not subject to Rule 62-296.405(1)(f) and is not required to install and operate continuous emissions monitors (e.g., oil- and gas-fired units), the quarterly reporting requirements of paragraph (g) should not apply.
- Trivial Activities—As you may recall, in May of 1996, the FCG submitted to the Department a list of small, de minimis emissions units and activities that it considered to be "trivial," consistent with the list developed by EPA as part of the Title V "White Paper" and incorporated by reference by the Department in its March 15, 1996, guidance memorandum (DARM-PER/V-15-Revised). We never received a response from the Department and now understand that the Department may not have made a determination as to whether any of the emission units or activities on the list should qualify as "trivial." This is an important issue to the FCG because only "trivial" activities can be omitted from the Title V permit application and permit, and ultimately omitted from emission estimates in the annual air operation reports under Rule 62-210.370(3), F.A.C. The FCG remains hopeful that the Department will consider its request to determine that most, if not all, of the emission units and activities on the May, 1995, list to be "trivial." We would like to discuss a possible resciution of this issue with you and your staff at the January 30 meeting.
- 8. Permit Shielz--The FCG continues to be concerned about the language in Conditions 5 and 20 of Appendix TV-1, Title V Conditions, which circumvents the permit shield provisions under Section 403.0872(15), Florida Statutes, and Rule 62-713.460, F.A.C. The FCG believes that these conditions should be deleted in their entirety. To the extent that the Department attempt to caveat the applicability of those conditions, the FCG believes that it is important to cite to not only the regulatory citation for the permit shield but the statutory citation as well.

Thank you again for considering the FCG's comments on the draft Title V permits. We very much appreciate the cooperation we have received from the Topamment throughout the

Clair H. Fancy, P.E. Chief, Bureau of Air Regulation Florida Department of Environmental Protection January 28, 1997 Page 5

Title V implementation process, and we look forward to our meeting later this week. have any questions in the meantime, please call me at 561-625-7661.

Sincerely,

Rich Piper, Chair (True FCG Air Subcommittee

Enclosures

Howard L. Rhodes, DEP cc: John Brown, DEP Pat Comer, DEP OGC Scott M. Sheplak, DEP Edward Svec, DEP FCG Air Subcomminee Angela Morrison, HGSS

10382

COMPILATION OF AIR POLLUTANT EMISSION FACTORS

VOLUME I: STATIONARY POINT AND AREA SOURCES

Office Of Air Quality Planning And Standards
Office Of Air And Radiation
U. S. Environmental Protection Agency
Research Triangle Park, NC 27711

1.4 Natural Gas Combustion

1.4.1 General¹⁻²

Natural gar is one of the major fuels used throughout the country. It is used mainly for inclustrial process steam and heat production; for residential and commercial space heating; and for electric power generation. Natural gas consists of a high percentage of methane (generally above 80 percent) and varying amounts of ethane, propane, butane, and inerts (typically nitrogen, carbon disaide, and helium). Gas processing plants are required for the recovery of liquefiable constituents and removal of hydrogen sulfide before the gas is used (see Section 5.3, Natural Gas Processing). The average gross heating value of natural gas is approximately 8900 kilocalories per standard cubic meter (1000 British thermal units per standard cubic foot), usually varying from 8000 to 9801 kcal sam (900 to 1100 Bru/scf).

1.4.2 Endissions And Controls³⁻⁵

First though natural gas is considered to be a relatively clean-burning fuel, some emissions can result from comburtion. For example, improper operating conditions, including poor air/fuel mixing, insufficient air, etc., may cause large amounts of smoke, carbon monoxide (CO), and organic compound emissions. Moreover, because a sulfur-containing mercaptan is added to natural gas to permit leak detection, small amounts of sulfur oxides will be produced in the combustion process.

Nitrogen exides (NO₂) are the major pollutants of concern when burning natural gas. Whogen exide, emissions depend primarily on the peak temperature within the combustion chamber at well as the turnace-zone exygen concentration, nitrogen concentration, and time of exposure at peak temperatures. Emission levels vary considerably with the type and size of combustor and with operating conditions (particularly combustion air temperature, load, and excess air level in boilers).

Currently, the two most prevalent NO_x control techniques being applied to natural gas-fired boilers (which require in characteristic changes in emission rates) are low NO_x burners and fine gas red outlot. In Low NO_x burners reduce NO_x by accomplishing the combustion process in stages. Stigling protectly delays the combustion process, resulting in a cooler fiame which suppresses NO_x formation. The three most common types of low NO_x burners being applied to natural gas-fired builers are staged air burners, staged fuel burners, and radiant fiber burners. Nitrogen oxide emission reductions of 40 to 85 percent (relative to uncontrolled emission levels) have been observed with low NO_x burners. Other combustion staging techniques which have been applied to natural gas-fired boilers include low excess air, reduced air preheat, and staged combustion (e.g., burners-out-of-service and overfire air). The degree of staging is a key operating parameter influencing NO_x emission rates for these systems.

In a five gas recirculation (FGR) system, a portion of the five gas is recycled from the stack to the burner windhox. Upon extering the windbox, the gas is mixed with combustion air prior to being fed to the burner. The FGR system reduces NO_x emissions by two mechanisms. The recycled five gas a mulle up of combustion products which are as inerts during combustion of the fuel/air mixture. This additional mass is heated in the combustion zone, thereby lowering the peak fiame tent; grature and reducing the amount of NO_x formed. To a lesser extent, FGR also reduces NO_x formation in the primary fiame zone. The amount of flue gas recirculated is a key operating parameter influencing NO_x emission rates for these systems. Flue gas

BEST AVAILABLE COPY

recirculation is normally used in combination with low NO₂ burners. When used in combination, these techniques are capable of reducing uncontrolled NO₂ emissions by 60 to 90 percent.

Two post-combustion technologies that may be applied to natural gas-fired boilers to reduce NO, emissions by further amounts are selective noncatalytic reduction and selective catalytic reduction. These systems inject ammonia (or urea) into combustion flue gase; to reduce inlet NO, emission rates by 40 to 70 percent.

Although not messured, all particulate matter (PM) from natural gas combustion has been estimated to be less than 1 micrometer in size. Particulate matter is composed of filterable and condensable fractions, based on the EPA sampling method. Filterable and condensable emission rates are of the same order of magnitude for boilers; for residential furnaces, most of the PM is in the form of condensable material.

The rates of CO and trace organic emissions from boilers and furnaces depend on the efficiency of natural gas combustion. These emissions are minimized by combustion practices that promote high combustion temperatures, long residence times at those temperatures, and turbulent mixing of fuel and combustion air. In some cases, the addition of NO₂ control systems such as FGR and low NO₂ burners reduces combustion efficiency (due to lower combustion temperatures), resulting in higher CO and organic emissions relative to uncontrolled boilers.

Emission factors for natural gas combustion in boilers and furnaces are presented in Tables 1.41, 1.42, and 1.43.6 For the purposes of developing emission factors, natural gas combustors have been organized into four general categories: utility/iarge industrial boilers, small industrial boilers, commercial boilers, and residential furnaces. Boilers and furnaces within these categories share the same general design and operating characteristics and hence have similar emission characteristics when combusting natural gas. The primary factor used to demarcate the individual combustor categories is heat input.

Combustor Type		Filterable PM ^c			Condensable PM ^d			
(Size, 10 ⁶ Dtu/hr Heat Input) (SCC) ^h	kg/10 ⁶ m ³	ϳϳν/10 ⁶ μ ₃	RATING	- kg/10 ⁶ m ³	16/10 ⁶ ft ³	RATING		
Utility/large industrial boilers (> 100) (1-01-006-01, 1-01-006-04)	16 - 80	1 - 5	В	, ND	ND .	ΝΛ		
Small industrial boilers (10 - 100) (1-02-006-02)	. 99	6.2	B.	120	7.5	D		
Commercial boilers (0.3 - < 10) (1-03-006-03)	72	4.5	. C	120	7.5	С		
Residential furnaces (<0.3) (No SCC)	2.8	. 0.18	.C	180	. 11	D		

References 9-14. All factors represent uncontrolled emissions. Units are kg of pollutant/10⁶ cubic meters natural gas fired and lb of pollutant/10⁶ cubic feet natural gas fired. Based on an average natural gas higher heating value of 8270 kcal/m³ (1000 Btu/scf). The emission factors in this table may be converted to other natural gas heating values by multiplying the given emission factor by the ratio of the specified heating value to this average heating value. ND = no data. NA = not applicable.

b SCC = Source Classification Code.

⁶ Filterable PM is that particulate matter collected on or prior to the filter of an EPA Method 5 (or equivalent) sampling train.

d Condensable PM is that particulate matter collected using EPA Method 202, (or equivalent). Total PM is the sum of the filterable PM and condensable PM. All PM emissions can be assumed to be less than 10 micrometers in aerodynamic equivalent diameter (PM-10).

. Table 1.4-2 (Metric And English Units). EMISSION FACTORS FOR SULFUR DIOXIDE (SO₂), NITROGEN OXIDES (NO₂), AND CARBON MONOXIDE (CO) FROM NATURAL GAS COMBUSTION*

			<u> </u>	·				•		
Combustor Type (Size, 10 ⁶ Btu/hr Heat Input)	SO ₂ °				NO _x d			CO.		
(SCC) ^b kg/10 ⁶ m ³	kg/10 ⁶ m ³	ווייוסף גין.	RATINO	kg/10 ⁶ m ³	18/10 ⁶ N ³	RATINO	kg/10 ⁶ m ³	1P\10 ₆ U ₃	RATINO	
Utility/large Industrial Boilers (> 100) (1-01-006-01, 1-01-006-04)		,		,	1:					
· Uncontrolled	9.6	0.6	: A	8800	550 ^r	٨	640	40	٨	
Controlled - Low NO _x burners	9.6	0.6	À	:1300	81	D	מא	ДИ	ΝΑ	
Controlled - Flue gas recirculation	9.6	0.6	. Λ	850	. 23t	D	מא	ИD	λи	
Small Industrial Boilers (10 - 100) (1-02-006-02)					•					
Uncontrolled	9.6	0.6	Λ	2240	140	λ .	·· 560 ··	35	٨	
Controlled - Low NOx burners	9.6	0.6	λ .	1300	. 81 _t	D	980	61	D	
Controlled - Flue gas recirculation	9.6	0.6	Å	. 480	· 30	·C	590	["] 37	С	
Commercial Boilers (0.3 - <10) (1-03-006-03)			· ·				•	•		
Uncontrolled	9.6	0.6	٠ ٨ .	1600	100	B	330	21	С	
Controlled - Low NO _x burners	9.6	0.6	٨	270 .	17	C.	425	. 27	С	
Controlled - Flue gas recirculation	9.6	0.6	٨	580	36	. D	. ND 1	ND	ΝΛ	
Residential Furnnees (<0.3) (No SCC)							با			
Uncontrolled	9.6	0.6	· ,	1500	94	, B	640	• 10	В	

^a Units are kg of pollutant/10⁶ cubic meters natural gas fired and lb of pollutant/10⁶ cubic feet natural gas fired. Based on an average natural gas fired higher heating value of 8270 kcal/m³ (1000 Btu/scf). The emission factors in this table may be converted to other natural gas heating values by multiplying the given emission factor by the ratio of the specified heating value to this average heating value. ND = no data. NA = not applicable. b SCC = Source Classification Code.

^c Reference 7. Based on average sulfur content of natural gas, 4600 g/10⁶ Nm³ (2000 gr/10⁶ scf).

External Combustion Sources

^c References 9-10,16-18,20-21.

^f Emission factors apply to packaged boilers only.

Table 1.4-3 (Metric And English Units). EMISSION FACTORS FOR CARBON DIOXIDE (CO₂) AND TOTAL ORGANIC COMPOUNDS (TOC) FROM NATURAL GAS COMBUSTION*

·				te.			
Combustor Type	CO ₂ c			TOCd			
(Size, 10 ⁶ Btu/hr Heat Input) (SCC) ^b	kg/Ï0 ⁶ m ³	10/106 U3	RATING	kg/10 ⁶ m ³	10/10 ⁶ ft ³	RATING	
Utility/large industrial boilers. (> 100) (1-01-006-01, 1-01-006-04)	ND°	CIN	. NA	28(1.7 ^f	С.	
Small industrial boilers (10 - 100) (1-02-006-02)	1.9 E+06	1.2 E+05	D	928	5.8 ^g	С	
Commercial boilers (0.3 - < 10) (1-03-006-03)	1.9 E+06	1.2 E+05	С	128 ^h	8.0 ^h	С	
Residential furnaces (No SCC)	2.0 E + 06	1.3 E+05	· D	180 ^h	11 ^h	. D	

^a All factors represent uncontrolled emissions. Units are kg of pollutant/10⁶ cubic meters and lb of pollutant/10⁶ cubic feet. Based on an average natural gas higher heating value of 8270 kcal/m³ (1000 Btu/scf). The emission factors in this table may be converted to other natural gas heating values by multiplying the given factor by the ratio of the specified heating value to this average heating value, NA = not applicable.

b SCC = Source Classification Code.

c References 10,22-23.

d References 9-10,18.

^c ND = no data.

Reference 8: methane comprises 17% of organic compounds.

Reference 8: methane comprises 52% of organic compounds.

h Reference 8: methane comprises 34% of organic compounds.




Figure 1.4-1. Load reduction coefficient as a function of boiler load. (Used to determine NO₄ reductions at reduced loads in large boilers.)


· References For Section 1.4

- 1. Exhaust Gases From Combustion and Industrial Processes, EPA Contract No. EHSD 71-36, Engineering Science, Inc., Washington, DC, October 1971.
- Chemical Engineers' Handbook, Fourth Edition, J. H. Perry, Editor, McGraw-Hill Book Company, New York, NY, 1963.
- Background Information Document For Industrial Boilers, EPA-450/3-82-0062,
 U. S. Environmental Protection Agency, Research Triangle Park, NC, March 1982.
- 4. Background Information Document For Small Steam Generating Units, EPA-450/3-87-000, U. S. Environmental Protection Agency, Research Triangle Park, NC, 1987.
- 5. Fine Particulate Emissions From Stationary and Miscellaneous Sources in the South Coast Air Basin, California Air Resources Board Contract No. A6-191-30, KVB, Inc., Tustin, CA, February 1979.
- Emission Factor Documentation for AP-42 Section 1.4 Natural Gas Combustion (Draft),
 Technical Support Division, Office of Air Quality Planning and Standards,
 U. S. Environmental Protection Agency, Research Triangle Park, NC, April 1993.
- 7. Systematic Field Study of NO. Emission Control Methods For Utility Eoilers, APTD-1163, U. S. Environmental Protection Agency, Research Triangle Park, NC, December 1971.
- 8. Compilation of Air Pollutant Emission Factors, Fourth Edition, AP-42, U.S. Environmental Protection Agency, Research Triangle Park, NC, September 1985.

BEST AVAILABLE COPY

- 9. J. L. Muhlbaier, "Particulate and Gaseous Emissions From Natural Gas Furnaces and Water Heaters", Journal of the Air Pollution Control Association, December 1981.
- 10. Field Investigation of Emissions From Combustion Equipment for Space Hearing, EPA-R2-73-0842, U. S. Environmental Protection Agency, Research Triangle Park, NC, June 1973.
- 11. N. F. Suprenant, et al., Emissions Assessment of Conventional Stationary: Combustion Systems, Volume 1: Gas and Oil Fired Residential Hearing Sources, EFA-600/7-79-029b, U. S. Environmental Protection Agency, Washington, DC, May 1979.
- 12. C. C. Shih, et al., Emissions Assessment of Convensional Stationary Combustion Systems, Volume III: External Combustion Sources for Electricity Generation, EPA Contract No. 68-02-2197, TRW, Inc., Redondo Beach, CA, November 1980.
- 13. N. F. Suprenant, et al., Emissions Assessment of Conventional Stationary Combustion Systems, Volume IV: Commercial/Institutional Combustion Sources, EPA Contract No. 68-02-2197, GCA Corporation, Bedford, MA, October 1980.
- 14. N. F. Suprenant, et al., Emissions Assessment of Conventional Stationary Combustion Systems, Volume V: Industrial Combustion Sources, EPA Contract No. 68-02-2197, GCA Corporation, Bedford, MA, October 1980.
- 15. Emissions Test on 200 HP Boiler at Kaiser Hospital in Woodland Hills, Energy Systems Associates, Tustin, CA, June 1986.
- 16. Results From Performance Tests: California Milk Producers Boiler No. 5, Energy Systems Associates, Tustin, CA, November 1984.
- 17. Source Test For Measurement of Nitrogen Oxides and Carbon Monoxide Emissions From Boller Exhaust at GAF Building Materials, Pacific Environmental Services, Inc., Baldwin Park, CA, May 1991.
- J. P. Kesselring and W. V. Krill, "A Low-NO₂ Burner For Gas-Fired Firetube Boilers", Proceedings: 1985 Symposium on Stationary Combustion NO₂ Control, Volume 2, EPRI CS-4360, Electric Power Research Institute, Palo Alto, CA, January 1986.
- 19. NO₂ Emission Control Technology Update, EPA Contract No. 68-01-6558, Rutium Corporation, Research Triangle Park, NC, January 1984.
- Background Information Document For Small Steam Generating Units, EF 4-450/7-87-000,
 U. S. Environmental Protection Agency, Research Triangle Park, NC, 1987.
- 21. Evaluation of the Pollutant Emissions From Gas-Fired Forced Air Furnaces: Research Report No. 1503, American Gas Association Laboratories, Cleveland, OH, May 1975.
- 22.7 Thirty-day Field Tests of Industrial Boilers: Site 5 Gas-fired Low-NO₂ Burner, EPA-600/7-81-095a, U. S. Environmental Protection Agency, Research Triangle Park, NC, May 1981.
- 23. Private communication from Kim Black (Industrial Combustion) to Ralph Harris (MR), Independent Third Party Source Tests, February 7, 1992.

Florida Power and Light Fort Myers Repowering Project



RECEIVED

JAN 06 1993

Hopping Boyd Green & Sams

STATE OF FLORIDA DEPARTMENT OF ENVIRONMENTAL REGULATION

In the matter of:

Permit No.

AO 64-131230

Florida Fower & Light Company)
Sanford Flant Unit No. 3,

TFR-91-A-01

Petitioner.

ORDER ON REQUEST

FOR

REDUCTION IN QUARTERLY PARTICULATE EMISSIONS COMPLIANCE TESTING

Pursuant to Rule 17-296.405(1)(a), Florida Administrative Code (F.A.C.), Florida Fower and Light Company, petitioned for approval to reduce the frequency of particulate emissions compliance testing from quarterly to annual for Petitioner's Sanford Plant Unit No. 3, operation permit number AO 64-131230, located in Volusia County.

Having considered Petitioner's written request and all supporting documentation, the following Findings of Fact, Conclusions of Law, and Order are entered:

FINDINGS OF FACT

- 1. On May 21, 1991, Petitioner requested a reduction in the frequency of particulate emission compliance testing for the fossil fuel-fired steam generator known as Sanford Plant Unit Number 3. [Exhibit 1]
- 2. Petitioner asked that the frequency of particulate emission compliance testing be reduced from the initial quarterly basis required by Rule 17-296.405(1)(a), F.A.C., to an annual basis. [Exhibit 1]
- 3. The petition and supporting documentation indicate that Fetitioner has conducted the quarterly particulate emission compliance tests required by Rule 17-296.405(1)(a), F.A.C., with the exception of those quarters when the unit did not operate or natural gas was the primary fuel burned. [Exhibit 1]
- 4. Petitioner's submission included the results of thirteen particulate emission compliance tests that were conducted while Sanford Plant Unit Number 3 was operating at steady state conditions and six particulate emission compliance tests that were

conducted while soot blowing operations were being conducted.

5. The results of Petitioner's particulate emission compliance tests indicate that Sanford Unit Number 3 was in compliance with the applicable emission limiting standard for particulate matter from 1983 through 1991. [Exhibit 1]

CONCLUSIONS OF LAW

- 1. The Department has jurisdiction to consider Petitioner's request pursuant to Section 403.061, Florida Statutes (F.S.), and Rule 17-296.405(1)(a), F.A.C.
- 2. Pursuant to Rule 17-296.405(1)(a), F.A.C., the Department may reduce the required frequency of particulate matter compliance testing from quarterly to annual based upon a showing that the affected source has regularly complied with the emission limiting standard for particulate matter.
- 3. Pursuant to Rule 17-4.080, F.A.C., the petitioner may apply for changes to permit conditions and the Department may grant the request by requiring Petitioner to conform to new or additional requirements.
- 5. Pursuant to Rule 17-297.340(2), F.A.C., the Department may require the owner or operator of an air pollution source to conduct compliance testing whenever the Department has good reason to believe an applicable emission limiting standard is being violated.
- 6. Pursuant to Rules 17-4.070(3), 17-4.070(5), and 17-4.080(1), F.A.C., the Department may require Petitioner to return to the more frequent testing schedule in Rule 17-296.405(1)(a), F.A.C., if the emission limiting standard for particulate matter is not regularly complied with.

ORDER

Having considered Petitioner's written request and supporting documentation, it is hereby ordered that:

- 1. Petitioner's request for a reduction in the frequency of particulate matter compliance testing is granted;
- 2. During each federal fiscal year (October 1 September 30), Patitioner shall conduct one steady-state particulate emission compliance test of Sanford Plant Unit Number 3 and one particulate emission compliance test of Sanford Plant Unit Number 3 while it is being operated under soot blowing conditions;

- 3. Visible emissions from Sanford Plant Unit No. 3 shall not exceed forty (40) percent opacity, except as allowed by Rule 17-210.700(3), F.A.C.;
- 5. The annual particulate compliance test frequency specified in this order shall supersede the quarterly particulate compliance testing frequency specified for Sanford Unit Number 3 in operation permit AO 64-131230;
- 6. Pursuant to Rule 17-297.340(2), F.A.C., the Department reserves the right to require particulate matter compliance testing whenever the Department has good reason to believe the emission limiting standard for particulate is being violated; and,
- 7. Pursuant to Rules 17-4.070(3), 17-4.070(5), and 17-4.080(1), F.A.C., the Department reserves the right to require Petitioner to return to the more frequent testing schedule in Rule 17-256.405(1)(a), F.A.C., if the emission limiting standard for particulate matter is not regularly complied with.

PETITION FOR ADMINISTRATIVE REVIEW

- 1. A person whose substantial interests are affected by the Department's decision may petition for an administrative proceeding (hearing) in accordance with Section 120.57, F.S. The petition must contain the information set forth below and must be filed (received) in the Office of General Counsel of the Department et 2600 Blair Stone Road, Tallahassee, Florida 32399-2400, within 21 days of receipt of this Order. The petitioner shall mail a copy of the petition to the applicant at the time of filing. Failure to file a petition within this time period shall constitute a waiver of any right such person may have to request an administrative determination (hearing) under Section 120.57, F.S.
 - 2. The petition shall contain the following information:
- (a) The name, address, and telephone number of each petitioner, the applicant's name and address, and the Department File Number;
- (b) A statement of how and when each petitioner received notice of the Department's action or proposed action;
- (c) A statement of how each petitioner's substantial interests are affected by the Dapartment's action or proposed action;
- (d) A statement of the material facts disputed by each petitioner, if any;

- (e) A statement of facts which each petitioner contends warrant reversal or modification of the Department's action or proposed action;
- (f) A statement of which rules or statutes each petitioner contends require reversal or modification of the Department's action or proposed action; and,
- (g) A statement of the relief sought by each petitioner, stating precisely the action petitioner wants the Department to take with respect to the Department's action or proposed action.
- process is designed to formulate agency action. Accordingly, the Department's final action may be different from the position taken by it in this Order. Persons whose substantial interests will be affected by any decision of the Department with regard to the application have the right to petition to become a party to the proceeding. The petition must conform with the requirements specified above and be filed (received) within 21 days of receipt of this notice in the Office of General Counsel at 2600 Blair Stone Road, Tallahassee, Florida 32399-2400. Failure to petition within the allowed time frame constitutes a waiver of any right such person has to request a hearing under Section 120.57, F.S., and to participate as a party to this proceeding. Any subsequent intervention will only be at the approval of the presiding officer upon motion filed pursuant to Rule 28-5.207, F.A.C.
- 4. This Order constitutes final agency action unless a petition is filed in accordance with the above paragraphs or unless a request for extension of time in which to file a petition is filed within the time specified for filing a petition and conforms to Rule 17-103.070, F.A.C. Upon timely filing of a petition or a request for an extension of time this Order will not be effective until further Order of the Department.

RIGHT TO APPEAL

Any party to this Order has the right to seek judicial review of the Order pursuant to Section 120.68, F.S., by the filing of a Notice of Appeal pursuant to Rule 9.110, Florida Rules of Appellate Procedure, with the Clerk of the Department in the Office of General Counsel, 2600 Blair Stone Road, Tallahassee, Florida 32399-2400; and by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The Notice of Appeal must be filed within 30 days from the date the Notice of Agency Action is filed

CARLES OF THE SECOND CONTRACTOR OF THE CARLES OF THE CARLE

with the Clark of the Department.

DONE AND ORDERED this 2154 day of December, 1993 in Tallahasses, Ficrida.

STATE OF FLORIDA DEFARTMENT OF ENVIRONMENTAL REGULATION

CHOL N. BACHNER

Secretary Twin Towers Office Building 2600 Blair Stone Road Tallahassee, Florida 32399-2400

(904) 488-4805

CERTIFICATE OF SERVICE

G. ESTSVZZ

Assistant General Counsel

STATE OF FLORIDA DEPARTMENT OF ENVIRONMENTAL REGULATION

Twin Towers Office Building 2600 Blair Stone Road Tallahassee, Florida 33399-2400

Talephone (904) 488-9730

THE STATE OF FLORIDA DEPARTMENT OF ENVIRONMENTAL REGULATION

In the matter of:

Petition for Reduction in Quarterly Particulate Emissions Compliance Testing,

FLORIDA POWER & LIGHT COMPANY SANFORD PLANT UNIT NO. 4,

Petitioner.

OGC File No. 89-1454

RECEIVED

MAR 0 6 1990

ENV. PERMITTING

ORDER APPROVING REQUEST

FOR

REDUCTION IN QUARTERLY PARTICULATE EMISSIONS COMPLIANCE TESTING

Pursuant to Rule 17-2.600(5)(a)1, Florida Administrative Code (F.A.C.), Florida Power and Light Company, the Petitioner, submitted a request for reduction to quarterly particulate emissions compliance testing pursuant to Rule 17-2.600(5)(b)1, F.A.C., for the Sanford Plant Unit No. 4.

Having considered the Petitioner's Written request and all supporting documentation, the following Findings of Fact,

Conclusions of Law, and Order are entered:

FINDINGS OF FACT

- 1. On July 19, 1989, the Petitioner filed for reduction in quarterly particulate emissions compliance testing required by Rule 17-2.600(5)(b)1, F.A.C., for the fossil fuel fired steam generating unit at the Sanford Plant Unit No. 4.
- 2. Pursuant to Rule 17-2.600(5)(b)1, F.A.C., the Petitioner has conducted quarterly particulate emission

compliance tests.

3. The petition and supporting documentation submitted by the Petitioner indicate that the Petitioner demonstrated compliance during the third quarter of 1983, during 1984, 1986, 1987, and during 1988.

CONCLUSIONS OF LAW

- 1. The Department has jurisdiction to consider the Petitioner's request pursuant to Section 403.061, Florida Statutes, and Rule 17-2.600(5)(a)(1), F.A.C.
- 2. Rule 17-2.600(5)(b)1, F.A.C., provides that the Department may reduce the frequency of particulate testing if the standard of 0.1 pounds per million Btu heat input has been regularly met.

ORDER

Eaving considered the Petitioner's written request and supporting documentation, it is hereby ordered that:

- 1. The Petitioner's request for a reduction in quarterly particulate emissions compliance testing is GRANTED, and that:
 - a. The Petitioner's generating unit Sanford Plant Unit
 No. 4 shall be required to conduct one steady-state
 particulate emission compliance test annually and one
 particulate emission compliance test while the source
 is operating under soot blowing conditions.
 - b. Sanford Plant Unit No. 4 shall be subject to a steady-state visible emission limiting standard of forty (40) percent opacity.
 - c. This order supercedes all conflicting conditions

relating to frequency of particulate emission compliance testing contained in the operating permit AO64-132055 for Sanford Plant Unit No. 4. All other permit conditions of permit No. AO64-132055 shall remain the same.

d. The Department may require additional tests for particulate emissions pursuant to Rule 17-2.700(2)(b), F.A.C., if, after investigation, the Sanford Plant Unit No. 4 is believed to be violating applicable emission standards.

RIGHT TO APPEAL

Any party to this Order has the right to seek judicial review of the Order pursuant to Section 120.68, Florida Statutes, by the filing of a Notice of Appeal pursuant to Rule 9.110, Florida Rules of Appellate Procedure, with the Clerk of the Department in the Office of General Counsel, 2600 Blair Stone Road, Tallahassee, Florida 32399-2400; and by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The Notice of Appeal must be filed within 30 days from the date the Notice of Agency Action is filed with the Clerk of the Department.

PETITION FOR ADMINISTRATIVE REVIEW

1. A person whose substantial interests are affected by the Department's decision may petition for an administrative proceeding (hearing) in accordance with Section 120.57, Florida Statutes. The petition must contain the information set forth

below and must be filed (received) in the Office of General Counsel of the Department at 2600 Blair Stone Road, Tallahassee, Florida 32399-2400, within 21 days of receipt of this Order. At the time of filing, Petitioner shall mail a copy of the petition to the applicant at Florida Power and Light Company, 9250 West Flagler Street, Miami, Florida 33152. Failure to file a petition within this time period shall constitute a waiver of any right such person may have to request an administrative determination (hearing) under Section 120.57, Florida Statutes.

- 2. The petition shall contain the following information:
- (a) The name, address, and telephone number of each

 Petitioner, the applicant's name and address, and the Department

 File Number;
- (b) A statement of how and when each Petitioner received notice of the Department's action or proposed action;
- (c) A statement of how each Petitioner's substantial interests are affected by the Department's action or proposed action;
- (d) A statement of the material facts disputed by Petitioner, if any;
- (e) A statement of facts which Petitioner contends warrant reversal or modification of the Department's action or proposed action;
- (f) A statement of which rules or statutes Petitioner contends require reversal or modification of the Department's action or proposed action; and
 - (g) A statement of the relief sought by Petitioner, stating

precisely the action Petitioner wants the Department to take with respect to the Department's action or proposed action.

- 3. If a petition is filed, the administrative hearing process is designed to formulate agency action. Accordingly, the Department's final action may be different from the position taken by it in this Order. Persons whose substantial interests will be affected by any decision of the Department with regard to the applicant have the right to petition to become a party to the proceeding. The petition must conform to the requirements specified above and be filed (received) within 21 days of receipt of this notice in the Office of General Counsel at 2600 Blair Stone Road, Tallahassee, Florida 32399-2400. Failure to petition within the allowed time frame constitutes a waiver of any right such person has to request a hearing under Section 120.57, F.S., and to participate as a party to this proceeding. Any subsequent intervention will only be on the approval of the presiding officer upon motion filed pursuant to Rule 28-5.207, F.A.C.
- 4. This Order constitutes final agency action unless a petition is filed in accordance with the above paragraph or unless a request for extension of time in which to file a petition is filed within the time specified for filing a petition and conforms to Rule 17-103.070, F.A.C. Upon timely filing of a petition or a request for an extension of time this Order will not be effective until further Order of the Department.

DONE AND ORDERED this The day of Tellanassee, Florida.

STATE OF FLORIDA DEPARTMENT OF ENVIRONMENTAL REGULATION

FILING AND ACKNOWLEDGEMENT FILED, on this date, pursuant to \$120.52 Florida Statutes, with the designated Department Clork, receipt of which is hereby acknow-

leaged.

Carter 3

3-1.90

Date

DALE TWACHTMANN

Secretary

Twin Towers Office Building

2600 Elair Stone Road Tallahassee, Florida

32399-2400

(904) 488-4805

1

CERTIFICATE OF SERVICE

I HEREBY CERTIFY that a true copy of the foregoing Order has been mailed, postage prepaid, to Florida Power and Light Company, 9250 West Flagler Street, Miami, Florida 33152, this ______ day of Murch _____, 1990.

GARY SMALLRIDGE Assistant General Counsel

STATE OF FLORIDA DEPARTMENT OF ENVIRONMENTAL REGULATION

Twin Towers Office Building 2600 Blair Stone Road Tallahassee, Florida 32399-2400

Telephone (904) 488-9730

BEFORE THE STATE OF FLORIDA DEPARTMENT OF ENVIRONMENTAL REGULATION

In the Matter of;

Petition for Reduction in Quarterly Particulate Emissions Compliance Testing, Sanford Unit No. 5; PLORIDA POWER & LIGHT COMPANY

OGC Case No.: 85-1420

Petitioner.

CRDER

On December 26, 1984, the Petitioner, Plorida Power & Light Company, filed a Petition for Reduction in Quarterly Particulate Emissions Compliance Testing pursuant to Florida Administrative Code Rule 17-2.600(5)(b)1. for the following fossil fuel steam generating unit:

Sanford Unit No. 5

Pursuant to Plorida Administrative Code Rule

17-2.600(5)(b)1., Petitioner has conducted quarterly particulate emission compliance tests. Plorida Administrative Code Rule

17-2.600(5)(b)1. provides that the Department may reduce the frequency of particulate testing upon a demonstration that the particulate standard of 0.1 pounds per million Btu heat input has been regularly met. The petition and supporting documentation submitted by Petitioner indicate that, since September 8, 1983, Petitioner has regularly met the particulate standard. It is therefore,

ORDERED that the Petition for Reduction in Quarterly
Particulate Emissions Compliance Testing is GRANTED. Petitioner,
may immediately commence testing on an annual basis. Test results
from the first regularly scheduled compliance test conducted in
PY 86 (October 1, 1985 - September 30, 1986), provided the results
of that test meet the particulate standard and the 40% opacity,
standard, shall be accepted as results from the first annual test.

Failure of Sanford Unit 5 to meet wither the particulate standard or the 40% opacity standard in the future shall constitute grounds for revocation of this authorization.

Parsons whose substantial interests are affected by the above proposed agency action has a right, pursuant to Section 120.57, Florido Statutes, to petition for an administrative determination (hearing) on the proposed action. The Petition must conform to the requirements of Chapters 17-103 and 28-5, Florida Administrative Code, and must be filed (received) with the Department's Office of General Counsel, 2600 Blair Stone Road, Tallahassee, Florida 32301, within fourteen (14) days of publication of this notice. Failure to file a petition within the fourteen (14) days constitutes a waiver of any right such person has to an administrative determination (hearing) pursuant to Section 120.57, Florida Statutes.

If a patition is filed, the administrative hearing process is designed to formulate agency action. Accordingly, the Department's final action may be different from the proposed agency action. Persons whose substantial interests will be affected by any decision of the Department have the right to intervene in the proceeding. A petition for intervention must be filed pursuant to Model Rule 28-5.207, Florida Administrative Code, at least five (5) days before the final hearing and be filed with the Rearing Officer if one has been assigned at the Division of Administrative Mearings, Department of Administration, 2009 Apalachee Farkway, Tallahassee, Florida 32301. If no Esaring Officer has been assigned, the petition is to be filed with the pepartment's Office of General Counsel, 2500 Blair Stone Road, Tallmhassee, Florida 32301. Pailure to petition to intervene within the allowed time frame constitutes a waiver of any right such person has to an administrative determination (hearing) under Section 120.57, Florida Statutes.

Best Available Copy

DONE AND ORDERED this 2 day of January, 1986, in Tallahassee, Florida.

STATE OF FLORIDA DEPARTMENT OF ENVIRONMENTAL REGULATION

TUNG AND ACKNOWLEDGEMENT

In this date, pursuent to \$120.52 (9), . . Statutes, with the designated Departitus, receipt of which is hereby acknow-

Record Brown 1-3-86

Secretary
Twin Towers Office Building

Twin Towers Office Building 2600 Hlair Stone Road Tallahassee, Plorida 32301 Talephone (904) 488-4805

CERTIFICATE OF SERVICE

I HEREBY CERTIFY that a true and correct copy of the foregoing ORDER has been furnished by United States Mail to Peter C. Cunningham, Esquire, Hopping, Boyd, Green & Sams, Post Office Box 6326, Tallahaszee, Florida 32314, on this A day of January, 1986, in Tallahassee, Florida.

B. GARY EARLY Assistant General Counsel

STATE OF FLORIDA DEPARTMENT OF ENVIRONMENTAL REGULATION Twin Towers Office Building 2600 Blair Stone Road Tallahassee, Florida 32301 (904) 488-9730 Phase II Acid Rain Part- Page 1

RECEIVED

AUG 3 0 2002

BUREAU OF AIR REGULATION

Phase II Acid Rain Part Application

For more information, see instructions and refer to 40 CFR 72.30 and 72.31 and Chapter 62-214, F.A.C.

□ Revised

STEP 1
Identify the source by plant name, State, and ORIS code from NADB

Plant Name Sanford Plant	•	State FL	ORIS Code 000620

STEP 2 Enter the unit ID# for each affected unit and indicate whether a unit is being repowered and the repowering plan being renewed by entering "yes" or "no" at column c. For new units, enter the requested information in columns d and e.

Compliance Plan					
	а	b	c .	đ	e
	Unit ID#	Unit will hold allowances in accordance	Repowering Plan	New Units	New Units
		with 40 CFR 72.9(c)(1)		Commence Operation Date	Monitor Certification Deadline
	PSN3	Yes	N/A	N/A	N/A
	PSNCT4A	Yes	N/A	12/16/2002	3/16/2003
	PSNCT4B	Yes	N/A	12/23/2002	3/23/2002
	PSNCT4C	Yes	N/A	12/30/2002	3/30/2003
	PSNCT4D	Yes	N/A	1/06/2003	4/6/2003
	PSNCT5A	Yes	N/A	2/21/2002	5/6/2002
	PSNCT5B	Yes	N/A	2/25/2002	5/7/2002
	PSNCT5C	Yes	N/A	3/4/2002	5/8/2002
	PSNCT5D		N/A	3/11/2002	5/13/2002

STEP 3
Check the box if the response in column c of Step 2 is "Yes" for any unit

For each unit-that is being repowered, the Repowering Extension Plan form is included.

Yes

Plant Name (from Step 1)

STEP 4 Read the standard requirements and certification, enter the name of the designated representative, and sign and date

Standard Requirements

Acid Rain Part Requirements.

- (1) The designated representative of each Acid Rain source and each Acid Rain unit at the source shall:
 - (i) Submit a complete Acid Rain part application (including a compliance plan) under 40 CFR part 72 and Rules 62-214.320 and 330, F.A.C., in accordance with the deadlines specified in Rule 62-214.320, F.A.C.; and
 - (ii) Submit in a timely manner any supplemental information that the Department determines is necessary in order to review an Acid Rain part application and issue or deny an Acid Rain part;
- (2) The owners and operators of each Acid Rain source and each Acid Rain unit at the source shall:
 - (i) Operate the unit in compliance with a complete Acid Rain part application or a superseding Acid Rain part issued by the Department; and
 - (ii) Have an Acid Rain Part.

Monitoring Requirements.

- (1) The owners and operators and, to the extent applicable, designated representative of each Acid Rain source and each Acid Rain unit at the source shall comply with the monitoring requirements as provided in 40 CFR part 75, and Rule 62-214.420, F.A.C.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program.
- (3) The requirements of 40 CFR part 75 shall not affect the responsibility of the owners and operators to monitor emissions of other pollutants or other emissions characteristics at the unit under other applicable requirements of the Act and other provisions of the operating permit for the source.

Sulfur Dioxide Requirements.

- (1) The owners and operators of each source and each Acid Rain unit at the source shall:
 - (i) Hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)) not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and
 - (ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide.
- (2) Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act.
- (3) An Acid Rain unit shall be subject to the requirements under paragraph (1) of the sulfur dioxide requirements as follows:
 - (i) Starting January 1, 2000, an Acid Rain unit under 40 CFR 72.6(a)(2); or
 - (ii) Starting on the later of January 1, 2000 or the deadline for monitor certification under 40 CFR part 75, an Acid Rain unit under 40 CFR 72.6(a)(3).
- (4) Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program.
- (5) An allowance shall not be deducted in order to comply with the requirements under paragraph (1)(i) of the sulfur dioxide requirements prior to the calendar year for which the allowance was allocated.
- (6) An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain part application, the Acid Rain part, or an exemption under 40 CFR 72.7, 72.8, or 72.14 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization.
- (7) An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right.

<u>Nitrogen Oxides Requirements.</u> The owners and operators of the source and each Acid Rain unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides.

Excess Emissions Requirements.

- (1) The designated representative of an Acid Rain unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR part 77.
- (2) The owners and operators of an Acid Rain unit that has excess emissions in any calendar year shall:
 - (i) Pay without demand the penalty required, and pay upon demand the interest on that penalty, as required by 40 CFR part 77; and
 - (ii) Comply with the terms of an approved offset plan, as required by 40 CFR part 77.

Recordkeeping and Reporting Requirements.

- (1) Unless otherwise provided, the owners and operators of the source and each Acid Rain unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 5 years, in writing by the EPA or the Department:
 - (i) The certificate of representation for the designated representative for the source and each Acid Rain unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with Rule 62-214.350, F.A.C.; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative;

 (ii) All emissions monitoring information, in accordance with 40 CFR part 75, provided that to the extent that 40 CFR part 75 provides for a 3-

year period for recordkeeping, the 3-year period shall apply;

(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the Acid Rain Program; and.

Plant Name (from Step 1)

Recordkeeping and Reporting Requirements (cont)

- (iv) Copies of all documents used to complete an Acid Rain part application and any other submission under the Acid Rain Program or to demonstrate compliance with the requirements of the Acid Rain Program.
- (2) The designated representative of an Acid Rain source and each Acid Rain unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR part 72 subpart I and 40 CFR part 75.

Liability

- (1) Any person who knowingly violates any requirement or prohibition of the Acid Rain Program, a complete Acid Rain part application, an Acid Rain part, or an exemption under 40 CFR 72.7, 72.8 or 72.14, including any requirement for the payment of any penalty owed to the United States, shall be subject to enforcement pursuant to section 113(c) of the Act.
- (2) Any person who knowingly makes a false, material statement in any record, submission, or report under the Acid Rain Program shall be subject to criminal enforcement pursuant to section 113(c) of the Act and 18 U.S.C. 1001.
- (3) No permit revision shall excuse any violation of the requirements of the Acid Rain Program that occurs prior to the date that the revision takes effect.
- (4) Each Acid Rain source and each Acid Rain unit shall meet the requirements of the Acid Rain Program.
- (5) Any provision of the Acid Rain Program that applies to an Acid Rain source (including a provision applicable to the designated representative of an Acid Rain source) shall also apply to the owners and operators of such source and of the Acid Rain units at the source.
- (6) Any provision of the Acid Rain Program that applies to an Acid Rain unit (including a provision applicable to the designated representative of an Acid Rain unit) shall also apply to the owners and operators of such unit. Except as provided under 40 CFR 72.44 (Phase II repowering extension plans) and 40 CFR 76.11 (NO_X averaging plans), and except with regard to the requirements applicable to units with a common stack under 40 CFR part 75 (including 40 CFR 75.16, 75.17, and 75.18), the owners and operators and the designated representative of one Acid Rain unit of the liable for any violation by any other Acid Rain unit of which they are not owners or operators or the designated representative and that is located at a source of which they are not owners or operators or the designated representative.
- (7) Each violation of a provision of 40 CFR parts 72, 73, 75, 76, 77, and 78 by an Acid Rain source or Acid Rain unit, or by an owner or operator or designated representative of such source or unit, shall be a separate violation of the Act.

Effect on Other Authorities. No provision of the Acid Rain Program, an Acid Rain part application, an Acid Rain part, or an exemption under 40 CFR 72.7, 72.8, or 72.14 shall be construed as:

- (1) Except as expressly provided in title IV of the Act, exempting or excluding the owners and operators and, to the extent applicable, the designated representative of an Acid Rain source or Acid Rain unit from compliance with any other provision of the Act, including the provisions of title I of the Act relating to applicable National Ambient Air Quality Standards or State Implementation Plans;
- (2) Limiting the number of allowances a unit can hold; provided, that the number of allowances held by the unit shall not affect the source's obligation to comply with any other provisions of the Act;
- (3) Requiring a change of any kind in any State law regulating electric utility rates and charges, affecting any State law regarding such State regulation, or limiting such State regulation, including any prudence review requirements under such State law;
- (4) Modifying the Federal Power Act or affecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act; or,
- (5) Interfering with or impairing any program for competitive bidding for power supply in a State in which such program is established.

Certification

I am authorized to make this submission on behalf of the owners and operators of the Acid Rain source or Acid Rain units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name David W. Knutson		
Signature Qual	Kuntson	Date 8-26-02

Acid Rain Program Instructions for Phase II Acid Rain Part Application (40 CFR 72.30 - 72.31 and Rule 62-214.320, F.A.C.)

The Acid Rain Program regulations require the designated representative to submit an Acid Rain part application for Phase II for each source with an Acid Rain unit. A complete Phase II part application is binding on the owners and operators of the Acid Rain source and is enforceable in the absence of an Acid Rain part until the permitting authority either issues an Acid Rain part to the source or disapproves the application.

Please type or print. The alternate designated representative may sign in lieu of the designated representative. If assistance is needed, contact the title V permitting authority.

- STEP 1 Use the plant name and ORIS Code listed on the Certificate of Representation for the plant. An ORIS code is a 4 digit number assigned by the Energy Information Agency (EIA) at the U.S. Department of Energy to power plants owned by utilities. If the plant is not owned by a utility but has a 5 digit facility code (also assigned by EIA), use the facility code. If no code has been assigned or if there is uncertainty regarding what the code number is, contact EIA at (202) 426-1234 (for ORIS codes), or (202) 426-1269 (for facility codes).
- STEP 2 For column "a," identify each Acid Rain unit at the Acid Rain source by providing the appropriate unit identification numbers, consistent with the unit identification numbers entered on the Certificate of Representation, with unit identification numbers listed in NADB (for units that commenced operation prior to 1993), and with unit identification numbers used in reporting to DOE and/or EIA. For new units without identification numbers, owners and operators may assign such numbers consistent with EIA and DOE requirements. NADB is the National Allowance Data Base for the Acid Rain Program, and can be downloaded from the Acid Rain Program Website at "www.epa.gov/acidrain/" or obtained on diskette by calling the Acid Rain Hotline. This data file is in dBase format for use on an IBM-compatible PC and requires 2 megabytes of hard drive memory.

For column "c," enter "yes" only if a repowering technology petition has been approved for the unit by U.S. EPA, an initial repowering extension plan was approved by the title V permitting authority and activated by the designated representative, and a repowering extension plan renewing the original repowering extension plan has been included with the current acid rain part application for that unit.

For columns "d" and "e," enter the commence operation date(s) and monitor certification deadline(s) for new units in accordance with 40 CFR 75.4. If the commence operation date or monitor certification date changes after the Phase II part is issued, the designated representative must submit a request for an administrative correction under Rule 62-214.370(6), F.A.C.

Submission Deadlines

For new units, an initial Phase II part application must be submitted to the title V permitting authority at least 24 months before the date the unit commences operation. Phase II acid rain renewal applications must be submitted at least 6 months in advance of the expiration of the acid rain portion of a title V permit, or such longer time as provided for under the title V permitting authority's operating permits regulation.

Submission Instructions

Submit this form and 1 copy to the appropriate title V air permitting authority. If you have questions regarding this form, contact your local, State, or EPA Regional acid rain contact, or call EPA's Acid Rain Hotline at (202) 564-9620.

DEP Form No. 62-210.900(1)(a) - Instructions Effective: 4-16-01