Appendix I-1, List of Insignificant Emissions Units and/or Activities.

North Florida / South Georgia Veterans Health System
Malcom Randall Veterans Affairs Medical Center
Gainesville Division

Proposed Permit No.: 0010041-008-AV
Facility ID No.: 0010041

The facilities, emissions units, or pollutant-emitting activities listed in Rule 62-210.300(3)(a), F.A.C., Categorical Exemptions, or that meet the criteria specified in Rule 62-210.300(3)(b)1., F.A.C., Generic Emissions Unit Exemption, are exempt from the permitting requirements of Chapters 62-210, 62-212 and 62-4, F.A.C.; provided, however, that exempt emissions units shall be subject to any applicable emission limiting standards and the emissions from exempt emissions units or activities shall be considered in determining the potential emissions of the facility containing such emissions units. Emissions units and pollutant-emitting activities exempt from permitting under Rules 62-210.300(3)(a) and (b)1., F.A.C., shall not be exempt from the permitting requirements of Chapter 62-213, F.A.C., if they are contained within a Title V source; however, such emissions units and activities shall be considered insignificant for Title V purposes provided they also meet the criteria of Rule 62-213.430(6)(b), F.A.C. No emissions unit shall be entitled to an exemption from permitting under Rules 62-210.300(3)(a) and (b)1., F.A.C., if its emissions, in combination with the emissions of other units and activities at the facility, would cause the facility to emit or have the potential to emit any pollutant in such amount as to make the facility a Title V source.

The below listed emissions units and/or activities are considered insignificant pursuant to Rule 62-213.430(6), F.A.C.

Brief Description of Emissions Units and/or Activities

Emergency Generators (diesel fuel fired, meeting exemption criteria of Rule 62-210.300(3)(a)35, F.A.C. Collectively burns less than 32,000 gallons of diesel fuel per year):

- 1275 kW Caterpillar
- 600 kW Caterpillar
- 600 kW Caterpillar
- 600 kW Caterpillar
- 600 kW Caterpillar
- 275 kW Detroit Diesel
- 150 kW Caterpillar

Ethylene Oxide sterilizers:

- AMSCO 3048
- AMSCO Eagle 3017
- AMSCO Eagle 3017

Fuel Storage Tanks:

- Two 30,000 gallon diesel underground storage tanks
- One 2,500 gallon diesel underground storage tank
- One 300 gallon gasoline storage tank