Table 2-1, Summary of Compliance Requirements

North Florida / South Goregia Veterans Health System
Malcom Randall Veterans Affairs Medical Center
Gainesville Division

Proposed Permit No.: 0010041-008-AV
Facility ID No.: 0010041

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	Brief Description
-001	Keeler 250 hp boiler
-002	Keeler 250 hp boiler
-003	Keeler 250 hp boiler

The compliance requirements listed apply to each of the Emissions Units listed above.

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date*	Min. Compliance Test Duration	CMS**	See permit condition(s)
PM	natual gas or #2 Fuel Oil	Meeting Opacity standard and firing natural gas/low sulfur No. 2 fuel oil					III.A.5.a.
PM	sooth blowoing	EPA Method 5	Annually while sootblowing		60 minutes		III.A.7,b,
SO2	natual gas or #2 Fuel Oil	Sulfur Content					III.A.8.
VE	natual gas or #2 Fuel Oil	DEP Method 9	Annually if fuel oil fired 400 hrs/yr or more				III.A.6.a.
VE	sootblowing	EPA Method 9	Annually while sootblowing				III.A.6.b.

Notes:
*Frequency base date established for planning purposes only; see guidance memo DARM-SS/CE-03 and Rule 62-297.310, F.A.C.
Particulate Matter complaince shall be demonstrated with compliance with the Opacity standard. EPA Method 5 may be required upon Department request.
**CMS [=] continuous monitoring system

[electronic file name: 00100412.xls]

Table 2-2, Summary of Compliance Requirements

North Florida / South Goregia Veterans Health System
Malcom Randall Veterans Affairs Medical Center
Gainesville Division

Proposed Permit No. 0010041-008-AV
Facility ID No.: 0010041

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	Brief Description
-006	Hospital/Medical/Infectious Waste Incinerator

The compliance requirements listed apply to each of the Emissions Units listed above.

Applicable after 40 CFR 60 Subpart Ce compliance test date

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date*	Min. Compliance Test Duration	CMS**	See permit condition(s)
Particulate Matter	HMIW	EPA Method 5 or 29	Annual over 3-year period ***	26-Jul-01	60 min.		III.B.22.
Carbon Monoxide	HMIW	EPA Method 10 or 10B	Annual over 3-year period ***	26-Jul-01	60 min.		III.B.23.
Dioxin/Furans	HMIW	EPA Method 23	Every 5 years, prior to Renewal	Prior to AO Renewal	4 hrs.		III.B.24.
Hydrogen Chloride	HMIW	EPA Method 26	Annual over 3-year period ***	26-Jul-01	60 min.		III.B.26.
Sulfur Dioxide	HMIW	EPA Method 6 or 6C	Every 5 years, prior to Renewal	Prior to AO Renewal	60 min.		III.B.27.
NOx	HMIW	EPA Method 7 or 7E	Every 5 years, prior to Renewal	Prior to AO Renewal	60 min.		III.B.28.
Lead	HMIW	EPA Method 29	Every 5 years, prior to Renewal	Prior to AO Renewal	60 min.		III.B.25.
Cadmium	HMIW	EPA Method 29	Every 5 years, prior to Renewal	Prior to AO Renewal	60 min.		III.B.25.
Mercury	HMIW	EPA Method 29	Every 5 years, prior to Renewal	Prior to AO Renewal	60 min.		III.B.25.
Visible Emissions	HMIW	EPA Method 9	Annual	26-Jul-01	60 min.		III.C.22.

Notes:
*Frequency base date established for planning purposes only; Rule 62-297.310, F.A.C.
**CMS [=] continuous monitoring system
***If all three performance tests over a 3-year period indicate compliance with the emission limit for PM, the owner or operator may forego a performance test for that pollutant for the subsequent 2 years.

Table 2-3, Summary of Compliance Requirements

North Florida / South Goregia Veterans Health System
Malcom Randall Veterans Affairs Medical Center
Gainesville Division

Proposed Permit No.: 0010041-008-AV
Facility ID No.: 0010041

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	Brief Description
007	Emergency Stationary Internal Combustion Engine No.1
008	Emergency Stationary Internal Combustion Engine No.2
009	Emergency Stationary Internal Combustion Engine No.3
010	Emergency Stationary Internal Combustion Engine No.4

Pollutant Name	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date*	Min. Compliance Test Duration	CMS**	See permit condition(s)
HC	Diesel	in-use testing procedures in 40 CFR part 1039, subpart F	upon request				C.11
CO	Diesel		upon request				C.11
Nox	Diesel		upon request				C.11
PM	Diesel		upon request				C.11

Notes:
*Frequency base date established for planning purposes only; Rule 62-297.310, F.A.C.
**CMS [=] continuous monitoring system