

## APPENDIX C

### NSPS SUBPART GG REQUIREMENTS FOR GAS TURBINES

The following emissions unit is subject to the applicable requirements of Subpart A (General Provisions) and Subpart GG (Stationary Gas Turbines) established as New Source Performance Standards in 40 CFR 60 and adopted by reference in Rule 62-204.800(7)(b), F.A.C.

EU ID	Emission Unit Description
003	Gas Turbine Compressor No. 1607

#### NSPS General Provisions

The emissions units are subject to the applicable General Provisions of the New Source Performance Standards including 40 CFR 60.7 (Notification and Record Keeping), 40 CFR 60.8 (Performance Tests), 40 CFR 60.11 (Compliance with Standards and Maintenance Requirements), 40 CFR 60.12 Circumvention), 40 CFR 60.13 (Monitoring Requirements), and 40 DFR 60.19 (General Notification and Reporting Requirements). The General Provisions are not included in this permit, but can be obtained from the Department upon request.

#### 40 CFR 60, Subpart GG Standards of Performance for Stationary Gas Turbines

*{Permitting Note: Each gas turbine shall comply with all applicable requirements of 40 CFR 60, Subpart GG adopted by reference in Rule 62-204.800(7)(b), F.A.C. Inapplicable provisions have been deleted in the following conditions, but the numbering of the original rules has been preserved for ease of reference. The term "Administrator" when used in 40 CFR 60 shall mean the Department's Secretary or the Secretary's designee. Department notes and requirements related to the Subpart GG requirements are shown in italics immediately following the section to which they refer. The rule basis for the Department requirements specified below is Rule 62-4.070(3), F.A.C.}*

#### 40 CFR 60.330 - Applicability and Designation of Affected Facility.

(a) The provisions of this subpart are applicable to the following affected facilities: All stationary gas turbines with a heat input at peak load equal to or greater than 10.7 gigajoules (10 million Btu) per hour, based on the lower heating value of the fuel fired.

#### 40 CFR 60.331 – Definitions

(g) *ISO standard day conditions* means 288 degrees Kelvin, 60 percent relative humidity and 101.3 kilopascals pressure.

(i) *Peak load* means 100 percent of the manufacturer's design capacity of the gas turbine at ISO standard day conditions.

(j) *Base load* means the load level at which a gas turbine is normally operated.

#### 40 CFR 60.332 – Standard for Nitrogen Oxides

(a) On and after the date on which the performance test required by 60.8 is completed, every owner or operator subject to the provisions of this subpart as specified in paragraphs (c) of this section shall comply with:

(2) No owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any stationary gas turbine, any gases which contain nitrogen oxides in excess of:

$$STD = 0.0150 \frac{(14.4)}{Y} + F$$

where:

STD = allowable NO<sub>x</sub> emission concentration (percent by volume at 15 percent oxygen and on a dry basis),

## APPENDIX C

### NSPS SUBPART GG REQUIREMENTS FOR GAS TURBINES

Y = manufacturer's rated heat rate at manufacturer's rated peak load (kilojoules per watt hour), or actual measured heat rate based on lower heating value of fuel as measured at actual peak load for the facility. The value of Y shall not exceed 14.4 kilojoules per watt hour, and

F = NOX emission allowance for fuel-bound nitrogen as defined in paragraph (a)(4) of this section.

(3) F shall be defined according to the nitrogen content of the fuel as follows:

Fuel-bound nitrogen (percent by weight)	F (NOx percent by volume)
$N \leq 0.015$	0
$0.015 < N \leq 0.1$	0.04(N)
$0.1 < N \leq 0.25$	$0.004 + 0.0067(N - 0.1)$
$N > 0.25$	0.005

Where:

N = the nitrogen content of the fuel (percent by weight).

Department Requirement: When firing natural gas, the "F" value shall be assumed to be 0.

*{Permitting Note: The "Y" value for this gas is approximately 12.2 for natural gas. The equivalent emission standard is 177 ppmvd corrected to 15% oxygen. The emissions standards specified in this permit are much more stringent than this requirement.}*

(c) Stationary gas turbines with a heat input at peak load equal to or greater than 10.7 gigajoules per hour (10 million Btu/hour) but less than or equal to 107.2 gigajoules per hour (100 million Btu/hour) based on the lower heating value of the fuel fired, shall comply with the provisions of paragraph (a)(2) of this section.

#### 40 CFR 60.333 - Standard for sulfur dioxide.

On and after the date on which the performance test required to be conducted by § 60.8 is completed, every owner or operator subject to the provision of this subpart shall comply with the following condition:

(b) No owner or operator subject to the provisions of this subpart shall burn in any stationary gas turbine any fuel which contains total sulfur in excess of 0.8 percent by weight (8000 ppmw).

*{Permitting Note: The gas turbines will exclusively fire natural gas, which contains less than 0.3% sulfur by weight assuming a density of 0.0455 lb/scf of natural gas.}*

#### 40 CFR 60.334 - Monitoring of Operations.

(c) For the purpose of reports required under Section 60.7(c), periods of excess emissions that shall be reported are defined as follows:

- (1) Nitrogen oxides. Any one-hour period during which the average water-to-fuel ratio, as measured by the continuous monitoring system, falls below the water-to-fuel ratio determined to demonstrate compliance with Section 60.332 by the performance test required in Section 60.8 or any period during which the fuel-bound nitrogen of the fuel is greater than the maximum nitrogen content allowed by the fuel-bound nitrogen allowance used during the performance test required in Section 60.8. Each report shall include the average water-to-fuel ratio, average fuel consumption, ambient conditions, gas turbine load, and nitrogen content of the fuel during the period of excess emissions, and the graphs or figures developed under Section 60.335(a).

*{Permitting Note: Excess NOx emissions reporting requirements do not apply. The gas turbine uses "dry" lean premix combustors and not wet injection to control NOx emissions. As indicated above, the Subpart GG NOx standard is 177 ppmvd @ 15% oxygen. This is nearly eight times the NOx standard specified in the permit and would be nearly impossible for this lean premix combustion turbine to exceed. As stated in*

---

**APPENDIX C**  
**NSPS SUBPART GG REQUIREMENTS FOR GAS TURBINES**

---

*the preamble to the July 2004 amendments, the rule changes do not impose any additional monitoring requirements for existing units.}*

(h) The owner or operator of any stationary gas turbine subject to the provisions of this subpart:

(2) Shall monitor the nitrogen content of the fuel combusted in the turbine, if the owner or operator claims an allowance for fuel bound nitrogen (i.e., if an F-value greater than zero is being or will be used by the owner or operator to calculate STD in Sec. 60.332).

*{Permitting Note: Because the nitrogen content of pipeline natural gas is negligible, the permittee does not claim an allowance for fuel bound nitrogen and will use "0" for the F-value when calculating the NOx standard in 60.332. The permit prohibits the permittee from claiming the allowance for fuel nitrogen. Therefore, no fuel nitrogen monitoring is required. The fuel monitoring provisions were revised pursuant to the final July 2004 amendments to Subpart GG.}*

(3) May elect not to monitor the total sulfur content of the gaseous fuel combusted in the turbine, if the gaseous fuel is demonstrated to meet the definition of natural gas in Sec. 60.331(u), regardless of whether an existing custom schedule approved by the administrator for subpart GG requires such monitoring.

60.331(u) states, "Natural gas means a naturally occurring fluid mixture of hydrocarbons (e.g., methane, ethane, or propane) produced in geological formations beneath the Earth's surface that maintains a gaseous state at standard atmospheric temperature and pressure under ordinary conditions. Natural gas contains 20.0 grains or less of total sulfur per 100 standard cubic feet. Equivalents of this in other units are as follows: 0.068 weight percent total sulfur, 680 parts per million by weight (ppmw) total sulfur, and 338 parts per million by volume (ppmv) at 20 degrees Celsius total sulfur. Additionally, natural gas must either be composed of at least 70 percent methane by volume or have a gross calorific value between 950 and 1100 British thermal units (Btu) per standard cubic foot. Natural gas does not include the following gaseous fuels: landfill gas, digester gas, refinery gas, sour gas, blast furnace gas, coal-derived gas, producer gas, coke oven gas, or any gaseous fuel produced in a process which might result in highly variable sulfur content or heating value."

The permittee elects not to monitor the sulfur content of natural gas based on 60.334(h)(3)(i), which states that, "The gas quality characteristics in a current, valid purchase contract, tariff sheet or transportation contract for the gaseous fuel, specifying that the maximum total sulfur content of the fuel is 20.0 grains/100 scf or less." The current tariff sheet specifies the natural gas delivered by the pipeline system shall contain not more than 10 grains of total sulfur per 100 cubic feet of gas. Therefore, the pipeline natural gas meets the above definition.

*{Permitting Note: The permit prohibits the permittee from claiming the allowance for fuel nitrogen. The permit also requires the gas turbine to fire only pipeline natural gas with a maximum sulfur content of 10 grains of sulfur per 100 cubic feet of gas. Therefore, no fuel nitrogen or fuel sulfur monitoring is required. The fuel monitoring provisions were revised pursuant to the final July 2004 amendments to Subpart GG.}*

**40 CFR 60.335 - Test methods and Procedures.**

- (a) To compute the nitrogen oxides emissions, the owner or operator shall use analytical methods and procedures that are accurate to within 5 percent and are approved by the Administrator to determine the nitrogen content of the fuel being fired.
- (b) In conducting the performance tests required in Section 60.8, the owner or operator shall use as reference methods and procedures the test methods in appendix A of this part or other methods and procedures as specified in this section, except as provided for in Section 60.8(b). Acceptable alternative methods and procedures are given in paragraph (f) of this section.

## APPENDIX C

### NSPS SUBPART GG REQUIREMENTS FOR GAS TURBINES

- (c) The owner or operator shall determine compliance with the nitrogen oxides and sulfur dioxide standards in Sections 60.332 and 60.333(a) as follows:

- (1) The nitrogen oxides emission rate (NO<sub>x</sub>) shall be computed for each run using the following equation:

$$\text{NO}_x = (\text{NO}_{x0}) (\text{Pr}/\text{Po})^{0.5} e^{19(\text{Ho} - 0.00633)} (288^\circ\text{K}/\text{Ta})^{1.53}$$

where:

NO<sub>x</sub> = emission rate of NO<sub>x</sub> at 15 percent O<sub>2</sub> and ISO standard ambient conditions, volume percent.

NO<sub>x0</sub> = observed NO<sub>x</sub> concentration, ppm by volume.

Pr = reference combustor inlet absolute pressure at 101.3 kilopascals ambient pressure, mm Hg.

Po = observed combustor inlet absolute pressure at test, mm Hg.

Ho = observed humidity of ambient air, g H<sub>2</sub>O/g air.

e = transcendental constant, 2.718.

Ta = ambient temperature, °K.

Department Requirement: The permittee is required to correct NO<sub>x</sub> emissions to ISO ambient atmospheric conditions for each required emissions performance test and compare to the NO<sub>x</sub> standard specified in 40 CFR 60.332.

- (2) The monitoring device of Section 60.334(a) shall be used to determine the fuel consumption and the water-to-fuel ratio necessary to comply with Section 60.332 at 30, 50, 75, and 100 percent of peak load or at four points in the normal operating range of the gas turbine, including the minimum point in the range and peak load. All loads shall be corrected to ISO conditions using the appropriate equations supplied by the manufacturer.

Department Requirement: The initial NO<sub>x</sub> performance tests shall be conducted at approximately four evenly spaced points between the minimum normal operating load and 100% of peak load.

{Permitting Note: Although the dry low-NO<sub>x</sub> combustion controls are only effective above a minimum load of approximately 50%, the proposed gas turbines are able to quickly ramp up above this level. Gas turbines used as compressor engines typically operate at permitted capacity. Excluding startup and shutdown, the permit requires operation above 50% load. The minimum normal operating load will be identified during initial testing.}

- (3) Method 20 shall be used to determine the nitrogen oxides, sulfur dioxide, and oxygen concentrations. The span values shall be 300 ppm of nitrogen oxide and 21 percent oxygen. The NO<sub>x</sub> emissions shall be determined at each of the load conditions specified in paragraph (c)(2) of this section.

Department Requirement: The span value shall be no greater than 75 ppm of nitrogen oxides due to the low NO<sub>x</sub> emission levels of the specified gas turbine.

- (d) The owner or operator shall determine compliance with the sulfur content standard in Section 60.333(b) as follows: ASTM D 2880-71 shall be used to determine the sulfur content of liquid fuels and ASTM D 1072-80, D 3031-81, D 4084-82, or D 3246-81 shall be used for the sulfur content of gaseous fuels (incorporated by reference--see Section 60.17). The applicable ranges of some ASTM methods mentioned above are not adequate to measure the levels of sulfur in some fuel gases. Dilution of samples before analysis (with verification of the dilution ratio) may be used, subject to the approval of the Administrator.

## APPENDIX C

---

### NSPS SUBPART GG REQUIREMENTS FOR GAS TURBINES

---

- (e) To meet the requirements of Section 60.334(b), the owner or operator shall use the methods specified in paragraphs (a) and (d) of this section to determine the nitrogen and sulfur contents of the fuel being burned. The analysis may be performed by the owner or operator, a service contractor retained by the owner or operator, the fuel vendor, or any other qualified agency.

*{Permitting Note: The permit prohibits the permittee from claiming the allowance for fuel nitrogen. The permit also requires the gas turbine to fire only pipeline natural gas with a maximum sulfur content of 10 grains of sulfur per 100 cubic feet of gas. Therefore, no fuel nitrogen or fuel sulfur monitoring is required. The fuel monitoring provisions were revised pursuant to the final July 2004 amendments to Subpart GG.}*