



Florida Department of Environmental Protection

Central District
3319 Maguire Boulevard, Suite 232
Orlando, Florida 32803-3767

Rick Scott
Governor

Jennifer Carroll
Lt. Governor

Herschel T. Vinyard Jr.
Secretary

Electronically sent – Received Receipt requested

March 26, 2012

Ms. Kim Scroggs
45 SW/CEA
1224 Jupiter Street
Patrick AFB, FL 32925-3343

Dear Ms. Scroggs:

In response to the Permit Exemption Request for Deluge Pumps at Cape Canaveral Air Force Station (CCAFS), Facility ID #0090005 received by the Department on November 28, 2011, the Department has determined that the deluge pumps meet the definition of emergency stationary RICE as indicated in 40 CFR Part 63, Subpart ZZZZ. The pumps shall operate according to the conditions listed in **§63.6640(f)(i), (ii), and (iii)** of 40 CFR Part 63, Subpart ZZZZ and shall meet **the requirements of Category 4 of Table 2d to Subpart ZZZZ of Part 63 – Requirements for Existing Stationary RICE Located at Area Sources of HAP Emissions**. These requirements for the deluge pump engines are primarily work practices (change oil, inspect air filter, and hoses...) and are part of the **Revised Draft** Title V Operation Permit Renewal No. 0090005-011-AV.

Sincerely,

Caroline D. Shine
District Air Program Administrator

March 26, 2012

Date

CDS/jr/tla

Ms. Kim Scroggs: kim.scroggs@patrick.af.mil
Brigadier General Anthony J. Cotton: 45swcce@patrick.af.mil
Mr. Brian L. Barfus, P.E.: brianbarfus@earthlink.net
Mr. R. Michael Willard: Michael.willard@patrick.af.mil