

Table 1-1, Summary of Air Pollutant Standards and Terms

ANHEUSER-BUSCH, INC.
JACKSONVILLE BREWERY

PROPOSED PERMIT NO.: 0310006-009-AV
FACILITY ID NO.: 0310006

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

Note: The "Equivalent Emissions" listed are for informational purposes only.

Eu ID No.	Pollutant Name	Fuel(s)	Hours/Year	Allowable Emissions			Equivalent Emissions*		Regulatory Citation(s)	See permit condition(s)
				Standard(s)	lbs./hour	TPY	lbs./hour	TPY		
001	PM	No. 6 F.O.	8760	0.1 lb/10 ⁶ Btu	9.20	40.30			62-296.406(3), FAC	III., EU001, 7. & 9.
		Nat. Gas			0.50	2.19				
		Biogas			1.00	1.10				
	SO ₂	No. 6 F.O.	8760		46.33	202.93			62-296.406(3), FAC	III., EU001, 7. & 9.
		Nat. Gas			0.10	0.44				
		Biogas			73.70	37.20				
	NO _x	No. 6 F.O.	8760	0.4 lb/10 ⁶ Btu 0.25 lb/10 ⁶ Btu	36.80	161.18			62-4.070(3), FAC	III., EU001, 8. & 9.
		Nat. Gas			24.30	106.43				
		Biogas			18.40	20.80				
	CO	No. 6 F.O.	8760		3.10	13.58			62-4.070(3), FAC	III., EU001, 8. & 9.
		Nat. Gas			8.02	35.14				
		Biogas			4.90	5.50				
	VOC	No. 6 F.O.	8760		0.20	0.88			62-4.070(3), FAC	III., EU001, 8. & 9.
		Nat. Gas			0.30	1.31				
		Biogas			1.00	1.10				
	VE		8760	20%, 40% 2 min/hr					62-296.406(1), FAC	III., EU001, 10.
002	PM	No. 6 F.O.	8760	0.1 lb/10 ⁶ Btu	9.20	40.30			62-296.406(3), FAC	III., EU002, 7. & 9.
		Nat. Gas			0.50	2.19				
		Biogas			1.00	1.10				
	SO ₂	No. 6 F.O.	8760		46.33	202.93			62-296.406(3), FAC	III., EU002, 7. & 9.
		Nat. Gas			0.10	0.44				
		Biogas			73.70	37.20				
	NO _x	No. 6 F.O.	8760	0.4 lb/10 ⁶ Btu 0.25 lb/10 ⁶ Btu	36.80	161.18			62-4.070(3), FAC	III., EU002, 8. & 9.
		Nat. Gas			24.30	106.43				
		Biogas			18.40	20.80				
	CO	No. 6 F.O.	8760		3.10	13.58			62-4.070(3), FAC	III., EU002, 8. & 9.
		Nat. Gas			8.02	35.14				
		Biogas			4.90	5.50				
	VOC	No. 6 F.O.	8760		0.20	0.88			62-4.070(3), FAC	III., EU002, 8. & 9.
		Nat. Gas			0.30	1.31				
		Biogas			1.00	1.10				
	VE		8760	20%, 40% 2 min/hr					62-296.406(1), FAC	III., EU002, 10.

Table 1-1, Summary of Air Pollutant Standards and Terms

ANHEUSER-BUSCH, INC.
JACKSONVILLE BREWERY

PROPOSED PERMIT NO.: 0310006-009-AV
FACILITY ID NO.: 0310006

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

Note: The "Equivalent Emissions" listed are for informational purposes only.

Eu ID No.	Pollutant Name	Fuel(s)	Hours/Year	Allowable Emissions			Equivalent Emissions*		Regulatory Citation(s)	See permit condition(s)
				Standard(s)	lbs./hour	TPY	lbs./hour	TPY		
003	PM	No. 6 F.O.	8760	0.1 lb/10 ⁶ Btu	9.20	40.30			62-296.406(3), FAC	III., EU002, 7. & 9.
		Nat. Gas			0.50	2.19				
		Biogas			1.00	1.10				
	SO ₂	No. 6 F.O.	8760		46.33	202.93			62-296.406(3), FAC	III., EU002, 7. & 9.
		Nat. Gas			0.10	0.44				
		Biogas			73.70	37.20				
	NO _x	No. 6 F.O.	8760	0.4 lb/10 ⁶ Btu 0.25 lb/10 ⁶ Btu	36.80	161.18			62-4.070(3), FAC	III., EU003, 8. & 9.
		Nat. Gas			24.30	106.43				
		Biogas			18.40	20.80				
	CO	No. 6 F.O.	8760		3.10	13.58			62-4.070(3), FAC	III., EU003, 8. & 9.
		Nat. Gas			8.02	35.14				
		Biogas			4.90	5.50				
	VOC	No. 6 F.O.	8760		0.20	0.88			62-4.070(3), FAC	III., EU003, 8. & 9.
		Nat. Gas			0.30	1.31				
		Biogas			1.00	1.10				
	VE		8760	20%, 40% 2 min/hr					62-296.406(1), FAC	III., EU003, 10.
004	PM	No. 6 F.O.	8760	0.1 lb/10 ⁶ Btu	9.20	40.30			62-296.406(3), FAC	III., EU004, 7. & 9.
		Nat. Gas			0.50	2.19				
		Biogas			1.00	1.10				
	SO ₂	No. 6 F.O.	8760		46.33	202.93			62-296.406(3), FAC	III., EU004, 7. & 9.
		Nat. Gas			0.10	0.44				
		Biogas			73.70	37.20				
	NO _x	No. 6 F.O.	8760	0.4 lb/10 ⁶ Btu 0.25 lb/10 ⁶ Btu	36.80	161.18			62-4.070(3), FAC	III., EU004, 8. & 9.
		Nat. Gas			24.30	106.43				
		Biogas			18.40	20.80				
	CO	No. 6 F.O.	8760		3.10	13.58			62-4.070(3), FAC	III., EU004, 8. & 9.
		Nat. Gas			8.02	35.14				
		Biogas			4.90	5.50				
	VOC	No. 6 F.O.	8760		0.20	0.88			62-4.070(3), FAC	III., EU004, 8. & 9.
		Nat. Gas			0.30	1.31				
		Biogas			1.00	1.10				
	VE		8760	20%, 40% 2 min/hr					62-296.406(1), FAC	III., EU004, 10.

Table 1-1, Summary of Air Pollutant Standards and Terms

ANHEUSER-BUSCH, INC.
JACKSONVILLE BREWERY

PROPOSED PERMIT NO.: 0310006-009-AV
FACILITY ID NO.: 0310006

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

Note: The "Equivalent Emissions" listed are for informational purposes only.

Eu ID No.	Pollutant Name	Fuel(s)	Hours/Year	Allowable Emissions			Equivalent Emissions*		Regulatory Citation(s)	See permit condition(s)
				Standard(s)	lbs./hour	TPY	lbs./hour	TPY		
009	PM VE		8760	5%		<1			62-296.700(2)(c), FAC 62-297.620(4), FAC	III., EU009, 4. III., EU009, 5.
010	PM VE		8760	5%		<1			62-296.700(2)(c), FAC 62-297.620(4), FAC	III., EU010, 4. III., EU010, 5.
011	PM VE		8760	0.03 gr/dscf 5%	1.72	7.53			62-296.711(2), FAC 62-296.711(2), FAC	III., EU011, 4. III., EU011, 5.
012	PM VE		8760	0.03 gr/dscf 5%	1.72	7.53			62-296.711(2), FAC 62-296.711(2), FAC	III., EU012, 4. III., EU012, 5.
013	PM VE		8760	0.03 gr/dscf 5%	0.67	2.93			62-296.711(2), FAC 62-296.711(2), FAC	III., EU013, 4. III., EU013, 5.
017	PM VE		8760	0.03 gr/dscf 5%	0.59	2.58			62-296.711(2), FAC 62-296.711(2), FAC	III., EU017, 4. III., EU017, 5.
018	PM VE		8760	5%		<1			62-296.700(2)(c), FAC 62-297.620(4), FAC	III., EU018, 4. III., EU018, 5.
025	PM VE		25	5%		<1			62-296.700(2)(c), FAC 62-297.620(4), FAC	III., EU025, 4. III., EU025, 5.
027	NO _x SO ₂ VE		8760	STD=0.0150(14.4/Y)+F 0.015% 5%	75.00	328.50			62-212.400(5), FAC 40 CFR 60.333(a) 62-212.400(5), FAC	III., EU027, 4. & 5. III., EU027, 6. III., EU027, 7.
028	NO _x VE PM CO VOC SO ₂		8760	0.1 lb/10 ⁶ Btu 5%	7.20	20.80			62-212.400(5), FAC 62-212.400(5), FAC 62-212.300(1)(d), FAC 62-212.300(1)(d), FAC 62-212.300(1)(d), FAC 62-212.300(1)(d), FAC	III., EU028, 4. III., EU028, 5. III., EU028, 6. III., EU028, 7. III., EU028, 8. III., EU028, 9.
					0.40 21.70 1.60 28.90	1.10 76.50 3.70 37.20				

Table 1-1, Summary of Air Pollutant Standards and Terms

ANHEUSER-BUSCH, INC.
JACKSONVILLE BREWERY

PROPOSED PERMIT NO.: 0310006-009-AV
FACILITY ID NO.: 0310006

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

Note: The "Equivalent Emissions" listed are for informational purposes only.

Eu ID No.	Pollutant Name	Fuel(s)	Hours/Year	Allowable Emissions			Equivalent Emissions*		Regulatory Citation(s)	See permit condition(s)
				Standard(s)	lbs./hour	TPY	lbs./hour	TPY		
031	VE		8760	No VE					62-4.070(3), FAC	III., EU031, 5.
032	VE		8760	No VE					62-4.070(3), FAC	III., EU032, 5.
033	H ₂ S		8760		0.05	0.40			62-4.070(3), FAC	III., EU033, 2.
034	PM		8760			<1			62-296.700(2)(c), FAC	III., EU034, 4.
	VE			5%					62-297.620(4), FAC	III., EU034, 5.
035	PM		8760	0.03 gr/dscf	0.33	1.44			62-296.711(2), FAC	III., EU035, 4.
	VE			5%					62-296.711(2), FAC	III., EU035, 5.
036	PM		8760			<1			62-296.700(2)(c), FAC	III., EU036, 4.
	VE			5%					62-297.620(4), FAC	III., EU036, 5.

S:/PermitV/TVOP/P/0310006-009sum1-AV