

SJRPP PSD PERMIT  
PSD-FL-010(C)

---

Table 6 – Part A

Emissions Unit	SO <sub>2</sub>	NO <sub>x</sub>	PM	Opacity (%)
Steam Generating Boiler No. 1 (6,144 MMBtu/hr maximum heat input)	4,669 lb/hr 0.76 lb/mmBtu (30-day rolling average)	3,686 lb/hr 0.6 lb/mmBtu	184 lb/hr 0.03 lb/mmBtu	20
Steam Generating Boiler No. 2 (6,144 MMBtu/hr maximum heat input)	4,669 lb/hr 0.76 lb/mmBtu (30-day rolling average)	3,686 lb/hr 0.6 lb/mmBtu	184 lb/hr 0.03 lb/mmBtu	20
Cooling Towers			67 lb/hr (each tower)	N/A