

Table 1-2, Summary of Air Pollutant Standards and Terms

Smurfit-Stone Container Enterprises, Inc.
Jacksonville Mill

Revised Draft Permit No.: 0310067-006-AV
Facility ID No.:0310067

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	Brief Description
022	No.1 Package Steam Boiler
023	No. 2 Package Steam Boiler
026	No. 3 Package Steam Boiler

Pollutant Name	Fuel(s)	Hours/Year	Allowable Emissions			Equivalent Emissions*		Regulatory Citation(s)	See permit condition(s)
			Standard(s)	lbs./hour	TPY	lbs./hour	TPY		
Nitrogen Oxide	Gas	8760	0.2 lb/MMBtu			34.94**	153.1**	40 CFR 60.44b(a)	III.A.5.
Nitrogen Oxide	Fuel Oil	8760	0.2 lb/MMBtu			32.9**	144.1**	41 CFR 60.44b(a)	III.A.5.
Sulfur Dioxide	Fuel Oil	8760	0.05% sulfur, max		25 ***			BACT	III.A.3., A.6.
Visible Emissions	Gas	8760	5% opacity					BACT	III.A.7.
Visible Emissions	Fuel Oil	8760	10% opacity					BACT	III.A.7.

Notes:

* The "Equivalent Emissions" listed are for informational purposes only.

** Per boiler. Total NOx emissions shall not exceed 310 tpy from all three boilers.

*** Total of all three boilers. 41 tpy is permitted under extreme circumstances. Refer to B.6. of permit.

[electronic file name: 03100671.xls]