

Appendix I-1, List of Insignificant Emissions Units and/or Activities.

St. Vincent's Medical Center

DRAFT Permit No.: 0310068-007-AV

Facility ID No.: 0310068

The facilities, emissions units, or pollutant-emitting activities listed in Rule 62-210.300(3)(a), FAC, Categorical Exemptions, are exempt from the permitting requirements of Chapters 62-210 and 62-4, FAC; provided, however, that exempt emissions units shall be subject to any applicable emission limiting standards and the emissions from exempt emissions units or activities shall be considered in determining the potential emissions of the facility containing such emissions units. Emissions units and pollutant-emitting activities exempt from permitting under Rule 62-210.300(3)(a), FAC, shall not be exempt from the permitting requirements of Chapter 62-213, FAC, if they are contained within a Title V source; however, such emissions units and activities shall be considered insignificant for Title V purposes provided they also meet the criteria of Rule 62-213.430(6)(b), FAC. No emissions unit shall be entitled to an exemption from permitting under Rule 62-210.300(3)(a), FAC, if its emissions, in combination with the emissions of other units and activities at the facility, would cause the facility to emit or have the potential to emit any pollutant in such amount as to make the facility a Title V source.

The below listed emissions units and/or activities are considered insignificant pursuant to Rule 62-213.430(6), FAC.

Brief Description of Emissions Units and / or Activities

1. Two Caterpillar D399 Diesel Generators
2. Ethylene Oxide Sterilizer
3. Two Caterpillar 3516B Diesel Reciprocating Engines