

Table 1-1, Summary of Air Pollutant Standards and Terms**ST. VINCENT'S MEDICAL CENTER****DRAFT PERMIT NO.: 0310068-007-AV****FACILITY ID NO.: 0310068**

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

Note: The "Equivalent Emissions" listed are for informational purposes only.

Eu ID No.	Pollutant Name	Fuel(s)	Hours/Year	Allowable Emissions			Equivalent Emissions*		Regulatory Citation(s)	See permit condition(s)
				Standard(s)	lbs./hour	TPY	lbs./hour	TPY		
002	VE		8760	20%, 27% 6 min/hr Opacity					62-296.406(1), FAC	III., EU002, 5.
003	VE		8760	20%, 27% 6 min/hr Opacity					62-296.406(1), FAC	III., EU003, 5.
004	VE		8760	20%, 27% 6 min/hr Opacity					62-296.406(1), FAC	III., EU004, 5.
005	NO _x		8760	STD = 0.0150(14.4/Y) + F 0.015% by Vol. 15% Opacity					40 CFR 60.332(a)(2)	III., EU005, 4.
	SO ₂								40 CFR 60.333(a)	III., EU005, 5.
	VE								62-4.070, FAC	III., EU005, 8.

S:/PermitV/ TVOP/D/0310068-007sum1-AV