Table 1-1, Summary of Air Pollutant Standards and Terms

ST. VINCENT'S MEDICAL CENTER

PROPOSED PERMIT NO.: 0310068-007-AV
FACILITY ID NO.: 0310068

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.
Note: The "Equivalent Emissions" listed are for informational purposes only.

				Allowable Emissions			Equivalent Emissions*			
Eu ID No.	Pollutant Name	Fuel(s)	Hours/Year	Standard(s)	lbs./hour	TPY	lbs./hour	TPY	Regulatory Citation(s)	See permit condition(s)
002	VE		8760	20%, 27% 6 min/hr Opacity					62-296.406(1), FAC	III., EU002, 5.
003	VE		8760	20%, 27% 6 min/hr Opacity					62-296.406(1), FAC	III., EU003, 5.
004	VE		8760	20%, 27% 6 min/hr Opacity					62-296.406(1), FAC	III., EU004, 5.
005	NO_x		8760	STD = 0.0150(14.4/Y) + F					40 CFR 60.332(a)(2)	III., EU005, 4.
	SO_2			0.015% by Vol.					40 CFR 60.333(a)	III., EU005, 5.
	VE			15% Opacity					62-4.070, FAC	III., EU005, 8.