

Table 2-1, Summary of Compliance Requirements

**HESS CORPORATION
JACKSONVILLE FACILITY**

**Revised Draft Permit No.: 0310180-012-AV
Facility ID No.: 0310180**

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

Notes: * The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.

**CMS [=] continuous monitoring system

| EU ID No. | Pollutant Name or Parameter | Fuel(s) | Compliance Method | Testing Time Frequency | Frequency Base Date * | Min. Compliance Test Duration | CMS** | See permit condition(s) |
|-----------|--------------------------------|-----------|----------------------|------------------------------|-----------------------------|-------------------------------------|-------|-------------------------|
| # 003 | Fuel Records | | Record and Maintain | During Storage Period | | | | III, 003 |
| # 005 | TOC | | EPA RM 25A/B | Annually | 12/1/2005 | | | III, 005 |
| | VCS | Pressure | 40 CFR 60.503(d) | During TOC Test | | | | III, 005 |
| | VCS | Leaks | EPA RM 21 | During TOC Test | | | | III, 005 |
| | Tank Truck | Tightness | EPA RM 27 | Annually | | | | III, 005 |
| | VCS | Leaks | Sight/Sound/Smell | Monthly | | | | III, 005 |

VCS=Vapor Collection System

TOC=Total Organic Carbon

0310180-0122-AV.xls