Table 2-1, Summary of Compliance Requirements

JACKSONVILLE FACILITY

Proposed Permit No.: 0310180-018-AV
Facility ID N(HESS CORPORATION

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.
Notes: * The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.
**CMS [=] continuous monitoring system

EU ID No.	Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	CMS**	See permit condition(s)
# 003	Fuel Records		Record and Maintain	During Storage Period				III, 003, 10.
# 005	TOC		EPA RM 25A/B	Annually	12/1/2008			III, 005, 9.
	VCS	Pressure	40 CFR 60.503(d)	During TOC Test				III, 005, 11.
	VCS	Leaks	EPA RM 21	During TOC Test				III, 005, 11.
	Tank Truck	Tightness	EPA RM 27	Annually				III, 005, 11.
	VCS	Leaks	Sight/Sound/Smell	Monthly				III, 005, 11.
#012	Gasoline/Ethanol		Recordkeeping	Monthly				III, 012, 3.
#012	Distillate Fuel Oil		Recordkeeping	Monthly				III, 012, 3.

VCS=Vapor Collection System TOC=Total Organic Carbon

[0310180-018sum2-AV.xls]