Florida Department of
Environmental Protection
Northwest District
160 W. Government Street, Suite 308
Pensacola, Florida 32502-5740

Rick Scott
Governor

Jennifer Carroll
Lt. Governor

Herschel T. Vinyard Jr.
Secretary

August 17, 2012

By Electronic Mail, Received Receipt Requested
carl.gunter@ipaper.com

Mr. Carl Gunter
Mill Manager
International Paper Company
375 Muscogee Road
Cantonment, Florida 32533

Dear Mr. Gunter:

This is in response to your August 8, 2012 letter regarding the initial effective steam ratio test results for No. 2 Condensate Stripper (EU 065) and your request for inclusion of the tested effective steam ratio in proposed permit 0330042-016-AV at the International Paper Facility in Escambia County.

The letter and supporting documentation demonstrate compliance with Section III, Emissions Units and Specific Conditions, Subsection R., No. 2 Condensate Stripper, of proposed permit 00330042-016-AV. The proposed permit, under EPA review, indicates an effective steam ratio of 17% in Specific Condition No. R.4. The testing results indicate compliance at an actual effective steam ratio of 12%. In final permit 0330042-016-AV, the effective steam ratio in Specific Condition R.4 will be changed from 17% to 12%. This change is not considered significant enough to reissue the DRAFT Title V Operation Permit or require another public notice.

No other changes will be made to Subsection R of permit 0330042-016-AV.

If you have any questions, please contact Rick Prusa at 850/595-0634 or e-mail rick.prusa@dep.state.fl.us.

Sincerely,

Rick Bradburn
Air Program Administrator

RB/rp/c

c: Laurie McLain, International Paper: laurie.mclain@ipaper.com