

Bend Unit 1

Sootblowing Emission Results for PM															
Time	4/23/04 12:05	4/23/04 13:31	4/23/04 18:30	6/14/06 12:15	6/14/06 13:43	6/14/06 16:41	5/17/07 7:32	5/17/07 9:25	5/17/07 11:01	5/17/07 7:32	5/17/07 9:25	5/17/07 11:01	2/25/09 13:14		
	4/23/04 13:18	4/23/04 14:39	4/23/04 19:39	6/14/06 13:22	6/14/06 14:53	6/14/06 17:51	5/17/07 8:44	5/17/07 10:35	5/17/07 12:11	5/17/07 8:44	5/17/07 10:35	5/17/07 12:11	2/25/09 14:27		
Run #	Run 1 - S	Run 2 - S	Run 4 - S	Run 1 - S	Run 2 - S	Run 3 - S	Run 1 - S	Run 2 - S	Run 3 - S	Run 1 - S	Run 2 - S	Run 3 - S	Run 1 - S		
Ib/MMBtu	0.020	0.018	0.021	0.020	0.020	0.020	0.020	0.020	0.020	0.040	0.030	0.030	0.023		
Opacity (%)	13	12	13	8	6	6	9	8	8	9	8	8	6		
													Maximum	Average	
													0.040	0.023	
													13	9	

Non-Sootblowing Emission Results for PM															
Time	04/23/2004 9:50	04/23/2004 14:55	04/23/2004 16:12	6/14/06 8:25	6/14/06 10:47	6/14/06 15:18	5/17/07 12:31	5/17/07 14:05	5/17/07 17:14	5/17/07 12:31	5/17/07 14:05	5/17/07 17:14		2/25/09 10:03	2/25/09 11:40
	04/23/2004 10:57	04/23/2004 16:02	04/23/2004 17:33	6/14/06 9:57	6/14/06 11:57	6/14/06 16:28	5/17/07 14:38	5/17/07 15:14	5/17/07 18:21	5/17/07 14:38	5/17/07 15:14	5/17/07 18:21		2/25/09 11:12	2/25/09 12:50
Run #	Run 1	Run 2	Run 3	Run 1	Run 2	Run 3	Run 1	Run 2	Run 3	Run 1	Run 2	Run 3		Run 1	Run 2
Ib/MMBtu	0.024	0.018	0.019	0.020	0.020	0.020	0.010	0.010	0.020	0.040	0.030	0.020		0.025	0.026
Opacity (%)	10	13	13	7	8	6	9	9	9	9	9	9		6	6
													Maximum	Average	
													0.040	0.022	
													13	9	

Bend Unit 2

Sootblowing Emission Results for PM															
Time	9/29/05 12:22	9/29/05 15:15	9/29/05 16:45	12/12/05 12:56	12/12/05 14:21	12/12/05 15:50	10/26/06 9:44	10/26/06 12:58	10/26/06 16:10	4/2/08 9:07	4/2/08 12:18	4/2/08 15:21	4/20/09 14:00		
	9/29/05 13:25	9/29/05 16:23	9/29/05 17:54	12/12/05 14:04	12/12/05 15:30	12/12/05 16:58	10/26/06 10:54	10/26/06 14:04	10/26/06 17:15	4/2/08 10:20	4/2/08 13:28	4/2/08 16:27	4/20/09 15:06		
Run #	Run 1 - S	Run 2 - S	Run 3 - S	Run 1 - S	Run 2 - S	Run 3 - S	Run 1 - S	Run 2 - S	Run 3 - S	Run 1 - S	Run 2 - S	Run 3 - S	Run 3 - S		
Ib/MMBtu	0.020	0.030	0.030	0.030	0.020	0.020	0.017	0.038	0.028	0.030	0.030	0.030	0.030		
Opacity (%)	5	6	6	1	1	1	9	7	4	11	8	9	4		
													Maximum	Average	
													0.038	0.027	
													11	6	

Non-Sootblowing Emission Results for PM															
Time	9/29/05 7:40	9/29/05 10:59	9/29/05 13:49	12/12/05 11:22	12/12/05 17:17	12/12/05 18:38	10/26/06 8:15	10/26/06 11:17	10/26/06 14:41	4/2/08 7:40	4/2/08 10:53	4/2/08 13:48		4/20/09 15:40	4/20/09 17:10
	9/29/05 8:58	9/29/05 12:07	9/29/05 14:56	12/12/05 12:32	12/12/05 18:23	12/12/05 19:43	10/26/06 9:26	10/26/06 12:22	10/26/06 15:51	4/2/08 8:49	4/2/08 12:01	4/2/08 14:59		4/20/09 16:45	4/20/09 18:17
Run #	Run 1	Run 2	Run 3	Run 1	Run 2	Run 3	Run 1	Run 2	Run 3	Run 1	Run 2	Run 3		Run 1	Run 2
Ib/MMBtu	0.01	0.01	0.01	0.020	0.020	0.020	0.018	0.017	0.018	0.030	0.030	0.040		0.030	0.020
Opacity (%)	5	6	6	6	1	2	8	7	3	14	9	8		4	5
													Maximum	Average	
													0.040	0.021	
													14	6	

Bend Unit 3

Sootblowing Emission Results for PM															
Time	4/5/04 10:12	4/5/04 12:00	4/5/04 13:30	3/8/06 11:57	3/8/06 14:54	3/8/06 17:37	4/5/07 9:15	4/5/07 12:46	4/5/07 15:42	8/27/08 6:42	8/27/08 12:04	8/27/08 13:38	6/3/09 9:52		
	4/5/04 11:24	4/5/04 13:08	4/5/04 14:37	3/8/06 13:10	3/8/06 16:02	3/8/06 18:43	4/6/07 10:36	4/6/07 13:57	4/6/07 16:54	8/28/08 7:58	8/28/08 13:14	8/28/08 14:47	6/3/09 11:03		
Run #	Run 1 - S	Run 2 - S	Run 3 - S	Run 1 - S	Run 2 - S	Run 3 - S	Run 1 - S	Run 2 - S	Run 3 - S	Run 1 - S	Run 2 - S	Run 3 - S	Run 1 - S		
Ib/MMBtu	0.012	0.018	0.014	0.020	0.010	0.010	0.020	0.020	0.020	0.016	0.019	0.018	0.020		
Opacity (%)	7	7	8	4	4	4	4	3	3	12	11	11	7		
													Maximum	Average	
													0.020	0.017	
													12	7	

Non-Sootblowing Emission Results for PM															
Time	4/5/04 14:54	4/5/04 16:36	4/5/04 18:10	3/8/06 13:27	3/8/06 16:14	3/8/06 18:55	4/5/07 11:07	4/5/07 14:14	4/5/07 17:22	8/27/08 8:54	8/27/08 10:05	8/27/08 15:08		6/3/09 11:34	6/3/09 13:49
	4/5/04 16:08	4/5/04 17:47	4/5/04 19:18	3/8/06 14:36	3/8/06 17:20	3/8/06 20:00	4/6/07 12:17	4/6/07 15:23	4/6/07 18:25	8/28/08 9:45	8/28/08 11:15	8/28/08 16:20		6/3/09 12:48	6/3/09 14:58
Run #	Run 1	Run 2	Run 3	Run 1	Run 2	Run 3	Run 1	Run 2	Run 3	Run 1	Run 2	Run 3		Run 2	Run 3
Ib/MMBtu	0.0165	0.0169	0.0143	0.010	0.020	0.020	0.020	0.010	0.030	0.014	0.007	0.020		0.010	0.010
Opacity (%)	9	9	10	5	4	4	3	3	3	11	11	10		6	6
													Maximum	Average	
													0.030	0.016	
													11	7	

Bend Unit 4

Sootblowing Emission Results for PM															
Time			11/17/04 13:24		4/25/06 11:54			9/11/07 12:27				4/16/08 10:49		5/21/09 10:54	
			11/17/04 14:23		4/25/06 9:44			9/11/07 14:39				4/16/08 13:01		5/21/09 13:04	
Run #			Run 3 - S		Run 2 - S			Run 2 - S				Run 2 - S		Run 2 - S	
Ib/MMBtu			0.006		0.010			0.008				0.005		0.010	
Opacity (%)			5		4			4				7		3	
													Maximum	Average	
													0.010	0.008	
													7	5	

Non-Sootblowing Emission Results for PM															
Time	11/17/04 8:00	11/17/04 10:53		4/25/06 7:08		4/25/06 12:14	9/11/07 9:45		9/11/07 16:11	4/16/08 7:55		4/16/08 13:27	5/21/09 8:00		5/21/09 13:33
	11/17/04 10:11	11/17/04 13:02		4/25/06 9:18		4/25/06 14:23	9/11/07 11:56		9/11/07 17:26	4/16/08 10:05		4/16/08 15:37	5/21/09 10:20		5/21/09 15:43
Run #	Run 1	Run 2		Run 1		Run 3	Run 1		Run 3	Run 1		Run 3	Run 1		Run 3
Ib/MMBtu	0.003	0.011		0.01		0.010	0.009		0.008	0.007		0.005	0.010		0.010
Opacity (%)	5	5		4		4	4		3	6		7	3		2
													Maximum	Average	
													0.011	0.008	
													7	4	